

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

City of Josephine (CN600670178) proposes to operate a proposed wastewater treatment plant #3 (RN to be assigned by TCEQ). a sequence batch reactor plant. The facility will be located at 601 Caddo Street, in Royse City, Collin County, Texas 75189.

This application is to discharge at an annual average of 750,000 gallons per day of treated domestic wastewater via outfall 001.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli*. domestic wastewater will be treated by a sequence batch reactor process plant and the treatment units include a bar screen, fine screens, grit removal, aeration basins, post EQ basin, digester basin, UV disinfection and a sludge screw press.

