

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

Coupland Water Supply Corporation (CN600642789 ) operates Coupland WWTP RN101917532. a wastewater treatment facility. The facility is located approximately 500 ft east of the intersection of Union Pacific Railroad and FM 1466, and 180' north of FM 1466, in Coupland, Williamson County, Texas 78615.

Coupland Water Supply Corporation requests the renewal of permit WQ00-14499-001 to discharge 25,000 gallons per day of treated domestic wastewater.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), ammonia nitrogen (NH<sub>3</sub>-N), and *Escherichia coli*. Domestic wastewater is treated by an activated sludge process plant and the treatment units will include an aeration basin, clarifier, sludge digester, and chlorine contact basin.

### PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS