

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

East Williamson County Municipal Utility District 1 (CN605705201) proposes to operate East Williamson County MUD 1 Wastewater Treatment Plant. a complete mix activated sludge wastewater treatment plant. The facility will be located east of the San Gabriel River directly north of where East State Highway crosses over San Gabriel River, in Georgetown, Williamson County, Texas 78626.

The new application is for the discharge of process wastewater at a daily average flow of Interim I Phase: 0.200 MGD, Phase II: 0.400 MGD, and Final Phase: 0.600 MGD.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and Escherichia coli. Domestic wastewater will be treated by complete mix activated sludge process plant and the treatment units include a manual bar screen, aeration basins, clarifiers, sludge digesters, and chlorine disinfection basins.

