

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

## **ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS**

### **DOMESTIC WASTEWATER**

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

UA Holdings 1994-5, L.P. (CN602477697 ) operates the Bayou Club Wastewater Treatment Facility RN101514131. a domestic wastewater treatment facility. The facility is located at 8550 Memorial Drive, in Houston, Harris County, Texas 77024.

Request for renewal of permit authorizing the discharge of 5,000 GPD of treated domestic wastewater.

Discharges from the facility are expected to contain CBOD(5), Total Suspended Solids, Ammonia Nitrogen and E. coli. Domestic wastewater is treated by **Activated sludge wastewater treatment plant operated in the extended aeration mode. The treatment units include: aeration basin, clarifier, chlorine contact chamber, lift pumps and a digester.**

## **PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS TPDES o TLAP**