

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Crystal Springs Water Co., Inc. (CN600633655) proposes to operate the Faulkner Landing Wastewater Treatment Facility (RN New). a conventional activated sludge with nitrification process plant. The facility will be located approximately 3200 feet south of the intersection of Old Highway 105 and Faulkner Road, in Cleveland, Montgomery County, Texas 77327.

This application is for a renewal to discharge at a daily average flow of 200,000 gallons per day of treated domestic wastewater.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7 (Pollutant Analysis of Treated Effluent) in the permit application package. The domestic wastewater from the Liberty Estates Wastewater Treatment Facility is treated by a conventional activated sludge with nitrification process plant and the treatment units include a bar screen, a selector basins, aeration basins, final clarifiers, sludge digesters and chlorine contact basins.

SPANISH TRANSLATION:

Crystal Springs Water Co., Inc. (CN600633655) propone operar la instalación de tratamiento de aguas residuales de Faulkner Landing (RN New). una planta convencional de lodos activados con proceso de nitrificación. La instalación se ubicada en aproximadamente 3200 pies al sur de la intersección de Antigua Carretera 105 y Camino Faulkner, en Cleveland, Condado de Montgomery, Texas 77327.

Esta solicitud es para una nueva aplicación para descargar a un flujo promedio diario de 200,000 galones por día de aguas residuales domésticas tratadas.

Se espera que las descargas de la instalación contengan demanda bioquímica de oxígeno carbónico (CBOD₅) de cinco días, sólidos suspendidos totales (TSS), nitrógeno amoniacal (NH₃-N) y *Escherichia coli*. Los contaminantes potenciales adicionales se incluyen en el Informe Técnico Doméstico 1.0, Sección 7 (Análisis de Contaminantes de Efluentes Tratados) en el paquete de solicitud de permiso. las unidades de tratamiento incluyen una pantalla de barras, un tanque selector, tanques de aireación, un clarificador final, un digester de lodos y un tanque de contacto de cloro.