

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### **ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS**

#### **DOMESTIC WASTEWATER**

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

Royal Valley Utilities, Inc. (CN 600653244 ) operates the Kingdom Heights Wastewater Treatment Plant (RN 104621990). an activated sludge with nitrification facility. The facility is located at 5703-1/2 Kingdom heights Boulevard, in Rosenberg, Fort Bend County, Texas 77471.

This application is for a renewal application to discharge at a daily average flow not to exceed 270,000 gallons per day.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), total suspended solids (TSS), ammonia nitrogen (NH<sub>3</sub>-N), and *Escherichia coli*. Additional potential pollutants are included in the Domestic Technical Report 1.0, Section 7. Pollutant Analysis of Treated Effluent in the permit application package. Domestic wastewater is treated by a conventional activated sludge process plant and the treatment units will include a bar screen, anoxic zones, aeration basins, final clarifiers, sludge digesters and chlorine contact chambers.