

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### **ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS**

#### **DOMESTIC WASTEWATER**

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

S7 Partnership GP, Inc. proposes to operate S7 Wastewater Treatment Plant a wastewater treatment plant. The facility will be located approximately 0.9 miles east of the intersection of FM 970 and CR 251, in Florence, Williamson County, Texas 76527.

This is a new application to discharge 0.95 MGD of treated domestic wastewater.

Discharges from the facility are expected to contain 5 mg/L BOD<sub>5</sub>, 5 mg/L TSS, 2.0 mg/L NH<sub>3</sub>-N, 1 mg/L P, and 126 CFU/100 mL E.coli in the final phase. Domestic wastewater will be treated by a *headworks screen unit, an activated sludge treatment plant with anaerobic and aerobic basins, tertiary filtration with either MBR modules or other filtration units, and chlorine disinfection.*

### **PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS TPDES o TLAP**