

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Bluff Dale ISD (CN600654560) proposes to operate Bluff Dale WWTP RN101211472. an extended aeration activated sludge TPDES facility. The facility will be located approximately 890 feet southwest of the intersection of US Hwy 377 and FM 2481, in Bluff Dale, Erath County, Texas 76433.

This application is for a new TPDES permit to discharge at a daily average flow of 10,000 gallons per day of treated domestic wastewater.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), and Escherichia Coli. Additional pollutants are included in the Domestic Technical Report 1.0 in the permit application package.. Domestic treated wastewater will be treated by *an extended aeration activated sludge process plant and is treated by a bar screen, aeration basin, final clarifier, a chlorine contact chamber, and a sludge digester.*