

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Brazoria County Fresh Water Supply District No. 1 (CN600665475) operates the Brazoria County Fresh Water Supply District No. 1 Wastewater Treatment Plant RN102335460. a domestic wastewater treatment facility. The facility is located on the east side of State Highway 36, approximately 1,100 feet southeast of the intersection of Farm-to-Market road 1462 and State Highway 36, , in Damon, Brazoria County, Texas 77430.

Request for renewal of permit authorizing the discharge of 140,000 GPD of treated domestic wastewater.

Discharges from the facility are expected to contain BOD(5), Total Suspended Solids and E. coli. Domestic wastewater is treated by **activated sludge plant operated in the extended aeration mode.**

Treatment units include: aeration basin, clarifier, reaeration chamber, digester, sludge drying beds and chlorine contact chamber.

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS TPDES o TLAP