

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Gulf Coast Authority (CN600126163) operates Blackhawk Regional Wastewater Treatment Facility RN102183340. a regional domestic Publicly Owned Treatment Works. The facility is located at 3902 W Bay Area Boulevard, in Friendswood, Harris County, Texas 77546.

This application is for the renewal of the existing permit to discharge an annual average of 9,250,000 gallons per day of treated domestic wastewater via Outfall 001.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand, total suspended solids, ammonia nitrogen, enterococci, and pH. Additional potential pollutants are included in the Domestic Wastewater Application Technical Report 1.0, Section 7 and Worksheet 4.0. Domestic wastewater is treated by activated sludge with an extended aeration process and an ultra violet light system for disinfection.