

## Section 15. Plain Language Summary (Instructions Page 40)

This information is required for new, major amendment, and renewal applications. It is not required for minor amendment or minor modification applications.

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

Pine Quest Ltd. (2. Enter Customer Number here (i.e., CN6#####).) proposes to operate Forest Lakes 5. Enter Regulated Entity Number here (i.e., RN1#####). a Domestic Wastewater Treatment Plant. The facility will be located approximately 0.75 miles southwest of the intersection of County Road 331 and County Road 3310 towards Whitmire Lane, in Cleveland, Liberty County, Texas 77327.

Authorize the discharge of treated wastewater at a volume not to exceed daily average flow of 400,000 gallons per day

Discharges from the facility are expected to contain 14. List all expected pollutants here. Domestic Wastewater will be treated by an activated sludge process plant and treatment units will include a bar screen, a grit chamber, aeration basins final clarifiers, sludge digesters, a belt filter press, chlorine contact chambers and a dichlorination chamber.

RECEIVED

JAN 17 2023

Water Quality Applications Team