

## Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

### ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

#### DOMESTIC WASTEWATER

*The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.*

Lake Houston Pines Apartments, LLC (CN N/A) operates Lake Houston Pines Wastewater Treatment Facility RN102916814, an apartment complex. The facility is located at 5830 South Lake Houston Parkway approximately 1.5 miles south/southeast of intersection of Farm-to-Market Road 526 and U.S. Highway 90 and approximately 10.5 miles northeast of the Harris County courthouse in downtown Houston in Harris County, Texas, in Houston, Harris County, Texas 77049.

Permit Renewal to discharge 120,000 gallons per day of treated domestic wastewater.

Discharges from the facility are expected to contain carbonaceous biochemical oxygen demand, total suspended solids, ammonia nitrogen. Domestic wastewater is treated by Complete Mix, Activated Sludge System: Influent Line; Aeration Basin; Final Clarifier; Aerobic Digester; Chlorine Contact; and out fall pipe.



### PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS TPDES o TLAP