

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

OP III ATX Georgetown 220, L.P. (2. Enter Customer Number here (i.e., CN6#####).) proposes to operate OP III ATX Georgetown Wastewater Treatment Plant (WWTP), an activated sludge wastewater treatment plant. The facility will be located approximately 0.95 miles northeast of the intersection of County Road 110 and County Road 107, in 10. Enter city name here., Williamson County, Texas 78626.

The application is for a new TPDES permit to authorize the discharge of treated domestic wastewater at a daily average flow not to exceed 0.06 MGD in Phase 1, 0.12 MGD in Phase 2, 0.27 MGD in Phase 3, and 0.99 MGD in Phase 4.

Discharges from the facility are expected to contain Biochemical Oxygen demand (cBOD₅), Total Suspended Solids (TSS), Ammonia Nitrogen (NH₃-N), and E. Coli. Domestic wastewater will be treated by a manual bar screen, aeration basin(s), clarifier(s), chlorine contact basin(s), and aerobic digester(s).