

EXECUTIVE SUMMARY - ENFORCEMENT MATTER

DOCKET NO.: 2010-0059-MWD-E **TCEQ ID:** RN101390995 **CASE NO.:** 38975

RESPONDENT NAME: Fort Bend County Municipal Utility District No. 124

ORDER TYPE:		
<input type="checkbox"/> 1660 AGREED ORDER	<input checked="" type="checkbox"/> FINDINGS AGREED ORDER	<input type="checkbox"/> FINDINGS ORDER FOLLOWING SOAH HEARING
<input type="checkbox"/> FINDINGS DEFAULT ORDER	<input type="checkbox"/> SHUTDOWN ORDER	<input type="checkbox"/> IMMINENT AND SUBSTANTIAL ENDANGERMENT ORDER
<input type="checkbox"/> AMENDED ORDER	<input type="checkbox"/> EMERGENCY ORDER	
CASE TYPE:		
<input type="checkbox"/> AIR	<input type="checkbox"/> MULTI-MEDIA (check all that apply)	<input type="checkbox"/> INDUSTRIAL AND HAZARDOUS WASTE
<input type="checkbox"/> PUBLIC WATER SUPPLY	<input type="checkbox"/> PETROLEUM STORAGE TANKS	<input type="checkbox"/> OCCUPATIONAL CERTIFICATION
<input checked="" type="checkbox"/> WATER QUALITY	<input type="checkbox"/> SEWAGE SLUDGE	<input type="checkbox"/> UNDERGROUND INJECTION CONTROL
<input type="checkbox"/> MUNICIPAL SOLID WASTE	<input type="checkbox"/> RADIOACTIVE WASTE	<input type="checkbox"/> DRY CLEANER REGISTRATION
<p>SITE WHERE VIOLATION(S) OCCURRED: Fort Bend County MUD 124, located approximately 16,000 feet southeast of the intersection of Interstate Highway 10 and Buffalo Bayou, Fort Bend County</p> <p>TYPE OF OPERATION: Wastewater treatment facility</p> <p>SMALL BUSINESS: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>OTHER SIGNIFICANT MATTERS: There are no complaints. There is no record of additional pending enforcement actions regarding this facility location.</p> <p>INTERESTED PARTIES: No one other than the ED and the Respondent has expressed an interest in this matter.</p> <p>COMMENTS RECEIVED: The <i>Texas Register</i> comment period expired on June 28, 2010. No comments were received.</p> <p>CONTACTS AND MAILING LIST: TCEQ Attorney/SEP Coordinator: None TCEQ Enforcement Coordinator: Ms. Lanae Foard, Enforcement Division, Enforcement Team 1, MC 169, (512) 239-2554; Ms. Laurie Eaves, Enforcement Division, MC 219, (512) 239-4495 Respondent: Mr. Chris Colihan, President, Board of Directors, Fort Bend County Municipal Utility District No. 124, 3200 Southwest Freeway, Suite 2600, Houston, Texas 77027 Respondent's Attorney: Not represented by counsel on this enforcement matter</p>		

VIOLATION SUMMARY CHART:		
VIOLATION INFORMATION	PENALTY CONSIDERATIONS	CORRECTIVE ACTIONS TAKEN/REQUIRED
<p>Type of Investigation: <input type="checkbox"/> Complaint <input type="checkbox"/> Routine <input type="checkbox"/> Enforcement Follow-up <input checked="" type="checkbox"/> Records Review</p> <p>Date(s) of Complaints Relating to this Case: None</p> <p>Date of Investigation Relating to this Case: September 1, 2009</p> <p>Date of NOV/NOE Relating to this Case: December 23, 2009 (NOE)</p> <p>Background Facts: This was a record review.</p> <p>WATER</p> <p>Failure to comply with permitted effluent limits for ammonia nitrogen and total suspended solids [TEX. WATER CODE § 26.121(a)(1), 30 TEX. ADMIN. CODE § 305.125(1), and Texas Pollutant Discharge Elimination System ("TPDES") Permit No. 14134001, Interim Phase Effluent Limitations and Monitoring Requirements No. 1].</p>	<p>Total Assessed: \$6,960</p> <p>Total Deferred: \$0 <input type="checkbox"/> Expedited Settlement <input type="checkbox"/> Financial Inability to Pay</p> <p>SEP Conditional Offset: \$0</p> <p>Total Paid to General Revenue: \$6,960</p> <p>Site Compliance History Classification <input type="checkbox"/> High <input checked="" type="checkbox"/> Average <input type="checkbox"/> Poor</p> <p>Person Compliance History Classification <input type="checkbox"/> High <input checked="" type="checkbox"/> Average <input type="checkbox"/> Poor</p> <p>Major Source: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Applicable Penalty Policy: September 2002</p> <p>Findings Orders Justification: The Respondent has three repeated enforcement actions over the prior five year period for the same violation.</p>	<p>Ordering Provisions:</p> <p>The Order will require the Respondent to, within 90 days after the effective date of this Agreed Order, submit written certification of compliance with the effluent limits of TPDES Permit No. 14134001, including specific corrective actions that were implemented at the Facility to achieve compliance and copies of the most current self reported discharge monitoring reports demonstrating at least three consecutive months of compliance with all permitted effluent limitations. The certification shall include detailed supporting documentation to demonstrate compliance.</p>

Additional ID No(s): WQ0014134001



Penalty Calculation Worksheet (PCW)

Policy Revision 2 (September 2002)

PCW Revision October 30, 2008

TCEQ

DATES	Assigned	28-Dec-2009	Screening	11-Jan-2010	EPA Due	
	PCW	12-Jan-2010				

RESPONDENT/FACILITY INFORMATION	
Respondent	Fort Bend County Municipal Utility District No. 124
Reg. Ent. Ref. No.	RN101390995
Facility/Site Region	12-Houston
Major/Minor Source	Minor

CASE INFORMATION		No. of Violations	1
Enf./Case ID No.	38975	Order Type	Findings
Docket No.	2010-0059-MWD-E	Government/Non-Profit	Yes
Media Program(s)	Water Quality	Enf. Coordinator	Lanae Foard
Multi-Media		EC's Team	Enforcement Team 1
Admin. Penalty \$ Limit Minimum	\$0	Maximum	\$10,000

Penalty Calculation Section

TOTAL BASE PENALTY (Sum of violation base penalties)	Subtotal 1	\$3,000
---	-------------------	---------

ADJUSTMENTS (+/-) TO SUBTOTAL 1

Subtotals 2-7 are obtained by multiplying the Total Base Penalty (Subtotal 1) by the indicated percentage.

Compliance History	132.0% Enhancement	Subtotals 2, 3, & 7	\$3,960
---------------------------	--------------------	--------------------------------	---------

Notes: Enhancement recommended due to 20 self-reported monthly effluent violations, two NOV's for violations similar to those cited in this order, one unrelated NOV, and one final agreed order with denial of liability.

Culpability	No	0.0% Enhancement	Subtotal 4	\$0
--------------------	----	------------------	-------------------	-----

Notes: The Respondent does not meet the culpability criteria.

Good Faith Effort to Comply Total Adjustments	Subtotal 5	\$0
--	-------------------	-----

Economic Benefit	0.0% Enhancement*	Subtotal 6	\$0
-------------------------	-------------------	-------------------	-----

Total EB Amounts: \$1,066
 Approx. Cost of Compliance: \$7,500
 *Capped at the Total EB \$ Amount

SUM OF SUBTOTALS 1-7	Final Subtotal	\$6,960
-----------------------------	-----------------------	---------

OTHER FACTORS AS JUSTICE MAY REQUIRE	0.0%	Adjustment	\$0
---	------	-------------------	-----

Reduces or enhances the Final Subtotal by the indicated percentage.

Notes:

Final Penalty Amount	\$6,960
-----------------------------	---------

STATUTORY LIMIT ADJUSTMENT	Final Assessed Penalty	\$6,960
-----------------------------------	-------------------------------	---------

DEFERRAL	0.0% Reduction	Adjustment	\$0
-----------------	----------------	-------------------	-----

Reduces the Final Assessed Penalty by the indicated percentage. (Enter number only; e.g. 20 for 20% reduction.)

Notes:

No deferral is recommended for Findings Orders.

PAYABLE PENALTY	\$6,960
------------------------	---------

Screening Date 11-Jan-2010

Docket No. 2010-0059-MWD-E

PCW

Respondent Fort Bend County Municipal Utility District No. 124

Policy Revision 2 (September 2002)

Case ID No. 38975

PCW Revision October 30, 2008

Reg. Ent. Reference No. RN101390995

Media [Statute] Water Quality

Enf. Coordinator Lanae Foard

Compliance History Worksheet

>> Compliance History Site Enhancement (Subtotal 2)

Component	Number of...	Enter Number Here	Adjust.
NOVs	Written NOVs with same or similar violations as those in the current enforcement action (number of NOVs meeting criteria)	22	110%
	Other written NOVs	1	2%
Orders	Any agreed final enforcement orders containing a denial of liability (number of orders meeting criteria)	1	20%
	Any adjudicated final enforcement orders, agreed final enforcement orders without a denial of liability, or default orders of this state or the federal government, or any final prohibitory emergency orders issued by the commission	0	0%
Judgments and Consent Decrees	Any non-adjudicated final court judgments or consent decrees containing a denial of liability of this state or the federal government (number of judgements or consent decrees meeting criteria)	0	0%
	Any adjudicated final court judgments and default judgments, or non-adjudicated final court judgments or consent decrees without a denial of liability, of this state or the federal government	0	0%
Convictions	Any criminal convictions of this state or the federal government (number of counts)	0	0%
Emissions	Chronic excessive emissions events (number of events)	0	0%
Audits	Letters notifying the executive director of an intended audit conducted under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (number of audits for which notices were submitted)	0	0%
	Disclosures of violations under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (number of audits for which violations were disclosed)	0	0%

Please Enter Yes or No

Other	Environmental management systems in place for one year or more	No	0%
	Voluntary on-site compliance assessments conducted by the executive director under a special assistance program	No	0%
	Participation in a voluntary pollution reduction program	No	0%
	Early compliance with, or offer of a product that meets future state or federal government environmental requirements	No	0%

Adjustment Percentage (Subtotal 2) 132%

>> Repeat Violator (Subtotal 3)

No

Adjustment Percentage (Subtotal 3) 0%

>> Compliance History Person Classification (Subtotal 7)

Average Performer

Adjustment Percentage (Subtotal 7) 0%

>> Compliance History Summary

Compliance History Notes

Enhancement recommended due to 20 self-reported monthly effluent violations, two NOVs for violations similar to those cited in this order, one unrelated NOV, and one final agreed order with denial of liability.

Total Adjustment Percentage (Subtotals 2, 3, & 7) 132%

Screening Date 11-Jan-2010

Docket No. 2010-0059-MWD-E

PCW

Respondent Fort Bend County Municipal Utility District No. 124

Policy Revision 2 (September 2002)

Case ID No. 38973

PCW Revision October 30, 2008

Reg. Ent. Reference No. RN101390995

Media [Statute] Water Quality

Enf. Coordinator Lanae Foard

Violation Number 1

Rule Cite(s) Tex. Water Code § 26.121(a)(1), 30 Tex. Admin. Code § 305.126(1), and Texas Pollutant Discharge Elimination System Permit No. 14134001, Interim Phase Effluent Limitations and Monitoring Requirements No. 1

Violation Description Failed to comply with permitted effluent limits, as documented during a record review conducted on September 1, 2009 and as shown in the attached violation table.

Base Penalty \$10,000

>> Environmental, Property and Human Health Matrix

Release	Harm			Percent
	Major	Moderate	Minor	
Actual			X	10%
Potential				

>> Programmatic Matrix

Falsification	Major	Moderate	Minor	Percent
				0%

Matrix Notes

A simplified model was used to evaluate ammonia nitrogen to determine whether the discharged amounts of pollutants exceeded protective levels. Total suspended solids were also considered. As a result of these discharges, human health or the environment has been exposed to insignificant amounts of pollutants which do not exceed protective levels.

Adjustment \$9,000

\$1,000

Violation Events

Number of Violation Events 3 152 Number of violation days

daily	
weekly	
monthly	
quarterly	X
semiannual	
annual	
single event	

mark only one with an x

Violation Base Penalty \$3,000

Three quarterly events are recommended.

Good Faith Efforts to Comply

0.0% Reduction \$0

Before NOV NOV to EDRP/Settlement Offer

Extraordinary		
Ordinary		
N/A	X	(mark with x)

Notes

The Respondent does not meet the good faith criteria for this violation.

Violation Subtotal \$3,000

Economic Benefit (EB) for this violation

Statutory Limit Test

Estimated EB Amount \$1,066

Violation Final Penalty Total \$6,960

This violation Final Assessed Penalty (adjusted for limits) \$6,960

Economic Benefit Worksheet

Respondent Fort Bend County Municipal Utility District No. 124
Case ID No. 38975
Reg. Ent. Reference No. RN101390985
Media Water Quality
Violation No. 1

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
No commas or \$							

Delayed Costs

Equipment				0.00	\$0	\$0	\$0
Buildings				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0
Engineering/construction	\$7,500	31-Jul-2008	11-Aug-2010	2.03	\$51	\$1,015	\$1,066
Land				0.00	\$0	n/a	\$0
Record Keeping System				0.00	\$0	n/a	\$0
Training/Sampling				0.00	\$0	n/a	\$0
Remediation/Disposal				0.00	\$0	n/a	\$0
Permit Costs				0.00	\$0	n/a	\$0
Other (as needed)				0.00	\$0	n/a	\$0

Notes for DELAYED costs

Estimated cost to increase the wall height in the aeration tank to ensure compliance with all permitted effluent limits. Date required is the first date of violation. Final date is the expected date of compliance.

Avoided Costs

ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)

Disposal				0.00	\$0	\$0	\$0
Personnel				0.00	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.00	\$0	\$0	\$0
Supplies/equipment				0.00	\$0	\$0	\$0
Financial Assurance [2]				0.00	\$0	\$0	\$0
ONE-TIME avoided costs [3]				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0

Notes for AVOIDED costs

Approx. Cost of Compliance	\$7,500	TOTAL	\$1,066
----------------------------	---------	--------------	---------

EFFLUENT VIOLATION TABLE
Fort Bend County Municipal Utility District No. 124
TPDES Permit No. 14134001
Docket No. 2010-0059-MWD-E

Permitted Effluent Limits	Monitoring Period End Date				
	7/31/08	10/31/08	12/31/08	1/31/09	2/28/09
NH ₃ -N daily avg. loading Limit = 3.8 lbs/day	c	c	4.50	c	c
NH ₃ -N daily avg. conc. Limit = 2.0 mg/L	c	c	3.59	c	c
TSS daily avg. conc. Limit = 15 mg/L	15.20	19.00	16.20	25.94	24.65
TSS daily avg. loading Limit = 29 lbs/day	c	c	c	32.60	c

NH₃-N = ammonia nitrogen
TSS = total suspended solids
c = compliant
conc. = concentration

mg/L = milligrams per liter
lbs/day = pounds per day
avg. = average

Compliance History Report

Customer/Respondent/Owner-Operator:	CN600736482	Fort Bend County Municipal Utility District No. 124	Classification: AVERAGE	Rating: 10.46
Regulated Entity:	RN101380995	FORT BEND COUNTY MUD 124	Classification: AVERAGE	Site Rating: 10.46
ID Number(s):	WASTEWATER	PERMIT	WQ0014134001	
	WASTEWATER	PERMIT	TPDES0119873	
	WASTEWATER	PERMIT	TX0119873	
Location:	approximately 16,000 feet southeast of the intersection of Interstate Highway 10 and Buffalo Bayou, Fort Bend County, Texas			
TCEQ Region:	REGION 12 - HOUSTON			
Date Compliance History Prepared:	January 07, 2010			
Agency Decision Requiring Compliance History:	Enforcement			
Compliance Period:	January 07, 2005 to January 07, 2010			

TCEQ Staff Member to Contact for Additional Information Regarding this Compliance History

Name: Lanae Foard Phone: 512-239-2554

Site Compliance History Components

1. Has the site been in existence and/or operation for the full five year compliance period? No
2. Has there been a (known) change in ownership/operator of the site during the compliance period? No
3. If Yes, who is the current owner/operator? N/A
4. If Yes, who was/were the prior owner(s)/operator(s) ? N/A
5. When did the change(s) in owner or operator occur? N/A
6. Rating Date: 9/1/2009 Repeat Violator: YES

Components (Multimedia) for the Site :

- A. Final Enforcement Orders, court judgements, and consent decrees of the state of Texas and the federal government.
- | | |
|--|----------------------------|
| Effective Date: 06/26/2008 | ADMINORDER 2006-0101-MWD-E |
| Classification: Moderate | |
| Citation: 2D TWC Chapter 26, SubChapter A 26.121(a) | |
| 30 TAC Chapter 305, SubChapter F 305.125(1) | |
| Rqmt Prov: Effluent Limits PERMIT | |
| Description: Failure to comply with permit effluent limits for ammonia-nitrogen ("NH3-N"). | |

- B. Any criminal convictions of the state of Texas and the federal government.

N/A

- C. Chronic excessive emissions events.

N/A

- D. The approval dates of investigations. (CCEDS Inv. Track. No.)

1	01/24/2005	(390259)
2	02/21/2005	(390256)
3	03/21/2005	(390257)
4	04/22/2005	(427714)
5	05/23/2005	(427715)
6	06/24/2005	(427716)
7	07/25/2005	(427717)
8	08/23/2005	(447764)
9	09/28/2005	(447765)
10	10/24/2005	(492936)
11	11/21/2005	(492937)
12	12/27/2005	(492938)
13	01/11/2006	(437789)
14	01/25/2006	(438228)
15	01/27/2006	(492939)
16	02/23/2006	(492934)
17	03/22/2006	(492935)
18	04/21/2006	(506513)
19	06/16/2006	(506515)
20	06/21/2006	(506514)
21	07/19/2006	(506516)
22	08/22/2006	(528698)
23	09/14/2006	(528699)
24	10/16/2008	(528700)

25	11/15/2006	(632016)
26	12/18/2006	(632018)
27	01/17/2007	(632020)
28	02/15/2007	(632007)
29	03/14/2007	(632008)
30	03/30/2007	(538310)
31	04/16/2007	(632009)
32	05/15/2007	(632010)
33	06/18/2007	(632011)
34	07/13/2007	(632012)
35	08/16/2007	(632013)
36	09/18/2007	(632014)
37	10/17/2007	(632015)
38	11/12/2007	(632017)
39	12/18/2007	(632019)
40	01/18/2008	(632021)
41	02/12/2008	(677445)
42	03/18/2008	(677446)
43	04/17/2008	(677447)
44	05/19/2008	(696187)
45	06/17/2008	(696188)
46	07/16/2008	(696189)
47	08/20/2008	(717834)
48	09/20/2008	(717835)
49	10/20/2008	(717836)
50	11/21/2008	(733153)
51	01/13/2009	(733154)
52	01/20/2009	(733155)
53	02/09/2009	(756310)
54	03/12/2009	(756311)
55	04/06/2009	(756312)
56	05/13/2009	(773277)
57	06/08/2009	(773278)
58	10/06/2009	(767732)
59	12/16/2009	(765162)
60	12/23/2009	(768069)

E. Written notices of violations (NOV). (CCEDS Inv. Track, No.)

Date: 01/31/2005 (390256) CN600736482

Self Report? YES Classification: Moderate

Citation: 30 TAC Chapter 305, SubChapter F 305.125(1)

TWC Chapter 26 26.121(a)

Description: Failure to meet the limit for one or more permit parameter

Date: 05/31/2005 (427716) CN600736482

Self Report? YES Classification: Moderate

Citation: 30 TAC Chapter 305, SubChapter F 305.125(1)

TWC Chapter 26 26.121(a)

Description: Failure to meet the limit for one or more permit parameter

Date: 06/30/2005 (427717) CN600736482

Self Report? YES Classification: Moderate

Citation: 30 TAC Chapter 305, SubChapter F 305.125(1)

TWC Chapter 26 26.121(a)

Description: Failure to meet the limit for one or more permit parameter

Date: 08/31/2005 (447765) CN600736482

Self Report? YES Classification: Moderate

Citation: 30 TAC Chapter 305, SubChapter F 305.125(1)

TWC Chapter 26 26.121(a)

Description: Failure to meet the limit for one or more permit parameter

Date: 09/30/2005 (492936) CN600736482

Self Report? YES Classification: Moderate

Citation: 30 TAC Chapter 305, SubChapter F 305.125(1)

TWC Chapter 26 26.121(a)

Description: Failure to meet the limit for one or more permit parameter

Date: 12/31/2005 (492939) CN600736482

Self Report? YES Classification: Moderate

Citation: 30 TAC Chapter 305, SubChapter F 305.125(1)

TWC Chapter 26 26.121(a)

Description: Failure to meet the limit for one or more permit parameter

Date: 01/25/2006 (438228) CN600736482

Self Report? NO Classification: Moderate

Citation: 30 TAC Chapter 305, SubChapter F 305.125(5)

Description: Failure to properly operate and maintain the clarifiers.

Self Report?	NO		Classification:	Minor
Citation:		30 TAC Chapter 305, SubChapter F 305.125(5) 30 TAC Chapter 317 317.3		
Description:		Failure to properly maintain the on-site lift station pumps.		
Self Report?	NO		Classification:	Major
Citation:		30 TAC Chapter 305, SubChapter F 305.125(4) 30 TAC Chapter 305, SubChapter F 305.125(5) TWC Chapter 26 26.121 TWC Chapter 26 26.121(a) TWC Chapter 26 26.121(a)(1) TWC Chapter 26 26.121(a)(2) TWC Chapter 26 26.121(a)(3) TWC Chapter 26 26.121(b) TWC Chapter 26 26.121(c) TWC Chapter 26 26.121(d) TWC Chapter 26 26.121(e)		
Description:		Failure to prevent the unauthorized discharge of wastewater from the wastewater treatment plant and its collection system.		
Self Report?	NO		Classification:	Minor
Citation:		30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:		Failure to maintain compliance with effluent permit limits.		
Self Report?	NO		Classification:	Minor
Citation:		30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:		Failure to accurately measure flow.		
Self Report?	NO		Classification:	Minor
Citation:		30 TAC Chapter 319, SubChapter A 319.11(d)		
Description:		Failure to adequately measure peak flows.		
Self Report?	NO		Classification:	Major
Citation:		30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:		Failure to maintain compliance with the permit effluent limits for ammonia nitrogen (NH ₃ -N) and total suspended solids (TSS).		
Self Report?	NO		Classification:	Major
Citation:		30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:		Failure to prevent the discharge of foam/scum into the receiving stream.		
Date:	04/30/2006	(506514) CN600736482		
Self Report?	YES		Classification:	Moderate
Citation:		30 TAC Chapter 305, SubChapter F 305.125(1) TWC Chapter 26 26.121(a)		
Description:		Failure to meet the limit for one or more permit parameter		
Date:	06/30/2006	(506516) CN600736482		
Self Report?	YES		Classification:	Moderate
Citation:		30 TAC Chapter 305, SubChapter F 305.125(1) TWC Chapter 26 26.121(a)		
Description:		Failure to meet the limit for one or more permit parameter		
Date:	03/30/2007	(538310) CN600736482		
Self Report?	NO		Classification:	Moderate
Citation:		30 TAC Chapter 305, SubChapter F 305.125(5)		
Description:		Failure to properly operate and maintain the clarifiers.		
Self Report?	NO		Classification:	Major
Citation:		30 TAC Chapter 305, SubChapter F 305.125(4) 30 TAC Chapter 305, SubChapter F 305.125(5) TWC Chapter 26 26.121 TWC Chapter 26 26.121(a) TWC Chapter 26 26.121(a)(1) TWC Chapter 26 26.121(a)(2) TWC Chapter 26 26.121(a)(3) TWC Chapter 26 26.121(b) TWC Chapter 26 26.121(c) TWC Chapter 26 26.121(d) TWC Chapter 26 26.121(e)		
Description:		Failure to prevent the unauthorized discharge of wastewater from the wastewater treatment plant and its collection system.		
Self Report?	NO		Classification:	Minor
Citation:		30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:		Failure to maintain compliance with effluent permit limits.		
Self Report?	NO		Classification:	Minor
Citation:		30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:		Failure to accurately measure flow.		
Self Report?	NO		Classification:	Minor
Citation:		30 TAC Chapter 319, SubChapter A 319.11(d)		
Description:		Failure to adequately measure peak flows.		
Self Report?	NO		Classification:	Major
Citation:		30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:		Failure to maintain compliance with the permit effluent limits for ammonia nitrogen (NH ₃ -N) and total suspended solids (TSS).		
Self Report?	NO		Classification:	Minor

Citation:	30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:	Failure to comply with permitted chlorine residual effluent limits.		
Date:	05/31/2007	(632011)	CN600736482
Self Report?	YES		Classification: Moderate
Citation:	2D TWC Chapter 26, SubChapter A 26.121(a)		
	30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:	Failure to meet the limit for one or more permit parameter		
Date:	09/30/2007	(632015)	CN600736482
Self Report?	YES		Classification: Moderate
Citation:	2D TWC Chapter 26, SubChapter A 26.121(a)		
	30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:	Failure to meet the limit for one or more permit parameter		
Date:	11/30/2007	(632019)	CN600736482
Self Report?	YES		Classification: Moderate
Citation:	2D TWC Chapter 26, SubChapter A 26.121(a)		
	30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:	Failure to meet the limit for one or more permit parameter		
Date:	12/31/2007	(632021)	CN600736482
Self Report?	YES		Classification: Moderate
Citation:	2D TWC Chapter 26, SubChapter A 26.121(a)		
	30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:	Failure to meet the limit for one or more permit parameter		
Date:	07/31/2008	(717834)	CN600736482
Self Report?	YES		Classification: Moderate
Citation:	2D TWC Chapter 26, SubChapter A 26.121(a)		
	30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:	Failure to meet the limit for one or more permit parameter		
Date:	10/31/2008	(733153)	CN600736482
Self Report?	YES		Classification: Moderate
Citation:	2D TWC Chapter 26, SubChapter A 26.121(a)		
	30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:	Failure to meet the limit for one or more permit parameter		
Date:	12/31/2008	(733155)	CN600736482
Self Report?	YES		Classification: Moderate
Citation:	2D TWC Chapter 26, SubChapter A 26.121(a)		
	30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:	Failure to meet the limit for one or more permit parameter		
Date:	01/31/2009	(756310)	CN600736482
Self Report?	YES		Classification: Moderate
Citation:	2D TWC Chapter 26, SubChapter A 26.121(a)		
	30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:	Failure to meet the limit for one or more permit parameter		
Date:	02/28/2009	(756311)	CN600736482
Self Report?	YES		Classification: Moderate
Citation:	2D TWC Chapter 26, SubChapter A 26.121(a)		
	30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:	Failure to meet the limit for one or more permit parameter		
Date:	04/30/2009	(773277)	CN600736482
Self Report?	YES		Classification: Moderate
Citation:	2D TWC Chapter 26, SubChapter A 26.121(a)		
	30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:	Failure to meet the limit for one or more permit parameter		
Date:	05/31/2009	(773278)	CN600736482
Self Report?	YES		Classification: Moderate
Citation:	2D TWC Chapter 26, SubChapter A 26.121(a)		
	30 TAC Chapter 305, SubChapter F 305.125(1)		
Description:	Failure to meet the limit for one or more permit parameter		
Date:	07/02/2009	(701345)	
Self Report?	NO		Classification: Moderate
Citation:	30 TAC Chapter 117, SubChapter D 117.2030(c)		
	5C THSC Chapter 382 382.085(b)		
Description:	Failure to test the emergency generator outside the hours of 6 a.m. and 12 noon. (CATEGORY B19 g(1) violation).		
Self Report?	NO		Classification: Moderate
Citation:	30 TAC Chapter 117, SubChapter D 117.2045(b)		
	5C THSC Chapter 382 382.085(b)		
Description:	Failure to maintain records to document exemption (CATEGORY B3 violation).		
Self Report?	NO		Classification: Moderate
Citation:	30 TAC Chapter 117, SubChapter D 117.2045(c)		
	5C THSC Chapter 382 382.085(b)		
Description:	Failure to maintain records for testing and maintenance. (CATEGORY B3 violation).		
Date:	10/31/2009		CN600736482
Self Report?	YES		Classification: Moderate
Citation:	2D TWC Chapter 26, SubChapter A 26.121(a)		

Description:

Failure to meet the limit for one or more permit parameter

F. Environmental audits.

N/A

G. Type of environmental management systems (EMSs).

N/A

H. Voluntary on-site compliance assessment dates.

N/A

I. Participation in a voluntary pollution reduction program.

N/A

J. Early compliance.

N/A

Sites Outside of Texas

N/A

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



IN THE MATTER OF AN
ENFORCEMENT ACTION
CONCERNING
FORT BEND COUNTY MUNICIPAL
UTILITY DISTRICT NO. 124
RN101390995

§
§
§
§
§
§

BEFORE THE
TEXAS COMMISSION ON
ENVIRONMENTAL QUALITY

AGREED ORDER
DOCKET NO. 2010-0059-MWD-E

At its _____ agenda, the Texas Commission on Environmental Quality ("the Commission" or "TCEQ") considered this agreement of the parties, resolving an enforcement action regarding Fort Bend County Municipal Utility District No. 124 ("the Respondent") under the authority of TEX. WATER CODE chs. 7 and 26. The Executive Director of the TCEQ, through the Enforcement Division, and the Respondent presented this agreement to the Commission.

The Respondent understands that it has certain procedural rights at certain points in the enforcement process, including, but not limited to, the right to formal notice of violations, notice of an evidentiary hearing, the right to an evidentiary hearing, and a right to appeal. By entering into this Agreed Order, the Respondent agrees to waive all notice and procedural rights.

It is further understood and agreed that this Order represents the complete and fully-integrated settlement of the parties. The provisions of this Agreed Order are deemed severable and, if a court of competent jurisdiction or other appropriate authority deems any provision of this Agreed Order unenforceable, the remaining provisions shall be valid and enforceable. The duties and responsibilities imposed by this Agreed Order are binding upon the Respondent.

The Commission makes the following Findings of Fact and Conclusions of Law:

I. FINDINGS OF FACT

1. The Respondent owns and operates a wastewater treatment facility located approximately 16,000 feet southeast of the intersection of Interstate Highway 10 and Buffalo Bayou in Fort Bend County, Texas (the "Facility").

2. The Respondent has discharged municipal waste into or adjacent to any water in the state under TEX. WATER CODE ch. 26.
3. During a record review on September 1, 2009, TCEQ staff documented the following from the self-reported monthly discharge monitoring reports:

EFFLUENT VIOLATION TABLE					
Permitted Effluent Limits	Monitoring Period End Date				
	7/31/08	10/31/08	12/31/08	1/31/09	2/28/09
NH ₃ -N daily avg. loading Limit = 3.8 lbs/day	c	c	4.50	c	c
NH ₃ -N daily avg. conc. Limit = 2.0 mg/L	c	c	3.59	c	c
TSS daily avg. conc. Limit = 15 mg/L	15.20	19.00	16.20	25.94	24.65
TSS daily avg. loading Limit = 29 lbs/day	c	c	c	32.60	c

NH₃-N = ammonia nitrogen
 TSS = total suspended solids
 c = compliant
 conc. = concentration

mg/L = milligrams per liter
 lbs/day = pounds per day
 avg. = average

4. The Respondent received notice of the violations on December 28, 2009.

II. CONCLUSIONS OF LAW

1. The Respondent is subject to the jurisdiction of the TCEQ pursuant to TEX. WATER CODE chs. 7 and 26 and the rules of the Commission.
2. As evidenced by Findings of Fact No. 3, the Respondent failed to comply with permitted effluent limits, in violation of TEX. WATER CODE § 26.121(a)(1), 30 TEX. ADMIN. CODE § 305.125(1), and Texas Pollutant Discharge Elimination System ("TPDES") Permit No. 14134001, Interim Phase Effluent Limitations and Monitoring Requirements No. 1.
3. Pursuant to TEX. WATER CODE § 7.051, the Commission has the authority to assess an administrative penalty against the Respondent for violations of the Texas Water Code and the Texas Health and Safety Code within the Commission's jurisdiction; for violations of rules adopted under such statutes; or for violations of orders or permits issued under such statutes.
4. An administrative penalty in the amount of Six Thousand Nine Hundred Sixty Dollars (\$6,960) is justified by the facts recited in this Agreed Order, and considered in light of the factors set forth

in TEX. WATER CODE § 7.053. The Respondent has paid the Six Thousand Nine Hundred Sixty Dollar (\$6,960) administrative penalty.

III. ORDERING PROVISIONS

NOW, THEREFORE, THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY ORDERS that:

1. The Respondent is assessed an administrative penalty in the amount of Six Thousand Nine Hundred Sixty Dollars (\$6,960) as set forth in Section II, Paragraph 4 above, for violations of TCEQ rules and state statutes. The payment of this administrative penalty and the Respondent's compliance with all the terms and conditions set forth in this Agreed Order completely resolve the violations set forth by this Agreed Order in this action. However, the Commission shall not be constrained in any manner from requiring corrective actions or penalties for other violations that are not raised here. Administrative penalty payments shall be made payable to "TCEQ" and shall be sent with the notation "Re: Fort Bend County Municipal Utility District No. 124, Docket No. 2010-0059-MWD-E" to:

Financial Administration Division, Revenues Section
Attention: Cashier's Office, MC 214
Texas Commission on Environmental Quality
P.O. Box 13088
Austin, Texas 78711-3088

2. It is further ordered that, within 90 days after the effective date of this Agreed Order, the Respondent shall submit written certification of compliance with the effluent limits of TPDES Permit No. 14134001, including specific corrective actions that were implemented at the Facility to achieve compliance and copies of the most current self reported discharge monitoring reports, demonstrating at least three consecutive months of compliance with all permitted effluent limitations. The certification shall include detailed supporting documentation to demonstrate compliance, be notarized by a State of Texas Notary Public and include the following certification language:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

The certification shall be submitted to:

Order Compliance Team
Enforcement Division, MC 149A
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

with a copy to:

Water Section, Manager
Houston Regional Office
Texas Commission on Environmental Quality
5425 Polk Avenue, Suite H
Houston, Texas 77023-1486

3. The provisions of this Agreed Order shall apply to and be binding upon the Respondent. The Respondent is ordered to give notice of the Agreed Order to personnel who maintain day-to-day control over the Facility operations referenced in this Agreed Order.
4. If the Respondent fails to comply with any of the Ordering Provisions in this Agreed Order within the prescribed schedules, and that failure is caused solely by an act of God, war, strike, riot, or other catastrophe, the Respondent's failure to comply is not a violation of this Agreed Order. The Respondent shall have the burden of establishing to the Executive Director's satisfaction that such an event has occurred. The Respondent shall notify the Executive Director within seven days after the Respondent becomes aware of a delaying event and shall take all reasonable measures to mitigate and minimize any delay.
5. The Executive Director may grant an extension of any deadline in this Agreed Order or in any plan, report, or other document submitted pursuant to this Agreed Order, upon a written and substantiated showing of good cause. All requests for extensions by the Respondent shall be made in writing to the Executive Director. Extensions are not effective until the Respondent receives written approval from the Executive Director. The determination of what constitutes good cause rests solely with the Executive Director.
6. The Executive Director may refer this matter to the Office of the Attorney General of the State of Texas ("OAG") for further enforcement proceedings without notice to the Respondent if the Executive Director determines that the Respondent has not complied with one or more of the terms or conditions in this Agreed Order.
7. This Agreed Order shall terminate five years from its effective date or upon compliance with all the terms and conditions set forth in this Agreed Order, whichever is later.
8. This Agreed Order, issued by the Commission, shall not be admissible against the Respondent in a civil proceeding, unless the proceeding is brought by the OAG to: (1) enforce the terms of this Agreed Order; or (2) pursue violations of a statute within the Commission's jurisdiction, or of a rule adopted or an order or permit issued by the Commission under such a statute.

9. This Agreed Order may be executed in multiple counterparts, which together shall constitute a single original instrument. Any executed signature page to this Agreed Order may be transmitted by facsimile transmission to the other parties, which shall constitute an original signature for all purposes under this Agreed Order.
10. The Chief Clerk shall provide a copy of this Agreed Order to each of the parties. By law, the effective date of this Agreed Order is the third day after the mailing date, as provided by 30 TEX. ADMIN. CODE § 70.10(b) and TEX. GOV'T CODE § 2001.142.

SIGNATURE PAGE

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

For the Commission

John Srdian
For the Executive Director

6/10/2010
Date

I, the undersigned, have read and understand the attached Agreed Order in the matter of Fort Bend County Municipal Utility District No. 124. I am authorized to agree to the attached Agreed Order on behalf of Fort Bend County Municipal Utility District No. 124, and do agree to the specified terms and conditions. I further acknowledge that the TCEQ, in accepting payment for the penalty amount, is materially relying on such representation.

I understand that by entering into this Agreed Order, Fort Bend County Municipal Utility District No. 124 waives certain procedural rights, including, but not limited to, the right to formal notice of violations addressed by this Agreed Order, notice of an evidentiary hearing, the right to an evidentiary hearing, and the right to appeal. I agree to the terms of the Agreed Order in lieu of an evidentiary hearing. This Agreed Order constitutes full and final adjudication by the Commission of the violations set forth in this Agreed Order.

I also understand that failure to comply with the Ordering Provisions, if any, in this order and/or failure to timely pay the penalty amount, may result in:

- A negative impact on compliance history;
- Greater scrutiny of any permit applications submitted;
- Referral of this case to the Attorney General's Office for contempt, injunctive relief, additional penalties, and/or attorney fees, or to a collection agency;
- Increased penalties in any future enforcement actions;
- Automatic referral to the Attorney General's Office of any future enforcement actions; and
- TCEQ seeking other relief as authorized by law.

In addition, any falsification of any compliance documents may result in criminal prosecution.

Chris Colihan
Signature

March 25, 2010
Date

Chris Colihan
Name (Printed or typed)
Authorized Representative of
Fort Bend County Municipal Utility District No. 124

President, Board of Directors
Title

Instructions: Send the original, signed Agreed Order with penalty payment to the Financial Administration Division, Revenues Section at the address in Section IV, Paragraph 1 of this Agreed Order.