Executive Summary – Enforcement Matter – Case No. 41443
Anjani C-Store Inc dba Minute Market
RN101888246
Docket No. 2011-0546-PST-E

Order Type:
1660 Agreed Order
Findings Order Justification:
N/A
Media:
PST
Small Business:
Yes
Location(s) Where Violation(s) Occurred:
Minute Market, 1702 North Brazosport Boulevard, Freeport, Brazoria County
Type of Operation:
Convenience store with retail sales of gasoline
Other Significant Matters:
Additional Pending Enforcement Actions: No
Past-Due Penalties: No
Other: N/A
Interested Third-Parties: None
Texas Register Publication Date: August 5, 2011
Comments Received: No

Penalty Information

Total Penalty Assessed: $6,680
Amount Deferred for Expedited Settlement: $1,336
Amount Deferred for Financial Inability to Pay: $0
Total Paid to General Revenue: $164
Total Due to General Revenue: $5,180
Payment Plan: 35 payments of $148 each
SEP Conditional Offset: $0
Name of SEP: N/A
Compliance History Classifications:
Person/CN - Average
Site/RN - Average
Major Source: No
Statutory Limit Adjustment: N/A
Applicable Penalty Policy: September 2002

Executive Summary – Enforcement Matter – Case No. 41443
Anjani C-Store Inc dba Minute Market
RN101888246
Docket No. 2011-0546-PST-E

Investigation Information

Complaint Date(s): N/A
Complaint Information: N/A
Date(s) of Investigation: January 11, 2011
Date(s) of NOE(s): April 1, 2011

Violation Information

1. Failed to monitor the underground storage tanks ("USTs") for releases at a frequency of at least once every month (not to exceed 35 days between each monitoring) [30 TEX. ADMIN. CODE § 334.50(b)(1)(A) and TEX. WATER CODE § 26.3475(c)(1)].

2. Failed to inspect all sumps, manways, overspill containers or catchment basins associated with a UST system at least once every 60 days to assure that their sides, bottoms, and any penetration points are maintained liquid-tight, and free of liquid and debris. Specifically, the spill buckets contained liquid [30 TEX. ADMIN. CODE § 334.42(i)].

3. Failed to maintain UST records and make them immediately available for inspection upon request by agency personnel [30 TEX. ADMIN. CODE §§ 334.10(b)(2) and 334.51(c)(2)].

4. Failed to install an emergency shutoff valve (also known as shear or impact valve) on each pressurized delivery or product line and ensure that it is securely anchored at the base of the dispenser. Specifically, shear valves were not anchored [30 TEX. ADMIN. CODE § 334.45(c)(3)(A)].

5. Failed to meet the technical standards for the underground piping in a UST system. Specifically, the installed riser piping at the Station did not meet technical standards approved for UST system piping material [30 TEX. ADMIN. CODE §§ 334.45(c)(1) and 115.242(2)(A) and (2)(E) and TEX. HEALTH & SAFETY CODE § 382.085(b)].

Corrective Actions/Technical Requirements

Corrective Action(s) Completed:

The Executive Director recognizes that the Respondent securely anchored all shear valves at the base of the dispensers at the Station on January 18, 2011.

Technical Requirements:

The Order will require the Respondent to:

a. Within 30 days:

i. Implement a release detection method for all USTs at the Station;

ii. Clean the spill buckets and begin conducting bi-monthly inspections of all sumps, manways, and overfill containers or catchment basins;

iii. Begin maintaining all UST records;

iv. Install riser piping that meets the technical standards for underground piping associated with a UST system; and

b. Within 45 days, submit written certification demonstrating compliance.

Litigation Information

Date Petition(s) Filed: N/A
Date Answer(s) Filed: N/A
SOAH Referral Date: N/A
Hearing Date(s): N/A
Settlement Date: N/A

Contact Information

TCEQ Attorney: N/A
TCEQ Enforcement Coordinator: Cara Windle, Enforcement Division, Enforcement Team 6, MC 128, (512) 239-2581; Debra Barber, Enforcement Division, MC 219, (512) 239-0412
TCEQ SEP Coordinator: N/A
Respondent: Upendra Bhakta, President, Anjani C-Store Inc, 1702 North Brazosport Boulevard, Freeport, Texas 77541
Respondent's Attorney: N/A

Penalty Calculation Worksheet (PCW)

Policy Revision 2 (September 2002) — *PCW Revision October 30, 2008*

TCEQ

DATES						
Assigned	4-Apr-2011					
PCW	13-Apr-2011	**Screening**	8-Apr-2011	**EPA Due**		

RESPONDENT/FACILITY INFORMATION

Respondent	Anjani C-Store Inc dba Minute Market		
Reg. Ent. Ref. No.	RN101888246		
Facility/Site Region	12-Houston	**Major/Minor Source**	Minor

CASE INFORMATION

Enf./Case ID No.	41443	**No. of Violations**	5
Docket No.	2011-0546-PST-E	**Order Type**	1660
Media Program(s)	Petroleum Storage Tank	**Government/Non-Profit**	No
Multi-Media		**Enf. Coordinator**	Cara Windle
		EC's Team	Enforcement Team 6

Admin. Penalty $ Limit Minimum $0 Maximum $10,000

Penalty Calculation Section

TOTAL BASE PENALTY (Sum of violation base penalties) — *Subtotal 1*: **$6,500**

ADJUSTMENTS (+/-) TO SUBTOTAL 1

Subtotals 2-7 are obtained by multiplying the Total Base Penalty (Subtotal 1) by the indicated percentage.

Compliance History — **5.0%** Enhancement — *Subtotals 2, 3, & 7*: **$325**

Notes: Enhancement for one NOV with same/similar violations.

Culpability — No — **0.0%** Enhancement — *Subtotal 4*: **$0**

Notes: The Respondent does not meet the culpability criteria.

Good Faith Effort to Comply Total Adjustments — *Subtotal 5*: **$250**

Economic Benefit — **0.0%** Enhancement* — *Subtotal 6*: **$0**

Total EB Amounts $260
Approx. Cost of Compliance $3,175

**Capped at the Total EB $ Amount*

SUM OF SUBTOTALS 1-7 — *Final Subtotal*: **$6,575**

OTHER FACTORS AS JUSTICE MAY REQUIRE — **1.6%** — *Adjustment*: **$105**

Reduces or enhances the Final Subtotal by the indicated percentage.

Notes: Recommended enhancement to capture the avoided cost of compliance associated with violation no. 2.

Final Penalty Amount: **$6,680**

STATUTORY LIMIT ADJUSTMENT — *Final Assessed Penalty*: **$6,680**

DEFERRAL — **20.0%** Reduction — *Adjustment*: **-$1,336**

Reduces the Final Assessed Penalty by the indicted percentage. *(Enter number only; e.g. 20 for 20% reduction.)*

Notes: Deferral offered for expedited settlement.

PAYABLE PENALTY: **$5,344**

Screening Date 8-Apr-2011 **Docket No.** 2011-0546-PST-E **PCW**

Respondent Anjani C-Store Inc dba Minute Market

Case ID No. 41443

Reg. Ent. Reference No. RN101888246

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Cara Windle

Policy Revision 2 (September 2002)

PCW Revision October 30, 2008

Compliance History Worksheet

>> Compliance History *Site* Enhancement (Subtotal 2)

Component	Number of...	Enter Number Here	Adjust.
NOVs	Written notices of violation ("NOVs") with same or similar violations as those in the current enforcement action (*number of NOVs meeting criteria*)	1	5%
	Other written NOVs	0	0%
Orders	Any agreed final enforcement orders containing a denial of liability (*number of orders meeting criteria*)	0	0%
	Any adjudicated final enforcement orders, agreed final enforcement orders without a denial of liability, or default orders of this state or the federal government, or any final prohibitory emergency orders issued by the commission	0	0%
Judgments and Consent Decrees	Any non-adjudicated final court judgments or consent decrees containing a denial of liability of this state or the federal government (*number of judgements or consent decrees meeting criteria*)	0	0%
	Any adjudicated final court judgments and default judgments, or non-adjudicated final court judgments or consent decrees without a denial of liability, of this state or the federal government	0	0%
Convictions	Any criminal convictions of this state or the federal government (*number of counts*)	0	0%
Emissions	Chronic excessive emissions events (*number of events*)	0	0%
Audits	Letters notifying the executive director of an intended audit conducted under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 *(number of audits for which notices were submitted)*	0	0%
	Disclosures of violations under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (*number of audits for which violations were disclosed*)	0	0%

		Please Enter Yes or No	
Other	Environmental management systems in place for one year or more	No	0%
	Voluntary on-site compliance assessments conducted by the executive director under a special assistance program	No	0%
	Participation in a voluntary pollution reduction program	No	0%
	Early compliance with, or offer of a product that meets future state or federal government environmental requirements	No	0%

Adjustment Percentage (Subtotal 2) 5%

>> Repeat Violator (Subtotal 3)

No

Adjustment Percentage (Subtotal 3) 0%

>> Compliance History Person Classification (Subtotal 7)

Average Performer

Adjustment Percentage (Subtotal 7) 0%

>> Compliance History Summary

Compliance History Notes

Enhancement for one NOV with same/similar violations.

Total Adjustment Percentage (Subtotals 2, 3, & 7) 5%

Screening Date 8-Apr-2011 **Docket No.** 2011-0546-PST-E **PCW**

Respondent Anjani C-Store Inc dba Minute Market *Policy Revision 2 (September 2002)*

Case ID No. 41443 *PCW Revision October 30, 2008*

Reg. Ent. Reference No. RN101888246

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Cara Windle

Violation Number 1

Rule Cite(s) 30 Tex. Admin. Code § 334.50(b)(1)(A) and Tex. Water Code § 26.3475(c)(1)

Violation Description Failed to monitor the underground storage tanks ("USTs") for releases at a frequency of at least once every month (not to exceed 35 days between each monitoring).

Base Penalty $10,000

>> Environmental, Property and Human Health Matrix

Release	Harm: Major	Moderate	Minor
Actual			
Potential	x		

OR

Percent 25%

>>Programmatic Matrix

Falsification	Major	Moderate	Minor

Percent 0%

Matrix Notes: Human health or the environment will or could be exposed to pollutants which would exceed levels that are protective of human health or environmental receptors as a result of the violation.

Adjustment $7,500

$2,500

Violation Events

Number of Violation Events 1 — 87 Number of violation days

mark only one with an x

daily	
weekly	
monthly	
quarterly	x
semiannual	
annual	
single event	

Violation Base Penalty $2,500

One quarterly event is recommended based on documentation of the violation during the January 11, 2011 investigation to the April 8, 2011 screening date.

Good Faith Efforts to Comply

0.0% Reduction $0

	Before NOV	NOV to EDPRP/Settlement Offer
Extraordinary		
Ordinary		
N/A	x	(mark with x)

Notes: The Respondent does not meet the good faith criteria for this violation.

Violation Subtotal $2,500

Economic Benefit (EB) for this violation

Estimated EB Amount $68

Statutory Limit Test

Violation Final Penalty Total $2,667

This violation Final Assessed Penalty (adjusted for limits) $2,667

Economic Benefit Worksheet

Respondent Anjani C-Store Inc dba Minute Market
Case ID No. 41443
Req. Ent. Reference No. RN101888246
Media Petroleum Storage Tank
Violation No. 1

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
	No commas or $						
Delayed Costs							
Equipment				0.00	$0	$0	$0
Buildings				0.00	$0	$0	$0
Other (as needed)				0.00	$0	$0	$0
Engineering/construction				0.00	$0	$0	$0
Land				0.00	$0	n/a	$0
Record Keeping System				0.00	$0	n/a	$0
Training/Sampling				0.00	$0	n/a	$0
Remediation/Disposal				0.00	$0	n/a	$0
Permit Costs				0.00	$0	n/a	$0
Other (as needed)	$1,500	11-Jan-2011	8-Dec-2011	0.91	$68	n/a	$68
Notes for DELAYED costs	Estimated cost to monitor the USTs for releases. Date Required is the investigation date. Final Date is the estimated date of compliance.						
Avoided Costs	ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)						
Disposal				0.00	$0	$0	$0
Personnel				0.00	$0	$0	$0
Inspection/Reporting/Sampling				0.00	$0	$0	$0
Supplies/equipment				0.00	$0	$0	$0
Financial Assurance [2]				0.00	$0	$0	$0
ONE-TIME avoided costs [3]				0.00	$0	$0	$0
Other (as needed)				0.00	$0	$0	$0
Notes for AVOIDED costs							

Approx. Cost of Compliance $1,500

TOTAL $68

Screening Date 8-Apr-2011 **Docket No.** 2011-0546-PST-E **PCW**

Respondent Anjani C-Store Inc dba Minute Market *Policy Revision 2 (September 2002)*

Case ID No. 41443 *PCW Revision October 30, 2008*

Reg. Ent. Reference No. RN101888246

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Cara Windle

Violation Number 2

Rule Cite(s) 30 Tex. Admin. Code § 334.42(i)

Violation Description Failed to inspect all sumps, manways, overspill containers or catchment basins associated with a UST system at least once every 60 days to assure that their sides, bottoms, and any penetration points are maintained liquid-tight, and free of liquid and debris. Specifically, the spill buckets contained liquid.

Base Penalty $10,000

>> Environmental, Property and Human Health Matrix

Release	Harm: Major	Moderate	Minor
Actual			
Potential		x	

OR

Percent 10%

>>Programmatic Matrix

Falsification	Major	Moderate	Minor

Percent 0%

Matrix Notes: Human health or the environment will or could be exposed to significant amounts of pollutants which would not exceed levels that are protective of human health or environmental receptors as a result of the violation.

Adjustment $9,000

$1,000

Violation Events

Number of Violation Events: 1 — 87 Number of violation days

mark only one with an x

daily	
weekly	
monthly	
quarterly	x
semiannual	
annual	
single event	

Violation Base Penalty $1,000

One quarterly event is recommended based on documentation of the violation during the January 11, 2011 investigation to the April 8, 2011 screening date.

Good Faith Efforts to Comply

0.0% Reduction — $0

	Before NOV	NOV to EDPRP/Settlement Offer
Extraordinary		
Ordinary		
N/A	x	(mark with x)

Notes: The Respondent does not meet the good faith criteria for this violation.

Violation Subtotal $1,000

Economic Benefit (EB) for this violation

Estimated EB Amount $105

Statutory Limit Test

Violation Final Penalty Total $1,067

This violation Final Assessed Penalty (adjusted for limits) $1,067

Economic Benefit Worksheet

Respondent Anjani C-Store Inc dba Minute Market
Case ID No. 41443
Reg. Ent. Reference No. RN101888246
Media Petroleum Storage Tank
Violation No. 2

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
	No commas or $						
Delayed Costs							
Equipment				0.00	$0	$0	$0
Buildings				0.00	$0	$0	$0
Other (as needed)				0.00	$0	$0	$0
Engineering/construction				0.00	$0	$0	$0
Land				0.00	$0	n/a	$0
Record Keeping System				0.00	$0	n/a	$0
Training/Sampling				0.00	$0	n/a	$0
Remediation/Disposal				0.00	$0	n/a	$0
Permit Costs				0.00	$0	n/a	$0
Other (as needed)				0.00	$0	n/a	$0
Notes for DELAYED costs							
Avoided Costs	ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)						
Disposal				0.00	$0	$0	$0
Personnel				0.00	$0	$0	$0
Inspection/Reporting/Sampling				0.00	$0	$0	$0
Supplies/equipment				0.00	$0	$0	$0
Financial Assurance [2]				0.00	$0	$0	$0
ONE-TIME avoided costs [3]	$100	12-Nov-2010	11-Jan-2011	1.08	$5	$100	$105
Other (as needed)				0.00	$0	$0	$0
Notes for AVOIDED costs	Estimated avoided cost to clean the spill buckets and conduct bimonthly inspections of all sumps, manways, overspill containers or catchment basins. Date Required is 60 days before the investigation date. Final Date is the investigation date.						

Approx. Cost of Compliance $100

TOTAL $105

Screening Date 8-Apr-2011 **Docket No.** 2011-0546-PST-E **PCW**

Respondent Anjani C-Store Inc dba Minute Market *Policy Revision 2 (September 2002)*

Case ID No. 41443 *PCW Revision October 30, 2008*

Reg. Ent. Reference No. RN101888246

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Cara Windle

Violation Number 3

Rule Cite(s) 30 Tex. Admin. Code §§ 334.10(b)(2) and 334.51(c)(2)

Violation Description Failed to maintain UST records and make them immediately available for inspection upon request by agency personnel.

Base Penalty $10,000

>> Environmental, Property and Human Health Matrix

	Harm		
Release	Major	Moderate	Minor
Actual			
Potential			

OR

Percent 0%

>>Programmatic Matrix

Falsification	Major	Moderate	Minor
	x		

Percent 10%

Matrix Notes: 100% of the rule requirement was not met.

Adjustment $9,000

$1,000

Violation Events

Number of Violation Events: 1 — 87 Number of violation days

mark only one with an x

daily	
weekly	
monthly	
quarterly	
semiannual	
annual	
single event	x

Violation Base Penalty $1,000

One single event is recommended.

Good Faith Efforts to Comply

0.0% Reduction — $0

	Before NOV	NOV to EDPRP/Settlement Offer
Extraordinary		
Ordinary		
N/A	x	(mark with x)

Notes: The Respondent does not meet the good faith criteria for this violation.

Violation Subtotal $1,000

Economic Benefit (EB) for this violation

Estimated EB Amount $23

Statutory Limit Test

Violation Final Penalty Total $1,067

This violation Final Assessed Penalty (adjusted for limits) $1,067

Economic Benefit Worksheet

Respondent Anjani C-Store Inc dba Minute Market
Case ID No. 41443
Req. Ent. Reference No. RN101888246
Media Petroleum Storage Tank
Violation No. 3

Percent Interest	Years of Depreciation
5.0	15

Item Description (No commas or $)	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
Delayed Costs							
Equipment				0.00	$0	$0	$0
Buildings				0.00	$0	$0	$0
Other (as needed)				0.00	$0	$0	$0
Engineering/construction				0.00	$0	$0	$0
Land				0.00	$0	n/a	$0
Record Keeping System	$500	11-Jan-2011	8-Dec-2011	0.91	$23	n/a	$23
Training/Sampling				0.00	$0	n/a	$0
Remediation/Disposal				0.00	$0	n/a	$0
Permit Costs				0.00	$0	n/a	$0
Other (as needed)				0.00	$0	n/a	$0
Notes for DELAYED costs	Estimated cost to maintain UST records. Date Required is the investigation date. Final Date is the estimated date of compliance.						
Avoided Costs	ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)						
Disposal				0.00	$0	$0	$0
Personnel				0.00	$0	$0	$0
Inspection/Reporting/Sampling				0.00	$0	$0	$0
Supplies/equipment				0.00	$0	$0	$0
Financial Assurance [2]				0.00	$0	$0	$0
ONE-TIME avoided costs [3]				0.00	$0	$0	$0
Other (as needed)				0.00	$0	$0	$0
Notes for AVOIDED costs							

Approx. Cost of Compliance $500

TOTAL $23

Screening Date 8-Apr-2011 **Docket No.** 2011-0546-PST-E **PCW**

Respondent Anjani C-Store Inc dba Minute Market *Policy Revision 2 (September 2002)*

Case ID No. 41443 *PCW Revision October 30, 2008*

Reg. Ent. Reference No. RN101888246

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Cara Windle

Violation Number 4

Rule Cite(s) 30 Tex. Admin. Code § 334.45(c)(3)(A)

Violation Description Failed to install an emergency shutoff valve (also known as shear or impact valve) on each pressurized delivery or product line and ensure that it is securely anchored at the base of the dispenser. Specifically, shear valves were not anchored.

Base Penalty $10,000

>> Environmental, Property and Human Health Matrix

	Harm		
Release	Major	Moderate	Minor
Actual			
Potential		x	

OR

Percent 10%

>>Programmatic Matrix

Falsification	Major	Moderate	Minor

Percent 0%

Matrix Notes: Human health or the environment will or could be exposed to a significant amount of pollutants which would not exceed levels that are protective of human health or environmental receptors as a result of the violation.

Adjustment $9,000

$1,000

Violation Events

Number of Violation Events 1 — 7 Number of violation days

mark only one with an x

daily	
weekly	
monthly	
quarterly	x
semiannual	
annual	
single event	

Violation Base Penalty $1,000

One quarterly event is recommended based on documentation of the violation during the January 11, 2011 investigation to the January 18, 2011 compliance date.

Good Faith Efforts to Comply

25.0% Reduction $250

	Before NOV	NOV to EDPRP/Settlement Offer
Extraordinary		
Ordinary	x	
N/A		(mark with x)

Notes: The Respondent came into compliance on January 18, 2011 prior to the Notice of Enforcement dated April 1, 2011.

Violation Subtotal $750

Economic Benefit (EB) for this violation — Statutory Limit Test

Estimated EB Amount $0

Violation Final Penalty Total $813

This violation Final Assessed Penalty (adjusted for limits) $813

Economic Benefit Worksheet

Respondent Anjani C-Store Inc dba Minute Market
Case ID No. 41443
Reg. Ent. Reference No. RN101888246
Media Petroleum Storage Tank
Violation No. 4

Percent Interest	Years of Depreciation
5.0	15

Item Description (No commas or $)	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
Delayed Costs							
Equipment	$75	11-Jan-2011	18-Jan-2011	0.02	$0	$0	$0
Buildings				0.00	$0	$0	$0
Other (as needed)				0.00	$0	$0	$0
Engineering/construction				0.00	$0	$0	$0
Land				0.00	$0	n/a	$0
Record Keeping System				0.00	$0	n/a	$0
Training/Sampling				0.00	$0	n/a	$0
Remediation/Disposal				0.00	$0	n/a	$0
Permit Costs				0.00	$0	n/a	$0
Other (as needed)				0.00	$0	n/a	$0
Notes for DELAYED costs	Actual cost to securely anchor all shear valves at the base of the dispensers per receipt. Date Required is the investigation date. Final Date is the date of compliance.						
Avoided Costs	ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)						
Disposal				0.00	$0	$0	$0
Personnel				0.00	$0	$0	$0
Inspection/Reporting/Sampling				0.00	$0	$0	$0
Supplies/equipment				0.00	$0	$0	$0
Financial Assurance [2]				0.00	$0	$0	$0
ONE-TIME avoided costs [3]				0.00	$0	$0	$0
Other (as needed)				0.00	$0	$0	$0
Notes for AVOIDED costs							

Approx. Cost of Compliance $75

TOTAL $0

Screening Date 8-Apr-2011 **Docket No.** 2011-0546-PST-E **PCW**

Respondent Anjani C-Store Inc dba Minute Market *Policy Revision 2 (September 2002)*

Case ID No. 41443 *PCW Revision October 30, 2008*

Reg. Ent. Reference No. RN101888246

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Cara Windle

Violation Number 5

Rule Cite(s) 30 Tex. Admin. Code §§ 334.45(c)(1) and 115.242(2)(A) and (2)(E) and Tex. Health & Safety Code § 382.085(b)

Violation Description Failed to meet the technical standards for the underground piping in a UST system. Specifically, the installed riser piping at the Station did not meet technical standards approved for UST system piping material.

Base Penalty $10,000

>> Environmental, Property and Human Health Matrix

	Harm		
Release	Major	Moderate	Minor
Actual			
Potential		x	

OR

Percent 10%

>>Programmatic Matrix

Falsification	Major	Moderate	Minor

Percent 0%

Matrix Notes: Human health or the environment will or could be exposed to significant amounts of pollutants which would not exceed levels that are protective of human health or environmental receptors as a result of the violation.

Adjustment $9,000

$1,000

Violation Events

Number of Violation Events 1 | 87 Number of violation days

mark only one with an x

daily	
weekly	
monthly	
quarterly	x
semiannual	
annual	
single event	

Violation Base Penalty $1,000

One quarterly event is recommended based on documentation of the violation during the January 11, 2011 investigation to the April 8, 2011 screening date.

Good Faith Efforts to Comply

0.0% Reduction $0

	Before NOV	NOV to EDPRP/Settlement Offer
Extraordinary		
Ordinary		
N/A	x	(mark with x)

Notes: The Respondent does not meet the good faith criteria for this violation.

Violation Subtotal $1,000

Economic Benefit (EB) for this violation

Estimated EB Amount $63

Statutory Limit Test

Violation Final Penalty Total $1,067

This violation Final Assessed Penalty (adjusted for limits) $1,067

Economic Benefit Worksheet

Respondent Anjani C-Store Inc dba Minute Market
Case ID No. 41443
Req. Ent. Reference No. RN101888246
Media Petroleum Storage Tank
Violation No. 5

Percent Interest	Years of Depreciation
5.0	15

	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
Item Description	No commas or $						
Delayed Costs							
Equipment	$1,000	11-Jan-2011	8-Dec-2011	0.91	$3	$60	$63
Buildings				0.00	$0	$0	$0
Other (as needed)				0.00	$0	$0	$0
Engineering/construction				0.00	$0	$0	$0
Land				0.00	$0	n/a	$0
Record Keeping System				0.00	$0	n/a	$0
Training/Sampling				0.00	$0	n/a	$0
Remediation/Disposal				0.00	$0	n/a	$0
Permit Costs				0.00	$0	n/a	$0
Other (as needed)				0.00	$0	n/a	$0
Notes for DELAYED costs	Estimated cost to install riser piping that meets the technical standards for underground piping associated with a UST system. Date Required is the investigation date. Final Date is the estimated date of compliance.						
Avoided Costs	**ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)**						
Disposal				0.00	$0	$0	$0
Personnel				0.00	$0	$0	$0
Inspection/Reporting/Sampling				0.00	$0	$0	$0
Supplies/equipment				0.00	$0	$0	$0
Financial Assurance [2]				0.00	$0	$0	$0
ONE-TIME avoided costs [3]				0.00	$0	$0	$0
Other (as needed)				0.00	$0	$0	$0
Notes for AVOIDED costs							

Approx. Cost of Compliance $1,000

TOTAL $63

Compliance History

Customer/Respondent/Owner-Operator: CN603511320 Anjani C-Store Inc Classification: AVERAGE Rating: 7.00

Regulated Entity: RN101888246 Minute Market Classification: AVERAGE Site Rating: 7.00

ID Number(s): PETROLEUM STORAGE TANK REGISTRATION REGISTRATION 53795

Location: 1702 North Brazosport Boulevard, Freeport, Texas 77541

TCEQ Region: REGION 12 - HOUSTON

Date Compliance History Prepared: April 08, 2011

Agency Decision Requiring Compliance History: Enforcement

Compliance Period: April 08, 2006 to April 08, 2011

TCEQ Staff Member to Contact for Additional Information Regarding this Compliance History

Name: Cara Windle Phone: (512) 239-2581

Site Compliance History Components

1. Has the site been in existence and/or operation for the full five year compliance period? Yes
2. Has there been a (known) change in ownership/operator of the site during the compliance period? Yes
3. If Yes, who is the current owner/operator? Anjani C-Store Inc
4. If Yes, who was/were the prior owner(s)/operator(s)? Aisha, Inc
5. When did the change(s) in owner or operator occur? 07/15/2009
6. Rating Date: 9/1/2010 Repeat Violator: NO

Components (Multimedia) for the Site :

A. Final Enforcement Orders, court judgments, and consent decrees of the State of Texas and the federal government.

N/A

B. Any criminal convictions of the state of Texas and the federal government.

N/A

C. Chronic excessive emissions events.

N/A

D. The approval dates of investigations. (CCEDS Inv. Track. No.)

1 07/28/2010 (796798)

2 04/01/2011 (893938)

E. Written notices of violations (NOV). (CCEDS Inv. Track. No.)

Date: 07/27/2010 (796798) CN603511320

Self Report? NO Classification: Moderate
Citation: 30 TAC Chapter 334, SubChapter C 334.50(d)(4)(A)
Description: The Automatic Tank Gauge equipment was not properly maintained, thus incapable of automatically monitoring the in-tank liquid levels as required.

Self Report? NO Classification: Moderate
Citation: 30 TAC Chapter 334, SubChapter C 334.42(i)
Description: The facility did not provide documentation of inspections every 60 days for liquids in sumps, manways, overspill containers and catchment basins.

Self Report? NO Classification: Moderate
Citation: 30 TAC Chapter 334, SubChapter A 334.10(b)(2)(C)
Description: Failure of the owner/operator to maintain records which demonstrate the required financial responsibility.

Self Report? NO Classification: Moderate
Citation: 30 TAC Chapter 334, SubChapter C 334.51(c)(2)
Description: Failure to maintain records adequate to demonstrate compliance with spill and overfill prevention requirements.

Self Report? NO Classification: Moderate

Citation: 30 TAC Chapter 334, SubChapter C 334.45(f)

Description: Failure to maintain records that the shear valves are present and anchored at the base of the dispenser in each pressurized delivery or product line as required.

F. Environmental audits.

N/A

G. Type of environmental management systems (EMSs).

N/A

H. Voluntary on-site compliance assessment dates.

N/A

I. Participation in a voluntary pollution reduction program.

N/A

J. Early compliance.

N/A

Sites Outside of Texas

N/A

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

IN THE MATTER OF AN ENFORCEMENT ACTION CONCERNING ANJANI C-STORE INC DBA MINUTE MARKET RN101888246	§ § § § § §	**BEFORE THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY**

AGREED ORDER
DOCKET NO. 2011-0546-PST-E

I. JURISDICTION AND STIPULATIONS

At its _____ agenda, the Texas Commission on Environmental Quality ("the Commission" or "TCEQ") considered this agreement of the parties, resolving an enforcement action regarding Anjani C-Store Inc dba Minute Market ("the Respondent") under the authority of TEX. HEALTH & SAFETY CODE ch. 382 and TEX. WATER CODE chs. 7 and 26. The Executive Director of the TCEQ, through the Enforcement Division, and the Respondent appear before the Commission and together stipulate that:

1. The Respondent owns and operates a convenience store with retail sales of gasoline at 1702 North Brazosport Boulevard in Freeport, Brazoria County, Texas (the "Station").

2. The Respondent's four underground storage tanks ("USTs") are not exempt or excluded from regulation under the Texas Water Code or the rules of the Commission. The Station consists of one or more sources as defined in TEX. HEALTH & SAFETY CODE § 382.003(12).

3. The Commission and the Respondent agree that the Commission has jurisdiction to enter this Agreed Order, and that the Respondent is subject to the Commission's jurisdiction.

4. The Respondent received notice of the violations alleged in Section II ("Allegations") on or about April 6, 2011.

5. The occurrence of any violation is in dispute and the entry of this Agreed Order shall not constitute an admission by the Respondent of any violation alleged in Section II ("Allegations"), nor of any statute or rule.

6. An administrative penalty in the amount of Six Thousand Six Hundred Eighty Dollars ($6,680) is assessed by the Commission in settlement of the violations alleged in Section II ("Allegations"). The Respondent has paid One Hundred Sixty-Four Dollars ($164) of the administrative penalty and One Thousand Three Hundred Thirty-Six Dollars ($1,336) is deferred contingent upon the Respondent's timely and satisfactory compliance with all the terms of this Agreed Order. The deferred amount will be waived upon full compliance with the terms of this Agreed Order. If the Respondent fails to timely and satisfactorily comply with all requirements of this Agreed Order, the Executive Director may require the Respondent to pay all or part of the deferred penalty.

   The remaining amount of Five Thousand One Hundred Eighty Dollars ($5,180) of the administrative penalty shall be payable in 35 monthly payments of One Hundred Forty-Eight Dollars ($148) each. The next monthly payment shall be paid within 30 days after the effective date of this Agreed Order. The subsequent payments shall each be paid not later than 30 days following the due date of the previous payment until paid in full. If the Respondent fails to timely and satisfactorily comply with the payment requirements of this Agreed Order, the Executive Director may, at the Executive Director's option, accelerate the maturity of the remaining installments, in which event the unpaid balance shall become immediately due and payable without demand or notice. In addition, the failure of the Respondent to meet the payment schedule of this Agreed Order constitutes the failure by the Respondent to timely and satisfactorily comply with all the terms of this Agreed Order.

7. Any notice and procedures, which might otherwise be authorized or required in this action, are waived in the interest of a more timely resolution of the matter.

8. The Executive Director of the TCEQ and the Respondent have agreed on a settlement of the matters alleged in this enforcement action, subject to the approval of the Commission.

9. The Executive Director recognizes that the Respondent securely anchored all shear valves at the base of the dispensers at the Station on January 18, 2011.

10. The Executive Director may, without further notice or hearing, refer this matter to the Office of the Attorney General of the State of Texas ("OAG") for further enforcement proceedings if the Executive Director determines that the Respondent has not complied with one or more of the terms or conditions in this Agreed Order.

11. This Agreed Order shall terminate five years from its effective date or upon compliance with all the terms and conditions set forth in this Agreed Order, whichever is later.

12. The provisions of this Agreed Order are deemed severable and, if a court of competent jurisdiction or other appropriate authority deems any provision of this Agreed Order unenforceable, the remaining provisions shall be valid and enforceable.

II. ALLEGATIONS

As owner and operator of the Station, the Respondent is alleged to have:

1. Failed to monitor the USTs for releases at a frequency of at least once every month (not to exceed 35 days between each monitoring), in violation of 30 TEX. ADMIN. CODE § 334.50(b)(1)(A) and TEX. WATER CODE § 26.3475(c)(1), as documented during an investigation conducted on January 11, 2011.

2. Failed to inspect all sumps, manways, overspill containers or catchment basins associated with a UST system at least once every 60 days to assure that their sides, bottoms, and any penetration points are maintained liquid-tight, and free of liquid and debris, in violation of 30 TEX. ADMIN. CODE § 334.42(i), as documented during an investigation conducted on January 11, 2011. Specifically, the spill buckets contained liquid.

3. Failed to maintain UST records and make them immediately available for inspection upon request by agency personnel, in violation of 30 TEX. ADMIN. CODE §§ 334.10(b)(2) and 334.51(c)(2), as documented during an investigation conducted on January 11, 2011.

4. Failed to install an emergency shutoff valve (also known as shear or impact valve) on each pressurized delivery or product line and ensure that it is securely anchored at the base of the dispenser, in violation of 30 TEX. ADMIN. CODE § 334.45(c)(3)(A), as documented during an investigation conducted on January 11, 2011. Specifically, shear valves were not anchored.

5. Failed to meet the technical standards for the underground piping in a UST system, in violation of 30 TEX. ADMIN. CODE §§ 334.45(c)(1) and 115.242(2)(A) and (2)(E) and TEX. HEALTH & SAFETY CODE § 382.085(b), as documented during an investigation conducted on January 11, 2011. Specifically, the installed riser piping at the Station did not meet technical standards approved for UST system piping material.

III. DENIALS

The Respondent generally denies each allegation in Section II ("Allegations").

IV. ORDERING PROVISIONS

1. It is, therefore, ordered by the TCEQ that the Respondent pay an administrative penalty as set forth in Section I, Paragraph 6 above. The payment of this administrative penalty and the Respondent's compliance with all the terms and conditions set forth in this Agreed Order resolve only the allegations in Section II. The Commission shall not be constrained in any manner from requiring corrective action or penalties for violations which are not raised here. Administrative penalty payments shall be made payable to "TCEQ" and shall be sent with the notation "Re: Anjani C-Store Inc dba Minute Market, Docket No. 2011-0546-PST-E" to:

Financial Administration Division, Revenues Section
Attention: Cashier's Office, MC 214
Texas Commission on Environmental Quality
P.O. Box 13088
Austin, Texas 78711-3088

2. It is further ordered that the Respondent shall undertake the following technical requirements:

a. Within 30 days after the effective date of this Agreed Order:

i. Implement a release detection method for all USTs at the Station, in accordance with 30 TEX. ADMIN. CODE § 334.50;

ii. Clean the spill buckets and begin conducting bimonthly inspections of all sumps, manways, and overfill containers or catchment basins, in accordance with 30 TEX. ADMIN. CODE § 334.42;

iii. Begin maintaining all UST records, in accordance with 30 TEX. A DMIN. CODE § 334.51;

iv. Install riser piping that meets the technical standards for underground piping associated with a UST system, in accordance with 30 TEX. ADMIN. CODE § 334.45; and

b. Within 45 days after the effective date of this Agreed Order, submit written certification as described below, and include detailed supporting documentation including photographs, receipts, and/or other records to demonstrate compliance with Ordering Provision Nos. 2.a.i. through 2.a.iv. The certification shall be notarized by a State of Texas Notary Public and include the following certification language:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

The certification shall be submitted to:

Order Compliance Team
Enforcement Division, MC 149A
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

with a copy to:

Waste Section Manager
Houston Regional Office
Texas Commission on Environmental Quality
5425 Polk Avenue, Suite H
Houston, Texas 77023-1486

3. The provisions of this Agreed Order shall apply to and be binding upon the Respondent. The Respondent is ordered to give notice of the Agreed Order to personnel who maintain day-to-day control over the Station operations referenced in this Agreed Order.

4. If the Respondent fails to comply with any of the Ordering Provisions in this Agreed Order within the prescribed schedules, and that failure is caused solely by an act of God, war, strike, riot, or other catastrophe, the Respondent's failure to comply is not a violation of this Agreed Order. The Respondent shall have the burden of establishing to the Executive Director's satisfaction that such an event has occurred. The Respondent shall notify the Executive Director within seven days after the Respondent becomes aware of a delaying event and shall take all reasonable measures to mitigate and minimize any delay.

5. The Executive Director may grant an extension of any deadline in this Agreed Order or in any plan, report, or other document submitted pursuant to this Agreed Order, upon a written and substantiated showing of good cause. All requests for extensions by the Respondent shall be made in writing to the Executive Director. Extensions are not effective until the Respondent receives written approval from the Executive Director. The determination of what constitutes good cause rests solely with the Executive Director.

6. This Agreed Order, issued by the Commission, shall not be admissible against the Respondent in a civil proceeding, unless the proceeding is brought by the OAG to: (1) enforce the terms of this Agreed Order; or (2) pursue violations of a statute within the Commission's jurisdiction, or of a rule adopted or an order or permit issued by the Commission under such a statute.

7. This Agreed Order may be executed in separate and multiple counterparts, which together shall constitute a single instrument. Any page of this Agreed Order may be copied, scanned, digitized, converted to electronic portable document format ("pdf"), or otherwise reproduced and may be transmitted by digital or electronic transmission, including but not limited to facsimile transmission and electronic mail. Any signature affixed to this Agreed Order shall constitute an original signature for all purposes and may be used, filed, substituted, or issued for any purpose for which an original signature could be used. The term "signature" shall include manual signatures and true and accurate reproductions of manual signatures created, executed, endorsed, adopted, or authorized by the person or persons to whom the signatures are attributable. Signatures may be copied or reproduced digitally, electronically, by photocopying, engraving, imprinting, lithographing, electronic mail, facsimile transmission, stamping, or any other means or process which the Executive Director deems acceptable. In this paragraph exclusively, the terms "electronic transmission", "owner", "person", "writing", and "written" shall have the meanings assigned to them under TEX. BUS. ORG. CODE § 1.002.

8. Under 30 TEX. ADMIN. CODE § 70.10(b), the effective date is the date of hand-delivery of the Order to the Respondent, or three days after the date on which the Commission mails notice of the Order to the Respondent, whichever is earlier. The Chief Clerk shall provide a copy of this Agreed Order to each of the parties.

SIGNATURE PAGE

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

For the Commission

For the Executive Director

8/30/11
Date

I, the undersigned, have read and understand the attached Agreed Order. I am authorized to agree to the attached Agreed Order on behalf of the entity indicated below my signature, and I do agree to the terms and conditions specified therein. I further acknowledge that the TCEQ, in accepting payment for the penalty amount, is materially relying on such representation.

I also understand that failure to comply with the Ordering Provisions, if any, in this order and/or failure to timely pay the penalty amount, may result in:

- A negative impact on compliance history;
- Greater scrutiny of any permit applications submitted;
- Referral of this case to the Attorney General's Office for contempt, injunctive relief, additional penalties, and/or attorney fees, or to a collection agency;
- Increased penalties in any future enforcement actions;
- Automatic referral to the Attorney General's Office of any future enforcement actions; and
- TCEQ seeking other relief as authorized by law.

In addition, any falsification of any compliance documents may result in criminal prosecution.

Signature

7-6-11
Date

Upendra Bhakta
Name (Printed or typed)
Authorized Representative of
Anjani C-Store Inc dba Minute Market

President (Owner)
Title

Instructions: Send the original, signed Agreed Order with penalty payment to the Financial Administration Division, Revenues Section at the address in Section IV, Paragraph 1 of this Agreed Order.