

Executive Summary – Enforcement Matter – Case No. 47915

Aqua Utilities, Inc.

RN102678950

Docket No. 2013-2043-PWS-E

Order Type:

Findings Agreed Order

Findings Order Justification:

Three or more enforcement actions (NOVs, orders, etc.) over the prior five year period for the same violation(s).

Media:

PWS

Small Business:

No

Location(s) Where Violation(s) Occurred:

Falling Water Subdivision, located five miles west of Comfort on United States Highway 87, Kerr County

Type of Operation:

Public water supply

Other Significant Matters:

Additional Pending Enforcement Actions: No

Past-Due Penalties: No

Other: N/A

Interested Third-Parties: None

Texas Register Publication Date: March 21, 2014

Comments Received: No

Penalty Information

Total Penalty Assessed: \$990

Amount Deferred for Expedited Settlement: \$990

Amount Deferred for Financial Inability to Pay: \$0

Total Paid to General Revenue: \$0

Total Due to General Revenue: \$0

Payment Plan: N/A

SEP Conditional Offset: \$0

Name of SEP: N/A

Compliance History Classifications:

Person/CN - Satisfactory

Site/RN - N/A

Major Source: Yes

Statutory Limit Adjustment: N/A

Applicable Penalty Policy: September 2011

**Executive Summary – Enforcement Matter – Case No. 47915
Aqua Utilities, Inc.
RN102678950
Docket No. 2013-2043-PWS-E**

Investigation Information

Complaint Date(s): N/A
Complaint Information: N/A
Date(s) of Investigation: September 30, 2013
Date(s) of NOE(s): October 23, 23013

Violation Information

Failed to comply with the maximum contaminant level ("MCL") of 5 picoCuries per liter for combined radium-226 and radium-228 based on the running annual average [30 TEX. ADMIN. CODE § 290.108(f)(1) and TEX. HEALTH & SAFETY CODE § 341.0315(c)].

Corrective Actions/Technical Requirements

Corrective Action(s) Completed:

On September 5, 2012, the Respondent gained conditional approval from the TCEQ for a pilot study to remove the combined radium-226 and radium-228 from the entry point No. 1 and entry point No. 2.

Technical Requirements:

The Order will require the Respondent to:

- a. Within 180 days, submit an acceptable written plan, including a proposed schedule, to the Executive Director that provides for the completion of an alternate water source or treatment technology;
- b. Within 180 days, and on a semi-annual basis thereafter, submit progress reports. These reports shall include information regarding actions taken to provide water which meets the MCL for combined radium-226 and radium-228;
- c. Within 195 days, submit written certification to demonstrate compliance with Ordering Provision a.;
- d. Within 1,095 days, return to compliance with the MCL for combined radium-226 and radium-228; and
- e. Within 1,110 days, submit written certification to demonstrate compliance with Ordering Provision d.

**Executive Summary – Enforcement Matter – Case No. 47915
Aqua Utilities, Inc.
RN102678950
Docket No. 2013-2043-PWS-E**

Litigation Information

Date Petition(s) Filed: N/A
Date Answer(s) Filed: N/A
SOAH Referral Date: N/A
Hearing Date(s): N/A
Settlement Date: N/A

Contact Information

TCEQ Attorney: N/A
TCEQ Enforcement Coordinator: Lisa Westbrook, Enforcement Division,
Enforcement Team 2, MC 169, (512) 239-1160; Candy Garrett, Enforcement Division,
MC 219, (512) 239-1456
TCEQ SEP Coordinator: N/A
Respondent: R.L. Laughman, President, Aqua Utilities, Inc., 1106 Clayton Lane, Suite
400 West, Austin, Texas 78723
Larry Mitchell, Compliance Manager, Aqua Utilities, Inc., 1106 Clayton Lane, Suite 400
West, Austin, Texas 78723
Respondent's Attorney: N/A



Penalty Calculation Worksheet (PCW)

Policy Revision 3 (September 2011)

PCW Revision August 3, 2011

TCEQ
DATES

| | | | | | |
|---------------------|-------------|------------------|------------|----------------|-------------|
| Assigned PCW | 21-Oct-2013 | Screening | 4-Nov-2013 | EPA Due | 30-Jun-2013 |
|---------------------|-------------|------------------|------------|----------------|-------------|

RESPONDENT/FACILITY INFORMATION

| | | | |
|-----------------------------|----------------------|---------------------------|-------|
| Respondent | Aqua Utilities, Inc. | | |
| Reg. Ent. Ref. No. | RN102678950 | | |
| Facility/Site Region | 13-San Antonio | Major/Minor Source | Major |

CASE INFORMATION

| | | | |
|-------------------------|---------------------|------------------------------|--------------------|
| Enf./Case ID No. | 47915 | No. of Violations | 1 |
| Docket No. | 2013-2043-PWS-E | Order Type | Findings |
| Media Program(s) | Public Water Supply | Government/Non-Profit | No |
| Multi-Media | | Enf. Coordinator | Lisa Westbrook |
| | | EC's Team | Enforcement Team 2 |

Admin. Penalty \$ Limit Minimum **Maximum**

Penalty Calculation Section

TOTAL BASE PENALTY (Sum of violation base penalties) **Subtotal 1**

ADJUSTMENTS (+/-) TO SUBTOTAL 1

Subtotals 2-7 are obtained by multiplying the Total Base Penalty (Subtotal 1) by the indicated percentage.

Compliance History Enhancement **Subtotals 2, 3, & 7**

Notes

Culpability Enhancement **Subtotal 4**

Notes

Good Faith Effort to Comply Total Adjustments **Subtotal 5**

Economic Benefit Enhancement* **Subtotal 6**

Total EB Amounts
 Approx. Cost of Compliance
 *Capped at the Total EB \$ Amount

SUM OF SUBTOTALS 1-7 **Final Subtotal**

OTHER FACTORS AS JUSTICE MAY REQUIRE **Adjustment**

Reduces or enhances the Final Subtotal by the indicated percentage.

Notes

Final Penalty Amount

STATUTORY LIMIT ADJUSTMENT **Final Assessed Penalty**

DEFERRAL Reduction **Adjustment**

Reduces the Final Assessed Penalty by the indicated percentage. (Enter number only; e.g. 20 for 20% reduction.)

Notes

PAYABLE PENALTY

Screening Date 4-Nov-2013

Docket No. 2013-2043-PWS-E

PCW

Respondent Aqua Utilities, Inc.

Policy Revision 3 (September 2011)

Case ID No. 47915

PCW Revision August 3, 2011

Reg. Ent. Reference No. RN102678950

Media [Statute] Public Water Supply

Enf. Coordinator Lisa Westbrook

Compliance History Worksheet

>> Compliance History *Site Enhancement (Subtotal 2)*

Component Number of... Enter Number Here Adjust.

| | | | |
|-------------------------------|--|---|-----|
| NOVs | Written notices of violation ("NOVs") with same or similar violations as those in the current enforcement action (<i>number of NOVs meeting criteria</i>) | 2 | 10% |
| | Other written NOVs | 0 | 0% |
| Orders | Any agreed final enforcement orders containing a denial of liability (<i>number of orders meeting criteria</i>) | 0 | 0% |
| | Any adjudicated final enforcement orders, agreed final enforcement orders without a denial of liability, or default orders of this state or the federal government, or any final prohibitory emergency orders issued by the commission | 0 | 0% |
| Judgments and Consent Decrees | Any non-adjudicated final court judgments or consent decrees containing a denial of liability of this state or the federal government (<i>number of judgements or consent decrees meeting criteria</i>) | 0 | 0% |
| | Any adjudicated final court judgments and default judgments, or non-adjudicated final court judgments or consent decrees without a denial of liability, of this state or the federal government | 0 | 0% |
| Convictions | Any criminal convictions of this state or the federal government (<i>number of counts</i>) | 0 | 0% |
| Emissions | Chronic excessive emissions events (<i>number of events</i>) | 0 | 0% |
| Audits | Letters notifying the executive director of an intended audit conducted under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which notices were submitted</i>) | 0 | 0% |
| | Disclosures of violations under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which violations were disclosed</i>) | 0 | 0% |

Please Enter Yes or No

| | | | |
|-------|---|----|----|
| Other | Environmental management systems in place for one year or more | No | 0% |
| | Voluntary on-site compliance assessments conducted by the executive director under a special assistance program | No | 0% |
| | Participation in a voluntary pollution reduction program | No | 0% |
| | Early compliance with, or offer of a product that meets future state or federal government environmental requirements | No | 0% |

Adjustment Percentage (Subtotal 2)

>> Repeat Violator (Subtotal 3)

Adjustment Percentage (Subtotal 3)

>> Compliance History Person Classification (Subtotal 7)

Adjustment Percentage (Subtotal 7)

>> Compliance History Summary

Compliance History Notes

Enhancement for two NOVs with same/similar violations.

Total Compliance History Adjustment Percentage (Subtotals 2, 3, & 7)

>> Final Compliance History Adjustment

Final Adjustment Percentage *capped at 100%

Screening Date 4-Nov-2013

Docket No. 2013-2043-PWS-E

PCW

Respondent Aqua Utilities, Inc.

Policy Revision 3 (September 2011)

Case ID No. 47915

PCW Revision August 3, 2011

Reg. Ent. Reference No. RN102678950

Media [Statute] Public Water Supply

Enf. Coordinator Lisa Westbrook

Violation Number 1

Rule Cite(s) 30 Tex. Admin. Code § 290.108(f)(1) and Tex. Health & Safety Code § 341.0315(c)

Violation Description Failed to comply with the maximum contaminant level ("MCL") of 5 pCi/L for combined radium-226 and radium-228, based on the running annual average. Specifically at the time of record review, it was documented that the running annual average concentration for combined radium-226 and radium-228 was 6 pCi/L for the first quarter 2012 and 6 pCi/L for the first quarter of 2013 at entry point No. 1, and the running annual average concentration for the combined radium-226 and radium-228 was 6 pCi/L for the fourth quarter of 2012 and 6 pCi/L for the first quarter of 2013 at entry point No. 2.

Base Penalty \$1,000

>> Environmental, Property and Human Health Matrix

Table with columns: Release (Actual, Potential), Harm (Major, Moderate, Minor), and Percent (30.0%). Includes an 'OR' label.

>> Programmatic Matrix

Table with columns: Falsification, Major, Moderate, Minor, and Percent (0.0%).

Matrix Notes Exceeding the MCL for combined radium caused the customers of the Facility to be exposed to a significant amount of contaminants which do not exceed levels protective of human health.

Adjustment \$700

\$300

Violation Events

Number of Violation Events 3 Number of violation days 455

Table for event frequency: daily, weekly, monthly, quarterly, semiannual, annual (marked with x), single event.

Violation Base Penalty \$900

Three annual events are recommended (two events at entry point No. 1 and one event at entry point No. 2)

Good Faith Efforts to Comply

0.0% Reduction \$0

Table for Good Faith Efforts: Extraordinary, Ordinary, N/A (marked with x), and Notes.

Notes The Respondent does not meet the good faith criteria for this violation.

Violation Subtotal \$900

Economic Benefit (EB) for this violation

Statutory Limit Test

Estimated EB Amount \$14,476

Violation Final Penalty Total \$990

This violation Final Assessed Penalty (adjusted for limits) \$990

Economic Benefit Worksheet

Respondent Aqua Utilities, Inc.
Case ID No. 47915
Reg. Ent. Reference No. RN102678950
Media Public Water Supply
Violation No. 1

| | |
|-------------------------|------------------------------|
| Percent Interest | Years of Depreciation |
| 5.0 | 15 |

| Item Description | Item Cost | Date Required | Final Date | Yrs | Interest Saved | Onetime Costs | EB Amount |
|------------------|-----------|---------------|------------|-----|----------------|---------------|-----------|
|------------------|-----------|---------------|------------|-----|----------------|---------------|-----------|

No commas or \$

Delayed Costs

| | | | | | | | |
|--------------------------|----------|-------------|-------------|------|-------|----------|----------|
| Equipment | | | | 0.00 | \$0 | \$0 | \$0 |
| Buildings | | | | 0.00 | \$0 | \$0 | \$0 |
| Other (as needed) | \$40,000 | 31-Mar-2012 | 31-May-2017 | 5.17 | \$689 | \$13,786 | \$14,476 |
| Engineering/construction | | | | 0.00 | \$0 | \$0 | \$0 |
| Land | | | | 0.00 | \$0 | n/a | \$0 |
| Record Keeping System | | | | 0.00 | \$0 | n/a | \$0 |
| Training/Sampling | | | | 0.00 | \$0 | n/a | \$0 |
| Remediation/Disposal | | | | 0.00 | \$0 | n/a | \$0 |
| Permit Costs | | | | 0.00 | \$0 | n/a | \$0 |
| Other (as needed) | | | | 0.00 | \$0 | n/a | \$0 |

Notes for DELAYED costs

The delayed cost includes the estimated amount to investigate, identify, and implement the necessary corrective actions to return to compliance with the MCL for combined radium-226 and radium-228, calculated from the last day of the first quarter of non-compliance to the estimated date of compliance.

Avoided Costs

ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)

| | | | | | | | |
|-------------------------------|--|--|--|------|-----|-----|-----|
| Disposal | | | | 0.00 | \$0 | \$0 | \$0 |
| Personnel | | | | 0.00 | \$0 | \$0 | \$0 |
| Inspection/Reporting/Sampling | | | | 0.00 | \$0 | \$0 | \$0 |
| Supplies/equipment | | | | 0.00 | \$0 | \$0 | \$0 |
| Financial Assurance [2] | | | | 0.00 | \$0 | \$0 | \$0 |
| ONE-TIME avoided costs [3] | | | | 0.00 | \$0 | \$0 | \$0 |
| Other (as needed) | | | | 0.00 | \$0 | \$0 | \$0 |

Notes for AVOIDED costs

Approx. Cost of Compliance

| |
|----------|
| \$40,000 |
|----------|

TOTAL

| |
|----------|
| \$14,476 |
|----------|

The TCEQ is committed to accessibility.

To request a more accessible version of this report, please contact the TCEQ Help Desk at (512) 239-4357.



TCEQ Compliance History Report

PENDING Compliance History Report for CN602787509, RN102678950, Rating Year 2013 which includes Compliance History (CH) components from September 1, 2008, through August 31, 2013.

Customer, Respondent, or Owner/Operator: CN602787509, Aqua Utilities, Inc.

Classification: SATISFACTORY **Rating:** 5.91

Regulated Entity: RN102678950, FALLING WATER SUBDIVISION

Classification: NOT APPLICABLE **Rating:** N/A

Complexity Points: N/A

Repeat Violator: N/A

CH Group: 14 - Other

Location: 5 MILES WEST OF COMFORT ON UNITED STATES HIGHWAY 87, KERR COUNTY, TEXAS

TCEQ Region: REGION 13 - SAN ANTONIO

ID Number(s):

PUBLIC WATER SYSTEM/SUPPLY REGISTRATION 1330154

WATER LICENSING LICENSE 1330154

Compliance History Period: September 01, 2008 to August 31, 2013 **Rating Year:** 2013 **Rating Date:** 09/01/2013

Date Compliance History Report Prepared: November 01, 2013

Agency Decision Requiring Compliance History: Enforcement

Component Period Selected: November 01, 2008 to November 01, 2013

TCEQ Staff Member to Contact for Additional Information Regarding This Compliance History.

Name: Lisa Westbrook

Phone: (512) 239-1160

Site and Owner/Operator History:

- 1) Has the site been in existence and/or operation for the full five year compliance period? YES
- 2) Has there been a (known) change in ownership/operator of the site during the compliance period? NO
- 3) If YES for #2, who is the current owner/operator? N/A
- 4) If YES for #2, who was/were the prior owner(s)/operator(s)? N/A
- 5) If YES, when did the change(s) in owner or operator occur? N/A

Components (Multimedia) for the Site Are Listed in Sections A - J

A. Final Orders, court judgments, and consent decrees:

N/A

B. Criminal convictions:

N/A

C. Chronic excessive emissions events:

N/A

D. The approval dates of investigations (CCEDS Inv. Track. No.):

Item 1 May 13, 2011 (915930)

E. Written notices of violations (NOV) (CCEDS Inv. Track. No.):

A notice of violation represents a written allegation of a violation of a specific regulatory requirement from the commission to a regulated entity. A notice of violation is not a final enforcement action, nor proof that a violation has actually occurred.

1 Date: 02/22/2013 (1123061)

CN602787509

Self Report? NO

Classification: Moderate

Citation: 30 TAC Chapter 290, SubChapter F 290.108(f)(1)
Description: COMB RAD MCL 4Q2012 - The system violated the maximum contaminant level for combined radium 226 and 228 during the 4th quarter of 2012 with a RAA of 6 pCi/L at EP002.

2 Date: 07/17/2013 (1123061) CN602787509
Self Report? NO Classification: Moderate
Citation: 30 TAC Chapter 290, SubChapter F 290.108(f)(1)
Description: COMB RAD MCL 1Q2013 - The system violated the maximum contaminant level for combined radium 226 and 228 during the 1st quarter of 2013 with a RAA of 6 pCi/L EP001.
Self Report? NO Classification: Moderate
Citation: 30 TAC Chapter 290, SubChapter F 290.108(f)(1)
Description: COMB RAD MCL 1Q2013 - The system violated the maximum contaminant level for combined radium 226 and 228 during the 1st quarter of 2013 with a RAA of 6 pCi/L EP002.

F. Environmental audits:

N/A

G. Type of environmental management systems (EMSs):

N/A

H. Voluntary on-site compliance assessment dates:

N/A

I. Participation in a voluntary pollution reduction program:

N/A

J. Early compliance:

N/A

Sites Outside of Texas:

N/A

Component Appendices

Appendix A

All NOVs Issued During Component Period 11/1/2008 and 11/1/2013

- 1 Date: 06/04/2012 (1123061) CN602787509
Classification: Moderate
Self Report? NO For Informational Purposes Only
Citation: 30 TAC Chapter 290, SubChapter F 290.108(f)(1)
Description: COMB RAD MCL 1Q2012 - The system violated the maximum contaminant level for combined radium 226 and 228 during the 1st quarter of 2012 with a RAA of 6 pCi/L at EP001.
- 2* Date: 02/22/2013 (1123061) CN602787509
Classification: Moderate
Self Report? NO For Informational Purposes Only
Citation: 30 TAC Chapter 290, SubChapter F 290.108(f)(1)
Description: COMB RAD MCL 4Q2012 - The system violated the maximum contaminant level for combined radium 226 and 228 during the 4th quarter of 2012 with a RAA of 6 pCi/L at EP002.
- 3* Date: 07/17/2013 (1123061) CN602787509
Classification: Moderate
Self Report? NO For Informational Purposes Only
Citation: 30 TAC Chapter 290, SubChapter F 290.108(f)(1)
Description: COMB RAD MCL 1Q2013 - The system violated the maximum contaminant level for combined radium 226 and 228 during the 1st quarter of 2013 with a RAA of 6 pCi/L EP001.
Classification: Moderate
Self Report? NO For Informational Purposes Only
Citation: 30 TAC Chapter 290, SubChapter F 290.108(f)(1)
Description: COMB RAD MCL 1Q2013 - The system violated the maximum contaminant level for combined radium 226 and 228 during the 1st quarter of 2013 with a RAA of 6 pCi/L EP002.

* NOVs applicable for the Compliance History rating period 9/1/2008 to 8/31/2013

Appendix B

All Investigations Conducted During Component Period November 01, 2008 and November 01, 2013

- (915930)
Item 1* May 13, 2011** For Informational Purposes Only
- (1123061)
Item 2 October 15, 2013 For Informational Purposes Only
- (1123828)
Item 3 October 18, 2013 For Informational Purposes Only

* No violations documented during this investigation

**Investigation applicable for the Compliance History Rating period between 09/01/2008 and 08/31/2013.

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



IN THE MATTER OF AN
ENFORCEMENT ACTION
CONCERNING
AQUA UTILITIES, INC.
RN102678950

§ BEFORE THE
§
§ TEXAS COMMISSION ON
§
§ ENVIRONMENTAL QUALITY

AGREED ORDER
DOCKET NO. 2013-2043-PWS-E

At its _____ agenda, the Texas Commission on Environmental Quality ("the Commission" or "TCEQ") considered this agreement of the parties, resolving an enforcement action regarding Aqua Utilities, Inc. (the "Respondent") under the authority of TEX. HEALTH & SAFETY CODE ch. 341. The Executive Director of the TCEQ, through the Enforcement Division, and the Respondent presented this agreement to the Commission.

The Respondent understands that it has certain procedural rights at certain points in the enforcement process, including, but not limited to, the right to formal notice of violations, notice of an evidentiary hearing, the right to an evidentiary hearing, and a right to appeal. By entering into this Agreed Order, the Respondent agrees to waive all notice and procedural rights.

It is further understood and agreed that this Order represents the complete and fully-integrated settlement of the parties. The provisions of this Agreed Order are deemed severable and, if a court of competent jurisdiction or other appropriate authority deems any provision of this Agreed Order unenforceable, the remaining provisions shall be valid and enforceable. The duties and responsibilities imposed by this Agreed Order are binding upon the Respondent.

The Commission makes the following Findings of Fact and Conclusions of Law:

I. FINDINGS OF FACT

1. The Respondent owns and operates a public water supply located five miles west of Comfort on United States Highway 87 in Kerr County, Texas (the "Facility") that has approximately 101 service connections and serves at least 25 people per day for at least 60 days per year.

2. During a record review conducted on September 30, 2013, TCEQ staff documented that the running annual average concentration for combined radium-226 and radium-228 was 6 picoCuries per liter ("pCi/L") for the first quarter 2012 and 6 pCi/L for the first quarter of 2013 at entry point No. 1, and the running annual average concentration for the combined radium-226 and radium-228 was 6 pCi/L for the fourth quarter of 2012 and 6 pCi/L for the first quarter of 2013 at entry point No. 2.
3. The Respondent received notice of the violations on October 21, 2013.
4. The Executive Director recognizes that on September 5, 2012, the Respondent gained conditional approval from the TCEQ for a pilot study to remove the combined radium-226 and radium-228 from the entry point No. 1 and entry point No. 2.

II. CONCLUSIONS OF LAW

1. The Respondent is subject to the jurisdiction of the TCEQ pursuant to TEX. HEALTH & SAFETY CODE ch. 341 and the rules of the Commission.
2. As evidenced by Findings of Fact No. 2, the Respondent failed to comply with the maximum contaminant level ("MCL") of 5 pCi/L for combined radium-226 and radium-228, based on the running annual average, in violation of 30 TEX. ADMIN. CODE § 290.108(f)(1) and TEX. HEALTH & SAFETY CODE § 341.0315(c).
3. Pursuant to TEX. HEALTH & SAFETY CODE § 341.049, the Commission has the authority to assess an administrative penalty against the Respondent for violations of the Texas Water Code and the Texas Health and Safety Code within the Commission's jurisdiction; for violations of rules adopted under such statutes; or for violations of orders or permits issued under such statutes.
4. An administrative penalty in the amount of Nine Hundred Ninety Dollars (\$990) is justified by the facts recited in this Agreed Order, and considered in light of the factors set forth in TEX. HEALTH & SAFETY CODE § 341.049(b). Nine Hundred Ninety Dollars (\$990) of the administrative penalty is deferred contingent upon the Respondent's timely and satisfactory compliance with all the terms of this Agreed Order and shall be waived only upon full compliance with all the the terms and conditions contained in this Agreed Order. If the Respondent fails to timely and satisfactorily comply with any requirement contained in this Agreed Order, the deferred amount of the administrative penalty shall become immediately due and payable without demand or notice, and the Executive Director may request the Respondent to pay all or part of the deferred administrative penalty.

III. ORDERING PROVISIONS

NOW, THEREFORE, THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY ORDERS that:

1. The Respondent is assessed an administrative penalty in the amount of Nine Hundred Ninety Dollars (\$990) as set forth in Section II, Paragraph 4 above, for violations of TCEQ rules and state statutes. The payment of this administrative penalty and the Respondent's compliance with all the terms and conditions set forth in this Agreed Order completely resolve the violations set forth by this Agreed Order in this action. However, the Commission shall not be constrained in any manner from requiring corrective actions or penalties for other violations that are not raised here. Administrative penalty payments shall be made payable to "TCEQ" and shall be sent with the notation "Re: Aqua Utilities, Inc., Docket No. 2013-2043-PWS-E" to:

Financial Administration Division, Revenue Operations Section
Attention: Cashier's Office, MC 214
Texas Commission on Environmental Quality
P.O. Box 13088
Austin, Texas 78711-3088

2. The Respondent shall undertake the following technical requirements:
 - a. Within 180 days after the effective date of this Agreed Order, submit an acceptable written plan, including a proposed schedule, to the Executive Director that provides for the completion of an alternate water source or treatment technology to the addresses listed in Ordering Provision No. 2.e.;
 - b. Within 180 days after the effective date of this Agreed Order, and on a semi-annual basis thereafter, submit progress reports to the addresses listed in Ordering Provision No. 2.e. below. These reports shall include information regarding actions taken to provide water which meets the MCL for combined radium-226 and radium-228;
 - c. Within 195 days after the effective date of this Agreed Order, submit written certification as described in Ordering Provision No. 2.e. below to demonstrate compliance with Ordering Provision No. 2.a.;
 - d. Within 1,095 days after the effective date of this Agreed Order, return to compliance with the MCL for combined radium-226 and radium-228, in accordance with 30 TEX. ADMIN. CODE § 290.108; and
 - e. Within 1,110 days after the effective date of this Agreed Order, submit written certification as described below, and include detailed supporting documentation including photographs, receipts, and/or other records to demonstrate compliance with Ordering Provision No. 2.d. The certification shall be notarized by a State of Texas Notary Public and include the following certification language:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

The certification shall be submitted to:

Order Compliance Team
Enforcement Division, MC 149A
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

with a copy to:

Public Drinking Water Section Manager
Water Supply Division, MC 155
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

and to:

Technical Review and Oversight Team
Water Supply Division, MC 159
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

3. The provisions of this Agreed Order shall apply to and be binding upon the Respondent. The Respondent is ordered to give notice of the Agreed Order to personnel who maintain day-to-day control over the Facility operations referenced in this Agreed Order.
4. The Executive Director may grant an extension of any deadline in this Agreed Order or in any plan, report, or other document submitted pursuant to this Agreed Order, upon a written and substantiated showing of good cause. All requests for extensions by the Respondent shall be made in writing to the Executive Director. Extensions are not effective until the Respondent receives written approval from the Executive Director. The determination of what constitutes good cause rests solely with the Executive Director.
5. The Executive Director may refer this matter to the Office of the Attorney General of the State of Texas ("OAG") for further enforcement proceedings without notice to the Respondent if the Executive Director determines that the Respondent has not complied with one or more of the terms or conditions in this Agreed Order.

6. This Agreed Order shall terminate five years from its effective date or upon compliance with all the terms and conditions set forth in this Agreed Order, whichever is later.
7. This Agreed Order, issued by the Commission, shall not be admissible against the Respondent in a civil proceeding, unless the proceeding is brought by the OAG to: (1) enforce the terms of this Agreed Order; or (2) pursue violations of a statute within the Commission's jurisdiction, or of a rule adopted or an order or permit issued by the Commission under such a statute.
8. This Agreed Order may be executed in separate and multiple counterparts, which together shall constitute a single instrument. Any page of this Agreed Order may be copied, scanned, digitized, converted to electronic portable document format ("pdf"), or otherwise reproduced and may be transmitted by digital or electronic transmission, including but not limited to facsimile transmission and electronic mail. Any signature affixed to this Agreed Order shall constitute an original signature for all purposes and may be used, filed, substituted, or issued for any purpose for which an original signature could be used. The term "signature" shall include manual signatures and true and accurate reproductions of manual signatures created, executed, endorsed, adopted, or authorized by the person or persons to whom the signatures are attributable. Signatures may be copied or reproduced digitally, electronically, by photocopying, engraving, imprinting, lithographing, electronic mail, facsimile transmission, stamping, or any other means or process which the Executive Director deems acceptable. In this paragraph exclusively, the terms "electronic transmission", "owner", "person", "writing", and "written" shall have the meanings assigned to them under TEX. BUS. ORG. CODE § 1.002.
9. The Chief Clerk shall provide a copy of this Agreed Order to each of the parties. By law, the effective date of this Agreed Order is the third day after the mailing date, as provided by 30 TEX. ADMIN. CODE § 70.10(b) and TEX. GOV'T CODE § 2001.142.

SIGNATURE PAGE

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

For the Commission

Pamela Martin
For the Executive Director

5/2/14
Date

I, the undersigned, have read and understand the attached Agreed Order in the matter of Aqua Utilities, Inc. I am authorized to agree to the attached Agreed Order on behalf of Aqua Utilities, Inc., and do agree to the specified terms and conditions. I further acknowledge that the TCEQ, in accepting payment for the penalty amount, is materially relying on such representation.

I understand that by entering into this Agreed Order, Aqua Utilities, Inc., waives certain procedural rights, including, but not limited to, the right to formal notice of violations addressed by this Agreed Order, notice of an evidentiary hearing, the right to an evidentiary hearing, and the right to appeal. I agree to the terms of the Agreed Order in lieu of an evidentiary hearing. This Agreed Order constitutes full and final adjudication by the Commission of the violations set forth in this Agreed Order.

I also understand that failure to comply with the Ordering Provisions, if any, in this order and/or failure to timely pay the penalty amount, may result in:

- A negative impact on compliance history;
- Greater scrutiny of any permit applications submitted;
- Referral of this case to the Attorney General's Office for contempt, injunctive relief, additional penalties, and/or attorney fees, or to a collection agency;
- Increased penalties in any future enforcement actions;
- Automatic referral to the Attorney General's Office of any future enforcement actions; and
- TCEQ seeking other relief as authorized by law.

In addition, any falsification of any compliance documents may result in criminal prosecution.

LM
R.L. Laughman
Signature

February 6, 2014
Date

R.L. Laughman
Name (Printed or typed)
Authorized Representative of
Aqua Utilities, Inc.

President
Title

Instructions: Send the original, signed Agreed Order with penalty payment to the Financial Administration Division, Revenue Operations Section at the address in Section III, Paragraph 1 of this Agreed Order.