

Executive Summary – Enforcement Matter – Case No. 48143
Mohammad Aleem dba Camden Store
RN102266442
Docket No. 2014-0091-PST-E

Order Type:

1660 Agreed Order

Findings Order Justification:

N/A

Media:

PST

Small Business:

Yes

Location(s) Where Violation(s) Occurred:

Camden Store, 11900 Veterans Memorial Drive, Houston, Harris County

Type of Operation:

Convenience store with retail sales of gasoline

Other Significant Matters:

Additional Pending Enforcement Actions: No

Past-Due Penalties: No

Other: N/A

Interested Third-Parties: None

Texas Register Publication Date: June 6, 2014

Comments Received: No

Penalty Information

Total Penalty Assessed: \$9,042

Amount Deferred for Expedited Settlement: \$1,808

Amount Deferred for Financial Inability to Pay: \$0

Total Paid to General Revenue: \$234

Total Due to General Revenue: \$7,000

Payment Plan: 35 payments of \$200 each

SEP Conditional Offset: \$0

Name of SEP: N/A

Compliance History Classifications:

Person/CN - Unsatisfactory

Site/RN - Unsatisfactory

Major Source: No

Statutory Limit Adjustment: N/A

Applicable Penalty Policy: September 2011

**Executive Summary – Enforcement Matter – Case No. 48143
Mohammad Aleem dba Camden Store
RN102266442
Docket No. 2014-0091-PST-E**

Investigation Information

Complaint Date(s): N/A

Complaint Information: N/A

Date(s) of Investigation: September 4, 2013 and October 4, 2013

Date(s) of NOE(s): December 20, 2013

Violation Information

1. Failed to verify proper operation of the Stage II equipment at least once every 12 months. Specifically, the Stage II annual compliance testing had not been conducted by the due date of October 14, 2012 [30 TEX. ADMIN. CODE § 115.245(2) and TEX. HEALTH & SAFETY CODE § 382.085(b)].
2. Failed to maintain the Stage II vapor recovery system in proper operating condition, as specified by the manufacturer and/or any applicable California Air Resources Board Executive Order, and free of defects that would impair the effectiveness of the system. Specifically, the vapor hoses on dispensers 1, 2, 3, and 4, and the whip hoses on dispensers 2 and 3 were cracked, and vapor leaks were detected [30 TEX. ADMIN. CODE § 115.242(d)(3) and (4) and TEX. HEALTH & SAFETY CODE § 382.085(b)].
3. Failed to conduct daily inspections of the Stage II vapor recovery system [30 TEX. ADMIN CODE § 115.244(1) and TEX. HEALTH & SAFETY CODE § 382.085(b)].

Corrective Actions/Technical Requirements

Corrective Action(s) Completed:

The Respondent has implemented the following corrective measures:

- a. Conducted the required Stage II annual compliance testing with passing results on October 11, 2013;
- b. Replaced the damaged Stage II vapor hoses on October 11, 2013; and
- c. Began conducting daily inspections of the Stage II equipment on September 20, 2013.

Technical Requirements:

N/A

Litigation Information

Date Petition(s) Filed: N/A

Date Answer(s) Filed: N/A

SOAH Referral Date: N/A

Hearing Date(s): N/A

Settlement Date: N/A

Executive Summary – Enforcement Matter – Case No. 48143
Mohammad Aleem dba Camden Store
RN102266442
Docket No. 2014-0091-PST-E

Contact Information

TCEQ Attorney: N/A

TCEQ Enforcement Coordinator: Rebecca Boyett, Enforcement Division,
Enforcement Team 7, MC 128, (512) 239-2503; Candy Garrett, Enforcement Division,
MC 219, (512) 239-1456

TCEQ SEP Coordinator: N/A

Respondent: Mohammad Aleem, Owner, Camden Store, 11900 Veterans Memorial
Drive, Houston, Texas 77067

Respondent's Attorney: N/A



Penalty Calculation Worksheet (PCW)

Policy Revision 3 (September 2011)

PCW Revision August 3, 2011

TCEQ

DATES	Assigned	6-Jan-2014	Screening	9-Jan-2014	EPA Due	
	PCW	16-Jan-2014				

RESPONDENT/FACILITY INFORMATION

Respondent	Mohammad Aleem dba Camden Store		
Reg. Ent. Ref. No.	RN102266442		
Facility/Site Region	12-Houston	Major/Minor Source	Minor

CASE INFORMATION

Enf./Case ID No.	48143	No. of Violations	3
Docket No.	2014-0091-PST-E	Order Type	1660
Media Program(s)	Petroleum Storage Tank	Government/Non-Profit	No
Multi-Media		Enf. Coordinator	Rebecca Boyett
		EC's Team	Enforcement Team 7
Admin. Penalty \$ Limit Minimum	\$0	Maximum	\$25,000

Penalty Calculation Section

TOTAL BASE PENALTY (Sum of violation base penalties)	Subtotal 1	\$6,250
-------------------------------------------------------------	-------------------	---------

ADJUSTMENTS (+/-) TO SUBTOTAL 1

Subtotals 2-7 are obtained by multiplying the Total Base Penalty (Subtotal 1) by the indicated percentage.

Compliance History	55.0% Enhancement	Subtotals 2, 3, & 7	\$3,437
---------------------------	-------------------	--------------------------------	---------

Notes: Enhancement for unsatisfactory performer classification, one order with denial of liability, and one order without denial of liability.

Culpability	No	0.0% Enhancement	Subtotal 4	\$0
--------------------	----	------------------	-------------------	-----

Notes: The Respondent does not meet the culpability criteria.

Good Faith Effort to Comply Total Adjustments	Subtotal 5	-\$1,561
------------------------------------------------------	-------------------	----------

Economic Benefit	0.0% Enhancement*	Subtotal 6	\$0
-------------------------	-------------------	-------------------	-----

Total EB Amounts \$918
Approx. Cost of Compliance \$2,250
*Capped at the Total EB \$ Amount

SUM OF SUBTOTALS 1-7	Final Subtotal	\$8,126
-----------------------------	-----------------------	---------

OTHER FACTORS AS JUSTICE MAY REQUIRE	11.3%	Adjustment	\$916
---------------------------------------------	-------	-------------------	-------

Reduces or enhances the Final Subtotal by the indicated percentage.

Notes: Recommended enhancement to capture the avoided cost of compliance associated with violation nos. 1 and 3.

Final Penalty Amount	\$9,042
-----------------------------	---------

STATUTORY LIMIT ADJUSTMENT	Final Assessed Penalty	\$9,042
-----------------------------------	-------------------------------	---------

DEFERRAL	20.0% Reduction	Adjustment	-\$1,808
-----------------	-----------------	-------------------	----------

Reduces the Final Assessed Penalty by the indicated percentage. (Enter number only; e.g. 20 for 20% reduction.)

Notes: Deferral offered for expedited settlement.

PAYABLE PENALTY	\$7,234
------------------------	---------

Screening Date 9-Jan-2014

Docket No. 2014-0091-PST-E

PCW

Respondent Mohammad Aleem dba Camden Store

Policy Revision 3 (September 2011)

Case ID No. 48143

PCW Revision August 3, 2011

Reg. Ent. Reference No. RN102266442

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Rebecca Boyett

Compliance History Worksheet

>> **Compliance History Site Enhancement (Subtotal 2)**

Component	Number of...	Enter Number Here	Adjust.
NOVs	Written notices of violation ("NOVs") with same or similar violations as those in the current enforcement action (<i>number of NOVs meeting criteria</i>)	0	0%
	Other written NOVs	0	0%
Orders	Any agreed final enforcement orders containing a denial of liability (<i>number of orders meeting criteria</i>)	1	20%
	Any adjudicated final enforcement orders, agreed final enforcement orders without a denial of liability, or default orders of this state or the federal government, or any final prohibitory emergency orders issued by the commission	1	25%
Judgments and Consent Decrees	Any non-adjudicated final court judgments or consent decrees containing a denial of liability of this state or the federal government (<i>number of judgments or consent decrees meeting criteria</i>)	0	0%
	Any adjudicated final court judgments and default judgments, or non-adjudicated final court judgments or consent decrees without a denial of liability, of this state or the federal government	0	0%
Convictions	Any criminal convictions of this state or the federal government (<i>number of counts</i>)	0	0%
Emissions	Chronic excessive emissions events (<i>number of events</i>)	0	0%
Audits	Letters notifying the executive director of an intended audit conducted under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which notices were submitted</i>)	0	0%
	Disclosures of violations under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which violations were disclosed</i>)	0	0%
<i>Please Enter Yes or No</i>			
Other	Environmental management systems in place for one year or more	No	0%
	Voluntary on-site compliance assessments conducted by the executive director under a special assistance program	No	0%
	Participation in a voluntary pollution reduction program	No	0%
	Early compliance with, or offer of a product that meets future state or federal government environmental requirements	No	0%

Adjustment Percentage (Subtotal 2) 45%

>> **Repeat Violator (Subtotal 3)**

No

Adjustment Percentage (Subtotal 3) 0%

>> **Compliance History Person Classification (Subtotal 7)**

Unsatisfactory Performer

Adjustment Percentage (Subtotal 7) 10%

>> **Compliance History Summary**

Compliance History Notes

Enhancement for unsatisfactory performer classification, one order with denial of liability, and one order without denial of liability.

Total Compliance History Adjustment Percentage (Subtotals 2, 3, & 7) 55%

>> **Final Compliance History Adjustment**

Final Adjustment Percentage *capped at 100% 55%

Screening Date 9-Jan-2014

Docket No. 2014-0091-PST-E

PCW

Respondent Mohammad Aleem dba Camden Store

Policy Revision 3 (September 2011)

Case ID No. 48143

PCW Revision August 3, 2011

Reg. Ent. Reference No. RN102266442

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Rebecca Boyett

Violation Number 1

Rule Cite(s)

30 Tex. Admin. Code § 115.245(2) and Tex. Health & Safety Code § 382.085(b)

Violation Description

Failed to verify proper operation of the Stage II equipment at least once every 12 months. Specifically, the Stage II annual compliance testing had not been conducted by the due date of October 14, 2012.

Base Penalty \$25,000

>> Environmental, Property and Human Health Matrix

OR

Release	Harm		
	Major	Moderate	Minor
Actual			
Potential	x		

Percent 15.0%

>> Programmatic Matrix

Falsification	Harm		
	Major	Moderate	Minor

Percent 0.0%

Matrix Notes

Human health or the environment will or could be exposed to pollutants which would exceed levels that are protective of human health or environmental receptors as a result of the violation.

Adjustment \$21,250

\$3,750

Violation Events

Number of Violation Events 1

362 Number of violation days

mark only one with an x

daily	
weekly	
monthly	
quarterly	
semiannual	
annual	x
single event	

Violation Base Penalty \$3,750

One annual event is recommended for the period preceding the October 4, 2013 investigation.

Good Faith Efforts to Comply

25.0% Reduction

\$937

	Before NOV	NOV to EDPRP/Settlement Offer
	Extraordinary	
Ordinary	x	
N/A		(mark with x)

Notes

The Respondent achieved compliance on October 11, 2013, prior to the Notice of Enforcement dated December 20, 2013.

Violation Subtotal \$2,813

Economic Benefit (EB) for this violation

Statutory Limit Test

Estimated EB Amount \$548

Violation Final Penalty Total \$5,425

This violation Final Assessed Penalty (adjusted for limits) \$5,425

Economic Benefit Worksheet

Respondent Mohammad Aleem dba Camden Store
Case ID No. 48143
Reg. Ent. Reference No. RN102266442
Media Petroleum Storage Tank
Violation No. 1

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
No commas or \$							

Delayed Costs

Equipment				0.00	\$0	\$0	\$0
Buildings				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0
Engineering/construction				0.00	\$0	\$0	\$0
Land				0.00	\$0	n/a	\$0
Record Keeping System				0.00	\$0	n/a	\$0
Training/Sampling				0.00	\$0	n/a	\$0
Remediation/Disposal				0.00	\$0	n/a	\$0
Permit Costs				0.00	\$0	n/a	\$0
Other (as needed)				0.00	\$0	n/a	\$0

Notes for DELAYED costs

Avoided Costs

ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)

Disposal				0.00	\$0	\$0	\$0
Personnel				0.00	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.00	\$0	\$0	\$0
Supplies/equipment				0.00	\$0	\$0	\$0
Financial Assurance [2]				0.00	\$0	\$0	\$0
ONE-TIME avoided costs [3]	\$500	14-Oct-2012	11-Oct-2013	1.91	\$48	\$500	\$548
Other (as needed)				0.00	\$0	\$0	\$0

Notes for AVOIDED costs

Estimated avoided cost for testing the Stage II equipment. The Date Required is the date Stage II testing was due, and the Final Date is the date of compliance.

Approx. Cost of Compliance

\$500

TOTAL

\$548

Screening Date 9-Jan-2014

Docket No. 2014-0091-PST-E

PCW

Respondent Mohammad Aleem dba Camden Store

Policy Revision 3 (September 2011)

Case ID No. 48143

PCW Revision August 3, 2011

Reg. Ent. Reference No. RN102266442

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Rebecca Boyett

Violation Number 2

Rule Cite(s) 30 Tex. Admin. Code § 115.242(d)(3) and (4) and Tex. Health & Safety Code § 382.085(b)

Violation Description

Failed to maintain the Stage II vapor recovery system in proper operating condition, as specified by the manufacturer and/or any applicable California Air Resources Board Executive Order, and free of defects that would impair the effectiveness of the system. Specifically, the vapor hoses on dispensers 1, 2, 3, and 4, and the whip hoses on dispensers 2 and 3 were cracked, and vapor leaks were detected.

Base Penalty \$25,000

>> Environmental, Property and Human Health Matrix

OR

Release	Harm		
	Major	Moderate	Minor
Actual			x
Potential			

Percent 5.0%

>> Programmatic Matrix

Falsification	Major	Moderate	Minor

Percent 0.0%

Matrix Notes

Human health or the environment has been exposed to insignificant amounts of pollutants which do not exceed levels that are protective of human health or environmental receptors as a result of this violation.

Adjustment \$23,750

\$1,250

Violation Events

Number of Violation Events 1

7 Number of violation days

mark only one with an x	daily	
	weekly	
	monthly	
	quarterly	x
	semiannual	
	annual	
	single event	

Violation Base Penalty \$1,250

One quarterly event is recommended from the October 4, 2013 investigation date to the October 11, 2013 compliance date.

Good Faith Efforts to Comply

25.0% Reduction

\$312

	Before NOV	NOV to EDPRP/Settlement Offer
Extraordinary		
Ordinary	x	
N/A		(mark with x)

Notes The Respondent achieved compliance on October 11, 2013, prior to the Notice of Enforcement dated December 20, 2013.

Violation Subtotal \$938

Economic Benefit (EB) for this violation

Statutory Limit Test

Estimated EB Amount \$2

Violation Final Penalty Total \$1,809

This violation Final Assessed Penalty (adjusted for limits) \$1,809

Economic Benefit Worksheet

Respondent Mohammad Aleem dba Camden Store
Case ID No. 48143
Reg. Ent. Reference No. RN102266442
Media Petroleum Storage Tank
Violation No. 2

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
No commas or \$							

Delayed Costs

	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
Equipment	\$1,400	4-Oct-2013	11-Oct-2013	0.02	\$0	\$2	\$2
Buildings				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0
Engineering/construction				0.00	\$0	\$0	\$0
Land				0.00	\$0	n/a	\$0
Record Keeping System				0.00	\$0	n/a	\$0
Training/Sampling				0.00	\$0	n/a	\$0
Remediation/Disposal				0.00	\$0	n/a	\$0
Permit Costs				0.00	\$0	n/a	\$0
Other (as needed)				0.00	\$0	n/a	\$0

Notes for DELAYED costs

Estimated cost to replace the damaged Stage II hoses. The Date Required is the investigation date, and the Final Date is the date of compliance.

Avoided Costs

ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)

	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
Disposal				0.00	\$0	\$0	\$0
Personnel				0.00	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.00	\$0	\$0	\$0
Supplies/equipment				0.00	\$0	\$0	\$0
Financial Assurance [2]				0.00	\$0	\$0	\$0
ONE-TIME avoided costs [3]				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0

Notes for AVOIDED costs

Approx. Cost of Compliance

\$1,400

TOTAL

\$2

Screening Date 9-Jan-2014

Docket No. 2014-0091-PST-E

PCW

Respondent Mohammad Aleem dba Camden Store

Policy Revision 3 (September 2011)

Case ID No. 48143

PCW Revision August 3, 2011

Reg. Ent. Reference No. RN102266442

Media [Statute] Petroleum Storage Tank

Enf. Coordinator Rebecca Boyett

Violation Number 3

Rule Cite(s)

30 Tex. Admin Code § 115.244(1) and Tex. Health & Safety Code § 382.085(b)

Violation Description

Failed to conduct daily inspections of the Stage II vapor recovery system.

Base Penalty \$25,000

>> Environmental, Property and Human Health Matrix

OR

Release	Harm		
	Major	Moderate	Minor
Actual			
Potential		x	

Percent 5.0%

>> Programmatic Matrix

Falsification	Major	Moderate	Minor

Percent 0.0%

Matrix Notes

Human health or the environment will or could be exposed to significant amounts of pollutants which would not exceed levels that are protective of human health or environmental receptors as a result of the violation.

Adjustment \$23,750

\$1,250

Violation Events

Number of Violation Events 1

16 Number of violation days

daily	
weekly	
monthly	
quarterly	x
semiannual	
annual	
single event	

mark only one with an x

Violation Base Penalty \$1,250

One quarterly event is recommended from the September 4, 2013 investigation date to the September 20, 2013 compliance date.

Good Faith Efforts to Comply

25.0% Reduction

\$312

	Before NOV	NOV to EDRP/Settlement Offer
Extraordinary		
Ordinary	x	
N/A		(mark with x)

Notes The Respondent achieved compliance on September 20, 2013, prior to the Notice of Enforcement dated December 20, 2013.

Violation Subtotal \$938

Economic Benefit (EB) for this violation

Statutory Limit Test

Estimated EB Amount \$368

Violation Final Penalty Total \$1,809

This violation Final Assessed Penalty (adjusted for limits) \$1,809

Economic Benefit Worksheet

Respondent Mohammad Aleem dba Camden Store
Case ID No. 48143
Reg. Ent. Reference No. RN102266442
Media Violation No. 3
Media Petroleum Storage Tank

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
No commas or \$							

Delayed Costs

Equipment				0.00	\$0	\$0	\$0
Buildings				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0
Engineering/construction				0.00	\$0	\$0	\$0
Land				0.00	\$0	n/a	\$0
Record Keeping System				0.00	\$0	n/a	\$0
Training/Sampling				0.00	\$0	n/a	\$0
Remediation/Disposal				0.00	\$0	n/a	\$0
Permit Costs				0.00	\$0	n/a	\$0
Other (as needed)				0.00	\$0	n/a	\$0

Notes for DELAYED costs

Avoided Costs

ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)

Disposal				0.00	\$0	\$0	\$0
Personnel				0.00	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.00	\$0	\$0	\$0
Supplies/equipment				0.00	\$0	\$0	\$0
Financial Assurance [2]				0.00	\$0	\$0	\$0
ONE-TIME avoided costs [3]	\$350	4-Aug-2013	20-Sep-2013	1.05	\$18	\$350	\$368
Other (as needed)				0.00	\$0	\$0	\$0

Notes for AVOIDED costs

Estimated avoided cost to conduct the required inspections of the components of the Stage II vapor recovery system. The Date Required is one month prior to the investigation date and the Final Date is the compliance date.

Approx. Cost of Compliance

\$350

TOTAL

\$368



Compliance History Report

PUBLISHED Compliance History Report for CN603848649, RN102266442, Rating Year 2013 which includes Compliance History (CH) components from September 1, 2008, through August 31, 2013.

Customer, Respondent, or Owner/Operator: CN603848649, Aleem, Mohammad **Classification:** UNSATISFACTORY **Rating:** 104.00

Regulated Entity: RN102266442, CAMDEN STORE **Classification:** UNSATISFACTORY **Rating:** 104.00

Complexity Points: 4 **Repeat Violator:** NO

CH Group: 14 - Other

Location: 11900 VETERANS MEMORIAL DR HOUSTON, TX 77067-1834, HARRIS COUNTY

TCEQ Region: REGION 12 - HOUSTON

ID Number(s):
PETROLEUM STORAGE TANK REGISTRATION REGISTRATION 43970

Compliance History Period: September 01, 2008 to August 31, 2013 **Rating Year:** 2013 **Rating Date:** 09/01/2013

Date Compliance History Report Prepared: January 16, 2014

Agency Decision Requiring Compliance History: Enforcement

Component Period Selected: January 09, 2009 to January 09, 2014

TCEQ Staff Member to Contact for Additional Information Regarding This Compliance History.

Name: Rebecca Boyett **Phone:** (512) 239-2503

Site and Owner/Operator History:

- 1) Has the site been in existence and/or operation for the full five year compliance period? YES
- 2) Has there been a (known) change in ownership/operator of the site during the compliance period? YES
- 3) If YES for #2, who is the current owner/operator? First Interstate Bank of Texas, N. A. OWNER since 1/1/1800
ALEEM, MOHAMMAD OWNER OPERATOR since 11/20/2010
- 4) If YES for #2, who was/were the prior owner(s)/operator(s)? HOUSTON CORNER STORE INC, OWNER OPERATOR, 11/21/2006 to 11/19/2010
- 5) If YES, when did the change(s) in owner or operator occur? 11/20/2010

Components (Multimedia) for the Site Are Listed in Sections A - J

A. Final Orders, court judgments, and consent decrees:

- 1 Effective Date: 05/28/2011 ADMINORDER 2010-0914-PST-E (Findings Order-Default)
Classification: Minor
Citation: 30 TAC Chapter 334, SubChapter A 334.10(b)
30 TAC Chapter 334, SubChapter A 334.12
Description: Failed to maintain UST records and make them immediately available for inspection upon request by agency personnel. Specifically, the certificate of insurance, release detection records, and inventory control records were not available for review.
Classification: Moderate
Citation: 2D TWC Chapter 26, SubChapter A 26.3475(d)
30 TAC Chapter 334, SubChapter C 334.49(c)(4)(C)
Description: Failed to inspect and test the cathodic protection system for operability and adequacy of protection at a frequency of at least once every three years. Specifically, the triennial test had not been conducted.
Classification: Moderate
Citation: 2D TWC Chapter 26, SubChapter A 26.3475(c)(1)
30 TAC Chapter 334, SubChapter C 334.50(b)(1)(A)
Description: Failed to ensure that all USTs are monitored in a manner which will detect a release at a frequency of at least once every month (not to exceed 35 days between each monitoring).

Classification: Moderate

Citation: 2D TWC Chapter 26, SubChapter A 26.3475(c)(2)
30 TAC Chapter 334, SubChapter C 334.51(b)(2)(C)

Description: Failed to equip each tank with a valve or other device designed to automatically shut off the flow of regulated substances into the tank when the liquid level in the tank reaches no higher than 95% capacity.

Classification: Moderate

Citation: 30 TAC Chapter 334, SubChapter C 334.42(i)

Description: Failed to inspect all sumps including the dispenser sumps, manways, overspill containers, or catchment basins associated with the UST system at least once every 60 days to assure that the sides, bottoms, and any penetration points are maintained liquid-tight and free of any liquid or debris.

Classification: Moderate

Citation: 2D TWC Chapter 26, SubChapter A 26.3467(a)
30 TAC Chapter 334, SubChapter A 334.8(c)(5)(A)(i)

Description: Failed to make available to a common carrier a valid, current TCEQ delivery certificate before accepting delivery of a regulated substance into the UST.

Classification: Moderate

Citation: 30 TAC Chapter 334, SubChapter A 334.8(c)(4)(A)(vii)
30 TAC Chapter 334, SubChapter A 334.8(c)(5)(B)(ii)

Description: Failed to timely renew a previously issued UST delivery certificate by submitting a properly completed UST registration and self-certification form at least 30 days before the expiration date.

2 Effective Date: 08/08/2013 ADMINORDER 2013-0020-PST-E (1660 Order-Agreed Order With Denial)

Classification: Moderate

Citation: 2D TWC Chapter 26, SubChapter A 26.3475(d)
30 TAC Chapter 334, SubChapter C 334.49(a)(1)

Description: Failure to have corrosion protection for the UST system.

B. Criminal convictions:

N/A

C. Chronic excessive emissions events:

N/A

D. The approval dates of investigations (CCEDS Inv. Track. No.):

N/A

E. Written notices of violations (NOV) (CCEDS Inv. Track. No.):

A notice of violation represents a written allegation of a violation of a specific regulatory requirement from the commission to a regulated entity. A notice of violation is not a final enforcement action, nor proof that a violation has actually occurred.

N/A

F. Environmental audits:

N/A

G. Type of environmental management systems (EMSs):

N/A

H. Voluntary on-site compliance assessment dates:

N/A

I. Participation in a voluntary pollution reduction program:

N/A

J. Early compliance:

N/A

Sites Outside of Texas:

N/A

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



**IN THE MATTER OF AN
ENFORCEMENT ACTION
CONCERNING
MOHAMMAD ALEEM DBA
CAMDEN STORE
RN102266442**

§
§
§
§
§
§

**BEFORE THE
TEXAS COMMISSION ON
ENVIRONMENTAL QUALITY**

**AGREED ORDER
DOCKET NO. 2014-0091-PST-E**

I. JURISDICTION AND STIPULATIONS

On _____, the Texas Commission on Environmental Quality ("the Commission" or "TCEQ") considered this agreement of the parties, resolving an enforcement action regarding Mohammad Aleem dba Camden Store ("Respondent") under the authority of TEX. HEALTH & SAFETY CODE ch. 382 and TEX. WATER CODE ch. 7. The Executive Director of the TCEQ, through the Enforcement Division, and the Respondent together stipulate that:

1. The Respondent owns and operates a convenience store with retail sales of gasoline at 11900 Veterans Memorial Drive in Houston, Harris County, Texas (the "Station").
2. The Station consists of one or more sources as defined in TEX. HEALTH & SAFETY CODE §382.003(12).
3. The Executive Director and the Respondent agree that the Commission has jurisdiction to enter this Agreed Order, and that the Respondent is subject to the Commission's jurisdiction.
4. The Respondent received notice of the violations alleged in Section II ("Allegations") on or about December 26, 2013.
5. The occurrence of any violation is in dispute and the entry of this Agreed Order shall not constitute an admission by the Respondent of any violation alleged in Section II ("Allegations"), nor of any statute or rule.
6. An administrative penalty in the amount of Nine Thousand Forty-Two Dollars (\$9,042) is assessed by the Commission in settlement of the violations alleged in Section II ("Allegations"). The Respondent has paid Two Hundred Thirty-Four Dollars (\$234) of

the administrative penalty and One Thousand Eight Hundred Eight Dollars (\$1,808) is deferred contingent upon the Respondent's timely and satisfactory compliance with all the terms of this Agreed Order. If the Respondent fails to timely and satisfactorily comply with all requirements of this Agreed Order, including the payment schedule, the Executive Director may require the Respondent to pay all or part of the deferred penalty.

The remaining amount of Seven Thousand Dollars (\$7,000) of the administrative penalty shall be payable in 35 monthly payments of Two Hundred Dollars (\$200) each. The next monthly payment shall be paid within 30 days after the effective date of this Agreed Order. The subsequent payments shall each be paid not later than 30 days following the due date of the previous payment until paid in full. If the Respondent fails to timely and satisfactorily comply with the payment requirements of this Agreed Order, the Executive Director may, at the Executive Director's option, accelerate the maturity of the remaining installments, in which event the unpaid balance shall become immediately due and payable without demand or notice. In addition, the failure of the Respondent to meet the payment schedule of this Agreed Order constitutes the failure by the Respondent to timely and satisfactorily comply with all the terms of this Agreed Order.

7. Any notice and procedures, which might otherwise be authorized or required in this action, are waived in the interest of a more timely resolution of the matter.
8. The Executive Director and the Respondent agree on a settlement of the matters alleged in this enforcement action, subject to final approval in accordance with 30 TEX. ADMIN. CODE § 70.10(a).
9. The Executive Director recognizes that the Respondent has implemented the following corrective measures at the Station:
 - a. Conducted the required Stage II annual compliance testing with passing results on October 11, 2013;
 - b. Replaced the damaged Stage II vapor hoses on October 11, 2013; and
 - c. Began conducting daily inspections of the Stage II equipment on September 20, 2013.
10. The Executive Director may, without further notice or hearing, refer this matter to the Office of the Attorney General of the State of Texas ("OAG") for further enforcement proceedings if the Executive Director determines that the Respondent has not complied with one or more of the terms or conditions in this Agreed Order.
11. This Agreed Order shall terminate five years from its effective date or upon compliance with all the terms and conditions set forth in this Agreed Order, whichever is later.
12. The provisions of this Agreed Order are deemed severable and, if a court of competent jurisdiction or other appropriate authority deems any provision of this Agreed Order unenforceable, the remaining provisions shall be valid and enforceable.

II. ALLEGATIONS

As owner and operator of the Station, the Respondent is alleged to have:

1. Failed to verify proper operation of the Stage II equipment at least once every 12 months, in violation of 30 TEX. ADMIN. CODE § 115.245(2) and TEX. HEALTH & SAFETY CODE § 382.085(b), as documented during an investigation conducted on October 4, 2013. Specifically, the Stage II annual compliance testing had not been conducted by the due date of October 14, 2012.
2. Failed to maintain the Stage II vapor recovery system in proper operating condition, as specified by the manufacturer and/or any applicable California Air Resources Board Executive Order, and free of defects that would impair the effectiveness of the system, in violation of 30 TEX. ADMIN. CODE § 115.242(d)(3) and (4) and TEX. HEALTH & SAFETY CODE § 382.085(b), as documented during an investigation conducted on October 4, 2013. Specifically, the vapor hoses on dispensers 1, 2, 3, and 4, and the whip hoses on dispensers 2 and 3 were cracked, and vapor leaks were detected.
3. Failed to conduct daily inspections of the Stage II vapor recovery system, in violation of 30 TEX. ADMIN. CODE § 115.244(1) and TEX. HEALTH & SAFETY CODE § 382.085(b), as documented during an investigation conducted on September 4, 2013.

III. DENIALS

The Respondent generally denies each allegation in Section II ("Allegations").

IV. ORDERING PROVISIONS

1. It is, therefore, ordered by the TCEQ that the Respondent pay an administrative penalty as set forth in Section I, Paragraph 6 above. The payment of this administrative penalty and the Respondent's compliance with all the terms and conditions set forth in this Agreed Order resolve only the allegations in Section II. The Commission shall not be constrained in any manner from requiring corrective action or penalties for violations which are not raised here. Administrative penalty payments shall be made payable to "TCEQ" and shall be sent with the notation "Re: Mohammad Aleem dba Camden Store, Docket No. 2014-0091-PST-E" to:

Financial Administration Division, Revenue Operations Section
Attention: Cashier's Office, MC 214
Texas Commission on Environmental Quality
P.O. Box 13088
Austin, Texas 78711-3088
2. The provisions of this Agreed Order shall apply to and be binding upon the Respondent. The Respondent is ordered to give notice of the Agreed Order to personnel who maintain day-to-day control over the Station operations referenced in this Agreed Order.

3. If the Respondent fails to comply with any of the Ordering Provisions in this Agreed Order within the prescribed schedules, and that failure is caused solely by an act of God, war, strike, riot, or other catastrophe, the Respondent's failure to comply is not a violation of this Agreed Order. The Respondent shall have the burden of establishing to the Executive Director's satisfaction that such an event has occurred. The Respondent shall notify the Executive Director within seven days after the Respondent becomes aware of a delaying event and shall take all reasonable measures to mitigate and minimize any delay.
4. The Executive Director may grant an extension of any deadline in this Agreed Order or in any plan, report, or other document submitted pursuant to this Agreed Order, upon a written and substantiated showing of good cause. All requests for extensions by the Respondent shall be made in writing to the Executive Director. Extensions are not effective until the Respondent receives written approval from the Executive Director. The determination of what constitutes good cause rests solely with the Executive Director.
5. This Agreed Order, issued by the Commission, shall not be admissible against the Respondent in a civil proceeding, unless the proceeding is brought by the OAG to: (1) enforce the terms of this Agreed Order; or (2) pursue violations of a statute within the Commission's jurisdiction, or of a rule adopted or an order or permit issued by the Commission under such a statute.
6. This Agreed Order may be executed in separate and multiple counterparts, which together shall constitute a single instrument. Any page of this Agreed Order may be copied, scanned, digitized, converted to electronic portable document format ("pdf"), or otherwise reproduced and may be transmitted by digital or electronic transmission, including but not limited to facsimile transmission and electronic mail. Any signature affixed to this Agreed Order shall constitute an original signature for all purposes and may be used, filed, substituted, or issued for any purpose for which an original signature could be used. The term "signature" shall include manual signatures and true and accurate reproductions of manual signatures created, executed, endorsed, adopted, or authorized by the person or persons to whom the signatures are attributable. Signatures may be copied or reproduced digitally, electronically, by photocopying, engraving, imprinting, lithographing, electronic mail, facsimile transmission, stamping, or any other means or process which the Executive Director deems acceptable. In this paragraph exclusively, the terms "electronic transmission", "owner", "person", "writing", and "written" shall have the meanings assigned to them under TEX. BUS. ORG. CODE § 1.002.
7. Under 30 TEX. ADMIN. CODE § 70.10(b), the effective date is the date of hand-delivery of the Order to the Respondent, or three days after the date on which the Commission mails notice of the Order to the Respondent, whichever is earlier.

ATT. REBECCA

SIGNATURE PAGE

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

For the Commission


For the Executive Director

7/7/14
Date

I, the undersigned, have read and understand the attached Agreed Order. I am authorized to agree to the attached Agreed Order on behalf of the entity indicated below my signature, and I do agree to the terms and conditions specified therein. I further acknowledge that the TCEQ, in accepting payment for the penalty amount, is materially relying on such representation.

I also understand that failure to comply with the Ordering Provisions, if any, in this order and/or failure to timely pay the penalty amount, may result in:

- A negative impact on compliance history;
- Greater scrutiny of any permit applications submitted;
- Referral of this case to the Attorney General's Office for contempt, injunctive relief, additional penalties, and/or attorney fees, or to a collection agency;
- Increased penalties in any future enforcement actions;
- Automatic referral to the Attorney General's Office of any future enforcement actions; and
- TCEQ seeking other relief as authorized by law.

In addition, any falsification of any compliance documents may result in criminal prosecution.


Signature

5-15-14
Date

Mohammad Aleem
Name (Printed or typed)
Authorized Representative of
Mohammad Aleem dba Camden Store

Owner
Title

Instructions: Send the original, signed Agreed Order with penalty payment to the Financial Administration Division, Revenue Operations Section at the address in Section IV, Paragraph 1 of this Agreed Order.