

Executive Summary – Enforcement Matter – Case No. 52082
Red River Authority of Texas
RN101237527
Docket No. 2016-0438-PWS-E

Order Type:

Findings Agreed Order

Findings Order Justification:

Three or more enforcement actions (NOVs, orders, etc.) over the prior five year period for the same violation(s).

Media:

PWS

Small Business:

No

Location(s) Where Violation(s) Occurred:

Preston Shores Water System, 208 Sherman Drive near Pottsboro, Grayson County

Type of Operation:

Public water supply

Other Significant Matters:

Additional Pending Enforcement Actions: No

Past-Due Penalties: No

Other: N/A

Interested Third-Parties: None

Texas Register Publication Date: June 3, 2016

Comments Received: No

Penalty Information

Total Penalty Assessed: \$1,260

Amount Deferred for Expedited Settlement: \$0

Amount Deferred for Financial Inability to Pay: \$0

Total Paid to General Revenue: \$1,260

Total Due to General Revenue: \$0

Payment Plan: N/A

Supplemental Environmental Project ("SEP") Conditional Offset: \$0

Name of SEP: N/A

Compliance History Classifications:

Person/CN - High

Site/RN - N/A

Major Source: Yes

Statutory Limit Adjustment: N/A

Applicable Penalty Policy: April 2014

Executive Summary – Enforcement Matter – Case No. 52082
Red River Authority of Texas
RN101237527
Docket No. 2016-0438-PWS-E

Investigation Information

Complaint Date(s): N/A

Complaint Information: N/A

Date(s) of Investigation: March 7 through March 18, 2016

Date(s) of NOE(s): March 18, 2016

Violation Information

1. Failed to comply with the maximum contaminant level ("MCL") of 0.060 milligrams per liter for haloacetic acids based on the locational running annual average [30 TEX. ADMIN. CODE § 290.115(f)(1) and TEX. HEALTH & SAFETY CODE § 341.0315(c)].

2. Failed to comply with the MCL of 0.080 milligrams per liter for total trihalomethanes based on the locational running annual average [30 TEX. ADMIN. CODE § 290.115(f)(1) and TEX. HEALTH & SAFETY CODE § 341.0315(c)].

Corrective Actions/Technical Requirements

Corrective Action(s) Completed:

N/A

Technical Requirements:

The Order will require the Respondent to:

a. Within 365 days:

i. Return to compliance with the MCL for haloacetic acids based on the locational running annual average; and

ii. Return to compliance with the MCL for total trihalomethanes based on the locational running annual average.

b. Within 380 days, submit written certification to demonstrate compliance with a.

Litigation Information

Date Petition(s) Filed: N/A

Date Answer(s) Filed: N/A

SOAH Referral Date: N/A

Hearing Date(s): N/A

Settlement Date: N/A

Executive Summary – Enforcement Matter – Case No. 52082
Red River Authority of Texas
RN101237527
Docket No. 2016-0438-PWS-E

Contact Information

TCEQ Attorney: N/A

TCEQ Enforcement Coordinator: Carol McGrath, Enforcement Division,
Enforcement Team 4, MC R-13, (210) 403-4063; Michael Parrish, Enforcement
Division, MC 219, (512) 239-2548

TCEQ SEP Coordinator: N/A

Respondent: Curtis W. Campbell, General Manager, Red River Authority of Texas,
P.O. Box 240, Wichita Falls, Texas 76307-0240

Respondent's Attorney: N/A



Penalty Calculation Worksheet (PCW)

Policy Revision 4 (April 2014)

PCW Revision March 26, 2014

TCEQ

DATES	Assigned PCW	21-Mar-2016	Screening	29-Mar-2016	EPA Due	31-Mar-2016
--------------	---------------------	-------------	------------------	-------------	----------------	-------------

RESPONDENT/FACILITY INFORMATION	
Respondent	Red River Authority of Texas
Reg. Ent. Ref. No.	RN101237527
Facility/Site Region	4-Dallas/Fort Worth
Major/Minor Source	Major

CASE INFORMATION			
Enf./Case ID No.	52082	No. of Violations	2
Docket No.	2016-0438-PWS-E	Order Type	Findings
Media Program(s)	Public Water Supply	Government/Non-Profit	Yes
Multi-Media		Enf. Coordinator	Carol McGrath
		EC's Team	Enforcement Team 4
Admin. Penalty \$ Limit Minimum	\$50	Maximum	\$1,000

Penalty Calculation Section

TOTAL BASE PENALTY (Sum of violation base penalties) **Subtotal 1** **\$1,200**

ADJUSTMENTS (+/-) TO SUBTOTAL 1

Subtotals 2-7 are obtained by multiplying the Total Base Penalty (Subtotal 1) by the indicated percentage.

Compliance History **5.0%** Adjustment **Subtotals 2, 3, & 7** **\$60**

Notes: Enhancement for three NOVs with same/similar violations and reduction for High Performer classification.

Culpability **No** **0.0%** Enhancement **Subtotal 4** **\$0**

Notes: The Respondent does not meet the culpability criteria.

Good Faith Effort to Comply Total Adjustments **Subtotal 5** **\$0**

Economic Benefit **0.0%** Enhancement* **Subtotal 6** **\$0**

Total EB Amounts	\$642
Estimated Cost of Compliance	\$5,000

*Capped at the Total EB \$ Amount

SUM OF SUBTOTALS 1-7 **Final Subtotal** **\$1,260**

OTHER FACTORS AS JUSTICE MAY REQUIRE **0.0%** Adjustment **\$0**

Reduces or enhances the Final Subtotal by the indicated percentage.

Notes:

Final Penalty Amount **\$1,260**

STATUTORY LIMIT ADJUSTMENT **Final Assessed Penalty** **\$1,260**

DEFERRAL **0.0%** Reduction Adjustment **\$0**

Reduces the Final Assessed Penalty by the indicated percentage. (Enter number only; e.g. 20 for 20% reduction.)

Notes:

No deferral is recommended for Findings Orders.

PAYABLE PENALTY **\$1,260**

Screening Date 29-Mar-2016

Docket No. 2016-0438-PWS-E

PCW

Respondent Red River Authority of Texas

Policy Revision 4 (April 2014)

Case ID No. 52082

PCW Revision March 26, 2014

Reg. Ent. Reference No. RN101237527

Media [Statute] Public Water Supply

Enf. Coordinator Carol McGrath

Compliance History Worksheet

>> Compliance History Site Enhancement (Subtotal 2)

Component	Number of...	Number	Adjust.
NOVs	Written notices of violation ("NOVs") with same or similar violations as those in the current enforcement action (<i>number of NOVs meeting criteria</i>)	3	15%
	Other written NOVs	0	0%
Orders	Any agreed final enforcement orders containing a denial of liability (<i>number of orders meeting criteria</i>)	0	0%
	Any adjudicated final enforcement orders, agreed final enforcement orders without a denial of liability, or default orders of this state or the federal government, or any final prohibitory emergency orders issued by the commission	0	0%
Judgments and Consent Decrees	Any non-adjudicated final court judgments or consent decrees containing a denial of liability of this state or the federal government (<i>number of judgments or consent decrees meeting criteria</i>)	0	0%
	Any adjudicated final court judgments and default judgments, or non-adjudicated final court judgments or consent decrees without a denial of liability, of this state or the federal government	0	0%
Convictions	Any criminal convictions of this state or the federal government (<i>number of counts</i>)	0	0%
Emissions	Chronic excessive emissions events (<i>number of events</i>)	0	0%
Audits	Letters notifying the executive director of an intended audit conducted under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which notices were submitted</i>)	0	0%
	Disclosures of violations under the Texas Environmental, Health, and Safety Audit Privilege Act, 74th Legislature, 1995 (<i>number of audits for which violations were disclosed</i>)	0	0%
Other	Environmental management systems in place for one year or more	No	0%
	Voluntary on-site compliance assessments conducted by the executive director under a special assistance program	No	0%
	Participation in a voluntary pollution reduction program	No	0%
	Early compliance with, or offer of a product that meets future state or federal government environmental requirements	No	0%

Adjustment Percentage (Subtotal 2) 15%

>> Repeat Violator (Subtotal 3)

N/A

Adjustment Percentage (Subtotal 3) 0%

>> Compliance History Person Classification (Subtotal 7)

High Performer

Adjustment Percentage (Subtotal 7) -10%

>> Compliance History Summary

Compliance History Notes

Enhancement for three NOVs with same/similar violations and reduction for High Performer classification.

Total Compliance History Adjustment Percentage (Subtotals 2, 3, & 7) 5%

>> Final Compliance History Adjustment

Final Adjustment Percentage *capped at 100% 5%

Screening Date 29-Mar-2016

Docket No. 2016-0438-PWS-E

PCW

Respondent Red River Authority of Texas

Policy Revision 4 (April 2014)

Case ID No. 52082

PCW Revision March 26, 2014

Reg. Ent. Reference No. RN101237527

Media [Statute] Public Water Supply

Enf. Coordinator Carol McGrath

Violation Number 1

Rule Cite(s) 30 Tex. Admin. Code § 290.115(f)(1) and Tex. Health & Safety Code § 341.0315(c)

Violation Description Failed to comply with the maximum contaminant level ("MCL") of 0.060 milligrams per liter ("mg/L") for haloacetic acids ("HAA5"), based on the locational running annual average. Specifically, the locational running annual average concentrations for HAA5 for Stage 2 Disinfection Byproducts ("DBP2") were 0.074 mg/L at Site 1 and 0.081 mg/L at Site 2 for the third quarter of 2015; 0.085 mg/L at Site 1 and 0.090 mg/L at Site 2 for the fourth quarter of 2015; and 0.095 mg/L at Site 1 and 0.101 mg/L at Site 2 for the first quarter of 2016.

Base Penalty \$1,000

>> Environmental, Property and Human Health Matrix

Table with columns: Release (Actual, Potential), Harm (Major, Moderate, Minor), and Percent (30.0%).

>> Programmatic Matrix

Table with columns: Falsification, Major, Moderate, Minor, and Percent (0.0%).

Matrix Notes Exceeding the MCL for HAA5 caused persons served by the Facility to be exposed to significant amounts of contaminants which did not exceed levels protective of human health.

Adjustment \$700

\$300

Violation Events

Number of Violation Events 2 Number of violation days 274

Table with columns: Frequency (daily, weekly, monthly, quarterly, semiannual, annual, single event) and Count.

Violation Base Penalty \$600

Two annual events are recommended (one for each site).

Good Faith Efforts to Comply

0.0%

Reduction \$0

Table with columns: Effort Type (Extraordinary, Ordinary, N/A) and Status (Before NOE/NOV, NOE/NOV to EDPRP/Settlement Offer).

Notes The Respondent does not meet the good faith criteria for this violation.

Violation Subtotal \$600

Economic Benefit (EB) for this violation

Statutory Limit Test

Estimated EB Amount \$642

Violation Final Penalty Total \$630

This violation Final Assessed Penalty (adjusted for limits) \$630

Economic Benefit Worksheet

Respondent Red River Authority of Texas
Case ID No. 52082
Reg. Ent. Reference No. RN101237527
Media Public Water Supply
Violation No. 1

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
------------------	-----------	---------------	------------	-----	----------------	---------------	-----------

Delayed Costs

Equipment				0.00	\$0	\$0	\$0
Buildings				0.00	\$0	\$0	\$0
Other (as needed)	\$5,000	30-Sep-2015	31-Jul-2017	1.84	\$31	\$612	\$642
Engineering/Construction				0.00	\$0	\$0	\$0
Land				0.00	\$0	n/a	\$0
Record Keeping System				0.00	\$0	n/a	\$0
Training/Sampling				0.00	\$0	n/a	\$0
Remediation/Disposal				0.00	\$0	n/a	\$0
Permit Costs				0.00	\$0	n/a	\$0
Other (as needed)				0.00	\$0	n/a	\$0

Notes for DELAYED costs

The delayed costs include the estimated amount to implement an alternative form of disinfection, calculated from the last date of the first quarter of noncompliance to the estimated date of compliance.

Avoided Costs

ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)

Disposal				0.00	\$0	\$0	\$0
Personnel				0.00	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.00	\$0	\$0	\$0
Supplies/Equipment				0.00	\$0	\$0	\$0
Financial Assurance [2]				0.00	\$0	\$0	\$0
ONE-TIME avoided costs [3]				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0

Notes for AVOIDED costs

Approx. Cost of Compliance

\$5,000

TOTAL

\$642

Screening Date 29-Mar-2016
Respondent Red River Authority of Texas
Case ID No. 52082
Reg. Ent. Reference No. RN101237527
Media [Statute] Public Water Supply
Enf. Coordinator Carol McGrath

Docket No. 2016-0438-PWS-E

PCW

Policy Revision 4 (April 2014)
 PCW Revision March 26, 2014

Violation Number

Rule Cite(s) 30 Tex. Admin. Code § 290.115(f)(1) and Tex. Health & Safety Code § 341.0315(c)

Violation Description
 Failed to comply with the MCL of 0.080 mg/L for total trihalomethanes ("TTHM"), based on the locational running annual average. Specifically, the locational running annual average concentrations for TTHM for DBP2 were 0.150 mg/L at Site 1 and 0.156 mg/L at Site 2 for the fourth quarter of 2015 and 0.153 mg/L at Site 1 and 0.160 mg/L at Site 2 for the first quarter of 2016.

Base Penalty

>> **Environmental, Property and Human Health Matrix**

Release	Harm			Percent
	Major	Moderate	Minor	
Actual	<input type="text"/>	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="text" value="30.0%"/>
Potential	<input type="text"/>	<input type="text"/>	<input type="text"/>	

>> **Programmatic Matrix**

Falsification	Major	Moderate	Minor	Percent
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text" value="0.0%"/>

Matrix Notes
 Exceeding the MCL for TTHM caused persons served by the Facility to be exposed to significant amounts of contaminants which did not exceed levels protective of human health.

Adjustment

Violation Events

Number of Violation Events Number of violation days

daily	<input type="text"/>
weekly	<input type="text"/>
monthly	<input type="text"/>
quarterly	<input type="text"/>
semiannual	<input type="text"/>
annual	<input checked="" type="checkbox"/>
single event	<input type="text"/>

Violation Base Penalty

Two annual events are recommended (one for each site).

Good Faith Efforts to Comply

Reduction

Before NOE/NOV NOE/NOV to EDRP/Settlement Offer

Extraordinary	<input type="text"/>	<input type="text"/>
Ordinary	<input type="text"/>	<input type="text"/>
N/A	<input checked="" type="checkbox"/>	<input type="text"/>

Notes
 The Respondent does not meet the good faith criteria for this violation.

Violation Subtotal

Economic Benefit (EB) for this violation

Statutory Limit Test

Estimated EB Amount

Violation Final Penalty Total

This violation Final Assessed Penalty (adjusted for limits)

Economic Benefit Worksheet

Respondent Red River Authority of Texas
Case ID No. 52082
Reg. Ent. Reference No. RN101237527
Media Public Water Supply
Violation No. 2

Percent Interest	Years of Depreciation
5.0	15

Item Description	Item Cost	Date Required	Final Date	Yrs	Interest Saved	Onetime Costs	EB Amount
------------------	-----------	---------------	------------	-----	----------------	---------------	-----------

Delayed Costs

Equipment				0.00	\$0	\$0	\$0
Buildings				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0
Engineering/Construction				0.00	\$0	\$0	\$0
Land				0.00	\$0	n/a	\$0
Record Keeping System				0.00	\$0	n/a	\$0
Training/Sampling				0.00	\$0	n/a	\$0
Remediation/Disposal				0.00	\$0	n/a	\$0
Permit Costs				0.00	\$0	n/a	\$0
Other (as needed)				0.00	\$0	n/a	\$0

Notes for DELAYED costs

Economic benefit included in Violation No. 1.

Avoided Costs

ANNUALIZE [1] avoided costs before entering item (except for one-time avoided costs)

Disposal				0.00	\$0	\$0	\$0
Personnel				0.00	\$0	\$0	\$0
Inspection/Reporting/Sampling				0.00	\$0	\$0	\$0
Supplies/Equipment				0.00	\$0	\$0	\$0
Financial Assurance [2]				0.00	\$0	\$0	\$0
ONE-TIME avoided costs [3]				0.00	\$0	\$0	\$0
Other (as needed)				0.00	\$0	\$0	\$0

Notes for AVOIDED costs

Approx. Cost of Compliance \$0

TOTAL \$0

The TCEQ is committed to accessibility.

To request a more accessible version of this report, please contact the TCEQ Help Desk at (512) 239-4357.



Compliance History Report

TCEQ PUBLISHED Compliance History Report for CN600630479, RN101237527, Rating Year 2015 which includes Compliance
Customer, Respondent, or Owner/Operator: CN600630479, Red River Authority of Texas **Classification:** HIGH **Rating:** 0.00

Regulated Entity: RN101237527, PRESTON SHORES WATER SYSTEM **Classification:** NOT APPLICABLE **Rating:** N/A

Complexity Points: N/A **Repeat Violator:** N/A

CH Group: 14 - Other

Location: 208 SHERMAN DR NEAR POTTSBORO, GRAYSON COUNTY, TEXAS

TCEQ Region: REGION 04 - DFW METROPLEX

ID Number(s):

PUBLIC WATER SYSTEM/SUPPLY REGISTRATION
0910037

Compliance History Period: September 01, 2010 to August 31, 2015 **Rating Year:** 2015 **Rating Date:** 09/01/2015

Date Compliance History Report Prepared: March 21, 2016

Agency Decision Requiring Compliance History: Enforcement

Component Period Selected: March 21, 2011 to March 21, 2016

TCEQ Staff Member to Contact for Additional Information Regarding This Compliance History.

Name: Carol McGrath

Phone: (210) 403-4063

Site and Owner/Operator History:

- 1) Has the site been in existence and/or operation for the full five year compliance period? YES
- 2) Has there been a (known) change in ownership/operator of the site during the compliance period? NO
- 3) If **YES** for #2, who is the current owner/operator? N/A
- 4) If **YES** for #2, who was/were the prior owner(s)/operator(s)? N/A
- 5) If **YES**, when did the change(s) in owner or operator occur? N/A

Components (Multimedia) for the Site Are Listed in Sections A - J

A. Final Orders, court judgments, and consent decrees: N/A

B. Criminal convictions: N/A

C. Chronic excessive emissions events: N/A

D. The approval dates of investigations (CCEDS Inv. Track. No.):

Item 1 January 03, 2013 (1043707)

E. Written notices of violations (NOV) (CCEDS Inv. Track. No.):

A notice of violation represents a written allegation of a violation of a specific regulatory requirement from the commission to a regulated entity. A notice of violation is not a final enforcement action, nor proof that a violation has actually occurred.

1 Date: 08/31/2015 (1321491) CN600630479
Self Report? NO Classification: Moderate
Citation: 30 TAC Chapter 290, SubChapter F 290.115(f)(1)
Description: HAA5 LRAA MCL 3Q2015 - During the third quarter of 2015 the system violated the maximum contaminant level for haloacetic acids with a LRAA of 0.074 mg/L at 464 Bentwood Dr, Pottsboro (DBP2-01) and with a LRAA of 0.081 mg/L at 91 Ridge Road, Pottsboro, TX (DBP2-02).

2 Date: 11/16/2015 (1321491) CN600630479
Self Report? NO Classification: Moderate
Citation: 30 TAC Chapter 290, SubChapter F 290.115(f)(1)

Description: HAA5 LRAA MCL 4Q2015 - During the fourth quarter of 2015 the system violated the maximum contaminant level for haloacetic acids with a LRAA of 0.085 mg/L at 464 Bentwood Dr, Pottsboro (DBP2-01) and with a LRAA of 0.090 mg/L at 91 Ridge Road, Pottsboro, TX (DBP2-02).

Self Report? NO Classification: Moderate

Citation: 30 TAC Chapter 290, SubChapter F 290.115(f)(1)

Description: TTHM LRAA MCL 4Q2015 - During the fourth quarter of 2015 the system violated the maximum contaminant level for trihalomethanes with a LRAA of 0.150 mg/L at 464 Bentwood Dr, Pottsboro (DBP2-01) and with a LRAA of 0.156 mg/L at 91 Ridge Road, Pottsboro, TX (DBP2-02).

3 Date: 03/07/2016 (1321491) CN600630479

Self Report? NO Classification: Moderate

Citation: 30 TAC Chapter 290, SubChapter F 290.115(f)(1)

Description: HAA5 LRAA MCL 1Q2016 - During the first quarter of 2016 the system violated the maximum contaminant level for haloacetic acids with a LRAA of 0.095 mg/L at 464 Bentwood Dr, Pottsboro (DBP2-01) and with a LRAA of 0.101 mg/L at 91 Ridge Road, Pottsboro, TX (DBP2-02).

Self Report? NO Classification: Moderate

Citation: 30 TAC Chapter 290, SubChapter F 290.115(f)(1)

Description: TTHM LRAA MCL 1Q2016 - During the first quarter of 2016 the system violated the maximum contaminant level for trihalomethanes with a LRAA of 0.153 mg/L at 464 Bentwood Dr, Pottsboro (DBP2-01) and with a LRAA of 0.160 mg/L at 91 Ridge Road, Pottsboro, TX (DBP2-02).

F. Environmental audits: N/A

G. Type of environmental management systems (EMSs): N/A

H. Voluntary on-site compliance assessment dates: N/A

I. Participation in a voluntary pollution reduction program: N/A

J. Early compliance: N/A

Sites Outside of Texas: N/A

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY



**IN THE MATTER OF AN
ENFORCEMENT ACTION
CONCERNING
RED RIVER AUTHORITY OF
TEXAS
RN101237527**

§
§
§
§
§
§

**BEFORE THE
TEXAS COMMISSION ON
ENVIRONMENTAL QUALITY**

AGREED ORDER DOCKET NO. 2016-0438-PWS-E

On _____, the Texas Commission on Environmental Quality ("the Commission" or "TCEQ") considered this agreement of the parties, resolving an enforcement action regarding Red River Authority of Texas (the "Respondent") under the authority of TEX. HEALTH & SAFETY CODE ch. 341. The Executive Director of the TCEQ, through the Enforcement Division, and the Respondent presented this Order to the Commission.

The Respondent understands that it has certain procedural rights at certain points in the enforcement process, including the right to formal notice of violations, notice of an evidentiary hearing, the right to an evidentiary hearing, and a right to appeal. By entering into this Order, the Respondent agrees to waive all notice and procedural rights.

It is further understood and agreed that this Order represents the complete and fully-integrated agreement of the parties. The provisions of this Order are deemed severable and, if a court of competent jurisdiction or other appropriate authority deems any provision of this Order unenforceable, the remaining provisions shall be valid and enforceable. The duties and responsibilities imposed by this Order are binding upon the Respondent.

The Commission makes the following Findings of Fact and Conclusions of Law:

I. FINDINGS OF FACT

1. The Respondent owns and operates a public water supply located at 208 Sherman Drive near Pottsboro, Grayson County, Texas (the "Facility"). The Facility provides water for human consumption, has approximately 714 service connections, and serves at least 25 people per day for at least 60 days per year. As such, the Facility is a public water system as defined in 30 TEX. ADMIN. CODE § 290.38(69).
2. During a record review conducted on March 7, 2016 through March 18, 2016, TCEQ staff documented that the locational running annual average concentrations for haloacetic acids ("HAA5") for Stage 2 Disinfection Byproducts ("DBP2") were 0.074 milligrams per liter ("mg/L") at Site 1 and 0.081 mg/L at Site 2 for the third quarter of 2015; 0.085 mg/L at Site 1 and 0.090 mg/L at Site 2 for the fourth quarter of 2015; and 0.095 mg/L at Site 1 and 0.101 mg/L at Site 2 for the first quarter of 2016.
3. During a record review conducted on March 7, 2016 through March 18, 2016, TCEQ staff documented that the locational running annual average concentrations for total trihalomethanes ("TTHM") for DBP2 were 0.150 mg/L at Site 1 and 0.156 mg/L at Site 2

for the fourth quarter of 2015 and 0.153 mg/L at Site 1 and 0.160 mg/L at Site 2 for the first quarter of 2016.

II. CONCLUSIONS OF LAW

1. As evidenced by Finding of Fact No. 1, the Respondent is subject to the jurisdiction of the TCEQ pursuant to TEX. HEALTH & SAFETY CODE ch. 341 and the rules of the TCEQ.
2. As evidenced by Finding of Fact No. 2, the Respondent failed to comply with the maximum contaminant level ("MCL") of 0.060 mg/L for HAA5, based on the locational running annual average, in violation of 30 TEX. ADMIN. CODE § 290.115(f)(1) and TEX. HEALTH & SAFETY CODE § 341.0315(c).
3. As evidenced by Finding of Fact No. 3, the Respondent failed to comply with the MCL of 0.080 mg/L for TTHM, based on the locational running annual average, in violation of 30 TEX. ADMIN. CODE § 290.115(f)(1) and TEX. HEALTH & SAFETY CODE § 341.0315(c).
4. Pursuant to TEX. HEALTH & SAFETY CODE § 341.049(a), the TCEQ has the authority to assess a penalty against the Respondent for violations of state statutes within the TCEQ's jurisdiction, for violations of rules adopted under such statutes, or for violations of orders or permits issued under such statutes.
5. An administrative penalty in the amount of \$1,260 is justified by the facts recited in this Order, and considered in light of the factors set forth in TEX. HEALTH & SAFETY CODE § 341.049(b). The Respondent paid the \$1,260 penalty.

III. ORDERING PROVISIONS

NOW, THEREFORE, THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY ORDERS that:

1. The Respondent is assessed a penalty as set forth in Conclusion of Law No. 5 for violations of state statutes and rules of the TCEQ. The payment of this penalty and the Respondent's compliance with all the requirements set forth in this Order resolve only the matters set forth by this Order in this action. The Commission shall not be constrained in any manner from requiring corrective actions or penalties for violations that are not raised here. Penalty payments shall be made payable to "TCEQ" and shall be sent with the notation "Re: Red River Authority of Texas, Docket No. 2016-0438-PWS-E" to:

Financial Administration Division, Revenue Operations Section
Attention: Cashier's Office, MC 214
Texas Commission on Environmental Quality
P.O. Box 13088
Austin, Texas 78711-3088

2. The Respondent shall undertake the following technical requirements:

- a. Within 365 days after the effective date of this Order:
 - i. Return to compliance with the MCL for HAA5, based on the locational running annual average, in accordance with 30 TEX. ADMIN. CODE § 290.115; and
 - ii. Return to compliance with the MCL for TTHM, based on the locational running annual average, in accordance with 30 TEX. ADMIN. CODE § 290.115.
- b. Within 380 days after the effective date of this Order, submit written certification as described below, and include detailed supporting documentation including photographs, receipts, and/or other records to demonstrate compliance with Ordering Provision Nos. 2.a.i and 2.a.ii. The certification shall be signed by the Respondent and shall include the following certification language:

"I certify under penalty of law that I have personally examined and am familiar with the information submitted and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

The certification shall be submitted to:

Order Compliance Team
Enforcement Division, MC 149A
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

with a copy to:

Public Drinking Water Section Manager
Water Supply Division, MC 155
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

3. All relief not expressly granted in this Order is denied.
4. The duties and provisions imposed by this Order shall apply to and be binding upon the Respondent. The Respondent is ordered to give notice of this Order to personnel who maintain day-to-day control over the Facility operations referenced in this Order.

5. The Executive Director may grant an extension of any deadline in this Order or in any plan, report, or other document submitted pursuant to this Order, upon a written and substantiated showing of good cause. All requests for extensions by the Respondent shall be made in writing to the Executive Director. Extensions are not effective until the Respondent receives written approval from the Executive Director. The determination of what constitutes good cause rests solely with the Executive Director. Extension requests shall be sent to the Order Compliance Team at the address listed above.
6. The Executive Director may, without further notice or hearing, refer this matter to the Office of the Attorney General of the State of Texas ("OAG") for further enforcement proceedings if the Executive Director determines that the Respondent has not complied with one or more of the terms in this Order.
7. This Order shall terminate five years from its effective date or upon compliance with all the terms and conditions set forth in this Order, whichever is later.
8. This Order, issued by the Commission, shall not be admissible against the Respondent in a civil proceeding, unless the proceeding is brought by the OAG to: (1) enforce the terms of this Order; or (2) pursue violations of a statute within the Commission's jurisdiction, or of a rule adopted or an order or permit issued by the Commission under such a statute.
9. This Order may be executed in separate and multiple counterparts, which together shall constitute a single instrument. Any page of this Order may be copied, scanned, digitized, converted to electronic portable document format ("pdf"), or otherwise reproduced and may be transmitted by digital or electronic transmission, including but not limited to facsimile transmission and electronic mail. Any signature affixed to this Order shall constitute an original signature for all purposes and may be used, filed, substituted, or issued for any purpose for which an original signature could be used. The term "signature" shall include manual signatures and true and accurate reproductions of manual signatures created, executed, endorsed, adopted, or authorized by the person or persons to whom the signatures are attributable. Signatures may be copied or reproduced digitally, electronically, by photocopying, engraving, imprinting, lithographing, electronic mail, facsimile transmission, stamping, or any other means or process which the Executive Director deems acceptable. In this paragraph exclusively, the terms: electronic transmission, owner, person, writing, and written, shall have the meanings assigned to them under TEX. BUS. ORG. CODE § 1.002.
10. The effective date of this Order is the date it is signed by the Commission. A copy of this fully executed Order shall be provided to each of the parties.

SIGNATURE PAGE

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

For the Commission

Date

Ronald M. Hovine Jr.

8/19/16

For the Executive Director

Date

I, the undersigned, have read and understand the attached Order. I am authorized to agree to the attached Order, and I do agree to the terms and conditions specified therein. I further acknowledge that the TCEQ, in accepting payment for the penalty amount, is materially relying on such representation.

I also understand that failure to comply with the Ordering Provisions, if any, in this order and/or failure to timely pay the penalty amount, may result in:

- A negative impact on compliance history;
- Greater scrutiny of any permit applications submitted;
- Referral of this case to the Attorney General's Office for contempt, injunctive relief, additional penalties, and/or attorney fees, or to a collection agency;
- Increased penalties in any future enforcement actions;
- Automatic referral to the Attorney General's Office of any future enforcement actions;
- and
- TCEQ seeking other relief as authorized by law.

In addition, any falsification of any compliance documents may result in criminal prosecution.

Curtis W. Campbell

4-29-16

Signature

Date

Curtis W. Campbell

General Manager

Name (Printed or typed)

Title

Authorized Representative of
Red River Authority of Texas

Instructions: Send the original, signed Order with penalty payment to the Financial Administration Division, Revenue Operations Section at the address in Section III, Paragraph 1 of this Order.

If mailing address has changed, please check this box and provide the new address below: