

Bryan W. Shaw, Ph.D., P.E., *Chairman*
Toby Baker, *Commissioner*
Zak Covar, *Commissioner*
Richard A. Hyde, P.E., *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

December 22, 2014

Bridget Bohac, Chief Clerk
Texas Commission on Environmental Quality
Office of the Chief Clerk (MC-105)
P.O. Box 13087
Austin, Texas 78711-3087

Re: West Park Municipal Utility District; TPDES Permit No. WQ0012346001:
TCEQ Docket No. 2014-1417-MWD

Dear Ms. Bohac:

Enclosed for filing is the Executive Director's Response to Hearing Request in the above-titled matter.

Respectfully,

A handwritten signature in black ink, appearing to read "Anthony Tatu".

Anthony Tatu, Staff Attorney
Environmental Law Division
State Bar of Texas No. 00792869
P.O. Box 13087, MC 173
Austin, Texas 78711-3087
(512) 239-2225
(512) 239-0606 (fax)

REPRESENTING THE
EXECUTIVE DIRECTOR OF THE
TEXAS COMMISSION ON
ENVIRONMENTAL QUALITY

cc: Mailing List

Enclosure

TCEQ Docket No. 2014-1417-MWD

APPLICATION BY WEST PARK MUNICIPAL UTILITY DISTRICT FOR NEW TEXAS POLLUTANT DISCHARGE ELIMINATION SYSTEM (TPDES) PERMIT NO. WQ0012346001	§ § § § § §	BEFORE THE TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
---	--	---

EXECUTIVE DIRECTOR’S RESPONSE TO HEARING REQUEST

The Executive Director (ED) of the Texas Commission on Environmental Quality (Commission or TCEQ) files this Response to Hearing Request on the West Park MUD application for new TPDES Permit No. WQ0012346001. One hearing requests was filed by Annette Baldwin. The ED respectfully recommends that this hearing request be denied.

Attached for Commission consideration are the following:

- Attachment A – Adjacent Landowners Map
- Attachment B – Fact Sheet and ED's Preliminary Decision
- Attachment C – Draft permit
- Attachment D – ED’s Response to Public Comment (RTC)
- Attachment E – Compliance History Reports

I. FACILITY DESCRIPTION

West Park Municipal Utility District has applied to the TCEQ for a major amendment that will authorize an increase in the discharge of treated domestic wastewater from a daily average flow not to exceed 0.5 million gallons per day to a daily average flow not to exceed 0.99 million gallons per day. The wastewater treatment facility serves the West Park Municipal Utility District. The wastewater treatment facility site is located at 19310 Katy Freeway, Houston in Harris County, Texas 77094.

The treated effluent is discharged to Harris County Flood Control District (HCFCD) ditch U101-02-00; then to South Mayde Creek; then to Buffalo Bayou Above Tidal in Segment No. 1014 of the San Jacinto River Basin. The unclassified receiving water uses are minimal aquatic life use for HCFCD ditch U101-02-00, limited aquatic life use for South Mayde Creek (upstream of unnamed tributary 0.62 km east of Barker-Cypress Road), and intermediate aquatic life use for South Mayde Creek (downstream of unnamed tributary 0.62 km east of Barker-Cypress Road). The designated uses for Segment No. 1014 are limited aquatic life use and primary contact recreation. The effluent limitations in the draft permit will maintain and protect the existing instream uses. In accordance with 30 Texas Administrative Code § 307.5 and the TCEQ implementation procedures (June 2010) for the Texas Surface Water Quality Standards, an antidegradation review of the receiving waters was performed. A Tier 1

antidegradation review has preliminarily determined that existing water quality uses will not be impaired by this permit action. Numerical and narrative criteria to protect existing uses will be maintained. A Tier 2 review has preliminarily determined that no significant degradation of water quality is expected in South Mayde Creek (downstream of unnamed tributary 0.62 km east of Barker-Cypress Road), which has been identified as having intermediate aquatic life use. Existing uses will be maintained and protected.

II. BACKGROUND

The application for major amendment was received on November 5, 2013 and declared administratively complete on January 8, 2014. The Notice of Receipt and Intent to Obtain a Water Quality Permit (NORI) was published on January 19, 2014 in the *Houston Chronicle* and in Spanish on January 19, 2014 in *La Voz de Houston*. The Notice of Application and Preliminary Decision (NAPD) for a Water Quality Permit was published on April 20, 2014 in the *Houston Chronicle*, and in Spanish on April 20, 2014 in *La Voz de Houston*. The public comment period ended on May 20, 2014. One hearing request was timely received by Annette Baldwin. This application was administratively complete on or after September 1, 1999; therefore, this application is subject to the procedural requirements adopted pursuant to House Bill 801, 76th Legislature, 1999.

III. THE EVALUATION PROCESS FOR HEARING REQUESTS

House Bill (HB) 801 established statutory procedures for public participation in certain environmental permitting proceedings. For those applications declared administratively complete on or after September 1, 1999, it established new procedures for providing public notice and public comment and for the Commission's consideration of hearing requests. The application in this case was declared administratively complete on October 24, 2011. Therefore, it is subject to the HB 801 requirements. The Commission implemented HB 801 by adopting procedural rules in title 30, chapters 39, 50, and 55 of the Texas Administrative Code.

A. Response to Requests

"The ED, the public interest counsel, and the applicant may submit written responses to [hearing] requests"¹

According to section 55.209(e), responses to hearing requests must specifically address the following:

- (1). whether the requestor is an affected person;
- (2). which issues raised in the hearing request are disputed;
- (3). whether the dispute involves questions of fact or law;
- (4). whether the issues were raised during the public comment period;
- (5). whether the hearing request is based on issues raised solely in a public

¹ 30 TEX. ADMIN. CODE § 55.209(d) (West 2013).

comment withdrawn by the commenter in writing by filing a withdrawal letter with the chief clerk prior to the filing of the ED's RTC;

- (6). whether the issues are relevant and material to the decision on the application; and
- (7). a maximum expected duration for the contested case hearing.

B. Hearing Request Requirements

For the Commission to consider a hearing request, the Commission must first determine whether the request meets certain requirements. As noted in section 55.201(c), "A request for a contested case hearing by an affected person must be in writing, must be filed with the chief clerk within the time provided . . . and may not be based on an issue that was raised solely in a public comment withdrawn by the commenter in writing by filing a withdrawal letter with the chief clerk prior to the filing of the ED's RTC."

According to section 55.201(d), a hearing request must substantially comply with the following:

- (1) give the name, address, daytime telephone number, and, where possible, fax number of the person who files the request. If the request is made by a group or association, the request must identify one person by name, address, daytime telephone number, and, where possible, fax number, who shall be responsible for receiving all official communications and documents for the group;
- (2) identify the person's personal justiciable interest affected by the application, including a brief, but specific, written statement explaining in plain language the requestor's location and distance relative to the proposed facility or activity that is the subject of the application and how and why the requestor believes he or she will be adversely affected by the proposed facility or activity in a manner not common to members of the general public;
- (3) request a contested case hearing;
- (4) list all relevant and material disputed issues of fact that were raised during the public comment period and that are the basis of the hearing request. To facilitate the commission's determination of the number and scope of issues to be referred to hearing, the requestor should, to the extent possible, specify any of the ED's responses to comments that the requestor disputes and the factual basis of the dispute and list any disputed issues of law or policy; and
- (5) provide any other information specified in the public notice of application.

C. Requirement that Requestor Be an Affected Person

To grant a contested case hearing, the Commission must determine that a

requestor is an affected person. The factors to consider in making this determination are found in section 55.203 as follows:

- (a) For any application, an affected person is one who has a personal justiciable interest related to a legal right, duty, privilege, power, or economic interest affected by the application. An interest common to members of the general public does not qualify as a personal justiciable interest.
- (b) Governmental entities, including local governments and public agencies, with authority under state law over issues raised by the application may be considered affected persons.
- (c) In determining whether a person is an affected person, all factors shall be considered, including, but not limited to, the following:
 - (1) whether the interest claimed is one protected by the law under which the application will be considered;
 - (2) distance restrictions or other limitations imposed by law on the affected interest;
 - (3) whether a reasonable relationship exists between the interest claimed and the activity regulated;
 - (4) likely impact of the regulated activity on the health and safety of the person, and on the use of property of the person;
 - (5) likely impact of the regulated activity on use of the impacted natural resource by the person; and
 - (6) for governmental entities, their statutory authority over or interest in the issues relevant to the application.

D. Referral to the State Office of Administrative Hearings (SOAH)

Section 50.115(b) details how the Commission refers a matter to SOAH: “When the commission grants a request for a contested case hearing, the commission shall issue an order specifying the number and scope of the issues to be referred to SOAH for a hearing.” Section 50.115(c) further states, “The commission may not refer an issue to SOAH for a contested case hearing unless the commission determines that the issue: (1) involves a disputed question of fact; (2) was raised during the public comment period; and (3) is relevant and material to the decision on the application.”

IV. HEARING REQUEST ANALYSIS

A. Whether the Requestor Complied with Section 55.201(c) and (d)

Annette Baldwin electronically submitted a request for hearing on March 08, 2014, that raised issues presented during the public comment period that have not been withdrawn. Ms. Baldwin does not provide a residential address, only a post office box, and she does not indicated how close she is to the wastewater discharge plant or the

discharge point. Furthermore, Ms. Baldwin does not explain how she has a personal justiciable interest in this application. The ED concludes that the hearing request does not comply with the section 55.201(c) and (d) requirements.

B. Whether the Requestor Meets the Affected Person Requirements

Considering the affected person factors listed in section 55.203(c), the ED cannot conclude that Ms. Baldwin is an affected person. A review of the map of adjacent landowners (Attachment A) does not list Ms. Baldwin as an adjacent landowner, and her request does not articulate a personal justiciable interest related to a legal right, duty, privilege, power or economic interest affected by the application.

The ED recommends that the Commission find that Ms. Baldwin is not an affected person.

C. Whether Issues Raised Are Referable to SOAH for a Contested Case Hearing

The ED analyzed the issues raised in the hearing request in accordance with the applicable regulatory criteria and provides the following recommendations regarding whether the issues can be referred to SOAH if the Commission grants the hearing request. All issues were raised during the public comment period, and none of the issues were withdrawn. All identified issues are considered disputed unless otherwise noted.

1. Whether the proposed discharge from the wastewater treatment facility, which flows from South Mayde Creek to Addicks Reservoir, puts areas of Houston at risk. (RTC Comment No. 2).

This is an issue of fact. However, this issue is not relevant and material to the decision on the application. As explained in the ED's Response to Comments, this issue is outside the scope of the evaluation of a wastewater permit application. The ED does not recommend referring this issue to SOAH.

Because Ms. Baldwin has not identified any referable issues, there are no issues to refer to SOAH pursuant to section 50.115(c). Therefore, the ED recommends denying the hearing request for Annette Baldwin.

V. CONTESTED CASE HEARING DURATION

If there is a contested case hearing on this application, the ED recommends that the duration of the hearing be six months, starting with the preliminary hearing and continuing until the presentation of a proposal for decision to the Commission.

VI. CONCLUSION

Because Ms. Baldwin has not met the requirements for submitting a request for a contested case hearing, the ED recommends that her request be denied.

Respectfully submitted,

TEXAS COMMISSION ON
ENVIRONMENTAL QUALITY

Richard A. Hyde, P.E., Executive Director

Robert Martinez, Director
Environmental Law Division

By:  _____
Anthony Tatu
Staff Attorney
Environmental Law Division
State Bar of Texas No. 00792869
MC-173, P.O. Box 13087
Austin, Texas 78711-3087
Phone: (512) 239-0600
Fax: (512) 239-0606

MAILING LIST
WEST PARK MUNICIPAL UTILITY DISTRICT
DOCKET NO. 2014-1417-MWD; PERMIT NO. WQ0012346001

FOR THE APPLICANT:

Brock Hudson
West Park Municipal Utility District
3700 Buffalo Speedway, Suite 830
Houston, Texas 77098-3709

Eric D. Johnson
IDS Engineering Group
13333 Northwest Freeway, Suite 300
Houston, Texas 77040-6016
Tel: (713) 462-3178
Fax: (713) 462-1631

David J. Ross, P.E.
Pate Engineers, Inc.
13333 Northwest Freeway, Suite 300
Houston, Texas 77040-6016
Tel: (713) 462-3178
Fax: (713) 462-1631

FOR THE EXECUTIVE DIRECTOR:
via electronic mail:

Rebecca R. Moore, Technical Staff
Texas Commission on Environmental
Quality
Water Quality Division, MC-148
P.O. Box 13087
Austin, Texas 78711-3087
Tel: (512) 239-0058
Fax: (512) 239-4430

Brian Christian, Director
Texas Commission on Environmental
Quality
Environmental Assistance Division
Public Education Program, MC-108
P.O. Box 13087
Austin, Texas 78711-3087
Tel: (512) 239-4000
Fax: (512) 239-5678

FOR PUBLIC INTEREST COUNSEL:
via electronic mail:

Vic Mcwherter, Public Interest Counsel
Texas Commission on Environmental
Quality
Public Interest Counsel, MC-103
P.O. Box 13087
Austin, Texas 78711-3087
Tel: (512) 239-6363
Fax: (512) 239-6377

**FOR ALTERNATIVE DISPUTE
RESOLUTION**
via electronic mail:

Kyle Lucas
Texas Commission on Environmental
Quality
Alternative Dispute Resolution, MC-222
P.O. Box 13087
Austin, Texas 78711-3087
Tel: (512) 239-4010
Fax: (512) 239-4015

FOR THE CHIEF CLERK:
Bridget C. Bohac
Texas Commission on Environmental
Quality
Office of Chief Clerk, MC-105
P.O. Box 13087
Austin, Texas 78711-3087
Tel: (512) 239-3300
Fax: (512) 239-3311

REQUESTER:

Annette Baldwin
Po Box 218481
Houston Texas 77218-8481

ATTACHMENT A


ATTACHMENT NO. 2 (REVISED)
WEST PARK M.U.D.

AFFECTED LANDOWNER INFORMATION



Legend

- West Park M.U.D. Boundary
- HCAD Parcels (7-2013)
- Affected Parcels
- Wastewater Treatment Plant Site Boundary
- Discharge Line (1 Mile)
- Rivers & Streams



WEST PARK M.U.D.

WASTEWATER TREATMENT PLANT

POINT OF DISCHARGE

RECEIVED
DEC 23 2013
 Water Quality Applications Team

T104-00-00



ATTACHMENT B

**STATEMENT OF BASIS/TECHNICAL SUMMARY
AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION**

DESCRIPTION OF APPLICATION

Applicant: West Park Municipal Utility District;
Texas Pollutant Discharge Elimination System (TPDES) Permit No.
WQ0012346001, TX0086185

Regulated Activity: Domestic Wastewater Permit

Type of Application: Major Amendment with Renewal

Request: Major Amendment

Authority: Federal Clean Water Act (CWA) § 402; Texas Water Code (TWC) §
26.027; 30 Texas Administrative Code (TAC) Chapters 30, 305, 307,
309, 312, and 319; Commission policies; and EPA guidelines.

EXECUTIVE DIRECTOR RECOMMENDATION

The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The draft permit includes an expiration date of **May 1, 2017** according to 30 TAC § 305.71, Basin Permitting.

REASON FOR PROJECT PROPOSED

The applicant has applied to the Texas Commission on Environmental Quality (TCEQ) for an amendment of the existing permit to authorize an increase in the discharge of treated domestic wastewater from a daily average flow not to exceed 0.5 million gallons per day to a daily average flow not to exceed 0.99 million gallons per day. The existing wastewater treatment facility serves the West Park Municipal Utility District.

PROJECT DESCRIPTION AND LOCATION

The West Park Municipal Utility District Wastewater Treatment Facility is an activated sludge process plant operated in the contact stabilization mode with single stage nitrification. In the Interim phase, treatment units include bar screens, two aeration basins, two re-aeration basins, two final clarifiers, two sludge digesters, and two chlorine contact chambers. In the Final phase, treatment units will include bar screens, three aeration basins, two final clarifiers, three sludge digesters, and a chlorine contact basin. The facility is operating in the interim phase.

Sludge generated from the treatment facility is hauled by a registered transporter and disposed of at a TCEQ authorized land application site, El Celoso Ranch, Permit No. WQ0004518000, in Waller County. The draft permit also authorizes the disposal of sludge at a TCEQ authorized land application site or co-disposal landfill.

The plant site is located at 19310 Katy Freeway, Houston in Harris County, Texas 77094.

The treated effluent is discharged to Harris County Flood Control District (HCFCD) ditch U101-02-00; thence to South Mayde Creek; thence to Buffalo Bayou Above Tidal in Segment No. 1014 of the San Jacinto River Basin. The unclassified receiving water uses are minimal aquatic life use for HCFCD ditch U101-02-00, limited aquatic life use for South Mayde Creek (upstream of unnamed tributary 0.62 km east of Barker-Cypress Road), and intermediate aquatic life use for South Mayde Creek (downstream of

unnamed tributary 0.62 km east of Barker-Cypress Road). The designated uses for Segment No. 1014 are limited aquatic life use and primary contact recreation. The effluent limitations in the draft permit will maintain and protect the existing instream uses. In accordance with 30 Texas Administrative Code §307.5 and the TCEQ implementation procedures (June 2010) for the Texas Surface Water Quality Standards, an antidegradation review of the receiving waters was performed. A Tier 1 antidegradation review has preliminarily determined that existing water quality uses will not be impaired by this permit action. Numerical and narrative criteria to protect existing uses will be maintained. A Tier 2 review has preliminarily determined that no significant degradation of water quality is expected in South Mayde Creek (downstream of unnamed tributary 0.62 km east of Barker-Cypress Road), which has been identified as having intermediate aquatic life use. Existing uses will be maintained and protected. The preliminary determination can be reexamined and may be modified if new information is received.

Effluent limitations for the conventional effluent parameters (i.e., Biochemical Oxygen Demand or Carbonaceous Biochemical Oxygen Demand, Ammonia Nitrogen, etc.) are based on stream standards and waste load allocations for water quality limited streams as established in the Texas Surface Water Quality Standards and the State of Texas Water Quality Management Plan (WQMP).

The effluent limits recommended above have been reviewed for consistency with the State of Texas Water Quality Management Plan (WQMP). The proposed limits are not contained in the approved WQMP. However, these limits will be included in the next WQMP update. A Waste Load Evaluation (WLE) for dissolved oxygen has been prepared for Segment 1014. The discharge is included in the *Waste Load Evaluation WLE-1R for the Houston Ship Channel System* (September 2006).

The discharge from this permit action is not expected to have an effect on any federal endangered or threatened aquatic or aquatic dependent species or proposed species or their critical habitat. This determination is based on the United States Fish and Wildlife Service's (USFWS) biological opinion on the State of Texas authorization of the Texas Pollutant Discharge Elimination System (TPDES, September 14, 1998; October 21, 1998 update). To make this determination for TPDES permits, TCEQ and EPA only considered aquatic or aquatic dependent species occurring in watersheds of critical concern or high priority as listed in Appendix A of the USFWS biological opinion. The determination is subject to reevaluation due to subsequent updates or amendments to the biological opinion. The permit does not require EPA review with respect to the presence of endangered or threatened species.

Segment 1014 is not currently listed on the State's inventory of impaired and threatened waters, the 2012 303(d) list.

Segment 1014 is included in the agency's document *Fourteen Total Maximum Daily Loads for Nickel in the Houston Ship Channel System* (TMDL Project No.1). The discharge was screened using the methods outlined in the documents Procedures to Implement the Texas Surface Water Quality Standards (IPs), TCEQ, June 2010 and Implementation Plan for Dissolved Nickel in the Houston Ship Channel (TMDL Implementation Plan), TCEQ, July 2001. The discharge authorized in this draft permit has been added to the inventory of permittee loads and the TMDL model was run to ensure nickel criteria are maintained. The TMDL indicates that the water quality criteria for dissolved nickel are generally being met in the Houston Ship Channel and a specific limit for nickel is not recommended for this facility.

On April 8, 2009, the TCEQ adopted *Eighteen Total Maximum Daily Loads for Bacteria in Buffalo and Whiteoak Bayous and Tributaries*. The U.S. Environmental Protection Agency (USEPA) approved the TMDL on June 11, 2009. The TMDL addresses elevated levels of bacteria in multiple segments and assessment units of these bayous and their tributaries. The waste load allocation (WLA) for wastewater treatment facilities was established as the permitted flow for each facility multiplied by one-half the geometric mean criterion for bacteria. Future growth from existing or new permitted sources is not limited by these TMDLs as long as the sources do not exceed the limits of one-half the bacteria geometric mean criterion for *E. coli*. To ensure that effluent limitations for this discharge are consistent

with the WLAs provided in the TMDL, a concentration based effluent limitation for *E. coli* of 63 MPN per 100 ml has been included in the draft permit. This facility is designed to provide adequate disinfection and when operated properly should not add to the bacterial impairment of the segment.

SUMMARY OF EFFLUENT DATA

The following is a summary of the applicant's Monthly Effluent Report data for the period January 31, 2011 through December 31, 2013. The average of Daily Avg value is computed by the averaging of all 30-day average values for the reporting period for each parameter.

<u>Parameter</u>	<u>Average of Daily Avg</u>
Flow, MGD	0.272
CBOD ₅ , mg/l	2.13
TSS, mg/l	2.13
NH ₃ -N, mg/l	0.281
<i>E. coli</i> , CFU or MPN/100 ml	2.42

DRAFT PERMIT CONDITIONS

The draft permit authorizes a discharge of treated domestic wastewater at an interim volume not to exceed a daily average flow of 0.5 million gallons per day and a final volume not to exceed a daily average flow of 0.99 million gallons per day.

The effluent limitations in both phases of the draft permit, based on a 30-day average, are 7 mg/l CBOD₅, 15 mg/l TSS, 2 mg/l NH₃-N, 63 CFU or MPN of *E. coli* per 100 ml and 6.0 mg/l minimum dissolved oxygen (DO). The effluent shall contain a chlorine residual of at least 1.0 mg/l and shall not exceed a chlorine residual of 4.0 mg/l after a detention time of at least 20 minutes based on peak flow.

The draft permit includes a requirement for the permittee to provide nuisance odor prevention according to 30 TAC § 309.13(e)(2). The applicant submitted the nuisance odor prevention plan to the TCEQ on December 3, 2013.

The facility does not appear to receive significant industrial wastewater contributions. Permit requirements for pretreatment are based on TPDES regulations contained in 30 TAC Chapter 315 which references 40 Code of Federal Regulations (CFR) Part 403, "General Pretreatment Regulations for Existing and New Sources of Pollution." [rev. Federal Register/ Vol. 70/ No. 198/ Friday, October 14, 2005/ Rules and Regulations, pages 60134-60798] The permit includes specific requirements that establish responsibilities of local government, industry, and the public to implement the standards to control pollutants which pass through or interfere with treatment processes in publicly owned treatment works or which may contaminate the sewage sludge. This permit has appropriate pretreatment language for a facility of this size and complexity.

The draft permit includes Sludge Provisions according to the requirements of 30 TAC Chapter 312, Sludge Use, Disposal and Transportation. Sludge generated from the treatment facility is hauled by a registered transporter and disposed of at a TCEQ authorized land application site, El Celoso Ranch, Permit No. WQ0004518000, in Waller County. The draft permit also authorizes the disposal of sludge at a TCEQ authorized land application site or co-disposal landfill.

SUMMARY OF CHANGES FROM APPLICATION

The applicant requested a daily average flow not to exceed 0.5 MGD in the Interim phase and 0.99 MGD in the Final phase.

SUMMARY OF CHANGES FROM EXISTING PERMIT

Effluent limitations and monitoring requirements in the draft permit remain the same as the existing permit requirements. A Final phase with a daily average flow of 0.99 MGD was included in the draft permit.

The single grab or daily maximum bacteria limits have been changed from 197 CFU or MPN per 100 ml to 200 CFU or MPN per 100 ml, based on the EPA approved portions of the 2010 Texas Surface Water Quality Standards (TSWQS) and TMDL Project No. 22.

The Standard Permit Conditions, Sludge Provisions, and Other Requirements sections of the draft permit have been updated. Pretreatment requirements have been included in the draft permit.

The existing permit authorizes a daily average flow of 0.5 MGD. The permittee is currently operating in the Interim phase.

BASIS FOR DRAFT PERMIT

The following items were considered in developing the draft permit:

1. Application received November 5, 2013 and additional information received December 23, 2013.
2. TPDES Permit No. WQ0012346001 issued June 17, 2011.
3. The effluent limitations and conditions in the draft permit comply with the Texas Surface Water Quality Standards, 30 TAC §§ 307.1 - 307.10, effective August 17, 2000 and the EPA approved portions of the 2010 Texas Surface Water Quality Standards, effective July 22, 2010.
4. The effluent limitations in the draft permit meet the requirements for secondary treatment and the requirements for disinfection according to 30 TAC Chapter 309, Subchapter A: Domestic Wastewater Effluent Limitations.
5. Interoffice memoranda from the Water Quality Assessment Section of the TCEQ Water Quality Division. Interoffice memorandum from the Storm Water & Pretreatment Team of the TCEQ Water Quality Division.
6. Consistency with the Coastal Management Plan: The facility is not located in the Coastal Management Program boundary.
7. *Procedures to Implement the Texas Surface Water Quality Standards (IP)*, Texas Commission on Environmental Quality, June 2010, as approved by EPA and the IP, January 2003, for portions of the 2010 IP not approved by EPA.
8. Texas 2012 Clean Water Act Section 303(d) List, Texas Commission on Environmental Quality, February 21, 2013; approved by the EPA May 9, 2013.

9. TNRCC Guidance Document for Establishing Monitoring Frequencies for Domestic and Industrial Wastewater Discharge Permits, Document No. 98-001.000-OWR-WQ, May 1998.
10. The TMDLs and IPs for the segment, including: *Fourteen Total Maximum Daily Loads for Nickel in the Houston Ship Channel System (TMDL Project No.1) and Eighteen Total Maximum Daily Loads for Bacteria in Buffalo and Whiteoak Bayous and Tributaries Segments 1013, 1013A, 1013C, 1014, 1014A, 1014B, 1014E, 1014H, 1014K, 1014L, 1014M, 1014N, 1014O, 1017, 1017A, 1017B, 1017D, and 1017E (TMDL Project No. 22).*

PROCEDURES FOR FINAL DECISION

When an application is declared administratively complete, the Chief Clerk sends a letter to the applicant advising the applicant to publish the Notice of Receipt of Application and Intent to Obtain Permit in the newspaper. In addition, the Chief Clerk instructs the applicant to place a copy of the application in a public place for review and copying in the county where the facility is or will be located. This application will be in a public place throughout the comment period. The Chief Clerk also mails this notice to any interested persons and, if required, to landowners identified in the permit application. This notice informs the public about the application, and provides that an interested person may file comments on the application or request a contested case hearing or a public meeting.

Once a draft permit is completed, it is sent, along with the Executive Director's preliminary decision, as contained in the technical summary or fact sheet, to the Chief Clerk. At that time, Notice of Application and Preliminary Decision will be mailed to the same people and published in the same newspaper as the prior notice. This notice sets a deadline for making public comments. The applicant must place a copy of the Executive Director's preliminary decision and draft permit in the public place with the application. This notice sets a deadline for public comment.

Any interested person may request a public meeting on the application until the deadline for filing public comments. A public meeting is intended for the taking of public comment, and is not a contested case proceeding.


After the public comment deadline, the Executive Director prepares a response to all significant public comments on the application or the draft permit raised during the public comment period. The Chief Clerk then mails the Executive Director's Response to Comments and Final Decision to people who have filed comments, requested a contested case hearing, or requested to be on the mailing list. This notice provides that if a person is not satisfied with the Executive Director's response and decision, they can request a contested case hearing or file a request to reconsider the Executive Director's decision within 30 days after the notice is mailed.

The Executive Director will issue the permit unless a written hearing request or request for reconsideration is filed within 30 days after the Executive Director's Response to Comments and Final Decision is mailed. If a hearing request or request for reconsideration is filed, the Executive Director will not issue the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting. If a contested case hearing is held, it will be a legal proceeding similar to a civil trial in state district court.


If the Executive Director calls a public meeting or the Commission grants a contested case hearing as described above, the Commission will give notice of the date, time, and place of the meeting or hearing. If a hearing request or request for reconsideration is made, the Commission will consider all public comments in making its decision and shall either adopt the Executive Director's response to public comments or prepare its own response.

West Park Municipal Utility District
TPDES Permit No. WQ0012346001
Statement of Basis Summary Executive Directors Preliminary Decision

For additional information about this application contact Rebecca Moore at (512) 239-0058.



Rebecca Moore
Municipal Permits Team
Wastewater Permitting Section (MC 148)



Date

ATTACHMENT C



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
P.O. Box 13087
Austin, Texas 78711-3087

TPDES PERMIT NO.
WQ0012346001
[For TCEQ office use only - EPA
I.D. No. TX0086185]

This is a renewal that replaces
TPDES Permit No.
WQ0012346001 issued
July 27, 2007.

PERMIT TO DISCHARGE WASTES
under provisions of
Section 402 of the Clean Water Act
and Chapter 26 of the Texas Water Code

West Park Municipal Utility District

whose mailing address is

3700 Buffalo Speedway, Suite 830
Houston, Texas 77098

is authorized to treat and discharge wastes from the West Park Municipal Utility District
Wastewater Treatment Facility, SIC Code 4952

located at 19310 Katy Freeway, approximately 800 feet north of Interstate Highway 10 and
approximately 3,200 feet east of Fry Road at the south termination of a Harris County Flood
Control District ditch in Harris County, Texas 77084

via 24-inch pipe to Harris County Flood Control District (HCFCD) ditch U101-02-00; thence to
South Mayde Creek; thence to Buffalo Bayou Above Tidal in Segment No. 1014 of the San
Jacinto River Basin

only according with effluent limitations, monitoring requirements and other conditions set
forth in this permit, as well as the rules of the Texas Commission on Environmental Quality
(TCEQ), the laws of the State of Texas, and other orders of the TCEQ. The issuance of this
permit does not grant to the permittee the right to use private or public property for
conveyance of wastewater along the discharge route described in this permit. This includes, but
is not limited to, property belonging to any individual, partnership, corporation or other entity.
Neither does this permit authorize any invasion of personal rights nor any violation of federal,
state, or local laws or regulations. It is the responsibility of the permittee to acquire property
rights as may be necessary to use the discharge route.

This permit shall expire at midnight, **May 1, 2014**.

ISSUED DATE: June 17, 2011


For the Commission

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Outfall Number 001

1. During the period beginning upon the date of issuance and lasting through the date of expiration, the permittee is authorized to discharge subject to the following effluent limitations:

The daily average flow of effluent shall not exceed 0.5 million gallons per day (MGD); nor shall the average discharge during any two-hour period (2-hour peak) exceed 1,389 gallons per minute (gpm).

<u>Effluent Characteristic</u>	<u>Discharge Limitations</u>			<u>Min. Self-Monitoring Requirements</u>	
	Daily Avg mg/l (lbs/day)	7-day Avg mg/l	Daily Max mg/l	Single Grab mg/l	Report Daily Avg. & Daily Max. Measurement Sample Type Frequency
Flow, MGD	Report 7 (29)	N/A	Report 22	N/A	Continuous Totalizing Meter
Carbonaceous Biochemical Oxygen Demand (5-day)	15 (63)	25	40	60	One/week Composite
Ammonia Nitrogen	2 (8.3)	5	10	15	One/week Composite
<i>E. coli</i> , CFU or MPN/100 ml	63	N/A	197	N/A	One/month Grab

2. The effluent shall contain a chlorine residual of at least 1.0 mg/l and shall not exceed a chlorine residual of 4.0 mg/l after a detention time of at least 20 minutes (based on peak flow), and shall be monitored daily by grab sample. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.

3. The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored twice per month by grab sample.

4. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.

5. Effluent monitoring samples shall be taken at the following location(s): Following the final treatment unit.

6. The effluent shall contain a minimum dissolved oxygen of 6.0 mg/l and shall be monitored once per week by grab sample.

DEFINITIONS AND STANDARD PERMIT CONDITIONS

As required by Title 30 Texas Administrative Code (TAC) Chapter 305, certain regulations appear as standard conditions in waste discharge permits. 30 TAC § 305.121 - 305.129 (relating to Permit Characteristics and Conditions) as promulgated under the Texas Water Code (TWC) §§ 5.103 and 5.105, and the Texas Health and Safety Code (THSC) §§ 361.017 and 361.024(a), establish the characteristics and standards for waste discharge permits, including sewage sludge, and those sections of 40 Code of Federal Regulations (CFR) Part 122 adopted by reference by the Commission. The following text includes these conditions and incorporates them into this permit. All definitions in TWC § 26.001 and 30 TAC Chapter 305 shall apply to this permit and are incorporated by reference. Some specific definitions of words or phrases used in this permit are as follows:

1. Flow Measurements

- a. Annual average flow - the arithmetic average of all daily flow determinations taken within the preceding 12 consecutive calendar months. The annual average flow determination shall consist of daily flow volume determinations made by a totalizing meter, charted on a chart recorder and limited to major domestic wastewater discharge facilities with one million gallons per day or greater permitted flow.
- b. Daily average flow - the arithmetic average of all determinations of the daily flow within a period of one calendar month. The daily average flow determination shall consist of determinations made on at least four separate days. If instantaneous measurements are used to determine the daily flow, the determination shall be the arithmetic average of all instantaneous measurements taken during that month. Daily average flow determination for intermittent discharges shall consist of a minimum of three flow determinations on days of discharge.
- c. Daily maximum flow - the highest total flow for any 24-hour period in a calendar month.
- d. Instantaneous flow - the measured flow during the minimum time required to interpret the flow measuring device.
- e. 2-hour peak flow (domestic wastewater treatment plants) - the maximum flow sustained for a two-hour period during the period of daily discharge. The average of multiple measurements of instantaneous maximum flow within a two-hour period may be used to calculate the 2-hour peak flow.
- f. Maximum 2-hour peak flow (domestic wastewater treatment plants) - the highest 2-hour peak flow for any 24-hour period in a calendar month.

2. Concentration Measurements

- a. Daily average concentration - the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar month, consisting of at least four separate representative measurements.
 - i. For domestic wastewater treatment plants - When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values in the previous four consecutive month period consisting of at least four measurements shall be utilized as the daily average concentration.
 - ii. For all other wastewater treatment plants - When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values taken during the month shall be utilized as the daily average concentration.
- b. 7-day average concentration - the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar week, Sunday through Saturday.
- c. Daily maximum concentration - the maximum concentration measured on a single day, by the sample type specified in the permit, within a period of one calendar month.
- d. Daily discharge - the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in terms of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the sampling day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the average measurement of the pollutant over the sampling day.

The daily discharge determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the daily discharge determination of concentration shall be the arithmetic average (weighted by flow value) of all samples collected during that day.

- e. Bacteria concentration (*E. coli* or Enterococci) - Colony Forming Units (CFU) or Most Probable Number (MPN) of bacteria per 100 milliliters effluent. The daily average bacteria concentration is a geometric mean of the values for the effluent samples collected in a calendar month. The geometric mean shall be determined by calculating the n th root of the product of all measurements made in a calendar month, where n equals the number of measurements made; or, computed as the antilogarithm of the arithmetic mean of the logarithms of all measurements made in a calendar month. For any measurement of bacteria equaling zero, a substituted value of one shall be made for input into either computation method.

If specified, the 7-day average for bacteria is the geometric mean of the values for all effluent samples collected during a calendar week.

- f. Daily average loading (lbs/day) - the arithmetic average of all daily discharge loading calculations during a period of one calendar month. These calculations must be made for each day of the month that a parameter is analyzed. The daily discharge, in terms of mass (lbs/day), is calculated as (Flow, MGD x Concentration, mg/l x 8.34).
 - g. Daily maximum loading (lbs/day) - the highest daily discharge, in terms of mass (lbs/day), within a period of one calendar month.
3. Sample Type
- a. Composite sample - For domestic wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (a). For industrial wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (b).
 - b. Grab sample - an individual sample collected in less than 15 minutes.
4. Treatment Facility (facility) - wastewater facilities used in the conveyance, storage, treatment, recycling, reclamation and/or disposal of domestic sewage, industrial wastes, agricultural wastes, recreational wastes, or other wastes including sludge handling or disposal facilities under the jurisdiction of the Commission.
5. The term "sewage sludge" is defined as solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in 30 TAC Chapter 312. This includes the solids that have not been classified as hazardous waste separated from wastewater by unit processes.
6. Bypass - the intentional diversion of a waste stream from any portion of a treatment facility.

MONITORING AND REPORTING REQUIREMENTS

1. Self-Reporting

Monitoring results shall be provided at the intervals specified in the permit. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall conduct effluent sampling and reporting in accordance with 30 TAC

§§ 319.4 - 319.12. Unless otherwise specified, a monthly effluent report shall be submitted each month, to the Enforcement Division (MC 224), by the 20th day of the following month for each discharge which is described by this permit whether or not a discharge is made for that month. Monitoring results must be reported on an approved self-report form that is signed and certified as required by Monitoring and Reporting Requirements No. 10.

As provided by state law, the permittee is subject to administrative, civil and criminal penalties, as applicable, for negligently or knowingly violating the Clean Water Act (CWA); TWC §§ 26, 27, and 28; and THSC § 361, including but not limited to knowingly making any false statement, representation, or certification on any report, record, or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance, or falsifying, tampering with or knowingly rendering inaccurate any monitoring device or method required by this permit or violating any other requirement imposed by state or federal regulations.

2. Test Procedures

- a. Unless otherwise specified in this permit, test procedures for the analysis of pollutants shall comply with procedures specified in 30 TAC §§ 319.11 - 319.12. Measurements, tests, and calculations shall be accurately accomplished in a representative manner.
- b. All laboratory tests submitted to demonstrate compliance with this permit must meet the requirements of 30 TAC § 25, Environmental Testing Laboratory Accreditation and Certification.

3. Records of Results

- a. Monitoring samples and measurements shall be taken at times and in a manner so as to be representative of the monitored activity.
- b. Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), monitoring and reporting records, including strip charts and records of calibration and maintenance, copies of all records required by this permit, records of all data used to complete the application for this permit, and the certification required by 40 CFR § 264.73(b)(9) shall be retained at the facility site, or shall be readily available for review by a TCEQ representative for a period of three years from the date of the record or sample, measurement, report, application or certification. This period shall be extended at the request of the Executive Director.
- c. Records of monitoring activities shall include the following:

- i. date, time and place of sample or measurement;
- ii. identity of individual who collected the sample or made the measurement.
- iii. date and time of analysis;
- iv. identity of the individual and laboratory who performed the analysis;
- v. the technique or method of analysis; and
- vi. the results of the analysis or measurement and quality assurance/quality control records.

The period during which records are required to be kept shall be automatically extended to the date of the final disposition of any administrative or judicial enforcement action that may be instituted against the permittee.

4. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit using approved analytical methods as specified above, all results of such monitoring shall be included in the calculation and reporting of the values submitted on the approved self-report form. Increased frequency of sampling shall be indicated on the self-report form.

5. Calibration of Instruments

All automatic flow measuring or recording devices and all totalizing meters for measuring flows shall be accurately calibrated by a trained person at plant start-up and as often thereafter as necessary to ensure accuracy, but not less often than annually unless authorized by the Executive Director for a longer period. Such person shall verify in writing that the device is operating properly and giving accurate results. Copies of the verification shall be retained at the facility site and/or shall be readily available for review by a TCEQ representative for a period of three years.

6. Compliance Schedule Reports

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date to the Regional Office and the Enforcement Division (MC 224).

7. Noncompliance Notification

- a. In accordance with 30 TAC § 305.125(9) any noncompliance which may endanger human health or safety, or the environment shall be reported by the permittee to

the TCEQ. Report of such information shall be provided orally or by facsimile transmission (FAX) to the Regional Office within 24 hours of becoming aware of the noncompliance. A written submission of such information shall also be provided by the permittee to the Regional Office and the Enforcement Division (MC 224) within five working days of becoming aware of the noncompliance. The written submission shall contain a description of the noncompliance and its cause; the potential danger to human health or safety, or the environment; the period of noncompliance, including exact dates and times; if the noncompliance has not been corrected, the time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance, and to mitigate its adverse effects.

- b. The following violations shall be reported under Monitoring and Reporting Requirement 7.a.:
 - i. Unauthorized discharges as defined in Permit Condition 2(g).
 - ii. Any unanticipated bypass that exceeds any effluent limitation in the permit.
 - iii. Violation of a permitted maximum daily discharge limitation for pollutants listed specifically in the Other Requirements section of an Industrial TPDES permit.
 - c. In addition to the above, any effluent violation which deviates from the permitted effluent limitation by more than 40% shall be reported by the permittee in writing to the Regional Office and the Enforcement Division (MC 224) within 5 working days of becoming aware of the noncompliance.
 - d. Any noncompliance other than that specified in this section, or any required information not submitted or submitted incorrectly, shall be reported to the Enforcement Division (MC 224) as promptly as possible. For effluent limitation violations, noncompliances shall be reported on the approved self-report form.
8. In accordance with the procedures described in 30 TAC §§ 35.301 - 35.303 (relating to Water Quality Emergency and Temporary Orders) if the permittee knows in advance of the need for a bypass, it shall submit prior notice by applying for such authorization.
9. Changes in Discharges of Toxic Substances

All existing manufacturing, commercial, mining, and silvicultural permittees shall notify the Regional Office, orally or by facsimile transmission within 24 hours, and both the Regional Office and the Enforcement Division (MC 224) in writing within five (5) working days, after becoming aware of or having reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant listed at 40 CFR Part 122,

Appendix D, Tables II and III (excluding Total Phenols) which is not limited in the permit, if that discharge will exceed the highest of the following “notification levels”:

- i. One hundred micrograms per liter (100 µg/L);
 - ii. Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - iii. Five (5) times the maximum concentration value reported for that pollutant in the permit application; or
 - iv. The level established by the TCEQ.
- b. That any activity has occurred or will occur which would result in any discharge, on a nonroutine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following “notification levels”:
- i. Five hundred micrograms per liter (500 µg/L);
 - ii. One milligram per liter (1 mg/L) for antimony;
 - iii. Ten (10) times the maximum concentration value reported for that pollutant in the permit application; or
 - iv. The level established by the TCEQ.

10. Signatories to Reports

All reports and other information requested by the Executive Director shall be signed by the person and in the manner required by 30 TAC § 305.128 (relating to Signatories to Reports).

11. All Publicly Owned Treatment Works (POTWs) must provide adequate notice to the Executive Director of the following:

- a. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to CWA § 301 or § 306 if it were directly discharging those pollutants;
- b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit; and

- c. For the purpose of this paragraph, adequate notice shall include information on:
 - i. The quality and quantity of effluent introduced into the POTW; and
 - ii. Any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

PERMIT CONDITIONS

1. General

- a. When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in an application or in any report to the Executive Director, it shall promptly submit such facts or information.
- b. This permit is granted on the basis of the information supplied and representations made by the permittee during action on an application, and relying upon the accuracy and completeness of that information and those representations. After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked, in whole or in part, in accordance with 30 TAC Chapter 305, Subchapter D, during its term for good cause including, but not limited to, the following:
 - i. Violation of any terms or conditions of this permit;
 - ii. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
 - iii. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- c. The permittee shall furnish to the Executive Director, upon request and within a reasonable time, any information to determine whether cause exists for amending, revoking, suspending or terminating the permit. The permittee shall also furnish to the Executive Director, upon request, copies of records required to be kept by the permit.

2. Compliance

- a. Acceptance of the permit by the person to whom it is issued constitutes acknowledgment and agreement that such person will comply with all the terms and conditions embodied in the permit, and the rules and other orders of the Commission.
- b. The permittee has a duty to comply with all conditions of the permit. Failure to comply with any permit condition constitutes a violation of the permit and the

Texas Water Code or the Texas Health and Safety Code, and is grounds for enforcement action, for permit amendment, revocation, or suspension, or for denial of a permit renewal application or an application for a permit for another facility.

- c. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit.
- d. The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal or other permit violation that has a reasonable likelihood of adversely affecting human health or the environment.
- e. Authorization from the Commission is required before beginning any change in the permitted facility or activity that may result in noncompliance with any permit requirements.
- f. A permit may be amended, suspended and reissued, or revoked for cause in accordance with 30 TAC §§ 305.62 and 305.66 and TWC§ 7.302. The filing of a request by the permittee for a permit amendment, suspension and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
- g. There shall be no unauthorized discharge of wastewater or any other waste. For the purpose of this permit, an unauthorized discharge is considered to be any discharge of wastewater into or adjacent to water in the state at any location not permitted as an outfall or otherwise defined in the Other Requirements section of this permit.
- h. In accordance with 30 TAC § 305.535(a), the permittee may allow any bypass to occur from a TPDES permitted facility which does not cause permitted effluent limitations to be exceeded or an unauthorized discharge to occur, but only if the bypass is also for essential maintenance to assure efficient operation.
- i. The permittee is subject to administrative, civil, and criminal penalties, as applicable, under TWC §§ 7.051 - 7.075 (relating to Administrative Penalties), 7.101 - 7.111 (relating to Civil Penalties), and 7.141 - 7.202 (relating to Criminal Offenses and Penalties) for violations including, but not limited to, negligently or knowingly violating the federal CWA §§ 301, 302, 306, 307, 308, 318, or 405, or any condition or limitation implementing any sections in a permit issued under the CWA § 402, or any requirement imposed in a pretreatment program approved under the CWA §§ 402 (a)(3) or 402 (b)(8).

3. Inspections and Entry

- a. Inspection and entry shall be allowed as prescribed in the TWC Chapters 26, 27, and 28, and THSC § 361.

- b. The members of the Commission and employees and agents of the Commission are entitled to enter any public or private property at any reasonable time for the purpose of inspecting and investigating conditions relating to the quality of water in the state or the compliance with any rule, regulation, permit or other order of the Commission. Members, employees, or agents of the Commission and Commission contractors are entitled to enter public or private property at any reasonable time to investigate or monitor or, if the responsible party is not responsive or there is an immediate danger to public health or the environment, to remove or remediate a condition related to the quality of water in the state. Members, employees, Commission contractors, or agents acting under this authority who enter private property shall observe the establishment's rules and regulations concerning safety, internal security, and fire protection, and if the property has management in residence, shall notify management or the person then in charge of his presence and shall exhibit proper credentials. If any member, employee, Commission contractor, or agent is refused the right to enter in or on public or private property under this authority, the Executive Director may invoke the remedies authorized in TWC § 7.002. The statement above, that Commission entry shall occur in accordance with an establishment's rules and regulations concerning safety, internal security, and fire protection, is not grounds for denial or restriction of entry to any part of the facility, but merely describes the Commission's duty to observe appropriate rules and regulations during an inspection.

4. Permit Amendment and/or Renewal

- a. The permittee shall give notice to the Executive Director as soon as possible of any planned physical alterations or additions to the permitted facility if such alterations or additions would require a permit amendment or result in a violation of permit requirements. Notice shall also be required under this paragraph when:
 - i. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in accordance with 30 TAC § 305.534 (relating to New Sources and New Dischargers); or
 - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in the permit, nor to notification requirements in Monitoring and Reporting Requirements No. 9;
 - iii. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.

- b. Prior to any facility modifications, additions, or expansions that will increase the plant capacity beyond the permitted flow, the permittee must apply for and obtain proper authorization from the Commission before commencing construction.
 - c. The permittee must apply for an amendment or renewal at least 180 days prior to expiration of the existing permit in order to continue a permitted activity after the expiration date of the permit. If an application is submitted prior to the expiration date of the permit, the existing permit shall remain in effect until the application is approved, denied, or returned. If the application is returned or denied, authorization to continue such activity shall terminate upon the effective date of the action. If an application is not submitted prior to the expiration date of the permit, the permit shall expire and authorization to continue such activity shall terminate.
 - d. Prior to accepting or generating wastes which are not described in the permit application or which would result in a significant change in the quantity or quality of the existing discharge, the permittee must report the proposed changes to the Commission. The permittee must apply for a permit amendment reflecting any necessary changes in permit conditions, including effluent limitations for pollutants not identified and limited by this permit.
 - e. In accordance with the TWC § 26.029(b), after a public hearing, notice of which shall be given to the permittee, the Commission may require the permittee, from time to time, for good cause, in accordance with applicable laws, to conform to new or additional conditions.
 - f. If any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under CWA § 307(a) for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitation on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standard or prohibition. The permittee shall comply with effluent standards or prohibitions established under CWA § 307(a) for toxic pollutants within the time provided in the regulations that established those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.
5. Permit Transfer
- a. Prior to any transfer of this permit, Commission approval must be obtained. The Commission shall be notified in writing of any change in control or ownership of facilities authorized by this permit. Such notification should be sent to the Applications Review and Processing Team (MC 148) of the Water Quality Division.

- b. A permit may be transferred only according to the provisions of 30 TAC § 305.64 (relating to Transfer of Permits) and 30 TAC § 50.133 (relating to Executive Director Action on Application or WQMP update).

6. Relationship to Hazardous Waste Activities

This permit does not authorize any activity of hazardous waste storage, processing, or disposal that requires a permit or other authorization pursuant to the Texas Health and Safety Code.

7. Relationship to Water Rights

Disposal of treated effluent by any means other than discharge directly to water in the state must be specifically authorized in this permit and may require a permit pursuant to TWC Chapter 11.

8. Property Rights

A permit does not convey any property rights of any sort, or any exclusive privilege.

9. Permit Enforceability

The conditions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstances, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

10. Relationship to Permit Application

The application pursuant to which the permit has been issued is incorporated herein; provided, however, that in the event of a conflict between the provisions of this permit and the application, the provisions of the permit shall control.

11. Notice of Bankruptcy.

- a. Each permittee shall notify the Executive Director, in writing, immediately following the filing of a voluntary or involuntary petition for bankruptcy under any chapter of Title 11 (Bankruptcy) of the United States Code (11 USC) by or against:
 - i. the permittee;
 - ii. an entity (as that term is defined in 11 USC, § 101(14)) controlling the permittee or listing the permit or permittee as property of the estate; or
 - iii. an affiliate (as that term is defined in 11 USC, § 101(2)) of the permittee.

- b. This notification must indicate:
 - i. the name of the permittee and the permit number(s);
 - ii. the bankruptcy court in which the petition for bankruptcy was filed; and
 - iii. the date of filing of the petition.

OPERATIONAL REQUIREMENTS

1. The permittee shall at all times ensure that the facility and all of its systems of collection, treatment, and disposal are properly operated and maintained. This includes, but is not limited to, the regular, periodic examination of wastewater solids within the treatment plant by the operator in order to maintain an appropriate quantity and quality of solids inventory as described in the various operator training manuals and according to accepted industry standards for process control. Process control, maintenance, and operations records shall be retained at the facility site, or shall be readily available for review by a TCEQ representative, for a period of three years.
2. Upon request by the Executive Director, the permittee shall take appropriate samples and provide proper analysis in order to demonstrate compliance with Commission rules. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall comply with all applicable provisions of 30 TAC Chapter 312 concerning sewage sludge use and disposal and 30 TAC §§ 319.21 - 319.29 concerning the discharge of certain hazardous metals.
3. Domestic wastewater treatment facilities shall comply with the following provisions:
 - a. The permittee shall notify the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, in writing, of any facility expansion at least 90 days prior to conducting such activity.
 - b. The permittee shall submit a closure plan for review and approval to the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, for any closure activity at least 90 days prior to conducting such activity. Closure is the act of permanently taking a waste management unit or treatment facility out of service and includes the permanent removal from service of any pit, tank, pond, lagoon, surface impoundment and/or other treatment unit regulated by this permit.
4. The permittee is responsible for installing prior to plant start-up, and subsequently maintaining, adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failures by means of alternate power sources, standby generators, and/or retention of inadequately treated wastewater.

5. Unless otherwise specified, the permittee shall provide a readily accessible sampling point and, where applicable, an effluent flow measuring device or other acceptable means by which effluent flow may be determined.
6. The permittee shall remit an annual water quality fee to the Commission as required by 30 TAC Chapter 21. Failure to pay the fee may result in revocation of this permit under TWC § 7.302(b)(6).
7. Documentation

For all written notifications to the Commission required of the permittee by this permit, the permittee shall keep and make available a copy of each such notification under the same conditions as self-monitoring data are required to be kept and made available. Except for information required for TPDES permit applications, effluent data, including effluent data in permits, draft permits and permit applications, and other information specified as not confidential in 30 TAC §§ 1.5(d), any information submitted pursuant to this permit may be claimed as confidential by the submitter. Any such claim must be asserted in the manner prescribed in the application form or by stamping the words confidential business information on each page containing such information. If no claim is made at the time of submission, information may be made available to the public without further notice. If the Commission or Executive Director agrees with the designation of confidentiality, the TCEQ will not provide the information for public inspection unless required by the Texas Attorney General or a court pursuant to an open records request. If the Executive Director does not agree with the designation of confidentiality, the person submitting the information will be notified.

8. Facilities that generate domestic wastewater shall comply with the following provisions; domestic wastewater treatment facilities at permitted industrial sites are excluded.
 - a. Whenever flow measurements for any domestic sewage treatment facility reach 75% of the permitted daily average or annual average flow for three consecutive months, the permittee must initiate engineering and financial planning for expansion and/or upgrading of the domestic wastewater treatment and/or collection facilities. Whenever the flow reaches 90% of the permitted daily average or annual average flow for three consecutive months, the permittee shall obtain necessary authorization from the Commission to commence construction of the necessary additional treatment and/or collection facilities. In the case of a domestic wastewater treatment facility which reaches 75% of the permitted daily average or annual average flow for three consecutive months, and the planned population to be served or the quantity of waste produced is not expected to exceed the design limitations of the treatment facility, the permittee shall submit an engineering report supporting this claim to the Executive Director of the Commission.

If in the judgment of the Executive Director the population to be served will not cause permit noncompliance, then the requirement of this section may be waived. To be effective, any waiver must be in writing and signed by the Director of the Enforcement Division (MC 149) of the Commission, and such waiver of these requirements will be reviewed upon expiration of the existing permit; however, any such waiver shall not be interpreted as condoning or excusing any violation of any permit parameter.

- b. The plans and specifications for domestic sewage collection and treatment works associated with any domestic permit must be approved by the Commission and failure to secure approval before commencing construction of such works or making a discharge is a violation of this permit and each day is an additional violation until approval has been secured.
 - c. Permits for domestic wastewater treatment plants are granted subject to the policy of the Commission to encourage the development of area-wide waste collection, treatment, and disposal systems. The Commission reserves the right to amend any domestic wastewater permit in accordance with applicable procedural requirements to require the system covered by this permit to be integrated into an area-wide system, should such be developed; to require the delivery of the wastes authorized to be collected in, treated by or discharged from said system, to such area-wide system; or to amend this permit in any other particular to effectuate the Commission's policy. Such amendments may be made when the changes required are advisable for water quality control purposes and are feasible on the basis of waste treatment technology, engineering, financial, and related considerations existing at the time the changes are required, exclusive of the loss of investment in or revenues from any then existing or proposed waste collection, treatment or disposal system.
9. Domestic wastewater treatment plants shall be operated and maintained by sewage plant operators holding a valid certificate of competency at the required level as defined in 30 TAC Chapter 30.
 10. For Publicly Owned Treatment Works (POTWs), the 30-day average (or monthly average) percent removal for BOD and TSS shall not be less than 85%, unless otherwise authorized by this permit.
 11. Facilities that generate industrial solid waste as defined in 30 TAC § 335.1 shall comply with these provisions:
 - a. Any solid waste, as defined in 30 TAC § 335.1 (including but not limited to such wastes as garbage, refuse, sludge from a waste treatment, water supply treatment plant or air pollution control facility, discarded materials, discarded materials to be recycled, whether the waste is solid, liquid, or semisolid), generated by the permittee during the management and treatment of wastewater, must be managed in accordance with all applicable provisions of 30 TAC Chapter 335, relating to Industrial Solid Waste Management.

- b. Industrial wastewater that is being collected, accumulated, stored, or processed before discharge through any final discharge outfall, specified by this permit, is considered to be industrial solid waste until the wastewater passes through the actual point source discharge and must be managed in accordance with all applicable provisions of 30 TAC Chapter 335.
- c. The permittee shall provide written notification, pursuant to the requirements of 30 TAC § 335.8(b)(1), to the Environmental Cleanup Section (MC 127) of the Remediation Division informing the Commission of any closure activity involving an Industrial Solid Waste Management Unit, at least 90 days prior to conducting such an activity.
- d. Construction of any industrial solid waste management unit requires the prior written notification of the proposed activity to the Registration and Reporting Section (MC 129) of the Registration, Review, and Reporting Division. No person shall dispose of industrial solid waste, including sludge or other solids from wastewater treatment processes, prior to fulfilling the deed recordation requirements of 30 TAC § 335.5.
- e. The term "industrial solid waste management unit" means a landfill, surface impoundment, waste-pile, industrial furnace, incinerator, cement kiln, injection well, container, drum, salt dome waste containment cavern, or any other structure vessel, appurtenance, or other improvement on land used to manage industrial solid waste.
- f. The permittee shall keep management records for all sludge (or other waste) removed from any wastewater treatment process. These records shall fulfill all applicable requirements of 30 TAC § 335 and must include the following, as it pertains to wastewater treatment and discharge:
 - i. Volume of waste and date(s) generated from treatment process;
 - ii. Volume of waste disposed of on-site or shipped off-site;
 - iii. Date(s) of disposal;
 - iv. Identity of hauler or transporter;
 - v. Location of disposal site; and
 - vi. Method of final disposal.

The above records shall be maintained on a monthly basis. The records shall be retained at the facility site, or shall be readily available for review by authorized representatives of the TCEQ for at least five years.

- 12. For industrial facilities to which the requirements of 30 TAC § 335 do not apply, sludge and solid wastes, including tank cleaning and contaminated solids for disposal, shall be disposed of in accordance with THSC § 361.

TCEQ Revision 08/2008

SLUDGE PROVISIONS

The permittee is authorized to dispose of sludge only at a Texas Commission on Environmental Quality (TCEQ) authorized land application site or co-disposal landfill. **The disposal of sludge by land application on property owned, leased or under the direct control of the permittee is a violation of the permit unless the site is authorized with the TCEQ. This provision does not authorize Distribution and Marketing of sludge. This provision does not authorize land application of Class A Sludge. This provision does not authorize the permittee to land apply sludge on property owned, leased or under the direct control of the permittee.**

SECTION I. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE LAND APPLICATION

A. General Requirements

1. The permittee shall handle and dispose of sewage sludge in accordance with 30 TAC § 312 and all other applicable state and federal regulations in a manner that protects public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present in the sludge.
2. In all cases, if the person (permit holder) who prepares the sewage sludge supplies the sewage sludge to another person for land application use or to the owner or lease holder of the land, the permit holder shall provide necessary information to the parties who receive the sludge to assure compliance with these regulations.
3. The permittee shall give 180 days prior notice to the Executive Director in care of the Wastewater Permitting Section (MC 148) of the Water Quality Division of any change planned in the sewage sludge disposal practice.

B. Testing Requirements

1. Sewage sludge shall be tested once during the term of this permit in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I [Toxicity Characteristic Leaching Procedure (TCLP)] or other method that receives the prior approval of the TCEQ for the contaminants listed in 40 CFR Part 261.24, Table 1. Sewage sludge failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal. Following failure of any TCLP test, the management or disposal of sewage sludge at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until

such time as the permittee can demonstrate the sewage sludge no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Remediation Support Division and the Regional Director (MC Region 12) within seven (7) days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Registration, Review, and Reporting Division (MC 129), Texas Commission on Environmental Quality, P.O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. This annual report shall be submitted to the TCEQ Regional Office (MC Region 12) and the Water Quality Compliance Monitoring Team (MC 224) of the Enforcement Division by September 30 of each year.

2. Sewage sludge shall not be applied to the land if the concentration of the pollutants exceeds the pollutant concentration criteria in Table 1. The frequency of testing for pollutants in Table 1 is found in Section I.C.

TABLE 1

<u>Pollutant</u>	<u>Ceiling Concentration</u> <u>(Milligrams per kilogram)*</u>
Arsenic	75
Cadmium	85
Chromium	3000
Copper	4300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
PCBs	49
Selenium	100
Zinc	7500

* Dry weight basis

3. Pathogen Control

All sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site shall be treated by one of the following methods to ensure that the sludge meets either the Class A or Class B pathogen requirements.

- a. Six alternatives are available to demonstrate compliance with Class A sewage sludge. The first 4 options require either the density of fecal coliform in the sewage sludge be less than 1000 Most Probable Number (MPN) per gram of total solids (dry weight basis), or the density of Salmonella sp. bacteria in the sewage sludge be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. Below are the additional requirements necessary to meet the definition of a Class A sludge.

Alternative 1 - The temperature of the sewage sludge that is used or disposed shall be maintained at or above a specific value for a period of time. See 30 TAC § 312.82(a)(2)(A) for specific information.

Alternative 2 - The pH of the sewage sludge that is used or disposed shall be raised to above 12 std. units and shall remain above 12 std. units for 72 hours.

The temperature of the sewage sludge shall be above 52° Celsius for 12 hours or longer during the period that the pH of the sewage sludge is above 12 std. units.

At the end of the 72-hour period during which the pH of the sewage sludge is above 12 std. units, the sewage sludge shall be air dried to achieve a percent solids in the sewage sludge greater than 50%.

Alternative 3 - The sewage sludge shall be analyzed for enteric viruses prior to pathogen treatment. The limit for enteric viruses is less than one Plaque-forming Unit per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC § 312.82(a)(2)(C)(i-iii) for specific information. The sewage sludge shall be analyzed for viable helminth ova prior to pathogen treatment. The limit for viable helminth ova is less than one per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC § 312.82(a)(2)(C)(iv-vi) for specific information.

Alternative 4 - The density of enteric viruses in the sewage sludge shall be less than one Plaque-forming Unit per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. The density of viable helminth ova in the sewage sludge shall be less than one per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed.

Alternative 5 (PFRP) - Sewage sludge that is used or disposed of shall be treated in one of the processes to Further Reduce Pathogens (PFRP) described in 40 CFR Part 503, Appendix B. PFRP include composting, heat drying, heat treatment, and thermophilic aerobic digestion.

Alternative 6 (PFRP Equivalent) - Sewage sludge that is used or disposed of shall be treated in a process that has been approved by the U. S.

Environmental Protection Agency as being equivalent to those in Alternative 5.

- b. Three alternatives are available to demonstrate compliance with Class B criteria for sewage sludge.

Alternative 1

- i. A minimum of seven random samples of the sewage sludge shall be collected within 48 hours of the time the sewage sludge is used or disposed of during each monitoring episode for the sewage sludge.
- ii. The geometric mean of the density of fecal coliform in the samples collected shall be less than either 2,000,000 MPN per gram of total solids (dry weight basis) or 2,000,000 Colony Forming Units per gram of total solids (dry weight basis).

Alternative 2 - Sewage sludge that is used or disposed of shall be treated in one of the Processes to Significantly Reduce Pathogens (PSRP) described in 40 CFR Part 503, Appendix B, so long as all of the following requirements are met by the generator of the sewage sludge.

- i. Prior to use or disposal, all the sewage sludge must have been generated from a single location, except as provided in paragraph v. below;
- ii. An independent Texas Licensed Professional Engineer must make a certification to the generator of a sewage sludge that the wastewater treatment facility generating the sewage sludge is designed to achieve one of the PSRP at the permitted design loading of the facility. The certification need only be repeated if the design loading of the facility is increased. The certification shall include a statement indicating the design meets all the applicable standards specified in Appendix B of 40 CFR Part 503;
- iii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U. S. Environmental Protection Agency final guidance;
- iv. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for

a minimum of three years and be available for inspection by commission staff for review; and

- v. If the sewage sludge is generated from a mixture of sources, resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the PSRP, and shall meet the certification, operation, and record keeping requirements of this paragraph.

Alternative 3 - Sewage sludge shall be treated in an equivalent process that has been approved by the U. S. Environmental Protection Agency, so long as all of the following requirements are met by the generator of the sewage sludge.

- i. Prior to use or disposal, all the sewage sludge must have been generated from a single location, except as provided in paragraph v. below;
- ii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U. S. Environmental Protection Agency final guidance;
- iii. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for a minimum of three years and be available for inspection by commission staff for review;
- iv. The Executive Director will accept from the U. S. Environmental Protection Agency a finding of equivalency to the defined PSRP; and
- v. If the sewage sludge is generated from a mixture of sources resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the Processes to Significantly Reduce Pathogens, and shall meet the certification, operation, and record keeping requirements of this paragraph.

In addition, the following site restrictions must be met if Class B sludge is land applied:

- i. Food crops with harvested parts that touch the sewage sludge/soil mixture

and are totally above the land surface shall not be harvested for 14 months after application of sewage sludge.

- ii. Food crops with harvested parts below the surface of the land shall not be harvested for 20 months after application of sewage sludge when the sewage sludge remains on the land surface for 4 months or longer prior to incorporation into the soil.
- iii. Food crops with harvested parts below the surface of the land shall not be harvested for 38 months after application of sewage sludge when the sewage sludge remains on the land surface for less than 4 months prior to incorporation into the soil.
- iv. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of sewage sludge.
- v. Animals shall not be allowed to graze on the land for 30 days after application of sewage sludge.
- vi. Turf grown on land where sewage sludge is applied shall not be harvested for 1 year after application of the sewage sludge when the harvested turf is placed on either land with a high potential for public exposure or a lawn.
- vii. Public access to land with a high potential for public exposure shall be restricted for 1 year after application of sewage sludge.
- viii. Public access to land with a low potential for public exposure shall be restricted for 30 days after application of sewage sludge.
- ix. Land application of sludge shall be in accordance with the buffer zone requirements found in 30 TAC § 312.44.

4. Vector Attraction Reduction Requirements

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site shall be treated by one of the following Alternatives 1 through 10 for vector attraction reduction.

Alternative 1 - The mass of volatile solids in the sewage sludge shall be reduced by a minimum of 38%.

Alternative 2 - If Alternative 1 cannot be met for an anaerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge anaerobically in the laboratory in a bench-scale unit for 40 additional days at a temperature between 30° and 37° Celsius. Volatile solids must be reduced by less than 17% to demonstrate compliance.

- Alternative 3 - If Alternative 1 cannot be met for an aerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge with percent solids of two percent or less aerobically in the laboratory in a bench-scale unit for 30 additional days at 20° Celsius. Volatile solids must be reduced by less than 15% to demonstrate compliance.
- Alternative 4 - The specific oxygen uptake rate (SOUR) for sewage sludge treated in an aerobic process shall be equal to or less than 1.5 milligrams of oxygen per hour per gram of total solids (dry weight basis) at a temperature of 20° Celsius.
- Alternative 5 - Sewage sludge shall be treated in an aerobic process for 14 days or longer. During that time, the temperature of the sewage sludge shall be higher than 40° Celsius and the average temperature of the sewage sludge shall be higher than 45° Celsius.
- Alternative 6 - The pH of sewage sludge shall be raised to 12 or higher by alkali addition and, without the addition of more alkali shall remain at 12 or higher for two hours and then remain at a pH of 11.5 or higher for an additional 22 hours at the time the sewage sludge is prepared for sale or given away in a bag or other container.
- Alternative 7 - The percent solids of sewage sludge that does not contain unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 75% based on the moisture content and total solids prior to mixing with other materials. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.
- Alternative 8 - The percent solids of sewage sludge that contains unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 90% based on the moisture content and total solids prior to mixing with other materials at the time the sludge is used. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.
- Alternative 9 -
- i. Sewage sludge shall be injected below the surface of the land.
 - ii. No significant amount of the sewage sludge shall be present on the land surface within one hour after the sewage sludge is injected.

SECTION II. REQUIREMENTS SPECIFIC TO BULK SEWAGE SLUDGE FOR APPLICATION TO THE LAND MEETING CLASS A or B PATHOGEN REDUCTION AND THE CUMULATIVE LOADING RATES IN TABLE 2, OR CLASS B PATHOGEN REDUCTION AND THE POLLUTANT CONCENTRATIONS IN TABLE 3

For those permittees meeting Class A or B pathogen reduction requirements and that meet the cumulative loading rates in Table 2 below, or the Class B pathogen reduction requirements and contain concentrations of pollutants below listed in Table 3, the following conditions apply:

A. Pollutant Limits

Table 2

<u>Pollutant</u>	<u>Cumulative Pollutant Loading Rate (pounds per acre)*</u>
Arsenic	36
Cadmium	35
Chromium	2677
Copper	1339
Lead	268
Mercury	15
Molybdenum	Report Only
Nickel	375
Selenium	89
Zinc	2500

Table 3

<u>Pollutant</u>	<u>Monthly Average Concentration (milligrams per kilogram)*</u>
Arsenic	41
Cadmium	39
Chromium	1200
Copper	1500
Lead	300
Mercury	17
Molybdenum	Report Only
Nickel	420
Selenium	36
Zinc	2800

*Dry weight basis

B. Pathogen Control

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, a reclamation site, shall be treated by either Class A or Class B pathogen reduction requirements as defined above in Section I.B.3.

C. Management Practices

1. Bulk sewage sludge shall not be applied to agricultural land, forest, a public contact site, or a reclamation site that is flooded, frozen, or snow-covered so that the bulk sewage sludge enters a wetland or other waters in the State.
2. Bulk sewage sludge not meeting Class A requirements shall be land applied in a manner which complies with the Management Requirements in accordance with 30 TAC § 312.44.
3. Bulk sewage sludge shall be applied at or below the agronomic rate of the cover crop.
4. An information sheet shall be provided to the person who receives bulk sewage sludge sold or given away. The information sheet shall contain the following information:
 - a. The name and address of the person who prepared the sewage sludge that is sold or given away in a bag or other container for application to the land.
 - b. A statement that application of the sewage sludge to the land is prohibited except in accordance with the instruction on the label or information sheet.
 - c. The annual whole sludge application rate for the sewage sludge application rate for the sewage sludge that does not cause any of the cumulative pollutant loading rates in Table 2 above to be exceeded, unless the pollutant concentrations in Table 3 found in Section II above are met.

D. Notification Requirements

1. If bulk sewage sludge is applied to land in a State other than Texas, written notice shall be provided prior to the initial land application to the permitting authority for the State in which the bulk sewage sludge is proposed to be applied. The notice shall include:
 - a. The location, by street address, and specific latitude and longitude, of each land application site.
 - b. The approximate time period bulk sewage sludge will be applied to the site.

- c. The name, address, telephone number, and National Pollutant Discharge Elimination System permit number (if appropriate) for the person who will apply the bulk sewage sludge.
2. The permittee shall give 180 days prior notice to the Executive Director in care of the Wastewater Permitting Section (MC 148) of the Water Quality Division of any change planned in the sewage sludge disposal practice.

E. Record keeping Requirements

The sludge documents will be retained at the facility site and/or shall be readily available for review by a TCEQ representative. The person who prepares bulk sewage sludge or a sewage sludge material shall develop the following information and shall retain the information at the facility site and/or shall be readily available for review by a TCEQ representative for a period of five years. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply.

1. The concentration (mg/kg) in the sludge of each pollutant listed in Table 3 above and the applicable pollutant concentration criteria (mg/kg), or the applicable cumulative pollutant loading rate and the applicable cumulative pollutant loading rate limit (lbs/ac) listed in Table 2 above.
2. A description of how the pathogen reduction requirements are met (including site restrictions for Class B sludge, if applicable).
3. A description of how the vector attraction reduction requirements are met.
4. A description of how the management practices listed above in Section II.C are being met.
5. The following certification statement:

“I certify, under penalty of law, that the applicable pathogen requirements in 30 TAC § 312.82(a) or (b) and the vector attraction reduction requirements in 30 TAC § 312.83(b) have been met for each site on which bulk sewage sludge is applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices have been met. I am aware that there are significant penalties for false certification including fine and imprisonment.”

6. The recommended agronomic loading rate from the references listed in Section II.C.3. above, as well as the actual agronomic loading rate shall be retained. The person who applies bulk sewage sludge or a sewage sludge material shall develop the following information and shall retain the information at the facility site

and/or shall be readily available for review by a TCEQ representative indefinitely. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply:

- a. A certification statement that all applicable requirements (specifically listed) have been met, and that the permittee understands that there are significant penalties for false certification including fine and imprisonment. See 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii), as applicable, and to the permittee's specific sludge treatment activities.
- b. The location, by street address, and specific latitude and longitude, of each site on which sludge is applied.
- c. The number of acres in each site on which bulk sludge is applied.
- d. The date and time sludge is applied to each site.
- e. The cumulative amount of each pollutant in pounds/acre listed in Table 2 applied to each site.
- f. The total amount of sludge applied to each site in dry tons.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

F. Reporting Requirements

The permittee shall report annually to the TCEQ Regional Office (MC Region 12) and Water Quality Compliance Monitoring Team (MC 224) of the Enforcement Division, by September 30 of each year the following information:

1. Results of tests performed for pollutants found in either Table 2 or 3 as appropriate for the permittee's land application practices.
2. The frequency of monitoring listed in Section I.C. that applies to the permittee.
3. Toxicity Characteristic Leaching Procedure (TCLP) results.
4. Identity of hauler(s) and TCEQ transporter number.
5. PCB concentration in sludge in mg/kg.
6. Date(s) of disposal.
7. Owner of disposal site(s).
8. Texas Commission on Environmental Quality registration number, if applicable.

9. Amount of sludge disposal dry weight (lbs/acre) at each disposal site.
10. The concentration (mg/kg) in the sludge of each pollutant listed in Table 1 (defined as a monthly average) as well as the applicable pollutant concentration criteria (mg/kg) listed in Table 3 above, or the applicable pollutant loading rate limit (lbs/acre) listed in Table 2 above if it exceeds 90% of the limit.
11. Level of pathogen reduction achieved (Class A or Class B).
12. Alternative used as listed in Section I.B.3.(a. or b.). Alternatives describe how the pathogen reduction requirements are met. If Class B sludge, include information on how site restrictions were met.
13. Vector attraction reduction alternative used as listed in Section I.B.4.
14. Annual sludge production in dry tons/year.
15. Amount of sludge land applied in dry tons/year.
16. The certification statement listed in either 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii) as applicable to the permittee's sludge treatment activities, shall be attached to the annual reporting form.
17. When the amount of any pollutant applied to the land exceeds 90% of the cumulative pollutant loading rate for that pollutant, as described in Table 2, the permittee shall report the following information as an attachment to the annual reporting form.
 - a. The location, by street address, and specific latitude and longitude.
 - b. The number of acres in each site on which bulk sewage sludge is applied.
 - c. The date and time bulk sewage sludge is applied to each site.
 - d. The cumulative amount of each pollutant (i.e., pounds/acre) listed in Table 2 in the bulk sewage sludge applied to each site.
 - e. The amount of sewage sludge (i.e., dry tons) applied to each site.

The above records shall be maintained on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

**SECTION III. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE
DISPOSED IN A MUNICIPAL SOLID WASTE LANDFILL**

- A. The permittee shall handle and dispose of sewage sludge in accordance with 30 TAC § 330 and all other applicable state and federal regulations to protect public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present. The permittee shall ensure that the sewage sludge meets the requirements in 30 TAC § 330 concerning the quality of the sludge disposed in a municipal solid waste landfill.
- B. If the permittee generates sewage sludge and supplies that sewage sludge to the owner or operator of a municipal solid waste landfill (MSWLF) for disposal, the permittee shall provide to the owner or operator of the MSWLF appropriate information needed to be in compliance with the provisions of this permit.
- C. The permittee shall give 180 days prior notice to the Executive Director in care of the Wastewater Permitting Section (MC 148) of the Water Quality Division of any change planned in the sewage sludge disposal practice.
- D. Sewage sludge shall be tested once during the term of this permit in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I (Toxicity Characteristic Leaching Procedure) or other method, which receives the prior approval of the TCEQ for contaminants listed in Table 1 of 40 CFR § 261.24. Sewage sludge failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal.

Following failure of any TCLP test, the management or disposal of sewage sludge at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until such time as the permittee can demonstrate the sewage sludge no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Remediation Support Division and the Regional Director (MC Region 12) of the appropriate TCEQ field office within 7 days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Registration, Review, and Reporting Division (MC 129), Texas Commission on Environmental Quality, P. O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. This annual report shall be submitted to the TCEQ Regional Office (MC Region 12) and the Water Quality Compliance Monitoring Team (MC 224) of the Enforcement Division by September 30 of each year.

E. Sewage sludge shall be tested as needed, in accordance with the requirements of 30 TAC Chapter 330.

F. Record keeping Requirements

The permittee shall develop the following information and shall retain the information for five years.

1. The description (including procedures followed and the results) of all liquid Paint Filter Tests performed.
2. The description (including procedures followed and results) of all TCLP tests performed.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

G. Reporting Requirements

The permittee shall report annually to the TCEQ Regional Office (MC Region 12) and Water Quality Compliance Monitoring Team (MC 224) of the Enforcement Division by September 30 of each year the following information:

1. Toxicity Characteristic Leaching Procedure (TCLP) results.
2. Annual sludge production in dry tons/year.
3. Amount of sludge disposed in a municipal solid waste landfill in dry tons/year.
4. Amount of sludge transported interstate in dry tons/year.
5. A certification that the sewage sludge meets the requirements of 30 TAC § 330 concerning the quality of the sludge disposed in a municipal solid waste landfill.
6. Identity of hauler(s) and transporter registration number.
7. Owner of disposal site(s).
8. Location of disposal site(s).
9. Date(s) of disposal.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

OTHER REQUIREMENTS

1. The permittee shall employ or contract with one or more licensed wastewater treatment facility operators or wastewater system operations companies holding a valid license or registration according to the requirements of 30 TAC Chapter 30, Occupational Licenses and Registrations and in particular 30 TAC Chapter 30, Subchapter J, Wastewater Operators and Operations Companies.

This Category C facility must be operated by a chief operator or an operator holding a Category C license or higher. The facility must be operated a minimum of five days per week by the licensed chief operator or an operator holding the required level of license or higher. The licensed chief operator or operator holding the required level of license or higher must be available by telephone or pager seven days per week. Where shift operation of the wastewater treatment facility is necessary, each shift which does not have the on-site supervision of the licensed chief operator must be supervised by an operator in charge who is licensed not less than one level below the category for the facility.

2. The facility is not located in the Coastal Management Program boundary.
3. The permittee is hereby placed on notice that this permit may be reviewed by the TCEQ after the completion of any new intensive water quality survey on Segment No. 1014 of the San Jacinto River Basin and any subsequent updating of the water quality model for Segment No. 1014, in order to determine if the limitations and conditions contained herein are consistent with any such revised model. The permit may be amended, pursuant to 30 TAC § 305.62, as a result of such review. The permittee is also hereby placed on notice that effluent limits may be made more stringent at renewal based on, for example, any change to modeling protocol approved in the TCEQ Continuing Planning Process.
4. In accordance with 30 TAC §319.9, a permittee that has at least twelve months of uninterrupted compliance with its bacteria limit may notify the commission in writing of its compliance and request a less frequent measurement schedule. To request a less frequent schedule, the permittee shall submit a written request to the TCEQ Wastewater Permitting Section (MC 148) for each phase that includes a different monitoring frequency. The request must contain all of the reported bacteria values (Daily Avg. and Daily Max/Single Grab) for the twelve consecutive months immediately prior to the request. If the Executive Director finds that a less frequent measurement schedule is protective of human health and the environment, the permittee will be given a less frequent measurement schedule. For this permit, 1/month will be reduced to 1/quarter. **A violation of any bacteria limit by a facility that has been granted a less frequent measurement schedule will require the permittee to return to the standard frequency schedule**, and the permittee may not apply for another reduction in measurement frequency for at least 24 months from the date of the last violation. The Executive Director may establish a more frequent measurement schedule if necessary to protect human health or the environment.

CONTRIBUTING INDUSTRIES AND PRETREATMENT REQUIREMENTS

1. The following pollutants may not be introduced into the treatment facility:
 - a. Pollutants which create a fire or explosion hazard in the publicly owned treatment works (POTW), including, but not limited to, waste streams with a closed cup flashpoint of less than 140 degrees Fahrenheit (60 degrees Celsius) using the test methods specified in 40 CFR § 261.21;
 - b. Pollutants which will cause corrosive structural damage to the POTW, but in no case shall there be discharges with pH lower than 5.0 standard units, unless the works are specifically designed to accommodate such discharges;
 - c. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW, resulting in Interference;
 - d. Any pollutant, including oxygen demanding pollutants (e.g., BOD), released in a discharge at a flow rate and/or pollutant concentration which will cause Interference with the POTW;
 - e. Heat in amounts which will inhibit biological activity in the POTW resulting in Interference but in no case shall there be heat in such quantities that the temperature at the POTW treatment plant exceeds 104 degrees Fahrenheit (40 degrees Celsius) unless the Executive Director, upon request of the POTW, approves alternate temperature limits;
 - f. Petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause Interference or Pass Through;
 - g. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems; and
 - h. Any trucked or hauled pollutants, except at discharge points designated by the POTW.
2. The permittee shall require any indirect discharger to the treatment works to comply with the reporting requirements of Sections 204(b), 307, and 308 of the Clean Water Act, including any requirements established under 40 CFR Part 403[*rev. Federal Register/ Vol. 70/ No. 198/ Friday, October 14, 2005/ Rules and Regulations, pages 60134-60798*].
3. The permittee shall provide adequate notification to the Executive Director care of the Wastewater Permitting Section (MC 148) of the Water Quality Division within 30 days subsequent to the permittee's knowledge of either of the following:
 - a. Any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Sections 301 and 306 of the Clean Water Act if it were directly discharging those pollutants; and

- b. Any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of the permit.

Any notice shall include information on the quality and quantity of effluent to be introduced into the treatment works, and any anticipated impact of the change on the quality or quantity of effluent to be discharged from the POTW.

Revised July 2007

ATTACHMENT D

TCEQ INTRA-AGENCY TRANSMITTAL MEMO

DATE: August 20, 2014

TO: FINAL DOCUMENTS TEAM LEADER
OFFICE OF THE CHIEF CLERK
BUILDING F, MC-105

FROM: ALICIA RAMIREZ
ENVIRONMENTAL LAW DIVISION
BUILDING A, MC-173

Attached: Executive Director's Response to Comments

Application Information

Program Area (Air, Water or Waste): **Water**

Permit No. **WQ0012346001**

Name: **WEST PARK MUNICIPAL UTILITY DISTRICT**

Docket/CID Item # (if known): _____

CHIEF CLERKS OFFICE
2014 AUG 20 PM 3: 22
TEXAS COMMISSION
ON ENVIRONMENTAL
QUALITY

OCC Action Required (check applicable boxes)

Date stamp and return copy to above-noted ELD Staff Attorney and:

FOR ALL PROGRAM AREAS: (required only when changes needed to official agency mailing list)

- Update** the mailing list in your file with the attached contact names and addresses
Include corrected or additional names and addresses for mailing list

FOR WASTE & WATER:

- Send Response to Comments Letter which solicits hearing requests and requests for reconsideration to the mailing list in your files
For Waste and Water this would occur in all circumstances when comments have been received for 801 applications
- Or
- Send Response to Comments Letter and Motion to Overturn Letter which solicits motions to overturn to the mailing list in your files
For Waste and Water this may occur when all comments have been withdrawn for 801 applications or when comments are received for applications that will not be set for agenda.

FOR AIR (NSR only):

- Send RTC with response to comments letter which solicits contested case hearing requests and requests for reconsideration to the mailing list in your files
For Air NSR applications this would occur only when there are pending contested case hearing requests (except no-increase renewals)
- Set for commission agenda and send RTC with agenda setting letter
This would occur when there are pending contested case hearing requests on a no-increase renewal and technical review is complete.
- Hold until a commission agenda date is requested and then send RTC with the Agenda Setting Letter
For Air applications this would occur when there are pending hearing requests on a no-increase renewal; but technical review is NOT complete. If this box is checked, ED staff must call the OCC Agenda Team Leader to arrange a specific agenda date.
- Place RTC in File - no further action required by OCC
For Air NSR applications this would occur when the matter is uncontested but comments were received, APD will send a copy with MTO letter

Other Instructions: _____

TPDES PERMIT NO. WQ0012346001

**APPLICATION BY
WEST PARK MUNICIPAL
UTILITY DISTRICT**

§
§
§

**BEFORE THE
TEXAS COMMISSION ON
ENVIRONMENTAL QUALITY**

TEXAS
COMMISSION
ON ENVIRONMENTAL
QUALITY
2014 APR 10 PM 3:22
CHIEF CLERK'S OFFICE

EXECUTIVE DIRECTOR'S RESPONSE TO PUBLIC COMMENT

The Executive Director (ED) of the Texas Commission on Environmental Quality (the commission or TCEQ) files this Response to Public Comment (Response) on the West Park Municipal Utility District's (Applicant) application and ED's preliminary decision. As required by 30 Texas Administrative Code (TAC) Section (§) 55.156, before a permit is issued, the ED prepares a response to all timely, relevant and material, or significant comments. The Office of Chief Clerk received timely comment letters from the following persons: Annette Mennen Baldwin, C. A. Preator, Lorna Miller, Steve Redditt, Eric V. Anderson, Franklin Marquardt, Jimmy Vance, Malcolm Baker, Robin Snitofsky, Carla Scholwinski, Elizabeth Etzel, Sheila Bradford, Sherryl R. Clark, Jeanne Strange, Jerome D. Richardson, Cynthia Ann Bryant, David T Bryant, Frank Weido, Sherry Thompson, and Brenna Rektorik. This response addresses all such timely public comments received, whether or not withdrawn. If you need more information about this permit application or the wastewater permitting process, please call the TCEQ Public Participation and Education Program at 1-800-687-4040. General information about the TCEQ can be found at our website at www.tceq.state.tx.us.

I. BACKGROUND

A. Description of Facility

West Park Municipal Utility District has applied to the TCEQ for a major amendment that will authorize an increase in the discharge of treated domestic wastewater from a daily average flow not to exceed 0.5 million gallons per day to a daily average flow not to exceed 0.99 million gallons per day. The wastewater treatment facility serves the West Park Municipal Utility District. The wastewater treatment facility site is located at 19310 Katy Freeway, Houston in Harris County, Texas 77094.

The West Park Municipal Utility District Wastewater Treatment Facility is an activated sludge process plant operated in the contact stabilization mode with single stage nitrification. In the Interim phase, treatment units include bar screens, two aeration basins, two final clarifiers, two sludge digesters, and a chlorine contact chamber. In the Final phase, treatment units will include bar screens, three aeration basins, two final clarifiers, three aerobic digesters, and a chlorine contact basin. The wastewater treatment facility is operating in the interim phase. Sludge generated from the wastewater treatment facility is hauled by a registered transporter and disposed of at a TCEQ authorized land application site, El Celoso Ranch, Permit No. WQ0004518000,

in Waller County. The draft permit also authorizes the disposal of sludge at a TCEQ authorized land application site or co-disposal landfill.

The effluent limitations in both phases of the draft permit, based on a 30-day average, are 7 mg/l five-day carbonaceous biochemical oxygen demand (CBOD₅), 15 mg/l total suspended solids (TSS), 2 mg/l ammonia-nitrogen (NH₃-N), 63 colony forming units (CFU) or most probable number (MPN) of *E. coli* per 100 ml and 6.0 mg/l minimum dissolved oxygen (DO). The effluent shall contain a chlorine residual of at least 1.0 mg/l and shall not exceed a chlorine residual of 4.0 mg/l after a detention time of at least 20 minutes based on peak flow.

The treated effluent is discharged to Harris County Flood Control District (HCFCD) ditch U101-02-00; then to South Mayde Creek; then to Buffalo Bayou Above Tidal in Segment No. 1014 of the San Jacinto River Basin. The unclassified receiving water uses are minimal aquatic life use for HCFCD ditch U101-02-00, limited aquatic life use for South Mayde Creek (upstream of unnamed tributary 0.62 km east of Barker-Cypress Road), and intermediate aquatic life use for South Mayde Creek (downstream of unnamed tributary 0.62 km east of Barker-Cypress Road). The designated uses for Segment No. 1014 are limited aquatic life use and primary contact recreation. The effluent limitations in the draft permit will maintain and protect the existing instream uses. In accordance with 30 Texas Administrative Code §307.5 and the TCEQ implementation procedures (June 2010) for the Texas Surface Water Quality Standards, an antidegradation review of the receiving waters was performed. A Tier 1 antidegradation review has preliminarily determined that existing water quality uses will not be impaired by this permit action. Numerical and narrative criteria to protect existing uses will be maintained. A Tier 2 review has preliminarily determined that no significant degradation of water quality is expected in South Mayde Creek (downstream of unnamed tributary 0.62 km east of Barker-Cypress Road), which has been identified as having intermediate aquatic life use. Existing uses will be maintained and protected. This preliminary determination can be reexamined and may be modified if new information is received.

B. Procedural Background

The application for major amendment was received on November 5, 2013 and declared administratively complete on January 8, 2014. The Notice of Receipt and Intent to Obtain a Water Quality Permit (NORI) was published on January 19, 2014 in the *Houston Chronicle* and in Spanish on January 19, 2014 in *La Voz de Houston*. The Notice of Application and Preliminary Decision (NAPD) for a Water Quality Permit was published on April 20, 2014 in the *Houston Chronicle*, and in Spanish on April 20, 2014 in *La Voz de Houston*. The public comment period ended on May 20, 2014. This application was administratively complete on or after September 1, 1999; therefore, this application is subject to the procedural requirements adopted pursuant to House Bill 801, 76th Legislature, 1999.

C. Access to Rules, Laws and Records

Please consult the following websites to access the rules and regulations applicable to this permit:

- to access the Secretary of State website: www.sos.state.tx.us;
- for TCEQ rules in Title 30 of the Texas Administrative Code: www.sos.state.tx.us/tac/ (select “TAC Viewer” on the right, then “Title 30 Environmental Quality”);
- for Texas statutes: www.capitol.state.tx.us/statutes/statutes.html;
- to access the TCEQ website: www.tceq.texas.gov (for downloadable rules in Adobe PDF formats, select “Rules” then “Current TCEQ Rules”, then “Download TCEQ Rules”);
- for Federal rules in Title 40 of the Code of Federal Regulations: www.epa.gov/epahome/cfr40.htm; and
- for Federal environmental laws: www.epa.gov/epahome/laws.htm.

Commission records on the Application are available for viewing and copying at the TCEQ’s Region 12 Office, 5425 Polk Street, Suite H, Houston, Texas.

II. COMMENTS AND RESPONSES

Comment 1:

All commenters expressed concerns for flooding in the receiving stream, South Mayde Creek. The commenters are concerned that there is no room in the Creek for the increase in flow from the Wastewater Treatment Facility. Several commenters explained that the Westlake community, particularly Cullen Park, floods during rain events. Eric V. Anderson and Jerome D. Richardson expressed concern for excessive rainfall events. Jeanne C. Strange, Elizabeth Etzel, C. A. Preator, Sherryl R. Clark, and Sherry Thompson also expressed concerns about backup at Cullen Park. C. A. Preator, Malcolm Baker, Jeanne Strange, Sherry Thompson, and Sherryl R. Clark, expressed concern about blockage or flooding on the property of the Army Corps of Engineers. C. A. Preator, Jimmy Vance, and Jeanne Strange also expressed concerns about trash and debris in the Creek.

Response 1:

TPDES permits establish terms and conditions that are intended to provide water quality pollution control. Therefore, the TCEQ’s review of an application for a TPDES permit focuses on controlling the discharge of pollutants into water in the state. The TCEQ does not have jurisdiction to address flooding, blockage, and trash downstream in the wastewater permitting process, unless there is an associated water quality concern.

The draft permit includes effluent limits and other requirements that the Applicant must meet even during rainfall events and periods of flooding. Additionally, the Federal Emergency Management Agency (FEMA) has programs that are designed to mitigate damage caused by flooding. Please contact your local floodplain administrator if you have additional flooding concerns. More information about your local floodplain administrator can be found at the following website: <http://www.hcfd.org/floodplain/>.

Comment 2:

Malcolm Baker asked what alternative discharge routes have been considered and David T. Bryant asked what alternatives had been considered. Franklin Marquardt commented that there must be alternatives to [discharging treated effluent to South Mayde Creek]. Annette Baldwin stated that the Addicks and Barker Reservoirs, built by the Army Corps of Engineers, are rated by the Federal Corps of Engineers as at risk for "catastrophic failure". Ms. Baldwin is concerned that the flow from the wastewater treatment facility, which flows from South Mayde Creek to Addicks Reservoir, puts areas of Houston in jeopardy. Ms. Baldwin suggested the flow from the wastewater treatment facility be diverted south to avoid the reservoirs. Eric Anderson also expressed concern about adding water to the Addicks Reservoir. He stated that flood control personnel previously stated that no additional water would be added to South Mayde Creek and Addicks Reservoir.

Response 2:

Texas Water Code, Section 26.121, authorizes discharges into waters of the state, provided the discharger obtains a permit from the Commission. TCEQ evaluates applications for wastewater treatment facilities based on the information provided in the application. TCEQ does not have authority to mandate a different outfall location or a different discharge route, if the applicant's proposed location and discharge route comply with TCEQ's rules. If the Applicant updates its application with a different outfall location or a different discharge route, the ED will reevaluate the discharge route to make sure that the draft permit contains appropriate limits and conditions for the revised discharge location or route. Similarly, if the Applicant decides to enclose (pipe) its effluent downstream and discharge at a different location, the ED must reevaluate the discharge route to ensure the effluent limits in the draft permit still comply with TCEQ's rules.

Comment 3:

Eric Anderson stated that the drainage area is in need of expansion.

Response 3:

TCEQ does not have authority to require the Applicant expand the discharge route, if the Applicant's proposed location and discharge route comply with TCEQ's rules.

Comment 4:

Jerome D. Richardson expressed concern that the Applicant will profit at the community's expense.

Response 4:

The TCEQ may not prohibit an applicant from receiving an authorization if the application complies with all statutory and regulatory requirements. Further, the TCEQ does not consider a company's profit motive in determining whether a wastewater discharge permit should be issued.

Comment 5:

Eric V. Anderson, Franklin Marquardt, Jerome D. Richardson, and Sherryl R. Clark expressed concerns about the effects of the discharge on the environment, water quality, and human health. Sherryl R. Clark asked if the water was clean enough to be released into an above ground drain system. Eric V. Anderson expressed concern about whether treated effluent was safe for wildlife.

Response 5:

The draft permit includes effluent limitations and monitoring requirements for 5-day Biochemical Oxygen Demand (BOD₅), Total Suspended Solids (TSS), ammonia nitrogen (NH₃-N), chlorine residual, *E. coli* bacteria, and pH to ensure that the proposed wastewater treatment facility meets water quality standards for the protection of surface water quality, groundwater, and human health according to TCEQ rules and policies. The draft permit also includes pretreatment requirements for the wastewater treatment system to ensure the protection of water quality and human health. The draft permit includes requirements for the disposal of domestic sludge generated from the wastewater treatment facility based on TCEQ rules.

Further, the draft permit was developed to protect aquatic life and human health in accordance with the Texas Surface Water Quality Standards. The draft permit was established to be protective of human health and the environment provided the Applicant operates and maintains the wastewater treatment facility according to TCEQ rules and the requirements in the draft permit. As part of the permit application process, TCEQ must determine the uses of the receiving water and set effluent limits that are protective of those uses. The effluent limits in the draft permit are set to maintain and protect the existing instream uses. In this case, the receiving stream uses are minimal aquatic life use for HCFCD ditch U101-02-00, limited aquatic life use for South Mayde Creek (upstream of unnamed tributary 0.62 km east of Barker-Cypress Road), and intermediate aquatic life use for South Mayde Creek (downstream of unnamed tributary 0.62 km east of Barker-Cypress Road). The designated uses for Segment No. 1014 are limited aquatic life use and primary contact recreation. The ED determined that these uses should be protected if the wastewater treatment facility is operated and maintained as required by the draft permit and regulations.

The ED has determined that the draft permit is protective of the environment, water quality, and human health and that it meets TCEQ rules and requirements. To report complaints about the wastewater treatment facility, please contact the TCEQ Region 12 Office at 1-713-767-3500, or e-mail complaint@TCEQ.state.tx.us. Noncompliance with the permit will result in enforcement action against the Applicant.

Comment 6:

Sherry Thompson, Annette Baldwin, Sheila Bradford, Sherryl R. Clark, Jeanne Strange, and Frank Weido expressed concern that the increase in discharge will negatively impact the price of flood insurance. Sherryl R. Clark and Robin Snitofsky also expressed concern the discharge will negatively impact their property values and enjoyment of their property or neighborhood.

Response 6:

The TCEQ does not have jurisdiction to review the effect, if any, that the location of the discharge route might have on property values or flood insurance of surrounding landowners in reviewing a domestic wastewater discharge permit application.

Comment 7:

Lorna Miller, Eric Anderson, and Carla Scholwinski expressed concern of medical waste in the effluent from the wastewater treatment facility.

Response 7:

The West Park Municipal Utility District Wastewater Treatment Facility treats municipal wastewater only. No industrial or medical waste is discharged to the wastewater treatment facility. However, commercial properties and doctor's offices in the service area may discharge municipal wastewater to the wastewater treatment facility. The draft permit includes specific requirements that establish the responsibilities of local government, industry, and the public to implement the standards to control pollutants which pass through or interfere with treatment processes in publicly owned treatment works or which may contaminate the sewage sludge. This draft permit has appropriate pretreatment language for a facility of this size and complexity. The pretreatment requirements outline what type of pollutants may not be introduced into the facility.

Comment 8:

Franklin Marquardt expressed concern of the smell from the treated wastewater flowing behind his house.

Response 8:

Flow from the wastewater treatment facility will be treated effluent. The Applicant is required to meet the effluent limitations of 7 mg/l CBOD₅, 15 mg/l TSS, 2 mg/l NH₃-N, 63 CFU or MPN of *E. coli* per 100 ml and 6.0 mg/l minimum dissolved oxygen (DO), based on a 30-day average. The effluent shall contain a chlorine residual of at least 1.0 mg/l and shall not exceed a chlorine residual of 4.0 mg/l after a detention time of at least 20 minutes based on peak flow. Effluent that has been treated to this quality is not expected to have an offensive odor. However, if an odor is detected, complaints may be filed with the TCEQ Region 12 Office at 1-713-767-3500, or by e-mail at cmplaint@TCEQ.state.tx.us.

Comment 9:

Jerome D. Richardson suggested the Applicant expand the capacity of the wastewater treatment facility to accommodate the increase in volume caused by development.

Response 9:

The Applicant is expanding its treatment capacity with this permitting action. The Applicant is currently authorized to treat and discharge 0.5 million gallons per day (MGD). The current permitting action will authorize the Applicant to treat and discharge 0.99 (MGD).

Comment 10:

C. A. Preator stated that more investigation needs to be done and questions answered before this permit is approved.

Response 10:

The ED has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The Texas Water Code, Section 26.121, authorizes discharges into waters of the state, provided the discharger obtains a permit from the Commission. TCEQ evaluates applications for wastewater treatment facilities based on the information provided in the application. TCEQ does not have authority to mandate that the Applicant provide more than what is required by statute and rule.

Comment 11:

Malcolm Baker asked what is the proposal to keep wastewater in the Westlake Community.

Response 11:

West Park Municipal Utility District has applied to the TCEQ for a major amendment that will authorize an increase in the discharge of treated domestic wastewater from a daily average flow not to exceed 0.5 million gallons per day to a daily average flow not to exceed 0.99 million gallons per day.

Comment 12:

Sherryl R. Clark commented that a utility study should have been done before building permits were issued to determine the impact on existing neighborhoods.

Response 12:

TCEQ does not issue building permits and does not have the authority to require the Applicant to perform a utility study. The ED has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The Texas Water Code, Section 26.121, authorizes discharges into waters of the state, provided the discharger obtains a permit from the Commission. TCEQ evaluates applications for wastewater treatment facilities based on the information provided in the application.

TCEQ does not have authority to mandate that the Applicant provide more than what is required by statute and rule. Additionally, the Applicant must comply with all federal, state, and local regulations.

Comment 13:

Sherryl R. Clark commented that there will be an increase in stagnant water in the Cullen Park area as a result of this permitting action.

Response 13:

The ED has determined that it is unlikely that the discharge from the Applicant's wastewater treatment facility will cause South Mayde Creek to stagnate. South Mayde Creek in Segment 1014 is a perennial stream. A perennial stream is a stream that has continuous flow in parts of its stream bed all year round during years of normal rainfall.

In addition, the draft permit requires the treated effluent to be disinfected prior to discharge. Chlorination of the treated effluent is required to provide adequate disinfection and reduce pathogenic organisms. The effluent must be chlorinated in a chlorine contact chamber to a chlorine residual of 1.0 mg/l with a minimum detention time of 20 minutes. The chlorine residual must be monitored five times per week by grab sample according to the draft permit requirements.

Comment 14:

Eric V. Anderson expressed concern about emergency releases and unanticipated emergencies or system failures at the wastewater treatment facility.

Response 14:

In accordance with 30 TAC § 217.36, the treatment facility has incorporated an on-site generator that starts automatically in the case of power failure. Additionally, in accordance with 30 TAC § 217.37, the disinfection system will automatically restart during a power outage. The Applicant is required to report any unauthorized discharge to TCEQ within 24 hours. If the Applicant fails to report the unauthorized discharge or bypass to TCEQ within the prescribed time period, the Applicant will be subject to enforcement by TCEQ. At the time of any accidental discharge, TCEQ and other local governmental entities determine if nearby residents need to be notified of any leak or runoff based on the severity and potential health impact of the discharge.

Changes Made to the Draft Permit in Response to Comments

No changes to the draft permit have been made in response to public comment.

Respectfully submitted,

Texas Commission on Environmental Quality

Richard A. Hyde, P.E.
Executive Director

Robert Martinez, Director
Environmental Law Division



Alicia Ramirez, Staff Attorney
Environmental Law Division
State Bar No. 24032665
P.O. Box 13087, MC 173
Austin, Texas 78711-3087
(512) 239-0600
REPRESENTING THE
EXECUTIVE DIRECTOR OF THE
TEXAS COMMISSION ON
ENVIRONMENTAL QUALITY

ATTACHMENT E

The TCEQ is committed to accessibility.
To request a more accessible version of this report, please contact the TCEQ Help Desk at (512) 239-4357.



Compliance History Report

PUBLISHED Compliance History Report for CN601279185, RN102487782, Rating Year 2013 which includes Compliance History (CH) components from September 1, 2008, through August 31, 2013.

Customer, Respondent, or Owner/Operator: CN601279185, West Park Municipal Utility District **Classification:** SATISFACTORY **Rating:** 0.33

Regulated Entity: RN102487782, WEST PARK MUD WATER PLANT **Classification:** SATISFACTORY **Rating:** 0.33

Complexity Points: 5 **Repeat Violator:** NO

CH Group: 08 - Sewage Treatment Facilities

Location: 19310 KATY FWY HOUSTON, TX 77094-1008, HARRIS COUNTY

TCEQ Region: REGION 12 - HOUSTON

ID Number(s):
WASTEWATER PERMIT WQ0012346001 **WASTEWATER EPA ID** TX0086185

Compliance History Period: September 01, 2008 to August 31, 2013 **Rating Year:** 2013 **Rating Date:** 09/01/2013

Date Compliance History Report Prepared: February 05, 2014

Agency Decision Requiring Compliance History: Permit - Issuance, renewal, amendment, modification, denial, suspension, or revocation of a permit.

Component Period Selected: November 05, 2008 to February 04, 2014

TCEQ Staff Member to Contact for Additional Information Regarding This Compliance History.

Name: Rebecca Moore **Phone:** (512) 239-0058

Site and Owner/Operator History:

- 1) Has the site been in existence and/or operation for the full five year compliance period? YES
- 2) Has there been a (known) change in ownership/operator of the site during the compliance period? NO
- 3) If YES for #2, who is the current owner/operator? N/A
- 4) If YES for #2, who was/were the prior owner(s)/operator(s)? N/A
- 5) If YES, when did the change(s) in owner or operator occur? N/A

Components (Multimedia) for the Site Are Listed in Sections A - J

A. Final Orders, court judgments, and consent decrees:

N/A

B. Criminal convictions:

N/A

C. Chronic excessive emissions events:

N/A

D. The approval dates of investigations (CCEDS Inv. Track. No.):

Item 1	November 20, 2008	(730887)
Item 2	December 16, 2008	(754129)
Item 3	January 15, 2009	(730888)
Item 4	February 13, 2009	(754126)
Item 5	March 10, 2009	(754127)
Item 6	April 15, 2009	(754128)
Item 7	May 12, 2009	(771447)
Item 8	June 12, 2009	(771448)

Item 9	July 16, 2009	(814441)
Item 10	August 21, 2009	(814442)
Item 11	September 14, 2009	(814443)
Item 12	October 16, 2009	(814444)
Item 13	November 13, 2009	(814445)
Item 14	December 17, 2009	(814446)
Item 15	January 13, 2010	(814447)
Item 16	February 11, 2010	(814440)
Item 17	March 11, 2010	(834264)
Item 18	April 14, 2010	(834265)
Item 19	May 13, 2010	(834266)
Item 20	June 14, 2010	(847310)
Item 21	July 14, 2010	(861753)
Item 22	August 23, 2010	(868154)
Item 23	September 15, 2010	(875082)
Item 24	October 18, 2010	(882688)
Item 25	November 15, 2010	(889101)
Item 26	December 15, 2010	(897476)
Item 27	January 17, 2011	(903370)
Item 28	February 17, 2011	(910283)
Item 29	March 14, 2011	(917498)
Item 30	April 18, 2011	(928518)
Item 31	May 17, 2011	(939192)
Item 32	June 15, 2011	(946615)
Item 33	July 14, 2011	(953865)
Item 34	August 23, 2011	(960465)
Item 35	September 14, 2011	(966521)
Item 36	November 10, 2011	(978680)
Item 37	December 12, 2011	(985501)
Item 38	January 13, 2012	(991796)
Item 39	February 16, 2012	(999139)
Item 40	March 12, 2012	(1004663)
Item 41	April 13, 2012	(1011239)
Item 42	May 14, 2012	(1017597)
Item 43	June 13, 2012	(1025393)
Item 44	July 12, 2012	(1032734)
Item 45	August 16, 2012	(1039160)
Item 46	September 12, 2012	(1048114)
Item 47	October 15, 2012	(1066963)
Item 48	November 15, 2012	(1066964)
Item 49	December 12, 2012	(1066965)
Item 50	January 14, 2013	(1081530)
Item 51	February 12, 2013	(1081529)
Item 52	March 13, 2013	(1090552)
Item 53	May 13, 2013	(1107870)
Item 54	June 12, 2013	(1111500)
Item 55	July 15, 2013	(1118401)
Item 56	August 26, 2013	(1126193)
Item 57	September 12, 2013	(1130744)
Item 58	November 14, 2013	(1141894)

E. Written notices of violations (NOV) (CCEDS Inv. Track. No.):

A notice of violation represents a written allegation of a violation of a specific regulatory requirement from the commission to a regulated entity. A notice of violation is not a final enforcement action, nor proof that a violation has actually occurred.

- | | | | |
|---|--------------|--|--------------------------|
| 1 | Date: | 03/31/2013 (1096905) | CN601279185 |
| | Self Report? | YES | Classification: Moderate |
| | Citation: | 2D TWC Chapter 26, SubChapter A 26.121(a)
30 TAC Chapter 305, SubChapter F 305.125(1) | |
| | Description: | Failure to meet the limit for one or more permit parameter | |
| 2 | Date: | 09/30/2013 (1136508) | CN601279185 |

Published Compliance History Report for CN601279185, RN102487782, Rating Year 2013 which includes Compliance History (CH) components from November 05, 2008, through February 04, 2014.

Self Report? YES

Classification: Moderate

Citation: 2D TWC Chapter 26, SubChapter A 26.121(a)

30 TAC Chapter 305, SubChapter F 305.125(1)

Description: Failure to meet the limit for one or more permit parameter

F. Environmental audits:

N/A

G. Type of environmental management systems (EMSs):

N/A

H. Voluntary on-site compliance assessment dates:

N/A

I. Participation in a voluntary pollution reduction program:

N/A

J. Early compliance:

N/A

Sites Outside of Texas:

N/A