

2008 FEB 19 PM 3:25

CHIEF CLERKS OFFICE

February 15, 2008

Chief Clerk
Texas Commission on Environmental Quality
Office of the Chief Clerk
PO BOX 13087
Austin, TX 78711
512-239-3300


RECEIVED
FEB 19 2008
TCEQ MAIL CENTER
FEB

RE: SOAH Docket No. 582-07-2361; TCEQ Docket No. 2006-1661-PST-E

Dear Chief Clerk,

On July 27, 2006 we had Stage II testing and we used W. Two Plus, Inc. We have always completed the testing and procedures correctly and by the books. The testing company sent the request to TNRCC the inspector came on the same day and inspected all the paperwork required by law and he was satisfied. The only issue we had that we were not able to provide the Veeder Root printouts, because they would fade so we used to write the information onto our daily sheet and disregard the printout. The memory on the Veeder Root was erased due to a surge of electricity the night before and there was a power outage. I have contacted the electric company for a letter, Supervisor Terry Jones representing the City of Denton Municipal Electric. As soon as I receive that letter I will forward on to the commission. I am attaching the line test report which the company had directly sent to the TNRCC. After the testing was completed the store was foreclosed on and I was not able to provide the attached document. This company has been closed and the store is no longer in operation. W. Two Plus, Inc had informed me that the attached document was sent to the commission directly on July 27, 2006.

Thanks



Habib Arab
Discount Beer & Cigarettes
4644 Old Pond Dr.
Plano, TX 75024
972-743-7319

CC: Blas J. Coy Jr; TCEQ

Benjamin Thompson; TCEQ

Vapor Recovery Test Procedure Results Cover Sheet

(NOTICE: Submit Test Results to the appropriate TCEQ regional office, and local program with jurisdiction, within 10 working days of test completion.)

Tests of the Vapor Recovery System were conducted at the following location:

Facility Name: DISCOUNT BEER AND CIGARETTES Facility ID Number: 39062
 Facility Address: 3430 E UNIVERSITY DR
 Facility City: DENTON State: TX Zip Code: 76201
 Facility Phone: 940-383-4403
 Owner Name: CB EXPRESS (CONTACT NIRAJ-817-581-1144) Phone Number: 972-578-4810

Vapor Recovery System installed:

System	UST or AST	Type of System	Executive Order or Certification Number	Test Purpose ²
Stage I	UST	Two Point	N/A	N/A
Stage II	UST	ASSIST	G-70-154 AA	CA

1. Coaxial or Two-point for Stage I; Balance or Assist for Stage II.
2. Test Purposes are: CI=Initial Compliance, CA=Annual Compliance, CM=After Major Modification, or 5Y=Five Year.

The Following Tests were Conducted at the Facility:

Test Procedure Number	Test Procedure Name	Date Tested	Name of Person(s) Conducting Test	Pass or Fail
TXP-101	Vapor Space Manifold			
TXP-102	Pressure Decay	7/27/2006	DAVID SOULE	PASS
TXP-103	Dynamic Back-Pressure			
TXP-104	Flow rate Determination	7/27/2006	DAVID SOULE	PASS
TXP-106-1	A/L Ratio Roots Meter			
TXP-106-2	A/L Ratio VacuSmart	7/27/2006	DAVID SOULE	PASS
TP 201.5	CARB A/L Ratio			
TP 201.6C	Liquid Removal Test			
TXP-107	Healy Booted Nozzle			
LINE AND LEAK DETECTORS		7/27/2006	DAVID SOULE	PASS

The tester arrived on-site at 1:30 PM and departed at 7:00 PM.

There are a total of 4 pages containing test results attached to this test results cover sheet.

I certify that the above tests, the results of which are attached to this cover sheet, were conducted in accordance with the test procedures as outlined in the Vapor Recovery Test Procedure Handbook, and that the results submitted here are true and correct to the best of my knowledge.

Signature of Test Contractor Responsible Party: _____

Date: 8/2/2006

Test Company Name: _____

W. Two Plus, Inc.

Phone Number: _____

817/572-9424