

Texas Commission on Environmental Quality

CHECKLIST WORKSHEET

MSW USED OIL HANDLER GENERATORS

Reg Ent Name : _____

Date : _____

Add ID _____

Investigator Name _____

Item No.	Description	Answer	Citations	Notes
0	Proper management of mixtures of UO & hazardous waste.		279.21(a) 279.21(b)	
2	SPCC Plan (SPCC (Spill Prevention, Control and Countermeasures) Plan applies to underground tank systems of more than 42,000 gallons and above ground systems of more than 1,320 gallons, or where the largest above ground tank exceeds 660 gallons.)		279.22	
3	USTs in compliance with 40 CFR Part 280 (This applies to underground storage tank (UST) systems with 10% or more of the system volume below ground level (40CFR 280.12).)		279.22	
4	Approved storage units.		279.22(a)	
5	Storage units in good condition, not rusted or leaking.		279.22(b)	
6	Containers & fill pipes have "Used Oil" labels.		279.22(c)	
7	Proper cleanup & notification of used oil spills.		324.15 279.22(d)	
8	On-site burning in space heaters.		279.23(c) 279.23(b) 279.23(a)	
9	Using registered UO handlers for off-site shipments:		279.24	
10	Registered UO handlers TCEQ Registration No:			
11	Registered UO handlers EPA ID No.:			

CHECKLIST WORKSHEET

MSW USED OIL HANDLER GENERATORS