

Texas Commission on Environmental Quality

CHECKLIST WORKSHEET

PST ABANDONMENT, REMOVAL, & CHANGE-IN-SERVICE INVESTIGATION REPORT

Reg Ent Name : _____

Date : _____

Add ID _____

Investigator Name _____

Item No.	Description	Answer	Citations	Notes
	NOTIFICATION			
2	Was a construction notification form filed with the TCEQ 30 days prior to the construction activity?		334.6	
2.a	Was a 30-day waiver requested?		334.6(b)(4)	
2.c	Was 24 to 72 hour notice of start of construction activities provided to the TCEQ?		334.6(b)(2)(C)	
3	Were all on-site tanks registered?		334.7	
	LIQUID WASTE REMOVAL & DISPOSAL/REUSE			
10	Liquid waste was not present in the tank pit (excavation).			
	TANK STORAGE, TRANSPORTATION, & DISPOSAL			
32	Was the area clearly identified with barriers and signs?			
33	Was longer on-site storage approved?			
34	Was the UST removed from the site within 24 hours of removal from the ground?			
35	Was the UST legibly and permanently labeled within 24 hours?		334.55(b)(4)(D)	
35.a	With letters at least 2 inches in height?		334.55(b)(4)(D)	
35.b	With the name of the former contents?		334.55(b)(4)(D)	
35.c	With a flammability warning (if applicable)?		334.55(b)(4)(D)	
35.d	With the words "unsuitable for human or animal use"?		334.55(b)(4)(D)	
36	Were all openings in the UST plugged except for one 1/8" hole?		334.55(b)(5)(C)(iii)	
	ABANDONMENT IN PLACE			
39	Was a closure plan approved (abandonment in-place)?			
40	Was the UST cleaned and purged of vapors (abandonment in place)?		334.55(a)(4)	
41	Were all void spaced eliminated(abandonment in place)?		334.55(c)(2)(B)	
	CHANGE IN SERVICE			
43	Was the UST emptied and purged of vapors prior to reuse (change in service)?		334.55(a)(4)	
	HYDROGEOLOGICAL FEATURES			
45	Was the excavation free of water?			
46	Tank pit not located near surface water?			

CHECKLIST WORKSHEET

PST ABANDONMENT, REMOVAL, & CHANGE-IN-SERVICE INVESTIGATION REPORT