

Texas Commission on Environmental Quality

CHECKLIST WORKSHEET

PST FULL CEI #7G MONTHLY TANK GAUGING

Reg Ent Name : _____

Date : _____

Add ID _____

Investigator Name _____

Item No.	Description	Answer	Citations	Notes
1	Tank is used for an emergency generator? If not, this method is not acceptable.			
2	Appropriate calibration chart is utilized and available for review?			
3	Records show liquid level measurements are taken once per month at the beginning and end of a 36 hour period (with no deliveries or removals)?		334.50(d)(3)(C)(iii)	
4	The difference between the beginning and ending measurements is recorded in gallons?		334.50(d)(3)(C)(i)(III)	
5	Level measurements are based on the average of two consecutive stick readings at both the beginning and end of the test period?		334.50(d)(3)(C)(i)(I)	
6	Monthly deviation is less than the standard for its corresponding tank size? (550 gallon UST has a 5 gallon monthly standard, 551-1000 gallon UST has a 7 gallon monthly standard, 1001-2000 gallon UST has a 13 gallon monthly standard, >2000 gallon UST has a monthly standard of 1% of total tank capacity)		334.50(d)(3)(C)(iv)	
7	If any monthly deviations exceeded the standard, was the Commission notified?		334.50(d)(3)(C)(v)	
8	Measuring equipment capable of measuring the level of stored substance over the full range of the tank's internal height to the nearest 1/8"?		334.50(d)(3)(C)(ii)	
9	Release detection records available for past 5 years?		334.50(e)(2)(C)	

CHECKLIST WORKSHEET

PST FULL CEI #7G MONTHLY TANK GAUGING