

(1) The following permit table lists the requirements for Stationary Compression Ignition Internal Combustion Engines affected by 40 CFR Part 60, Subpart III.

Consecutive Months at a Site	Constructed, Modified or Reconstructed [Model Year]	Displacement per Cylinder	Horsepower	Emission Standards	Index No.	Regulatory Requirements [Exemption]	Monitoring and Testing	Recordkeeping and Reporting
Less than 12 months	N/A	N/A	N/A	N/A	518-01-001	N/A	N/A	N/A
More than 12 months	Commence construction before July 12, 2005 and manufactured before April 2, 2006	≤ 10 liters	< 11	§60.4204(a) Table 1 1	518-01-002	None [§60.4200(a)(2)(i)]	None	None
	Modified or reconstructed before July 12, 2005				518-01-003	None [§60.4200(a)(3)]	None	None
	[Pre-2007]				518-01-004	§60.4206 §60.4207(a) – (c) [G]§60.4208 §60.4211(a),(b)(1),(e) §60.4217 §60.4218 Table 8 §60.1 - §60.6 Table 8 §60.9 - §60.12 Table 8 §60.14 - §60.19	[G]§60.4209 §60.4211(b)(5) [G]§60.4212	§60.4211(b)(2)-(4) §60.4214(b),(c)
			11 ≤ HP < 25	§60.4204(a) Table 1 2	518-01-005	§60.4206 §60.4207(a) – (c) [G]§60.4208 §60.4211(a),(b)(1),(e) §60.4217 §60.4218 Table 8 §60.1 - §60.6 Table 8 §60.9 - §60.12 Table 8 §60.14 - §60.19	[G]§60.4209 §60.4211(b)(5) [G]§60.4212	§60.4211(b)(2)-(4) §60.4214(b),(c)
			25 ≤ HP < 50	§60.4204(a) Table 1 3	518-01-006	§60.4206 §60.4207(a) – (c) [G]§60.4208 §60.4211(a),(b)(1),(e) §60.4217 §60.4218 Table 8 §60.1 - §60.6 Table 8 §60.9 - §60.12 Table 8 §60.14 - §60.19	[G]§60.4209 §60.4211(b)(5) [G]§60.4212	§60.4211(b)(2)-(4) §60.4214(b),(c)

Consecutive Months at a Site	Constructed, Modified or Reconstructed [Model Year]	Displacement per Cylinder	Horsepower	Emission Standards	Index No.	Regulatory Requirements [Exemption]	Monitoring and Testing	Recordkeeping and Reporting
More than 12 months (continued)	[Pre-2007] (continued)	≤ 10 liters (continued)	50 ≤ HP < 75	§60.4204(a) Table 1 4	518-01-007	§60.4206 §60.4207(a) – (c) [G]§60.4208 §60.4211(a),(b)(1),(e) §60.4217 §60.4218 Table 8 §60.1 - §60.6 Table 8 §60.9 - §60.12 Table 8 §60.14 - §60.19	[G]§60.4209 §60.4211(b)(5) [G]§60.4212	§60.4211(b)(2)-(4) §60.4214(b),(c)
			75 ≤ HP < 100	§60.4204(a) Table 1 5	518-01-008	§60.4206 §60.4207(a) – (c) [G]§60.4208 §60.4211(a),(b)(1),(e) §60.4217 §60.4218 Table 8 §60.1 - §60.6 Table 8 §60.9 - §60.12 Table 8 §60.14 - §60.19	[G]§60.4209 §60.4211(b)(5) [G]§60.4212	§60.4211(b)(2)-(4) §60.4214(b),(c)
			100 ≤ HP < 175	§60.4204(a) Table 1 6	518-01-009	§60.4206 §60.4207(a) – (c) [G]§60.4208 §60.4211(a),(b)(1),(e) §60.4217 §60.4218 Table 8 §60.1 - §60.6 Table 8 §60.9 - §60.12 Table 8 §60.14 - §60.19	[G]§60.4209 §60.4211(b)(5) [G]§60.4212	§60.4211(b)(2)-(4) §60.4214(b),(c)
			175 ≤ HP < 300	§60.4204(a) Table 1 7	518-01-010	§60.4206 §60.4207(a) – (c) [G]§60.4208 §60.4211(a),(b)(1),(e) §60.4217 §60.4218 Table 8 §60.1 - §60.6 Table 8 §60.9 - §60.12 Table 8 §60.14 - §60.19	[G]§60.4209 §60.4211(b)(5) [G]§60.4212	§60.4211(b)(2)-(4) §60.4214(b),(c)
	[2007 and later]	< 30 liters	N/A	§60.4204(b)	518-01-011	§60.4206 §60.4207(a) – (c) [G]§60.4208 §60.4211(a),(c),(e) §60.4217 §60.4218 Table 8 §60.1 - §60.6 Table 8 §60.9 - §60.12 Table 8 §60.14 - §60.19	[G]§60.4209 §60.4211(b)(5) [G]§60.4212	§60.4211(b)(2)-(4) §60.4214(b),(c)

(2) The following permit table lists the requirements for Stationary Spark Ignition Internal Combustion Engines affected by 40 CFR Part 60, Subpart JJJJ.

Consecutive Months at a Site	Constructed, Modified, or Reconstructed Date	Date of Manufacture	Engine Type and Fuel	Engine Power	Index No.	Regulatory Requirements [Exemption]	Monitoring and Testing	Recordkeeping and Reporting
Less than 12 months	N/A	N/A	N/A	N/A	518-02-001	N/A	N/A	N/A
More than 12 months	Constructed, modified, or reconstructed before June 13, 2006	N/A	N/A	N/A	518-02-002	None [§60.4230(a)(4)-(5)]	None	None
					Constructed or reconstructed after June 12, 2006	On or after July 1, 2007	Any	HP ≤ 25
	On or after January 1, 2008	Any	25 < HP < 100	518-02-004	§60.4233(d),(f)(4),(f)(4)(ii) §60.4234 §60.4236(a),(e) §60.4246 §60.4248	§60.4243(a),(b),(c),(e),(f),(g) §60.4244	§60.4245(a)	
			HP ≤ 25	518-02-005	§60.4233(f)(1) §60.4234 §60.4236(a),(d),(e) §60.4246 §60.4248	§60.4243(a),(c),(e),(f),(g)	§60.4245(a)	
	On or after July 1, 2008	Any	25 < HP < 100	518-02-006	§60.4233(d),(f)(4),(f)(4)(ii) §60.4234 §60.4236(a),(e) §60.4246 §60.4248	§60.4243(a),(b),(c),(e),(f),(g)	§60.4245(a)	
			HP ≤ 25	518-02-007	§60.4230(a)(4)(iii) §60.4233(a),(f)(1) §60.4234 §60.4236(a),(d),(e) §60.4246 §60.4248	§60.4243(a),(c),(e),(f),(g)	§60.4245(a)	
	25 < HP < 100	518-02-008	§60.4230(a)(4)(iii) §60.4233(d),(f)(4),(f)(4)(ii) §60.4234 §60.4236(a),(e) §60.4246 §60.4248	§60.4243(a),(b),(c),(e),(f),(g)	§60.4245(a)			

Consecutive Months at a Site	Constructed, Modified, or Reconstructed Date	Date of Manufacture	Engine Type and Fuel	Engine Power	Index No.	Regulatory Requirements [Exemption]	Monitoring and Testing	Recordkeeping and Reporting
		On or after January 1, 2009		HP ≤ 25	518-02-009	§60.4233(f)(1) §60.4234 §60.4236(a),(d),(e) §60.4246 §60.4248	§60.4243(a),(c),(e),(f),(g)	§60.4245(a)
More than 12 months (continued)	Constructed or reconstructed after June 12, 2006 (continued)	On or after January 1, 2009 (continued)	Any	25 < HP < 100	518-02-010	§60.4233(d),(f)(4),(f)(4)(ii) §60.4234 §60.4236(a),(e) §60.4246 §60.4248	§60.4243(a),(b),(c),(e),(f),(g)	§60.4245(a)
		Modification after June 12, 2006		Any	HP ≤ 25	518-02-011	§60.4231(a) §60.4233(a),(f)(1) §60.4234	§60.4243(a)
		Rich Burn LPG	HP > 25	518-02-012	§60.4233(c),(f)(3) §60.4234 §60.4235 §60.4243(a),(e),(f),(g)	§60.4243(a) §60.4244	§60.4245(a),(c),(d)	
		Lean Burn LPG			518-02-013	§60.4233(d),(e),(f)(4) §60.4234 §60.4235 §60.4243(b),(c),(e),(f),(g)	§60.4243(a) §60.4244	§60.4245(a),(c),(d)
		SI Engine (Any fuel type)	100 ≤ HP < 500	518-02-014	§60.4233(b),(f)(2) §60.4234 §60.4235 §60.4243	§60.4243(a),(b),(c),(e),(f),(g) §60.4244	§60.4245(a),(d)	