

# Texas Natural Resource Conservation Commission

## INTEROFFICE MEMORANDUM

To: Permit Reviewers Date: February 20, 2002  
Thru <sup>RD</sup> Kerry Drake, Executive Assistant, Air Permits Division  
From: <sup>DB</sup> Harry Pruett, Manager, Chemical and Coatings Section  
Subject: Update to Draft Technical Guidance Package for Bulk Gasoline Terminals -  
Publication RG-123 dated February 2001\*  
Enclosed Flares/Vapor Combustors

Gasoline terminal loading emissions are controlled at many facilities by utilizing an enclosed flare/vapor combustor. We now regard BACT for VOC emissions from the stack of an enclosed flare/vapor combustor to be no greater than 10 mg/liter of gasoline loaded. This will usually be equivalent to a somewhat higher destruction efficiency than the previous BACT guideline of 98 percent.

\* The December 1998 revision of the subject document underwent minor format and text changes and was redated in February 2001, but the technical content was not changed.

cc: John Steib, Director, Air Permits Division