

# Statement of Basis of the Federal Operating Permit

City of Bryan

Site/Area Name: Roland C Dansby Power Plant

Physical location: 8181 Mumford Road

Nearest City: Bryan

County: Brazos

Permit Number: O82

Project Type: Renewal

Standard Industrial Classification (SIC) Code: 4911

SIC Name: Electric Services

This Statement of Basis sets forth the legal and factual basis for the draft permit conditions in accordance with 30 TAC §122.201(a)(4). Per 30 TAC §§ 122.241 and 243, the permit holder has submitted an application under § 122.134 for permit renewal. This document may include the following information:

- A description of the facility/area process description;
- A basis for applying permit shields;
- A list of the federal regulatory applicability determinations;
- A table listing the determination of applicable requirements;
- A list of the New Source Review Requirements;
- The rationale for periodic monitoring methods selected;
- The rationale for compliance assurance methods selected;
- A compliance status; and
- A list of available unit attribute forms.

Prepared on: August 13, 2015

## Operating Permit Basis of Determination

### Permit Area Process Description

The Roland C. Dansby power plant consists of one 1,095 MMBtu/hr front fired boiler that produces steam to drive a 105 MW steam turbine electric generator and one simple cycle combustion turbine generator (Unit 2). The electricity that is generated is fed to the utility grid.

The boiler (unit 1) utilizes natural gas as a primary fuel, but also has the capability to fire fuel oil during periods of natural gas shortages or when it is more economically feasible for short periods of time during cold weather. It is also possible for the unit to fire fuel oil and natural gas simultaneously. The unit has six burners of which any combination of natural gas and fuel oil can be fired. Fuel oil is stored in three above-ground storage tanks. Two of the tanks have capacities of 1,500,000 gallons. The third tank has a capacity of 127,000 gallons.

The simple cycle combustion turbine (unit 2) is a General Electric LM 6000 Model PC fueled with natural gas. The combustion turbine utilizes water injection to control NO<sub>x</sub> to 25ppm. A high temperature SCR provides additional control for NO<sub>x</sub> and CO. Aqueous ammonia is used as the catalyst reagent. Storage tanks are utilized for the storage of the aqueous ammonia and turbine lube oil. The combustion turbine is installed with inlet air cooling coils which utilize chilled water provided by a chiller.

### FOPs at Site

The “application area” consists of the emission units and that portion of the site included in the application and this permit. Multiple FOPs may be issued to a site in accordance with 30 TAC § 122.201(e). When there is only one area for the site, then the application information and permit will include all units at the site. Additional FOPs that exist at the site, if any, are listed below.

Additional FOPs: None

### Major Source Pollutants

The table below specifies the pollutants for which the site is a major source:

Major Pollutants	SO <sub>2</sub> , NO <sub>x</sub> , CO
------------------	----------------------------------------

### Reading State of Texas’s Federal Operating Permit

The Title V Federal Operating Permit (FOP) lists all state and federal air emission regulations and New Source Review (NSR) authorizations (collectively known as “applicable requirements”) that apply at a particular site or permit area (in the event a site has multiple FOPs). **The FOP does not authorize new emissions or new construction activities.** The FOP begins with an introductory page which is common to all Title V permits. This page gives the details of the company, states the authority of the issuing agency, requires the company to operate in accordance with this permit and 30 Texas Administrative Code (TAC) Chapter 122, requires adherence with NSR requirements of 30 TAC Chapter 116, and finally indicates the permit number and the issuance date.

This is followed by the table of contents, which is generally composed of the following elements. Not all permits will have all of the elements.

- General Terms and Conditions
- Special Terms and Conditions
  - Emissions Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

- Additional Monitoring Requirements
- New Source Review Authorization Requirements
- Compliance Requirements
- Protection of Stratosphere Ozone
- Permit Location
- Permit Shield (30 TAC § 122.148)
- Attachments
  - Applicable Requirements Summary
    - Unit Summary
    - Applicable Requirements Summary
  - Additional Monitoring Requirements
  - Permit Shield
  - New Source Review Authorization References
  - Compliance Plan
  - Alternative Requirements
- Appendix A
  - Acronym list

## General Terms and Conditions

The General Terms and Conditions are the same and appear in all permits. The first paragraph lists the specific citations for 30 TAC Chapter 122 requirements that apply to all Title V permit holders. The second paragraph describes the requirements for record retention. The third paragraph provides details for voiding the permit, if applicable. The fourth paragraph states that the permit holder shall comply with the requirements of 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit. The fifth paragraph provides details on submission of reports required by the permit.

## Special Terms and Conditions

Emissions Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting. The TCEQ has designated certain applicable requirements as site-wide requirements. A site-wide requirement is a requirement that applies uniformly to all the units or activities at the site. Units with only site-wide requirements are addressed on Form OP-REQ1 and are not required to be listed separately on a OP-UA Form or Form OP-SUM. Form OP-SUM must list all units addressed in the application and provide identifying information, applicable OP-UA Forms, and preconstruction authorizations. The various OP-UA Forms provide the characteristics of each unit from which applicable requirements are established. Some exceptions exist as a few units may have both site-wide requirements and unit specific requirements.

Other conditions. The other entries under special terms and conditions are in general terms referring to compliance with the more detailed data listed in the attachments.

## Attachments

Applicable Requirements Summary. The first attachment, the Applicable Requirements Summary, has two tables, addressing unit specific requirements. The first table, the Unit Summary, includes a list of units with applicable requirements, the unit type, the applicable regulation, and the requirement driver. The intent of the requirement driver is to inform the reader that a given unit may have several different operating scenarios and the differences between those operating scenarios.

The applicable requirements summary table provides the detailed citations of the rules that apply to the various units. For each unit and operating scenario, there is an added modifier called the “index number,”

detailed citations specifying monitoring and testing requirements, recordkeeping requirements, and reporting requirements. The data for this table are based on data supplied by the applicant on the OP-SUM and various OP-UA forms.

**Additional Monitoring Requirement.** The next attachment includes additional monitoring the applicant must perform to ensure compliance with the applicable standard. Compliance assurance monitoring (CAM) is often required to provide a reasonable assurance of compliance with applicable emission limitations/standards for large emission units that use control devices to achieve compliance with applicant requirements. When necessary, periodic monitoring (PM) requirements are specified for certain parameters (i.e. feed rates, flow rates, temperature, fuel type and consumption, etc.) to determine if a term and condition or emission unit is operating within specified limits to control emissions. These additional monitoring approaches may be required for two reasons. First, the applicable rules do not adequately specify monitoring requirements (exception- Maximum Achievable Control Technology Standards (MACTs) generally have sufficient monitoring), and second, monitoring may be required to fill gaps in the monitoring requirements of certain applicable requirements. In situations where the NSR permit is the applicable requirement requiring extra monitoring for a specific emission unit, the preferred solution is to have the monitoring requirements in the NSR permit updated so that all NSR requirements are consolidated in the NSR permit.

**Permit Shield.** A permit may or may not have a permit shield, depending on whether an applicant has applied for, and justified the granting of, a permit shield. A permit shield is a special condition included in the permit document stating that compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirement(s) or specified applicable state-only requirement(s).

**New Source Review Authorization References.** All activities which are related to emissions in the state of Texas must have a NSR authorization prior to beginning construction. This section lists all units in the permit and the NSR authorization that allowed the unit to be constructed or modified. Units that do not have unit specific applicable requirements other than the NSR authorization do not need to be listed in this attachment. While NSR permits are not physically a part of the Title V permit, they are legally incorporated into the Title V permit by reference. Those NSR permits whose emissions exceed certain PSD/NA thresholds must also undergo a Federal review of federally regulated pollutants in addition to review for state regulated pollutants.

**Compliance Plan.** A permit may have a compliance schedule attachment for listing corrective actions plans for any emission unit that is out of compliance with an applicable requirement.

**Alternative Requirements.** This attachment will list any alternative monitoring plans or alternative means of compliance for applicable requirements that have been approved by the EPA Administrator and/or the TCEQ Executive Director.

Appendix A

Acronym list. This attachment lists the common acronyms used when discussing the FOPs.

### **Stationary vents subject to 30 TAC Chapter 111, Subchapter A, § 111.111(a)(1)(B) addressed in the Special Terms and Conditions**

The site contains stationary vents with a flowrate less than 100,000 actual cubic feet per minute (acfm) and constructed after January 31, 1972 which are limited, over a six-minute average, to 20% opacity as required by 30 TAC § 111.111(a)(1)(B). As a site may have a large number of stationary vents that fall into this category, they are not required to be listed individually in the permit's Applicable Requirement Summary. This is consistent with EPA's White Paper for Streamlined Development of Part 70 Permit Applications, July 10, 1995, that states that requirements that apply identically to emission units at a site can be treated on a generic basis such as source-wide opacity limits.

Periodic monitoring is specified in Special Term and Condition 3.A. for stationary vents subject to 30 TAC § 111.111(a)(1)(B) to verify compliance with the 20% opacity limit. These vents are not expected to produce visible emissions during normal operation. The TCEQ evaluated the probability of these sources violating the opacity standards and determined that there is a very low potential that an opacity standard would be exceeded. It was determined that continuous monitoring for these sources is not warranted as there would be very limited environmental benefit in continuously monitoring sources that have a low potential to produce visible emissions. Therefore, the TCEQ set the visible observation monitoring frequency for these sources to once per calendar quarter.

The TCEQ has exempted vents that are not capable of producing visible emissions from periodic monitoring requirements. These vents include sources of colorless VOCs, non-fuming liquids, and other materials that cannot produce emissions that obstruct the transmission of light. Passive ventilation vents, such as plumbing vents, are also included in this category. Since this category of vents are not capable of producing opacity due to the physical or chemical characteristics of the emission source, periodic monitoring is not required as it would not yield any additional data to assure compliance with the 20% opacity standard of 30 TAC § 111.111(a)(1)(B).

In the event that visible emissions are detected, either through the quarterly observation or other credible evidence, such as observations from company personnel, the permit holder shall either report a deviation or perform a Test Method 9 observation to determine the opacity consistent with the 6-minute averaging time specified in 30 TAC § 111.111(a)(1)(B). An additional provision is included to monitor combustion sources more frequently than quarterly if alternate fuels are burned for periods greater than 24 consecutive hours. This will address possible emissions that may arise when switching fuel types.

**Stationary Vents subject to 30 TAC Chapter 111 not addressed in the Special Terms and Conditions**

All other stationary vents subject to 30 TAC Chapter 111 not covered in the Special Terms and Conditions are listed in the permit’s Applicable Requirement Summary. The basis for the applicability determinations for these vents are listed in the Determination of Applicable Requirements table.

**Federal Regulatory Applicability Determinations**

The following chart summarizes the applicability of the principal air pollution regulatory programs to the permit area:

<b>Regulatory Program</b>	<b>Applicability (Yes/No)</b>
Prevention of Significant Deterioration (PSD)	No
Nonattainment New Source Review (NNSR)	No
Minor NSR	Yes
40 CFR Part 60 - New Source Performance Standards	Yes
40 CFR Part 61 - National Emission Standards for Hazardous Air Pollutants (NESHAPs)	No
40 CFR Part 63 - NESHAPs for Source Categories	Yes
Title IV (Acid Rain) of the Clean Air Act (CAA)	Yes

Title V (Federal Operating Permits) of the CAA	Yes
Title VI (Stratospheric Ozone Protection) of the CAA	Yes
CAIR (Clean Air Interstate Rule)	Yes

## **Basis for Applying Permit Shields**

An operating permit applicant has the opportunity to specifically request a permit shield to document that specific applicable requirements do not apply to emission units in the permit. A permit shield is a special condition stating that compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements. A permit shield has been requested in the application for specific emission units. For the permit shield requests that have been approved, the basis of determination for regulations that the owner/operator need not comply with are located in the "Permit Shield" attachment of the permit.

### **Acid Rain Permit**

The permitted area is subject to Federal Clean Air Act Title IV Acid Rain rules for Phase II units, as codified in 40 CFR Parts 72 through 78, because it meets the definition of "affected source." Applicability of affected sources are defined in 40 CFR § 72.6 and include those sources that burn fossil fuel, and generates electricity for sale. Under 40 CFR Part 72, incorporated by reference into 30 TAC Chapter 122, all acid rain permits must contain specific terms and conditions, including monitoring, reporting, recordkeeping and excess emission requirements, established by the U.S. EPA. The Title IV permitting procedures are described within 30 TAC Chapter 122, Subchapter E. The applicable requirements of the Acid Rain Permit are contained in the Special Terms and Conditions of the FOP. The Acid Rain permit is effective as of the date of the issuance of the FOP and has a term ending in concurrence with the FOP.

### **CAIR Permit**

The Clean Air Interstate Rule (CAIR) was established to mitigate the interstate transport of NO<sub>x</sub> and SO<sub>2</sub> which contribute to the formation of fine particles (PM 2.5) and ground-level ozone. The EPA has promulgated a model cap and trade program in 40 CFR Part 96 to implement CAIR. This rule has been adopted by reference into 30 TAC Chapter 122, Subchapter E, Division 2: Clean Air Interstate Rule.

The permitted area is subject to CAIR as it contains units that meet the definition of a NO<sub>x</sub> budget unit in 40 CFR § 96.4(a)(1)-(2) and a CAIR SO<sub>2</sub> unit in 40 CFR § 96.204(a)(1)-(2). The applicable requirements of the CAIR permit are contained in the Special Terms and Conditions of the FOP. The CAIR permit is effective as of the date of the issuance of this revision and has a term ending in concurrence with the FOP.

### **Insignificant Activities**

In general, units not meeting the criteria for inclusion on either Form OP-SUM or Form OP-REQ1 are not required to be addressed in the operating permit application. Examples of these types of units include, but are not limited to, the following:

1. Office activities such as photocopying, blueprint copying, and photographic processes.
2. Sanitary sewage collection and treatment facilities other than those used to incinerate wastewater treatment plant sludge. Stacks or vents for sanitary sewer plumbing traps are also included.
3. Food preparation facilities including, but not limited to, restaurants and cafeterias used for preparing food or beverages primarily for consumption on the premises.

4. Outdoor barbecue pits, campfires, and fireplaces.
5. Laundry dryers, extractors, and tumblers processing bedding, clothing, or other fabric items generated primarily at the premises. This does not include emissions from dry cleaning systems using perchloroethylene or petroleum solvents.
6. Facilities storing only dry, sweet natural gas, including natural gas pressure regulator vents.
7. Any air separation or other industrial gas production, storage, or packaging facility. Industrial gases, for purposes of this list, include only oxygen, nitrogen, helium, neon, argon, krypton, and xenon.
8. Storage and handling of sealed portable containers, cylinders, or sealed drums.
9. Vehicle exhaust from maintenance or repair shops.
10. Storage and use of non-VOC products or equipment for maintaining motor vehicles operated at the site (including but not limited to, antifreeze and fuel additives).
11. Air contaminant detectors and recorders, combustion controllers and shut-off devices, product analyzers, laboratory analyzers, continuous emissions monitors, other analyzers and monitors, and emissions associated with sampling activities. Exception to this category includes sampling activities that are deemed fugitive emissions and under a regulatory leak detection and repair program.
12. Bench scale laboratory equipment and laboratory equipment used exclusively for chemical and physical analysis, including but not limited to, assorted vacuum producing devices and laboratory fume hoods.
13. Steam vents, steam leaks, and steam safety relief valves, provided the steam (or boiler feedwater) has not contacted other materials or fluids containing regulated air pollutants other than boiler water treatment chemicals.
14. Storage of water that has not contacted other materials or fluids containing regulated air pollutants other than boiler water treatment chemicals.
15. Well cellars.
16. Fire or emergency response equipment and training, including but not limited to, use of fire control equipment including equipment testing and training, and open burning of materials or fuels associated with firefighting training.
17. Crucible or pot furnaces with a brim full capacity of less than 450 cubic inches of any molten metal.
18. Equipment used exclusively for the melting or application of wax.
19. All closed tumblers used for the cleaning or deburring of metal products without abrasive blasting, and all open tumblers with a batch capacity of 1,000 lbs. or less.
20. Shell core and shell mold manufacturing machines.
21. Sand or investment molds with a capacity of 100 lbs. or less used for the casting of metals;
22. Equipment used for inspection of metal products.
23. Equipment used exclusively for rolling, forging, pressing, drawing, spinning, or extruding either hot or cold metals by some mechanical means.
24. Instrument systems utilizing air, natural gas, nitrogen, oxygen, carbon dioxide, helium, neon, argon, krypton, and xenon.
25. Battery recharging areas.
26. Brazing, soldering, or welding equipment.

## **Determination of Applicable Requirements**

The tables below include the applicability determinations for the emission units, the index number(s) where applicable, and all relevant unit attribute information used to form the basis of the applicability determination. The unit attribute information is a description of the physical properties of an emission unit which is used to determine the requirements to which the permit holder must comply. For more information about the descriptions of the unit attributes specific Unit Attribute Forms may be viewed at [www.tceq.texas.gov/permitting/air/nav/air\\_all\\_ua\\_forms.html](http://www.tceq.texas.gov/permitting/air/nav/air_all_ua_forms.html).

A list of unit attribute forms is included at the end of this document. Some examples of unit attributes include construction date; product stored in a tank; boiler fuel type; etc.. Generally, multiple attributes are needed to determine the requirements for a given emission unit and index number. The table below lists these attributes

in the column entitled “Basis of Determination.” Attributes that demonstrate that an applicable requirement applies will be the factual basis for the specific citations in an applicable requirement that apply to a unit for that index number. The TCEQ Air Permits Division has developed flowcharts for determining applicability of state and federal regulations based on the unit attribute information in a Decision Support System (DSS). These flowcharts can be accessed via the internet at [www.tceq.texas.gov/permitting/air/nav/air\\_supportsys.html](http://www.tceq.texas.gov/permitting/air/nav/air_supportsys.html). The Air Permits Division staff may also be contacted for assistance at (512) 239-1250.

The attributes for each unit and corresponding index number provide the basis for determining the specific legal citations in an applicable requirement that apply, including emission limitations or standards, monitoring, recordkeeping, and reporting. The rules were found to apply or not apply by using the unit attributes as answers to decision questions found in the flowcharts of the DSS. Some additional attributes indicate which legal citations of a rule apply. The legal citations that apply to each emission unit may be found in the Applicable Requirements Summary table of the draft permit. There may be some entries or rows of units and rules not found in the permit, or if the permit contains a permit shield, repeated in the permit shield area. These are sets of attributes that describe negative applicability, or; in other words, the reason why a potentially applicable requirement does not apply.

If applicability determinations have been made which differ from the available flowcharts, an explanation of the decisions involved in the applicability determination is specified in the column “Changes and Exceptions to RRT.” If there were no exceptions to the DSS, then this column has been removed.

The draft permit includes all emission limitations or standards, monitoring, recordkeeping and reporting required by each applicable requirement. If an applicable requirement does not require monitoring, recordkeeping, or reporting, the word “None” will appear in the Applicable Requirements Summary table. If additional periodic monitoring is required for an applicable requirement, it will be explained in detail in the portion of this document entitled “Rationale for Compliance Assurance Monitoring (CAM)/ Periodic Monitoring Methods Selected.”

When attributes demonstrate that a unit is not subject to an applicable requirement, the applicant may request a permit shield for those items. The portion of this document entitled “Basis for Applying Permit Shields” specifies which units, if any, have a permit shield.

#### Operational Flexibility

When an emission unit has multiple operating scenarios, it will have a different index number associated with each operating condition. This means that units are permitted to operate under multiple operating conditions. The applicable requirements for each operating condition are determined by a unique set of unit attributes. For example, a tank may store two different products at different points in time. The tank may, therefore, need to comply with two distinct sets of requirements, depending on the product that is stored. Both sets of requirements are included in the permit, so that the permit holder may store either product in the tank.

## Determination of Applicable Requirements

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
COMGEN	30 TAC Chapter 117, East Texas Combustion	R73300	Unit Type = The engine is a diesel engine.	
COMGEN	40 CFR Part 60, Subpart IIII	60IIII	<p>Applicability Date = Stationary CI ICE commenced construction, reconstruction, or modification after July 11, 2005.</p> <p>Diesel = Diesel fuel is used.</p> <p>Kilowatts = Power rating is greater than or equal to 37 KW and less than 75 KW.</p> <p>Exemptions = The CI ICE is not exempt due to national security, testing at an engine test cell/stand or as a temporary replacement.</p> <p>Displacement = Displacement is less than 10 liters per cylinder.</p> <p>Service = CI ICE is an emergency engine.</p> <p>Standards = The emergency CI ICE meets the standards applicable to non-emergency engines.</p> <p>Commencing = CI ICE that is commencing new construction.</p> <p>Compliance Option = The CI ICE and control device is installed, configured, operated, and maintained according to the manufacturer's emission-related written instructions.</p> <p>Manufacture Date = Date of manufacture is after 04/01/2006.</p> <p>Model Year = CI ICE was manufactured in model year 2011.</p>	
COMGEN	40 CFR Part 63, Subpart ZZZZ	63ZZZZ	<p>HAP Source = Any stationary source of hazardous air pollutants that is not a major source as defined in 40 CFR § 63.2.</p> <p>Brake HP = Stationary RICE with a brake hp less than 100 hp.</p> <p>Construction/Reconstruction Date = Commenced construction or reconstruction on or after June 12, 2006.</p>	
DIESELGEN	30 TAC Chapter 117, East Texas Combustion	R73300	Unit Type = The engine is a diesel engine.	
DIESELGEN	40 CFR Part 60, Subpart IIII	60IIII	<p>Applicability Date = Stationary CI ICE commenced construction, reconstruction, or modification after July 11, 2005.</p> <p>Diesel = Diesel fuel is used.</p> <p>Kilowatts = Power rating is greater than or equal to 130 KW and less than or equal to 2237 KW.</p> <p>Exemptions = The CI ICE is not exempt due to national security, testing at an engine test cell/stand or as a temporary replacement.</p> <p>Displacement = Displacement is greater than or equal to 10 and less than 15 liters per cylinder.</p> <p>Service = CI ICE is an emergency engine.</p> <p>Standards = The emergency CI ICE meets the standards applicable to non-emergency engines.</p> <p>Commencing = CI ICE that is commencing new construction.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			Compliance Option = Certified engine according to §60.4211(b)(1). Manufacture Date = Date of manufacture is after 04/01/2006. Model Year = CI ICE was manufactured prior to model year 2007.	
DIESELGEN	40 CFR Part 63, Subpart ZZZZ	63ZZZZ	HAP Source = Any stationary source of hazardous air pollutants that is not a major source as defined in 40 CFR § 63.2. Brake HP = Stationary RICE with a brake hp greater than 500. Construction/Reconstruction Date = Commenced construction or reconstruction on or after June 12, 2006.	
GENERATOR	30 TAC Chapter 117, East Texas Combustion	R73300	Unit Type = The engine is a diesel engine.	
GENERATOR	40 CFR Part 60, Subpart IIII	60IIII	Applicability Date = Stationary CI ICE commenced construction, reconstruction, or modification after July 11, 2005. Diesel = Diesel fuel is used. Kilowatts = Power rating is greater than or equal to 600 KW and less than 1400 KW. Exemptions = The CI ICE is not exempt due to national security, testing at an engine test cell/stand or as a temporary replacement. Displacement = Displacement is greater than or equal to 10 and less than 15 liters per cylinder. Service = CI ICE is an emergency engine. Standards = The emergency CI ICE meets the standards applicable to non-emergency engines. Commencing = CI ICE that is commencing new construction. Compliance Option = The CI ICE and control device is installed, configured, operated, and maintained according to the manufacturer's emission-related written instructions. Manufacture Date = Date of manufacture is after 04/01/2006. Model Year = CI ICE was manufactured in model year 2007.	
GENERATOR	40 CFR Part 63, Subpart ZZZZ	63ZZZZ	HAP Source = Any stationary source of hazardous air pollutants that is not a major source as defined in 40 CFR § 63.2. Brake HP = Stationary RICE with a brake hp greater than 500. Construction/Reconstruction Date = Commenced construction or reconstruction on or after June 12, 2006.	
T-1	40 CFR Part 60, Subpart K	60K	Construction/Modification Date = After March 8, 1974 and on or before May 19, 1978 Storage Capacity = Capacity is greater than 65,000 gallons (246,052 liters) Product Stored = Stored product other than petroleum liquid (as defined in 40 CFR Part 60, Subpart K)	
T-2	40 CFR Part 60, Subpart K	60K	Construction/Modification Date = After March 8, 1974 and on or before May 19, 1978 Storage Capacity = Capacity is greater than 65,000 gallons (246,052 liters) Product Stored = Stored product other than petroleum liquid (as defined in 40 CFR	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			Part 60, Subpart K)	
T-3	40 CFR Part 60, Subpart K	60K	Construction/Modification Date = After March 8, 1974 and on or before May 19, 1978 Storage Capacity = Capacity is greater than 65,000 gallons (246,052 liters) Product Stored = Stored product other than petroleum liquid (as defined in 40 CFR Part 60, Subpart K)	
T-4	40 CFR Part 60, Subpart Kb	60Kb	Product Stored = Stored product other than volatile organic liquid or petroleum liquid	
T-5	40 CFR Part 60, Subpart Kb	60Kb	Product Stored = Volatile organic liquid Storage Capacity = Capacity is less than 10,600 gallons (40,000 liters)	
T-6	40 CFR Part 60, Subpart K	60K	Construction/Modification Date = After March 8, 1974 and on or before May 19, 1978 Storage Capacity = Capacity is 40,000 gallons (151,416 liters) or less	
T-7	40 CFR Part 60, Subpart K	60K	Construction/Modification Date = After March 8, 1974 and on or before May 19, 1978 Storage Capacity = Capacity is 40,000 gallons (151,416 liters) or less	
T-8	40 CFR Part 60, Subpart K	60K	Construction/Modification Date = After March 8, 1974 and on or before May 19, 1978 Storage Capacity = Capacity is 40,000 gallons (151,416 liters) or less	
T-9	40 CFR Part 60, Subpart K	60K	Construction/Modification Date = After March 8, 1974 and on or before May 19, 1978 Storage Capacity = Capacity is 40,000 gallons (151,416 liters) or less	
1	30 TAC Chapter 112, Sulfur Compounds	R112-1	Fuel Type = Liquid fuel. Heat Input = Design heat input is greater than 250 MMBtu/hr. Control Equipment = Unit not equipped with SO <sub>2</sub> control equipment. Stack Height = The effective stack height is at least the standard effective stack height for each stack to which the unit routes emissions.	
1	30 TAC Chapter 117, Subchapter E, Division 1	R117	Date Placed in Service = Before December 31, 1995. NO <sub>x</sub> Emission Limitation = Title 30 TAC § 117.3010(1). Fuel = The unit is a gas fired electric power boiler. Unit Exempt = The unit does not qualify for any exemptions under the rule. Location = The unit is not a gas-fired steam generator located in Palo Pinto County as specified in 30 TAC § 117.3005(a). NO <sub>x</sub> Monitoring = A continuous emissions monitoring system is used to monitor NO <sub>x</sub> emissions. Maximum Emission Rate = The owner or operator is using one of the other allowed methods under § 117.3020(e)(1) - (3) to provide substitute emissions compliance when the NO <sub>x</sub> monitor is off-line. Ammonia Use = Ammonia injection is not used to control NO <sub>x</sub> emissions.	
1	40 CFR Part 60, Subpart D	60D-1	Construction/Modification Date = After August 17, 1971, and on or before December 22, 1976. D-Series Fuel Type #1 = Gaseous fossil fuel.	<u>Monitoring/Testing</u> - § 60.45(a), § 60.45(c) & § 60.45(a)(3) for PM (Opacity) were deleted due to the EPA approved alternative monitoring requirements.

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>Covered Under Subpart Da = The steam generating unit is not covered under 40 CFR Part 60, Subpart Da.</p> <p>Changes to Existing Affected Facility = No change has been made to the existing fossil fuel-fired steam generating unit.</p> <p>Alternate 43D = No alternative requirement is used for SO<sub>2</sub>, unit is complying with requirements of § 60.43(a) and (b).</p> <p>Heat Input Rate = Heat input rate is greater than 250 MMBtu/hr (73 MW).</p> <p>Alternate 42C = The facility is meeting the requirements of § 60.42(a) for PM.</p> <p>Alternate 44E = The facility is meeting the requirements of § 60.44(a), (b), and (d) for NO<sub>x</sub>.</p> <p>Flue Gas Desulfurization = The unit does not utilize a flue gas desulfurization device.</p> <p>PM CEMS = The facility does not use a CEMS to measure PM.</p> <p>Fuel Sampling and Analysis = The unit uses fuel sampling and analysis for monitoring of sulfur dioxide emissions.</p> <p>Gas or Liquid Fuel Only = Burns gaseous or liquid fossil fuel with potential SO<sub>2</sub> emissions rates greater than 0.060 lb/MMBtu, or other fuels, or uses post combustion technology to reduce of SO<sub>2</sub> or PM, or does not monitor SO<sub>2</sub> emissions by sampling or fuel receipts.</p> <p>Cyclone-Fired Unit = The unit is not a cyclone-fired unit.</p> <p>Fuels with 0.33 Percent or Less Sulfur = Facility uses post combustion technology (except a wet scrubber) for reducing PM, SO<sub>2</sub>, or CO, burns gaseous fuels or fuel oils that contain more than 0.30 % sulfur by weight or other fuels, or operates so CO emissions are &gt; 0.15 lb/MMBtu average.</p> <p>NO<sub>x</sub> Monitoring Type = It was not demonstrated during the performance test that emissions of NO<sub>x</sub> are less than 70% of applicable standards in 40 CFR § 60.44.</p> <p>PM CEMS Petition = No petition has been granted to install a PM CEMS as an alternative to the CEMS for monitoring opacity emissions.</p>	
1	40 CFR Part 60, Subpart D	60D-2	<p>Construction/Modification Date = After August 17, 1971, and on or before December 22, 1976.</p> <p>D-Series Fuel Type #1 = Liquid fossil fuel.</p> <p>Covered Under Subpart Da = The steam generating unit is not covered under 40 CFR Part 60, Subpart Da.</p> <p>Changes to Existing Affected Facility = No change has been made to the existing fossil fuel-fired steam generating unit.</p> <p>Alternate 43D = No alternative requirement is used for SO<sub>2</sub>, unit is complying with requirements of § 60.43(a) and (b).</p> <p>Heat Input Rate = Heat input rate is greater than 250 MMBtu/hr (73 MW).</p> <p>Alternate 42C = The facility is meeting the requirements of § 60.42(a) for PM.</p> <p>Alternate 44E = The facility is meeting the requirements of § 60.44(a), (b), and (d) for NO<sub>x</sub>.</p> <p>Flue Gas Desulfurization = The unit does not utilize a flue gas desulfurization device.</p> <p>PM CEMS = The facility does not use a CEMS to measure PM.</p> <p>Fuel Sampling and Analysis = The unit uses fuel sampling and analysis for monitoring</p>	<p><u>Monitoring/Testing</u> - § 60.45(a), § 60.45(c) &amp; § 60.45(a)(3) for PM (Opacity) were deleted due to the EPA approved alternative monitoring requirements.</p>

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>of sulfur dioxide emissions.</p> <p>Gas or Liquid Fuel Only = Burns gaseous or liquid fossil fuel with potential SO<sub>2</sub> emissions rates greater than 0.060 lb/MMBtu, or other fuels, or uses post combustion technology to reduce of SO<sub>2</sub> or PM, or does not monitor SO<sub>2</sub> emissions by sampling or fuel receipts.</p> <p>Cyclone-Fired Unit = The unit is not a cyclone-fired unit.</p> <p>Fuels with 0.33 Percent or Less Sulfur = Facility uses post combustion technology (except a wet scrubber) for reducing PM, SO<sub>2</sub>, or CO, burns gaseous fuels or fuel oils that contain more than 0.30 % sulfur by weight or other fuels, or operates so CO emissions are &gt; 0.15 lb/MMBtu average.</p> <p>NO<sub>x</sub> Monitoring Type = It was not demonstrated during the performance test that emissions of NO<sub>x</sub> are less than 70% of applicable standards in 40 CFR § 60.44.</p> <p>PM CEMS Petition = No petition has been granted to install a PM CEMS as an alternative to the CEMS for monitoring opacity emissions.</p>	
1	40 CFR Part 60, Subpart D	60D-3	<p>Construction/Modification Date = After August 17, 1971, and on or before December 22, 1976.</p> <p>D-Series Fuel Type #1 = Gaseous fossil fuel.</p> <p>Covered Under Subpart Da = The steam generating unit is not covered under 40 CFR Part 60, Subpart Da.</p> <p>D-Series Fuel Type #2 = Liquid fossil fuel.</p> <p>Changes to Existing Affected Facility = No change has been made to the existing fossil fuel-fired steam generating unit.</p> <p>Alternate 43D = No alternative requirement is used for SO<sub>2</sub>, unit is complying with requirements of § 60.43(a) and (b).</p> <p>Heat Input Rate = Heat input rate is greater than 250 MMBtu/hr (73 MW).</p> <p>Alternate 42C = The facility is meeting the requirements of § 60.42(a) for PM.</p> <p>Alternate 44E = The facility is meeting the requirements of § 60.44(a), (b), and (d) for NO<sub>x</sub>.</p> <p>Flue Gas Desulfurization = The unit does not utilize a flue gas desulfurization device.</p> <p>PM CEMS = The facility does not use a CEMS to measure PM.</p> <p>Fuel Sampling and Analysis = The unit uses fuel sampling and analysis for monitoring of sulfur dioxide emissions.</p> <p>Gas or Liquid Fuel Only = Burns gaseous or liquid fossil fuel with potential SO<sub>2</sub> emissions rates greater than 0.060 lb/MMBtu, or other fuels, or uses post combustion technology to reduce of SO<sub>2</sub> or PM, or does not monitor SO<sub>2</sub> emissions by sampling or fuel receipts.</p> <p>Cyclone-Fired Unit = The unit is not a cyclone-fired unit.</p> <p>Fuels with 0.33 Percent or Less Sulfur = Facility uses post combustion technology (except a wet scrubber) for reducing PM, SO<sub>2</sub>, or CO, burns gaseous fuels or fuel oils that contain more than 0.30 % sulfur by weight or other fuels, or operates so CO emissions are &gt; 0.15 lb/MMBtu average.</p> <p>NO<sub>x</sub> Monitoring Type = It was not demonstrated during the performance test that emissions of NO<sub>x</sub> are less than 70% of applicable standards in 40 CFR § 60.44.</p> <p>PM CEMS Petition = No petition has been granted to install a PM CEMS as an</p>	<p><u>Monitoring/Testing</u> - § 60.45(a), § 60.45(c) &amp; § 60.45(a)(3) for PM (Opacity) were deleted due to the EPA approved alternative monitoring requirements.</p>

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			alternative to the CEMS for monitoring opacity emissions.	
1	40 CFR Part 60, Subpart Da	60Da	Construction/Modification Date = ON/BEFORE SEPTEMBER 18, 1978	
1	40 CFR Part 60, Subpart Dc	60Dc	Construction/Modification Date = On or before June 9, 1989.	
2	40 CFR Part 60, Subpart GG	60GG	<p>NOx Control Method = Selective catalytic reduction.</p> <p>Peak Load Heat Input = Heat Input is greater than 100 MMBtu/hr (107.2 GJ/hr)</p> <p>Construction/Modification Date = On or after October 3, 1982 and before July 8, 2004.</p> <p>NOx Allowance = The owner or operator is not electing to use a NO<sub>x</sub> allowance in determining emission limits in 40 CFR § 60.332(a).</p> <p>NOx Monitoring Method = Continuous emission monitoring system.</p> <p>Sulfur Content = Compliance is demonstrated by determining the sulfur content of the fuel.</p> <p>Turbine Cycle = Unit does not recover heat from the gas turbine exhaust to preheat inlet combustion air; or to heat water or generate steam.</p> <p>Fuel Type Fired = Natural gas meeting the definition in § 60.331(u).</p> <p>Subpart GG Service Type = Electric utility generation.</p> <p>Fuel Supply = Stationary gas turbine is supplied its fuel without intermediate bulk storage.</p> <p>Fuel Monitoring Schedule = Fuel meets the definition of natural gas in 40 CFR § 60.331(u) and is not monitored.</p>	
3	30 TAC Chapter 117, Subchapter E, Division 1	R73000	Date Placed in Service = On or after December 31, 1995.	
3	40 CFR Part 60, Subpart KKKK	60KKKK-1	<p>75% of Peak = The combustion turbine operates at 75% of peak load or greater.</p> <p>Unit Type = Simple Combustion Turbine</p> <p>Construction/Modification Date = Turbine was constructed after February 18, 2005.</p> <p>SO<sub>2</sub> Standard = The heat input based SO<sub>2</sub> emission standard in § 60.4330(a)(2) or (a)(3) is being used.</p> <p>Fuel Monitoring = All fuels used are demonstrated not to exceed the potential emissions standard in § 60.4365.</p> <p>Heat Input = Turbine has a heat input at peak load of at least 50 MMBtu/hr but less than 850 MMBtu/hr.</p> <p>Fuel Quality = Fuel is demonstrated not to exceed emission standard by characteristics in purchase contract or tariff sheet.</p> <p>NOx Control = NO<sub>x</sub> emissions are being controlled by steam or water injection.</p> <p>Subject to Da = The combustion turbine is not located at an integrated gasification combined cycle electric utility steam generating unit subject to Subpart Da of Part 60.</p> <p>NOx Monitoring = A diluent NO<sub>x</sub> CEMS is used.</p> <p>Performance Test = Sulfur content of the fuel combusted in the turbine is being</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>periodically determined.</p> <p>Service Type = Service other than emergency service, as defined in § 60.4420(i), or research and development.</p> <p>NO<sub>x</sub> Standard = The parts per million NO<sub>x</sub> emission standard in Table 1 is being used.</p> <p>Fuel Type = 100% natural gas.</p>	
3	40 CFR Part 60, Subpart KKKK	60KKKK-2	<p>75% of Peak = The combustion turbine operates at 75% of peak load or greater.</p> <p>Unit Type = Simple Combustion Turbine</p> <p>Construction/Modification Date = Turbine was constructed after February 18, 2005.</p> <p>SO<sub>2</sub> Standard = The heat input based SO<sub>2</sub> emission standard in § 60.4330(a)(2) or (a)(3) is being used.</p> <p>Fuel Monitoring = All fuels used are demonstrated not to exceed the potential emissions standard in § 60.4365.</p> <p>Heat Input = Turbine has a heat input at peak load of at least 50 MMBtu/hr but less than 850 MMBtu/hr.</p> <p>Fuel Quality = Fuel is demonstrated not to exceed emission standard by characteristics in purchase contract or tariff sheet.</p> <p>NO<sub>x</sub> Control = NO<sub>x</sub> emissions are being controlled by steam or water injection.</p> <p>Subject to Da = The combustion turbine is not located at an integrated gasification combined cycle electric utility steam generating unit subject to Subpart Da of Part 60.</p> <p>NO<sub>x</sub> Monitoring = A diluent NO<sub>x</sub> CEMS is used.</p> <p>Performance Test = Sulfur content of the fuel combusted in the turbine is being periodically determined.</p> <p>Service Type = Service other than emergency service, as defined in § 60.4420(i), or research and development.</p> <p>NO<sub>x</sub> Standard = The parts per million NO<sub>x</sub> emission standard in Table 1 is being used.</p> <p>Fuel Type = Gaseous fuels and fuel oil, &gt; 50% natural gas.</p>	
3	40 CFR Part 60, Subpart KKKK	60KKKK-3	<p>75% of Peak = The combustion turbine operates at 75% of peak load or greater.</p> <p>Unit Type = Simple Combustion Turbine</p> <p>Construction/Modification Date = Turbine was constructed after February 18, 2005.</p> <p>SO<sub>2</sub> Standard = The heat input based SO<sub>2</sub> emission standard in § 60.4330(a)(2) or (a)(3) is being used.</p> <p>Fuel Monitoring = All fuels used are demonstrated not to exceed the potential emissions standard in § 60.4365.</p> <p>Heat Input = Turbine has a heat input at peak load of at least 50 MMBtu/hr but less than 850 MMBtu/hr.</p> <p>Fuel Quality = Fuel is demonstrated not to exceed emission standard by characteristics in purchase contract or tariff sheet.</p> <p>NO<sub>x</sub> Control = NO<sub>x</sub> emissions are being controlled by steam or water injection.</p> <p>Subject to Da = The combustion turbine is not located at an integrated gasification combined cycle electric utility steam generating unit subject to Subpart Da of Part 60.</p> <p>NO<sub>x</sub> Monitoring = A diluent NO<sub>x</sub> CEMS is used.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>Performance Test = Sulfur content of the fuel combusted in the turbine is being periodically determined.</p> <p>Service Type = Service other than emergency service, as defined in § 60.4420(i), or research and development.</p> <p>NO<sub>x</sub> Standard = The parts per million NO<sub>x</sub> emission standard in Table 1 is being used.</p> <p>Fuel Type = Gaseous fuels and fuel oil, &gt; 50% fuel oil.</p>	
3	40 CFR Part 60, Subpart KKKK	60KKKK-4	<p>75% of Peak = The combustion turbine operates at 75% of peak load or greater.</p> <p>Unit Type = Simple Combustion Turbine</p> <p>Construction/Modification Date = Turbine was constructed after February 18, 2005.</p> <p>SO<sub>2</sub> Standard = The heat input based SO<sub>2</sub> emission standard in § 60.4330(a)(2) or (a)(3) is being used.</p> <p>Fuel Monitoring = All fuels used are demonstrated not to exceed the potential emissions standard in § 60.4365.</p> <p>Heat Input = Turbine has a heat input at peak load of at least 50 MMBtu/hr but less than 850 MMBtu/hr.</p> <p>Fuel Quality = Fuel is demonstrated not to exceed emission standard by characteristics in purchase contract or tariff sheet.</p> <p>NO<sub>x</sub> Control = NO<sub>x</sub> emissions are being controlled by steam or water injection.</p> <p>Subject to Da = The combustion turbine is not located at an integrated gasification combined cycle electric utility steam generating unit subject to Subpart Da of Part 60.</p> <p>NO<sub>x</sub> Monitoring = A diluent NO<sub>x</sub> CEMS is used.</p> <p>Performance Test = Sulfur content of the fuel combusted in the turbine is being periodically determined.</p> <p>Service Type = Service other than emergency service, as defined in § 60.4420(i), or research and development.</p> <p>NO<sub>x</sub> Standard = The parts per million NO<sub>x</sub> emission standard in Table 1 is being used.</p> <p>Fuel Type = 100% fuel oil.</p>	
3	40 CFR Part 60, Subpart KKKK	60KKKK-5	<p>75% of Peak = The combustion turbine operates at less than 75% of peak load.</p> <p>Unit Type = Simple Combustion Turbine</p> <p>30 MW = The combustion turbine has an output of 30 MW or greater.</p> <p>Construction/Modification Date = Turbine was constructed after February 18, 2005.</p> <p>SO<sub>2</sub> Standard = The heat input based SO<sub>2</sub> emission standard in § 60.4330(a)(2) or (a)(3) is being used.</p> <p>Fuel Monitoring = All fuels used are demonstrated not to exceed the potential emissions standard in § 60.4365.</p> <p>Heat Input = Turbine has a heat input at peak load of at least 50 MMBtu/hr but less than 850 MMBtu/hr.</p> <p>Fuel Quality = Fuel is demonstrated not to exceed emission standard by characteristics in purchase contract or tariff sheet.</p> <p>NO<sub>x</sub> Control = NO<sub>x</sub> emissions are being controlled by steam or water injection.</p> <p>Subject to Da = The combustion turbine is not located at an integrated gasification</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>combined cycle electric utility steam generating unit subject to Subpart Da of Part 60.</p> <p>NOx Monitoring = A diluent NO<sub>x</sub> CEMS is used.</p> <p>Performance Test = Sulfur content of the fuel combusted in the turbine is being periodically determined.</p> <p>Service Type = Service other than emergency service, as defined in § 60.4420(i), or research and development.</p> <p>NOx Standard = The parts per million NO<sub>x</sub> emission standard in Table 1 is being used.</p> <p>Fuel Type = 100% natural gas.</p>	
3	40 CFR Part 60, Subpart KKKK	60KKKK-6	<p>75% of Peak = The combustion turbine operates at less than 75% of peak load.</p> <p>Unit Type = Simple Combustion Turbine</p> <p>30 MW = The combustion turbine has an output of 30 MW or greater.</p> <p>Construction/Modification Date = Turbine was constructed after February 18, 2005.</p> <p>SO<sub>2</sub> Standard = The heat input based SO<sub>2</sub> emission standard in § 60.4330(a)(2) or (a)(3) is being used.</p> <p>Fuel Monitoring = All fuels used are demonstrated not to exceed the potential emissions standard in § 60.4365.</p> <p>Heat Input = Turbine has a heat input at peak load of at least 50 MMBtu/hr but less than 850 MMBtu/hr.</p> <p>Fuel Quality = Fuel is demonstrated not to exceed emission standard by characteristics in purchase contract or tariff sheet.</p> <p>NOx Control = NO<sub>x</sub> emissions are being controlled by steam or water injection.</p> <p>Subject to Da = The combustion turbine is not located at an integrated gasification combined cycle electric utility steam generating unit subject to Subpart Da of Part 60.</p> <p>NOx Monitoring = A diluent NO<sub>x</sub> CEMS is used.</p> <p>Performance Test = Sulfur content of the fuel combusted in the turbine is being periodically determined.</p> <p>Service Type = Service other than emergency service, as defined in § 60.4420(i), or research and development.</p> <p>NOx Standard = The parts per million NO<sub>x</sub> emission standard in Table 1 is being used.</p> <p>Fuel Type = Gaseous fuels and fuel oil, &gt; 50% natural gas.</p>	
3	40 CFR Part 60, Subpart KKKK	60KKKK-7	<p>75% of Peak = The combustion turbine operates at less than 75% of peak load.</p> <p>Unit Type = Simple Combustion Turbine</p> <p>30 MW = The combustion turbine has an output of 30 MW or greater.</p> <p>Construction/Modification Date = Turbine was constructed after February 18, 2005.</p> <p>SO<sub>2</sub> Standard = The heat input based SO<sub>2</sub> emission standard in § 60.4330(a)(2) or (a)(3) is being used.</p> <p>Fuel Monitoring = All fuels used are demonstrated not to exceed the potential emissions standard in § 60.4365.</p> <p>Heat Input = Turbine has a heat input at peak load of at least 50 MMBtu/hr but less than 850 MMBtu/hr.</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>Fuel Quality = Fuel is demonstrated not to exceed emission standard by characteristics in purchase contract or tariff sheet.</p> <p>NOx Control = NO<sub>x</sub> emissions are being controlled by steam or water injection.</p> <p>Subject to Da = The combustion turbine is not located at an integrated gasification combined cycle electric utility steam generating unit subject to Subpart Da of Part 60.</p> <p>NOx Monitoring = A diluent NO<sub>x</sub> CEMS is used.</p> <p>Performance Test = Sulfur content of the fuel combusted in the turbine is being periodically determined.</p> <p>Service Type = Service other than emergency service, as defined in § 60.4420(i), or research and development.</p> <p>NOx Standard = The parts per million NO<sub>x</sub> emission standard in Table 1 is being used.</p> <p>Fuel Type = Gaseous fuels and fuel oil, &gt; 50% fuel oil.</p>	
3	40 CFR Part 60, Subpart KKKK	60KKKK-8	<p>75% of Peak = The combustion turbine operates at less than 75% of peak load.</p> <p>Unit Type = Simple Combustion Turbine</p> <p>30 MW = The combustion turbine has an output of 30 MW or greater.</p> <p>Construction/Modification Date = Turbine was constructed after February 18, 2005.</p> <p>SO<sub>2</sub> Standard = The heat input based SO<sub>2</sub> emission standard in § 60.4330(a)(2) or (a)(3) is being used.</p> <p>Fuel Monitoring = All fuels used are demonstrated not to exceed the potential emissions standard in § 60.4365.</p> <p>Heat Input = Turbine has a heat input at peak load of at least 50 MMBtu/hr but less than 850 MMBtu/hr.</p> <p>Fuel Quality = Fuel is demonstrated not to exceed emission standard by characteristics in purchase contract or tariff sheet.</p> <p>NOx Control = NO<sub>x</sub> emissions are being controlled by steam or water injection.</p> <p>Subject to Da = The combustion turbine is not located at an integrated gasification combined cycle electric utility steam generating unit subject to Subpart Da of Part 60.</p> <p>NOx Monitoring = A diluent NO<sub>x</sub> CEMS is used.</p> <p>Performance Test = Sulfur content of the fuel combusted in the turbine is being periodically determined.</p> <p>Service Type = Service other than emergency service, as defined in § 60.4420(i), or research and development.</p> <p>NOx Standard = The parts per million NO<sub>x</sub> emission standard in Table 1 is being used.</p> <p>Fuel Type = 100% fuel oil.</p>	
CT-1	40 CFR Part 63, Subpart Q	63Q	Used Compounds Containing Chromium on or After September 8, 1994 = The industrial process cooling tower has not used compounds containing chromium on or after September 8, 1994.	
CT-2	40 CFR Part 63, Subpart Q	63Q	Used Compounds Containing Chromium on or After September 8, 1994 = The industrial process cooling tower has not used compounds containing chromium on or after September 8, 1994.	
4	30 TAC Chapter	R111-1	Alternate Opacity Limitation = Not complying with an alternate opacity limit under 30	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
	111, Visible Emissions		<p>TAC § 111.113.</p> <p>SIP Violation = The source is able to comply with applicable PM and opacity regulations without the use of PM collection equipment and has not been found to be in violation of any visible emission standard in a State Implementation Plan.</p> <p>Vent Source = The source of the vent is a steam generator that burns oil or a mixture of oil and gas.</p> <p>Opacity Monitoring System = Optical instrument capable of measuring the opacity of emissions is not installed in the vent or optical instrumentation does not meet the requirements of § 111.111(a)(1)(D), or the vent stream does not qualify for the exemption in § 111.111(a)(3).</p> <p>Construction Date = After January 31, 1972</p> <p>Effluent Flow Rate = Effluent flow rate is at least 100,000 actual cubic feet per minute.</p>	
4	30 TAC Chapter 111, Visible Emissions	R111-2	<p>Alternate Opacity Limitation = Not complying with an alternate opacity limit under 30 TAC § 111.113.</p> <p>Vent Source = The source of the vent is not a steam generator fired by solid fossil fuel, oil or a mixture of oil and gas and is not a catalyst regenerator for a fluid bed catalytic cracking unit.</p> <p>Opacity Monitoring System = Optical instrument capable of measuring the opacity of emissions is not installed in the vent or optical instrumentation does not meet the requirements of § 111.111(a)(1)(D), or the vent stream does not qualify for the exemption in § 111.111(a)(3).</p> <p>Construction Date = After January 31, 1972</p> <p>Effluent Flow Rate = Effluent flow rate is at least 100,000 actual cubic feet per minute.</p>	
5	30 TAC Chapter 111, Visible Emissions	R111-3	<p>Alternate Opacity Limitation = Not complying with an alternate opacity limit under 30 TAC § 111.113.</p> <p>Vent Source = The source of the vent is not a steam generator fired by solid fossil fuel, oil or a mixture of oil and gas and is not a catalyst regenerator for a fluid bed catalytic cracking unit.</p> <p>Opacity Monitoring System = Optical instrument capable of measuring the opacity of emissions is not installed in the vent or optical instrumentation does not meet the requirements of § 111.111(a)(1)(D), or the vent stream does not qualify for the exemption in § 111.111(a)(3).</p> <p>Construction Date = After January 31, 1972</p> <p>Effluent Flow Rate = Effluent flow rate is at least 100,000 actual cubic feet per minute.</p>	
6	30 TAC Chapter 111, Visible Emissions	R111-4	<p>Alternate Opacity Limitation = Not complying with an alternate opacity limit under 30 TAC § 111.113.</p> <p>Vent Source = The source of the vent is not a steam generator fired by solid fossil fuel, oil or a mixture of oil and gas and is not a catalyst regenerator for a fluid bed catalytic cracking unit.</p> <p>Opacity Monitoring System = Optical instrument capable of measuring the opacity of emissions is not installed in the vent or optical instrumentation does not meet the requirements of § 111.111(a)(1)(D), or the vent stream does not qualify for the exemption in § 111.111(a)(3).</p> <p>Construction Date = After January 31, 1972</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			Effluent Flow Rate = Effluent flow rate is at least 100,000 actual cubic feet per minute.	

\* - The "unit attributes" or operating conditions that determine what requirements apply

\*\* - Notes changes made to the automated results from the DSS, and a brief explanation why

## NSR Versus Title V FOP

The state of Texas has two Air permitting programs, New Source Review (NSR) and Title V Federal Operating Permits. The two programs are substantially different both in intent and permit content.

NSR is a preconstruction permitting program authorized by the Texas Clean Air Act and Title I of the Federal Clean Air Act (FCAA). The processing of these permits is governed by 30 Texas Administrative Code (TAC) Chapter 116.111. The Title V Federal Operating Program is a federal program authorized under Title V of the FCAA that has been delegated to the state of Texas to administer and is governed by 30 TAC Chapter 122. The major differences between the two permitting programs are listed in the table below:

NSR Permit	Federal Operating Permit(FOP)
Issued Prior to new Construction or modification of an existing facility	For initial permit with application shield, can be issued after operation commences; significant revisions require approval prior to operation.
Authorizes air emissions	Codifies existing applicable requirements, does not authorize new emissions
Ensures issued permits are protective of the environment and human health by conducting a health effects review and that requirement for best available control technology (BACT) is implemented.	Applicable requirements listed in permit are used by the inspectors to ensure proper operation of the site as authorized. Ensures that adequate monitoring is in place to allow compliance determination with the FOP.
Up to two Public notices may be required. Opportunity for public comment and contested case hearings for some authorizations.	One public notice required. Opportunity for public comments. No contested case hearings.
Applies to all point source emissions in the state.	Applies to all major sources and some non-major sources identified by the EPA.
Applies to facilities: a portion of site or individual emission sources	One or multiple FOPs cover the entire site (consists of multiple facilities)
Permits include terms and conditions under which the applicant must construct and operate its various equipment and processes on a facility basis.	Permits include terms and conditions that specify the general operational requirements of the site; and also include codification of all applicable requirements for emission units at the site.
Opportunity for EPA review for Federal Prevention of Significant Deterioration (PSD) and Nonattainment (NA) permits for major sources.	Opportunity for EPA review, Affected states review, and a Public petition period for every FOP.
Permits have a table listing maximum emission limits for pollutants	Permit has an applicable requirements table and Periodic Monitoring (PM) / Compliance Assurance Monitoring (CAM) tables which document applicable monitoring requirements.
Permits can be altered or amended upon application by company. Permits must be issued before construction or modification of facilities can begin.	Permits can be revised through several revision processes, which provide for different levels of public notice and opportunity to comment. Changes that would be significant revisions require that a revised permit be issued before those changes can be operated.
NSR permits are issued independent of FOP requirements.	FOP are independent of NSR permits, but contain a list of all NSR permits incorporated by reference

## New Source Review Requirements

Below is a list of the New Source Review (NSR) permits for the permitted area. These NSR permits are incorporated by reference into the operating permit and are enforceable under it. These permits can be found in the main TCEQ file room, located on the first floor of Building E, 12100 Park 35 Circle, Austin, Texas. The Public Education Program may be contacted at 1-800-687-4040 or the Air Permits Division (APD) may be contacted at 1-512-239-1250 for help with any question.

Additionally, the site contains emission units that are permitted by rule under the requirements of 30 TAC Chapter 106, Permits by Rule. The following table specifies the permits by rule that apply to the site. All current permits by rule are contained in Chapter 106. Outdated 30 TAC Chapter 106 permits by rule may be viewed at the following Web site:

[www.tceq.texas.gov/permitting/air/permitbyrule/historical\\_rules/old106list/index106.html](http://www.tceq.texas.gov/permitting/air/permitbyrule/historical_rules/old106list/index106.html)

Outdated Standard Exemption lists may be viewed at the following Web site:

[www.tceq.texas.gov/permitting/air/permitbyrule/historical\\_rules/oldselist/se\\_index.html](http://www.tceq.texas.gov/permitting/air/permitbyrule/historical_rules/oldselist/se_index.html)

The status of air permits and applications and a link to the Air Permits Remote Document Server is located at the following Web site:

[www.tceq.texas.gov/permitting/air/nav/air\\_status\\_permits.html](http://www.tceq.texas.gov/permitting/air/nav/air_status_permits.html)

<b>Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.</b>	
Authorization No.: 4415	Issuance Date: 12/08/2011
Authorization No.: 54162	Issuance Date: 11/16/2012
<b>Permits By Rule (30 TAC Chapter 106) for the Application Area</b>	
Number: 106.183	Version No./Date: 09/04/2000
Number: 106.227	Version No./Date: 09/04/2000
Number: 106.265	Version No./Date: 09/04/2000
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 09/04/2000
Number: 106.532	Version No./Date: 09/04/2000
Number: 6	Version No./Date: 09/12/1989
Number: 8	Version No./Date: 09/12/1989
Number: 51	Version No./Date: 09/12/1989
Number: 70	Version No./Date: 09/12/1989
Number: 107	Version No./Date: 09/12/1989

## Emission Units and Emission Points

In air permitting terminology, any source capable of generating emissions (for example, an engine or a sandblasting area) is called an Emission Unit. For purposes of Title V, emission units are specifically listed in

the operating permit when they have applicable requirements other than New Source Review (NSR), or when they are listed in the permit shield table.

The actual physical location where the emissions enter the atmosphere (for example, an engine stack or a sand-blasting yard) is called an emission point. For New Source Review preconstruction permitting purposes, every emission unit has an associated emission point. Emission limits are listed in an NSR permit, associated with an emission point. This list of emission points and emission limits per pollutant is commonly referred to as the “Maximum Allowable Emission Rate Table”, or “MAERT” for short. Specifically, the MAERT lists the Emission Point Number (EPN) that identifies the emission point, followed immediately by the Source Name, identifying the emission unit that is the source of those emissions on this table.

Thus, by reference, an emission unit in a Title V operating permit is linked by reference number to an NSR authorization, and its related emission point.

**Monitoring Sufficiency**

Federal and state rules, 40 CFR § 70.6(a)(3)(i)(B) and 30 TAC § 122.142(c) respectively, require that each federal operating permit include additional monitoring for applicable requirements that lack periodic or instrumental monitoring (which may include recordkeeping that serves as monitoring) that yields reliable data from a relevant time period that are representative of the emission unit’s compliance with the applicable emission limitation or standard. Furthermore, the federal operating permit must include compliance assurance monitoring (CAM) requirements for emission sources that meet the applicability criteria of 40 CFR Part 64 in accordance with 40 CFR § 70.6(a)(3)(i)(A) and 30 TAC § 122.604(b).

With the exception of any emission units listed in the Periodic Monitoring or CAM Summaries in the FOP, the TCEQ Executive Director has determined that the permit contains sufficient monitoring, testing, recordkeeping, and reporting requirements that assure compliance with the applicable requirements. If applicable, each emission unit that requires additional monitoring in the form of periodic monitoring or CAM is described in further detail under the Rationale for CAM/PM Methods Selected section following this paragraph.

**Rationale for Compliance Assurance Monitoring (CAM)/ Periodic Monitoring Methods Selected**

**Periodic Monitoring:**

The Federal Clean Air Act requires that each federal operating permit include monitoring sufficient to assure compliance with the terms and conditions of the permit. Most of the emission limits and standards applicable to emission units at Title V sources include adequate monitoring to show that the units meet the limits and standards. For those requirements that do not include monitoring, or where the monitoring is not sufficient to assure compliance, the federal operating permit must include such monitoring for the emission units affected. The following emission units are subject to periodic monitoring requirements because the emission units are subject to an emission limitation or standard for an air pollutant (or surrogate thereof) in an applicable requirement that does not already require monitoring, or the monitoring for the applicable requirement is not sufficient to assure compliance:

<b>Unit/Group/Process Information</b>	
ID No.: 1	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: R112-1

Pollutant: SO <sub>2</sub>	Main Standard: § 112.9(a)
<b>Monitoring Information</b>	
Indicator: Fuel purchase and composition records.	
Minimum Frequency: Upon receipt of fuel oil or upon completion of fuel blending	
Averaging Period: n/a	
Deviation Limit: Sulfur content of fuel oil > 0.8% sulfur.	
<p>Basis of monitoring:  Monitoring the sulfur content of fuel ensures that low sulfur fuel is being combusted. A boiler fired with low sulfur fuel is expected to produce little sulfur or visible emissions. Therefore, a reasonable assurance of compliance is proved by firing low sulfur content fuels in the boiler.</p>	

<b>Unit/Group/Process Information</b>	
ID No.: 1	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60D-1
Pollutant: PM	Main Standard: § 60.42(a)(1)
<b>Monitoring Information</b>	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Firing a liquid fuel for greater than 24 consecutive hours without conducting a visible emission observation; or if visible emissions are observed & Test Method 9 is not performed; or if opacity is greater than 20% over a six-minute period.	
<p>Basis of monitoring:</p> <p>Industry has demonstrated through performance tests and historical data that opacity and particulate matter standards are consistently met when combustion units fire natural gas only. If the emission unit fires a different fuel for more than 24 hours, the permit holder may elect to perform opacity readings or visible emissions to demonstrate compliance is consistent with EPA Reference Test Method 9 and 22. Opacity and visible emissions have been used as an indicator of particulate emissions in many federal rules including 40 CFR Part 60, Subpart F and Subpart HH. In addition, use of these indicators is consistent with the EPA's "Compliance Assurance Monitoring (CAM) Technical Guidance Document" (August 1998). Monitoring specifications and procedures for the opacity are consistent with federal requirements and include the EPA's Test Method 9 for determining opacity by visual observations and the requirements of 40 CFR § 60.13 for a continuous opacity monitoring system (COMS). The monitoring specifications and procedures for the visible emissions monitoring are similar to "EPA Reference Method 22" procedures.</p>	

<b>Unit/Group/Process Information</b>	
ID No.: 1	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60D-2
Pollutant: PM	Main Standard: § 60.42(a)(1)
<b>Monitoring Information</b>	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Firing a liquid fuel greater than 24 consecutive hours without conducting a visible emission observation; visible emissions observed & Test Method 9 is not performed; or opacity greater than 20% except for one six-minute period/hour not greater 27%.	
<p>Basis of monitoring:</p> <p>Industry has demonstrated through performance tests and historical data that opacity and particulate matter standards are consistently met when combustion units fire natural gas only. If the emission unit fires a different fuel for more than 24 hours, the permit holder may elect to perform opacity readings or visible emissions to demonstrate compliance is consistent with EPA Reference Test Method 9 and 22. Opacity and visible emissions have been used as an indicator of particulate emissions in many federal rules including 40 CFR Part 60, Subpart F and Subpart HH. In addition, use of these indicators is consistent with the EPA's "Compliance Assurance Monitoring (CAM) Technical Guidance Document" (August 1998). Monitoring specifications and procedures for the opacity are consistent with federal requirements and include the EPA's Test Method 9 for determining opacity by visual observations and the requirements of 40 CFR § 60.13 for a continuous opacity monitoring system (COMS). The monitoring specifications and procedures for the visible emissions monitoring are similar to "EPA Reference Method 22" procedures.</p>	

<b>Unit/Group/Process Information</b>	
ID No.: 1	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60D-3
Pollutant: PM	Main Standard: § 60.42(a)(1)
<b>Monitoring Information</b>	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Firing a liquid fuel for greater than 24 consecutive hours without conducting a visible emission observation; or if visible emissions are observed & Test Method 9 is not performed; or if opacity is greater than 20% over a six-minute period.	
<p>Basis of monitoring:</p> <p>Industry has demonstrated through performance tests and historical data that opacity and particulate matter standards are consistently met when combustion units fire natural gas only. If the emission unit fires a different fuel for more than 24 hours, the permit holder may elect to perform opacity readings or visible emissions to demonstrate compliance is consistent with EPA Reference Test Method 9 and 22. Opacity and visible emissions have been used as an indicator of particulate emissions in many federal rules including 40 CFR Part 60, Subpart F and Subpart HH. In addition, use of these indicators is consistent with the EPA's "Compliance Assurance Monitoring (CAM) Technical Guidance Document" (August 1998). Monitoring specifications and procedures for the opacity are consistent with federal requirements and include the EPA's Test Method 9 for determining opacity by visual observations and the requirements of 40 CFR § 60.13 for a continuous opacity monitoring system (COMS). The monitoring specifications and procedures for the visible emissions monitoring are similar to "EPA Reference Method 22" procedures.</p>	

<b>Unit/Group/Process Information</b>	
ID No.: 1	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60D-2
Pollutant: SO <sub>2</sub>	Main Standard: § 60.43(a)(1)
<b>Monitoring Information</b>	
Indicator: Sulfur Content of Fuel	
Minimum Frequency: Quarterly and within 24 hours of any fuel change	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if maximum fuel oil sulfur concentration is greater than 0.77%.	
Basis of monitoring: A common way to determine SO <sub>2</sub> emissions is by determining the amount (percentage) of sulfur in fuel combusted by an emission unit. This quantity along with stack flow rate and quantity of fuel combusted may be used to calculate the amount of SO <sub>2</sub> emitted to the atmosphere.	

\*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

<b>Unit/Group/Process Information</b>	
ID No.: 1	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60D-3
Pollutant: SO <sub>2</sub>	Main Standard: § 60.43(b)
<b>Monitoring Information</b>	
Indicator: Sulfur Content of Fuel	
Minimum Frequency: Quarterly and within 24 hours of any fuel change	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if maximum fuel oil sulfur concentration is greater than 0.77%.	
Basis of monitoring: A common way to determine SO <sub>2</sub> emissions is by determining the amount (percentage) of sulfur in fuel combusted by an emission unit. This quantity along with stack flow rate and quantity of fuel combusted may be used to calculate the amount of SO <sub>2</sub> emitted to the atmosphere.	

\*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

<b>Unit/Group/Process Information</b>	
ID No.: 4	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R111-1
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(C)
<b>Monitoring Information</b>	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Firing a liquid fuel for greater than 24 consecutive hours without conducting a visible emission observation; or if visible emissions are observed & Test Method 9 is not performed; or if opacity is greater than 15% over a six-minute period.	
<p>Basis of monitoring:</p> <p>Industry has demonstrated through performance tests and historical data that opacity and particulate matter standards are consistently met when combustion units fire natural gas only. If the emission unit fires a different fuel for more than 24 hours, the permit holder may elect to perform opacity readings or visible emissions to demonstrate compliance is consistent with EPA Reference Test Method 9 and 22. Opacity and visible emissions have been used as an indicator of particulate emissions in many federal rules including 40 CFR Part 60, Subpart F and Subpart HH. In addition, use of these indicators is consistent with the EPA's "Compliance Assurance Monitoring (CAM) Technical Guidance Document" (August 1998). Monitoring specifications and procedures for the opacity are consistent with federal requirements and include the EPA's Test Method 9 for determining opacity by visual observations and the requirements of 40 CFR § 60.13 for a continuous opacity monitoring system (COMS). The monitoring specifications and procedures for the visible emissions monitoring are similar to "EPA Reference Method 22" procedures.</p>	

<b>Unit/Group/Process Information</b>	
ID No.: 4	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R111-2
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(C)
<b>Monitoring Information</b>	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Firing a liquid fuel for greater than 24 consecutive hours without conducting a visible emission observation; or if visible emissions are observed & Test Method 9 is not performed; or if opacity is greater than 15% over a six-minute period.	
<p>Basis of monitoring:</p> <p>Industry has demonstrated through performance tests and historical data that opacity and particulate matter standards are consistently met when combustion units fire natural gas only. If the emission unit fires a different fuel for more than 24 hours, the permit holder may elect to perform opacity readings or visible emissions to demonstrate compliance is consistent with EPA Reference Test Method 9 and 22. Opacity and visible emissions have been used as an indicator of particulate emissions in many federal rules including 40 CFR Part 60, Subpart F and Subpart HH. In addition, use of these indicators is consistent with the EPA's "Compliance Assurance Monitoring (CAM) Technical Guidance Document" (August 1998). Monitoring specifications and procedures for the opacity are consistent with federal requirements and include the EPA's Test Method 9 for determining opacity by visual observations and the requirements of 40 CFR § 60.13 for a continuous opacity monitoring system (COMS). The monitoring specifications and procedures for the visible emissions monitoring are similar to "EPA Reference Method 22" procedures.</p>	

<b>Unit/Group/Process Information</b>	
ID No.: 5	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R111-3
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(C)
<b>Monitoring Information</b>	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: It is a deviation if visible emissions are observed & Test Method 9 is not performed; or if Opacity exceeds 15% averaged over a six-minute period per a Test Method 9 observation.	
<p>Basis of monitoring:  Industry has demonstrated through performance tests and historical data that opacity and particulate matter standards are consistently met when combustion units fire natural gas only. If the emission unit fires a different fuel for more than 24 hours, the permit holder may elect to perform opacity readings or visible emissions to demonstrate compliance is consistent with EPA Reference Test Method 9 and 22. Opacity and visible emissions have been used as an indicator of particulate emissions in many federal rules including 40 CFR Part 60, Subpart F and Subpart HH. In addition, use of these indicators is consistent with the EPA's "Compliance Assurance Monitoring (CAM) Technical Guidance Document" (August 1998). Monitoring specifications and procedures for the opacity are consistent with federal requirements and include the EPA's Test Method 9 for determining opacity by visual observations and the requirements of 40 CFR § 60.13 for a continuous opacity monitoring system (COMS). The monitoring specifications and procedures for the visible emissions monitoring are similar to "EPA Reference Method 22" procedures.</p>	

<b>Unit/Group/Process Information</b>	
ID No.: 6	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R111-4
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(C)
<b>Monitoring Information</b>	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: It is a deviation if visible emissions are observed & Test Method 9 is not performed; or if Opacity exceeds 15% averaged over a six-minute period per a Test Method 9 observation.	
<p>Basis of monitoring:  Industry has demonstrated through performance tests and historical data that opacity and particulate matter standards are consistently met when combustion units fire natural gas only. If the emission unit fires a different fuel for more than 24 hours, the permit holder may elect to perform opacity readings or visible emissions to demonstrate compliance is consistent with EPA Reference Test Method 9 and 22. Opacity and visible emissions have been used as an indicator of particulate emissions in many federal rules including 40 CFR Part 60, Subpart F and Subpart HH. In addition, use of these indicators is consistent with the EPA's "Compliance Assurance Monitoring (CAM) Technical Guidance Document" (August 1998). Monitoring specifications and procedures for the opacity are consistent with federal requirements and include the EPA's Test Method 9 for determining opacity by visual observations and the requirements of 40 CFR § 60.13 for a continuous opacity monitoring system (COMS). The monitoring specifications and procedures for the visible emissions monitoring are similar to "EPA Reference Method 22" procedures.</p>	

**Compliance Review**

1. In accordance with 30 TAC Chapter 60, the compliance history was reviewed on May 29, 2015.

Site rating: 0.55 / Satisfactory Company rating: 0.13 / Satisfactory

(High < 0.10; Satisfactory ≥ 0.10 and ≤ 55; Unsatisfactory > 55)

2. Has the permit changed on the basis of the compliance history or site/company rating? .....No

**Site/Permit Area Compliance Status Review**

1. Were there any out-of-compliance units listed on Form OP-ACPS? .....No

2. Is a compliance plan and schedule included in the permit?.....No

**Available Unit Attribute Forms**

- OP-UA1 - Miscellaneous and Generic Unit Attributes
- OP-UA2 - Stationary Reciprocating Internal Combustion Engine Attributes
- OP-UA3 - Storage Tank/Vessel Attributes
- OP-UA4 - Loading/Unloading Operations Attributes
- OP-UA5 - Process Heater/Furnace Attributes
- OP-UA6 - Boiler/Steam Generator/Steam Generating Unit Attributes
- OP-UA7 - Flare Attributes
- OP-UA8 - Coal Preparation Plant Attributes
- OP-UA9 - Nonmetallic Mineral Process Plant Attributes
- OP-UA10 - Gas Sweetening/Sulfur Recovery Unit Attributes
- OP-UA11 - Stationary Turbine Attributes
- OP-UA12 - Fugitive Emission Unit Attributes
- OP-UA13 - Industrial Process Cooling Tower Attributes
- OP-UA14 - Water Separator Attributes
- OP-UA15 - Emission Point/Stationary Vent/Distillation Operation/Process Vent Attributes
- OP-UA16 - Solvent Degreasing Machine Attributes
- OP-UA17 - Distillation Unit Attributes
- OP-UA18 - Surface Coating Operations Attributes
- OP-UA19 - Wastewater Unit Attributes
- OP-UA20 - Asphalt Operations Attributes
- OP-UA21 - Grain Elevator Attributes
- OP-UA22 - Printing Attributes
- OP-UA24 - Wool Fiberglass Insulation Manufacturing Plant Attributes
- OP-UA25 - Synthetic Fiber Production Attributes
- OP-UA26 - Electroplating and Anodizing Unit Attributes
- OP-UA27 - Nitric Acid Manufacturing Attributes
- OP-UA28 - Polymer Manufacturing Attributes
- OP-UA29 - Glass Manufacturing Unit Attributes
- OP-UA30 - Kraft, Soda, Sulfite, and Stand-Alone Semichemical Pulp Mill Attributes
- OP-UA31 - Lead Smelting Attributes
- OP-UA32 - Copper and Zinc Smelting/Brass and Bronze Production Attributes
- OP-UA33 - Metallic Mineral Processing Plant Attributes
- OP-UA34 - Pharmaceutical Manufacturing
- OP-UA35 - Incinerator Attributes
- OP-UA36 - Steel Plant Unit Attributes
- OP-UA37 - Basic Oxygen Process Furnace Unit Attributes
- OP-UA38 - Lead-Acid Battery Manufacturing Plant Attributes
- OP-UA39 - Sterilization Source Attributes
- OP-UA40 - Ferroalloy Production Facility Attributes
- OP-UA41 - Dry Cleaning Facility Attributes
- OP-UA42 - Phosphate Fertilizer Manufacturing Attributes

OP-UA43 - Sulfuric Acid Production Attributes  
OP-UA44 - Municipal Solid Waste Landfill/Waste Disposal Site Attributes  
OP-UA45 - Surface Impoundment Attributes  
OP-UA46 - Epoxy Resins and Non-Nylon Polyamides Production Attributes  
OP-UA47 - Ship Building and Ship Repair Unit Attributes  
OP-UA48 - Air Oxidation Unit Process Attributes  
OP-UA49 - Vacuum-Producing System Attributes  
OP-UA50 - Fluid Catalytic Cracking Unit Catalyst Regenerator/Fuel Gas Combustion Device/Claus Sulfur Recovery Plant Attributes  
OP-UA51 - Dryer/Kiln/Oven Attributes  
OP-UA52 - Closed Vent Systems and Control Devices  
OP-UA53 - Beryllium Processing Attributes  
OP-UA54 - Mercury Chlor-Alkali Cell Attributes  
OP-UA55 - Transfer System Attributes  
OP-UA56 - Vinyl Chloride Process Attributes  
OP-UA57 - Cleaning/Depainting Operation Attributes  
OP-UA58 - Treatment Process Attributes  
OP-UA59 - Coke By-Product Recovery Plant Attributes  
OP-UA60 - Chemical Manufacturing Process Unit Attributes  
OP-UA61 - Pulp, Paper, or Paperboard Producing Process Attributes  
OP-UA62 - Glycol Dehydration Unit Attributes  
OP-UA63 - Vegetable Oil Production Attributes