

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements	7
New Source Review Authorization Requirements.....	8
Compliance Requirements	9
Risk Management Plan	10
Protection of Stratospheric Ozone	10
Permit Location.....	10
Permit Shield (30 TAC § 122.148)	10
Attachments.....	11
Applicable Requirements Summary.....	12
Additional Monitoring Requirements	171
Permit Shield	189
New Source Review Authorization References	198
Appendix A	203
Acronym List	204

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.

- D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.
 - E. Emission units subject to 40 CFR Part 63, Subparts A, H, DD, and EEE as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, §113.100, §113.130, §113.350, and §113.620 respectively, which incorporates the 40 CFR Part 63 Subpart by reference.
2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
- A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
- A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
 - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
 - (ii) Title 30 TAC § 111.111(a)(1)(E)
 - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)

- (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the “Applicable Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:
- (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
 - (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
 - (3) Records of all observations shall be maintained.
 - (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer’s eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

- (5) Compliance Certification:
- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
 - (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.
- B. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
- C. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).
- D. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
- (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_c) less than the standard effective stack height (H_c), must reduce the allowable emission level by multiplying it by $[h_c/H_c]^2$ as required in 30 TAC § 111.151(b)
 - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)

4. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
 - A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
 - B. Title 40 CFR § 60.8 (relating to Performance Tests)
 - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
 - F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
5. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 61, unless otherwise stated in the applicable subpart:
 - A. Title 40 CFR § 61.05 (relating to Prohibited Activities)
 - B. Title 40 CFR § 61.07 (relating to Application for Approval of Construction or Modification)
 - C. Title 40 CFR § 61.09 (relating to Notification of Start-up)
 - D. Title 40 CFR § 61.10 (relating to Source Reporting and Request Waiver)
 - E. Title 40 CFR § 61.12 (relating to Compliance with Standards and Maintenance Requirements)
 - F. Title 40 CFR § 61.13 (relating to Emissions Tests and Waiver of Emission Tests)
 - G. Title 40 CFR § 61.14 (relating to Monitoring Requirements)
 - H. Title 40 CFR § 61.15 (relating to Modification)
 - I. Title 40 CFR § 61.19 (relating to Circumvention)
6. For facilities where total annual benzene quantity from waste is greater than or equal to 10 megagrams per year and subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:
 - A. Title 40 CFR § 61.342(c)(1)(i) - (iii) (relating to Standards: General)
 - B. Title 40 CFR § 61.342(c)(2) (relating to Standards: General)
 - C. For exempting waste streams:

- (i) Title 40 CFR § 61.342(c)(3)(ii)(A) - (C) (relating to Standards: General)
 - D. Title 40 CFR § 61.342(f)(1), and (2) (relating to Standards: General)
 - E. Title 40 CFR § 61.342(g) (relating to Standards: General)
 - F. Title 40 CFR § 61.350(a) and (b) (relating to Standards: Delay of Repair)
 - G. Title 40 CFR § 61.355(a)(1)(iii), (a)(2), (a)(6), (b), and (c)(1) - (3) (relating to Test Methods, Procedures, and Compliance Provisions)
 - H. Title 40 CFR § 61.355(j) (relating to Test Methods, Procedures, and Compliance Provisions), for calculation procedures
 - I. Title 40 CFR § 61.356(a) (relating to Recordkeeping Requirements)
 - J. Title 40 CFR § 61.356(b), and (b)(1) (relating to Recordkeeping Requirements)
 - K. Title 40 CFR § 61.356(b)(2)(i) - (ii) (relating to Recordkeeping Requirements)
 - L. Title 40 CFR § 61.356(b)(5) (relating to Recordkeeping Requirements)
 - M. Title 40 CFR § 61.356(c) (relating to Recordkeeping Requirements)
 - N. Title 40 CFR § 61.357(a), (d)(1), (d)(2) (d)(6) and (d)(8) (relating to Reporting Requirements)
 - O. Title 40 CFR § 61.357(d)(3) (relating to Reporting Requirements)
7. For facilities with containers subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:
- A. Title 40 CFR § 61.345(a)(1) - (3), (b), and (c) (relating to Standards: Containers)
 - B. Title 40 CFR § 61.355(h) (relating to Test Methods, Procedures and Compliance Provisions)
 - C. Title 40 CFR § 61.356(g) (relating to Recordkeeping Requirements)
 - D. Title 40 CFR § 61.356(h) (relating to Recordkeeping Requirements)
8. For facilities with individual drain systems subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:
- A. Title 40 CFR § 61.346(a)(1)(i)(A), (B), (ii), (2), and (3) (relating to Standards: Individual Drain Systems)
 - B. Title 40 CFR § 61.355(h) (relating to Test Methods, Procedures and Compliance Provisions)
 - C. Title 40 CFR § 61.356(g) (relating to Recordkeeping Requirements)
 - D. Title 40 CFR § 61.356(h) (relating to Recordkeeping Requirements)

9. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
10. For the Off-Site Waste and Recovery Operations specified in 40 CFR Part 63, Subpart DD, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.350 incorporated by reference):
 - A. Requirements specified with reference to 40 CFR Part 63, Subpart A:
 - (i) Title 40 CFR § 63.680(f) for applicability of the General Provisions of Subpart A
 - (ii) Title 40 CFR § 63.696(a) (relating to Recordkeeping Requirements)
 - (iii) Title 40 CFR § 63.697(a) (relating to Reporting Requirements)
 - B. Title 40 CFR § 63.688(b) and (c) (relating to Standards: Containers), for control of air emissions
11. For containers using controls specified in 40 CFR Part 63, Subpart PP, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.470 incorporated by reference):
 - A. Title 40 CFR § 63.923(b)(1) - (3), (c), (d), (d)(1) - (5), (e), and (f), (f)(1) - (4) (relating to Standards - Container Level 2 Controls)
 - B. Title 40 CFR § 63.925(a)(1) - (8), and (b)(1) - (3) (relating to Test Methods and Procedures)
 - C. Title 40 CFR § 63.926(a)(1) - (3) (relating to Inspection and Monitoring Requirements)
12. For miscellaneous chemical process facilities subject to maintenance wastewater requirements as specified in 40 CFR § 63.2485, Table 7, the permit holder shall comply with the requirements of 40 CFR § 63.105 (relating to Maintenance Wastewater Requirements) (Title 30 TAC Chapter 113, Subchapter C, § 113.890 incorporated by reference).

Additional Monitoring Requirements

13. Unless otherwise specified, the permit holder shall comply with the compliance assurance monitoring requirements as specified in the attached "CAM Summary" upon issuance of the permit. In addition, the permit holder shall comply with the following:
 - A. The permit holder shall comply with the terms and conditions contained in 30 TAC § 122.147 (General Terms and Conditions for Compliance Assurance Monitoring).
 - B. The permit holder shall report, consistent with the averaging time identified in the "CAM Summary," deviations as defined by the deviation limit in the "CAM Summary." Any monitoring data below a minimum limit or above a maximum limit, that is collected in accordance with the requirements specified in

40 CFR § 64.7(c), shall be reported as a deviation. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

- C. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time specified in the “CAM Summary,” for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances in order to avoid reporting deviations. All monitoring data shall be collected in accordance with the requirements specified in 40 CFR § 64.7(c).
 - D. The permit holder shall operate the monitoring, identified in the attached “CAM Summary,” in accordance with the provisions of 40 CFR § 64.7.
 - E. The permit holder shall comply with the requirements of 40 CFR § 70.6(a)(3)(ii)(A) and 30 TAC § 122.144(1)(A)-(F) for documentation of all required inspections.
14. The permit holder shall comply with the periodic monitoring requirements as specified in the attached “Periodic Monitoring Summary” upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time specified in the “Periodic Monitoring Summary,” for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

15. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule, standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
- A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
16. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
17. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit

listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).

Compliance Requirements

18. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
19. Use of Discrete Emission Credits to comply with the applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
 - B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122

- (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Risk Management Plan

- 20. For processes subject to 40 CFR Part 68 and specified in 40 CFR § 68.10, the permit holder shall comply with the requirements of the Accidental Release Prevention Provisions in 40 CFR Part 68. The permit holder shall submit to the appropriate agency either a compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR § 68.10(a), or as part of the compliance certification submitted under this permit, a certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of a risk management plan.

Protection of Stratospheric Ozone

- 21. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
 - A. Any on site servicing, maintenance, and repair of fleet vehicle air conditioning using ozone-depleting refrigerants shall be conducted in accordance with 40 CFR Part 82, Subpart B. Permit holders shall ensure that repairs or refrigerant removal are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart B.

Permit Location

- 22. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

- 23. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Applicable Requirements Summary

Unit Summary 13

Applicable Requirements Summary 19

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
04FLR032	FLARES	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
04FLR032	FLARES	N/A	60A-1	40 CFR Part 60, Subpart A	No changing attributes.
04FLR032	FLARES	N/A	63A-1	40 CFR Part 63, Subpart A	No changing attributes.
12BLR001	STATIONARY TURBINES	N/A	60GG-1	40 CFR Part 60, Subpart GG	No changing attributes.
12CAS001	CLOSED VENT SYSTEM AND CONTROL DEVICE	N/A	61FF-2	40 CFR Part 61, Subpart FF	No changing attributes.
12FLR001	FLARES	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
12STK001	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
14FLR001A	FLARES	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
14FLR001A	FLARES	N/A	60A-1	40 CFR Part 60, Subpart A	No changing attributes.
14PRC	INORGANIC CHEMICAL MANUFACTURING PROCESSES	N/A	R7451	30 TAC Chapter 117, Nitric Acid Man.-Gen.	No changing attributes.
14PRC	INORGANIC CHEMICAL MANUFACTURING PROCESSES	N/A	60G	40 CFR Part 60, Subpart G	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
14STK001	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
14STK002	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-2	30 TAC Chapter 111, Visible Emissions	No changing attributes.
15BLR001	TREATMENT PROCESS	N/A	61FF-1	40 CFR Part 61, Subpart FF	No changing attributes.
15BLR001	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63EEE-1	40 CFR Part 63, Subpart EEE	Heating Value = The hazardous waste as-fired heating value is 10,000 Btu/lb or greater.
15BLR001	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63EEE-2	40 CFR Part 63, Subpart EEE	Heating Value = The hazardous waste as-fired heating value is less than 10,000 Btu/lb.
15BLR002	TREATMENT PROCESS	N/A	61FF-1	40 CFR Part 61, Subpart FF	No changing attributes.
15BLR002	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63EEE-1	40 CFR Part 63, Subpart EEE	Heating Value = The hazardous waste as-fired heating value is 10,000 Btu/lb or greater.
15BLR002	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63EEE-2	40 CFR Part 63, Subpart EEE	Heating Value = The hazardous waste as-fired heating value is less than 10,000 Btu/lb.
15BLR003	TREATMENT PROCESS	N/A	61FF-3	40 CFR Part 61, Subpart FF	No changing attributes.
15BLR003	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63EEE-1	40 CFR Part 63, Subpart EEE	Heating Value = The hazardous waste as-fired heating value is 10,000 Btu/lb or greater.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
15BLR003	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63EEE-2	40 CFR Part 63, Subpart EEE	Heating Value = The hazardous waste as-fired heating value is less than 10,000 Btu/lb.
15BLR004	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60D-2	40 CFR Part 60, Subpart D	No changing attributes.
15BLR004	TREATMENT PROCESS	N/A	61FF-3	40 CFR Part 61, Subpart FF	No changing attributes.
15BLR004	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63EEE-1	40 CFR Part 63, Subpart EEE	Heating Value = The hazardous waste as-fired heating value is 10,000 Btu/lb or greater.
15BLR004	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63EEE-2	40 CFR Part 63, Subpart EEE	Heating Value = The hazardous waste as-fired heating value is less than 10,000 Btu/lb.
15CAD001	CLOSED VENT SYSTEM AND CONTROL DEVICE	N/A	61FF-2	40 CFR Part 61, Subpart FF	No changing attributes.
15CAT001	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-2	30 TAC Chapter 111, Visible Emissions	No changing attributes.
15FUG	FUGITIVE EMISSION UNITS	N/A	63H-ALL	40 CFR Part 63, Subpart H	No changing attributes.
15LTR026	LOADING/UNLOADING OPERATIONS	N/A	R5212-1	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
15STK005	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-3	30 TAC Chapter 111, Visible Emissions	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
15STK006	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1-151	30 TAC Chapter 111, Nonagricultural Processes	No changing attributes.
15STK006	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-4	30 TAC Chapter 111, Visible Emissions	No changing attributes.
15VNT005	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5113-2	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas steam emissions of the specific VOCs ethylene, butadiene, isobutylene, styrene, isoprene, propylene, and/or methylstyrene.
15VNT005	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5113-3	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream emissions of the specified classes of VOCs including aldehydes, alcohols, aromatics, ethers, olefins, peroxides, amines, acids, esters, ketones, sulfides, and branched chain hydrocarbons (C8 and above).
15VNT006	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5113-2	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas steam emissions of the specific VOCs ethylene, butadiene, isobutylene, styrene, isoprene, propylene, and/or methylstyrene.
15VNT006	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5113-3	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream emissions of the specified classes of VOCs including aldehydes, alcohols, aromatics, ethers, olefins, peroxides, amines, acids, esters, ketones, sulfides, and branched chain hydrocarbons (C8 and above).

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
17BLR007	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60D-3	40 CFR Part 60, Subpart D	No changing attributes.
17BLR007	TREATMENT PROCESS	N/A	61FF-3	40 CFR Part 61, Subpart FF	No changing attributes.
17BLR007	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63EEE-1	40 CFR Part 63, Subpart EEE	Heating Value = The hazardous waste as-fired heating value is 10,000 Btu/lb or greater.
17BLR007	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63EEE-2	40 CFR Part 63, Subpart EEE	Heating Value = The hazardous waste as-fired heating value is less than 10,000 Btu/lb.
17BLR008	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60D-3	40 CFR Part 60, Subpart D	No changing attributes.
17BLR008	TREATMENT PROCESS	N/A	61FF-3	40 CFR Part 61, Subpart FF	No changing attributes.
17BLR008	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63EEE-1	40 CFR Part 63, Subpart EEE	Heating Value = The hazardous waste as-fired heating value is 10,000 Btu/lb or greater.
17BLR008	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63EEE-2	40 CFR Part 63, Subpart EEE	Heating Value = The hazardous waste as-fired heating value is less than 10,000 Btu/lb.
17FUG	FUGITIVE EMISSION UNITS	N/A	61J-1	40 CFR Part 61, Subpart J	No changing attributes.
17FUG	FUGITIVE EMISSION UNITS	N/A	61V-1	40 CFR Part 61, Subpart V	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
17FUG	FUGITIVE EMISSION UNITS	N/A	63H-ALL	40 CFR Part 63, Subpart H	No changing attributes.
17LTR010	LOADING/UNLOADING OPERATIONS	N/A	R5212-1	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
17STK007	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-4	30 TAC Chapter 111, Visible Emissions	No changing attributes.
17TFX004	STORAGE TANKS/VESSELS	N/A	R5112-4	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
17TFX004	STORAGE TANKS/VESSELS	N/A	61FF-1	40 CFR Part 61, Subpart FF	No changing attributes.
17TFX008	STORAGE TANKS/VESSELS	N/A	R5112-4	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
17TFX008	STORAGE TANKS/VESSELS	N/A	61FF-1	40 CFR Part 61, Subpart FF	No changing attributes.
17TFX009	STORAGE TANKS/VESSELS	N/A	R5112-4	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
17TFX009	STORAGE TANKS/VESSELS	N/A	63DD-2	40 CFR Part 63, Subpart DD	No changing attributes.
17VNT007	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5113-2	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
TS17TFX009	TRANSFER SYSTEM	N/A	63DD-1	40 CFR Part 63, Subpart DD	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
04FLR032	EU	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period, except for upset emissions as provided in §101.11(a).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
04FLR032	CD	60A-1	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1) § 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(i) § 60.18(c)(6) § 60.18(e)	Flares shall comply with paragraphs (c)-(f) of § 60.18.	§ 60.18(d) § 60.18(f)(1) § 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4)	None	None
04FLR032	CD	63A-1	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(i)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
12BLR001	EU	60GG-1	SO ₂	40 CFR Part 60, Subpart GG	§ 60.333(b)	No stationary gas turbine shall burn any fuel which contains sulfur in excess of 0.8% by weight.	§ 60.334(h) [G]§ 60.334(h)(3)	None	None
12CAS001	CD	61FF-2	BENZENE	40 CFR Part 61, Subpart FF	§ 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(ii) § 61.349(b) § 61.349(e) § 61.349(f)	For each closed-vent system and control device used to comply with §§61.343-61.348, properly design, install, operate, and maintain the closed-vent system and control device.	§ 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(d) [G]§ 61.355(h)	§ 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(G) § 61.356(h) § 61.356(j) § 61.356(j)(1)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(g)			§ 61.356(j)(10) § 61.356(j)(2) § 61.356(j)(3)	
12FLR001	EU	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period, except for upset emissions as provided in §101.11(a).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
12STK001	EP	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
14FLR001 A	EU	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period, except for upset emissions as provided in §101.11(a).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
14FLR001 A	CD	60A-1	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1) § 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(i) § 60.18(c)(6) § 60.18(e)	Flares shall comply with paragraphs (c)-(f) of § 60.18.	§ 60.18(d) § 60.18(f)(1) § 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
14PRC	PRO	R7451	NOX	30 TAC Chapter 117, Nitric Acid Man.-Gen.	§ 117.4205	No person shall allow emissions of nitrogen oxides, calculated as nitrogen dioxide, from any nitric acid production unit to exceed 600 parts per million by volume.	** See CAM Summary	None	None
14PRC	PRO	60G	NOX	40 CFR Part 60, Subpart G	§ 60.72(a)(1)	After performance test required by §60.8 is completed, no owner or operator subject shall discharge to atmosphere from any affected facility gases which contain nitrogen oxides (NO2), >3.0 lb/ton of acid produced.	§ 60.73(a) § 60.73(b) § 60.73(c) § 60.73(e) § 60.74(a) [G]§ 60.74(b) [G]§ 60.74(c) § 60.74(d)	§ 60.73(c)	§ 60.73(e)
14PRC	PRO	60G	OPACITY	40 CFR Part 60, Subpart G	§ 60.72(a)(2)	After §60.8 test, no owner or operator shall discharge into the atmosphere from any affected facility any gases which exhibit 10 percent opacity, or greater.	§ 60.74(a) ** See Periodic Monitoring Summary	None	None
14STK001	EP	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
14STK002	EP	R1111-2	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
15BLR001	PRO	61FF-1	BENZENE	40 CFR Part 61, Subpart FF	§ 61.348(a)(1) § 61.348(a)(1)(iii) § 61.348(a)(4) [G]§ 61.348(d)	The owner or operator shall design, install, operate and maintain a treatment process that removes or destroys benzene as specified.	None	§ 61.356(e) § 61.356(e)(1) [G]§ 61.356(i)	None
15BLR001	EU	63EEE-1	DIOXINS/ FURANS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(1)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(l)(2) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(k) § 63.1209(k)(1)(i) § 63.1209(k)(2)(i) § 63.1209(k)(2)(ii)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO emissions in excess of the limits provided by §63.1217(a)(5) for sources not equipped with a dry air pollution control system;	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) [G]§ 63.1207(b)(2) [G]§ 63.1207(b)(3) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) [G]§ 63.1207(f)(1)(vii) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) [G]§ 63.1207(f)(1)(xx) [G]§ 63.1207(f)(1)(xxi)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) [G]§ 63.1207(f)(1)(xx) [G]§ 63.1207(f)(1)(xxi)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1209(k)(3) [G]§ 63.1209(k)(4) § 63.1209(k)(5) [G]§ 63.1209(k)(6) [G]§ 63.1209(k)(7) [G]§ 63.1209(k)(8) [G]§ 63.1209(k)(9) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(g) § 63.1207(g)(1)(i)(A) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(ii) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1208(b)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(8) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(2) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-1	Mercury	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(2)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(B) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	atmosphere combustion gases that contain Hg, except as provided for in paragraph §63.1217 (a)(2)(iii), when you burn hazardous waste with an as-fired heating value 10,000 Btu/lb or greater, emissions in excess of 4.2 x 10 ⁻⁵ lbs Hg attributable to the hazardous waste per million Btu heat input from the hazardous waste on an (not-to-exceed) annual averaging period.	§ 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(2) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii)	[G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(B) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-1	COMBINED METALS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(3)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) § 63.1209(m)(2)(v)(A)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 8.2 x 10 ⁻⁵ lbs combined cadmium and lead emissions attributable to the hazardous waste per million Btu heat input from the hazardous waste on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) [G]§ 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(n)(2)(v)(A)(1) [G]§ 63.1209(n)(2)(v)(A)(2) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		[G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(3) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(n)(2)(v)(A) § 63.1209(n)(2)(v)(A)(1) [G]§ 63.1209(n)(2)(v)(A)(2) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-1	Total Chlorine	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(6)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m)(4) § 63.1209(o) [G]§ 63.1209(o)(1)(ii)(A) [G]§ 63.1209(o)(2) [G]§ 63.1209(o)(3) § 63.1209(o)(4) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	§63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 5.08 x 10-2 lbs combined emissions of hydrogen chloride and chlorine gas attributable to the hazardous waste per million Btu heat input from the hazardous waste.	[G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) [G]§ 63.1208(b)(5)(i) § 63.1208(b)(5)(ii) [G]§ 63.1208(b)(5)(ii)(B) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i)	§ 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxv) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-1	PM	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(7) [G]§ 63.1206(b)(5) § 63.1206(b)(8)(v) § 63.1206(b)(8)(vi) § 63.1206(b)(8)(vii) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain particulate matter, except for an area source as defined under §63.2 or as provided by §63.1217(e), emissions in excess of 80 mg/dscm corrected to 7 % 02.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(C) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iv)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) [G]§ 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxiii) [G]§ 63.1207(f)(1)(xxiv) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxiii) [G]§ 63.1207(f)(1)(xxiv) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iv) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(n)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		[G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(6) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(iii) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-1	POHC	40 CFR Part 63, Subpart EEE	§ 63.1217(c)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v)	For liquid fuel boilers, except as provided in §63.1217(c)(2), you must achieve a DRE of 99.99% for each POHC designated under paragraph §63.1217(c)(3). You must calculate DRE for each POHC using the equation in	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(7)(i) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(c)(3)(i) § 63.1217(c)(3)(ii)	§63.1217(c)(2).	§ 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	§ 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-1	Chromium	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(4)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) [G]§ 63.1209(m)(2)(v)(B)(1) § 63.1209(m)(2)(vi) [G]§ 63.1209(m)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 1.3 x 10 ⁻⁴ lbs chromium emissions attributable to the hazardous waste per million Btu heat input from the hazardous waste.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(4) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(ix) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(m)(2)(v)(B)(1) § 63.1209(m)(2)(vi) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-1	Total Hydrocarbons/CO	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(5)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO in excess of 100 ppmv, over an hourly rolling average (monitored continuously with a CEMs), dry basis and corrected to 7 % O ₂ . If complying with this CO standard rather than the hydrocarbon standard under §63.1217(a)(5)(ii),	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(6) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	hydrocarbons do not exceed 10 ppmv , and must be reported as specified.	§ 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(i) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(i) § 63.1209(a)(2) [G]§ 63.1209(a)(3) [G]§ 63.1209(a)(6) § 63.1209(a)(7) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	§ 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(i) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-2	DIOXINS/ FURANS	40 CFR Part 63, Subpart	§ 63.1217(a)(1)(ii) [G]§ 63.1206(b)(5)	For existing liquid fuel boilers, you must not	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				EEE	[G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(l)(2) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(k) § 63.1209(k)(1)(i) § 63.1209(k)(2)(i) § 63.1209(k)(2)(ii) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(4) § 63.1209(k)(5) [G]§ 63.1209(k)(6) [G]§ 63.1209(k)(7) [G]§ 63.1209(k)(8) [G]§ 63.1209(k)(9) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	discharge or cause to be emitted into the atmosphere combustion gases that contain CO emissions in excess of the limits provided by §63.1217(a)(5) for sources not equipped with a dry air pollution control system;	[G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) [G]§ 63.1207(b)(2) [G]§ 63.1207(b)(3) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(ix) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(g) § 63.1207(g)(1)(i)(A) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(ii) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1208(b)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4)	[G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) [G]§ 63.1207(f)(1)(xxx) [G]§ 63.1207(f)(1)(xxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(2) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(8) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-2	Mercury	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(2)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain Hg, except as provided for in paragraph §63.1217 (a)(2)(iii), when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 19 µg/dscm , corrected to 7 % O ₂ , on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xviii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1209(d) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(C) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(2) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(C) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(B) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-2	COMBINED METALS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(3)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(n)(1) § 63.1209(n)(2)(i) § 63.1209(n)(2)(v)(A) § 63.1209(n)(2)(v)(A)(1) [G]§ 63.1209(n)(2)(v)(A)(3) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	atmosphere combustion gases that contain cadmium and lead combined, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 150 µg/dscm, corrected to 7 % O ₂ , on an (not-to-exceed) annual averaging period.	§ 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) [G]§ 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(3) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f)	[G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m)(2)(v)(A) § 63.1209(m)(2)(v)(A)(1) [G]§ 63.1209(m)(2)(v)(A)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-2	PM	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(7) [G]§ 63.1206(b)(5) § 63.1206(b)(8)(v) § 63.1206(b)(8)(vi) § 63.1206(b)(8)(vii) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain particulate matter, except for an area source as defined under §63.2 or as provided by §63.1217(e), emissions in excess of 80 mg/dscm corrected to 7 % O ₂ .	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) [G]§ 63.1207(f)(1)(xxiv) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iv)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(g)(1)(i)(C) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iv) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(6) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(iii) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-2	POHC	40 CFR Part 63, Subpart EEE	§ 63.1217(c)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i)	For liquid fuel boilers, except as provided in §63.1217(c)(2), you must achieve a DRE of 99.99% for each POHC designated under paragraph §63.1217(c)(3). You	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(7)(i) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(c)(3)(i) § 63.1217(c)(3)(ii)	must calculate DRE for each POHC using the equation in §63.1217(c)(2).	[G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-2	Chromium	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(4)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) § 63.1209(m)(2)(v)(B)(2) § 63.1209(m)(2)(vi) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain chromium, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 370 µg/dscm, corrected to 7 % O ₂ .	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) [G]§ 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(4)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) [G]§ 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) [G]§ 63.1207(f)(1)(vi) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) [G]§ 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) [G]§ 63.1207(f)(1)(vi) [G]§ 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m)(2)(v)(B)(2) § 63.1209(m)(2)(vi) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR001	EU	63EEE-2	Total Hydrocarbons/CO	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(5)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO in excess of 100 ppmv, over an hourly rolling average (monitored continuously with a CEMs), dry basis and corrected to 7 % O ₂ . If complying with this CO	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(6) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(iii)(A)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	standard rather than the hydrocarbon standard under §63.1217(a)(5)(ii), hydrocarbons do not exceed 10 ppmv , and must be reported as specified.	§ 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(i) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(i) § 63.1209(a)(2) [G]§ 63.1209(a)(3) [G]§ 63.1209(a)(6) § 63.1209(a)(7) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(2)(i) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.1212(a)
15BLR002	PRO	61FF-1	BENZENE	40 CFR Part 61, Subpart FF	§ 61.348(a)(1) § 61.348(a)(1)(iii) § 61.348(a)(4) [G]§ 61.348(d)	The owner or operator shall design, install, operate and maintain a treatment process that removes or destroys benzene as specified.	None	§ 61.356(e) § 61.356(e)(1) [G]§ 61.356(i)	None
15BLR002	EU	63EEE-1	DIOXINS/ FURANS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(1)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(l)(2) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(k) § 63.1209(k)(1)(i) § 63.1209(k)(2)(i) § 63.1209(k)(2)(ii) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(4) § 63.1209(k)(5) [G]§ 63.1209(k)(6) [G]§ 63.1209(k)(7) [G]§ 63.1209(k)(8) [G]§ 63.1209(k)(9)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO emissions in excess of the limits provided by §63.1217(a)(5) for sources not equipped with a dry air pollution control system;	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) [G]§ 63.1207(b)(2) [G]§ 63.1207(b)(3) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xx) [G]§ 63.1207(f)(1)(xxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(ii) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) [G]§ 63.1207(f)(1)(xx) [G]§ 63.1207(f)(1)(xxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		[G]§ 63.1207(l)(1) [G]§ 63.1208(b)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(8) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(2) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR002	EU	63EEE-1	Mercury	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(2)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain Hg, except as provided for in paragraph §63.1217 (a)(2)(iii), when you burn hazardous waste with an as-fired heating value	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(B) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	10,000 Btu/lb or greater, emissions in excess of 4.2 x 10 ⁻⁵ lbs Hg attributable to the hazardous waste per million Btu heat input from the hazardous waste on an (not-to-exceed) annual averaging period.	§ 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(2) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(B) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p)	§ 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) [G]§ 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(B) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR002	EU	63EEE-1	COMBINED METALS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(3)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(n)(1) § 63.1209(n)(2)(i) § 63.1209(n)(2)(v)(A) § 63.1209(n)(2)(v)(A)(1) [G]§ 63.1209(n)(2)(v)(A)(2) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 8.2 x 10 ⁻⁵ lbs combined cadmium and lead emissions attributable to the hazardous waste per million Btu heat input from the hazardous waste on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(3) § 63.1208(b)(7) § 63.1208(b)(8)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii)(C) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1211(c)(4) § 63.1217(d)		§ 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m)(2)(v)(A) § 63.1209(m)(2)(v)(A)(1) [G]§ 63.1209(m)(2)(v)(A)(2) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR002	EU	63EEE-1	Total Chlorine	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(6)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 5.08 x 10 ⁻² lbs combined emissions of	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m)(4) § 63.1209(o) [G]§ 63.1209(o)(1)(ii)(A) [G]§ 63.1209(o)(2) [G]§ 63.1209(o)(3) § 63.1209(o)(4) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	hydrogen chloride and chlorine gas attributable to the hazardous waste per million Btu heat input from the hazardous waste.	§ 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) [G]§ 63.1208(b)(5)(i) § 63.1208(b)(5)(ii) [G]§ 63.1208(b)(5)(ii)(B) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxv) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR002	EU	63EEE-1	PM	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(7) [G]§ 63.1206(b)(5) § 63.1206(b)(8)(v) § 63.1206(b)(8)(vi) § 63.1206(b)(8)(vii) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(n)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain particulate matter, except for an area source as defined under §63.2 or as provided by §63.1217(e), emissions in excess of 80 mg/dscm corrected to 7 % 02.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(C) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iv) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(6) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(iii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxiii) [G]§ 63.1207(f)(1)(xxiv) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iv) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR002	EU	63EEE-1	POHC	40 CFR Part 63, Subpart EEE	§ 63.1217(c)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2)	For liquid fuel boilers, except as provided in §63.1217(c)(2), you must achieve a DRE of 99.99% for each POHC designated under paragraph §63.1217(c)(3). You must calculate DRE for each POHC using the equation in §63.1217(c)(2).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1209(b)(1) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(v) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(7)(i) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) [G]§ 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1209(d) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(c)(3)(i) § 63.1217(c)(3)(ii)		§ 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR002	EU	63EEE-1	Chromium	40 CFR Part 63, Subpart	§ 63.1217(a)(4)(ii) [G]§ 63.1206(b)(5)	For existing liquid fuel boilers, you must not	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				EEE	[G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) [G]§ 63.1209(n)(2)(v)(B)(1) § 63.1209(m)(2)(vi) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 1.3 x 10 ⁻⁴ lbs chromium emissions attributable to the hazardous waste per million Btu heat input from the hazardous waste.	[G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(4) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5)	[G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(m)(2)(v)(B)(1) § 63.1209(n)(2)(vi) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR002	EU	63EEE-1	Total Hydrocarbon/CO	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(5)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO in excess of 100 ppmv, over an hourly rolling average (monitored continuously with a CEMs), dry basis and corrected to 7 % O ₂ . If complying with this CO standard rather than the hydrocarbon standard under §63.1217(a)(5)(ii), hydrocarbons do not exceed 10 ppmv , and must be reported as specified.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(6) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(i) § 63.1207(f)(2)(ix)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(i) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(i) § 63.1209(a)(2) [G]§ 63.1209(a)(3) [G]§ 63.1209(a)(6) § 63.1209(a)(7) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR002	EU	63EEE-2	DIOXINS/ FURANS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(1)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO emissions in excess of the limits provided by §63.1217(a)(5) for	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) [G]§ 63.1207(b)(2) [G]§ 63.1207(b)(3) § 63.1207(c)(1) [G]§ 63.1207(c)(2)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(l)(2) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(k) § 63.1209(k)(1)(i) § 63.1209(k)(2)(i) § 63.1209(k)(2)(ii) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(4) § 63.1209(k)(5) [G]§ 63.1209(k)(6) [G]§ 63.1209(k)(7) [G]§ 63.1209(k)(8) [G]§ 63.1209(k)(9) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	sources not equipped with a dry air pollution control system;	[G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(A) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(ii) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1208(b)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3)	[G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) [G]§ 63.1207(f)(1)(xxx) [G]§ 63.1207(f)(1)(xxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(2) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(k)(8) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR002	EU	63EEE-2	Mercury	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(2)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(C) [G]§ 63.1209(l)(1)(ii)(D)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain Hg, except as provided for in paragraph §63.1217 (a)(2)(iii), when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 19 µg/dscm , corrected to 7 % O ₂ , on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) [G]§ 63.1206(c)(7) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		[G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(2) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(C) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(B) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR002	EU	63EEE-2	COMBINED METALS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(3)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain cadmium and lead combined, except for an area source as defined under §63.2, when you burn hazardous waste	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(n)(1) § 63.1209(n)(2)(i) § 63.1209(n)(2)(v)(A) § 63.1209(n)(2)(v)(A)(1) [G]§ 63.1209(n)(2)(v)(A)(3) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 150 µg/dscm, corrected to 7 % O ₂ , on an (not-to-exceed) annual averaging period.	§ 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(3) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m)(2)(v)(A) § 63.1209(m)(2)(v)(A)(1) [G]§ 63.1209(m)(2)(v)(A)(3) § 63.1209(p)	§ 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(q) § 63.1209(r)		§ 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR002	EU	63EEE-2	PM	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(7) [G]§ 63.1206(b)(5) § 63.1206(b)(8)(v) § 63.1206(b)(8)(vi) § 63.1206(b)(8)(vii) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain particulate matter, except for an area source as defined under §63.2 or as provided by §63.1217(e), emissions in excess of 80 mg/dscm corrected to 7 % O ₂ .	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(C) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iv) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(6)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) [G]§ 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxiii) § 63.1207(f)(1)(xxiv) [G]§ 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iv) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(iii) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR002	EU	63EEE-2	POHC	40 CFR Part 63, Subpart EEE	§ 63.1217(c)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k)	For liquid fuel boilers, except as provided in §63.1217(c)(2), you must achieve a DRE of 99.99% for each POHC designated under paragraph §63.1217(c)(3). You must calculate DRE for each POHC using the equation in §63.1217(c)(2).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) § 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(7)(i) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) [G]§ 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(c)(3)(i) § 63.1217(c)(3)(ii)		[G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.1212(a)
15BLR002	EU	63EEE-2	Chromium	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(4)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) § 63.1209(m)(2)(v)(B)(2) § 63.1209(m)(2)(vi) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain chromium, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 370 µg/dscm, corrected to 7 % O2.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(4) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) [G]§ 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) [G]§ 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(x) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xiii) § 63.1207(f)(1)(xiv) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m)(2)(v)(B)(2) § 63.1209(m)(2)(vi) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR002	EU	63EEE-2	Total Hydrocarbon/CO	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(5)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO in excess of 100 ppmv, over an hourly rolling average (monitored continuously with a CEMs), dry basis and corrected to 7 % O ₂ . If complying with this CO standard rather than the hydrocarbon standard under §63.1217(a)(5)(ii), hydrocarbons do not exceed 10 ppmv , and must be reported as specified.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(6) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii) [G]§ 63.1207(f)(1)(ii)(A) [G]§ 63.1207(f)(1)(ii)(B) [G]§ 63.1207(f)(1)(ii)(C) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xviii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(i) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(i) § 63.1209(a)(2) [G]§ 63.1209(a)(3) [G]§ 63.1209(a)(6) § 63.1209(a)(7) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(i) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	PRO	61FF-3	BENZENE	40 CFR Part 61, Subpart FF	§ 61.348(a)(1) § 61.348(a)(1)(iii) § 61.348(a)(4) [G]§ 61.348(d)	The owner or operator shall design, install, operate and maintain a treatment process that removes or destroys benzene as specified.	None	§ 61.356(e) § 61.356(e)(1) [G]§ 61.356(i)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
15BLR003	EU	63EEE-1	DIOXINS/ FURANS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(1)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(l)(2) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(k) § 63.1209(k)(1)(i) § 63.1209(k)(2)(i) § 63.1209(k)(2)(ii) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(4) § 63.1209(k)(5) [G]§ 63.1209(k)(6) [G]§ 63.1209(k)(7) [G]§ 63.1209(k)(8) [G]§ 63.1209(k)(9) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO emissions in excess of the limits provided by §63.1217(a)(5) for sources not equipped with a dry air pollution control system;	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) [G]§ 63.1207(b)(2) [G]§ 63.1207(b)(3) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(A) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(ii) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1208(b)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) [G]§ 63.1207(f)(1)(xxx) [G]§ 63.1207(f)(1)(xxxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(2) § 63.1207(j)(3) § 63.1207(j)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(8) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	EU	63EEE-1	Mercury	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(2)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain Hg, except as provided for in paragraph §63.1217 (a)(2)(iii), when you burn hazardous waste with an as-fired heating value 10,000 Btu/lb or greater, emissions in excess of 4.2 x 10 ⁻⁵ lbs Hg attributable to the hazardous waste per million Btu heat input from the hazardous waste on an (not-to-	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) [G]§ 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(B) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	exceed) annual averaging period.	§ 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(2) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(B) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(B) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	EU	63EEE-1	COMBINED METALS	40 CFR Part 63, Subpart	§ 63.1217(a)(3)(ii) [G]§ 63.1206(b)(5)	For existing liquid fuel boilers, you must not	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				EEE	[G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) § 63.1209(m)(2)(v)(A) § 63.1209(m)(2)(v)(A)(1) [G]§ 63.1209(n)(2)(v)(A)(2) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 8.2 x 10 ⁻⁵ lbs combined cadmium and lead emissions attributable to the hazardous waste per million Btu heat input from the hazardous waste on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(3) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5)	[G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(n)(2)(v)(A) § 63.1209(n)(2)(v)(A)(1) [G]§ 63.1209(n)(2)(v)(A)(2) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	EU	63EEE-1	Total Chlorine	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(6)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 5.08 x 10 ⁻² lbs combined emissions of hydrogen chloride and chlorine gas attributable to the hazardous waste per million Btu heat input from the hazardous waste.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(n)(4) § 63.1209(o) [G]§ 63.1209(o)(1)(ii)(A) [G]§ 63.1209(o)(2) [G]§ 63.1209(o)(3) § 63.1209(o)(4) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) [G]§ 63.1208(b)(5)(i) § 63.1208(b)(5)(ii) [G]§ 63.1208(b)(5)(ii)(B) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(1)(xxv) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	EU	63EEE-1	PM	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(7) [G]§ 63.1206(b)(5) § 63.1206(b)(8)(v)	For existing liquid fuel boilers, you must not discharge or cause to be	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1206(b)(8)(vi) § 63.1206(b)(8)(vii) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	emitted into the atmosphere combustion gases that contain particulate matter, except for an area source as defined under §63.2 or as provided by §63.1217(e), emissions in excess of 80 mg/dscm corrected to 7 % O ₂ .	[G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(C) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iv) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(6) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(iii) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d)	[G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) [G]§ 63.1207(f)(1)(xxiv) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iv) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	EU	63EEE-1	POHC	40 CFR Part 63, Subpart EEE	§ 63.1217(c)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4)	For liquid fuel boilers, except as provided in §63.1217(c)(2), you must achieve a DRE of 99.99% for each POHC designated under paragraph §63.1217(c)(3). You must calculate DRE for each POHC using the equation in §63.1217(c)(2).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(7)(i) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1217(c)(3)(i) § 63.1217(c)(3)(ii)		[G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	EU	63EEE-1	Chromium	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(4)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(n) § 63.1209(n)(1) § 63.1209(n)(2)(i) [G]§ 63.1209(n)(2)(v)(B)(1) § 63.1209(n)(2)(vi) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 1.3 x 10 ⁻⁴ lbs chromium emissions attributable to the hazardous waste per million Btu heat input from the hazardous waste.	§ 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(4) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(n)(2)(v)(B)(1) § 63.1209(n)(2)(vi) § 63.1209(p)	§ 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(q) § 63.1209(r)		§ 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	EU	63EEE-1	Total Hydrocarbon/CO	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(5)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO in excess of 100 ppmv, over an hourly rolling average (monitored continuously with a CEMs), dry basis and corrected to 7 % O ₂ . If complying with this CO standard rather than the hydrocarbon standard under §63.1217(a)(5)(ii), hydrocarbons do not exceed 10 ppmv , and must be reported as specified.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(6) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(i) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(i) § 63.1209(a)(2) [G]§ 63.1209(a)(3) [G]§ 63.1209(a)(6) § 63.1209(a)(7) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	EU	63EEE-2	DIOXINS/ FURANS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(1)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(l)(2)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO emissions in excess of the limits provided by §63.1217(a)(5) for sources not equipped with a dry air pollution control system;	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) [G]§ 63.1207(b)(2) [G]§ 63.1207(b)(3) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(k) § 63.1209(k)(1)(i) § 63.1209(k)(2)(i) § 63.1209(k)(2)(ii) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(4) § 63.1209(k)(5) [G]§ 63.1209(k)(6) [G]§ 63.1209(k)(7) [G]§ 63.1209(k)(8) [G]§ 63.1209(k)(9) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(A) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(ii) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1208(b)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(8) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) [G]§ 63.1207(f)(1)(xx) [G]§ 63.1207(f)(1)(xxi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(2) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	EU	63EEE-2	Mercury	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(2)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(C) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain Hg, except as provided for in paragraph §63.1217 (a)(2)(iii), when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 19 µg/dscm , corrected to 7 % O ₂ , on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(2) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) [G]§ 63.1207(m)(1) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(C) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(B) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	EU	63EEE-2	COMBINED METALS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(3)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain cadmium and lead combined, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 150 µg/dscm, corrected to 7 % O ₂ , on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) § 63.1209(m)(2)(v)(A) § 63.1209(m)(2)(v)(A)(1) [G]§ 63.1209(m)(2)(v)(A)(3) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(3) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m)(2)(v)(A) § 63.1209(m)(2)(v)(A)(1) [G]§ 63.1209(m)(2)(v)(A)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
15BLR003	EU	63EEE-2	PM	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(7) [G]§ 63.1206(b)(5) § 63.1206(b)(8)(v) § 63.1206(b)(8)(vi) § 63.1206(b)(8)(vii) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain particulate matter, except for an area source as defined under §63.2 or as provided by §63.1217(e), emissions in excess of 80 mg/dscmm corrected to 7 % 02.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(C) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iv) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(6) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(iii) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxiii) § 63.1207(f)(1)(xxiv) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iv) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	EU	63EEE-2	POHC	40 CFR Part 63, Subpart EEE	§ 63.1217(c)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q)	For liquid fuel boilers, except as provided in §63.1217(c)(2), you must achieve a DRE of 99.99% for each POHC designated under paragraph §63.1217(c)(3). You must calculate DRE for each POHC using the equation in §63.1217(c)(2).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(7)(i) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(c)(3)(i) § 63.1217(c)(3)(ii)		§ 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	EU	63EEE-2	Chromium	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(4)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain chromium, except for an	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) § 63.1209(m)(2)(v)(B)(2) § 63.1209(m)(2)(vi) [G]§ 63.1209(m)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 370 µg/dscm, corrected to 7 % 02.	[G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(4) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i)	[G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxiii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(n)(2)(v)(B)(2) § 63.1209(n)(2)(vi) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR003	EU	63EEE-2	Total Hydrocarbon/CO	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(5)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO in excess of 100 ppmv, over an hourly rolling average (monitored continuously with a CEMs), dry basis and corrected to 7 % O ₂ . If complying with this CO standard rather than the hydrocarbon standard under §63.1217(a)(5)(ii), hydrocarbons do not exceed 10 ppmv , and must be reported as specified.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(6) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xiii) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(i) § 63.1207(g)(2)(v)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xiii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(i) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(i) § 63.1209(a)(2) [G]§ 63.1209(a)(3) [G]§ 63.1209(a)(6) § 63.1209(a)(7) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	60D-2	PM	40 CFR Part 60, Subpart D	§ 60.42(a)(1)	On/after the §60.8 tests, no affected facility shall emit gases containing particulate matter in excess of 43 ng/J heat input (0.10 lb/MMBtu) derived from fossil fuel or fossil fuel and wood residue.	§ 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(2) [G]§ 60.46(d)(1) § 60.46(d)(2) [G]§ 60.46(d)(3) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
15BLR004	EU	60D-2	PM (OPACITY)	40 CFR Part 60, Subpart D	§ 60.42(a)(2)	On/after the performance tests of §60.8, no affected	§ 60.45(a) § 60.45(c) § 60.45(c)(5)	None	§ 60.45(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						facility shall emit gases exhibiting greater than 20% opacity except for one six-minute period per hour of not more than 27% opacity.	§ 60.45(g) § 60.45(g)(1) § 60.46(a) § 60.46(b)(3)		
15BLR004	EU	60D-2	SO ₂	40 CFR Part 60, Subpart D	§ 60.40(a)	The affected facility burns fuel (such as only gaseous fuels) that has no specific SO ₂ emission requirements.	§ 60.45(b)(2) § 60.45(b)(4)	None	None
15BLR004	EU	60D-2	NO _x	40 CFR Part 60, Subpart D	§ 60.44(a)(1)	On/after the §60.8 tests, no affected facility shall emit gases containing NO _x , expressed as NO ₂ , in excess of 86 ng/J heat input (0.2 lb/MMBtu) derived from gaseous fossil fuel.	§ 60.45(a) § 60.45(b)(3) § 60.45(c) § 60.45(c)(1) § 60.45(c)(2) § 60.45(c)(5) [G]§ 60.45(e) [G]§ 60.45(f) § 60.45(g) § 60.45(g)(3) § 60.45(g)(3)(i) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(5) [G]§ 60.46(d)(1) § 60.46(d)(5) § 60.46(d)(6) § 60.46(d)(7)	None	§ 60.45(g)
15BLR004	PRO	61FF-3	BENZENE	40 CFR Part 61, Subpart FF	§ 61.348(a)(1) § 61.348(a)(1)(iii) § 61.348(a)(4) [G]§ 61.348(d)	The owner or operator shall design, install, operate and maintain a treatment process that removes or destroys benzene as specified.	None	§ 61.356(e) § 61.356(e)(1) [G]§ 61.356(i)	None
15BLR004	EU	63EEE-1	DIOXINS/ FURANS	40 CFR Part 63, Subpart	§ 63.1217(a)(1)(ii) [G]§ 63.1206(b)(5)	For existing liquid fuel boilers, you must not	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				EEE	[G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(l)(2) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(k) § 63.1209(k)(1)(i) § 63.1209(k)(2)(i) § 63.1209(k)(2)(ii) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(4) § 63.1209(k)(5) [G]§ 63.1209(k)(6) [G]§ 63.1209(k)(7) [G]§ 63.1209(k)(8) [G]§ 63.1209(k)(9) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	discharge or cause to be emitted into the atmosphere combustion gases that contain CO emissions in excess of the limits provided by §63.1217(a)(5) for sources not equipped with a dry air pollution control system;	[G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) [G]§ 63.1207(b)(2) [G]§ 63.1207(b)(3) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) [G]§ 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(g) § 63.1207(g)(1)(i)(A) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(ii) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1208(b)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4)	[G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xiv) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) [G]§ 63.1207(f)(1)(xx) [G]§ 63.1207(f)(1)(xxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(2) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(8) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-1	Mercury	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(2)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain Hg, except as provided for in paragraph §63.1217 (a)(2)(iii), when you burn hazardous waste with an as-fired heating value 10,000 Btu/lb or greater, emissions in excess of 4.2 x 10 ⁻⁵ lbs Hg attributable to the hazardous waste per million Btu heat input from the hazardous waste on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) [G]§ 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xviii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1209(d) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(B) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(2) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(B) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(B) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-1	COMBINED METALS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(3)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(n)(1) § 63.1209(n)(2)(i) § 63.1209(n)(2)(v)(A) § 63.1209(n)(2)(v)(A)(1) [G]§ 63.1209(n)(2)(v)(A)(2) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 8.2 x 10 ⁻⁵ lbs combined cadmium and lead emissions attributable to the hazardous waste per million Btu heat input from the hazardous waste on an (not-to-exceed) annual averaging period.	§ 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(3) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f)	[G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m)(2)(v)(A) § 63.1209(m)(2)(v)(A)(1) [G]§ 63.1209(m)(2)(v)(A)(2) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-1	Total Chlorine	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(6)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m)(4) § 63.1209(o)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 5.08 x 10 ⁻² lbs combined emissions of hydrogen chloride and chlorine gas attributable to the hazardous waste per million Btu heat input from the hazardous waste.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxv) § 63.1207(f)(1)(xxvi)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1209(o)(1)(ii)(A) [G]§ 63.1209(o)(2) [G]§ 63.1209(o)(3) § 63.1209(o)(4) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(g)(1)(ii) § 63.1207(g)(2)(iii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) [G]§ 63.1208(b)(5)(i) § 63.1208(b)(5)(ii) [G]§ 63.1208(b)(5)(ii)(B) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-1	PM	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(7) [G]§ 63.1206(b)(5) § 63.1206(b)(8)(v) § 63.1206(b)(8)(vi) § 63.1206(b)(8)(vii)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(3) § 63.1207(a)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	gases that contain particulate matter, except for an area source as defined under §63.2 or as provided by §63.1217(e), emissions in excess of 80 mg/dscm corrected to 7 % 02.	§ 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(i)(C) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iv) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(6) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(iii) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i)	[G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxiii) § 63.1207(f)(1)(xxiii) [G]§ 63.1207(f)(1)(xxiv) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iv) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-1	POHC	40 CFR Part 63, Subpart EEE	§ 63.1217(c)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(c)(3)(i) § 63.1217(c)(3)(ii)	For liquid fuel boilers, except as provided in §63.1217(c)(2), you must achieve a DRE of 99.99% for each POHC designated under paragraph §63.1217(c)(3). You must calculate DRE for each POHC using the equation in §63.1217(c)(2).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) [G]§ 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) § 63.1207(f)(1)(iii) § 63.1207(f)(1)(iii)(A) § 63.1207(f)(1)(iii)(B) § 63.1207(f)(1)(iii)(C) § 63.1207(f)(1)(iii)(D) § 63.1207(f)(1)(iii)(E) § 63.1207(f)(1)(iii)(F) § 63.1207(f)(1)(iii)(G) § 63.1207(f)(1)(iii)(H) § 63.1207(f)(1)(iii)(I) § 63.1207(f)(1)(iii)(J) § 63.1207(f)(1)(iii)(K) § 63.1207(f)(1)(iii)(L) § 63.1207(f)(1)(iii)(M) § 63.1207(f)(1)(iii)(N) § 63.1207(f)(1)(iii)(O) § 63.1207(f)(1)(iii)(P) § 63.1207(f)(1)(iii)(Q) § 63.1207(f)(1)(iii)(R) § 63.1207(f)(1)(iii)(S) § 63.1207(f)(1)(iii)(T) § 63.1207(f)(1)(iii)(U) § 63.1207(f)(1)(iii)(V) § 63.1207(f)(1)(iii)(W) § 63.1207(f)(1)(iii)(X) § 63.1207(f)(1)(iii)(Y) § 63.1207(f)(1)(iii)(Z)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(7)(i) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-1	Chromium	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(4)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater,	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(iii)(A)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) [G]§ 63.1209(m)(2)(v)(B)(1) § 63.1209(m)(2)(vi) [G]§ 63.1209(m)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	emissions in excess of 1.3 x 10 ⁻⁴ lbs chromium emissions attributable to the hazardous waste per million Btu heat input from the hazardous waste.	§ 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(4) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(m)(2)(v)(B)(1) § 63.1209(m)(2)(vi) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-1	Total Hydrocarbon/ CO	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(5)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO in excess of 100 ppmv, over an hourly rolling average (monitored continuously with a CEMs), dry basis and corrected to 7 % O ₂ . If complying with this CO standard rather than the hydrocarbon standard under §63.1217(a)(5)(ii), hydrocarbons do not exceed 10 ppmv , and must be reported as specified.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(6) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(xvii) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(i) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(i) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(a)(1)(i) § 63.1209(a)(2) [G]§ 63.1209(a)(3) [G]§ 63.1209(a)(6) § 63.1209(a)(7) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-2	DIOXINS/ FURANS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(1)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(l)(2) § 63.1209(c)(1) [G]§ 63.1209(c)(2)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO emissions in excess of the limits provided by §63.1217(a)(5) for sources not equipped with a dry air pollution control system;	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) [G]§ 63.1207(b)(2) [G]§ 63.1207(b)(3) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) [G]§ 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(ix)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1206(c)(6)(vii) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(q) § 63.1211(b)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1209(d) § 63.1209(i) § 63.1209(k) § 63.1209(k)(1)(i) § 63.1209(k)(2)(i) § 63.1209(k)(2)(ii) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(4) § 63.1209(k)(5) [G]§ 63.1209(k)(6) [G]§ 63.1209(k)(7) [G]§ 63.1209(k)(8) [G]§ 63.1209(k)(9) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(A) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(ii) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1208(b)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(8) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) [G]§ 63.1207(f)(1)(xx) [G]§ 63.1207(f)(1)(xxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(2) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-2	Mercury	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(2)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(C) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain Hg, except as provided for in paragraph §63.1217 (a)(2)(iii), when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 19 µg/dscm , corrected to 7 % O ₂ , on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(2) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(iii)(A) [G]§ 63.1209(l)(1)(ii)(C) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(B) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-2	COMBINED METALS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(3)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain cadmium and lead combined, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 150 µg/dscm, corrected to 7 % O ₂ , on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1209(d) § 63.1209(i) § 63.1209(n) § 63.1209(m)(1) § 63.1209(m)(2)(i) § 63.1209(m)(2)(v)(A) § 63.1209(m)(2)(v)(A)(1) [G]§ 63.1209(m)(2)(v)(A)(3) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(3) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m)(2)(v)(A) § 63.1209(m)(2)(v)(A)(1) [G]§ 63.1209(m)(2)(v)(A)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-2	PM	40 CFR Part 63, Subpart	§ 63.1217(a)(7) [G]§ 63.1206(b)(5)	For existing liquid fuel boilers, you must not	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				EEE	§ 63.1206(b)(8)(v) § 63.1206(b)(8)(vi) § 63.1206(b)(8)(vii) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	discharge or cause to be emitted into the atmosphere combustion gases that contain particulate matter, except for an area source as defined under §63.2 or as provided by §63.1217(e), emissions in excess of 80 mg/dscm corrected to 7 % O ₂ .	[G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(C) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iv) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(6) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(iii) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4)	[G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) [G]§ 63.1207(f)(1)(ix) § 63.1207(f)(1)(x) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xiii) § 63.1207(f)(1)(xiv) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xix) [G]§ 63.1207(f)(1)(xx) § 63.1207(f)(1)(xxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxiii) [G]§ 63.1207(f)(1)(xxiv) § 63.1207(f)(1)(xxv) § 63.1207(f)(2)(iv) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-2	POHC	40 CFR Part 63, Subpart EEE	§ 63.1217(c)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2)	For liquid fuel boilers, except as provided in §63.1217(c)(2), you must achieve a DRE of 99.99% for each POHC designated under paragraph §63.1217(c)(3). You must calculate DRE for each POHC using the equation in §63.1217(c)(2).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(7)(i) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) [G]§ 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xiii) § 63.1207(f)(1)(xiv) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1211(c)(4) § 63.1217(c)(3)(i) § 63.1217(c)(3)(ii)		§ 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-2	Chromium	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(4)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain chromium, except for an area source as defined under §63.2, when you	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) § 63.1209(m)(2)(v)(B)(2) § 63.1209(m)(2)(vi) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 370 µg/dscm, corrected to 7 % O ₂ .	[G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(4) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m)(2)(v)(B)(2) § 63.1209(m)(2)(vi)	[G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15BLR004	EU	63EEE-2	Total Hydrocarbon/ CO	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(5)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO in excess of 100 ppmv, over an hourly rolling average (monitored continuously with a CEMs), dry basis and corrected to 7 % O ₂ . If complying with this CO standard rather than the hydrocarbon standard under §63.1217(a)(5)(ii), hydrocarbons do not exceed 10 ppmv , and must be reported as specified.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(6) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(i) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(i) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(i) § 63.1209(a)(2) [G]§ 63.1209(a)(3) [G]§ 63.1209(a)(6) § 63.1209(a)(7) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
15CAD001	CD	61FF-2	BENZENE	40 CFR Part 61, Subpart FF	§ 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(ii) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	For each closed-vent system and control device used to comply with §§61.343-61.348, properly design, install, operate, and maintain the closed-vent system and control device.	§ 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(d) [G]§ 61.355(h)	§ 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(G) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(10) § 61.356(j)(2) § 61.356(j)(3)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
15CAT001	EP	R1111-2	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.162(e) § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h)	Equipment that is in organic HAP service less than 300 hours per year is excluded from the requirements of §§63.163 - 63.174 and §63.178 if it is identified as required in §63.181(j).	[G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(i) § 63.181(j)	[G]§ 63.182(a) [G]§ 63.182(b)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.164 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Compressors. §63.164(a)-(i)	[G]§ 63.164 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.165 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief device in gas/vapor service. §63.165(a)-(d)	[G]§ 63.165 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.166 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Sampling connection systems. §63.166(a)-(c)	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pumps in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Valves in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Connectors in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Agitators in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Instrumentation systems. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief devices in liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.170 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Surge control vessels and bottom receivers.	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.173 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Agitators gas/vapor service and in light liquid service. §63.173(a)-(j).	[G]§ 63.173 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.174 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Connectors in gas/vapor service and in light liquid service. §63.174(a)-(j)	[G]§ 63.174 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.163 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.176	Standards: Pumps in light liquid service. §63.163(a)-(j)	[G]§ 63.163 [G]§ 63.176 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(3) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								§ 63.181(h)(8)	
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.167 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Open-ended valves or lines. §63.167(a)-(e).	[G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
15FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.168 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Valves in gas/vapor service and in light liquid service. §63.168(a)-(j)	[G]§ 63.168 [G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
15LTR026	EU	R5212-1	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(b)(2) § 115.212(b)(2) § 115.214(b)(1)(B) § 115.214(b)(1)(D) § 115.214(b)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division except as specified.	§ 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
15STK005	EP	R1111-3	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	§ 111.111(a)(1)(D) [G]§ 111.111(a)(1)(F)	§ 111.111(a)(1)(C) § 111.111(a)(1)(D)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
15STK006	EP	R1-151	PM	30 TAC Chapter 111, Nonagricultural Processes	§ 111.151(a) § 111.151(c)	No person may cause, suffer, allow, or permit emissions of particulate matter from any source to exceed the allowable rates specified in Table 1 as follows, except as provided by §111.153 of this title (relating to Emissions Limits for Steam Generators).	** See Periodic Monitoring Summary	None	None
15STK006	EP	R1111-4	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	§ 111.111(a)(1)(D) [G]§ 111.111(a)(1)(F)	§ 111.111(a)(1)(C) § 111.111(a)(1)(D)	None
15VNT005	EP	R5113-2	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(b) § 115.121(b) § 115.122(b)(3)	For all persons in Nueces and Victoria Counties, any vent gas streams affected by §115.121(b) of this title must be controlled properly with a control efficiency of at least 90% or to a VOC concentration of no more than 20 ppmv (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2) ** See CAM Summary	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
15VNT005	EP	R5113-3	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(b) § 115.121(b) § 115.122(b)(3)	For all persons in Nueces and Victoria Counties, any vent gas streams affected by §115.121(b) of this title	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2) ** See CAM Summary	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						must be controlled properly with a control efficiency of at least 90% or to a VOC concentration of no more than 20 ppmv (on a dry basis corrected to 3.0% oxygen for combustion devices).			
15VNT006	EP	R5113-2	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(b) § 115.121(b) § 115.122(b)(3)	For all persons in Nueces and Victoria Counties, any vent gas streams affected by §115.121(b) of this title must be controlled properly with a control efficiency of at least 90% or to a VOC concentration of no more than 20 ppmv (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2) ** See CAM Summary	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
15VNT006	EP	R5113-3	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(b) § 115.121(b) § 115.122(b)(3)	For all persons in Nueces and Victoria Counties, any vent gas streams affected by §115.121(b) of this title must be controlled properly with a control efficiency of at least 90% or to a VOC concentration of no more than 20 ppmv (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2) ** See CAM Summary	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
17BLR007	EU	60D-3	PM	40 CFR Part 60, Subpart D	§ 60.42(a)(1)	On/after the §60.8 tests, no affected facility shall emit gases containing particulate matter in excess of 43 ng/J heat input (0.10 lb/MMBtu) derived from fossil fuel or fossil fuel and wood residue.	§ 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(2) [G]§ 60.46(d)(1) § 60.46(d)(2) [G]§ 60.46(d)(3) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
17BLR007	EU	60D-3	PM (OPACITY)	40 CFR Part 60, Subpart D	§ 60.42(a)(2)	On/after the performance tests of §60.8, no affected facility shall emit gases exhibiting greater than 20% opacity except for one six-minute period per hour of not more than 27% opacity.	§ 60.45(a) § 60.45(c) § 60.45(c)(5) § 60.45(g) § 60.45(g)(1) § 60.46(a) § 60.46(b)(3)	None	§ 60.45(g)
17BLR007	EU	60D-3	SO ₂	40 CFR Part 60, Subpart D	§ 60.40(a)	The affected facility burns fuel (such as only gaseous fuels) that has no specific SO ₂ emission requirements.	§ 60.45(a) § 60.45(c) § 60.45(c)(1) § 60.45(c)(2) § 60.45(c)(5) [G]§ 60.45(e) [G]§ 60.45(f) § 60.45(g) § 60.45(g)(2)(i)	None	§ 60.45(g)
17BLR007	EU	60D-3	NO _x	40 CFR Part 60, Subpart D	§ 60.44(a)(1)	On/after the §60.8 tests, no affected facility shall emit gases containing NO _x , expressed as NO ₂ , in excess of 86 ng/J heat input (0.2 lb/MMBtu) derived from gaseous fossil fuel.	§ 60.45(b)(3) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(5) [G]§ 60.46(d)(1) § 60.46(d)(5) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							Summary		
17BLR007	PRO	61FF-3	BENZENE	40 CFR Part 61, Subpart FF	§ 61.348(a)(1) § 61.348(a)(1)(iii) § 61.348(a)(4) [G]§ 61.348(d)	The owner or operator shall design, install, operate and maintain a treatment process that removes or destroys benzene as specified.	None	§ 61.356(e) § 61.356(e)(1) [G]§ 61.356(i)	None
17BLR007	EU	63EEE-1	DIOXINS/ FURANS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(1)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(l)(2) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(k) § 63.1209(k)(1)(i) § 63.1209(k)(2)(i) § 63.1209(k)(2)(ii) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(4) § 63.1209(k)(5) [G]§ 63.1209(k)(6) [G]§ 63.1209(k)(7) [G]§ 63.1209(k)(8) [G]§ 63.1209(k)(9)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO emissions in excess of the limits provided by §63.1217(a)(5) for sources not equipped with a dry air pollution control system;	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) [G]§ 63.1207(b)(2) [G]§ 63.1207(b)(3) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(A) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(ii) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xxv) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) [G]§ 63.1207(f)(1)(xxx) [G]§ 63.1207(f)(1)(xxxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		[G]§ 63.1207(l)(1) [G]§ 63.1208(b)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(8) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(2) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR007	EU	63EEE-1	Mercury	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(2)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain Hg, except as provided for in paragraph §63.1217 (a)(2)(iii), when you burn hazardous waste with an as-fired heating value	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(B) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	10,000 Btu/lb or greater, emissions in excess of 4.2 x 10 ⁻⁵ lbs Hg attributable to the hazardous waste per million Btu heat input from the hazardous waste on an (not-to-exceed) annual averaging period.	§ 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(2) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(B) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p)	§ 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) [G]§ 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(B) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR007	EU	63EEE-1	COMBINED METALS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(3)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) [G]§ 63.1209(i) § 63.1209(m) § 63.1209(n)(1) § 63.1209(n)(2)(i) § 63.1209(n)(2)(v)(A) § 63.1209(n)(2)(v)(A)(1) [G]§ 63.1209(n)(2)(v)(A)(2) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 8.2 x 10 ⁻⁵ lbs combined cadmium and lead emissions attributable to the hazardous waste per million Btu heat input from the hazardous waste on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(3) § 63.1208(b)(7) § 63.1208(b)(8)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii)(C) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1211(c)(4) § 63.1217(d)		§ 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m)(2)(v)(A) § 63.1209(m)(2)(v)(A)(1) [G]§ 63.1209(m)(2)(v)(A)(2) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR007	EU	63EEE-1	Total Chlorine	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(6)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 5.08 x 10 ⁻² lbs combined emissions of	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m)(4) § 63.1209(o) [G]§ 63.1209(o)(1)(ii)(A) [G]§ 63.1209(o)(2) [G]§ 63.1209(o)(3) § 63.1209(o)(4) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	hydrogen chloride and chlorine gas attributable to the hazardous waste per million Btu heat input from the hazardous waste.	§ 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) [G]§ 63.1208(b)(5)(i) § 63.1208(b)(5)(ii) [G]§ 63.1208(b)(5)(ii)(B) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxv) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR007	EU	63EEE-1	PM	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(7) [G]§ 63.1206(b)(5) § 63.1206(b)(8)(v) § 63.1206(b)(8)(vi) § 63.1206(b)(8)(vii) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain particulate matter, except for an area source as defined under §63.2 or as provided by §63.1217(e), emissions in excess of 80 mg/dscm corrected to 7 % O ₂ .	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(C) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iv) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(6) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(iii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxiii) [G]§ 63.1207(f)(1)(xxiv) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iv) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR007	EU	63EEE-1	POHC	40 CFR Part 63, Subpart EEE	§ 63.1217(c)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2)	For liquid fuel boilers, except as provided in §63.1217(c)(2), you must achieve a DRE of 99.99% for each POHC designated under paragraph §63.1217(c)(3). You must calculate DRE for each POHC using the equation in §63.1217(c)(2).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1209(b)(1) § 63.1207(f)(1)(ix) [G]§ 63.1207(f)(1)(vii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(7)(i) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1209(d) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(c)(3)(i) § 63.1217(c)(3)(ii)		§ 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR007	EU	63EEE-1	Chromium	40 CFR Part 63, Subpart	§ 63.1217(a)(4)(ii) [G]§ 63.1206(b)(5)	For existing liquid fuel boilers, you must not	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				EEE	[G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) [G]§ 63.1209(n)(2)(v)(B)(1) § 63.1209(m)(2)(vi) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 1.3 x 10 ⁻⁴ lbs chromium emissions attributable to the hazardous waste per million Btu heat input from the hazardous waste.	[G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(4) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5)	[G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(m)(2)(v)(B)(1) § 63.1209(m)(2)(vi) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR007	EU	63EEE-1	Total Hydrocarbons/CO	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(5)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO in excess of 100 ppmv, over an hourly rolling average (monitored continuously with a CEMs), dry basis and corrected to 7 % O ₂ . If complying with this CO standard rather than the hydrocarbon standard under §63.1217(a)(5)(ii), hydrocarbons do not exceed 10 ppmv , and must be reported as specified.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(6) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(i) § 63.1207(f)(2)(ix)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(i) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(i) § 63.1209(a)(2) [G]§ 63.1209(a)(3) [G]§ 63.1209(a)(6) § 63.1209(a)(7) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR007	EU	63EEE-2	DIOXINS/ FURANS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(1)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO emissions in excess of the limits provided by §63.1217(a)(5) for	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) [G]§ 63.1207(b)(2) [G]§ 63.1207(b)(3) § 63.1207(c)(1) [G]§ 63.1207(c)(2)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(l)(2) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(k) § 63.1209(k)(1)(i) § 63.1209(k)(2)(i) § 63.1209(k)(2)(ii) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(4) § 63.1209(k)(5) [G]§ 63.1209(k)(6) [G]§ 63.1209(k)(7) [G]§ 63.1209(k)(8) [G]§ 63.1209(k)(9) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	sources not equipped with a dry air pollution control system;	[G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(A) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(ii) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1208(b)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3)	[G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) [G]§ 63.1207(f)(1)(xxx) [G]§ 63.1207(f)(1)(xxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(2) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(k)(8) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR007	EU	63EEE-2	Mercury	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(2)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(C) [G]§ 63.1209(l)(1)(ii)(D)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain Hg, except as provided for in paragraph §63.1217 (a)(2)(iii), when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 19 µg/dscm , corrected to 7 % O ₂ , on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		[G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(2) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(C) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(B) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR007	EU	63EEE-2	COMBINED METALS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(3)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain cadmium and lead combined, except for an area source as defined under §63.2, when you burn hazardous waste	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(n)(1) § 63.1209(n)(2)(i) § 63.1209(n)(2)(v)(A) § 63.1209(n)(2)(v)(A)(1) [G]§ 63.1209(n)(2)(v)(A)(3) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 150 µg/dscm, corrected to 7 % O ₂ , on an (not-to-exceed) annual averaging period.	§ 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(3) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m)(2)(v)(A) § 63.1209(m)(2)(v)(A)(1) [G]§ 63.1209(m)(2)(v)(A)(3) § 63.1209(p)	§ 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(q) § 63.1209(r)		§ 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR007	EU	63EEE-2	PM	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(7) [G]§ 63.1206(b)(5) § 63.1206(b)(8)(v) § 63.1206(b)(8)(vi) § 63.1206(b)(8)(vii) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain particulate matter, except for an area source as defined under §63.2 or as provided by §63.1217(e), emissions in excess of 80 mg/dscm corrected to 7 % O ₂ .	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(C) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iv) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(6)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) [G]§ 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxiii) § 63.1207(f)(1)(xxiv) [G]§ 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iv) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(iii) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR007	EU	63EEE-2	POHC	40 CFR Part 63, Subpart EEE	§ 63.1217(c)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k)	For liquid fuel boilers, except as provided in §63.1217(c)(2), you must achieve a DRE of 99.99% for each POHC designated under paragraph §63.1217(c)(3). You must calculate DRE for each POHC using the equation in §63.1217(c)(2).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) § 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(7)(i) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii) [G]§ 63.1207(f)(1)(ii)(A) [G]§ 63.1207(f)(1)(ii)(B) [G]§ 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) [G]§ 63.1209(b)(1) [G]§ 63.1209(c)(2)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(c)(3)(i) § 63.1217(c)(3)(ii)		[G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.1212(a)
17BLR007	EU	63EEE-2	Chromium	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(4)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) § 63.1209(m)(2)(v)(B)(2) § 63.1209(m)(2)(vi) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain chromium, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 370 µg/dscm, corrected to 7 % O2.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(4) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) [G]§ 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) [G]§ 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(x) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xiii) § 63.1207(f)(1)(xiv) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m)(2)(v)(B)(2) § 63.1209(m)(2)(vi) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR007	EU	63EEE-2	Total Hydrocarbons/CO	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(5)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO in excess of 100 ppmv, over an hourly rolling average (monitored continuously with a CEMs), dry basis and corrected to 7 % O ₂ . If complying with this CO standard rather than the hydrocarbon standard under §63.1217(a)(5)(ii), hydrocarbons do not exceed 10 ppmv , and must be reported as specified.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(6) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xviii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(i) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(i) § 63.1209(a)(2) [G]§ 63.1209(a)(3) [G]§ 63.1209(a)(6) § 63.1209(a)(7) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(i) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR008	EU	60D-3	PM	40 CFR Part 60, Subpart D	§ 60.42(a)(1)	On/after the §60.8 tests, no affected facility shall emit gases containing particulate matter in excess of 43 ng/J heat input (0.10 lb/MMBtu)	§ 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(2) [G]§ 60.46(d)(1) § 60.46(d)(2) [G]§ 60.46(d)(3)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						derived from fossil fuel or fossil fuel and wood residue.	§ 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary		
17BLR008	EU	60D-3	PM (OPACITY)	40 CFR Part 60, Subpart D	§ 60.42(a)(2)	On/after the performance tests of §60.8, no affected facility shall emit gases exhibiting greater than 20% opacity except for one six-minute period per hour of not more than 27% opacity.	§ 60.45(a) § 60.45(c) § 60.45(c)(5) § 60.45(g) § 60.45(g)(1) § 60.46(a) § 60.46(b)(3)	None	§ 60.45(g)
17BLR008	EU	60D-3	SO ₂	40 CFR Part 60, Subpart D	§ 60.40(a)	The affected facility burns fuel (such as only gaseous fuels) that has no specific SO ₂ emission requirements.	§ 60.45(a) § 60.45(c) § 60.45(c)(1) § 60.45(c)(2) § 60.45(c)(5) [G]§ 60.45(e) [G]§ 60.45(f) § 60.45(g) § 60.45(g)(2)(i)	None	§ 60.45(g)
17BLR008	EU	60D-3	NO _x	40 CFR Part 60, Subpart D	§ 60.44(a)(1)	On/after the §60.8 tests, no affected facility shall emit gases containing NO _x , expressed as NO ₂ , in excess of 86 ng/J heat input (0.2 lb/MMBtu) derived from gaseous fossil fuel.	§ 60.45(b)(3) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(5) [G]§ 60.46(d)(1) § 60.46(d)(5) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
17BLR008	PRO	61FF-3	BENZENE	40 CFR Part 61, Subpart FF	§ 61.348(a)(1) § 61.348(a)(1)(iii) § 61.348(a)(4) [G]§ 61.348(d)	The owner or operator shall design, install, operate and maintain a treatment process that	None	§ 61.356(e) § 61.356(e)(1) [G]§ 61.356(i)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						removes or destroys benzene as specified.			
17BLR008	EU	63EEE-1	DIOXINS/ FURANS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(1)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(l)(2) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(k) § 63.1209(k)(1)(i) § 63.1209(k)(2)(i) § 63.1209(k)(2)(ii) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(4) § 63.1209(k)(5) [G]§ 63.1209(k)(6) [G]§ 63.1209(k)(7) [G]§ 63.1209(k)(8) [G]§ 63.1209(k)(9) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO emissions in excess of the limits provided by §63.1217(a)(5) for sources not equipped with a dry air pollution control system;	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) [G]§ 63.1207(b)(2) [G]§ 63.1207(b)(3) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iii)(A) § 63.1207(f)(1)(iii)(B) § 63.1207(f)(1)(iii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) [G]§ 63.1207(f)(1)(xx) [G]§ 63.1207(f)(1)(xxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1208(b)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) [G]§ 63.1207(f)(1)(xx) [G]§ 63.1207(f)(1)(xxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(8) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR008	EU	63EEE-1	Mercury	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(2)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain Hg, except as provided for in paragraph §63.1217 (a)(2)(iii), when you burn hazardous waste with an as-fired heating value 10,000 Btu/lb or greater, emissions in excess of 4.2 x 10 ⁻⁵ lbs Hg attributable to the hazardous waste per million Btu heat input	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(B) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	from the hazardous waste on an (not-to-exceed) annual averaging period.	§ 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(2) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(B) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(B) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
17BLR008	EU	63EEE-1	COMBINED METALS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(3)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) § 63.1209(m)(2)(v)(A) § 63.1209(m)(2)(v)(A)(1) [G]§ 63.1209(m)(2)(v)(A)(2) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 8.2 x 10 ⁻⁵ lbs combined cadmium and lead emissions attributable to the hazardous waste per million Btu heat input from the hazardous waste on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(3) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m)(2)(v)(A) § 63.1209(n)(2)(v)(A)(1) [G]§ 63.1209(n)(2)(v)(A)(2) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR008	EU	63EEE-1	Total Chlorine	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(6)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 5.08 x 10 ⁻² lbs combined emissions of hydrogen chloride and chlorine gas attributable to the hazardous waste per million Btu heat input from the hazardous waste.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) [G]§ 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1209(d) § 63.1209(i) § 63.1209(n)(4) § 63.1209(o) [G]§ 63.1209(o)(1)(ii)(A) [G]§ 63.1209(o)(2) [G]§ 63.1209(o)(3) § 63.1209(o)(4) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) [G]§ 63.1208(b)(5)(i) § 63.1208(b)(5)(ii) [G]§ 63.1208(b)(5)(ii)(B) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxv) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR008	EU	63EEE-1	PM	40 CFR Part	§ 63.1217(a)(7)	For existing liquid fuel	[G]§ 63.1206(b)(12)	§ 63.1206(b)(11)	§ 63.1206(b)(11)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				63, Subpart EEE	[G]§ 63.1206(b)(5) § 63.1206(b)(8)(v) § 63.1206(b)(8)(vi) § 63.1206(b)(8)(vii) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain particulate matter, except for an area source as defined under §63.2 or as provided by §63.1217(e), emissions in excess of 80 mg/dscm corrected to 7 % 02.	[G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(C) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iv) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(6) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(iii) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5)	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxiii) [G]§ 63.1207(f)(1)(xxiv) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iv) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR008	EU	63EEE-1	POHC	40 CFR Part 63, Subpart EEE	§ 63.1217(c)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1)	For liquid fuel boilers, except as provided in §63.1217(c)(2), you must achieve a DRE of 99.99% for each POHC designated under paragraph §63.1217(c)(3). You must calculate DRE for each POHC using the equation in §63.1217(c)(2).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(7)(i) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(ii)(D) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(c)(3)(i) § 63.1217(c)(3)(ii)		§ 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR008	EU	63EEE-1	Chromium	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(4)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, except for an area source as defined under	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(n)(1) § 63.1209(n)(2)(i) [G]§ 63.1209(n)(2)(v)(B)(1) § 63.1209(m)(2)(vi) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	§63.2, when you burn hazardous waste with an as-fired heating value of 10,000 Btu/lb or greater, emissions in excess of 1.3 x 10 ⁻⁴ lbs chromium emissions attributable to the hazardous waste per million Btu heat input from the hazardous waste.	[G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(4) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(n)(2)(v)(B)(1)	§ 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(i) § 63.1209(a)(2) [G]§ 63.1209(a)(3) [G]§ 63.1209(a)(6) § 63.1209(a)(7) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR008	EU	63EEE-2	DIOXINS/ FURANS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(1)(ii) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO emissions in excess of the limits provided by §63.1217(a)(5) for sources not equipped with a dry air pollution control system;	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) [G]§ 63.1207(b)(2) [G]§ 63.1207(b)(3) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) [G]§ 63.1207(f)(1)(iii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(iii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1207(l)(1) [G]§ 63.1207(l)(2) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(k) § 63.1209(k)(1)(i) § 63.1209(k)(2)(i) § 63.1209(k)(2)(ii) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(4) § 63.1209(k)(5) [G]§ 63.1209(k)(6) [G]§ 63.1209(k)(7) [G]§ 63.1209(k)(8) [G]§ 63.1209(k)(9) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)		§ 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(A) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(ii) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1208(b)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(8) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	§ 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) [G]§ 63.1207(f)(1)(xx) [G]§ 63.1207(f)(1)(xxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(2) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR008	EU	63EEE-2	Mercury	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(2)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(C) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain Hg, except as provided for in paragraph §63.1217 (a)(2)(iii), when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 19 µg/dscm , corrected to 7 % O ₂ , on an (not-to-exceed) annual averaging period.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(2) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii)(C) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xxiii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(l) § 63.1209(l)(1)(ii) § 63.1209(l)(1)(ii)(A) [G]§ 63.1209(l)(1)(ii)(C) [G]§ 63.1209(l)(1)(ii)(D) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(B) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR008	EU	63EEE-2	COMBINED METALS	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(3)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain cadmium and lead combined, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 150 µg/dscm, corrected to 7 % O ₂ , on an (not-to-exceed)	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(n)(1) § 63.1209(n)(2)(i) § 63.1209(n)(2)(v)(A) § 63.1209(n)(2)(v)(A)(1) [G]§ 63.1209(n)(2)(v)(A)(3) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	annual averaging period.	§ 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(3) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(n)(2)(v)(A) § 63.1209(n)(2)(v)(A)(1) [G]§ 63.1209(n)(2)(v)(A)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.1211(d) § 63.1212(a)
17BLR008	EU	63EEE-2	PM	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(7) [G]§ 63.1206(b)(5) § 63.1206(b)(8)(v) § 63.1206(b)(8)(vi) § 63.1206(b)(8)(vii) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain particulate matter, except for an area source as defined under §63.2 or as provided by §63.1217(e), emissions in excess of 80 mg/dscm corrected to 7 % 02.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(C) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iv) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(6) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(iii) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) [G]§ 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xiii) [G]§ 63.1207(f)(1)(xxiv) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iv) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(m)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR008	EU	63EEE-2	POHC	40 CFR Part 63, Subpart EEE	§ 63.1217(c)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) [G]§ 63.1209(j)	For liquid fuel boilers, except as provided in §63.1217(c)(2), you must achieve a DRE of 99.99% for each POHC designated under paragraph §63.1217(c)(3). You must calculate DRE for each POHC using the equation in §63.1217(c)(2).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(7)(i) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(c)(3)(i) § 63.1217(c)(3)(ii)		§ 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR008	EU	63EEE-2	Chromium	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(4)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) § 63.1209(m)(1) § 63.1209(m)(2)(i) § 63.1209(m)(2)(v)(B)(2) § 63.1209(m)(2)(vi) [G]§ 63.1209(m)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	gases that contain chromium, except for an area source as defined under §63.2, when you burn hazardous waste with an as-fired heating value less than 10,000 Btu/lb, emissions in excess of 370 µg/dscm, corrected to 7 % O ₂ .	§ 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(4) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i)	[G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	[G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(n)(2)(v)(B)(2) § 63.1209(n)(2)(vi) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17BLR008	EU	63EEE-2	Total Hydrocarbons/CO	40 CFR Part 63, Subpart EEE	§ 63.1217(a)(5)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1217(d)	For existing liquid fuel boilers, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO in excess of 100 ppmv, over an hourly rolling average (monitored continuously with a CEMs), dry basis and corrected to 7 % O ₂ . If complying with this CO standard rather than the hydrocarbon standard under §63.1217(a)(5)(ii), hydrocarbons do not exceed 10 ppmv , and must be reported as specified.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(6) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) [G]§ 63.1207(f)(1)(vii) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(2)(vi) § 63.1207(g)(1)(ii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) [G]§ 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(i) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1207(g)(2)(i) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(i) § 63.1209(a)(2) [G]§ 63.1209(a)(3) [G]§ 63.1209(a)(6) § 63.1209(a)(7) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
17FUG	EU	61J-1	BENZENE	40 CFR Part 61, Subpart J	§ 61.112(a) § 61.112(b)	Each owner or operator subject to this subpart shall comply with the requirements of 40 CFR 61, Subpart V - National Emission Standard for Equipment Leaks (Fugitive Emission Sources).	None	None	None
17FUG	EU	61V-1	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-2 § 61.242-1(a)	Comply with standards for pumps. §61.242-	[G]§ 61.242-2 [G]§ 61.245(b)	[G]§ 61.246(a) [G]§ 61.246(b)	[G]§ 61.247(a) [G]§ 61.247(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	2(a)-(g)	[G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(h) [G]§ 61.246(i) § 61.246(j)	§ 61.247(c) [G]§ 61.247(e)
17FUG	EU	61V-1	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-4 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for pressure relief devices in gas/vapor service. §61.242-4(a)-(c)	[G]§ 61.242-4 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
17FUG	EU	61V-1	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-7 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10 [G]§ 61.243-1 [G]§ 61.243-2	Comply with standards for valves. §61.242-7(a)-(h)	[G]§ 61.242-7 [G]§ 61.243-1 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(f) [G]§ 61.246(g) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) § 61.247(d) [G]§ 61.247(e)
17FUG	EU	61V-1	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-8 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for flanges and other connectors. § 61.242-8(a)-(d)	[G]§ 61.242-8 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
17FUG	EU	61V-1	VHAP	40 CFR Part 61, Subpart V	§ 61.242-11(d) § 60.18 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) § 61.242-11(e) § 61.242-11(m)	Flares shall be used to comply with this subpart shall comply with the requirements of §60.18.	[G]§ 61.245(d) [G]§ 61.245(e)	[G]§ 61.246(a) [G]§ 61.246(d) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.162(e) § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h)	Equipment that is in organic HAP service less than 300 hours per year is excluded from the requirements of	[G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(i) § 63.181(j)	[G]§ 63.182(a) [G]§ 63.182(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						§§63.163 - 63.174 and §63.178 if it is identified as required in §63.181(j).			
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.164 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Compressors. §63.164(a)-(i)	[G]§ 63.164 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.165 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief device in gas/vapor service. §63.165(a)-(d)	[G]§ 63.165 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.166 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Sampling connection systems. §63.166(a)-(c)	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pumps in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Valves in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Connectors in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Agitators in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Instrumentation systems. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief devices in liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.170 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Surge control vessels and bottom receivers.	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.173 § 63.162(a)	Standards: Agitators gas/vapor service and in	[G]§ 63.173 [G]§ 63.180(b)	§ 63.181(a) [G]§ 63.181(b)	[G]§ 63.182(a) [G]§ 63.182(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	light liquid service. §63.173(a)-(j).	[G]§ 63.180(d)	§ 63.181(c) [G]§ 63.181(d)	§ 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.174 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Connectors in gas/vapor service and in light liquid service. §63.174(a)-(j)	[G]§ 63.174 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.163 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.176	Standards: Pumps in light liquid service. §63.163(a)-(j)	[G]§ 63.163 [G]§ 63.176 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(3) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7) § 63.181(h)(8)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.167 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Open-ended valves or lines. §63.167(a)-(e).	[G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.168 § 63.162(a) § 63.162(c)	Standards: Valves in gas/vapor service and in light liquid service.	[G]§ 63.168 [G]§ 63.175 [G]§ 63.180(b)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	§63.168(a)-(j)	[G]§ 63.180(d)	[G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7)	[G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
17LTR010	EU	R5212-1	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(b)(2) § 115.212(b)(2) § 115.214(b)(1)(B) § 115.214(b)(1)(D) § 115.214(b)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division except as specified.	§ 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
17STK007	EP	R1111-4	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	§ 111.111(a)(1)(D) [G]§ 111.111(a)(1)(F)	§ 111.111(a)(1)(C) § 111.111(a)(1)(D)	None
17TFX004	EU	R5112-4	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.116(b)(2) § 60.18	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	[G]§ 115.117	§ 115.118(b)(4) § 115.118(b)(5)	None
17TFX004	EU	61FF-1	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 60.18 § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent	§ 60.18(f)(2) § 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(3) § 61.356(d)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(B) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	system that routes all organic vapors vented from the tank to a control device.	§ 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) § 61.354(f)(1) [G]§ 61.355(h)	§ 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(i) § 61.356(j)(7)	
17TFX008	EU	R5112-4	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.116(b)(2) § 60.18	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	[G]§ 115.117	§ 115.118(b)(4) § 115.118(b)(5)	None
17TFX008	EU	61FF-1	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 60.18 § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(B) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 60.18(f)(2) § 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) § 61.354(f)(1) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(i) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
17TFX009	EU	R5112-4	VOC	30 TAC Chapter 115,	§ 115.112(b)(1) § 115.116(b)(2)	Tanks shall not store VOC unless the required	[G]§ 115.117	§ 115.118(b)(4) § 115.118(b)(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Storage of VOCs	§ 60.18	pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).			
17TFX009	EU	63DD-2	112(B) HAPS	40 CFR Part 63, Subpart DD	§ 63.685(c)(2)(ii) § 63.11(b) § 63.685(g) [G]§ 63.685(g)(1) [G]§ 63.685(g)(2) § 63.693(b)(1) § 63.693(b)(2) [G]§ 63.693(b)(3) § 63.693(c)(1)(i) § 63.693(c)(2) § 63.693(c)(2)(ii) § 63.693(h)(1) [G]§ 63.693(h)(2) [G]§ 63.695(b)(4) § 63.695(c)(1)(iii) [G]§ 63.695(c)(3)	As an alternative, an owner or operator may control air emissions from the tank in accordance with the provisions for Tank Level 2 controls as specified in §63.685(d).	§ 63.685(c)(1) § 63.693(b)(4)(i) § 63.693(b)(5) § 63.693(c)(2)(ii) § 63.693(h)(3) [G]§ 63.694(j) [G]§ 63.694(k) [G]§ 63.695(b)(3) [G]§ 63.695(b)(4) § 63.695(c)(1) § 63.695(c)(1)(i) § 63.695(c)(1)(ii) § 63.695(c)(1)(ii)(A) § 63.695(c)(1)(ii)(B) § 63.695(c)(1)(ii)(C) § 63.695(c)(1)(ii)(D) § 63.695(c)(1)(iv) [G]§ 63.695(c)(3) [G]§ 63.695(f)	§ 63.693(b)(4)(i) § 63.693(h)(3) [G]§ 63.694(j) § 63.695(c)(1) § 63.695(c)(1)(ii)(C) § 63.695(c)(1)(iv) [G]§ 63.695(f) § 63.696(b) [G]§ 63.696(e) [G]§ 63.696(g) [G]§ 63.696(h)	§ 63.693(b)(4)(i) [G]§ 63.697(b)
17VNT007	EP	R5113-2	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(b) § 115.121(b) § 115.122(b)(3)	For all persons in Nueces and Victoria Counties, any vent gas streams affected by §115.121(b) of this title must be controlled properly with a control efficiency of at least 90% or to a VOC concentration of no more than 20 ppmv (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2) ** See CAM Summary	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition I.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TS17TFX009	EU	63DD-1	112(B) HAPS	40 CFR Part 63, Subpart DD	§ 63.689(c)(2)	For each affected transfer system that is not an individual drain system, the transfer system shall consist of continuous hard-piping, and permanently or semipermanently sealed joints or seams.	None	None	None

Additional Monitoring Requirements

Compliance Assurance Monitoring Summary 172
Periodic Monitoring Summary 178

CAM Summary

Unit/Group/Process Information	
ID No.: 14PRC	
Control Device ID No.: 14STK001	Control Device Type: Selective Non-Catalytic Reduction (SCR)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Nitric Acid Man.-Gen.	SOP Index No.: R7451
Pollutant: NOX	Main Standard: 117.4205
Monitoring Information	
Indicator: Nitrogen Oxides Concentration	
Minimum Frequency: four times per hour	
Averaging Period: one hour	
Deviation Limit: Maximum concentration in exhaust of 600 parts per million by volume, calculated as nitrogen dioxide.	
CAM Text: Use a continuous emission monitoring system (CEMS) to measure and record the concentration of nitrogen oxides and either oxygen or carbon dioxide in the exhaust stream of the control device. The CEMS shall be operated in accordance with the monitoring requirements of 40 CFR § 60.13 and the performance specifications of 40 CFR Part 60, Appendix B. NOx Emissions shall be corrected/calculated in units of the underlying applicable emission limitation (grams per horsepower-hour, pounds per MMBtu, pounds per hour).	

CAM Summary

Unit/Group/Process Information	
ID No.: 15VNT005	
Control Device ID No.: 15BLR001	Control Device Type: Steam Generating Unit (Boiler)/Process Heater (Design heat input is greater than or equal to 44MW)
Control Device ID No.: 15BLR002	Control Device Type: Steam Generating Unit (Boiler)/Process Heater (Design heat input is greater than or equal to 44MW)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Vent Gas Controls	SOP Index No.: R5113-2
Pollutant: VOC	Main Standard: § 115.122(b)
Monitoring Information	
Indicator: Period of Operation	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Any period of operation of the steam generating unit that is not recorded when the vent from 15VNT005 is routed to the steam generating unit.	
CAM Text: Monitor and record the periods of operation of the steam generating units or process heater. The records must be readily available for inspection.	

CAM Summary

Unit/Group/Process Information	
ID No.: 15VNT005	
Control Device ID No.: 15BLR001	Control Device Type: Steam Generating Unit (Boiler)/Process Heater (Design heat input is greater than or equal to 44MW)
Control Device ID No.: 15BLR002	Control Device Type: Steam Generating Unit (Boiler)/Process Heater (Design heat input is greater than or equal to 44MW)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Vent Gas Controls	SOP Index No.: R5113-3
Pollutant: VOC	Main Standard: § 115.122(b)
Monitoring Information	
Indicator: Period of Operation	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Any period of operation of the steam generating unit that is not recorded when the vent from 15VNT005 is routed to the steam generating unit.	
CAM Text: Monitor and record the periods of operation of the steam generating units or process heater. The records must be readily available for inspection.	

CAM Summary

Unit/Group/Process Information	
ID No.: 15VNT006	
Control Device ID No.: 15BLR003	Control Device Type: Steam Generating Unit (Boiler)/Process Heater (Design heat input is greater than or equal to 44MW)
Control Device ID No.: 15BLR004	Control Device Type: Steam Generating Unit (Boiler)/Process Heater (Design heat input is greater than or equal to 44MW)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Vent Gas Controls	SOP Index No.: R5113-2
Pollutant: VOC	Main Standard: § 115.122(b)
Monitoring Information	
Indicator: Period of Operation	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Any period of operation of the steam generating unit that is not recorded when the vent from 15VNT006 is routed to the steam generating unit.	
CAM Text: Monitor and record the periods of operation of the steam generating units or process heater. The records must be readily available for inspection.	

CAM Summary

Unit/Group/Process Information	
ID No.: 15VNT006	
Control Device ID No.: 15BLR003	Control Device Type: Steam Generating Unit (Boiler)/Process Heater (Design heat input is greater than or equal to 44MW)
Control Device ID No.: 15BLR004	Control Device Type: Steam Generating Unit (Boiler)/Process Heater (Design heat input is greater than or equal to 44MW)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Vent Gas Controls	SOP Index No.: R5113-3
Pollutant: VOC	Main Standard: § 115.122(b)
Monitoring Information	
Indicator: Period of Operation	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Any period of operation of the steam generating unit that is not recorded when the vent from 15VNT006 is routed to the steam generating unit.	
CAM Text: Monitor and record the periods of operation of the steam generating units or process heater. The records must be readily available for inspection.	

CAM Summary

Unit/Group/Process Information	
ID No.: 17VNT007	
Control Device ID No.: 17BLR007	Control Device Type: Steam Generating Unit (Boiler)/Process Heater (Design heat input is greater than or equal to 44MW)
Control Device ID No.: 17BLR008	Control Device Type: Steam Generating Unit (Boiler)/Process Heater (Design heat input is greater than or equal to 44MW)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Vent Gas Controls	SOP Index No.: R5113-2
Pollutant: VOC	Main Standard: § 115.122(b)
Monitoring Information	
Indicator: Period of Operation	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Any period of operation of the steam generating unit that is not recorded when the vent from 17VNT007 is routed to the steam generating unit.	
CAM Text: Monitor and record the periods of operation of the steam generating units or process heater. The records must be readily available for inspection.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 12STK001	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 14PRC	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart G	SOP Index No.: 60G
Pollutant: OPACITY	Main Standard: § 60.72(a)(2)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: Once per month	
Averaging Period: Six-minutes	
Deviation Limit: Maximum Opacity = 10%	
Periodic Monitoring Text: No visible emissions. If visible emissions are observed the permit holder shall either report a deviation or determine visible emissions consistent with Test Method 22 or Test Method 9.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 14STK001	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: n/a	
Deviation Limit: No visible emissions. If visible emissions are observed the permit holder shall either report a deviation or determine opacity consistent with Test Method 22 or Test Method 9. Opacity shall not exceed 15% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If a Test Method 9 is performed, the opacity limit is the corresponding opacity limit associated with the particulate matter standard in the underlying applicable requirement. If there is no corresponding opacity limit in the underlying applicable requirement, the maximum opacity will be established using the most recent performance test. If the result of the Test Method 9 is opacity above the corresponding opacity limit (associated with the particulate matter standard in the underlying applicable requirement or as identified as a result of a previous performance test to establish the maximum opacity limit), the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 14STK002	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-2
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: n/a	
Deviation Limit: No visible emissions. If visible emissions are observed the permit holder shall either report a deviation or determine opacity consistent with Test Method 22 or Test Method 9. Opacity shall not exceed 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If a Test Method 9 is performed, the opacity limit is the corresponding opacity limit associated with the particulate matter standard in the underlying applicable requirement. If there is no corresponding opacity limit in the underlying applicable requirement, the maximum opacity will be established using the most recent performance test. If the result of the Test Method 9 is opacity above the corresponding opacity limit (associated with the particulate matter standard in the underlying applicable requirement or as identified as a result of a previous performance test to establish the maximum opacity limit), the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 15BLR004	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60D-2
Pollutant: PM	Main Standard: § 60.42(a)(1)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: Six times per minute	
Averaging Period: Six minutes	
Deviation Limit: Exhibit greater than 20% opacity except for one six minute period per hour not greater than 27% opacity.	
<p>Periodic Monitoring Text: Measure and record the opacity with a continuous opacity monitoring system (COMS). The COMS shall be operated in accordance with 40 CFR § 60.13, and shall complete six monitoring cycles each minute and record the average opacity at least once every six minutes.. Any opacity readings that are above the opacity limit from the underlying applicable requirement and occur during periods when (1) neither boiler is in startup, shutdown, or malfunction mode, and (2) 100% gaseous fossil fuel is the only fuel being fired in either boiler (i.e., when both boilers are burning 100% fossil fuel or one boiler is burning 100% fossil fuel and the other is not operating) shall be considered and reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 15CAT001	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-2
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 15STK006	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Nonagricultural Processes	SOP Index No.: R1-151
Pollutant: PM	Main Standard: § 111.151(a)
Monitoring Information	
Indicator: PM Emission Rate	
Minimum Frequency: Once per month	
Averaging Period: hourly	
Deviation Limit: A particulate matter (PM) emission rate greater than 154.5 lb/hr at maximum firing rates. At less than maximum firing rates, a PM emission rate greater than the limit that is determined from the equations in 30 TAC 111.151.	
<p>Periodic Monitoring Text: Maximum hourly average particulate matter (PM) emission rates will be calculated from the quarterly ash analysis for each liquid fuel and the flow rates of the liquid waste fuels and natural gas fired in Boilers 3 and 4. Records of hourly waste stream flow rates and each quarterly liquid fuel ash analysis will be maintained. A quarterly ash analysis will be performed for each liquid waste stream burned in the Boilers 3 and 4. Particulate matter emissions resulting from natural gas combustion will be based on the natural gas flow rates and the EPA AP-42 total particulate matter emission factor for natural gas combustion in Table 1.4-2 (7/98).</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 17BLR007	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60D-3
Pollutant: PM	Main Standard: § 60.42(a)(1)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: Six times per minute	
Averaging Period: Six minutes	
Deviation Limit: Exhibit greater than 20% opacity, except for one six minute period per hour not greater than 27% opacity, during periods when (1) neither boiler is in startup, shutdown, or malfunction mode and (2) 100% gaseous fossil fuel is the only fuel being fire	
<p>Periodic Monitoring Text: Measure and record the opacity with a continuous opacity monitoring system (COMS), which is located on a common stack (17STK007). The COMS shall be operated in accordance with 40 CFR § 60.13, and shall complete six monitoring cycles each minute and record the average opacity at least once every six minutes. Any opacity readings that are above the opacity limit from the underlying applicable requirement and occur during periods when (1) neither boiler is in startup, shutdown, or malfunction mode, and (2) 100% gaseous fossil fuel is the only fuel being fired in either boiler (i.e., when both boilers are burning 100% fossil fuel or one boiler is burning 100% fossil fuel and the other is not operating) shall be considered and reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 17BLR007	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60D-3
Pollutant: NO _x	Main Standard: § 60.44(a)(1)
Monitoring Information	
Indicator: NOX Concentration	
Minimum Frequency: Quarterly, provided the boiler operates at least 180 hours on 100% fossil fuels during the quarter	
Averaging Period: N/A	
Deviation Limit: Greater than 86 ng/J heat input (0.20 lb/MMBtu) while firing 100% gaseous fossil fuel.	
<p>Periodic Monitoring Text: For any calendar quarter during which the boiler operates at least 180 hours on 100% fossil fuels: Monitor and record the nitrogen oxide concentration in the exhaust stream using a portable analyzer. The portable analyzer shall be operated in accordance with the Environmental Protection Agency's, Office of Air Quality Planning & Standards, Emission Measurement Center Conditional Test Method - Determination of Oxygen, Carbon Monoxide and Oxides of Nitrogen from Stationary Sources for Periodic Monitoring (Portable electrochemical Analyzer Procedure) [CTM-034] (September 8, 1999). NOx emissions shall be corrected/calculated in units of the underlying applicable emission limitation, i.e. pounds per MMBtu.</p>	
<p>Date and time of periods during the calendar quarter when only 100% fossil fuel being burned in the boilers shall be recorded at least once every hour.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 17BLR008	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60D-3
Pollutant: PM	Main Standard: § 60.42(a)(1)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: Six times per minute	
Averaging Period: Six minutes	
Deviation Limit: Exhibit greater than 20% opacity, except for one six minute period per hour not greater than 27% opacity, during periods when (1) neither boiler is in startup, shutdown, or malfunction mode and (2) 100% gaseous fossil fuel is the only fuel being fire	
<p>Periodic Monitoring Text: Measure and record the opacity with a continuous opacity monitoring system (COMS), which is located on a common stack (17STK007). The COMS shall be operated in accordance with 40 CFR § 60.13, and shall complete six monitoring cycles each minute and record the average opacity at least once every six minutes. Any opacity readings that are above the opacity limit from the underlying applicable requirement and occur during periods when (1) neither boiler is in startup, shutdown, or malfunction mode, and (2) 100% gaseous fossil fuel is the only fuel being fired in either boiler (i.e., when both boilers are burning 100% fossil fuel or one boiler is burning 100% fossil fuel and the other is not operating) shall be considered and reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 17BLR008	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60D-3
Pollutant: NO _x	Main Standard: § 60.44(a)(1)
Monitoring Information	
Indicator: NOX Concentration	
Minimum Frequency: Quarterly, provided the boiler operates at least 180 hours on 100% fossil fuels during the quarter	
Averaging Period: N/A	
Deviation Limit: Greater than 86 ng/J heat input (0.20 lb/MMBtu) while firing 100% gaseous fossil fuel	
<p>Periodic Monitoring Text: For any calendar quarter during which the boiler operates at least 180 hours on 100% fossil fuels: Monitor and record the nitrogen oxide concentration in the exhaust stream using a portable analyzer. The portable analyzer shall be operated in accordance with the Environmental Protection Agency's, Office of Air Quality Planning & Standards, Emission Measurement Center Conditional Test Method - Determination of Oxygen, Carbon Monoxide and Oxides of Nitrogen from Stationary Sources for Periodic Monitoring (Portable electrochemical Analyzer Procedure) [CTM-034] (September 8, 1999). NOx emissions shall be corrected/calculated in units of the underlying applicable emission limitation, i.e. pounds per MMBtu.</p>	
<p>Date and time of periods during the calendar quarter when only 100% fossil fuel being burned in the boilers shall be recorded at least once every hour.</p>	

Permit Shield

Permit Shield 190

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
12BLR001	N/A	30 TAC Chapter 117, Subchapter B	The site is not located in the applicable ozone nonattainment areas.
12BLR001	N/A	40 CFR Part 63, Subpart YYYY	The turbine is an existing stationary combustion turbine with no applicable requirements. The construction date was on or before January 14, 2003.
12FLR001	N/A	40 CFR Part 60, Subpart A	Flare not used to comply with 40 CFR 60 or 61.
12FLR001	N/A	40 CFR Part 63, Subpart A	Flare not used to comply with 40 CFR 63.
12STK001	N/A	30 TAC Chapter 115, Vent Gas Controls	The vent stream is combustion unit exhaust and the combustion unit is not used as a control device for a vent stream originating from a noncombustion source subject to 30 TAC Chapter 115, Subchapter B, Division 2.
12TFX026	N/A	30 TAC Chapter 115, Storage of VOCs	Capacity is less than 1,000 gallons.
12TFX026	N/A	40 CFR Part 60, Subpart K	Constructed after May 19, 1978.
12TFX026	N/A	40 CFR Part 60, Subpart Ka	Constructed after July 23, 1984.
12TFX026	N/A	40 CFR Part 60, Subpart Kb	Capacity less than 75 cubic meters (19,813 gallons).
14FLR001A	N/A	40 CFR Part 63, Subpart A	Flare not used to comply with 40 CFR 63.
14FUG	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	The Nitric Acid Unit is not a petroleum refinery.
14FUG	N/A	40 CFR Part 60, Subpart VV	The Nitric Acid Unit does not produce a listed chemical.
14FUG	N/A	40 CFR Part 63, Subpart YY	The Nitric Acid Unit is not an affected category or affected source specified in Table 1 of 63.1000.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
14LTR001	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	The emission unit is not a VOC transfer unit.
14LTR001	N/A	40 CFR Part 61, Subpart BB	Benzene loading is not done at this unit.
14LTR001	N/A	40 CFR Part 63, Subpart F	The emission unit is not part of a chemical manufacturing process unit that manufactures as a primary product one or more of the chemicals listed in 40 CFR Part 63 Subpart F, paragraphs 63.100(b)(1)(i) or (b)(1)(ii).
14PRC	N/A	30 TAC Chapter 115, Vent Gas Controls	The vent stream does not contain specified VOC.
14PRC	N/A	30 TAC Chapter 117, Subchapter B	The nitric acid production unit is not located in the Beaumont/Port Arthur or the Houston/Galveston/Brazoria ozone nonattainment areas.
14PRC	N/A	40 CFR Part 63, Subpart F	The process unit is not part of a chemical manufacturing process that manufactures as a primary product one or more of the chemicals listed in 40 CFR 63, Subpart F, paragraphs 63.100(b)(1)(i) or (b)(1)(ii).
14STK001	N/A	30 TAC Chapter 115, Vent Gas Controls	The vent stream does not contain any VOC.
14STK002	N/A	30 TAC Chapter 115, Vent Gas Controls	The vent stream does not contain any VOC.
14TFX516	N/A	40 CFR Part 60, Subpart K	Capacity less than 151,412 liters (40000 gallons).
15BLR001	N/A	30 TAC Chapter 112, Sulfur Compounds	The boiler combusts liquid fuels from hazardous waste streams. The definition of liquid fuels excludes liquid fuels derived from hazardous waste.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
15BLR001	N/A	40 CFR Part 60, Subpart CCCC	Hazardous waste combustion unit for which there is a requirement to have a permit under section 3005 of the Solid Waste Disposal Act are exempt from 40 CFR Part 60, Subpart CCCC.
15BLR001	N/A	40 CFR Part 60, Subpart D	Constructed prior to August 17, 1971. (1965)
15BLR001	N/A	40 CFR Part 60, Subpart Db	Construction, modification, or reconstruction of the boilers did not commence after June 19, 1984.
15BLR001	N/A	40 CFR Part 63, Subpart DDDDD	Boilers covered by 40 CFR Part 63, Subpart EEE are not subject to 40 CFR 63, Subpart DDDDD.
15BLR002	N/A	40 CFR Part 60, Subpart CCCC	Hazardous waste combustion units for which there is a requirement to have a permit under section 3005 of the Solid Waste Disposal Act are exempt from 40 CFR Part 60, Subpart CCCC.
15BLR002	N/A	40 CFR Part 60, Subpart D	Constructed prior to August 17, 1971. (1965)
15BLR002	N/A	40 CFR Part 60, Subpart Db	Construction, modification, or reconstruction of the boilers did not commence after June 19, 1984.
15BLR002	N/A	40 CFR Part 63, Subpart DDDDD	Boilers covered by 40 CFR Part 63, Subpart EEE are not subject to 40 CFR 63, Subpart DDDDD.
15BLR003	N/A	40 CFR Part 60, Subpart CCCC	Hazardous waste combustion units for which there is a requirement to have a permit under section 3005 of the Solid Waste Disposal Act are exempt from 40 CFR Part 60, Subpart CCCC.
15BLR003	N/A	40 CFR Part 60, Subpart D	Constructed prior to August 17, 1971. (1965)

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
15BLR003	N/A	40 CFR Part 60, Subpart Db	Construction, modification, or reconstruction of the boilers did not commence after June 19, 1984.
15BLR003	N/A	40 CFR Part 63, Subpart DDDDD	Boilers covered by 40 CFR Part 63, Subpart EEE are not subject to 40 CFR 63, Subpart DDDDD.
15BLR004	N/A	30 TAC Chapter 112, Sulfur Compounds	The boiler combusts liquid fuels from hazardous waste streams. The definition of liquid fuels excludes liquid fuels derived from hazardous waste.
15BLR004	N/A	40 CFR Part 60, Subpart CCCC	Hazardous waste combustion unit for which there is a requirement to have a permit under section 3005 of the Solid Waste Disposal Act are exempt from 40 CFR Part 60, Subpart CCCC.
15BLR004	N/A	40 CFR Part 60, Subpart Da	Constructed prior to September 18, 1978. (1973)
15BLR004	N/A	40 CFR Part 63, Subpart DDDDD	Boilers covered by 40 CFR Part 63, Subpart EEE are not subject to 40 CFR 63, Subpart DDDDD.
15FUG	N/A	30 TAC Chapter 115, Fugitives Pet Ref B Counties	Not a petroleum refinery.
15FUG	N/A	40 CFR Part 60, Subpart VV	Does not produce any chemical listed in 40 CFR §60.489 as an intermediate or final product.
15FUG	N/A	40 CFR Part 63, Subpart YY	The fugitive components are associated with a closed vent system and control device that do not receive a process vent because the gas stream is transferred for fuel value, use, reuse, or sale for fuel value, use, or reuse.
15LTR023	N/A	30 TAC Chapter 115, Vent Gas Controls	The material being transferred does not meet the definition of VOC.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
15TFX021	N/A	40 CFR Part 60, Subpart Kb	Non-petroleum liquid storage tank constructed prior to July 23, 1984.
15TFX023	N/A	30 TAC Chapter 115, Storage of VOCs	Capacity less than 1000 gallons.
15TFX023	N/A	40 CFR Part 60, Subpart Kb	Non-petroleum liquid storage tank with capacity less than 75 cubic meters (19813 gallons).
15TFX025	N/A	30 TAC Chapter 115, Storage of VOCs	Capacity less than 1000 gallons.
15TFX025	N/A	40 CFR Part 60, Subpart K	Constructed after May 19, 1978.
15TFX025	N/A	40 CFR Part 60, Subpart Ka	Constructed after July 23, 1984.
15TFX025	N/A	40 CFR Part 60, Subpart Kb	Capacity less than 75 cubic meters (19813 gallons).
15TFX536	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than or equal to 1,000 gallons.
15TFX536	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19,813 gallons).
15TFX598	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than or equal to 1,000 gallons.
15TFX598	N/A	40 CFR Part 60, Subpart K	Tank capacity is less than 151,412 liters (40,000 gallons).
15TFX601	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than or equal to 1,000 gallons.
15TFX601	N/A	40 CFR Part 60, Subpart K	Tank constructed prior to June 11, 1973.
15TFX604	N/A	30 TAC Chapter 115, Storage of	Tank capacity is less than or equal to 1,000 gallons.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
		VOCs	
15TFX604	N/A	40 CFR Part 60, Subpart K	Tank capacity is less than 151,412 liters (40,000 gallons).
15TFX605	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than or equal to 1,000 gallons.
15TFX605	N/A	40 CFR Part 60, Subpart K	Tank constructed prior to June 11, 1973.
17BLR007	N/A	30 TAC Chapter 112, Sulfur Compounds	The boiler combusts liquid fuels from hazardous waste streams. The definition of liquid fuels excludes liquid fuels derived from hazardous waste.
17BLR007	N/A	40 CFR Part 60, Subpart Da	Constructed prior to September 18, 1978.
17BLR008	N/A	30 TAC Chapter 112, Sulfur Compounds	The boiler combusts liquid fuels from hazardous waste streams. The definition of liquid fuels excludes liquid fuels derived from hazardous waste.
17BLR008	N/A	40 CFR Part 60, Subpart Da	Constructed prior to September 18, 1978.
17ENG001	N/A	40 CFR Part 60, Subpart IIII	The engine was constructed before July 11, 2005.
17FUG	N/A	30 TAC Chapter 115, Fugitives Pet Ref B Counties	Not a petroleum refinery.
17FUG	N/A	40 CFR Part 60, Subpart VV	Does not produce any chemical listed in 40 CFR §60.489 as an intermediate or final product.
17LTR549	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	This operation does not constitute loading into transport vessels as defined by 115.110(46).
17LTR550	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	This operation does not constitute loading into transport vessels as defined by 115.110(46).

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
17TFX004	N/A	40 CFR Part 60, Subpart Kb	Non-petroleum liquid storage tank with a capacity less than 75 cubic meters (19,813 gallons).
17TFX004	N/A	40 CFR Part 63, Subpart DD	The off-site material management unit is also subject to 40 CFR 61, Subpart FF. Any HAPs listed in 40 CFR 63, Subpart DD, Table 1 are controlled in accordance with Subpart FF.
17TFX008	N/A	40 CFR Part 60, Subpart K	Constructed after May 19, 1978.
17TFX008	N/A	40 CFR Part 60, Subpart Ka	Constructed after July 23, 1984.
17TFX008	N/A	40 CFR Part 60, Subpart Kb	Capacity is less than 75 cubic meters (19,813 gallons).
17TFX008	N/A	40 CFR Part 63, Subpart DD	The off-site material management unit is also subject to 40 CFR Part 61, Subpart FF, and any HAPs listed in Table 1 are controlled in accordance with that subpart.
17TFX009	N/A	40 CFR Part 60, Subpart Kb	Non-petroleum liquid storage tank with a capacity less than 75 cubic meters (19,813 gallons).
17TFX009	N/A	40 CFR Part 61, Subpart FF	Tank does not store a benzene waste.
17TFX538	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than or equal to 1,000 gallons.
17TFX538	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19,813 gallons).
17TFX547	N/A	40 CFR Part 60, Subpart Kb	The tank does not meet the definition of a storage vessel since the tank does not store volatile organic liquids (it is a process tank).

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
17TFX548	N/A	40 CFR Part 60, Subpart Kb	The tank does not meet the definition of a storage vessel since the tank does not store volatile organic liquids (it is a process tank).

New Source Review Authorization References

New Source Review Authorization References..... 199

New Source Review Authorization References by Emission Unit 100

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 809	Issuance Date: 06/30/2014
Authorization No.: 812	Issuance Date: 12/23/2013
Authorization No.: 813	Issuance Date: 01/12/2012
Authorization No.: 9560	Issuance Date: 02/13/2015
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.261	Version No./Date: 12/24/1998
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 12/24/1998
Number: 106.262	Version No./Date: 11/01/2003
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.371	Version No./Date: 09/04/2000
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.476	Version No./Date: 09/04/2000
Number: 106.478	Version No./Date: 03/14/1997
Number: 106.511	Version No./Date: 09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
04FLR032	DIAMINE FLARE	813, 106.261/11/01/2003, 106.262/11/01/2003
12BLR001	COGENERATION GAS TURBINE	9560
12CAS001	DISTILLATE DUMPSTER CARBON ADSORBER	9560
12FLR001	COGEN MSS FLARE	9560
12STK001	COGENERATION GAS TURBINE	9560
12TFX026	DISTILLATE DUMPSTER	9560
14FLR001A	NITRIC ACID FLARE	809, 106.263/11/01/2001
14FUG	FUGITIVES	809
14LTR001	NITRIC ACID LOADING/UNLOADING	809, 106.472/09/04/2000
14PRC	NITRIC ACID PROCESS	809
14STK001	NITRIC ACID PROCESS STACK	809
14STK002	SAMPLE SINK VENT HOOD STACK	809
14TFX516	COMPRESSOR LUBE OIL CONSOLE	106.472/09/04/2000
15BLR001	BOILER 1	812, 106.472/09/04/2000
15BLR002	BOILER 2	812, 106.472/09/04/2000
15BLR003	BOILER 3	812, 106.472/09/04/2000
15BLR004	BOILER 4	812, 106.472/09/04/2000
15CAD001	DISTILLATE DUMPSTER CARBON ADOSRBER	812

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
15CAT001	CATALYTIC ABATER	812, 106.263/11/01/2001
15FUG	FUGITIVE EMISSIONS	812, 106.261/11/01/2003, 106.262/11/01/2003, 106.263/11/01/2001, 106.371/09/04/2000
15LTR023	HCL TRAILER UNLOAD	812
15LTR026	LUBE OIL TRUCK UNLOADING	106.472/09/04/2000
15STK005	BOILER 1&2 STACK	812, 106.472/09/04/2000
15STK006	BOILER 3 & 4 STACK	812, 106.472/09/04/2000
15TFX021	NVR TANK	812
15TFX023	DISTILLATE DUMPSTER	812
15TFX025	WASTE L.O. DUMPSTER A/C	812
15TFX536	O2 SCAVENGER STORAGE TANK	106.371/09/04/2000
15TFX598	PAC 1/BAC 1 LUBE OIL TANK	106.472/09/04/2000
15TFX601	PAC 2 LUBE OIL TANK	106.472/09/04/2000
15TFX604	BAC 2 LUBE OIL TANK	106.472/09/04/2000
15TFX605	BAC 2 HELPER LUBE OIL TANK	106.472/09/04/2000
15VNT005	BOILER 1&2 STACK	812, 106.472/09/04/2000
15VNT006	BOILER 3 & 4 STACK	812, 106.472/09/04/2000
17BLR007	BOILER 7	813, 106.263/11/01/2001

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
17BLR008	BOILER 8	813, 106.263/11/01/2001
17ENG001	DIESEL ENGINE GENERATOR	106.511/09/04/2000
17FUG	FUGITIVES	813, 106.261/11/01/2003, 106.262/11/01/2003, 106.371/09/04/2000
17LTR010	UREA TANK TRUCK LOADING/UNLOADING	813
17LTR549	DUMPSTER UNLOADING (LUBE OIL)	813
17LTR550	DUMPSTER UNLOADING (VINYL ACETATE)	813
17STK007	BOILER 7 & 8 STACK	813
17TFX004	HMD WASTE OIL TANK	813, 106.476/09/04/2000
17TFX008	WASTE LUBE OIL TANK	813
17TFX009	WASTE VAMT TANK	813
17TFX538	EMERGENCY GENERATOR DIESEL STORAGE TANK	106.472/09/04/2000
17TFX547	EAST STORMWATER TANK	106.472/09/04/2000
17TFX548	WEST STORMWATER TANK	106.472/09/04/2000
17VNT007	BOILER 7 & 8 STACK	813
TS17TFX009	TRANSFER SYSTEM FOR WASTE VAMT TANK	813

Appendix A

Acronym List 204

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
COMS	continuous opacity monitoring system
CVS	closed-vent system
D/FW	Dallas/Fort Worth (nonattainment area)
DR	Designated Representative
EIP	El Paso (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
GF	grandfathered
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MMBtu/hr	Million British thermal units per hour
MRRT	monitoring, recordkeeping, reporting, and testing
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PM	particulate matter
ppmv	parts per million by volume
PSD	prevention of significant deterioration
RO	Responsible Official
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound