Form 107-1:
Determination of Healy Booted Nozzle Operation

Test Date: ___/___/_____
Page ___ of ___

Facility Name: _____ Facility ID Number: _____

Nozzle		Gallons Dispensed	Pressure / Vacuum ("WC) During Dispensing						Pass [1] or Fail
Number	Fuel Grade		Gal. 1	Gal. 2	Gal. 3	Gal. 4	Gal. 5	Average	

[1] Nozzle passes if the average Pressure / Vacuum value is between +1/4 and -1/2 inches of WC, and fails if the value is outside this range.