

Texas Commission on Environmental Quality

CHECKLIST WORKSHEET

MSW USED OIL HANDLER GENERATORS

Regulating Entity Name

Date :

Additional I D:

Investigator Name:

Item Number 0	Description Proper management of mixtures of UO & hazardous waste.			
	Answer	Citations	279.21(b)	Notes
Item Number 2	Description SPCC Plan (SPCC (Spill Prevention, Control and Countermeasures) Plan applies to underground tank systems of more than 42,000 gallons and above ground systems of more than 1,320 gallons, or where the largest above ground tank exceeds 660 gallons.)			
	Answer	Citations	279.22	Notes
Item Number 3	Description USTs in compliance with 40 CFR Part 280 (This applies to underground storage tank (UST) systems with 10% or more of the system volume below ground level (40CFR 280.12).)			
	Answer	Citations	279.22	Notes
Item Number 4	Description Approved storage units.			
	Answer	Citations	279.22(a)	Notes
Item Number 5	Description Storage units in good condition, not rusted or leaking.			
	Answer	Citations	279.22(b)	Notes
Item Number 6	Description Containers & fill pipes have "Used Oil" labels.			
	Answer	Citations	279.22(c)	Notes
Item Number 7	Description Proper cleanup & notification of used oil spills.			
	Answer	Citations	324.15	Notes
Item Number 8	Description On-site burning in space heaters.			
	Answer	Citations	279.23(b)	Notes
Item Number 9	Description Using registered UO handlers for off-site shipments:			
	Answer	Citations	279.24	Notes
Item Number 10	Description Registered UO handlers TCEQ Registration No:			
	Answer	Citations		Notes
Item Number 11	Description Registered UO handlers EPA ID No.:			
	Answer	Citations		Notes