

Texas Commission on Environmental Quality

CHECKLIST WORKSHEET

PST FULL CEI #7F MANUAL TANK GAUGING

Regulating Entity Name

Date :

Additional I D:

Investigator Name:

Item Number 1	Description	Is the tank less than 1000 gallons in size? (If it is not, this method is unacceptable)		
	Answer	Citations	Notes	
Item Number 2	Description	Appropriate calibration chart is utilized and available for review?		
	Answer	Citations	Notes	
Item Number 3	Description	Records show liquid level measurements are taken once per week at the beginning and end of the appropriate test period (36, 44, or 58 hours) with no deliveries or removals?		
	Answer	Citations	334.50(d)(2)(C)	Notes
Item Number 4	Description	The difference between the beginning and ending measurements is recorded in gallons?		
	Answer	Citations	334.50(d)(2)(C)	Notes
Item Number 5	Description	Level measurements are based on the average of two consecutive stick readings at both the beginning and end of the test period?		
	Answer	Citations	334.50(d)(2)(C)	Notes
Item Number 6	Description	The difference between the beginning and ending readings is less than the weekly standard? (550 gallon UST has a 10 gallon weekly standard, 551-1000 gallon UST with a 64 " diameter has a 9 gallon weekly standard, 551-1000 gallon UST with a 48" diameter has a 12 gallon weekly standard)		
	Answer	Citations	334.50(d)(2)(C)	Notes
Item Number 7	Description	Monthly average of the weekly differences is less than the monthly standard? (550 gallon UST has a 5 gallon monthly standard, 551-1000 gallon UST with a 64 " diameter has a 4 gallon monthly standard, 551-1000 gallon UST with a 48" diameter has a 6 gallon monthly standard)		
	Answer	Citations	334.50(d)(2)(C)	Notes
Item Number 8	Description	If any weekly or monthly deviations exceeded the standard, was the Commission notified?		
	Answer	Citations	334.50(d)(2)(C)	Notes
Item Number 9	Description	Measuring equipment capable of measuring the level of stored substance over the full range of the tank's internal height to the nearest 1/8"?		
	Answer	Citations	334.50(d)(2)(C)	Notes
Item Number 10	Description	Release detection records available for past 5 years?		
	Answer	Citations	334.50(e)(2)(C)	Notes