

Texas Commission on Environmental Quality

CHECKLIST WORKSHEET

PST FULL CEI #7G MONTHLY TANK GAUGING

Regulating Entity Name

Date :

Additional I D:

Investigator Name:

Item Number 1	Description	Tank is used for an emergency generator? If not, this method is not acceptable.		
	Answer	Citations	Notes	
Item Number 2	Description	Appropriate calibration chart is utilized and available for review?		
	Answer	Citations	Notes	
Item Number 3	Description	Records show liquid level measurements are taken once per month at the beginning and end of a 36 hour period (with no deliveries or removals)?		
	Answer	Citations	334.50(d)(3)(C)	Notes
Item Number 4	Description	The difference between the beginning and ending measurements is recorded in gallons?		
	Answer	Citations	334.50(d)(3)(C)	Notes
Item Number 5	Description	Level measurements are based on the average of two consecutive stick readings at both the beginning and end of the test period?		
	Answer	Citations	334.50(d)(3)(C)	Notes
Item Number 6	Description	Monthly deviation is less than the standard for its corresponding tank size? (550 gallon UST has a 5 gallon monthly standard, 551-1000 gallon UST has a 7 gallon monthly standard, 1001-2000 gallon UST has a 13 gallon monthly standard, >2000 gallon UST has a monthly standard of 1% of total tank capacity)		
	Answer	Citations	334.50(d)(3)(C)	Notes
Item Number 7	Description	If any monthly deviations exceeded the standard, was the Commission notified?		
	Answer	Citations	334.50(d)(3)(C)	Notes
Item Number 8	Description	Measuring equipment capable of measuring the level of stored substance over the full range of the tank's internal height to the nearest 1/8"?		
	Answer	Citations	334.50(d)(3)(C)	Notes
Item Number 9	Description	Release detection records available for past 5 years?		
	Answer	Citations	334.50(e)(2)(C)	Notes