



2023 CONTAMINANT SUMMARY REPORT

August 26, 2024

3:43 pm

CN : CN600130140
RN : RN100214766
Last EI Date : 12/31/2023

Organization : CITY OF GARLAND POWER & LIGHT

Account : DF0012T

Site : SPENCER GENERATING STATION

CRITERIA EMISSIONS TOTALS

Pollutant Class	Annual (TPY)	Ozone (PPD)	SMSS (TPY)	Emiss Event (TPY)	EE/SMSS (TPY)
PM2.5	2.4033	30.1093	0.0000	0.0000	0.0000
VOC	1.6898	21.1434	0.0000	0.0000	0.0000
CO	0.6235	7.7650	0.0000	0.0000	0.0000
NOX	19.6608	248.6117	0.0000	0.0098	0.0098
SO2	0.1931	2.4114	0.0000	0.0000	0.0000
PM10	23.6445	307.7974	0.0000	0.0000	0.0000

CONTAMINANT SUMMARY REPORT

Contam	Contam Name	Annual (TPY)	Ozone (PPD)	SMSS (TPY)	Emiss Event (TPY)	EE/SMSS (TPY)
10000	PART-U	32.5575	424.3163	0.0000	0.0000	0.0000
20000	PM10 PART-U	23.6445	307.7974	0.0000	0.0000	0.0000
39999	TOTAL PM2.5 PARTICULATE	2.4033	30.1093	0.0000	0.0000	0.0000
50001	VOC-UNCLASSIFIED	1.6898	21.1434	0.0000	0.0000	0.0000
59210	NO 2 FUEL OIL	0.0000	0.0000	0.0000	0.0000	0.0000
70400	NITROGEN OXIDES	19.6608	248.6117	0.0000	0.0098	0.0098
70510	SULFUR DIOXIDE	0.1931	2.4114	0.0000	0.0000	0.0000
90300	CARBON MONOXIDE	0.6235	7.7650	0.0000	0.0000	0.0000

HAPS SUMMARY REPORT

Contam	Contam Name	Annual (TPY)	Ozone (PPD)	SMSS (TPY)	Emiss Event (TPY)	EE/SMSS (TPY)
----	<NONE>	0.0000	0.0000	0.0000	0.0000	0.0000