



# 2023 CONTAMINANT SUMMARY REPORT

August 21, 2024

3:46 pm

CN : CN600358980

Organization : CITY OF DENTON

RN : RN106080914

Account : DFA256U

Site : 225 MW DENTON ENERGY CENTER

Last EI Date : 12/31/2023

## CRITERIA EMISSIONS TOTALS

Pollutant Class	Annual (TPY)	Ozone (PPD)	SMSS (TPY)	Emiss Event (TPY)	EE/SMSS (TPY)
PM2.5	15.4490	119.9350	0.0000	0.0000	0.0000
VOC	19.4550	133.4560	0.0000	0.0000	0.0000
CO	21.3160	118.8411	0.0000	0.0000	0.0000
NOX	21.2830	120.8581	0.0000	0.0000	0.0000
SO2	0.2960	3.7250	0.0000	0.0000	0.0000
PB	0.0000	0.0000	0.0000	0.0000	0.0000
PM10	15.4490	119.9350	0.0000	0.0000	0.0000

## CONTAMINANT SUMMARY REPORT

Contam	Contam Name	Annual (TPY)	Ozone (PPD)	SMSS (TPY)	Emiss Event (TPY)	EE/SMSS (TPY)
10000	PART-U	15.4490	119.9350	0.0000	0.0000	0.0000
20000	PM10 PART-U	15.4490	119.9350	0.0000	0.0000	0.0000
39999	TOTAL PM2.5 PARTICULATE	15.4490	119.9350	0.0000	0.0000	0.0000
50001	VOC-UNCLASSIFIED	19.4550	133.4560	0.0000	0.0000	0.0000
70050	AMMONIA	3.4940	29.0000	0.0000	0.0000	0.0000
70400	NITROGEN OXIDES	21.2830	120.8581	0.0000	0.0000	0.0000
70510	SULFUR DIOXIDE	0.2960	3.7250	0.0000	0.0000	0.0000
90300	CARBON MONOXIDE	21.3160	118.8411	0.0000	0.0000	0.0000

## HAPS SUMMARY REPORT

Contam	Contam Name	Annual (TPY)	Ozone (PPD)	SMSS (TPY)	Emiss Event (TPY)	EE/SMSS (TPY)
----	<NONE>	0.0000	0.0000	0.0000	0.0000	0.0000