

TCEQ COMBUSTION SOURCES CURRENT BACT REQUIREMENTS FOR MSS ACTIVITIES

Boilers

This information is maintained by the Combustion/Coatings NSR Section and is subject to change. Last update 4/2009.

Year	Source Type	Pollutant	Minimum Acceptable Control	Control Efficiency or Details
2006	Boiler	NOx	NOx and CO to be established on a case-by-case basis	Minimize startup period and shutdown period
		CO		
		PM	Opacity: 30 TAC 111 limits	