

## 40 CFR Part 63, Subpart ZZZZ - Requirements Reference Tables

### Subpart ZZZZ Standards

- [§63.6590\(b\)\(1\)](#) Exemption for emergency or limited use stationary RICE
- [§63.6590\(b\)\(2\)](#) Exemption for RICE which combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis
- [§63.6590\(c\)](#) Standard for new or reconstructed stationary RICE subject to Regulations under 40 CFR Parts 60 IIII or JJJJ
- [§63.6600\(a\)-Table 1a.1.a](#) 4SRB stationary RICE reducing formaldehyde emissions
- [§63.6600\(a\)-Table 1a.1.b](#) 4SRB stationary RICE limiting the concentration of formaldehyde
- [§63.6600\(b\)-Table 2a.1.a](#) 2SLB stationary RICE reducing CO emissions
- [§63.6600\(b\)-Table 2a.1.b](#) 2SLB stationary RICE limiting the concentration of formaldehyde
- [§63.6600\(b\)-Table 2a.2.a](#) 4SLB stationary RICE with site rating greater than 500 hp reducing CO emissions
- [§63.6600\(b\)-Table 2a.2.b](#) 4SLB stationary RICE with site rating greater than 500 hp limiting the concentration of formaldehyde
- [§63.6600\(b\)-Table 2a.3.a](#) CI stationary RICE reducing CO emissions
- [§63.6600\(b\)-Table 2a.3.b](#) CI stationary RICE limiting the concentration of formaldehyde
- [§63.6600\(d\)-Table 2c.5.a](#) Existing CI stationary RICE limiting concentration of CO
- [§63.6600\(d\)-Table 2c.5.b](#) Existing CI stationary RICE reducing CO emissions
- [§63.6601-Table 2a.2.a](#) 4SLB stationary RICE with site rating less than or equal to 500 hp and greater than or equal to 250 hp reducing CO emissions
- [§63.6601-Table 2a.2.b](#) 4SLB stationary RICE with site rating less than or equal to 500 hp and greater than or equal to 250 hp limiting the concentration of formaldehyde
- [§63.6602-Table 2c.1](#) Existing emergency or black start CI stationary RICE
- [§63.6602-Table 2c.2](#) Existing CI stationary RICE with site rating less than 100 hp
- [§63.6602-Table 2c.3](#) Existing CI stationary RICE with site rating greater than 100 hp and less than or equal to 300 hp limiting the concentration of CO
- [§63.6602-Table 2c.4.a](#) Existing CI stationary RICE with site rating greater than 300 hp and less than or equal to 500 hp limiting the concentration of CO
- [§63.6602-Table 2c.4.b](#) Existing CI stationary RICE with site rating greater than 300 hp and less than or equal to 500 hp reducing CO emissions
- [§63.6602-Table 2c.6](#) Existing emergency or black start SI stationary RICE with a site rating less than or equal to 500 hp
- [§63.6602-Table 2c.7](#) Existing SI stationary RICE with a site rating less than 100 hp that are not 2SLB
- [§63.6602-Table 2c.8](#) Existing 2SLB SI stationary RICE with a site rating less than 100 hp

- [§63.6602-Table 2c.9](#) Existing 2SLB SI stationary RICE with a site rating greater than or equal to 100 hp and less than or equal to 500 hp
- [§63.6602-Table 2c.10](#) Existing 4SLB stationary RICE with a site rating greater than or equal to 100 hp and less than or equal to 500 hp
- [§63.6602-Table 2c.11](#) Existing 4SRB stationary RICE with a site rating greater than or equal to 100 hp and less than or equal to 500 hp
- [§63.6602-Table 2c.12](#) Existing landfill or digester gas-fired stationary RICE with a site rating greater than or equal to 100 hp and less than or equal to 500 hp
- [§63.6603\(a\)-Table 2d.1](#) Existing area source CI stationary RICE with a site rating less than or equal to 300 hp
- [§63.6603\(a\)-Table 2d.2.a](#) Existing area source CI stationary RICE with a site rating greater than 300 hp and less than or equal to 500 hp limiting the concentration of CO
- [§63.6603\(a\)-Table 2d.2.b](#) Existing area source CI stationary RICE with a site rating greater than 300 hp and less than or equal to 500 hp, reducing CO emissions
- [§63.6603\(a\)-Table 2d.3.a](#) Existing area source CI stationary RICE with a site rating greater than 500 hp, limiting the concentration of CO
- [§63.6603\(a\)-Table 2d.3.b](#) Existing area source CI stationary RICE with a site rating greater than 500 hp, reducing CO emissions
- [§63.6603\(a\)-Table 2d.4](#) Existing area source emergency or black start stationary CI RICE
- [§63.6603\(a\)-Table 2d.5](#) Existing area source emergency or black start stationary SI RICE; 4SLB or 4SRB with site rating greater than 500 hp operating 24 hours or less per calendar year
- [§63.6603\(a\)-Table 2d.6](#) Existing area source 2SLB stationary RICE
- [§63.6603\(a\)-Table 2d.7](#) Existing area source 4SLB stationary RICE with a site rating less than or equal to 500 hp
- [§63.6603\(a\)-Table 2d.8](#) Existing area source 4SLB remote stationary RICE with a site rating greater than 500 hp
- [§63.6603\(a\)-Table 2d.9](#) Existing area source 4SLB stationary RICE with a site rating greater than 500 hp operating more than 24 hours per calendar year
- [§63.6603\(a\)-Table 2d.10](#) Existing area source 4SRB stationary RICE with a site rating less than or equal to 500 hp
- [§63.6603\(a\)-Table 2d.11](#) Existing area source 4SRB remote stationary RICE with a site rating greater than 500 hp
- [§63.6603\(a\)-Table 2d.12](#) Existing area source 4SRB stationary RICE with a site rating greater than 500 hp operating more than 24 hours per calendar year
- [§63.6603\(a\)-Table 2d.13](#) Existing area source landfill or digester gas-fired stationary RICE
- [§63.6603\(d\)](#) Existing area source CI stationary RICE with a site rating more than 300 hp certified to the Tier 1 or Tier emission standards in Table 1 of 40 CFR 89.112 choosing to comply with Table 2d
- [§63.6603\(e\)](#) Existing area source CI stationary RICE with a site rating more than 300 hp certified to Tier 3 (Tier 2 for engines above 560 kW) emission standards

**in Table 1 of 40 CFR 89.112 choosing to comply with 40 CFR Part 60, Subpart IIII**

**These relationship entry screens and flowcharts are for use by sources subject to the Texas Federal Operating Permits Program only and are subject to revision.**

**Last modified: May 27, 2014**