30 TAC Chapter 117, Subchapter B, Division 1: Stationary Gas Turbines Requirements Reference Tables

30 TAC Chapter 117/Stationary Gas Turbine Standards

- §117.103(a)(6)(D) Exemption for stationary gas turbines that are used exclusively in emergency situations
- §117.103(b)(2) Exemption for low annual capacity factor stationary gas turbines
- §117.103(b)(6) Exemption for stationary gas turbines with a MW rating less than 10.0 MW
- §117.105(a)(1)|1 NOx emission limit for units is limit stated in NSR permit in effect on June 9, 1993
- §117.105(a)(3)|1 NOx emission limit for units placed into service after June 9, 1993 and before the final compliance date is limit stated in NSR permit
- §117.105(c)|1 NOx emission limit for gas turbines
- §117.105(c)|2 CO emission limit for gas turbines
- §117.105(g) NH_3 emission limit for gas turbines
- §117.115(a)|1 Alternative NOx emission specification to §117.105 based on plant-wide averaging at maximum capacity
- §117.123(a)|1 Alternative NOx emission specification to §117.105 based on source cap limitation
- §117.125(a)|1 Alternative NOx emission specification to §117.105 as approved by the executive director
- §117.125(a)|2 Alternative CO emission specification to §117.105 as approved by the executive director
- §117.125(a)|3 Alternative NH3 emission specification to §117.105 as approved by the executive director

These relationship entry screens and flowcharts are for use by sources subject to the Texas Federal Operating Permits Program only and are subject to revision.

Last Modified: April 22, 2013