

# Statement of Basis of the Federal Operating Permit

NRG Texas Power LLC

Site/Area Name: Limestone Electric Generating Station  
Physical location: 9 Miles North Of Jewett, Texas on FM 39  
Nearest City: Jewett  
County: Limestone

Permit Number: O75  
Project Type: Significant Revision

Standard Industrial Classification (SIC) Code: 4911  
SIC Name: Electric Services

This Statement of Basis sets forth the legal and factual basis for the draft changes to the permit conditions resulting from the significant revision project in accordance with 30 TAC §122.201(a)(4). The applicant has submitted an application for a significant permit revision per §§ 122.219-211. This document may include the following information:

- A description of the facility/area process description;
- A description of the revision project;
- A basis for applying permit shields;
- A list of the federal regulatory applicability determinations;
- A table listing the determination of applicable requirements;
- A list of the New Source Review Requirements;
- The rationale for periodic monitoring methods selected;
- The rationale for compliance assurance methods selected;
- A compliance status; and
- A list of available unit attribute forms.

Prepared on: January 6, 2014

## **Operating Permit Basis of Determination**

### **Description of Revisions**

A significant revision application was submitted on July 23, 2013 for an amendment to NSR permits 8576 & 8579 and PSD Permit PSDTX371M4 for authorized emissions associated with three emissions controls projects planned for Limestone Electric Generating Station: 1) install Activated Carbon Injection (ACI) systems, 2) undertake combustion tuning activities to reduce NOx, and 3) installation of Selective Non-Catalytic Reduction (SNCR) system. Also, the Standard Permit No. 97947 is being rolled into NSR Permit No. 8576. The amendment to NSR Permits 8576 & 8579 and PSD Permit PSDTX371M4 was issued on December 20, 2013 changing the modification number for the PSD Permit from M4 to M5. A new Major NSR Summary Table was provided with the new issuance dates for both NSR permits associated with the PSD permit.

### **Permit Area Process Description**

The Limestone Electric Generating Station consists of two high-pressure boilers (FINs Units 1 and 2) that produce steam for the generation of electricity. These units operate on the Rankine cycle, in which fuel is combusted to turn water into steam, which is used to turn a steam turbine connected to a generator, which produces electricity. Each boiler can fire lignite, coal, a blend of lignite and coal, and a blend of up to 20% by weight petroleum (pet) coke with either lignite or coal. Each boiler also utilizes natural gas for start-up and flame stability. The lignite used for fuel is mined at a site adjacent to the plant and transferred to storage piles by means of conveyors. Units 1 and 2 are both equipped with flue gas desulfurization (FGD) system for control of sulfur dioxide (SO<sub>2</sub>) emissions and an electrostatic precipitator for control of particulate matter (PM) emissions.

Other equipment at the station is used to support the primary activity of generating electricity. The other equipment includes lignite, limestone, and waste handling systems, degreasers (FINs DG-1 to DG-13), engines (FINs SWDAEG, FGDEG1, FGDEG2, PBEG1, PBEG2 and MCTEG), and oil-water separators (FINs S1 and S2). The limestone handling system is used to transport limestone from the railcar unloader and storage area to the flue gas desulfurization (FGD) systems. The waste handling system is used to transport, blend, and store fly ash and FGD sludge prior to its disposal in the landfill. Degreasers are used in the shops for parts cleaning. Engines are used for emergency/backup equipment such as fire water pumps and emergency generators and for mobile equipment. The oil-water separator is used for treating wastewater generated at the site.

### **FOPs at Site**

The "application area" consists of the emission units and that portion of the site included in the application and this permit. Multiple FOPs may be issued to a site in accordance with 30 TAC § 122.201(e). When there is only one area for the site, then the application information and permit will include all units at the site. Additional FOPs that exist at the site, if any, are listed below.

Additional FOPs: None

### **Major Source Pollutants**

The table below specifies the pollutants for which the site is a major source:

Major Pollutants	VOC, SO <sub>2</sub> , PM, NO <sub>x</sub> , HAPS, CO, H <sub>2</sub> SO <sub>4</sub>
------------------	---

### **Reading State of Texas's Federal Operating Permit**

The Title V Federal Operating Permit (FOP) lists all state and federal air emission regulations and New Source Review (NSR) authorizations (collectively known as "applicable requirements") that apply at a particular site or permit area (in the event a site has multiple FOPs). **The FOP does not authorize new emissions or new construction activities.** The FOP begins with an introductory page which is common to all Title V permits.

This page gives the details of the company, states the authority of the issuing agency, requires the company to operate in accordance with this permit and 30 Texas Administrative Code (TAC) Chapter 122, requires adherence with NSR requirements of 30 TAC Chapter 116, and finally indicates the permit number and the issuance date.

This is followed by the table of contents, which is generally composed of the following elements. Not all permits will have all of the elements.

- General Terms and Conditions
- Special Terms and Conditions
  - Emissions Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting
  - Additional Monitoring Requirements
  - New Source Review Authorization Requirements
  - Compliance Requirements
  - Protection of Stratosphere Ozone
  - Permit Location
  - Permit Shield (30 TAC § 122.148)
- Attachments
  - Applicable Requirements Summary
    - Unit Summary
    - Applicable Requirements Summary
  - Additional Monitoring Requirements
  - Permit Shield
  - New Source Review Authorization References
  - Compliance Plan
  - Alternative Requirements
- Appendix A
  - Acronym list
- Appendix B
  - Copies of major NSR authorizations

### General Terms and Conditions

The General Terms and Conditions are the same and appear in all permits. The first paragraph lists the specific citations for 30 TAC Chapter 122 requirements that apply to all Title V permit holders. The second paragraph describes the requirements for record retention. The third paragraph provides details for voiding the permit, if applicable. The fourth paragraph states that the permit holder shall comply with the requirements of 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit. The fifth paragraph provides details on submission of reports required by the permit.

### Special Terms and Conditions

Emissions Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting. The TCEQ has designated certain applicable requirements as site-wide requirements. A site-wide requirement is a requirement that applies uniformly to all the units or activities at the site. Units with only site-wide requirements are addressed on Form OP-REQ1 and are not required to be listed separately on a OP-UA Form or Form OP-SUM. Form OP-SUM must list all units addressed in the application and provide identifying information, applicable OP-UA Forms, and preconstruction authorizations. The various OP-UA Forms provide the characteristics of each unit from which applicable requirements are established. Some exceptions exist as a few units may have both site-wide requirements and unit specific requirements.

Other conditions. The other entries under special terms and conditions are in general terms referring to compliance with the more detailed data listed in the attachments.

## Attachments

**Applicable Requirements Summary.** The first attachment, the Applicable Requirements Summary, has two tables, addressing unit specific requirements. The first table, the Unit Summary, includes a list of units with applicable requirements, the unit type, the applicable regulation, and the requirement driver. The intent of the requirement driver is to inform the reader that a given unit may have several different operating scenarios and the differences between those operating scenarios.

The applicable requirements summary table provides the detailed citations of the rules that apply to the various units. For each unit and operating scenario, there is an added modifier called the “index number,” detailed citations specifying monitoring and testing requirements, recordkeeping requirements, and reporting requirements. The data for this table are based on data supplied by the applicant on the OP-SUM and various OP-UA forms.

**Additional Monitoring Requirement.** The next attachment includes additional monitoring the applicant must perform to ensure compliance with the applicable standard. Compliance assurance monitoring (CAM) is often required to provide a reasonable assurance of compliance with applicable emission limitations/standards for large emission units that use control devices to achieve compliance with applicant requirements. When necessary, periodic monitoring (PM) requirements are specified for certain parameters (i.e. feed rates, flow rates, temperature, fuel type and consumption, etc.) to determine if a term and condition or emission unit is operating within specified limits to control emissions. These additional monitoring approaches may be required for two reasons. First, the applicable rules do not adequately specify monitoring requirements (exception- Maximum Achievable Control Technology Standards (MACTs) generally have sufficient monitoring), and second, monitoring may be required to fill gaps in the monitoring requirements of certain applicable requirements. In situations where the NSR permit is the applicable requirement requiring extra monitoring for a specific emission unit, the preferred solution is to have the monitoring requirements in the NSR permit updated so that all NSR requirements are consolidated in the NSR permit.

**Permit Shield.** A permit may or may not have a permit shield, depending on whether an applicant has applied for, and justified the granting of, a permit shield. A permit shield is a special condition included in the permit document stating that compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirement(s) or specified applicable state-only requirement(s).

**New Source Review Authorization References.** All activities which are related to emissions in the state of Texas must have a NSR authorization prior to beginning construction. This section lists all units in the permit and the NSR authorization that allowed the unit to be constructed or modified. Units that do not have unit specific applicable requirements other than the NSR authorization do not need to be listed in this attachment. While NSR permits are not physically a part of the Title V permit, they are legally incorporated into the Title V permit by reference. Those NSR permits whose emissions exceed certain PSD/NA thresholds must also undergo a Federal review of federally regulated pollutants in addition to review for state regulated pollutants.

**Compliance Plan.** A permit may have a compliance schedule attachment for listing corrective actions plans for any emission unit that is out of compliance with an applicable requirement.

**Alternative Requirements.** This attachment will list any alternative monitoring plans or alternative means of compliance for applicable requirements that have been approved by the EPA Administrator and/or the TCEQ Executive Director.

## Appendix A

Acronym list. This attachment lists the common acronyms used when discussing the FOPs.

## Appendix B

Copies of major NSR authorizations applicable to the units covered by this permit have been included in this Appendix, to ensure that all interested persons can access those authorizations.

### **Stationary vents subject to 30 TAC Chapter 111, Subchapter A, § 111.111(a)(1)(B) addressed in the Special Terms and Conditions**

The site contains stationary vents with a flowrate less than 100,000 actual cubic feet per minute (acfm) and constructed after January 31, 1972 which are limited, over a six-minute average, to 20% opacity as required by 30 TAC § 111.111(a)(1)(B). As a site may have a large number of stationary vents that fall into this category, they are not required to be listed individually in the permit's Applicable Requirement Summary. This is consistent with EPA's White Paper for Streamlined Development of Part 70 Permit Applications, July 10, 1995, that states that requirements that apply identically to emission units at a site can be treated on a generic basis such as source-wide opacity limits.

Periodic monitoring is specified in Special Term and Condition 3.A for stationary vents subject to 30 TAC § 111.111(a)(1)(B) to verify compliance with the 20% opacity limit. These vents are not expected to produce visible emissions during normal operation. The TCEQ evaluated the probability of these sources violating the opacity standards and determined that there is a very low potential that an opacity standard would be exceeded. It was determined that continuous monitoring for these sources is not warranted as there would be very limited environmental benefit in continuously monitoring sources that have a low potential to produce visible emissions. Therefore, the TCEQ set the visible observation monitoring frequency for these sources to once per calendar quarter.

The TCEQ has exempted vents that are not capable of producing visible emissions from periodic monitoring requirements. These vents include sources of colorless VOCs, non-fuming liquids, and other materials that cannot produce emissions that obstruct the transmission of light. Passive ventilation vents, such as plumbing vents, are also included in this category. Since this category of vents are not capable of producing opacity due to the physical or chemical characteristics of the emission source, periodic monitoring is not required as it would not yield any additional data to assure compliance with the 20% opacity standard of 30 TAC § 111.111(a)(1)(B).

In the event that visible emissions are detected, either through the quarterly observation or other credible evidence, such as observations from company personnel, the permit holder shall either report a deviation or perform a Test Method 9 observation to determine the opacity consistent with the 6-minute averaging time specified in 30 TAC § 111.111(a)(1)(B). An additional provision is included to monitor combustion sources more frequently than quarterly if alternate fuels are burned for periods greater than 24 consecutive hours. This will address possible emissions that may arise when switching fuel types.

### **Stationary Vents subject to 30 TAC Chapter 111 not addressed in the Special Terms and Conditions**

All other stationary vents subject to 30 TAC Chapter 111 not covered in the Special Terms and Conditions are listed in the permit's Applicable Requirement Summary. The basis for the applicability determinations for these vents are listed in the Determination of Applicable Requirements table.

### **Federal Regulatory Applicability Determinations**

The following chart summarizes the applicability of the principal air pollution regulatory programs to the permit area:

<b>Regulatory Program</b>	<b>Applicability (Yes/No)</b>
Prevention of Significant Deterioration (PSD)	Yes
Nonattainment New Source Review (NNSR)	No
Minor NSR	Yes
40 CFR Part 60 - New Source Performance Standards	Yes
40 CFR Part 61 - National Emission Standards for Hazardous Air Pollutants (NESHAPs)	No
40 CFR Part 63 - NESHAPs for Source Categories	Yes
Title IV (Acid Rain) of the Clean Air Act (CAA)	Yes
Title V (Federal Operating Permits) of the CAA	Yes
Title VI (Stratospheric Ozone Protection) of the CAA	Yes
CAIR (Clean Air Interstate Rule)	Yes

### **Basis for Applying Permit Shields**

An operating permit applicant has the opportunity to specifically request a permit shield to document that specific applicable requirements do not apply to emission units in the permit. A permit shield is a special condition stating that compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements. A permit shield has been requested in the application for specific emission units. For the permit shield requests that have been approved, the basis of determination for regulations that the owner/operator need not comply with are located in the “Permit Shield” attachment of the permit.

### **Acid Rain Permit**

The permitted area is subject to Federal Clean Air Act Title IV Acid Rain rules for Phase II units, as codified in 40 CFR Parts 72 through 78, because it meets the definition of “affected source.” Applicability of affected sources are defined in 40 CFR § 72.6 and include those sources that burn fossil fuel, and generates electricity for sale. Under 40 CFR Part 72, incorporated by reference into 30 TAC Chapter 122, all acid rain permits must contain specific terms and conditions, including monitoring, reporting, recordkeeping and excess emission requirements, established by the U.S. EPA. The Title IV permitting procedures are described within 30 TAC Chapter 122, Subchapter E. The applicable requirements of the Acid Rain Permit are contained in the Special Terms and Conditions of the FOP. The Acid Rain permit is effective as of the date of the issuance of the FOP and has a term ending in concurrence with the FOP.

### **CAIR Permit**

The Clean Air Interstate Rule (CAIR) was established to mitigate the interstate transport of NO<sub>x</sub> and SO<sub>2</sub> which contribute to the formation of fine particles (PM 2.5) and ground-level ozone. The EPA has promulgated a model cap and trade program in 40 CFR Part 96 to implement CAIR. This rule has been adopted by reference into 30 TAC Chapter 122, Subchapter E, Division 2: Clean Air Interstate Rule.

The permitted area is subject to CAIR as it contains units that meet the definition of a NO<sub>x</sub> budget unit in 40 CFR § 96.4(a)(1)-(2) and a CAIR SO<sub>2</sub> unit in 40 CFR § 96.204(a)(1)-(2). The applicable requirements of the CAIR permit are contained in the Special Terms and Conditions of the FOP. The CAIR permit is effective as of the date of the issuance of this revision and has a term ending in concurrence with the FOP.

## **Insignificant Activities**

In general, units not meeting the criteria for inclusion on either Form OP-SUM or Form OP-REQ1 are not required to be addressed in the operating permit application. Examples of these types of units include, but are not limited to, the following:

1. Office activities such as photocopying, blueprint copying, and photographic processes.
2. Sanitary sewage collection and treatment facilities other than those used to incinerate wastewater treatment plant sludge. Stacks or vents for sanitary sewer plumbing traps are also included.
3. Food preparation facilities including, but not limited to, restaurants and cafeterias used for preparing food or beverages primarily for consumption on the premises.
4. Outdoor barbecue pits, campfires, and fireplaces.
5. Laundry dryers, extractors, and tumblers processing bedding, clothing, or other fabric items generated primarily at the premises. This does not include emissions from dry cleaning systems using perchloroethylene or petroleum solvents.
6. Facilities storing only dry, sweet natural gas, including natural gas pressure regulator vents.
7. Any air separation or other industrial gas production, storage, or packaging facility. Industrial gases, for purposes of this list, include only oxygen, nitrogen, helium, neon, argon, krypton, and xenon.
8. Storage and handling of sealed portable containers, cylinders, or sealed drums.
9. Vehicle exhaust from maintenance or repair shops.
10. Storage and use of non-VOC products or equipment for maintaining motor vehicles operated at the site (including but not limited to, antifreeze and fuel additives).
11. Air contaminant detectors and recorders, combustion controllers and shut-off devices, product analyzers, laboratory analyzers, continuous emissions monitors, other analyzers and monitors, and emissions associated with sampling activities. Exception to this category includes sampling activities that are deemed fugitive emissions and under a regulatory leak detection and repair program.
12. Bench scale laboratory equipment and laboratory equipment used exclusively for chemical and physical analysis, including but not limited to, assorted vacuum producing devices and laboratory fume hoods.
13. Steam vents, steam leaks, and steam safety relief valves, provided the steam (or boiler feedwater) has not contacted other materials or fluids containing regulated air pollutants other than boiler water treatment chemicals.
14. Storage of water that has not contacted other materials or fluids containing regulated air pollutants other than boiler water treatment chemicals.
15. Well cellars.
16. Fire or emergency response equipment and training, including but not limited to, use of fire control equipment including equipment testing and training, and open burning of materials or fuels associated with firefighting training.
17. Crucible or pot furnaces with a brim full capacity of less than 450 cubic inches of any molten metal.
18. Equipment used exclusively for the melting or application of wax.
19. All closed tumblers used for the cleaning or deburring of metal products without abrasive blasting, and all open tumblers with a batch capacity of 1,000 lbs. or less.
20. Shell core and shell mold manufacturing machines.
21. Sand or investment molds with a capacity of 100 lbs. or less used for the casting of metals;
22. Equipment used for inspection of metal products.
23. Equipment used exclusively for rolling, forging, pressing, drawing, spinning, or extruding either hot or cold metals by some mechanical means.
24. Instrument systems utilizing air, natural gas, nitrogen, oxygen, carbon dioxide, helium, neon, argon, krypton, and xenon.
25. Battery recharging areas.
26. Brazing, soldering, or welding equipment.

## **Determination of Applicable Requirements**

The tables below include the applicability determinations for the emission units, the index number(s) where applicable, and all relevant unit attribute information used to form the basis of the applicability determination. The unit attribute information is a description of the physical properties of an emission unit which is used to determine the requirements to which the permit holder must comply. For more information about the descriptions of the unit attributes specific Unit Attribute Forms may be viewed at [www.tceq.texas.gov/permitting/air/nav/air\\_all\\_ua\\_forms.html](http://www.tceq.texas.gov/permitting/air/nav/air_all_ua_forms.html).

A list of unit attribute forms is included at the end of this document. Some examples of unit attributes include construction date; product stored in a tank; boiler fuel type; etc.. Generally, multiple attributes are needed to determine the requirements for a given emission unit and index number. The table below lists these attributes in the column entitled "Basis of Determination." Attributes that demonstrate that an applicable requirement applies will be the factual basis for the specific citations in an applicable requirement that apply to a unit for that index number. The TCEQ Air Permits Division has developed flowcharts for determining applicability of state and federal regulations based on the unit attribute information in a Decision Support System (DSS). These flowcharts can be accessed via the internet at [www.tceq.texas.gov/permitting/air/nav/air\\_supportsys.html](http://www.tceq.texas.gov/permitting/air/nav/air_supportsys.html). The Air Permits Division staff may also be contacted for assistance at (512) 239-1250.

The attributes for each unit and corresponding index number provide the basis for determining the specific legal citations in an applicable requirement that apply, including emission limitations or standards, monitoring, recordkeeping, and reporting. The rules were found to apply or not apply by using the unit attributes as answers to decision questions found in the flowcharts of the DSS. Some additional attributes indicate which legal citations of a rule apply. The legal citations that apply to each emission unit may be found in the Applicable Requirements Summary table of the draft permit. There may be some entries or rows of units and rules not found in the permit, or if the permit contains a permit shield, repeated in the permit shield area. These are sets of attributes that describe negative applicability, or, in other words, the reason why a potentially applicable requirement does not apply.

If applicability determinations have been made which differ from the available flowcharts, an explanation of the decisions involved in the applicability determination is specified in the column "Changes and Exceptions to RRT." If there were no exceptions to the DSS, then this column has been removed.

The draft permit includes all emission limitations or standards, monitoring, recordkeeping and reporting required by each applicable requirement. If an applicable requirement does not require monitoring, recordkeeping, or reporting, the word "None" will appear in the Applicable Requirements Summary table. If additional periodic monitoring is required for an applicable requirement, it will be explained in detail in the portion of this document entitled "Rationale for Compliance Assurance Monitoring (CAM)/ Periodic Monitoring Methods Selected."

When attributes demonstrate that a unit is not subject to an applicable requirement, the applicant may request a permit shield for those items. The portion of this document entitled "Basis for Applying Permit Shields" specifies which units, if any, have a permit shield.

### **Operational Flexibility**

When an emission unit has multiple operating scenarios, it will have a different index number associated with each operating condition. This means that units are permitted to operate under multiple operating conditions. The applicable requirements for each operating condition are determined by a unique set of unit attributes. For example, a tank may store two different products at different points in time. The tank may, therefore, need to comply with two distinct sets of requirements, depending on the product that is stored. Both sets of requirements are included in the permit, so that the permit holder may store either product in the tank.

## Determination of Applicable Requirements

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
FGDEG1	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-01	Brake HP = Stationary RICE with a brake hp greater than 500. Construction/Reconstruction Date = Commenced construction or reconstruction before December 19, 2002.	
FGDEG2	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-01	Brake HP = Stationary RICE with a brake hp greater than 500. Construction/Reconstruction Date = Commenced construction or reconstruction before December 19, 2002.	
MCTEG	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-01	Brake HP = Stationary RICE with a brake hp greater than or equal to 300 hp and less than or equal to 500 hp. Construction/Reconstruction Date = Commenced construction or reconstruction before December 19, 2002. Service Type = Emergency use. Stationary RICE Type = Compression ignition engine	
PBEG1	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-01	Brake HP = Stationary RICE with a brake hp greater than 500. Construction/Reconstruction Date = Commenced construction or reconstruction before December 19, 2002.	
PBEG2	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-01	Brake HP = Stationary RICE with a brake hp greater than 500. Construction/Reconstruction Date = Commenced construction or reconstruction before December 19, 2002.	
SWDAEG	40 CFR Part 63, Subpart ZZZZ	63ZZZZ-01	Brake HP = Stationary RICE with a brake hp greater than 500. Construction/Reconstruction Date = Commenced construction or reconstruction before December 19, 2002.	
LMSUNLOAD	30 TAC Chapter 115, Loading and Unloading of VOC	R5212-1	30 TAC CHAPTER 115 (REG V) FACILITY TYPE = Facility type other than a gasoline terminal, gasoline bulk plant, motor vehicle fuel dispensing facility or marine terminal. ALTERNATE CONTROL REQUIREMENT (ACR) [REG V] = No alternate control requirements are being utilized. PRODUCT TRANSFERRED = Volatile organic compounds other than gasoline. TRANSFER TYPE = Only unloading.	
GRP-B-1	30 TAC Chapter 112, Sulfur Compounds	REG2-1	30 TAC CHAPTER 112 (REG II) FUEL TYPE = Solid fossil fuel. 30 TAC CHAPTER 112 (REG II) HEAT INPUT = Design heat input is greater than 1500 MMBtu/hr. CONTROL EQUIPMENT [REG II] = Unit equipped with SO <sub>2</sub> control equipment. FEDERAL CLEAN AIR ACT (FCAA) SECTION 412(C) [REG II] = The unit is subject to the Federal Clean Air Act § 412(c) [FCAA § 412(c)] as amended in 1990.	
GRP-B-1	30 TAC Chapter 117, Subchapter E, Division 1	R7UT-1	DATE PLACED IN SERVICE = Before December 31, 1995. NOX EMISSION LIMITATION = Unit is complying with the System Cap under 30 TAC § 117.3020. UNIT EXEMPT = The unit does not qualify for any exemptions under the rule. LOCATION = The unit is not a gas-fired steam generator located in Palo Pinto County as specified in 30 TAC § 117.3005(a). NOX MONITORING = A continuous emissions monitoring system is used to monitor NO <sub>x</sub> emissions. MAXIMUM EMISSION RATE = The owner or operator is using one of the other allowed methods under § 117.3020(e)(1) - (3) to provide substitute emissions compliance when the NO <sub>x</sub> monitor is off-line. AMMONIA USE = Ammonia injection is not used to control NO <sub>x</sub> emissions.	
GRP-B-1	30 TAC Chapter	R7UT-2	DATE PLACED IN SERVICE = Before December 31, 1995.	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
	117, Subchapter E, Division 1		<p>NOX EMISSION LIMITATION = Unit is complying with the System Cap under 30 TAC § 117.3020.</p> <p>UNIT EXEMPT = The unit does not qualify for any exemptions under the rule.</p> <p>LOCATION = The unit is not a gas-fired steam generator located in Palo Pinto County as specified in 30 TAC § 117.3005(a).</p> <p>NOX MONITORING = A continuous emissions monitoring system is used to monitor NO<sub>x</sub> emissions.</p> <p>MAXIMUM EMISSION RATE = The owner or operator is using one of the other allowed methods under § 117.3020(e)(1) - (3) to provide substitute emissions compliance when the NO<sub>x</sub> monitor is off-line.</p> <p>AMMONIA USE = Ammonia injection is not used to control NO<sub>x</sub> emissions.</p>	
GRP-B-1	40 CFR Part 60, Subpart Da	60Da-1	<p>40 CFR 60 (NSPS) SUBPART DA CONSTRUCTION/MODIFICATION (RECONSTRUCTION) DATE = AFTER SEPTEMBER 18, 1978 AND ON OR BEFORE JULY 9, 1997</p> <p>FUEL PRETREATMENT = Fuel pretreatment credit is not claimed.</p> <p>40 CFR 60 (NSPS) SUBPART DA UNIT TYPE = Not a resource recovery unit.</p> <p>COMBINED CYCLE SYSTEM = The unit is not used in conjunction with an electric utility combined cycle gas turbine not designed to burn fuels containing 50 percent (by heat input) or more solid derived fuel not meeting the definition of natural gas.</p> <p>HEAT INPUT OF FOSSIL FUEL [NSPS DA] = Heat input of fossil fuel is greater than 250 MMBtu/hr (73 MW).</p> <p>40 CFR 60 (NSPS) SUBPART DA FUEL TYPE #1 = Natural gas.</p> <p>DUCT BURNER = The unit is not a duct burner.</p> <p>OPACITY MONITORING TYPE = Continuous monitoring system for opacity (COMS).</p> <p>SULFUR DIOXIDE (SO<sub>2</sub>) MONITORING TYPE = Continuous emission monitoring system installed to meet the requirements of Part 75 [§ 60.49Da(b)(4)].</p> <p>40 CFR 60 (NSPS) SUBPART DA CHANGES TO EXISTING AFFECTED FACILITY = Changes have not been made to the existing fossil fuel-fired steam generating unit, which was not previously subject to 40 CFR Part 60, Subpart Da, to accommodate the use of fuels not previously fired.</p> <p>NOX MONITORING TYPE = Continuous emission monitoring system installed to meet the requirements of Part 75.</p> <p>COMMERCIAL DEMONSTRATION PERMIT = The EPA Administrator has not issued a commercial demonstration permit (CDP).</p> <p>COMBINED CYCLE TYPE = Not a combined cycle gas turbine.</p> <p>SULFUR DIOXIDE (SO<sub>2</sub>) EMISSION RATE [NSPS DA] = SO<sub>2</sub> emission rate is less than 0.20 lb/MMBtu (86 ng/J) heat input.</p> <p>FGD = The facility has a flue gas desulfurization system.</p>	<p>The citations § 60.49Da(g) and [G]§ 60.49Da(s) were removed from the PM Monitoring/Testing requirements since the units do not have a PM CEMS.</p> <p>The citation § 60.51Da(f) was added to the PM (Opacity) Reporting requirements.</p>
GRP-B-1	40 CFR Part 60, Subpart Da	60Da-2	<p>40 CFR 60 (NSPS) SUBPART DA CONSTRUCTION/MODIFICATION (RECONSTRUCTION) DATE = AFTER SEPTEMBER 18, 1978 AND ON OR BEFORE JULY 9, 1997</p> <p>FUEL PRETREATMENT = Fuel pretreatment credit is not claimed.</p> <p>40 CFR 60 (NSPS) SUBPART DA UNIT TYPE = Not a resource recovery unit.</p> <p>COMBINED CYCLE SYSTEM = The unit is not used in conjunction with an electric utility combined cycle gas turbine not designed to burn fuels containing 50 percent (by heat input) or more solid derived fuel not meeting the definition of natural gas.</p> <p>HEAT INPUT OF FOSSIL FUEL [NSPS DA] = Heat input of fossil fuel is greater than 250 MMBtu/hr (73 MW).</p> <p>40 CFR 60 (NSPS) SUBPART DA FUEL TYPE #1 = Solid fossil fuel.</p>	<p>The citations § 60.49Da(g) and [G]§ 60.49Da(s) were removed from the PM Monitoring/Testing requirements since the units do not have a PM CEMS.</p> <p>The citation § 60.51Da(f) was added to the PM (Opacity) Reporting requirements.</p>

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>DUCT BURNER = The unit is not a duct burner.</p> <p>OPACITY MONITORING TYPE = Continuous monitoring system for opacity (COMS).</p> <p>SULFUR DIOXIDE (SO<sub>2</sub>) MONITORING TYPE = Continuous emission monitoring system installed to meet the requirements of Part 75 [§ 60.49Da(b)(4)].</p> <p>40 CFR 60 (NSPS) SUBPART DA CHANGES TO EXISTING AFFECTED FACILITY = Changes have not been made to the existing fossil fuel-fired steam generating unit, which was not previously subject to 40 CFR Part 60, Subpart Da, to accommodate the use of fuels not previously fired.</p> <p>NOX MONITORING TYPE = Continuous emission monitoring system installed to meet the requirements of Part 75.</p> <p>COMMERCIAL DEMONSTRATION PERMIT = The EPA Administrator has not issued a commercial demonstration permit (CDP).</p> <p>COMBINED CYCLE TYPE = Not a combined cycle gas turbine.</p> <p>SULFUR DIOXIDE (SO<sub>2</sub>) EMISSION RATE [NSPS DA] = SO<sub>2</sub> emission rate is greater than or equal to 0.20 lb/MMBtu (86 ng/J) heat input but less than or equal to 0.60 lb/MMBtu (260 ng/J) heat input.</p> <p>FGD = The facility has a flue gas desulfurization system.</p>	
GRP-B-1	40 CFR Part 60, Subpart Da	60Da-3	<p>40 CFR 60 (NSPS) SUBPART DA CONSTRUCTION/MODIFICATION (RECONSTRUCTION) DATE = AFTER SEPTEMBER 18, 1978 AND ON OR BEFORE JULY 9, 1997</p> <p>FUEL PRETREATMENT = Fuel pretreatment credit is not claimed.</p> <p>40 CFR 60 (NSPS) SUBPART DA UNIT TYPE = Not a resource recovery unit.</p> <p>COMBINED CYCLE SYSTEM = The unit is not used in conjunction with an electric utility combined cycle gas turbine not designed to burn fuels containing 50 percent (by heat input) or more solid derived fuel not meeting the definition of natural gas.</p> <p>HEAT INPUT OF FOSSIL FUEL [NSPS DA] = Heat input of fossil fuel is greater than 250 MMBtu/hr (73 MW).</p> <p>40 CFR 60 (NSPS) SUBPART DA FUEL TYPE #1 = Natural gas.</p> <p>40 CFR 60 (NSPS) SUBPART DA FUEL TYPE #2 = Solid fossil fuel.</p> <p>OPACITY MONITORING TYPE = Continuous monitoring system for opacity (COMS).</p> <p>SULFUR DIOXIDE (SO<sub>2</sub>) MONITORING TYPE = Continuous emission monitoring system installed to meet the requirements of Part 75 [§ 60.49Da(b)(4)].</p> <p>40 CFR 60 (NSPS) SUBPART DA CHANGES TO EXISTING AFFECTED FACILITY = Changes have not been made to the existing fossil fuel-fired steam generating unit, which was not previously subject to 40 CFR Part 60, Subpart Da, to accommodate the use of fuels not previously fired.</p> <p>NOX MONITORING TYPE = Continuous emission monitoring system installed to meet the requirements of Part 75.</p> <p>COMMERCIAL DEMONSTRATION PERMIT = The EPA Administrator has not issued a commercial demonstration permit (CDP).</p> <p>COMBINED CYCLE TYPE = Not a combined cycle gas turbine.</p> <p>SULFUR DIOXIDE (SO<sub>2</sub>) EMISSION RATE [NSPS DA] = SO<sub>2</sub> emission rate is greater than or equal to 0.20 lb/MMBtu (86 ng/J) heat input but less than or equal to 0.60 lb/MMBtu (260 ng/J) heat input.</p> <p>FGD = The facility has a flue gas desulfurization system.</p>	<p>The citations § 60.49Da(g) and [G]§ 60.49Da(s) were removed from the PM Monitoring/Testing requirements since the units do not have a PM CEMS.</p> <p>The citation § 60.51Da(f) was added to the PM (Opacity) Reporting requirements.</p>
GRP-B-1	40 CFR Part 60, Subpart Da	60Da-4	<p>40 CFR 60 (NSPS) SUBPART DA CONSTRUCTION/MODIFICATION (RECONSTRUCTION) DATE = AFTER SEPTEMBER 18, 1978 AND ON OR BEFORE JULY 9, 1997</p>	<p>The citations § 60.49Da(g) and [G]§ 60.49Da(s) were removed from the PM</p>

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>FUEL PRETREATMENT = Fuel pretreatment credit is not claimed.</p> <p>40 CFR 60 (NSPS) SUBPART DA UNIT TYPE = Not a resource recovery unit.</p> <p>COMBINED CYCLE SYSTEM = The unit is not used in conjunction with an electric utility combined cycle gas turbine not designed to burn fuels containing 50 percent (by heat input) or more solid derived fuel not meeting the definition of natural gas.</p> <p>HEAT INPUT OF FOSSIL FUEL [NSPS DA] = Heat input of fossil fuel is greater than 250 MMBtu/hr (73 MW).</p> <p>40 CFR 60 (NSPS) SUBPART DA FUEL TYPE #1 = Natural gas.</p> <p>40 CFR 60 (NSPS) SUBPART DA FUEL TYPE #2 = Solid fossil fuel.</p> <p>OPACITY MONITORING TYPE = Continuous monitoring system for opacity (COMS).</p> <p>40 CFR 60 (NSPS) SUBPART DA FUEL TYPE #3 = Other solid fossil fuel derived from another solid fossil fuel.</p> <p>SULFUR DIOXIDE (SO<sub>2</sub>) MONITORING TYPE = Continuous emission monitoring system installed to meet the requirements of Part 75 [§ 60.49Da(b)(4)].</p> <p>40 CFR 60 (NSPS) SUBPART DA CHANGES TO EXISTING AFFECTED FACILITY = Changes have not been made to the existing fossil fuel-fired steam generating unit, which was not previously subject to 40 CFR Part 60, Subpart Da, to accommodate the use of fuels not previously fired.</p> <p>NOX MONITORING TYPE = Continuous emission monitoring system installed to meet the requirements of Part 75.</p> <p>COMMERCIAL DEMONSTRATION PERMIT = The EPA Administrator has not issued a commercial demonstration permit (CDP).</p> <p>COMBINED CYCLE TYPE = Not a combined cycle gas turbine.</p> <p>SULFUR DIOXIDE (SO<sub>2</sub>) EMISSION RATE [NSPS DA] = SO<sub>2</sub> emission rate is greater than or equal to 0.20 lb/MMBtu (86 ng/J) heat input but less than or equal to 0.60 lb/MMBtu (260 ng/J) heat input.</p> <p>FGD = The facility has a flue gas desulfurization system.</p>	<p>Monitoring/Testing requirements since the units do not have a PM CEMS.</p> <p>The citation § 60.51Da(f) was added to the PM (Opacity) Reporting requirements.</p>
GRP-B-1	40 CFR Part 60, Subpart Da	60Da-5	<p>40 CFR 60 (NSPS) SUBPART DA CONSTRUCTION/MODIFICATION (RECONSTRUCTION) DATE = AFTER SEPTEMBER 18, 1978 AND ON OR BEFORE JULY 9, 1997</p> <p>FUEL PRETREATMENT = Fuel pretreatment credit is not claimed.</p> <p>40 CFR 60 (NSPS) SUBPART DA UNIT TYPE = Not a resource recovery unit.</p> <p>COMBINED CYCLE SYSTEM = The unit is not used in conjunction with an electric utility combined cycle gas turbine not designed to burn fuels containing 50 percent (by heat input) or more solid derived fuel not meeting the definition of natural gas.</p> <p>HEAT INPUT OF FOSSIL FUEL [NSPS DA] = Heat input of fossil fuel is greater than 250 MMBtu/hr (73 MW).</p> <p>40 CFR 60 (NSPS) SUBPART DA FUEL TYPE #1 = Solid fossil fuel.</p> <p>40 CFR 60 (NSPS) SUBPART DA FUEL TYPE #2 = Other solid fossil fuel derived from another solid fossil fuel.</p> <p>OPACITY MONITORING TYPE = Continuous monitoring system for opacity (COMS).</p> <p>SULFUR DIOXIDE (SO<sub>2</sub>) MONITORING TYPE = Continuous emission monitoring system installed to meet the requirements of Part 75 [§ 60.49Da(b)(4)].</p> <p>40 CFR 60 (NSPS) SUBPART DA CHANGES TO EXISTING AFFECTED FACILITY = Changes have not been made to the existing fossil fuel-fired steam generating unit, which was not previously subject to 40 CFR Part 60, Subpart Da, to accommodate the use of fuels not previously fired.</p> <p>NOX MONITORING TYPE = Continuous emission monitoring system installed to meet the requirements of Part 75.</p>	<p>The citations § 60.49Da(g) and [G]§ 60.49Da(s) were removed from the PM Monitoring/Testing requirements since the units do not have a PM CEMS.</p> <p>The citation § 60.51Da(f) was added to the PM (Opacity) Reporting requirements.</p>

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			<p>COMMERCIAL DEMONSTRATION PERMIT = The EPA Administrator has not issued a commercial demonstration permit (CDP).</p> <p>COMBINED CYCLE TYPE = Not a combined cycle gas turbine.</p> <p>SULFUR DIOXIDE (SO<sub>2</sub>) EMISSION RATE [NSPS DA] = SO<sub>2</sub> emission rate is greater than or equal to 0.20 lb/MMBtu (86 ng/J) heat input but less than or equal to 0.60 lb/MMBtu (260 ng/J) heat input.</p> <p>FGD = The facility has a flue gas desulfurization system.</p>	
FH-10	40 CFR Part 60, Subpart Y	60Y-1A	<p>Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems.</p> <p>Design Capacity = Design capacity is greater than 200 tons of coal per day.</p> <p>Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.</p>	
FH-10	40 CFR Part 60, Subpart Y	60Y-1A	<p>Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems.</p> <p>Construction/Reconstruction/Modification Date =</p>	
FH-11	40 CFR Part 60, Subpart Y	60Y-1A	<p>Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems.</p> <p>Design Capacity = Design capacity is greater than 200 tons of coal per day.</p> <p>Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.</p>	
FH-11	40 CFR Part 60, Subpart Y	60Y-1A	<p>Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems.</p> <p>Construction/Reconstruction/Modification Date =</p>	
FH-12	40 CFR Part 60, Subpart Y	60Y-1A	<p>Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems.</p> <p>Design Capacity = Design capacity is greater than 200 tons of coal per day.</p> <p>Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.</p>	
FH-12	40 CFR Part 60, Subpart Y	60Y-1A	<p>Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems.</p> <p>Construction/Reconstruction/Modification Date =</p>	
FH-13	40 CFR Part 60, Subpart Y	60Y-1A	<p>Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems.</p> <p>Design Capacity = Design capacity is greater than 200 tons of coal per day.</p> <p>Federally Enforceable Limit Option = The plant chooses not to operate under a</p>	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
			federally enforceable limit of less than 200 tons per day.	
FH-13	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems. Construction/Reconstruction/Modification Date =	
FH-14	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems. Design Capacity = Design capacity is greater than 200 tons of coal per day. Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-14	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems. Construction/Reconstruction/Modification Date =	
FH-1A	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems. Design Capacity = Design capacity is greater than 200 tons of coal per day. Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-1A	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems. Construction/Reconstruction/Modification Date =	
FH-1B	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems. Design Capacity = Design capacity is greater than 200 tons of coal per day. Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-1B	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems. Construction/Reconstruction/Modification Date =	
FH-1C	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems. Design Capacity = Design capacity is greater than 200 tons of coal per day. Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	

<b>Unit ID</b>	<b>Regulation</b>	<b>Index Number</b>	<b>Basis of Determination*</b>	<b>Changes and Exceptions to DSS**</b>
FH-1C	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems. Construction/Reconstruction/Modification Date =	
FH-2	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems. Design Capacity = Design capacity is greater than 200 tons of coal per day. Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-2	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems. Construction/Reconstruction/Modification Date =	
FH-3A	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems. Design Capacity = Design capacity is greater than 200 tons of coal per day. Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-3A	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems. Construction/Reconstruction/Modification Date =	
FH-3B	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems. Design Capacity = Design capacity is greater than 200 tons of coal per day. Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-3B	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems. Construction/Reconstruction/Modification Date =	
FH-4	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems. Design Capacity = Design capacity is greater than 200 tons of coal per day. Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-4	40 CFR Part 60,	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage	

<b>Unit ID</b>	<b>Regulation</b>	<b>Index Number</b>	<b>Basis of Determination*</b>	<b>Changes and Exceptions to DSS**</b>
	Subpart Y		systems (excluding open storage piles), or coal transfer and loading systems. Construction/Reconstruction/Modification Date =	
FH-5	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems. Design Capacity = Design capacity is greater than 200 tons of coal per day. Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-5	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems. Construction/Reconstruction/Modification Date =	
FH-6	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems. Design Capacity = Design capacity is greater than 200 tons of coal per day. Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-6	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems. Construction/Reconstruction/Modification Date =	
FH-8A	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems. Design Capacity = Design capacity is greater than 200 tons of coal per day. Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-8A	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems. Construction/Reconstruction/Modification Date =	
FH-8B	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems. Design Capacity = Design capacity is greater than 200 tons of coal per day. Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-8B	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems.	

<b>Unit ID</b>	<b>Regulation</b>	<b>Index Number</b>	<b>Basis of Determination*</b>	<b>Changes and Exceptions to DSS**</b>
			Construction/Reconstruction/Modification Date =	
FH-8C	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems.  Design Capacity = Design capacity is greater than 200 tons of coal per day.  Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-8C	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems.  Construction/Reconstruction/Modification Date =	
FH-8D	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems.  Design Capacity = Design capacity is greater than 200 tons of coal per day.  Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-8D	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems.  Construction/Reconstruction/Modification Date =	
FH-9A	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems.  Design Capacity = Design capacity is greater than 200 tons of coal per day.  Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-9A	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems.  Construction/Reconstruction/Modification Date =	
FH-9B	40 CFR Part 60, Subpart Y	60Y-1A	Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems.  Design Capacity = Design capacity is greater than 200 tons of coal per day.  Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.	
FH-9B	40 CFR Part 60, Subpart Y	60Y-1A	Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems.  Construction/Reconstruction/Modification Date =	

Unit ID	Regulation	Index Number	Basis of Determination*	Changes and Exceptions to DSS**
GRP-FH-1	40 CFR Part 60, Subpart Y	60Y-1A	<p>Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems.</p> <p>Design Capacity = Design capacity is greater than 200 tons of coal per day.</p> <p>Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.</p>	
GRP-FH-1	40 CFR Part 60, Subpart Y	60Y-1A	<p>Affected Facility = Coal processing and conveying equipment (including breakers and crushers), coal storage systems (excluding open storage piles), or coal transfer and loading systems.</p> <p>Construction/Reconstruction/Modification Date =</p>	
PLTFUELHDL	40 CFR Part 60, Subpart Y	60Y-1A	<p>Coal Preparation Plant = Coal preparation plant contains thermal dryers, pneumatic coal-cleaning equipment (air tables), coal processing and conveying equipment (including breakers and crushers), coal storage systems or coal transfer and loading systems.</p> <p>Design Capacity = Design capacity is greater than 200 tons of coal per day.</p> <p>Federally Enforceable Limit Option = The plant chooses not to operate under a federally enforceable limit of less than 200 tons per day.</p>	
GRP-BSTK-1	30 TAC Chapter 111, Visible Emissions	R1111-1	<p>Alternate Opacity Limitation = Not complying with an alternate opacity limit under 30 TAC § 111.113.</p> <p>Annual ACF = Annual average capacity factor is greater than 30%, as reported to the Federal Power Commission for calendar year 1974</p> <p>Heat Input = Heat Input is greater than 250 MMBtu/hr.</p> <p>Vent Source = The source of the vent is a steam generator fired by solid fossil fuel.</p> <p>Opacity Monitoring System = A continuous emissions monitoring system (CEMS) capable of measuring the opacity of emissions is installed in the vent in accordance with 30 TAC § 111.111(a)(1)(C).</p> <p>Construction Date = After January 31, 1972</p> <p>Effluent Flow Rate = Effluent flow rate is at least 100,000 actual cubic feet per minute.</p>	

\* - The "unit attributes" or operating conditions that determine what requirements apply

\*\* - Notes changes made to the automated results from the DSS, and a brief explanation why

## NSR Versus Title V FOP

The state of Texas has two Air permitting programs, New Source Review (NSR) and Title V Federal Operating Permits. The two programs are substantially different both in intent and permit content.

NSR is a preconstruction permitting program authorized by the Texas Clean Air Act and Title I of the Federal Clean Air Act (FCAA). The processing of these permits is governed by 30 Texas Administrative Code (TAC) Chapter 116.111. The Title V Federal Operating Program is a federal program authorized under Title V of the FCAA that has been delegated to the state of Texas to administer and is governed by 30 TAC Chapter 122. The major differences between the two permitting programs are listed in the table below:

NSR Permit	Federal Operating Permit(FOP)
Issued Prior to new Construction or modification of an existing facility	For initial permit with application shield, can be issued after operation commences; significant revisions require approval prior to operation.
Authorizes air emissions	Codifies existing applicable requirements, does not authorize new emissions
Ensures issued permits are protective of the environment and human health by conducting a health effects review and that requirement for best available control technology (BACT) is implemented.	Applicable requirements listed in permit are used by the inspectors to ensure proper operation of the site as authorized. Ensures that adequate monitoring is in place to allow compliance determination with the FOP.
Up to two Public notices may be required. Opportunity for public comment and contested case hearings for some authorizations.	One public notice required. Opportunity for public comments. No contested case hearings.
Applies to all point source emissions in the state.	Applies to all major sources and some non-major sources identified by the EPA.
Applies to facilities: a portion of site or individual emission sources	One or multiple FOPs cover the entire site (consists of multiple facilities)
Permits include terms and conditions under which the applicant must construct and operate its various equipment and processes on a facility basis.	Permits include terms and conditions that specify the general operational requirements of the site; and also include codification of all applicable requirements for emission units at the site.
Opportunity for EPA review for Federal Prevention of Significant Deterioration (PSD) and Nonattainment (NA) permits for major sources.	Opportunity for EPA review, Affected states review, and a Public petition period for every FOP.
Permits have a table listing maximum emission limits for pollutants	Permit has an applicable requirements table and Periodic Monitoring (PM) / Compliance Assurance Monitoring (CAM) tables which document applicable monitoring requirements.
Permits can be altered or amended upon application by company. Permits must be issued before construction or modification of facilities can begin.	Permits can be revised through several revision processes, which provide for different levels of public notice and opportunity to comment. Changes that would be significant revisions require that a revised permit be issued before those changes can be operated.
NSR permits are issued independent of FOP requirements.	FOP are independent of NSR permits, but contain a list of all NSR permits incorporated by reference

## New Source Review Requirements

Below is a list of the New Source Review (NSR) permits for the permitted area. These NSR permits are incorporated by reference into the operating permit and are enforceable under it. These permits can be found in the main TCEQ file room, located on the first floor of Building E, 12100 Park 35 Circle, Austin, Texas. The

Public Education Program may be contacted at 1-800-687-4040 or the Air Permits Division (APD) may be contacted at 1-512-239-1250 for help with any question.

Additionally, the site contains emission units that are permitted by rule under the requirements of 30 TAC Chapter 106, Permits by Rule. The following table specifies the permits by rule that apply to the site. All current permits by rule are contained in Chapter 106. Outdated 30 TAC Chapter 106 permits by rule may be viewed at the following Web site:

[www.tceq.texas.gov/permitting/air/permitbyrule/historical\\_rules/old106list/index106.html](http://www.tceq.texas.gov/permitting/air/permitbyrule/historical_rules/old106list/index106.html)

Outdated Standard Exemption lists may be viewed at the following Web site:

[www.tceq.texas.gov/permitting/air/permitbyrule/historical\\_rules/oldselist/se\\_index.html](http://www.tceq.texas.gov/permitting/air/permitbyrule/historical_rules/oldselist/se_index.html)

<b>Prevention of Significant Deterioration (PSD) Permits</b>	
PSD Permit No.: PSDTX371M5	Issuance Date: 12/20/2013
<b>Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.</b>	
Authorization No.: 51712	Issuance Date: 03/22/2012
Authorization No.: 8576	Issuance Date: 12/20/2013
Authorization No.: 8579	Issuance Date: 12/20/2013
<b>Permits By Rule (30 TAC Chapter 106) for the Application Area</b>	
Number: 106.144	Version No./Date: 09/04/2000
Number: 106.261	Version No./Date: 12/24/1998
Number: 106.262	Version No./Date: 09/04/2000
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.264	Version No./Date: 09/04/2000
Number: 106.452	Version No./Date: 09/04/2000
Number: 106.454	Version No./Date: 11/01/2001
Number: 106.477	Version No./Date: 09/04/2000
Number: 106.533	Version No./Date: 09/04/2000
Number: 5	Version No./Date: 06/07/1996
Number: 8	Version No./Date: 06/07/1996
Number: 14	Version No./Date: 06/07/1996
Number: 34	Version No./Date: 06/07/1996
Number: 39	Version No./Date: 06/07/1996
Number: 51	Version No./Date: 06/07/1996
Number: 53	Version No./Date: 06/07/1996
Number: 61	Version No./Date: 06/07/1996

Number: 68	Version No./Date: 06/07/1996
Number: 107	Version No./Date: 06/07/1996

**Emission Units and Emission Points**

In air permitting terminology, any source capable of generating emissions (for example, an engine or a sandblasting area) is called an Emission Unit. For purposes of Title V, emission units are specifically listed in the operating permit when they have applicable requirements other than New Source Review (NSR), or when they are listed in the permit shield table.

The actual physical location where the emissions enter the atmosphere (for example, an engine stack or a sandblasting yard) is called an emission point. For New Source Review preconstruction permitting purposes, every emission unit has an associated emission point. Emission limits are listed in an NSR permit, associated with an emission point. This list of emission points and emission limits per pollutant is commonly referred to as the “Maximum Allowable Emission Rate Table”, or “MAERT” for short. Specifically, the MAERT lists the Emission Point Number (EPN) that identifies the emission point, followed immediately by the Source Name, identifying the emission unit that is the source of those emissions on this table.

Thus, by reference, an emission unit in a Title V operating permit is linked by reference number to an NSR authorization, and its related emission point.

**Monitoring Sufficiency**

Federal and state rules, 40 CFR § 70.6(a)(3)(i)(B) and 30 TAC § 122.142(c) respectively, require that each federal operating permit include additional monitoring for applicable requirements that lack periodic or instrumental monitoring (which may include recordkeeping that serves as monitoring) that yields reliable data from a relevant time period that are representative of the emission unit’s compliance with the applicable emission limitation or standard. Furthermore, the federal operating permit must include compliance assurance monitoring (CAM) requirements for emission sources that meet the applicability criteria of 40 CFR Part 64 in accordance with 40 CFR § 70.6(a)(3)(i)(A) and 30 TAC § 122.604(b).

With the exception of any emission units listed in the Periodic Monitoring or CAM Summaries in the FOP, the TCEQ Executive Director has determined that the permit contains sufficient monitoring, testing, recordkeeping, and reporting requirements that assure compliance with the applicable requirements. If applicable, each emission unit that requires additional monitoring in the form of periodic monitoring or CAM is described in further detail under the Rationale for CAM/PM Methods Selected section following this paragraph.

**Rationale for Compliance Assurance Monitoring (CAM)/ Periodic Monitoring Methods Selected**

**Periodic Monitoring:**

The Federal Clean Air Act requires that each federal operating permit include monitoring sufficient to assure compliance with the terms and conditions of the permit. Most of the emission limits and standards applicable to emission units at Title V sources include adequate monitoring to show that the units meet the limits and standards. For those requirements that do not include monitoring, or where the monitoring is not sufficient to assure compliance, the federal operating permit must include such monitoring for the emission units affected. The following emission units are subject to periodic monitoring requirements because the emission units are subject to an emission limitation or standard for an air pollutant (or surrogate thereof) in an applicable requirement that does not already require monitoring, or the monitoring for the applicable requirement is not sufficient to assure compliance:

<b>Unit/Group/Process Information</b>	
ID No.: GRP-FH-1	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 40 CFR Part 60, Subpart Y	SOP Index No.: 60Y-1A
Pollutant: PM (OPACITY)	Main Standard: § 60.254(a)
<b>Monitoring Information</b>	
Indicator: Visible Emissions	
Minimum Frequency: Once per week	
Averaging Period: n/a	
Deviation Limit: An opacity reading greater than 20% is a deviation	
<p>Basis of monitoring:  The option to perform opacity readings or visible emissions to demonstrate compliance is consistent with EPA Reference Test Method 9 and 22. Opacity and visible emissions have been used as an indicator of particulate emissions in many federal rules including 40 CFR Part 60, Subpart F and Subpart HH. In addition, use of these indicators is consistent with the EPA's "Compliance Assurance Monitoring (CAM) Technical Guidance Document" (August 1998). Monitoring specifications and procedures for the opacity are consistent with federal requirements and include the EPA's Test Method 9 for determining opacity by visual observations and the requirements of 40 CFR § 60.13 for a continuous opacity monitoring system (COMS). The monitoring specifications and procedures for the visible emissions monitoring are similar to "EPA Reference Method 22" procedures.</p>	

**Compliance Assurance Monitoring (CAM):**

Compliance Assurance Monitoring (CAM) is a federal monitoring program established under Title 40 Code of Federal Regulations Part 64 (40 CFR Part 64).

Emission units are subject to CAM requirements if they meet the following criteria:

1. the emission unit is subject to an emission limitation or standard for an air pollutant (or surrogate thereof) in an applicable requirement;
2. the emission unit uses a control device to achieve compliance with the emission limitation or standard specified in the applicable requirement; and
3. the emission unit has the pre-control device potential to emit greater than or equal to the amount in tons per year for a site to be classified as a major source.

The following table(s) identify the emission unit(s) that are subject to CAM:

<b>Unit/Group/Process Information</b>	
ID No.: GRP-B-1	
Control Device ID No.: ESP	Control Device Type: Wet or Dry Electrostatic Precipitator
<b>Applicable Regulatory Requirement</b>	
Name: 40 CFR Part 60, Subpart Da	SOP Index No.: 60Da-1, 60Da-2, 60Da-3, 60Da-4, 60Da-5
Pollutant: PM	Main Standard: § 60.42Da(a)(1)
<b>Monitoring Information</b>	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: Greater than 15% opacity (six-minute average) is a deviation.	
Basis of CAM: The option to perform opacity readings or visible emissions to demonstrate compliance is consistent with EPA Reference Test Method 9 and 22. Opacity and visible emissions have been used as an indicator of particulate emissions in many federal rules including 40 CFR Part 60, Subpart F and Subpart HH. In addition, use of these indicators is consistent with the EPA's "Compliance Assurance Monitoring (CAM) Technical Guidance Document" (August 1998). Monitoring specifications and procedures for the opacity are consistent with federal requirements and include the EPA's Test Method 9 for determining opacity by visual observations and the requirements of 40 CFR § 60.13 for a continuous opacity monitoring system (COMS). The monitoring specifications and procedures for the visible emissions monitoring are similar to "EPA Reference Method 22" procedures.	

<b>Unit/Group/Process Information</b>	
ID No.: GRP-B-1	
Control Device ID No.: ESP	Control Device Type: Wet or Dry Electrostatic Precipitator
<b>Applicable Regulatory Requirement</b>	
Name: 40 CFR Part 60, Subpart Da	SOP Index No.: 60Da-1, 60Da-2, 60Da-3, 60Da-4, 60Da-5
Pollutant: PM (OPACITY)	Main Standard: § 60.42Da(b)
<b>Monitoring Information</b>	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: Greater than 15% opacity (six-minute average) is a deviation.	
<p>Basis of CAM: The option to perform opacity readings or visible emissions to demonstrate compliance is consistent with EPA Reference Test Method 9 and 22. Opacity and visible emissions have been used as an indicator of particulate emissions in many federal rules including 40 CFR Part 60, Subpart F and Subpart HH. In addition, use of these indicators is consistent with the EPA's "Compliance Assurance Monitoring (CAM) Technical Guidance Document" (August 1998). Monitoring specifications and procedures for the opacity are consistent with federal requirements and include the EPA's Test Method 9 for determining opacity by visual observations and the requirements of 40 CFR § 60.13 for a continuous opacity monitoring system (COMS). The monitoring specifications and procedures for the visible emissions monitoring are similar to "EPA Reference Method 22" procedures.</p>	

<b>Unit/Group/Process Information</b>	
ID No.: GRP-BSTK-1	
Control Device ID No.: ESP	Control Device Type: Wet or Dry Electrostatic Precipitator
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(B)
<b>Monitoring Information</b>	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: Greater than 15% opacity (6 minute average) is a deviation.	
Basis of CAM: The option to perform opacity readings or visible emissions to demonstrate compliance is consistent with EPA Reference Test Method 9 and 22. Opacity and visible emissions have been used as an indicator of particulate emissions in many federal rules including 40 CFR Part 60, Subpart F and Subpart HH. In addition, use of these indicators is consistent with the EPA's "Compliance Assurance Monitoring (CAM) Technical Guidance Document" (August 1998). Monitoring specifications and procedures for the opacity are consistent with federal requirements and include the EPA's Test Method 9 for determining opacity by visual observations and the requirements of 40 CFR § 60.13 for a continuous opacity monitoring system (COMS). The monitoring specifications and procedures for the visible emissions monitoring are similar to "EPA Reference Method 22" procedures.	

**Compliance Review**

1. In accordance with 30 TAC Chapter 60, the compliance history was reviewed on 01/06/2014.
2. The compliance history review evaluated the period from 07/19/2008 to 07/19/2013.  
 Site rating: 0      Company rating: 0.01  
*(High < 0.10; Satisfactory > 0.10 and < 55; Unsatisfactory > 55)*
3. Has the permit changed on the basis of the compliance history or site/company rating? .....No

## Available Unit Attribute Forms

OP-UA1 - Miscellaneous and Generic Unit Attributes  
OP-UA2 - Stationary Reciprocating Internal Combustion Engine Attributes  
OP-UA3 - Storage Tank/Vessel Attributes  
OP-UA4 - Loading/Unloading Operations Attributes  
OP-UA5 - Process Heater/Furnace Attributes  
OP-UA6 - Boiler/Steam Generator/Steam Generating Unit Attributes  
OP-UA7 - Flare Attributes  
OP-UA8 - Coal Preparation Plant Attributes  
OP-UA9 - Nonmetallic Mineral Process Plant Attributes  
OP-UA10 - Gas Sweetening/Sulfur Recovery Unit Attributes  
OP-UA11 - Stationary Turbine Attributes  
OP-UA12 - Fugitive Emission Unit Attributes  
OP-UA13 - Industrial Process Cooling Tower Attributes  
OP-UA14 - Water Separator Attributes  
OP-UA15 - Emission Point/Stationary Vent/Distillation Operation/Process Vent Attributes  
OP-UA16 - Solvent Degreasing Machine Attributes  
OP-UA17 - Distillation Unit Attributes  
OP-UA18 - Surface Coating Operations Attributes  
OP-UA19 - Wastewater Unit Attributes  
OP-UA20 - Asphalt Operations Attributes  
OP-UA21 - Grain Elevator Attributes  
OP-UA22 - Printing Attributes  
OP-UA24 - Wool Fiberglass Insulation Manufacturing Plant Attributes  
OP-UA25 - Synthetic Fiber Production Attributes  
OP-UA26 - Electroplating and Anodizing Unit Attributes  
OP-UA27 - Nitric Acid Manufacturing Attributes  
OP-UA28 - Polymer Manufacturing Attributes  
OP-UA29 - Glass Manufacturing Unit Attributes  
OP-UA30 - Kraft, Soda, Sulfite, and Stand-Alone Semicheical Pulp Mill Attributes  
OP-UA31 - Lead Smelting Attributes  
OP-UA32 - Copper and Zinc Smelting/Brass and Bronze Production Attributes  
OP-UA33 - Metallic Mineral Processing Plant Attributes  
OP-UA34 - Pharmaceutical Manufacturing  
OP-UA35 - Incinerator Attributes  
OP-UA36 - Steel Plant Unit Attributes  
OP-UA37 - Basic Oxygen Process Furnace Unit Attributes  
OP-UA38 - Lead-Acid Battery Manufacturing Plant Attributes  
OP-UA39 - Sterilization Source Attributes  
OP-UA40 - Ferroalloy Production Facility Attributes  
OP-UA41 - Dry Cleaning Facility Attributes  
OP-UA42 - Phosphate Fertilizer Manufacturing Attributes  
OP-UA43 - Sulfuric Acid Production Attributes  
OP-UA44 - Municipal Solid Waste Landfill/Waste Disposal Site Attributes  
OP-UA45 - Surface Impoundment Attributes  
OP-UA46 - Epoxy Resins and Non-Nylon Polyamides Production Attributes  
OP-UA47 - Ship Building and Ship Repair Unit Attributes  
OP-UA48 - Air Oxidation Unit Process Attributes  
OP-UA49 - Vacuum-Producing System Attributes  
OP-UA50 - Fluid Catalytic Cracking Unit Catalyst Regenerator/Fuel Gas Combustion Device/Claus Sulfur Recovery Plant Attributes  
OP-UA51 - Dryer/Kiln/Oven Attributes  
OP-UA52 - Closed Vent Systems and Control Devices  
OP-UA53 - Beryllium Processing Attributes  
OP-UA54 - Mercury Chlor-Alkali Cell Attributes  
OP-UA55 - Transfer System Attributes  
OP-UA56 - Vinyl Chloride Process Attributes  
OP-UA57 - Cleaning/Depainting Operation Attributes  
OP-UA58 - Treatment Process Attributes  
OP-UA59 - Coke By-Product Recovery Plant Attributes  
OP-UA60 - Chemical Manufacturing Process Unit Attributes  
OP-UA61 - Pulp, Paper, or Paperboard Producing Process Attributes  
OP-UA62 - Glycol Dehydration Unit Attributes  
OP-UA63 - Vegetable Oil Production Attributes