

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO

Alcon Laboratories, Inc.

AUTHORIZING THE OPERATION OF

Fort Worth Campus
Pharmaceutical Preparations

LOCATED AT

Tarrant County, Texas

Latitude 32° 39' 27" Longitude 097° 19' 01"

Regulated Entity Number: RN100218007

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: O2304 Issuance Date: _____

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting	1
Additional Monitoring Requirements	10
New Source Review Authorization Requirements	10
Compliance Requirements.....	11
Protection of Stratospheric Ozone.....	13
Permit Location.....	14
Permit Shield (30 TAC § 122.148)	14
Attachments	15
Applicable Requirements Summary	16
Additional Monitoring Requirements	35
Permit Shield.....	42
New Source Review Authorization References.....	46
Appendix A	51
Acronym List	52

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions: Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.

- C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
 - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.
 - E. Emission units subject to 40 CFR Part 63, Subpart ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.
2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
- A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:

- A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1 , shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
- (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
 - (ii) Title 30 TAC § 111.111(a)(1)(E)
 - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
 - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the “Applicable Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:
 - (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
 - (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.

- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (5) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required

under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
 - (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.
 - (3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the

observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A)
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

C. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)
- (iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following

periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:

- (1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.
- (2) Records of all observations shall be maintained.
- (3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (4) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity

requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- D. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
- E. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
 - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)
 - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
- 4. For storage vessels maintaining working pressure as specified in 30 TAC Chapter 115, Subchapter B, Division 1: Storage of Volatile Organic Compounds, the permit holder shall comply with the requirements of 30 TAC § 115.112(e)(1).
- 5. For industrial wastewater specified in 30 TAC Chapter 115, Subchapter B, the permit holder shall comply with the following requirements for wastewater drains, junction boxes, lift stations and weirs:
 - A. Title 30 TAC § 115.142(1)(E) and (F) (relating to Control Requirements)
 - B. Title 30 TAC § 115.146 (relating to Recordkeeping Requirements)
- 6. Permit holder shall comply with the following 30 TAC Chapter 115, Subchapter C requirements:
 - A. When filling stationary gasoline storage vessels (Stage I) for motor vehicle fuel dispensing facilities, constructed prior to November 15, 1992, with transfers to stationary storage tanks located at a facility which has dispensed no more than 10,000 gallons of gasoline in any calendar month

after January 1, 1991, the permit holder shall comply with the following requirements specified in 30 TAC Chapter 115, Subchapter C:

- (i) Title 30 TAC § 115.222(7) (relating to Control Requirements)
- (ii) Title 30 TAC § 115.222(3), as it applies to liquid gasoline leaks
- (iii) Title 30 TAC § 115.224(1) (relating to Inspection Requirements), as it applies to liquid gasoline leaks
- (iv) Title 30 TAC § 115.226(2)(B) (relating to Recordkeeping Requirements)

7. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:

- A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
- B. Title 40 CFR § 60.8 (relating to Performance Tests)
- C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
- D. Title 40 CFR § 60.12 (relating to Circumvention)
- E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
- F. Title 40 CFR § 60.14 (relating to Modification)
- G. Title 40 CFR § 60.15 (relating to Reconstruction)
- H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)

8. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.

9. For each gasoline dispensing facility, with a throughput of less than 10,000 gallons per month as specified in 40 CFR Part 63, Subpart CCCCCC, the permit holder shall comply with the following requirements (Title 30 TAC, Subchapter C, § 113.1380 incorporated by reference):

- A. Title 40 CFR § 63.1111(e), for records of monthly throughput
- B. Title 40 CFR § 63.1111(i), for compliance due to increase of throughput
- C. Title 40 CFR § 63.1113(c), for compliance due to increase of throughput

- D. Title 40 CFR § 63.11115(a), for operation of the source
 - E. Title 40 CFR § 63.11116(a) and (a)(1) - (4), for work practices
 - F. Title 40 CFR § 63.11116(b), for records availability
 - G. Title 40 CFR § 63.11116(d), for portable gasoline containers
10. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

Additional Monitoring Requirements

11. The permit holder shall comply with the periodic monitoring requirements as specified in the attached “Periodic Monitoring Summary” upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time specified in the “Periodic Monitoring Summary,” for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

12. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule, standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:

- A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
13. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
14. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, material safety data sheets (MSDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144.
- A. If applicable, monitoring of control device performance or general work practice standards shall be made in accordance with the TCEQ Periodic Monitoring Guidance document.
 - B. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
15. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
- A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
 - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
 - C. Boiler Standard Permit

Compliance Requirements

16. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any

other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.

17. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:
 - A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
 - (i) For sources in the Dallas-Fort Worth Eight-Hour Nonattainment area, 30 TAC § 117.9030
 - B. The permit holder shall comply with the Initial Control Plan unit identification requirements in 30 TAC § 117.450(a) and (a)(1).
 - C. The permit holder shall comply with the requirements of 30 TAC § 117.454 for Final Control Plan Procedures for Attainment Demonstration Emission Specifications and 30 TAC § 117.456 for Revision of Final Control Plan.
18. Use of Emission Credits to comply with applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) Offsets for Title 30 TAC Chapter 116
 - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)(2)
 - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
 - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)(2)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122

19. Use of Discrete Emission Credits to comply with the applicable requirements:
- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
 - B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122

Protection of Stratospheric Ozone

20. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone.
- A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.
 - B. The permit holder shall comply with 40 CFR Part 82, Subpart A for controlling the production, transformation, destruction, export or import

of a controlled (ozone-depleting) substance or product as specified in 40 CFR § 82.1 - § 82.13 and the applicable Part 82 Appendices.

- C. The permit holder shall comply with 40 CFR Part 82, Subpart F related to the disposal requirements for appliances using Class I or Class II (ozone-depleting) substances or non-exempt substitutes as specified in 40 CFR §§ 82.150 - 82.166 and the applicable Part 82 Appendices.
- D. The permit holder shall comply with 40 CFR Part 82, Subpart H related to Halon Emissions Reduction requirements as specified in 40 CFR § 82.250 - § 82.270 and the applicable Part 82 Appendices.
- E. The permit holder shall comply with 40 CFR Part 82, Subpart A, § 82.13 related to recordkeeping and reporting requirements for the production and consumption of ozone depleting substances.

Permit Location

- 21. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

- 22. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Applicable Requirements Summary

Unit Summary17

Applicable Requirements Summary 21

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
BLR-10	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	REG2-3	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
BLR-10	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-4	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Natural gas, SO2 Inlet Monitoring = No SO2 monitoring.
BLR-10	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-5	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Distillate oil, SO2 Inlet Monitoring = Fuel certification (or maintaining receipts).
BLR-11	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	REG2-1	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
BLR-11	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-1	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Natural gas, SO2 Inlet Monitoring = No SO2 monitoring.
BLR-11	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-10	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Distillate oil, SO2 Inlet Monitoring = Fuel certification (or maintaining receipts).
BLR-8	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	REG2-2	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
BLR-8	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-2	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Natural gas, SO2 Inlet Monitoring = No SO2 monitoring.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
BLR-8	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-3	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Distillate oil, SO2 Inlet Monitoring = Fuel certification (or maintaining receipts).
CEPSBLR-15	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	REG2-4	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
CEPSBLR-15	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-6	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Natural gas, SO2 Inlet Monitoring = No SO2 monitoring.
CEPSBLR-15	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-7	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Distillate oil, SO2 Inlet Monitoring = Fuel certification (or maintaining receipts).
CEPSBLR-16	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	REG2-5	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
CEPSBLR-16	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-8	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Natural gas, SO2 Inlet Monitoring = No SO2 monitoring.
CEPSBLR-16	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-9	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Distillate oil, SO2 Inlet Monitoring = Fuel certification (or maintaining receipts).
CEPSBLR-17	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	REG2-6	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
CEPSBLR-17	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-11	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Natural gas, SO2 Inlet Monitoring = No SO2 monitoring.
CEPSBLR-17	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-12	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Distillate oil, SO2 Inlet Monitoring = Fuel certification (or maintaining receipts).
GRPEG1	SRIC ENGINES	EG-CG1, EG-ITL, EG-N, EG-RD3, EG-RD4, EG-S	R7ICI-1	40 CFR Part 63, Subpart <i>ZZZZ</i>	No changing attributes.
GRPEG2	SRIC ENGINES	EG-RD2	R7ICI-2	40 CFR Part 63, Subpart <i>ZZZZ</i>	No changing attributes.
GRPEG3	SRIC ENGINES	EG-CG2, EG-CG3	R7ICI-3	40 CFR Part 63, Subpart <i>ZZZZ</i>	No changing attributes.
GRPEG4	SRIC ENGINES	EG-CGP, EG- CWH, EG-QA, EG- RDAAC, EG-SA	R7ICI-4	40 CFR Part 63, Subpart <i>ZZZZ</i>	No changing attributes.
GRPEG5	SRIC ENGINES	EG-EDC, EG- WDC2	R7ICI-14	40 CFR Part 60, Subpart IIII	No changing attributes.
GRPEG5	SRIC ENGINES	EG-EDC, EG- WDC2	R7ICI-5	40 CFR Part 63, Subpart <i>ZZZZ</i>	No changing attributes.
TANK1	STORAGE TANKS/VESSELS	N/A	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TANK14	STORAGE TANKS/VESSELS	N/A	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
TANK15	STORAGE TANKS/VESSELS	N/A	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TANK2	STORAGE TANKS/VESSELS	N/A	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TANK4	STORAGE TANKS/VESSELS	N/A	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TANK5	STORAGE TANKS/VESSELS	N/A	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLR-10	EU	REG2-3	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(a)	No person may cause, suffer, allow, or permit emissions of SO ₂ from any liquid fuel-fired steam generator, furnace, or heater to exceed 440 ppmv at actual stack conditions and averaged over 3-hours.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)
BLR-10	EU	60DC-4	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BLR-10	EU	60DC-4	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BLR-10	EU	60DC-4	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLR-10	EU	60DC-5	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.42c(d) § 60.40c(c) § 60.42c(h) § 60.42c(i) § 60.42c(j)	On/after the §60.8 test, oil-fired facilities shall not discharge SO ₂ gases in excess of 215 ng/J (0.50 lb/MMBtu) heat input or, alternatively, combust oil with a greater than 0.5 weight % sulfur.	§ 60.44c(a) § 60.44c(d) § 60.44c(h) § 60.44c(j) § 60.46c(e)	[G]§ 60.48c(e) [G]§ 60.48c(f) § 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) § 60.48c(d) [G]§ 60.48c(e) § 60.48c(j)
BLR-10	EU	60DC-5	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BLR-10	EU	60DC-5	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.43c(c) § 60.40c(c) § 60.43c(d) § 60.47c(g)	Facilities firing the specified fuels and that have heat input capacity of 8.7 MW (30 MMBtu/hr) or greater, shall not exhibit opacity greater than 20%, 6-minute average, except as specified.	§ 60.45c(a) § 60.45c(a)(8) § 60.47c(g)	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) [G]§ 60.48c(c) § 60.48c(j)
BLR-11	EU	REG2-1	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(a)	No person may cause, suffer, allow, or permit emissions of SO ₂ from any liquid fuel-fired steam generator, furnace, or heater to exceed 440 ppmv at actual stack conditions and averaged over 3-hours.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLR-11	EU	60DC-1	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BLR-11	EU	60DC-1	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BLR-11	EU	60DC-1	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BLR-11	EU	60DC-10	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.42c(d) § 60.40c(c) § 60.42c(h) § 60.42c(i) § 60.42c(j)	On/after the §60.8 test, oil-fired facilities shall not discharge SO ₂ gases in excess of 215 ng/J (0.50 lb/MMBtu) heat input or, alternatively, combust oil with a greater than 0.5 weight % sulfur.	§ 60.44c(a) § 60.44c(d) § 60.44c(h) § 60.44c(j) § 60.46c(e)	[G]§ 60.48c(e) [G]§ 60.48c(f) § 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) § 60.48c(d) [G]§ 60.48c(e) § 60.48c(j)
BLR-11	EU	60DC-10	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLR-11	EU	60DC-10	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.43c(c) § 60.40c(c) § 60.43c(d) § 60.47c(g)	Facilities firing the specified fuels and that have heat input capacity of 8.7 MW (30 MMBtu/hr) or greater, shall not exhibit opacity greater than 20%, 6-minute average, except as specified.	§ 60.45c(a) § 60.45c(a)(8) § 60.47c(g)	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) [G]§ 60.48c(c) § 60.48c(j)
BLR-8	EU	REG2-2	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(a)	No person may cause, suffer, allow, or permit emissions of SO ₂ from any liquid fuel-fired steam generator, furnace, or heater to exceed 440 ppmv at actual stack conditions and averaged over 3-hours.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)
BLR-8	EU	60DC-2	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BLR-8	EU	60DC-2	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BLR-8	EU	60DC-2	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLR-8	EU	6oDC-3	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.42c(d) § 60.40c(c) § 60.42c(h) § 60.42c(i) § 60.42c(j)	On/after the §60.8 test, oil-fired facilities shall not discharge SO ₂ gases in excess of 215 ng/J (0.50 lb/MMBtu) heat input or, alternatively, combust oil with a greater than 0.5 weight % sulfur.	§ 60.44c(a) § 60.44c(d) § 60.44c(h) § 60.44c(j) § 60.46c(e)	[G]§ 60.48c(e) [G]§ 60.48c(f) § 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) § 60.48c(d) [G]§ 60.48c(e) § 60.48c(j)
BLR-8	EU	6oDC-3	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
BLR-8	EU	6oDC-3	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.43c(c) § 60.40c(c) § 60.43c(d) § 60.47c(g)	Facilities firing the specified fuels and that have heat input capacity of 8.7 MW (30 MMBtu/hr) or greater, shall not exhibit opacity greater than 20%, 6-minute average, except as specified.	§ 60.45c(a) § 60.45c(a)(8) § 60.47c(g)	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) [G]§ 60.48c(c) § 60.48c(j)
CEPSBLR-15	EU	REG2-4	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(a)	No person may cause, suffer, allow, or permit emissions of SO ₂ from any liquid fuel-fired steam generator, furnace, or heater to exceed 440 ppmv at actual stack conditions and averaged over 3-hours.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CEPSBLR-15	EU	60DC-6	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
CEPSBLR-15	EU	60DC-6	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
CEPSBLR-15	EU	60DC-6	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
CEPSBLR-15	EU	60DC-7	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.42c(d) § 60.40c(c) § 60.42c(h) § 60.42c(i) § 60.42c(j)	On/after the §60.8 test, oil-fired facilities shall not discharge SO ₂ gases in excess of 215 ng/J (0.50 lb/MMBtu) heat input or, alternatively, combust oil with a greater than 0.5 weight % sulfur.	§ 60.44c(a) § 60.44c(d) § 60.44c(h) § 60.44c(j) § 60.46c(e)	[G]§ 60.48c(e) [G]§ 60.48c(f) § 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) § 60.48c(d) [G]§ 60.48c(e) § 60.48c(j)
CEPSBLR-15	EU	60DC-7	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CEPSBLR-15	EU	6oDC-7	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.43c(c) § 60.40c(c) § 60.43c(d) § 60.47c(g)	Facilities firing the specified fuels and that have heat input capacity of 8.7 MW (30 MMBtu/hr) or greater, shall not exhibit opacity greater than 20%, 6-minute average, except as specified.	§ 60.45c(a) § 60.45c(a)(8) § 60.47c(g)	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) [G]§ 60.48c(c) § 60.48c(j)
CEPSBLR-16	EU	REG2-5	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(a)	No person may cause, suffer, allow, or permit emissions of SO ₂ from any liquid fuel-fired steam generator, furnace, or heater to exceed 440 ppmv at actual stack conditions and averaged over 3-hours.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)
CEPSBLR-16	EU	6oDC-8	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
CEPSBLR-16	EU	6oDC-8	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
CEPSBLR-16	EU	6oDC-8	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CEPSBLR-16	EU	60DC-9	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.42c(d) § 60.40c(c) § 60.42c(h) § 60.42c(i) § 60.42c(j)	On/after the §60.8 test, oil-fired facilities shall not discharge SO ₂ gases in excess of 215 ng/J (0.50 lb/MMBtu) heat input or, alternatively, combust oil with a greater than 0.5 weight % sulfur.	§ 60.44c(a) § 60.44c(d) § 60.44c(h) § 60.44c(j) § 60.46c(e)	[G]§ 60.48c(e) [G]§ 60.48c(f) § 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) § 60.48c(d) [G]§ 60.48c(e) § 60.48c(j)
CEPSBLR-16	EU	60DC-9	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
CEPSBLR-16	EU	60DC-9	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.43c(c) § 60.40c(c) § 60.43c(d) § 60.47c(g)	Facilities firing the specified fuels and that have heat input capacity of 8.7 MW (30 MMBtu/hr) or greater, shall not exhibit opacity greater than 20%, 6-minute average, except as specified.	§ 60.45c(a) § 60.45c(a)(8) § 60.47c(g)	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) [G]§ 60.48c(c) § 60.48c(j)
CEPSBLR-17	EU	REG2-6	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(a)	No person may cause, suffer, allow, or permit emissions of SO ₂ from any liquid fuel-fired steam generator, furnace, or heater to exceed 440 ppmv at actual stack conditions and averaged over 3-hours.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CEPSBLR-17	EU	60DC-11	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
CEPSBLR-17	EU	60DC-11	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
CEPSBLR-17	EU	60DC-11	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
CEPSBLR-17	EU	60DC-12	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.42c(d) § 60.40c(c) § 60.42c(h) § 60.42c(i) § 60.42c(j)	On/after the §60.8 test, oil-fired facilities shall not discharge SO ₂ gases in excess of 215 ng/J (0.50 lb/MMBtu) heat input or, alternatively, combust oil with a greater than 0.5 weight % sulfur.	§ 60.44c(a) § 60.44c(d) § 60.44c(h) § 60.44c(j) § 60.46c(e)	[G]§ 60.48c(e) [G]§ 60.48c(f) § 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) § 60.48c(d) [G]§ 60.48c(e) § 60.48c(j)
CEPSBLR-17	EU	60DC-12	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CEPSBLR-17	EU	60DC-12	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.43c(c) § 60.40c(c) § 60.43c(d) § 60.47c(g)	Facilities firing the specified fuels and that have heat input capacity of 8.7 MW (30 MMBtu/hr) or greater, shall not exhibit opacity greater than 20%, 6-minute average, except as specified.	§ 60.45c(a) § 60.45c(a)(8) § 60.47c(g)	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) [G]§ 60.48c(c) § 60.48c(j)
GRPEG1	EU	R7ICI-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart ZZZZ
GRPEG2	EU	R7ICI-2	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart ZZZZ
GRPEG3	EU	R7ICI-3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart ZZZZ

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPEG4	EU	R7ICI-4	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart ZZZZ	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart ZZZZ
GRPEG5	EU	R7ICI-14	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) § 60.4211(c) [G]§ 60.4211(f) § 60.4211(g) § 60.4211(g)(3) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4211(g)(3) [G]§ 60.4212	§ 60.4211(g)(3)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPEG5	EU	R7ICI-14	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) § 60.4211(c) [G]§ 60.4211(f) § 60.4211(g) § 60.4211(g)(3) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4211(g)(3) [G]§ 60.4212	§ 60.4211(g)(3)	[G]§ 60.4214(d)
GRPEG5	EU	R7ICI-14	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) § 60.4211(c) [G]§ 60.4211(f) § 60.4211(g) § 60.4211(g)(3) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4211(g)(3) [G]§ 60.4212	§ 60.4211(g)(3)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPEG5	EU	R7ICI-5	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
TANK1	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
TANK14	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TANK15	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
TANK2	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
TANK4	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
TANK5	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

Additional Monitoring Requirements

Periodic Monitoring Summary..... 36

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: BLR-10	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: REG2-3
Pollutant: SO ₂	Main Standard: § 112.9(a)
Monitoring Information	
Indicator: Percent sulfur (by weight) in back-up fuel to boiler	
Minimum Frequency: Semi-Annually	
Averaging Period: 30 day rolling average	
Deviation Limit: 0.5 weight percent sulfur (30 day average)	
<p>Periodic Monitoring Text: Ensure that the sulfur dioxide (SO₂) limit on boiler stack emission is not exceeded by monitoring the sulfur content in the No. 2 fuel oil occasionally used as back-up fuel in the boilers, as detailed in the fuel oil specification provided by the fuel oil supplier. The No. 2 fuel oil shall contain no more than 0.5 weight percent sulfur on a 30-day rolling average. Any specification data above this amount shall be considered and reported as a deviation, if No. 2 fuel oil had been fired in the boiler during the subject semi-annual monitoring period.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: BLR-11	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: REG2-1
Pollutant: SO ₂	Main Standard: § 112.9(a)
Monitoring Information	
Indicator: Percent weight sulfur in fuel oil	
Minimum Frequency: Semi-Annually	
Averaging Period: 30 day rolling average	
Deviation Limit: 0.5 weight percent sulfur (30 day average)	
<p>Periodic Monitoring Text: Ensure that the sulfur dioxide (SO₂) limit on boiler stack emission is not exceeded by monitoring the sulfur content in the No. 2 fuel oil occasionally used as back-up fuel in the boilers, as detailed in the fuel oil specification provided by the fuel oil supplier. The No. 2 fuel oil shall contain no more than 0.5 weight percent sulfur on a 30-day rolling average. Any specification data above this amount shall be considered and reported as a deviation, if No. 2 fuel oil had been fired in the boiler during the subject semi-annual monitoring period.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: BLR-8	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: REG2-2
Pollutant: SO ₂	Main Standard: § 112.9(a)
Monitoring Information	
Indicator: Percent sulfur (by weight) in back-up fuel to boiler	
Minimum Frequency: Semi-Annually	
Averaging Period: 30 day rolling average	
Deviation Limit: 0.5 weight percent sulfur (30 day average)	
<p>Periodic Monitoring Text: Ensure that the sulfur dioxide (SO₂) limit on boiler stack emission is not exceeded by monitoring the sulfur content in the No. 2 fuel oil occasionally used as back-up fuel in the boilers, as detailed in the fuel oil specification provided by the fuel oil supplier. The No. 2 fuel oil shall contain no more than 0.5 weight percent sulfur on a 30-day rolling average. Any specification data above this amount shall be considered and reported as a deviation, if No. 2 fuel oil had been fired in the boiler during the subject semi-annual monitoring period.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CEPSBLR-15	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: REG2-4
Pollutant: SO ₂	Main Standard: § 112.9(a)
Monitoring Information	
Indicator: Percent sulfur (by weight) in back-up fuel to boiler	
Minimum Frequency: Semi-Annually	
Averaging Period: 30 day rolling average	
Deviation Limit: 0.5 weight percent sulfur (30 day average)	
<p>Periodic Monitoring Text: Ensure that the sulfur dioxide (SO₂) limit on boiler stack emission is not exceeded by monitoring the sulfur content in the No. 2 fuel oil occasionally used as back-up fuel in the boilers, as detailed in the fuel oil specification provided by the fuel oil supplier. The No. 2 fuel oil shall contain no more than 0.5 weight percent sulfur on a 30-day rolling average. Any specification data above this amount shall be considered and reported as a deviation, if No. 2 fuel oil had been fired in the boiler during the subject semi-annual monitoring period.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CEPSBLR-16	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: REG2-5
Pollutant: SO ₂	Main Standard: § 112.9(a)
Monitoring Information	
Indicator: Percent sulfur (by weight) in back-up fuel to boiler	
Minimum Frequency: Semi-Annually	
Averaging Period: 30 day rolling average	
Deviation Limit: 0.5 weight percent sulfur (30 day average)	
<p>Periodic Monitoring Text: Ensure that the sulfur dioxide (SO₂) limit on boiler stack emission is not exceeded by monitoring the sulfur content in the No. 2 fuel oil occasionally used as back-up fuel in the boilers, as detailed in the fuel oil specification provided by the fuel oil supplier. The No. 2 fuel oil shall contain no more than 0.5 weight percent sulfur on a 30-day rolling average. Any specification data above this amount shall be considered and reported as a deviation, if No. 2 fuel oil had been fired in the boiler during the subject semi-annual monitoring period.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CEPSBLR-17	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: REG2-6
Pollutant: SO ₂	Main Standard: § 112.9(a)
Monitoring Information	
Indicator: Percent sulfur (by weight) in back-up fuel to boiler	
Minimum Frequency: Semi-Annually	
Averaging Period: 30 day rolling average	
Deviation Limit: 0.5 weight percent sulfur (30 day average)	
<p>Periodic Monitoring Text: Ensure that the sulfur dioxide (SO₂) limit on boiler stack emission is not exceeded by monitoring the sulfur content in the No. 2 fuel oil occasionally used as back-up fuel in the boilers, as detailed in the fuel oil specification provided by the fuel oil supplier. The No. 2 fuel oil shall contain no more than 0.5 weight percent sulfur on a 30-day rolling average. Any specification data above this amount shall be considered and reported as a deviation, if No. 2 fuel oil had been fired in the boiler during the subject semi-annual monitoring period.</p>	

Permit Shield

Permit Shield 43

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
BLR-8	N/A	30 TAC Chapter 115, Vent Gas Controls	Combustion unit exhaust stream is exempt. Unit is not being used as a control device for any vent gas stream.
BLR-8	N/A	40 CFR Part 60, Subpart D	Heat input capacity < 250 MMBTU/hr
BLR-8	N/A	40 CFR Part 60, Subpart Da	Heat input capacity < 250 MMBTU/hr
BLR-8	N/A	40 CFR Part 60, Subpart Db	Heat input capacity < 100 MMBTU/hr
GRPVENT	BLR-10, BLR-11, CEPSBLR-15, CEPSBLR-16, CEPSBLR-17	30 TAC Chapter 115, Vent Gas Controls	Combustion unit exhaust stream is exempt. Unit is not being used as a control device for any vent gas stream.
GRPVENT	BLR-10, BLR-11, CEPSBLR-15, CEPSBLR-16, CEPSBLR-17	30 TAC Chapter 117, Subchapter B	Units are exempt from regulation since maximum rated capacity is less than 40 MMBTU/hr, 30 TAC 117.203(a)(2).
GRPVENT	BLR-10, BLR-11, CEPSBLR-15, CEPSBLR-16, CEPSBLR-17	40 CFR Part 60, Subpart D	Heat input capacity < 250 MMBTU/hr
GRPVENT	BLR-10, BLR-11, CEPSBLR-15, CEPSBLR-16, CEPSBLR-17	40 CFR Part 60, Subpart Da	Heat input capacity < 250 MMBTU/hr
GRPVENT	BLR-10, BLR-11, CEPSBLR-15, CEPSBLR-16, CEPSBLR-17	40 CFR Part 60, Subpart Db	Heat Input Capacity < 100 MMBTU/hr

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
GRPEG1	EG-CG1, EG-ITL, EG-N, EG-RD3, EG-RD4, EG-S	30 TAC Chapter 117, Subchapter B	Units are exempt from regulation since they are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based upon a rolling 12-month average, 30 TAC 117.203(a)(6)(D)
GRPEG2	EG-RD2	30 TAC Chapter 117, Subchapter B	Units are exempt from regulation since they are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based upon a rolling 12-month average, 30 TAC 117.203(a)(6)(D)
GRPEG3	EG-CG2, EG-CG3	30 TAC Chapter 117, Subchapter B	Used exclusively in emergency situations, except for O&M for up to 52 hours per year/12 month rolling average.
GRPEG4	EG-CGP, EG-CWH, EG-QA, EG-RDAAC, EG-SA	30 TAC Chapter 117, Subchapter B	Used exclusively in emergency situations, except for O&M for up to 52 hours per year/12 month rolling average.
TANK1	N/A	40 CFR Part 60, Subpart Kb	151 m3 > Capacity > 75 m3 and maximum true vapor pressure less than 15 kPa.
TANK13	N/A	40 CFR Part 60, Subpart Kb	Storage tank < 75 m3

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
TANK14	N/A	40 CFR Part 60, Subpart Kb	Storage tank < 75 m3
TANK15	N/A	40 CFR Part 60, Subpart Kb	Storage tank < 75 m3
TANK2	N/A	40 CFR Part 60, Subpart Kb	151 m3 > Capacity > 75 m3 and maximum true vapor pressure less than 15 kPa.
TANK22	N/A	40 CFR Part 60, Subpart Kb	Storage tank < 75 m3
TANK23	N/A	40 CFR Part 60, Subpart Kb	Storage tank < 75 m3
TANK25	N/A	40 CFR Part 60, Subpart Kb	Storage tank is < 75 m3
TANK26	N/A	40 CFR Part 60, Subpart Kb	Storage tank < 75 m3
TANK28	N/A	40 CFR Part 60, Subpart Kb	Storage tank < 75 m3
TANK31	N/A	40 CFR Part 60, Subpart Kb	Storage tank capacity < 10,600 gallons.
TANK32	N/A	40 CFR Part 60, Subpart Kb	Storage tank capacity <10,600 gallons.
TANK4	N/A	40 CFR Part 60, Subpart Kb	Storage tank < 75 m3
TANK5	N/A	40 CFR Part 60, Subpart Kb	Storage tank < 75 m3
TANK9	N/A	30 TAC Chapter 115, Storage of VOCs	Capacity less than or equal to 1,000 gallons.
TANK9	N/A	40 CFR Part 60, Subpart Kb	Storage tank < 75 m3

New Source Review Authorization References

New Source Review Authorization References 47

New Source Review Authorization References by Emission Unit.....48

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 21411	Issuance Date: 07/02/2013
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.183	Version No./Date: 09/04/2000
Number: 106.227	Version No./Date: 09/04/2000
Number: 106.261	Version No./Date: 09/04/2000
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 09/04/2000
Number: 106.262	Version No./Date: 11/01/2003
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.264	Version No./Date: 09/04/2000
Number: 106.265	Version No./Date: 09/04/2000
Number: 106.371	Version No./Date: 09/04/2000
Number: 106.412	Version No./Date: 09/04/2000
Number: 106.454	Version No./Date: 07/08/1998
Number: 106.454	Version No./Date: 09/04/2000
Number: 106.454	Version No./Date: 11/01/2001
Number: 106.478	Version No./Date: 09/04/2000
Number: 106.494	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 09/04/2000
Number: 7	Version No./Date: 05/04/1994
Number: 14	Version No./Date: 08/30/1988
Number: 51	Version No./Date: 09/12/1989

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
BLR-10	BOILER 10 STACK	106.183/09/04/2000
BLR-10	COGEN BOILER #10	106.183/09/04/2000
BLR-11	BOILER 11 STACK	106.183/09/04/2000
BLR-11	CEP NORTH BOILER #11	106.183/09/04/2000
BLR-8	CEP NORTH BOILER #8	21411
CEPSBLR-15	BOILER 15 STACK	106.183/09/04/2000
CEPSBLR-15	CEP SOUTH BOILER #15	007/05/04/1994, 106.264/09/04/2000
CEPSBLR-16	BOILER 16 STACK	106.183/09/04/2000
CEPSBLR-16	CEP SOUTH BOILER #16	007/05/04/1994, 106.264/09/04/2000
CEPSBLR-17	BOILER 17 STACK	106.183/09/04/2000
CEPSBLR-17	CEP SOUTH BOILER #17	106.183/09/04/2000
EG-CG1	CONNER GENERATOR NUMBER ONE	106.511/09/04/2000
EG-CG2	CONNER GENERATOR #2	106.511/09/04/2000
EG-CG3	CONNER GENERATOR #3	106.511/09/04/2000
EG-CGP	CO-GEN PLANT	106.511/09/04/2000
EG-CWH	CENTRE WAREHOUSE	106.511/09/04/2000
EG-EDC	EAST DATA CENTER	106.511/09/04/2000
EG-ITL	IT/LEGAL EMERGENCY GENERATOR	106.511/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
EG-N	CEP-NORTH EMERGENCY GENERATOR	106.511/09/04/2000
EG-QA	QUALITY ASSURANCE	106.511/09/04/2000
EG-RD2	R&D(A,B&C) EMERGENCY GENERATOR	106.511/09/04/2000
EG-RD3	R&D(D) EMERGENCY GENERATOR	106.511/09/04/2000
EG-RD4	R&D(F) EMERGENCY GENERATOR	106.511/09/04/2000
EG-RDAAC	RDAAC TOWER	106.511/09/04/2000
EG-SA	SURGICAL ANNEX	106.511/09/04/2000
EG-S	CEP-SOUTH EMERGENCY GENERATOR	106.511/09/04/2000
EG-WDC2	WEST DATA CENTER #2	106.511/09/04/2000
EG-WDC	WEST DATA CENTER	106.511/09/04/2000
TANK13	R&D,- F DIESEL STORAGE TANK	106.478/09/04/2000
TANK14	CEP-SOUTH DIESEL STORAGE TANK	106.478/09/04/2000
TANK15	CEP-SOUTH DIESEL STORAGE TANK	106.478/09/04/2000
TANK1	CO-GENERATION PLANT DIESEL STORAGE TANK	106.478/09/04/2000
TANK22	IT/LEGAL DIESEL STORAGE TANK	106.478/09/04/2000
TANK23	CONNER GENERATOR #1 DIESEL STORAGE TANK	106.478/09/04/2000
TANK25	CONNER GENERATOR #2, DIESEL STORAGE TANK	106.478/09/04/2000
TANK26	CONNER GENERATOR #3, DIESEL STORAGE TANK	106.478/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
TANK28	WEST DATA CENTER EG DIESEL STORAGE TANK	106.478/09/04/2000
TANK2	CO-GENERATION PLANT DIESEL STORAGE TANK	106.478/09/04/2000
TANK31	WDC#2 STORAGE TANK	106.478/09/04/2000
TANK32	EDC STORAGE TANK	106.478/09/04/2000
TANK4	CEP-NORTH DIESEL STORAGE TANK	106.478/09/04/2000
TANK5	CEP-NORTH DIESEL STORAGE TANK	106.478/09/04/2000
TANK9	MAINTENANCE FACILITY GASOLINE STORAGE TANK	014/08/30/1988

Appendix A

Acronym List 52

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
COMS	continuous opacity monitoring system
CVS	closed-vent system
D/FW	Dallas/Fort Worth (nonattainment area)
DR	Designated Representative
ELP	El Paso (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
GF	grandfathered
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MMBtu/hr	Million British thermal units per hour
MRRT	monitoring, recordkeeping, reporting, and testing
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PM	particulate matter
ppmv	parts per million by volume
PSD	prevention of significant deterioration
RO	Responsible Official
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound