

# FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO  
Moss Bluff Hub LLC

AUTHORIZING THE OPERATION OF  
Moss Bluff Natural Gas Storage Facility  
Moss Bluff Dehydration Gas Storage Facility  
Natural Gas Transmission

LOCATED AT  
Liberty County, Texas  
Latitude 29° 54' 11" Longitude 94° 41' 49"  
Regulated Entity Number: RN100217256

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No:   O2587   Issuance Date: \_\_\_\_\_

---

For the Commission

## Table of Contents

Section	Page
General Terms and Conditions .....	1
Special Terms and Conditions .....	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting .....	1
Additional Monitoring Requirements .....	10
New Source Review Authorization Requirements .....	10
Compliance Requirements.....	11
Protection of Stratospheric Ozone.....	13
Permit Location.....	13
Permit Shield (30 TAC § 122.148) .....	13
Attachments .....	15
Applicable Requirements Summary .....	16
Additional Monitoring Requirements .....	30
Permit Shield.....	36
New Source Review Authorization References.....	39
Appendix A .....	43
Acronym List .....	44

## **General Terms and Conditions**

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

## **Special Terms and Conditions: Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting**

1. Permit holder shall comply with the following requirements:
  - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
  - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.

- C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
- D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.
- E. Emission units subject to 40 CFR Part 63, Subparts HHH and ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, §113.650 and §113.1090 respectively, which incorporates the 40 CFR Part 63 Subpart by reference.
- F. For the purpose of generating emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 1 (Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
  - (i) Title 30 TAC § 101.302 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.303 (relating to Emission Reduction Credit Generation Certification)
  - (iii) Title 30 TAC § 101.304 (relating to Mobile Emission Reduction Credit Generation and Certification)
  - (iv) Title 30 TAC § 101.309 (relating to Emission Credit Banking and Trading)
  - (v) The terms and conditions by which the emission limits are established to generate the reduction credit are applicable requirements of this permit
- G. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 3 (Mass Emission Cap and Trade Program) Requirements:
  - (i) Title 30 TAC § 101.352 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.353 (relating to Allocation of Allowances)
  - (iii) Title 30 TAC § 101.354 (relating to Allowance Deductions)
  - (iv) Title 30 TAC § 101.356 (relating to Allowance Banking and Trading)

- (v) Title 30 TAC § 101.358 (relating to Emission Monitoring and Compliance Demonstration)
  - (vi) Title 30 TAC § 101.359 (relating to Reporting)
  - (vii) Title 30 TAC § 101.360 (relating to Level of Activity Certification)
  - (viii) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit
2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
- A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
  - B. Title 30 TAC § 101.3 (relating to Circumvention)
  - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
  - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
  - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
  - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
  - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
  - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
  - I. Title 30 TAC § 101.222 (relating to Demonstrations)
  - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
- A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1 , shall not exceed 20% opacity averaged over a six-minute period. The permit holder

shall comply with the following requirements for stationary vents at the site subject to this standard:

- (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(1)(E)
- (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
- (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the “Applicable Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:
  - (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
  - (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
  - (3) Records of all observations shall be maintained.
  - (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset.

Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

- (5) Compliance Certification:
- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
  - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.
- B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:
  - (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
  - (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
  - (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
    - (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.
    - (2) Records of all observations shall be maintained.
    - (3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions

outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A)
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader

C. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)
- (iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following

periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:

- (1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.
- (2) Records of all observations shall be maintained.
- (3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (4) Compliance Certification:
  - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)
  - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in

compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- D. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).
  - E. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
    - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
    - (ii) Sources with an effective stack height ( $h_e$ ) less than the standard effective stack height ( $H_e$ ), must reduce the allowable emission level by multiplying it by  $[h_e/H_e]^2$  as required in 30 TAC § 111.151(b)
    - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
4. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
- A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
  - B. Title 40 CFR § 60.8 (relating to Performance Tests)
  - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
  - D. Title 40 CFR § 60.12 (relating to Circumvention)
  - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
  - F. Title 40 CFR § 60.14 (relating to Modification)
  - G. Title 40 CFR § 60.15 (relating to Reconstruction)
  - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)

5. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
6. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

### **Additional Monitoring Requirements**

7. The permit holder shall comply with the periodic monitoring requirements as specified in the attached “Periodic Monitoring Summary” upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time specified in the “Periodic Monitoring Summary,” for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

### **New Source Review Authorization Requirements**

8. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule, standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
  - A. Are incorporated by reference into this permit as applicable requirements
  - B. Shall be located with this operating permit

- C. Are not eligible for a permit shield
- 9. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
- 10. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).

### **Compliance Requirements**

- 11. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
- 12. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:
  - A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
    - (i) For sources in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9020:
      - (1) Title 30 TAC § 117.9020(2)(A), (C), and (D)
  - B. The permit holder shall comply with the Initial Control Plan unit listing requirement in 30 TAC § 117.350(c) and (c)(1).

- C. The permit holder shall comply with the requirements of 30 TAC § 117.354 for Final Control Plan Procedures for Attainment Demonstration Emission Specifications and 30 TAC § 117.356 for Revision of Final Control Plan.
13. Use of Emission Credits to comply with applicable requirements:
- A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
    - (i) Title 30 TAC Chapter 115
    - (ii) Title 30 TAC Chapter 117
    - (iii) Offsets for Title 30 TAC Chapter 116
  - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
    - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)(2)
    - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
    - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)(2)
    - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
    - (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)
14. Use of Discrete Emission Credits to comply with the applicable requirements:
- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
    - (i) Title 30 TAC Chapter 115
    - (ii) Title 30 TAC Chapter 117
    - (iii) If applicable, offsets for Title 30 TAC Chapter 116
    - (iv) Temporarily exceed state NSR permit allowables

- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
- (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
  - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
  - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
  - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
  - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

### **Protection of Stratospheric Ozone**

15. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
- A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.

### **Permit Location**

16. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

### **Permit Shield (30 TAC § 122.148)**

17. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified

by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

## **Attachments**

**Applicable Requirements Summary**

**Additional Monitoring Requirements**

**Permit Shield**

**New Source Review Authorization References**

### **Applicable Requirements Summary**

**Unit Summary .....17**

**Applicable Requirements Summary ..... 19**

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

## Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
D-950	STORAGE TANKS/VESSELS	N/A	R5112-02	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
DEHY-2VENT	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R115B-0001	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
DEHY-2VENT	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	63HHH-001	40 CFR Part 63, Subpart HHH	No changing attributes.
DEHY-UNIT1	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R115B-0002	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
DEHY-UNIT1	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	63HHH-001	40 CFR Part 63, Subpart HHH	No changing attributes.
DG-1	SRIC ENGINES	N/A	R117-2	30 TAC Chapter 117, Subchapter B	No changing attributes.
DG-1	SRIC ENGINES	N/A	63ZZZZ-0002	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRPCOTANK	STORAGE TANKS/VESSELS	D-1000, D-990	R5112-03	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRP-ENG	SRIC ENGINES	GC-100, GC-200, GC-300, GC-400, GC-500, GC-600	R117-1	30 TAC Chapter 117, Subchapter B	No changing attributes.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRP-LOAD1	LOADING/UNLOADING OPERATIONS	MG-TL1, MG-TL4	R5211	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
GRP-LOAD2	LOADING/UNLOADING OPERATIONS	MG-TL2, MG-TL3	R5211	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
GRPLOTANK	STORAGE TANKS/VESSELS	D-960, D-966	R5112-02	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPSWTANK	STORAGE TANKS/VESSELS	D-940A, D-940B	R5112-02	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
METHTANK	STORAGE TANKS/VESSELS	N/A	R5112-04	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
METHTANK	STORAGE TANKS/VESSELS	N/A	60KB-03	40 CFR Part 60, Subpart Kb	No changing attributes.
MG-036	SRIC ENGINES	N/A	R117-5	30 TAC Chapter 117, Subchapter B	No changing attributes.
MG-036	SRIC ENGINES	N/A	60III-0001	40 CFR Part 60, Subpart III	No changing attributes.
MG-036	SRIC ENGINES	N/A	63ZZZZ-0003	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
MG-037	SRIC ENGINES	N/A	R117-5	30 TAC Chapter 117, Subchapter B	No changing attributes.
MG-037	SRIC ENGINES	N/A	60III-0002	40 CFR Part 60, Subpart III	No changing attributes.
MG-037	SRIC ENGINES	N/A	M63ZZZZ-0004	40 CFR Part 63, Subpart ZZZZ	No changing attributes.

## Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
D-950	EU	R5112-02	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
DEHY-2VENT	EP	R115B-0001	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.121(a)(1) § 115.122(a)(1) § 115.122(a)(1)(A)	No person may allow a vent gas stream containing VOC to be emitted from any process vent, unless the vent gas stream is burned properly in accordance with §115.122(a)(1) of this title.	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	None
DEHY-2VENT	EP	63HHH-001	112(B) HAPS	40 CFR Part 63, Subpart HHH	§ 63.1274(c) § 63.1270(a) § 63.1270(b)(2) § 63.1270(d)(3) § 63.1270(e) § 63.1274(a) § 63.1274(b) [G]§ 63.1274(c) § 63.1274(e) § 63.1274(h) § 63.1275(a) [G]§ 63.1275(b)(1)(iii) § 63.1275(b)(2) § 63.1275(c)(3)(iii) § 63.1281(e)(1) § 63.1281(e)(2) § 63.1281(e)(3)(i)	The owner or operator of an affected source (i.e., glycol dehydration unit) located at an existing or new major source of HAP emissions shall comply with the requirements in this subpart.	§ 63.1282(a)(1)(ii) § 63.1282(a)(2)(i) [G]§ 63.1282(c)(2)	§ 63.1284(a)-Table 2 [G]§ 63.1284(b)(1) § 63.1284(b)(2) § 63.1284(b)(9) § 63.1284(f)	§ 63.1285(a)-Table 2 § 63.1285(b)(1)(ii) § 63.1285(b)(4) § 63.1285(b)(5) § 63.1285(b)(6) § 63.1285(d)(6) § 63.1285(d)(8) § 63.1285(d)(9) § 63.1285(e)(2)(xiii) [G]§ 63.1285(f)
DEHY-UNIT1	EP	R115B-0002	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC)	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2) ** See Periodic Monitoring Summary	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None

## Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).			
DEHY-UNIT1	EP	63HHH-001	112(B) HAPS	40 CFR Part 63, Subpart HHH	§ 63.1274(c) § 63.1270(a) § 63.1270(b)(2) § 63.1270(d)(3) § 63.1270(e) § 63.1274(a) § 63.1274(b) [G]§ 63.1274(c) § 63.1274(e) § 63.1274(h) § 63.1275(a) [G]§ 63.1275(b)(1)(iii) § 63.1275(b)(2) § 63.1275(c)(3)(iii) § 63.1281(e)(1) § 63.1281(e)(2) § 63.1281(e)(3)(i)	The owner or operator of an affected source (i.e., glycol dehydration unit) located at an existing or new major source of HAP emissions shall comply with the requirements in this subpart.	§ 63.1282(a)(1)(ii) § 63.1282(a)(2)(i) [G] § 63.1282(c)(2)	§ 63.1284(a)-Table 2 [G]§ 63.1284(b)(1) § 63.1284(b)(2) § 63.1284(b)(9) § 63.1284(f)	§ 63.1285(a)-Table 2 § 63.1285(b)(1)(ii) § 63.1285(b)(4) § 63.1285(b)(5) § 63.1285(b)(6) § 63.1285(d)(6) § 63.1285(d)(8) § 63.1285(d)(9) § 63.1285(e)(2)(xiii) [G]§ 63.1285(f)
DG-1	EU	R117-2	EXEMPT	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(10) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include any stationary diesel engine placed into service before October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average; and has not been modified, reconstructed, or relocated on or after October 1, 2001.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

## Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						§117.303(a)(10)(A)-(B)			
DG-1	EU	63ZZZZ-0002	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(b) § 63.6640(f)(1) [G]§ 63.6640(f)(2) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii § 63.6640(b)	§ 63.6625(i) § 63.6655(a) § 63.6655(a)(1) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(b) § 63.6640(e) § 63.6650(f)
GRPCOTANK	EU	R5112-03	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None

## Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-ENG	EU	R117-1	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(9)(B)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(D) § 117.340(h) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) § 117.345(f)(12) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.345(f)(3)(B) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) [G]§ 117.345(e) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

## Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-ENG	EU	R117-1	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(D) § 117.340(h) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) § 117.345(f)(12) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) [G]§ 117.345(e) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRP-LOAD1	EU	R5211	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(2)(A) § 115.212(a)(2) [G]§ 115.212(a)(7) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Any plant, excluding gasoline bulk plants, which loads less than 20,000 gpd of VOC with a true vapor pressure of 0.5 psia or greater is exempt from the requirements of this division, except for the specified requirements.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B) § 115.216(3)(D)	None

## Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-LOAD2	EU	R5211	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
GRPLOTANK	EU	R5112-02	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPSWTANK	EU	R5112-02	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
METHTANK	EU	R5112-04	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None

## Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						condensate.			
METHTANK	EU	6oKB-03	VOC	40 CFR Part 60, Subpart Kb	§ 60.110b(a)	Except for §60.110b(b), this subpart applies to vessels with a capacity greater than or equal to 75 cubic meters (19,800 gal) used to store VOLs for which construction/reconstruction /modification began after 7/23/84.	§ 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(d) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3)	§ 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.116b(d)
MG-036	EU	R117-5	EXEMPT	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
MG-036	EU	6oIII-0001	CO	40 CFR Part 60, Subpart III	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) § 60.4211(b) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 75 KW and less than 130 KW and a displacement of less than 30 liters per cylinder	None	§ 60.4211(b)(3)	[G]§ 60.4214(d)

## Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						and is a 2009 model year or earlier must comply with a CO emission limit of 5.0 g/KW-hr, as listed in Table 4 to this subpart.			
MG-036	EU	60III-0001	NMHC and NO <sub>x</sub>	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) § 60.4211(b) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 75 KW and less than 130 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year or earlier must comply with an NMHC+NO <sub>x</sub> emission limit of 10.5 g/KW-hr, as listed in Table 4 to this subpart.	None	§ 60.4211(b)(3)	[G]§ 60.4214(d)
MG-036	EU	60III-0001	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) § 60.4211(b) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 75 KW and less than 130 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year or earlier must comply with a PM emission limit of 0.80 g/KW-hr, as listed in Table 4 to this subpart.	None	§ 60.4211(b)(3)	[G]§ 60.4214(d)
MG-036	EU	63ZZZZ-0003	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet	None	None	None

## Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
MG-037	EU	R117-5	EXEMPT	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
MG-037	EU	60III-0002	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a	None	None	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						2007 model year and later must comply with a CO emission limit of 5.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
MG-037	EU	6oIII-0002	NMHC and NO <sub>x</sub>	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later, must comply with an NMHC+NO <sub>x</sub> emission limit of 4.7 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	None
MG-037	EU	6oIII-0002	PM (OPACITY)	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.113(a)(1) § 89.113(a)(2) § 89.113(a)(3)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2)	None	None	None

## Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						and §89.113(a)(1)-(3) and §1039.105(b)(1)-(3).			
MG-037	EU	60III-0002	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.40 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	None
MG-037	EU	M63ZZZZ-0004	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart III, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None

**Additional Monitoring Requirements**

**Periodic Monitoring Summary.....31**

## Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: DEHY-UNIT1	
Control Device ID No.: R-610	Control Device Type: Steam Generating Unit (Boiler)/Process Heater (Design heat input is greater than or equal to 44MW)
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 115, Vent Gas Controls	SOP Index No.: R115B-0002
Pollutant: VOC	Main Standard: § 115.122(a)(1)
<b>Monitoring Information</b>	
Indicator: Period of Operation	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: All periods that are not recorded shall be considered and reported as a deviation.	
Periodic Monitoring Text: Monitor and record the periods of operation of the steam generating units or process heater. All periods that are not recorded shall be considered and reported as a deviation. The records must be readily available for inspection.	

## Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: GRPCOTANK	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-03
Pollutant: VOC	Main Standard: § 115.112(e)(1)
<b>Monitoring Information</b>	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Failure to repair the fill pipe before the storage vessel is refilled.	
<p>Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.</p>	

## Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: GRPCOTANK	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-03
Pollutant: VOC	Main Standard: § 115.112(e)(1)
<b>Monitoring Information</b>	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Failure to keep a record of tank construction specifications (e.g. engineering drawings).	
<p>Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.</p>	

## Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: METHTANK	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-04
Pollutant: VOC	Main Standard: § 115.112(e)(1)
<b>Monitoring Information</b>	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Failure to repair the fill pipe before the storage vessel is refilled.	
<p>Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.</p>	

## Periodic Monitoring Summary

<b>Unit/Group/Process Information</b>	
ID No.: METHTANK	
Control Device ID No.: N/A	Control Device Type: N/A
<b>Applicable Regulatory Requirement</b>	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-04
Pollutant: VOC	Main Standard: § 115.112(e)(1)
<b>Monitoring Information</b>	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Failure to keep a record of tank construction specifications (e.g. engineering drawings).	
<p>Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.</p>	

**Permit Shield**

**Permit Shield ..... 37**

## Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
D-680	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of this division.
D-680	N/A	40 CFR Part 60, Subpart Kb	Storage vessel capacity is less than 40 cubic meters (10,600 gal).
D-950	N/A	40 CFR Part 60, Subpart Kb	Storage vessel capacity is less than 40 cubic meters (10,600 gal).
D-981	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of this division.
D-981	N/A	40 CFR Part 60, Subpart Kb	Storage vessel capacity is less than 40 cubic meters (10,600 gal).
D-982	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of this division.
D-982	N/A	40 CFR Part 60, Subpart Kb	Storage vessel capacity is less than 40 cubic meters (10,600 gal).
D-983	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of this division.
D-983	N/A	40 CFR Part 60, Subpart Kb	Storage vessel capacity is less than 40 cubic meters (10,600 gal).
D-984	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of this division.
D-984	N/A	40 CFR Part 60, Subpart Kb	Storage vessel capacity is less than 40 cubic meters (10,600 gal).
GRPCOTANK	D-1000, D-990	40 CFR Part 60, Subpart Kb	Storage vessel capacity is less than 40 cubic meters (10,600 gal).
GRPCOTANK	D-1000, D-990	40 CFR Part 60, Subpart OOOO	Storage vessels commenced construction, modification, or reconstruction before the applicability date of August 23, 2011.

## Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
GRP-ENG	GC-100, GC-200, GC-300, GC-400, GC-500, GC-600	40 CFR Part 63, Subpart ZZZZ	Existing spark ignition 4 stroke lean burn (4SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
GRPLOTANK	D-960, D-966	40 CFR Part 60, Subpart Kb	Storage vessel capacity is less than 40 cubic meters (10,600 gal).
GRPSWTANK	D-940A, D-940B	40 CFR Part 60, Subpart Kb	Storage vessel capacity (16,900 gal) is greater than 75 m <sup>3</sup> but less than 151 m <sup>3</sup> storing a liquid with a maximum true vapor pressure (<1.0 psi) less than 15.0 kPa.
MBDAYTK	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of this division.
MBDAYTK	N/A	40 CFR Part 60, Subpart Kb	The storage capacity is less than 75 cubic meters.
MB-RB2	N/A	30 TAC Chapter 117, Subchapter B	Maximum rated capacity is less than 40 MMBtu/hr.
MB-RB2	N/A	40 CFR Part 60, Subpart Db	Maximum heat input capacity is less than 100 MMBtu/hr.
MB-RB2	N/A	40 CFR Part 60, Subpart Dc	Maximum heat input capacity is less than 10 MMBtu/hr.
MB-TO1R	N/A	30 TAC Chapter 117, Subchapter B	Maximum rated capacity is less than 40 MMBtu/hr.
R-610	N/A	30 TAC Chapter 117, Subchapter B	Maximum rated capacity is less than 40 MMBtu/hr.
R-610	N/A	40 CFR Part 60, Subpart Db	Maximum heat input capacity is less than 100 MMBtu/hr.
R-610	N/A	40 CFR Part 60, Subpart Dc	Maximum heat input capacity is less than 10 MMBtu/hr.

**New Source Review Authorization References**

**New Source Review Authorization References .....40**

**New Source Review Authorization References by Emission Unit..... 41**

## New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

<b>Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.</b>	
Authorization No.: 20205	Issuance Date: 04/30/2012
<b>Permits By Rule (30 TAC Chapter 106) for the Application Area</b>	
Number: 106.183	Version No./Date: 09/04/2000
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.352	Version No./Date: 02/27/2011
Number: 106.359	Version No./Date: 09/10/2013
Number: 106.452	Version No./Date: 09/04/2000
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.478	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 09/04/2000

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
D-1000	2,200 GAL CAVERN 4 CONDENSATE STORAGE TANK	106.473/09/04/2000
D-680	500 GAL TRIETHYLENE GLYCOL STORAGE TANK	20205
D-940A	16,900 GAL STORMWATER STORAGE TANK	20205
D-940B	16,900 GAL STORMWATER STORAGE TANK	20205
D-950	2,100 GAL ETHYLENE GLYCOL STORAGE TANK	20205
D-960	3,200 GAL LUBE OIL STORAGE TANK	20205
D-966	8,820 GAL LUBE OIL STORAGE TANK	20205
D-981	750-GAL DIESEL STORAGE TANK	106.473/09/04/2000
D-982	1,000-GAL DIESEL STORAGE TANK	106.473/09/04/2000
D-983	200-GAL DIESEL STORAGE TANK	106.473/09/04/2000
D-984	100-GAL DIESEL STORAGE TANK	106.473/09/04/2000
D-990	8,820 GAL PIPELINE LIQUIDS STORAGE TANK	106.473/09/04/2000
DEHY-2VENT	DEHY-UNIT2 STILL VENT	106.352/02/27/2011
DEHY-UNIT1	DEHYDRATION UNIT	20205
DG-1	387 HP DIESEL-FIRED STANDBY GENERATOR ENGINE	20205
GC-100	2587 BHP 4-STROKE LEAN-BURN COMBUSTION ENGINE 1	20205
GC-200	2587 BHP 4-STROKE LEAN-BURN COMBUSTION ENGINE 2	20205
GC-300	2587 BHP 4-STROKE LEAN-BURN COMBUSTION ENGINE 3	20205

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
GC-400	3335 BHP 4-STROKE LEAN-BURN COMBUSTION ENGINE 4	20205
GC-500	3335 BHP 4-STROKE LEAN-BURN COMBUSTION ENGINE 5	20205
GC-600	7605 BHP 4-STROKE LEAN-BURN COMBUSTION ENGINE 6	20205
MBDAYTK	500-GAL LUBE OIL STORAGE TANK	106.472/09/04/2000
MB-RB2	DEHY-UNIT2 REBOILER	106.352/02/27/2011
MB-TO1R	THERMAL OXIDIZER	106.352/02/27/2011
METHTANK	25,000-GAL METHANOL STORAGE TANK	106.478/09/04/2000
MG-036	175 HP DIESEL FIRE PUMP ENGINE	106.511/09/04/2000
MG-037	80 HP DIESEL EMERGENCY GENERATOR	106.511/09/04/2000
MG-TL1	PIPELINE LIQUIDS TRUCK LOADING OPERATION	20205
MG-TL2	OILY WATER TRUCK LOADING OPERATION	20205
MG-TL3	SPENT COOLANT TRUCK LOADING OPERATION	20205
MG-TL4	CONDENSATE TANK TRUCK LOADING	106.473/09/04/2000
R-610	DEHY-UNIT1 REBOILER	20205

**Appendix A**

**Acronym List ..... 44**

## Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM .....	actual cubic feet per minute
AMOC.....	alternate means of control
ARP .....	Acid Rain Program
ASTM .....	American Society of Testing and Materials
B/PA.....	Beaumont/Port Arthur (nonattainment area)
CAM .....	Compliance Assurance Monitoring
CD .....	control device
COMS.....	continuous opacity monitoring system
CVS.....	closed-vent system
D/FW .....	Dallas/Fort Worth (nonattainment area)
DR .....	Designated Representative
ELP .....	El Paso (nonattainment area)
EP .....	emission point
EPA .....	U.S. Environmental Protection Agency
EU .....	emission unit
FCAA Amendments .....	Federal Clean Air Act Amendments
FOP .....	federal operating permit
GF.....	grandfathered
gr/100 scf.....	grains per 100 standard cubic feet
HAP.....	hazardous air pollutant
H/G/B.....	Houston/Galveston/Brazoria (nonattainment area)
H <sub>2</sub> S .....	hydrogen sulfide
ID No.....	identification number
lb/hr .....	pound(s) per hour
MMBtu/hr.....	Million British thermal units per hour
MRRT.....	monitoring, recordkeeping, reporting, and testing
NA .....	nonattainment
N/A.....	not applicable
NADB .....	National Allowance Data Base
NO <sub>x</sub> .....	nitrogen oxides
NSPS .....	New Source Performance Standard (40 CFR Part 60)
NSR.....	New Source Review
ORIS.....	Office of Regulatory Information Systems
Pb .....	lead
PBR .....	Permit By Rule
PM.....	particulate matter
ppmv .....	parts per million by volume
PSD .....	prevention of significant deterioration
RO .....	Responsible Official
SO <sub>2</sub> .....	sulfur dioxide
TCEQ.....	Texas Commission on Environmental Quality
TSP .....	total suspended particulate
TVP.....	true vapor pressure
U.S.C. ....	United States Code
VOC.....	volatile organic compound