FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
Occidental Chemical Corporation

AUTHORIZING THE OPERATION OF
Ingleside Plant
Alkalies and Chlorine

LOCATED AT
San Patricio County, Texas
Latitude 27° 52' 51" Longitude 97° 14' 39"
Regulated Entity Number: RN100211176

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: O1240 Issuance Date: May 28, 2013

For the Commission

Table of Contents

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:

    A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.

    B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.

C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.

D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.

E. Emission units subject to 40 CFR Part 63, Subpart G, as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.120 which incorporates the 40 CFR Part 63 Subpart by reference.

F. Emission units subject to 40 CFR Part 63, Subpart EEE, as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, §113.620 which incorporates the 40 CFR Part 63 Subpart by reference.

G. Emission units subject to 40 CFR Part 63, Subpart F, as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.110 which incorporates the 40 CFR Part 63 Subpart by reference.

H. Emission units subject to 40 CFR Part 63, Subpart H, as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.130 which incorporates the 40 CFR Part 63 Subpart by reference.

I. Emission units subject to 40 CFR Part 63, Subpart Y, as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.300 which incorporates the 40 CFR Part 63 Subpart by reference.

J. Emission units subject to 40 CFR Part 63, Subpart ZZZZ, as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.

K. Emission units subject to 40 CFR Part 63, Subpart YYYY, as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1080 which incorporates the 40 CFR Part 63 Subpart by reference.

L. Emission units subject to 40 CFR Part 63, Subpart DDDDD, as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1130 which incorporates the 40 CFR Part 63 Subpart by reference.

2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):

A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements

B. Title 30 TAC § 101.3 (relating to Circumvention)

C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ

D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ

E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)

F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)

G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)

H. Title 30 TAC § 101.221 (relating to Operational Requirements)

I. Title 30 TAC § 101.222 (relating to Demonstrations)

J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)

3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:

A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1 , shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:

(i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)

(ii) Title 30 TAC § 111.111(a)(1)(E)

(iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)

(iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the "Applicable Requirements Summary" attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:

(1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.

(2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.

(3) Records of all observations shall be maintained.

(4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with

each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(5) Compliance Certification:

(a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).

(b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

(c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

(i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)

(ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)

(iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:

(1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.

(2) Records of all observations shall be maintained.

(3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

(a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A)

(b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader

C. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

(i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)

(ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)

(iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to sources that are subject to the emission limitation of 30 TAC § 111.111(a)(8)(A) and Periodic Monitoring (PM) as specified in the "Applicable Requirements Summary" and "Additional Monitoring Requirements" attachments:

(1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.

(2) Records of all observations shall be maintained.

(3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

(a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)

(b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the

source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

D. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.

E. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).

F. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:

(i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)

(ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)

(iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)

G. Outdoor burning, as stated in 30 TAC § 111.201, shall not be authorized unless the following requirements are satisfied:

(i) Title 30 TAC § 111.205 (relating to Exception for Fire Training)

(ii) Title 30 TAC § 111.207 (relating to Exception for Recreation, Ceremony, Cooking, and Warmth)

(iii) Title 30 TAC § 111.219 (relating to General Requirements for Allowable Outdoor Burning)

(iv) Title 30 TAC § 111.221 (relating to Responsibility for Consequences of Outdoor Burning)

4. For storage vessels maintaining working pressure as specified in 30 TAC Chapter 115, Subchapter B, Division 1: "Storage of Volatile Organic Compounds," the permit holder shall comply with the requirements of 30 TAC § 115.112(c)(1).

5. Permit holder shall comply with the following 30 TAC Chapter 115, Subchapter C requirements:

   A. When filling stationary gasoline storage vessels (Stage I) for motor vehicle fuel dispensing facilities specified in 30 TAC Chapter 115, Subchapter C, the permit holder shall comply with the following requirements:

      (i) Title 30 TAC § 115.221 (relating to Emission Specifications)

      (ii) Title 30 TAC § 115.222 (relating to Control Requirements)

      (iii) Title 30 TAC § 115.223 (relating to Alternate Control Requirements)

      (iv) Title 30 TAC § 115.224 (relating to Inspection Requirements)

      (v) Title 30 TAC § 115.225 (relating to Testing Requirements)

      (vi) Title 30 TAC § 115.226 (relating to Recordkeeping Requirements)

6. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:

   A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)

   B. Title 40 CFR § 60.8 (relating to Performance Tests)

   C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)

   D. Title 40 CFR § 60.12 (relating to Circumvention)

   E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)

   F. Title 40 CFR § 60.14 (relating to Modification)

   G. Title 40 CFR § 60.15 (relating to Reconstruction)

   H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)

7. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 61, unless otherwise stated in the applicable subpart:

   A. Title 40 CFR § 61.05 (relating to Prohibited Activities)

   B. Title 40 CFR § 61.07 (relating to Application for Approval of Construction or Modification)

C. Title 40 CFR § 61.09 (relating to Notification of Start-up)

D. Title 40 CFR § 61.10 (relating to Source Reporting and Request Waiver)

E. Title 40 CFR § 61.12 (relating to Compliance with Standards and Maintenance Requirements)

F. Title 40 CFR § 61.13 (relating to Emissions Tests and Waiver of Emission Tests)

G. Title 40 CFR § 61.14 (relating to Monitoring Requirements)

H. Title 40 CFR § 61.15 (relating to Modification)

I. Title 40 CFR § 61.19 (relating to Circumvention)

8. For the National Emissions Standards for Asbestos specified in 40 CFR Part 61, Subpart M, the permit holder shall comply with the following requirements:

A. Requirements for Manufacturing Operations using Commercial Asbestos:

(i) Title 40 CFR § 61.144(a), and (b)(1) - (8) (relating to Standards for Manufacturing)

(ii) Title 40 CFR § 61.150(a)(1) (relating to Standard for Waste Disposal for Manufacturing, Fabricating, Demolition, Renovation, and Spraying Operations), for wetting for control of visible emissions

(iii) Title 40 CFR § 61.150(a)(2) (relating to Standard for Waste Disposal for Manufacturing, Fabricating, Demolition, Renovation, and Spraying Operations), for nonfriable asbestos processing

(iv) Title 40 CFR § 61.150(a)(3), and (5) (relating to Standard for Waste Disposal for Manufacturing, Fabricating, Demolition, Renovation, and Spraying Operations), for demolition and renovation

(v) Title 40 CFR § 61.150(b) - (e) (relating to Standard for Waste Disposal for Manufacturing, Fabricating, Demolition, Renovation, and Spraying Operations), for transport and disposal of asbestos-containing waste materials

(vi) Title 40 CFR § 61.152(b)(2) (relating to Air-Cleaning), for high efficiency particulate air (HEPA) filter requirements

(vii) Title 40 CFR § 61.153(a)(1) - (4), and (b) (relating to Reporting), for requirements to submit control device technical information to the EPA

9. For facilities where total annual benzene quantity from waste is greater than or equal to 1 megagram per year and less than 10 megagrams per year and subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:

   A. Title 40 CFR § 61.355(a)(1)(iii), (a)(2), (a)(4)(i) - (ii), (a)(6), (b), and (c)(1) - (3) (relating to Test Methods, Procedures, and Compliance Provisions), for calculation procedures

   B. Title 40 CFR § 61.356(a) (relating to Recordkeeping Requirements)

   C. Title 40 CFR § 61.356(b), and (b)(1) (relating to Recordkeeping Requirements)

   D. Title 40 CFR § 61.357(a), and (c) (relating to Reporting Requirements)

10. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.

11. For the chemical manufacturing process specified in 40 CFR Part 63, Subpart F, the permit holder shall comply with 40 CFR § 63.103(a) (relating to General Compliance, Reporting, and Recordkeeping Provisions) (Title 30 TAC Chapter 113, Subchapter C, § 113.110 incorporated by reference).

12. For the chemical manufacturing facilities with a 40 CFR Part 63, Subpart G Group 1 or Group 2 wastewater streams that are also subject to 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):

   A. Title 40 CFR § 63.110(e)(1)(i) and (e)(1)(ii) (relating to Applicability), for 40 CFR Part 63, Subpart G applicability to Group 1 or 2 Wastewater Streams

13. For the chemical manufacturing facilities with a 40 CFR Part 63, Subpart G Group 1 or Group 2 wastewater stream that is also subject to 40 CFR Part 61, Subpart F, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):

   A. Title 40 CFR § 63.110(f)(4)(i) (relating to Applicability), for 40 CFR Part 63, Subpart G applicability to Group 1 or 2 Wastewater Streams

14. For the chemical manufacturing facilities with a 40 CFR Part 63, Subpart G Group 2 wastewater stream, the permit holder shall comply with (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):

A. Title 40 CFR § 63.132(a), (a)(1), and (a)(1)(i) (relating to Process Wastewater Provisions - General)

B. Title 40 CFR § 63.146(b)(1) (relating to Process Wastewater Provisions - Reporting)

C. Title 40 CFR § 63.147(b)(8) (relating to Process Wastewater Provisions - Recordkeeping)

15. For the chemical manufacturing facilities subject to transfer operations requirements in 40 CFR Part 63, Subpart G, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):

A. Title 40 CFR § 63.126(e)(1) - (2), and (f) (relating to Transfer Operations Provisions Reference Control Technology)

B. Title 40 CFR § 63.128(f)(1) - (2) (relating to Transfer Operations Provisions - Test Methods and Procedures)

C. Title 40 CFR § 63.130(e) (relating to Transfer Operations Provisions - Periodic Recordkeeping and Reporting)

16. For the operations pertaining to the loading and unloading of marine tank vessels specified in 40 CFR Part 63, Subpart Y, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.300 incorporated by reference):

A. Title 40 CFR § 63.560(c) (relating to Designation of Affected Source), for applicability of the General Provisions of Subpart A

B. Title 40 CFR § 63.563(a)(4) (relating to Compliance and Performance Testing), for vapor tightness requirements of the marine vessels

C. Title 40 CFR § 63.564(a)(1) and (d) (relating to Monitoring Requirements)

D. Title 40 CFR § 63.565(a) (relating to Test Methods and Procedures), for performance testing requirements

E. Title 40 CFR § 63.565(c) (relating to Test Methods and Procedures), for vapor tightness requirements of the marine vessels

F. Title 40 CFR § 63.566 (relating to Construction and Reconstruction)

G. Title 40 CFR § 63.567(a) - (b) and (h) - (i) (relating to Reporting and Recordkeeping Requirements)

17. For ethylene process facilities subject to 40 CFR Part 63, Subpart YY with benzene laden waste streams and total annual benzene quantity from the facility

of less than 10 megagrams per year the permit holder shall comply with the following requirements for control of spent caustic and dilution steam blowdown waste streams as specified in 40 CFR § 63.1095(b)(1) (Title 30 TAC Chapter 113, Subchapter C, § 113.560 incorporated by reference):

A. For facilities with waste managed in containers the permit holder shall comply with the following requirements:

(i) Title 40 CFR § 61.345(a)(1) - (3), (b), and (c) (relating to Standards: Containers)

(ii) Title 40 CFR § 61.355(h) (relating to Test Methods, Procedures and Compliance Provisions)

(iii) Title 40 CFR § 61.356(g) (relating to Recordkeeping Requirements)

(iv) Title 40 CFR § 61.356(h) (relating to Recordkeeping Requirements)

B. For facilities with waste managed in individual drain systems the permit holder shall comply with the following requirements:

(i) Title 40 CFR § 61.346(a)(1)(i)(A), (B), (ii), (2), and (3) (relating to Standards: Individual Drain Systems)

(ii) Title 40 CFR § 61.355(h) (relating to Test Methods, Procedures and Compliance Provisions)

(iii) Title 40 CFR § 61.356(g) (relating to Recordkeeping Requirements)

(iv) Title 40 CFR § 61.356(h) (relating to Recordkeeping Requirements)

18. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

Additional Monitoring Requirements

19. Unless otherwise specified, the permit holder shall comply with the compliance assurance monitoring requirements as specified in the attached “CAM Summary”

upon issuance of the permit. In addition, the permit holder shall comply with the following:

A. The permit holder shall comply with the terms and conditions contained in 30 TAC § 122.147 (General Terms and Conditions for Compliance Assurance Monitoring).

B. The permit holder shall report, consistent with the averaging time identified in the "CAM Summary," deviations as defined by the deviation limit in the "CAM Summary." Any monitoring data below a minimum limit or above a maximum limit, that is collected in accordance with the requirements specified in 40 CFR § 64.7(c), shall be reported as a deviation. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

C. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time specified in the "CAM Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances in order to avoid reporting deviations. All monitoring data shall be collected in accordance with the requirements specified in 40 CFR § 64.7(c).

D. The permit holder shall operate the monitoring, identified in the attached "CAM Summary," in accordance with the provisions of 40 CFR § 64.7.

E. The permit holder shall comply with either of the following requirements for any capture system associated with the VOC control device subject to CAM. If the results of the following inspections indicate that the capture system is not working properly, the permit holder shall promptly take necessary corrective actions:

   (i) Once a year the permit holder shall inspect the capture system in compliance of CAM for leaks in accordance with 40 CFR Part 60, Appendix A, Test Method 21. Leaks shall be indicated by an instrument reading greater than or equal to 500 ppm above background or as defined by the underlying applicable requirement; or

   (ii) Once a month, the permit holder shall conduct a visual, audible, and/or olfactory inspection of the capture system in compliance of CAM to detect leaking components.

F. The permit holder shall comply with the requirements of 40 CFR § 70.6(a)(3)(ii)(A) and 30 TAC § 122.144(1)(A)-(F) for documentation of all required inspections.

20. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

21. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule, standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:

    A. Are incorporated by reference into this permit as applicable requirements

    B. Shall be located with this operating permit

    C. Are not eligible for a permit shield

22. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.

23. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard

Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).

24. The permit holder shall comply with the terms and conditions of the air addendum of the Industrial Hazardous Waste permits listed in the New Source Review Authorization Reference Attachment. Requirements other than those of the air addendum are not applicable to this operating permit.

25. The permit holder shall comply with the following requirements for Air Quality Standard Permits:

    A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit

    B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit

    C. Applicable requirements of 30 TAC § 116.617 for Pollution Control Projects based on the information contained in the registration application.

Compliance Requirements

26. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.

27. Use of Discrete Emission Credits to comply with the applicable requirements:

    A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:

        (i) Title 30 TAC Chapter 115

        (ii) Title 30 TAC Chapter 117

        (iii) If applicable, offsets for Title 30 TAC Chapter 116

        (iv) Temporarily exceed state NSR permit allowables

    B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:

        (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)

(ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4

(iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)

(iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122

(v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Risk Management Plan

28. For processes subject to 40 CFR Part 68 and specified in 40 CFR § 68.10, the permit holder shall comply with the requirements of the Accidental Release Prevention Provisions in 40 CFR Part 68. The permit holder shall submit to the appropriate agency either a compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR § 68.10(a), or as part of the compliance certification submitted under this permit, a certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of a risk management plan.

Protection of Stratospheric Ozone

29. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:

A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.

B. The permit holder shall comply with 40 CFR Part 82, Subpart F related to the disposal requirements for appliances using Class I or Class II (ozone-depleting) substances or non-exempt substitutes as specified in 40 CFR §§ 82.150 - 82.166 and the applicable Part 82 Appendices.

C. The permit holder shall comply with 40 CFR Part 82, Subpart H related to Halon Emissions Reduction requirements as specified in 40 CFR § 82.250 - § 82.270 and the applicable Part 82 Appendices.

Alternative Requirements

30. The permit holder shall comply with the approved alternative means of control (AMOC); alternative monitoring, recordkeeping, or reporting requirements; or requirements determined to be equivalent to an otherwise applicable requirement contained in the Alternative Requirements attachment of this permit. Units complying with an approved alternative requirement have reference to the approval in the Applicable Requirements summary listing for the unit. The permit holder shall maintain the original documentation, from the TCEQ Executive Director, demonstrating the method or limitation utilized. Documentation shall be maintained and made available in accordance with 30 TAC § 122.144.

Permit Location

31. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

New Source Review Authorization References

Alternative Requirement

Applicable Requirements Summary

Note: A "none" entry may be noted for some emission sources in this permit's "Applicable Requirements Summary" under the heading of "Monitoring and Testing Requirements" and/or "Recordkeeping Requirements" and/or "Reporting Requirements." Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
263	SRIC ENGINES	N/A	60IIII-EMERGEN	40 CFR Part 60, Subpart IIII	No changing attributes.
263	SRIC ENGINES	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
354	SRIC ENGINES	N/A	60IIII-EMERGEN	40 CFR Part 60, Subpart IIII	No changing attributes.
354	SRIC ENGINES	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
C-253	STORAGE TANKS/VESSELS	N/A	R5112-1-13	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-1
C-253	STORAGE TANKS/VESSELS	N/A	R5112-2-7	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-2
C-253	STORAGE TANKS/VESSELS	N/A	R5112-3-5	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-23
C-253	STORAGE TANKS/VESSELS	N/A	63G-1-1	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-253	STORAGE TANKS/VESSELS	N/A	63G-2-1	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-253	STORAGE TANKS/VESSELS	N/A	63G-3-1	40 CFR Part 63, Subpart G	Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
C-521	STORAGE TANKS/VESSELS	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
C-710	STORAGE TANKS/VESSELS	N/A	R5112-1-23	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-1
C-710	STORAGE TANKS/VESSELS	N/A	R5112-2-16	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-2
C-710	STORAGE TANKS/VESSELS	N/A	R5112-3-11	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-23
C-710	STORAGE TANKS/VESSELS	N/A	63G-1-8	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-710	STORAGE TANKS/VESSELS	N/A	63G-2-8	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-710	STORAGE TANKS/VESSELS	N/A	63G-3-6	40 CFR Part 63, Subpart G	Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).
C-711	STORAGE TANKS/VESSELS	N/A	R5112-1-24	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-1
C-711	STORAGE TANKS/VESSELS	N/A	R5112-2-17	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-2
C-711	STORAGE TANKS/VESSELS	N/A	R5112-3-12	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-23

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
C-711	STORAGE TANKS/VESSELS	N/A	63G-1-9	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-711	STORAGE TANKS/VESSELS	N/A	63G-2-9	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-711	STORAGE TANKS/VESSELS	N/A	63G-3-7	40 CFR Part 63, Subpart G	Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).
C-712A	STORAGE TANKS/VESSELS	N/A	R5112-1-19	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-1
C-712A	STORAGE TANKS/VESSELS	N/A	R5112-2-12	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-2
C-712A	STORAGE TANKS/VESSELS	N/A	R5112-3-8	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-23
C-712A	STORAGE TANKS/VESSELS	N/A	63G-1-5	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-712A	STORAGE TANKS/VESSELS	N/A	63G-2-5	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-712A	STORAGE TANKS/VESSELS	N/A	63G-3-3	40 CFR Part 63, Subpart G	Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).
C-712B	STORAGE TANKS/VESSELS	N/A	R5112-1-20	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-1
C-712B	STORAGE TANKS/VESSELS	N/A	R5112-2-13	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-2
C-712B	STORAGE TANKS/VESSELS	N/A	R5112-3-9	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-23
C-712B	STORAGE TANKS/VESSELS	N/A	63G-1-6	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-712B	STORAGE TANKS/VESSELS	N/A	63G-2-6	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-712B	STORAGE TANKS/VESSELS	N/A	63G-3-4	40 CFR Part 63, Subpart G	Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).
C-714	STORAGE TANKS/VESSELS	N/A	R5112-1-25	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-1
C-714	STORAGE TANKS/VESSELS	N/A	R5112-2-18	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-2

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
C-714	STORAGE TANKS/VESSELS	N/A	R5112-3-13	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-23
C-714	STORAGE TANKS/VESSELS	N/A	63G-1-10	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-714	STORAGE TANKS/VESSELS	N/A	63G-2-10	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-714	STORAGE TANKS/VESSELS	N/A	63G-3-8	40 CFR Part 63, Subpart G	Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).
C-720A	STORAGE TANKS/VESSELS	N/A	R5112-1-15	30 TAC Chapter 115, Storage of VOCs	TRUE VAPOR PRESSURE = True vapor pressure is greater than or equal to 1.5 psia but less than 11 psia, TANK DESCRIPTION = Tank using a vapor recovery system (VRS)
C-720A	STORAGE TANKS/VESSELS	N/A	R5112-1-40	30 TAC Chapter 115, Storage of VOCs	TRUE VAPOR PRESSURE = True vapor pressure is greater than or equal to 11 psia, TANK DESCRIPTION = Tank using a submerged fill pipe and vapor recovery system

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
C-720A	STORAGE TANKS/VESSELS	N/A	R5112-2-29	30 TAC Chapter 115, Storage of VOCs	TRUE VAPOR PRESSURE = True vapor pressure is greater than or equal to 11 psia, TANK DESCRIPTION = Tank using a submerged fill pipe and vapor recovery system
C-720A	STORAGE TANKS/VESSELS	N/A	R5112-2-8	30 TAC Chapter 115, Storage of VOCs	TRUE VAPOR PRESSURE = True vapor pressure is greater than or equal to 1.5 psia but less than 11 psia, TANK DESCRIPTION = Tank using a vapor recovery system (VRS)
C-720A	STORAGE TANKS/VESSELS	N/A	R5112-3-19	30 TAC Chapter 115, Storage of VOCs	TRUE VAPOR PRESSURE = True vapor pressure is greater than or equal to 11 psia, TANK DESCRIPTION = Tank using a submerged fill pipe and vapor recovery system
C-720A	STORAGE TANKS/VESSELS	N/A	R5112-3-6	30 TAC Chapter 115, Storage of VOCs	TRUE VAPOR PRESSURE = True vapor pressure is greater than or equal to 1.5 psia but less than 11 psia, TANK DESCRIPTION = Tank using a vapor recovery system (VRS)
C-720A	STORAGE TANKS/VESSELS	N/A	63G-1-2	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is greater than or equal to 11.11 psi (76.6 kPa), Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
C-720A	STORAGE TANKS/VESSELS	N/A	63G-1-20	40 CFR Part 63, Subpart G	NSPS Subpart Kb Applicability = The unit is subject to 40 CFR Part 60, Subpart Kb., Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa), Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-720A	STORAGE TANKS/VESSELS	N/A	63G-2-17	40 CFR Part 63, Subpart G	NSPS Subpart Kb Applicability = The unit is subject to 40 CFR Part 60, Subpart Kb., Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa), Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-720A	STORAGE TANKS/VESSELS	N/A	63G-2-2	40 CFR Part 63, Subpart G	NSPS Subpart Kb Applicability = The unit is subject to 40 CFR Part 60, Subpart Kb., Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is greater than or equal to 11.11 psi (76.6 kPa), Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
C-720A	STORAGE TANKS/VESSELS	N/A	63G-3-10	40 CFR Part 63, Subpart G	NSPS Subpart Kb Applicability = The unit is subject to 40 CFR Part 60, Subpart Kb., Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa), Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).
C-720A	STORAGE TANKS/VESSELS	N/A	63G-3-2	40 CFR Part 63, Subpart G	NSPS Subpart Kb Applicability = The unit is subject to 40 CFR Part 60, Subpart Kb., Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa), Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).
C-720B	STORAGE TANKS/VESSELS	N/A	R5112-1-16	30 TAC Chapter 115, Storage of VOCs	TRUE VAPOR PRESSURE = True vapor pressure is greater than or equal to 11 psia, TANK DESCRIPTION = Tank using a submerged fill pipe and vapor recovery system

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
C-720B	STORAGE TANKS/VESSELS	N/A	R5112-1-41	30 TAC Chapter 115, Storage of VOCs	TRUE VAPOR PRESSURE = True vapor pressure is greater than or equal to 1.5 psia but less than 11 psia, TANK DESCRIPTION = Tank using a vapor recovery system (VRS)
C-720B	STORAGE TANKS/VESSELS	N/A	R5112-2-30	30 TAC Chapter 115, Storage of VOCs	TRUE VAPOR PRESSURE = True vapor pressure is greater than or equal to 1.5 psia but less than 11 psia, TANK DESCRIPTION = Tank using a vapor recovery system (VRS)
C-720B	STORAGE TANKS/VESSELS	N/A	R5112-2-9	30 TAC Chapter 115, Storage of VOCs	TRUE VAPOR PRESSURE = True vapor pressure is greater than or equal to 11 psia, TANK DESCRIPTION = Tank using a submerged fill pipe and vapor recovery system
C-720B	STORAGE TANKS/VESSELS	N/A	R5112-3-20	30 TAC Chapter 115, Storage of VOCs	TRUE VAPOR PRESSURE = True vapor pressure is greater than or equal to 1.5 psia but less than 11 psia, TANK DESCRIPTION = Tank using a vapor recovery system (VRS)
C-720B	STORAGE TANKS/VESSELS	N/A	R5112-3-7	30 TAC Chapter 115, Storage of VOCs	TRUE VAPOR PRESSURE = True vapor pressure is greater than or equal to 11 psia, TANK DESCRIPTION = Tank using a submerged fill pipe and vapor recovery system

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
C-720B	STORAGE TANKS/VESSELS	N/A	63G-1-21	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is greater than or equal to 11.11 psi (76.6 kPa), Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-720B	STORAGE TANKS/VESSELS	N/A	63G-1-22	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa), Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-720B	STORAGE TANKS/VESSELS	N/A	63G-2-16	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is greater than or equal to 11.11 psi (76.6 kPa), Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
C-720B	STORAGE TANKS/VESSELS	N/A	63G-2-18	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is greater than or equal to 11.11 psi (76.6 kPa), Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
C-720B	STORAGE TANKS/VESSELS	N/A	63G-3-11	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa), Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).
C-720B	STORAGE TANKS/VESSELS	N/A	63G-3-9	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is greater than or equal to 11.11 psi (76.6 kPa), Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).
D-104	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-6	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
D-104A	STORAGE TANKS/VESSELS	N/A	R5112-1-33	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
D-104A	STORAGE TANKS/VESSELS	N/A	63G-1-13	40 CFR Part 63, Subpart G	No changing attributes.
D-104B	STORAGE TANKS/VESSELS	N/A	R5112-1-34	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
D-104B	STORAGE	N/A	63G-1-14	40 CFR Part 63,	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	TANKS/VESSELS			Subpart G	
D-104C	STORAGE TANKS/VESSELS	N/A	R5112-1-35	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
D-104C	STORAGE TANKS/VESSELS	N/A	63G-1-15	40 CFR Part 63, Subpart G	No changing attributes.
D-2525A	STORAGE TANKS/VESSELS	N/A	R5112-1-29	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-1
D-2525A	STORAGE TANKS/VESSELS	N/A	R5112-2-21	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-2
D-2525A	STORAGE TANKS/VESSELS	N/A	R5112-3-14	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-23
D-2525A	STORAGE TANKS/VESSELS	N/A	63G-1-23	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa), Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
D-2525A	STORAGE TANKS/VESSELS	N/A	63G-2-19	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is greater than or equal to 11.11 psi (76.6 kPa), Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
D-2525A	STORAGE TANKS/VESSELS	N/A	63G-3-12	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is greater than or equal to 11.11 psi (76.6 kPa), Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).
D-2525B	STORAGE TANKS/VESSELS	N/A	R5112-1-30	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-1
D-2525B	STORAGE TANKS/VESSELS	N/A	R5112-2-22	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-2
D-2525B	STORAGE TANKS/VESSELS	N/A	R5112-3-15	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-23
D-2525B	STORAGE TANKS/VESSELS	N/A	63G-1-24	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
D-2525B	STORAGE TANKS/VESSELS	N/A	63G-2-20	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
D-2525B	STORAGE TANKS/VESSELS	N/A	63G-3-13	40 CFR Part 63, Subpart G	Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
D-525A	STORAGE TANKS/VESSELS	N/A	R5112-1-31	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-1
D-525A	STORAGE TANKS/VESSELS	N/A	R5112-2-23	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-2
D-525A	STORAGE TANKS/VESSELS	N/A	R5112-3-16	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-23
D-525A	STORAGE TANKS/VESSELS	N/A	63G-1-25	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
D-525A	STORAGE TANKS/VESSELS	N/A	63G-2-21	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
D-525A	STORAGE TANKS/VESSELS	N/A	63G-3-14	40 CFR Part 63, Subpart G	Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).
D-525B	STORAGE TANKS/VESSELS	N/A	R5112-1-32	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-1
D-525B	STORAGE TANKS/VESSELS	N/A	R5112-2-24	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-2
D-525B	STORAGE TANKS/VESSELS	N/A	R5112-3-17	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-23

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
D-525B	STORAGE TANKS/VESSELS	N/A	63G-1-26	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
D-525B	STORAGE TANKS/VESSELS	N/A	63G-2-22	40 CFR Part 63, Subpart G	Control Device Type = Hazardous waste incinerator as specified in 40 CFR § 63.120(d)(8)(iii)
D-525B	STORAGE TANKS/VESSELS	N/A	63G-3-15	40 CFR Part 63, Subpart G	Control Device Type = Thermal incinerator, Design Evaluation Submitted = Results of a performance test was submitted to demonstrate compliance with 40 CFR § 63.119(e).
D-540	STORAGE TANKS/VESSELS	N/A	R5112-1-7	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-1
D-540	STORAGE TANKS/VESSELS	N/A	R5112-2-2	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-2
D-540	STORAGE TANKS/VESSELS	N/A	R5112-3-1	30 TAC Chapter 115, Storage of VOCs	Control Device = VCM-23
DB-1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DB-3	40 CFR Part 60, Subpart Db	No changing attributes.
DB-2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DB-4	40 CFR Part 60, Subpart Db	No changing attributes.
EDC-7	FUGITIVE EMISSION UNITS	N/A	63H-ALL-EDC-1	40 CFR Part 63, Subpart H	EDC plant fugitives control to EDC-1

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EDC-7	FUGITIVE EMISSION UNITS	N/A	63H-ALL-EDC-2	40 CFR Part 63, Subpart H	EDC plant fugitives control to EDC-2
EGEN-4	SRIC ENGINES	N/A	60IIII-EMERGEN	40 CFR Part 60, Subpart IIII	No changing attributes.
EGEN-4	SRIC ENGINES	N/A	63ZZZZ-2	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ENGSTK3	SRIC ENGINES	N/A	60IIII-EMERFWP	40 CFR Part 60, Subpart IIII	No changing attributes.
ENGSTK3	SRIC ENGINES	N/A	63ZZZZ-2	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRPENG-3	SRIC ENGINES	ENGSTK1, ENGSTK2, ENGSTK4, ENGSTK5, ENGSTK6, ENGSTK7	60IIII-EMERFWP	40 CFR Part 60, Subpart IIII	No changing attributes.
GRPENG-3	SRIC ENGINES	ENGSTK1, ENGSTK2, ENGSTK4, ENGSTK5, ENGSTK6, ENGSTK7	63ZZZZ-3	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRPFURN-5D	PROCESS HEATERS/FURNACES	F-2410, F-2420, F-410, F-420, F-430, F-440	63DDDDD	40 CFR Part 63, Subpart DDDDD	No changing attributes.
GRPINCIN	PROCESS HEATERS/FURNACES	VCM-1, VCM-2	63EEE-HAP	40 CFR Part 63, Subpart EEE	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRPLUBVENT	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	CTG-1LV, CTG-2LV, STG-1LV, STG-2LV	R5121-LV	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
LVPTRANSFER	LOADING/UNLOADING OPERATIONS	N/A	R5211-0	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
PLTBLAST	MISCELLANEOUS UNITS	N/A	R1111-PLTBLAST	30 TAC Chapter 111, Visible Emissions	No changing attributes.
PLTPAINT	MISCELLANEOUS UNITS	N/A	R1111-PLTPAINT	30 TAC Chapter 111, Visible Emissions	No changing attributes.
PRE-VCM-1	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-VCM-1	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
PRE-VCM-1	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	63G-3	40 CFR Part 63, Subpart G	No changing attributes.
PRE-VCM-2	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-VCM-2	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
PRE-VCM-2	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	63G4	40 CFR Part 63, Subpart G	No changing attributes.
PRE-VCM-23	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-VCM-23	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
PRE-VCM-23	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	63G5	40 CFR Part 63, Subpart G	No changing attributes.
UNIT 1	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-GT	30 TAC Chapter 111, Visible Emissions	No changing attributes.
UNIT 1	STATIONARY TURBINES	N/A	60GG-1	40 CFR Part 60, Subpart GG	No changing attributes.
UNIT 1	STATIONARY TURBINES	N/A	63YYYY	40 CFR Part 63, Subpart YYYY	No changing attributes.
UNIT 2	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-GT	30 TAC Chapter 111, Visible Emissions	No changing attributes.
UNIT 2	STATIONARY TURBINES	N/A	60GG-2	40 CFR Part 60, Subpart GG	No changing attributes.
UNIT 2	STATIONARY TURBINES	N/A	63YYYY	40 CFR Part 63, Subpart YYYY	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
VCM1	VINYL CHLORIDE PROCESS	N/A	61F-1	40 CFR Part 61, Subpart F	PRODUCT PRODUCED = ETHYLENE DICHLORIDE BY REACTION OF OXYGEN AND HYDROGEN CHLORIDE WITH ETHYLENE, OXYCHLORINATION REACTOR = PROCESS CONTAINS AN OXYCHLORINATION REACTOR, ETHYLENE DICHLOR PURIFICA = PROCESS CONTAINS EQUIPMENT USED IN ETHYLENE DICHLORIDE PURIFICATION, REACTOR = PROCESS DOES NOT INCLUDE A REACTOR
VCM1	VINYL CHLORIDE PROCESS	N/A	61F-2	40 CFR Part 61, Subpart F	PRODUCT PRODUCED = VINYL CHLORIDE BY ANY PROCESS, REACTOR = PROCESS INCLUDES A REACTOR
VCM1	CHEMICAL MANUFACTURING PROCESS	N/A	63F-2	40 CFR Part 63, Subpart F	No changing attributes.
VCM2	VINYL CHLORIDE PROCESS	N/A	61F-3	40 CFR Part 61, Subpart F	PRODUCT PRODUCED = ETHYLENE DICHLORIDE BY REACTION OF OXYGEN AND HYDROGEN CHLORIDE WITH ETHYLENE, OXYCHLORINATION REACTOR = PROCESS CONTAINS AN OXYCHLORINATION REACTOR, ETHYLENE DICHLOR PURIFICA = PROCESS CONTAINS EQUIPMENT USED IN ETHYLENE

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					DICHLORIDE PURIFICATION, REACTOR = PROCESS DOES NOT INCLUDE A REACTOR
VCM2	VINYL CHLORIDE PROCESS	N/A	61F-4	40 CFR Part 61, Subpart F	PRODUCT PRODUCED = VINYL CHLORIDE BY ANY PROCESS, REACTOR = PROCESS INCLUDES A REACTOR
VCM2	CHEMICAL MANUFACTURING PROCESS	N/A	63F-3	40 CFR Part 63, Subpart F	No changing attributes.
VCM-20	MISCELLANEOUS UNITS	N/A	R1111-VCM-20	30 TAC Chapter 111, Visible Emissions	No changing attributes.
VCM-21	MISCELLANEOUS UNITS	N/A	R1111-VCM-21	30 TAC Chapter 111, Visible Emissions	No changing attributes.
VCM-22	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-12	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
VCM-4	MISCELLANEOUS UNITS	N/A	R1111-VCM-4	30 TAC Chapter 111, Visible Emissions	No changing attributes.
VCM-5	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-10	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
VCM-6	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-11	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
VCM-9	FUGITIVE EMISSION UNITS	N/A	63H-ALL-VCM-1	40 CFR Part 63, Subpart H	VCM plant fugitives with possible control to VCM-1
VCM-9	FUGITIVE EMISSION UNITS	N/A	63H-ALL-VCM-2	40 CFR Part 63, Subpart H	VCM plant fugitives with possible control to VCM-2
VCM-9	FUGITIVE EMISSION UNITS	N/A	63H-ALL-VCM-23	40 CFR Part 63, Subpart H	VCM plant fugitives with possible control to VCM-23
VCMHE	LOADING/UNLOADING OPERATIONS	N/A	R5211-12	30 TAC Chapter 115, Loading and Unloading of VOC	Control Device = VCM-2
VCMHE	LOADING/UNLOADING OPERATIONS	N/A	R5211-17	30 TAC Chapter 115, Loading and Unloading of VOC	Control Device = VCM-23
VCMHE	LOADING/UNLOADING OPERATIONS	N/A	R5211-5	30 TAC Chapter 115, Loading and Unloading of VOC	Control Device = VCM-1
VCMHE	LOADING/UNLOADING OPERATIONS	N/A	63G-12	40 CFR Part 63, Subpart G	INSTALLATION DATE = The installation date of the halogen reduction device was on or after December 31, 1992., PERFORMANCE TEST EXEMPT = Boiler, process heater or incinerator does not qualify for exemption and a performance test is required.
VCMHE	LOADING/UNLOADING OPERATIONS	N/A	63G-3	40 CFR Part 63, Subpart G	INSTALLATION DATE = The installation date of the halogen reduction device was prior to December 31, 1992.,

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					PERFORMANCE TEST EXEMPT = The incinerator is burning hazardous waste and meets the requirements of 40 CFR § 63.128(c)(7).
VCMHE	LOADING/UNLOADING OPERATIONS	N/A	63G-8	40 CFR Part 63, Subpart G	INSTALLATION DATE = The installation date of the halogen reduction device was prior to December 31, 1992., PERFORMANCE TEST EXEMPT = The incinerator is burning hazardous waste and meets the requirements of 40 CFR § 63.128(c)(7).
VCMLE	LOADING/UNLOADING OPERATIONS	N/A	R5211-13	30 TAC Chapter 115, Loading and Unloading of VOC	Control Device = VCM-2
VCMLE	LOADING/UNLOADING OPERATIONS	N/A	R5211-18	30 TAC Chapter 115, Loading and Unloading of VOC	Control Device = VCM-23
VCMLE	LOADING/UNLOADING OPERATIONS	N/A	R5211-6	30 TAC Chapter 115, Loading and Unloading of VOC	Control Device = VCM-1
VCMLE	LOADING/UNLOADING OPERATIONS	N/A	63G-13	40 CFR Part 63, Subpart G	INSTALLATION DATE = The installation date of the halogen reduction device was on or after December 31, 1992., PERFORMANCE TEST EXEMPT = Boiler, process heater or incinerator does not qualify for exemption and a

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					performance test is required.
VCMLE	LOADING/UNLOADING OPERATIONS	N/A	63G-4	40 CFR Part 63, Subpart G	INSTALLATION DATE = The installation date of the halogen reduction device was prior to December 31, 1992., PERFORMANCE TEST EXEMPT = The incinerator is burning hazardous waste and meets the requirements of 40 CFR § 63.128(c)(7).
VCMLE	LOADING/UNLOADING OPERATIONS	N/A	63G-9	40 CFR Part 63, Subpart G	INSTALLATION DATE = The installation date of the halogen reduction device was prior to December 31, 1992., PERFORMANCE TEST EXEMPT = The incinerator is burning hazardous waste and meets the requirements of 40 CFR § 63.128(c)(7).
VCMML	LOADING/UNLOADING OPERATIONS	N/A	R5211-14	30 TAC Chapter 115, Loading and Unloading of VOC	Control Device = VCM-2
VCMML	LOADING/UNLOADING OPERATIONS	N/A	R5211-19	30 TAC Chapter 115, Loading and Unloading of VOC	Control Device = VCM-23
VCMML	LOADING/UNLOADING OPERATIONS	N/A	R5211-7	30 TAC Chapter 115, Loading and Unloading of VOC	Control Device = VCM-1
VCMML	LOADING/UNLOADING OPERATIONS	N/A	63G-10	40 CFR Part 63, Subpart G	INSTALLATION DATE = The installation date of the halogen

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					reduction device was prior to December 31, 1992., PERFORMANCE TEST EXEMPT = The incinerator is burning hazardous waste and meets the requirements of 40 CFR § 63.128(c)(7).
VCMML	LOADING/UNLOADING OPERATIONS	N/A	63G-14	40 CFR Part 63, Subpart G	INSTALLATION DATE = The installation date of the halogen reduction device was on or after December 31, 1992., PERFORMANCE TEST EXEMPT = Boiler, process heater or incinerator does not qualify for exemption and a performance test is required.
VCMML	LOADING/UNLOADING OPERATIONS	N/A	63G-5	40 CFR Part 63, Subpart G	INSTALLATION DATE = The installation date of the halogen reduction device was prior to December 31, 1992., PERFORMANCE TEST EXEMPT = The incinerator is burning hazardous waste and meets the requirements of 40 CFR § 63.128(c)(7).
VCMRAIL	LOADING/UNLOADING OPERATIONS	N/A	R5211-11	30 TAC Chapter 115, Loading and Unloading of VOC	Control Device = VCM-2
VCMRAIL	LOADING/UNLOADING OPERATIONS	N/A	R5211-16	30 TAC Chapter 115, Loading and Unloading of VOC	Control Device = VCM-23

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
VCMRAIL	LOADING/UNLOADING OPERATIONS	N/A	R5211-4	30 TAC Chapter 115, Loading and Unloading of VOC	Control Device = VCM-1
VCMRAIL	LOADING/UNLOADING OPERATIONS	N/A	63G-11	40 CFR Part 63, Subpart G	INSTALLATION DATE = The installation date of the halogen reduction device was on or after December 31, 1992., PERFORMANCE TEST EXEMPT = Boiler, process heater or incinerator does not qualify for exemption and a performance test is required.
VCMRAIL	LOADING/UNLOADING OPERATIONS	N/A	63G-2	40 CFR Part 63, Subpart G	INSTALLATION DATE = The installation date of the halogen reduction device was prior to December 31, 1992., PERFORMANCE TEST EXEMPT = The incinerator is burning hazardous waste and meets the requirements of 40 CFR § 63.128(c)(7).
VCMRAIL	LOADING/UNLOADING OPERATIONS	N/A	63G-7	40 CFR Part 63, Subpart G	INSTALLATION DATE = The installation date of the halogen reduction device was prior to December 31, 1992., PERFORMANCE TEST EXEMPT = The incinerator is burning hazardous waste and meets the requirements of 40 CFR § 63.128(c)(7).
VCMSHIP	LOADING/UNLOADING OPERATIONS	N/A	63Y-2	40 CFR Part 63, Subpart Y	Index Number = 63Y-2

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
VCMSHIP	LOADING/UNLOADING OPERATIONS	N/A	63Y-4	40 CFR Part 63, Subpart Y	Index Number = 63Y-4
VCMSHIP	LOADING/UNLOADING OPERATIONS	N/A	63Y-5	40 CFR Part 63, Subpart Y	Index Number = 63Y-5
YARDBLAST	MISCELLANEOUS UNITS	N/A	R1111-YARDBLAST	30 TAC Chapter 111, Visible Emissions	No changing attributes.
YARDENG	SRIC ENGINES	N/A	60IIII-BLSTCOMP	40 CFR Part 60, Subpart IIII	No changing attributes.
YARDENG	SRIC ENGINES	N/A	63ZZZZ-EMERCOMP	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
YARDPAINT	MISCELLANEOUS UNITS	N/A	R1111-YDPAINT	30 TAC Chapter 111, Visible Emissions	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
263	EU	60IIII-EMERGEN	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	None
263	EU	60IIII-EMERGEN	NMHC and NO_X	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	None
263	EU	60IIII-EMERGEN	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less	§ 60.4209(a)	§ 60.4214(b)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 89.112(a)	than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
263	EU	63ZZZZ-1	EXEMPT	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(b)(1) § 63.6595(c) § 63.6640(f)(1) [G]§ 63.6640(f)(2) § 63.6640(f)(3)	An affected source which meets either of the criteria in paragraphs §63.6590(b)(1)(i)-(ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(f).	None	None	§ 63.6645(c) § 63.6645(f)
354	EU	60IIII-EMERGEN	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	None
354	EU	60IIII-EMERGEN	NMHC and NO_X	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum	§ 60.4209(a)	§ 60.4214(b)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
354	EU	60IIII-EMERGEN	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	None
354	EU	63ZZZZ-1	EXEMPT	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(b)(1) § 63.6595(c) § 63.6640(f)(1) [G]§ 63.6640(f)(2) § 63.6640(f)(3)	An affected source which meets either of the criteria in paragraphs §63.6590(b)(1)(i)-(ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(f).	None	None	§ 63.6645(c) § 63.6645(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
C-253	EU	R5112-1-13	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-253	EU	R5112-2-7	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-253	EU	R5112-3-5	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-253	EU	63G-1-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-253	EU	63G-2-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-253	EU	63G-3-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii) § 63.120(d)(4) § 63.122(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-521	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
C-710	EU	R5112-1-23	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
C-710	EU	R5112-2-16	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-710	EU	R5112-3-11	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-710	EU	63G-1-8	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
C-710	EU	63G-2-8	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-710	EU	63G-3-6	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii) § 63.120(d)(4) § 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-711	EU	R5112-1-24	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-711	EU	R5112-2-17	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-711	EU	R5112-3-12	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
C-711	EU	63G-1-9	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-711	EU	63G-2-9	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-711	EU	63G-3-7	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii) § 63.120(d)(4) § 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
C-712A	EU	R5112-1-19	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-712A	EU	R5112-2-12	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-712A	EU	R5112-3-8	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-712A	EU	63G-1-5	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-712A	EU	63G-2-5	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-712A	EU	63G-3-3	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii) § 63.120(d)(4) § 63.122(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-712B	EU	R5112-1-20	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-712B	EU	R5112-2-13	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
C-712B	EU	R5112-3-9	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-712B	EU	63G-1-6	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-712B	EU	63G-2-6	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								[G]§ 63.152(a)	§ 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-712B	EU	63G-3-4	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii) § 63.120(d)(4) § 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.152(c)(6)
C-714	EU	R5112-1-25	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-714	EU	R5112-2-18	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-714	EU	R5112-3-13	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-714	EU	63G-1-10	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-714	EU	63G-2-10	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-714	EU	63G-3-8	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.148(e)		[G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	[G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.120(d)(4) § 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-720A	EU	R5112-1-15	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-720A	EU	R5112-1-40	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
C-720A	EU	R5112-2-29	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-720A	EU	R5112-2-8	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-720A	EU	R5112-3-19	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-720A	EU	R5112-3-6	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-720A	EU	63G-1-2	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-720A	EU	63G-1-20	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
C-720A	EU	63G-2-17	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-720A	EU	63G-2-2	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-720A	EU	63G-3-10	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii) § 63.120(d)(4) § 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-720A	EU	63G-3-2	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.148(e)		[G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	[G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.120(d)(4) § 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-720B	EU	R5112-1-16	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-720B	EU	R5112-1-41	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
C-720B	EU	R5112-2-30	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-720B	EU	R5112-2-9	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-720B	EU	R5112-3-20	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-720B	EU	R5112-3-7	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
C-720B	EU	63G-1-21	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-720B	EU	63G-1-22	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
C-720B	EU	63G-2-16	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-720B	EU	63G-2-18	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-720B	EU	63G-3-11	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii) § 63.120(d)(4) § 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
C-720B	EU	63G-3-9	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.148(e)		[G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	[G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.120(d)(4) § 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
D-104	EP	R5121-6	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(c)(1)(B) § 115.127(c)(1)	A vent gas stream with a combined weight of the VOC or classes of compounds specified in § 115.121(c)(1)(B)-(C) of 100 lbs (45.4 kg), or less, in a continuous 24-hour period is exempt from § 115.121(c)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
D-104A	EU	R5112-1-33	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1) § 115.111(c)(2) § 115.112(c)(2) § 115.112(c)(2)(A) § 115.114(c)(1)(A)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	§ 115.114(c)(1)(A) ** See Periodic Monitoring Summary	None	§ 115.114(c)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
D-104A	EU	63G-1-13	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(iii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(3)(i) § 63.120(a)(3)(ii) § 63.120(a)(3)(iii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
D-104B	EU	R5112-1-34	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1) § 115.111(c)(2) § 115.112(c)(2) § 115.112(c)(2)(A) § 115.114(c)(1)(A)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	§ 115.114(c)(1)(A) ** See Periodic Monitoring Summary	None	§ 115.114(c)(1)(B)
D-104B	EU	63G-1-14	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(iii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(3)(i) § 63.120(a)(3)(ii) § 63.120(a)(3)(iii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)				§ 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
D-104C	EU	R5112-1-35	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1) § 115.111(c)(2) § 115.112(c)(2) § 115.112(c)(2)(A) § 115.114(c)(1)(A)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	§ 115.114(c)(1)(A) ** See Periodic Monitoring Summary	None	§ 115.114(c)(1)(B)
D-104C	EU	63G-1-15	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(iii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(3)(i) § 63.120(a)(3)(ii) § 63.120(a)(3)(iii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
D-2525A	EU	R5112-1-29	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
D-2525A	EU	R5112-2-21	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
D-2525A	EU	R5112-3-14	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
D-2525A	EU	63G-1-23	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
D-2525A	EU	63G-2-19	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
D-2525A	EU	63G-3-12	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii) § 63.120(d)(4) § 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
D-2525B	EU	R5112-1-30	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
D-2525B	EU	R5112-2-22	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
D-2525B	EU	R5112-3-15	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
D-2525B	EU	63G-1-24	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
D-2525B	EU	63G-2-20	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
D-2525B	EU	63G-3-13	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii) § 63.120(d)(4) § 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
D-525A	EU	R5112-1-31	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device	** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						specified in Table I(b).			
D-525A	EU	R5112-2-23	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
D-525A	EU	R5112-3-16	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
D-525A	EU	63G-1-25	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.152(c)(6)
D-525A	EU	63G-2-21	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
D-525A	EU	63G-3-14	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii) § 63.120(d)(4) § 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
D-525B	EU	R5112-1-32	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
D-525B	EU	R5112-2-24	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
D-525B	EU	R5112-3-17	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
D-525B	EU	63G-1-26	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
D-525B	EU	63G-2-22	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.148(j) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
D-525B	EU	63G-3-15	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) [G]§ 63.148(d) § 63.148(e)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(d)(1) § 63.120(d)(1)(ii) § 63.120(d)(1)(ii)(A) § 63.120(d)(5) § 63.120(d)(6) § 63.148(b)(1)(i) § 63.148(b)(1)(ii) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.123(a) § 63.123(f)(1) [G]§ 63.123(f)(2) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a)	§ 63.120(d)(1)(ii)(B) § 63.120(d)(2) § 63.120(d)(2)(i) [G]§ 63.120(d)(2)(iii) § 63.120(d)(3) § 63.120(d)(3)(i) § 63.120(d)(3)(ii) § 63.120(d)(4) § 63.122(b) § 63.122(c)(1) [G]§ 63.122(g)(1) [G]§ 63.122(g)(2) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
D-540	EU	R5112-1-7	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device	** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						specified in Table I(b).			
D-540	EU	R5112-2-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
D-540	EU	R5112-3-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(c)(1)	Tanks shall not store VOC, other than crude oil or condensate, unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(b).	** See Periodic Monitoring Summary	None	None
DB-1	EU	60DB-3	SO_2	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
DB-1	EU	60DB-3	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
DB-1	EU	60DB-3	PM (OPACITY)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
DB-1	EU	60DB-3	NO_X	40 CFR Part 60, Subpart Db	§ 60.44b(l)(1) § 60.44b(h) § 60.44b(i) § 60.46b(a) § 60.48b(h)	Affected facilities combusting coal, oil, or natural gas, or a mixture of these fuels, or any other fuels: a limit of 86 ng/JI (0.20 lb/million Btu) heat input unless the affected facility meets the specified requirements.	§ 60.46b(c) § 60.46b(f) [G]§ 60.46b(f)(1)	[G]§ 60.49b(d) § 60.49b(o) [G]§ 60.49b(p)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3) § 60.49b(b)
DB-2	EU	60DB-4	SO_2	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
DB-2	EU	60DB-4	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
DB-2	EU	60DB-4	PM (OPACITY)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
DB-2	EU	60DB-4	NO_X	40 CFR Part 60, Subpart Db	§ 60.44b(l)(1) § 60.44b(h) § 60.44b(i) § 60.46b(a) § 60.48b(h)	Affected facilities combusting coal, oil, or natural gas, or a mixture of these fuels, or any other fuels: a limit of 86 ng/JI (0.20 lb/million Btu) heat input unless the affected facility meets the specified requirements.	§ 60.46b(c) § 60.46b(f) [G]§ 60.46b(f)(1)	[G]§ 60.49b(d) § 60.49b(o) [G]§ 60.49b(p)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3) § 60.49b(b)
EDC-7	EU	63H-ALL-EDC-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.164 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Compressors. §63.164(a)-(i)	[G]§ 63.164 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.165 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief device in gas/vapor service. §63.165(a)-(d)	[G]§ 63.165 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.166 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Sampling connection systems. §63.166(a)-(c)	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EDC-7	EU	63H-ALL-EDC-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Instrumentation systems. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief devices in liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-1	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.170 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Surge control vessels and bottom receivers.	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-1	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	Owners/operators of closed-vent systems and control devices used to comply with provisions of this subpart shall comply with the provisions of this section, except as provided in §63.162(b).	[G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	[G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-1	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(c) § 63.172(e) [G]§ 63.172(h) § 63.172(m)	Enclosed combustion devices shall be designed and operated to reduce the organic HAP or VOC emissions vented to them with requirements as	§ 63.172(e) [G]§ 63.172(h) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						specified in this section.		§ 63.181(g)(1)(ii) § 63.181(g)(1)(iv) [G]§ 63.181(g)(2)	
EDC-7	EU	63H-ALL-EDC-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.173 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Agitators gas/vapor service and in light liquid service. §63.173(a)-(j).	[G]§ 63.173 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.174 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Connectors in gas/vapor service and in light liquid service. §63.174(a)-(j)	[G]§ 63.174 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.163 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.176	Standards: Pumps in light liquid service. §63.163(a)-(j)	[G]§ 63.163 [G]§ 63.176 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(3) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7) § 63.181(h)(8)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.167 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Open-ended valves or lines. §63.167(a)-(e).	[G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								§ 63.181(h)(6) § 63.181(h)(7)	
EDC-7	EU	63H-ALL-EDC-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.168 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Valves in gas/vapor service and in light liquid service. §63.168(a)-(j)	[G]§ 63.168 [G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.164 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Compressors. §63.164(a)-(i)	[G]§ 63.164 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.165 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief device in gas/vapor service. §63.165(a)-(d)	[G]§ 63.165 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.166 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Sampling connection systems. §63.166(a)-(c)	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EDC-7	EU	63H-ALL-EDC-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Instrumentation systems. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief devices in liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-2	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.170 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Surge control vessels and bottom receivers.	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-2	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	Owners/operators of closed-vent systems and control devices used to comply with provisions of this subpart shall comply with the provisions of this section, except as provided in §63.162(b).	[G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	[G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-2	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(c) § 63.172(e) [G]§ 63.172(h) § 63.172(m)	Enclosed combustion devices shall be designed and operated to reduce the organic HAP or VOC emissions vented to them with requirements as	§ 63.172(e) [G]§ 63.172(h) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						specified in this section.		§ 63.181(g)(1)(ii) § 63.181(g)(1)(iv) [G]§ 63.181(g)(2)	
EDC-7	EU	63H-ALL-EDC-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.173 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Agitators gas/vapor service and in light liquid service. §63.173(a)-(j).	[G]§ 63.173 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.174 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Connectors in gas/vapor service and in light liquid service. §63.174(a)-(j)	[G]§ 63.174 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.163 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.176	Standards: Pumps in light liquid service. §63.163(a)-(j)	[G]§ 63.163 [G]§ 63.176 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(3) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7) § 63.181(h)(8)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EDC-7	EU	63H-ALL-EDC-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.167 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Open-ended valves or lines. §63.167(a)-(e).	[G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								§ 63.181(h)(6) § 63.181(h)(7)	
EDC-7	EU	63H-ALL-EDC-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.168 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Valves in gas/vapor service and in light liquid service. §63.168(a)-(j)	[G]§ 63.168 [G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EGEN-4	EU	60IIII-EMERGEN	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	None
EGEN-4	EU	60IIII-EMERGEN	NMHC and NO_x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder	§ 60.4209(a)	§ 60.4214(b)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
EGEN-4	EU	60IIII-EMERGEN	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	None
EGEN-4	EU	63ZZZZ-2	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						engines under this part.			
ENGSTK3	EU	60IIII-EMERFWP	NMHC and NO_x	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as listed in Table 4 to this subpart.	§ 60.4209(a)	§ 60.4214(b)	None
ENGSTK3	EU	60IIII-EMERFWP	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as listed in Table 4 to this subpart.	§ 60.4209(a)	§ 60.4214(b)	None
ENGSTK3	EU	63ZZZZ-2	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
GRPENG-3	EU	60IIII-EMERFWP	NMHC and NO_X	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as listed in Table 4 to this subpart.	§ 60.4209(a)	§ 60.4214(b)	None
GRPENG-3	EU	60IIII-EMERFWP	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as listed in Table 4 to this subpart.	§ 60.4209(a)	§ 60.4214(b)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPENG-3	EU	63ZZZZ-3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(b) § 63.6640(f)(1) [G]§ 63.6640(f)(2) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii § 63.6640(b)	§ 63.6625(i) § 63.6655(a) § 63.6655(a)(1) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(b) § 63.6640(e) § 63.6650(f)
GRPFURN-5D	EU	63DDDDD	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
GRPINCIN	EU	63EEE-HAP	DIOXINS/FURANS	40 CFR Part 63, Subpart EEE	§ 63.1218(a)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(l)(2)	For existing HCl production furnaces, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, for dioxins and furans, CO emissions in excess of the limits provided by paragraph § 63.1218(a)(5).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) [G]§ 63.1207(b)(2) [G]§ 63.1207(b)(3) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(k) § 63.1209(k)(1)(i) § 63.1209(k)(2)(i) § 63.1209(k)(2)(ii) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(4) § 63.1209(k)(5) [G]§ 63.1209(k)(6) [G]§ 63.1209(k)(7) [G]§ 63.1209(k)(8) [G]§ 63.1209(k)(9) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1218(a)(5)(i) § 63.1218(d)		§ 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(A) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(ii) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1208(b)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(k)(2)(i) [G]§ 63.1209(k)(3) [G]§ 63.1209(k)(8) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xv) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) [G]§ 63.1207(f)(1)(xx) [G]§ 63.1207(f)(1)(xxi) § 63.1207(f)(1)(xxii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(2) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
GRPINCIN	EU	63EEE-HAP	Mercury	40 CFR Part 63, Subpart EEE	§ 63.1218(a)(2) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1218(d)	For existing HCl production furnaces, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, for Hg, hydrogen chloride and chlorine gas emissions in excess of the levels provided by paragraph § 63.1218(a)(6).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(2) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(B) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
GRPINCIN	EU	63EEE-HAP	Cd and Pb	40 CFR Part 63, Subpart EEE	§ 63.1218(a)(3) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1)	For existing HCl production furnaces, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, for lead and cadmium, except for an area source as defined under § 63.2, hydrogen chloride and chlorine gas emissions in excess of the levels provided by § 63.1218(a)(6).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(n) § 63.1209(n)(1) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1218(d)		§ 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(3) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
GRPINCIN	EU	63EEE-HAP	A_R, B_E and C_R	40 CFR Part 63, Subpart EEE	§ 63.1218(a)(4) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(n) § 63.1209(n)(1) [G]§ 63.1209(n)(5) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1218(d)	For existing HCl production furnaces, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, for arsenic, beryllium, and chromium, except for an area source as defined under § 63.2, hydrogen chloride and chlorine gas emissions in excess of the levels provided by paragraph § 63.1218(a)(6).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1208(b)(4) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) § 63.1209(g)(1)(iv)(A) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
GRPINCIN	EU	63EEE-HAP	Total Hydrocarbons/CO	40 CFR Part 63, Subpart EEE	§ 63.1218(a)(5)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k)	For existing HCl production furnaces, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain CO in excess of 100 ppmv, over an hourly rolling average (monitored continuously with a CEMs), dry basis and corrected to 7 % 02. If complying with this CO standard rather than the hydrocarbon standard under §63.1218(a)(5)(ii), you must also document as	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(6) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1218(d)	specified.	[G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(i) § 63.1207(g)(2)(v) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(i) § 63.1209(a)(2) [G]§ 63.1209(a)(3) [G]§ 63.1209(a)(6) § 63.1209(a)(7) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(i) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPINCIN	EU	63EEE-HAP	Total Chlorine	40 CFR Part 63, Subpart EEE	§ 63.1218(a)(6)(i) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1207(m)(3) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(n)(4) § 63.1209(o) § 63.1209(o)(1)(i) [G]§ 63.1209(o)(2) [G]§ 63.1209(o)(3) § 63.1209(o)(4) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1218(d)	For existing HCl production furnaces, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain emission in excess of 150 ppmv, combined emissions, expressed as a chloride (Cl^-) equivalent, dry basis and corrected to 7 % 02.	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) [G]§ 63.1208(b)(5)(i) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(m)(1) [G]§ 63.1207(m)(2) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xi) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvi) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxv) § 63.1207(f)(1)(xxvi) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) § 63.1209(c)(5) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		[G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1207(m)(5) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
GRPINCIN	EU	63EEE-HAP	PM	40 CFR Part 63, Subpart EEE	§ 63.1218(a)(7) [G]§ 63.1206(b)(5) § 63.1206(b)(8)(v) § 63.1206(b)(8)(vi) § 63.1206(b)(8)(vii) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k)	For existing HCl production furnaces, you must not discharge or cause to be emitted into the atmosphere combustion gases that contain, for particulate matter, except for an area source as defined under §63.2, hydrogen chloride and chlorine gas emissions in excess of the levels provided by §63.1218(a)(6).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(b)(8)(iii) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) § 63.1209(m) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(n)(3) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1218(d)		§ 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(i)(C) § 63.1207(g)(1)(ii) § 63.1207(g)(2)(iv) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(6) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(a)(1)(iii) § 63.1209(a)(5) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4) [G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(m)(1)(i) [G]§ 63.1209(m)(1)(iv) [G]§ 63.1209(m)(2) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)	[G]§ 63.1211(d)	§ 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxiii) [G]§ 63.1207(f)(1)(xxiv) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(iv) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.1212(a)
GRPINCIN	EU	63EEE-HAP	P¯RICIPAL ORGANIC HAZARDO	40 CFR Part 63, Subpart EEE	§ 63.1218(c)(1) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(i) § 63.1206(c)(6)(ii) [G]§ 63.1206(c)(6)(iv) [G]§ 63.1206(c)(6)(v) [G]§ 63.1206(c)(6)(vi) [G]§ 63.1206(c)(7) § 63.1207(g)(1)(iii)(A) [G]§ 63.1207(k) [G]§ 63.1207(l)(1) § 63.1209(c)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(d) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1211(c)(1) § 63.1211(c)(2) § 63.1211(c)(4) § 63.1218(c)(3)(i) § 63.1218(c)(3)(ii)	For HCl production furnaces, except as provided in §63.1218(c)(2), you must achieve a DRE of 99.99% for each POHC designated under paragraph §63.1218(c)(3). You must calculate SRE for each POHC from the equation in §63.1218(c)(1).	[G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) § 63.1206(b)(7)(iii) [G]§ 63.1206(c)(3) § 63.1207(a) § 63.1207(b)(1) § 63.1207(c)(1) [G]§ 63.1207(c)(2) [G]§ 63.1207(d) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xxvii) § 63.1207(g) § 63.1207(g)(1)(ii) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(l)(1) § 63.1208(b)(7) § 63.1208(b)(8) § 63.1209(b)(1) [G]§ 63.1209(b)(2) § 63.1209(b)(3) § 63.1209(b)(4) [G]§ 63.1209(b)(5) [G]§ 63.1209(c)(4)	§ 63.1206(b)(11) [G]§ 63.1206(b)(12) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(1) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1206(c)(5) § 63.1206(c)(6)(vii) [G]§ 63.1206(c)(7) § 63.1207(f)(1)(xii) § 63.1207(g)(1)(iii)(A) § 63.1209(b)(1) [G]§ 63.1209(c)(2) [G]§ 63.1209(c)(4) [G]§ 63.1209(q) § 63.1211(b) [G]§ 63.1211(c)(3) [G]§ 63.1211(d)	§ 63.1206(b)(11) [G]§ 63.1206(b)(5) [G]§ 63.1206(c)(2) [G]§ 63.1206(c)(3) [G]§ 63.1206(c)(4) [G]§ 63.1207(e) [G]§ 63.1207(f)(1)(i) § 63.1207(f)(1)(ii) § 63.1207(f)(1)(ii)(A) § 63.1207(f)(1)(ii)(B) § 63.1207(f)(1)(ii)(C) § 63.1207(f)(1)(ii)(D) [G]§ 63.1207(f)(1)(iii) § 63.1207(f)(1)(iv) § 63.1207(f)(1)(ix) § 63.1207(f)(1)(v) § 63.1207(f)(1)(vi) § 63.1207(f)(1)(vii) § 63.1207(f)(1)(viii) § 63.1207(f)(1)(xii) § 63.1207(f)(1)(xix) § 63.1207(f)(1)(xvii) § 63.1207(f)(1)(xviii) § 63.1207(f)(1)(xxvii) § 63.1207(f)(2)(ix) § 63.1207(f)(2)(v) § 63.1207(f)(2)(vi) § 63.1207(f)(2)(vii) § 63.1207(f)(2)(viii) § 63.1207(f)(2)(x) [G]§ 63.1207(h) [G]§ 63.1207(i) [G]§ 63.1207(j)(1) § 63.1207(j)(3) § 63.1207(j)(4) § 63.1207(j)(5) [G]§ 63.1207(k) [G]§ 63.1207(l)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.1209(d) [G]§ 63.1209(f) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) § 63.1209(i) [G]§ 63.1209(j) § 63.1209(p) [G]§ 63.1209(q) § 63.1209(r)		§ 63.1207(l)(3) § 63.1209(c)(3) § 63.1209(g)(1)(i) § 63.1209(g)(1)(ii) [G]§ 63.1209(g)(1)(iii) [G]§ 63.1210(a) [G]§ 63.1210(b)(1) § 63.1210(b)(2) § 63.1210(b)(3)(i) § 63.1210(c)(1)(i) § 63.1210(c)(2) [G]§ 63.1210(c)(3) [G]§ 63.1210(c)(4) [G]§ 63.1210(d) § 63.1211(a) [G]§ 63.1211(c)(3) [G]§ 63.1211(d) § 63.1212(a)
GRPLUBVENT	EP	R5121-LV	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(c)(1)(B) § 115.127(c)(1)	A vent gas stream with a combined weight of the VOC or classes of compounds specified in § 115.121(c)(1)(B)-(C) of 100 lbs (45.4 kg), or less, in a continuous 24-hour period is exempt from § 115.121(c)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(3) § 115.126(4)	None
LVPTRANSFER	EU	R5211-0	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(b)(2) § 115.212(b)(2) § 115.214(b)(1)(B) § 115.214(b)(1)(D) § 115.214(b)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division except as specified.	§ 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
PLTBLAST	EU	R1111-PLTBLAST	OPACITY	30 TAC Chapter 111, Visible	§ 111.111(a)(8)(A)	Visible emissions shall not be permitted to exceed an	§ 111.111(a)(8)(A) ** See Periodic	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Emissions		opacity of 30% for any six-minute period from all other sources not specified in this section.	Monitoring Summary		
PLTPAINT	EU	R1111-PLTPAINT	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(8)(A)	Visible emissions shall not be permitted to exceed an opacity of 30% for any six-minute period from all other sources not specified in this section.	§ 111.111(a)(8)(A) ** See Periodic Monitoring Summary	None	None
PRE-VCM-1	EP	R5121-VCM-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.121(c)(1) § 115.122(c)(1) § 115.122(c)(1)(A)	Any process vent containing one or more VOC or classes of VOC specified in §115.121(c)(1)(A)-(C), shall be controlled as per §115.122(c)(1).	[G]§ 115.125 § 115.126(2) ** See CAM Summary	§ 115.126 § 115.126(2)	None
PRE-VCM-1	EP	63G-3	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.113(a)(2) § 63.113(c)(1) § 63.113(c)(1)(ii) § 63.113(h) [G]§ 63.115(f) § 63.116(b)	Reduce emissions of total organic HAPs by 98 wt.% or to a concentration of 20 ppm by volume; whichever is less stringent or as specified. §63.113(a)(2)(i)-(ii)	§ 63.114(a) § 63.114(a)(1)(i) [G]§ 63.114(a)(4) § 63.114(e) [G]§ 63.115(f) [G]§ 63.116(d)	§ 63.114(a)(1) [G]§ 63.114(a)(4) [G]§ 63.117(a)(6) § 63.118(a)(1) § 63.118(a)(2) [G]§ 63.152(a) [G]§ 63.152(f)	§ 63.114(e) [G]§ 63.117(a)(6) § 63.117(f) § 63.118(f)(1) § 63.118(f)(2) [G]§ 63.151(b) § 63.151(e) [G]§ 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(4)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.152(c)(6)
PRE-VCM-2	EP	R5121-VCM-2	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.121(c)(1) § 115.122(c)(1) § 115.122(c)(1)(A)	Any process vent containing one or more VOC or classes of VOC specified in §115.121(c)(1)(A)-(C), shall be controlled as per §115.122(c)(1).	[G]§ 115.125 § 115.126(2) ** See CAM Summary	§ 115.126 § 115.126(2)	None
PRE-VCM-2	EP	63G4	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.113(a)(2) § 63.113(c)(1) § 63.113(c)(1)(ii) § 63.113(h) [G]§ 63.115(f) § 63.116(b)	Reduce emissions of total organic HAPs by 98 wt.% or to a concentration of 20 ppm by volume; whichever is less stringent or as specified. §63.113(a)(2)(i)-(ii)	§ 63.114(a) § 63.114(a)(1)(i) [G]§ 63.114(a)(4) § 63.114(e) [G]§ 63.115(f) [G]§ 63.116(d)	§ 63.114(a)(1) [G]§ 63.114(a)(4) [G]§ 63.117(a)(6) § 63.118(a)(1) § 63.118(a)(2) [G]§ 63.152(a) [G]§ 63.152(f)	§ 63.114(e) [G]§ 63.117(a)(6) § 63.117(f) § 63.118(f)(1) § 63.118(f)(2) [G]§ 63.151(b) § 63.151(e) [G]§ 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
PRE-VCM-23	EP	R5121-VCM-23	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.121(c)(1) § 115.122(c)(1) § 115.122(c)(1)(A)	Any process vent containing one or more VOC or classes of VOC specified in §115.121(c)(1)(A)-(C), shall be controlled as per §115.122(c)(1).	[G]§ 115.125 § 115.126(2) ** See CAM Summary	§ 115.126 § 115.126(2)	None
PRE-VCM-	EP	63G5	112(B)	40 CFR Part 63,	[G]§ 63.113(a)(2)	Reduce emissions of total	§ 63.114(a)	§ 63.114(a)(1)	§ 63.114(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
23			HAPS	Subpart G	§ 63.113(c)(1) § 63.113(c)(1)(ii) § 63.113(h) [G]§ 63.115(f) § 63.116(b)	organic HAPs by 98 wt.% or to a concentration of 20 ppm by volume; whichever is less stringent or as specified. §63.113(a)(2)(i)-(ii)	§ 63.114(a)(1)(i) [G]§ 63.114(a)(4) § 63.114(e) [G]§ 63.115(f) [G]§ 63.116(d)	[G]§ 63.114(a)(4) [G]§ 63.117(a)(6) § 63.118(a)(1) § 63.118(a)(2) [G]§ 63.152(a) [G]§ 63.152(f)	[G]§ 63.117(a)(6) § 63.117(f) § 63.118(f)(1) § 63.118(f)(2) [G]§ 63.151(b) § 63.151(e) [G]§ 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
UNIT 1	EP	R1111-GT	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
UNIT 1	EU	60GG-1	SO2	40 CFR Part 60, Subpart GG	§ 60.333(b)	No stationary gas turbine shall burn any fuel which contains sulfur in excess of 0.8% by weight.	§ 60.334(h) § 60.334(h)(4)	None	None
UNIT 1	EU	63YYYY	112(B) HAPS	40 CFR Part 63, Subpart YYYY	§ 63.6095(d)	If you start up a new or reconstructed stationary combustion turbine that is a lean premix gas-fired	None	None	§ 63.6145(a) § 63.6145(b) § 63.6145(c) § 63.6145(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						stationary combustion turbine or diffusion flame gas-fired stationary combustion turbine as defined by this subpart, you must comply with the Initial Notification requirements set forth in §63.6145 but need not comply with any other requirement of this subpart until EPA takes final action to require compliance.			
UNIT 2	EP	R1111-GT	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
UNIT 2	EU	60GG-2	SO2	40 CFR Part 60, Subpart GG	§ 60.333(b)	No stationary gas turbine shall burn any fuel which contains sulfur in excess of 0.8% by weight.	§ 60.334(h) § 60.334(h)(4)	None	None
UNIT 2	EU	63YYYY	112(B) HAPS	40 CFR Part 63, Subpart YYYY	§ 63.6095(d)	If you start up a new or reconstructed stationary combustion turbine that is a lean premix gas-fired stationary combustion turbine or diffusion flame gas-fired stationary combustion turbine as defined by this subpart, you must comply with the Initial Notification requirements set forth in §63.6145 but	None	None	§ 63.6145(a) § 63.6145(b) § 63.6145(c) § 63.6145(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						need not comply with any other requirement of this subpart until EPA takes final action to require compliance.			
VCM1	EU	61F-1	Vinyl Chloride	40 CFR Part 61, Subpart F	§ 61.60(a)(1) § 61.62(a) § 61.62(b) [G]§ 61.65(b)(6) § 61.68(e)	This subpart applies to plants which produce ethylene dichloride by reaction of oxygen and hydrogen chloride with ethylene.	§ 61.67(a) § 61.67(a)(2) § 61.67(b) § 61.67(c) § 61.67(e) § 61.67(f) § 61.67(g) [G]§ 61.67(g)(1) § 61.68(a) § 61.68(b) [G]§ 61.68(c) § 61.68(d) § 61.68(e) § 61.68(f) § 61.70(c)	§ 61.67(f) § 61.68(f) § 61.71(a) § 61.71(a)(3)	§ 61.67(e) § 61.69(a) § 61.69(b)(2) [G]§ 61.69(c) § 61.70(a)(1) § 61.70(b)(2) § 61.70(c)(1)
VCM1	EU	61F-2	Vinyl Chloride	40 CFR Part 61, Subpart F	§ 61.63(a) [G]§ 61.65(b)(6) § 61.68(e)	The concentration of vinyl chloride in each exhaust gas stream is not to exceed 10 ppm (average for 3-hour period), except as provided in §61.65(a).	§ 61.67(a) § 61.67(a)(2) § 61.67(b) § 61.67(c) § 61.67(e) § 61.67(f) § 61.67(g) [G]§ 61.67(g)(1) § 61.68(a) § 61.68(b) [G]§ 61.68(c) § 61.68(d) § 61.68(e) § 61.68(f) § 61.70(c)	§ 61.67(f) § 61.68(f) § 61.71(a) § 61.71(a)(3)	§ 61.67(e) § 61.69(a) § 61.69(b)(2) [G]§ 61.69(c) § 61.70(a)(1) § 61.70(b)(2) § 61.70(c)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
VCM1	PRO	63F-2	112(B) HAPS	40 CFR Part 63, Subpart F	§ 63.100(b) [G]§ 63.102(a) [G]§ 63.102(c) § 63.104(a) [G]§ 63.104(d) § 63.104(e) § 63.104(e)(1) [G]§ 63.104(e)(2) § 63.105(d)	Except as provided in paragraphs (b)(4) and (c) of this section, the provisions of subparts F, G, and H apply to chemical manufacturing process units that meet the criteria.	§ 63.103(b)(1) § 63.103(b)(3) § 63.103(b)(4) [G]§ 63.103(b)(5) § 63.103(b)(6) [G]§ 63.104(c)	[G]§ 63.103(c) [G]§ 63.104(c) [G]§ 63.104(e)(2) [G]§ 63.104(f)(1) [G]§ 63.105(b) § 63.105(c) § 63.105(e)	§ 63.103(b)(2) [G]§ 63.103(b)(5) [G]§ 63.103(d) [G]§ 63.104(f)(2)
VCM2	EU	61F-3	Vinyl Chloride	40 CFR Part 61, Subpart F	§ 61.60(a)(1) § 61.62(a) § 61.62(b) [G]§ 61.65(b)(6) § 61.68(e)	This subpart applies to plants which produce ethylene dichloride by reaction of oxygen and hydrogen chloride with ethylene.	§ 61.67(a) § 61.67(a)(2) § 61.67(b) § 61.67(c) § 61.67(e) § 61.67(f) § 61.67(g) [G]§ 61.67(g)(1) § 61.68(a) § 61.68(b) [G]§ 61.68(c) § 61.68(d) § 61.68(e) § 61.68(f) § 61.70(c)	§ 61.67(f) § 61.68(f) § 61.71(a) § 61.71(a)(3)	§ 61.67(e) § 61.69(a) § 61.69(b)(2) [G]§ 61.69(c) § 61.70(a)(1) § 61.70(b)(2) § 61.70(c)(1)
VCM2	EU	61F-4	Vinyl Chloride	40 CFR Part 61, Subpart F	§ 61.63(a) [G]§ 61.65(b)(6) § 61.68(e)	The concentration of vinyl chloride in each exhaust gas stream is not to exceed 10 ppm (average for 3-hour period), except as provided in §61.65(a).	§ 61.67(a) § 61.67(a)(2) § 61.67(b) § 61.67(c) § 61.67(e) § 61.67(f) § 61.67(g) [G]§ 61.67(g)(1) § 61.68(a) § 61.68(b) [G]§ 61.68(c) § 61.68(d) § 61.68(e) § 61.68(f)	§ 61.67(f) § 61.68(f) § 61.71(a) § 61.71(a)(3)	§ 61.67(e) § 61.69(a) § 61.69(b)(2) [G]§ 61.69(c) § 61.70(a)(1) § 61.70(b)(2) § 61.70(c)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 61.70(c)		
VCM2	PRO	63F-3	112(B) HAPS	40 CFR Part 63, Subpart F	§ 63.100(b) [G]§ 63.102(a) [G]§ 63.102(c) § 63.104(a) [G]§ 63.104(d) § 63.104(e) § 63.104(e)(1) [G]§ 63.104(e)(2) § 63.105(d)	Except as provided in paragraphs (b)(4) and (c) of this section, the provisions of subparts F, G, and H apply to chemical manufacturing process units that meet the criteria.	§ 63.103(b)(1) § 63.103(b)(3) § 63.103(b)(4) [G]§ 63.103(b)(5) § 63.103(b)(6) [G]§ 63.104(c)	[G]§ 63.103(c) [G]§ 63.104(c) [G]§ 63.104(e)(2) [G]§ 63.104(f)(1) [G]§ 63.105(b) § 63.105(c) § 63.105(e)	§ 63.103(b)(2) [G]§ 63.103(b)(5) [G]§ 63.103(d) [G]§ 63.104(f)(2)
VCM-20	EU	R1111-VCM-20	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(8)(A)	Visible emissions shall not be permitted to exceed an opacity of 30% for any six-minute period from all other sources not specified in this section.	§ 111.111(a)(8)(A) ** See Periodic Monitoring Summary	None	None
VCM-21	EU	R1111-VCM-21	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B)	Contributions from uncombined water shall not be included in determining compliance with this section. The burden of proof which establishes the applicability of this subsection shall be upon the person seeking to come within its provisions.	§ 111.111(a)(1)(B) ** See Periodic Monitoring Summary	None	None
VCM-22	EP	R5121-12	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(c)(1)(B) § 115.127(c)(1)	A vent gas stream with a combined weight of the VOC or classes of compounds specified in § 115.121(c)(1)(B)-(C) of 100 lbs (45.4 kg), or less, in a continuous 24-hour period is exempt from § 115.121(c)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
VCM-4	EU	R1111-VCM-4	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B)	Contributions from uncombined water shall not be included in determining compliance with this section. The burden of proof which establishes the applicability of this subsection shall be upon the person seeking to come within its provisions.	§ 111.111(a)(1)(B) ** See Periodic Monitoring Summary	None	None
VCM-5	EP	R5121-10	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(c)(1)(B) § 115.127(c)(1)	A vent gas stream with a combined weight of the VOC or classes of compounds specified in § 115.121(c)(1)(B)-(C) of 100 lbs (45.4 kg), or less, in a continuous 24-hour period is exempt from § 115.121(c)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
VCM-6	EP	R5121-11	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(c)(1)(B) § 115.127(c)(1)	A vent gas stream with a combined weight of the VOC or classes of compounds specified in § 115.121(c)(1)(B)-(C) of 100 lbs (45.4 kg), or less, in a continuous 24-hour period is exempt from § 115.121(c)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
VCM-9	EU	63H-ALL-VCM-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.164 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Compressors. §63.164(a)-(i)	[G]§ 63.164 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
VCM-9	EU	63H-ALL-VCM-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.165 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief device in gas/vapor service. §63.165(a)-(d)	[G]§ 63.165 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.166 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Sampling connection systems. §63.166(a)-(c)	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Instrumentation systems. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief devices in liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-1	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.170 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Surge control vessels and bottom receivers.	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-1	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(a) [G]§ 63.172(h) § 63.172(i)	Owners/operators of closed-vent systems and control devices used to	[G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g)	[G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.172(m)	comply with provisions of this subpart shall comply with the provisions of this section, except as provided in §63.162(b).	[G]§ 63.172(h) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-1	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(c) § 63.172(e) [G]§ 63.172(h) § 63.172(m)	Enclosed combustion devices shall be designed and operated to reduce the organic HAP or VOC emissions vented to them with requirements as specified in this section.	§ 63.172(e) [G]§ 63.172(h) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) § 63.181(g)(1)(iv) [G]§ 63.181(g)(2)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.173 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Agitators gas/vapor service and in light liquid service. §63.173(a)-(j).	[G]§ 63.173 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.174 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Connectors in gas/vapor service and in light liquid service. §63.174(a)-(j)	[G]§ 63.174 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.163 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h)	Standards: Pumps in light liquid service. §63.163(a)-(j)	[G]§ 63.163 [G]§ 63.176 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(3)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.171 [G]§ 63.176			§ 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7) § 63.181(h)(8)	
VCM-9	EU	63H-ALL-VCM-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.167 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Open-ended valves or lines. §63.167(a)-(e).	[G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-1	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.168 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Valves in gas/vapor service and in light liquid service. §63.168(a)-(j)	[G]§ 63.168 [G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.164 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Compressors. §63.164(a)-(i)	[G]§ 63.164 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.165 § 63.162(a) § 63.162(c)	Standards: Pressure relief device in gas/vapor service. §63.165(a)-(d)	[G]§ 63.165 [G]§ 63.180(b) [G]§ 63.180(c)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.162(g) § 63.162(h) [G]§ 63.171		[G]§ 63.180(d)	[G]§ 63.181(f)	[G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.166 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Sampling connection systems. §63.166(a)-(c)	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Instrumentation systems. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief devices in liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-2	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.170 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Surge control vessels and bottom receivers.	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-2	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	Owners/operators of closed-vent systems and control devices used to comply with provisions of this subpart shall comply with the provisions of this	[G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(l) [G]§ 63.180(b)	[G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						section, except as provided in §63.162(b).	[G]§ 63.180(d)	§ 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	
VCM-9	EU	63H-ALL-VCM-2	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(c) § 63.172(e) [G]§ 63.172(h) § 63.172(m)	Enclosed combustion devices shall be designed and operated to reduce the organic HAP or VOC emissions vented to them with requirements as specified in this section.	§ 63.172(e) [G]§ 63.172(h) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) § 63.181(g)(1)(iv) [G]§ 63.181(g)(2)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.173 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Agitators gas/vapor service and in light liquid service. §63.173(a)-(j).	[G]§ 63.173 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.174 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Connectors in gas/vapor service and in light liquid service. §63.174(a)-(j)	[G]§ 63.174 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.163 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.176	Standards: Pumps in light liquid service. §63.163(a)-(j)	[G]§ 63.163 [G]§ 63.176 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(3) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								§ 63.181(h)(7) § 63.181(h)(8)	
VCM-9	EU	63H-ALL-VCM-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.167 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Open-ended valves or lines. §63.167(a)-(e).	[G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-2	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.168 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Valves in gas/vapor service and in light liquid service. §63.168(a)-(j)	[G]§ 63.168 [G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-23	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.164 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Compressors. §63.164(a)-(i)	[G]§ 63.164 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-23	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.165 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief device in gas/vapor service. §63.165(a)-(d)	[G]§ 63.165 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
VCM-9	EU	63H-ALL-VCM-23	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.166 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Sampling connection systems. §63.166(a)-(c)	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-23	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Instrumentation systems. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-23	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief devices in liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-23	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.170 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Surge control vessels and bottom receivers.	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-23	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	Owners/operators of closed-vent systems and control devices used to comply with provisions of this subpart shall comply with the provisions of this section, except as provided in §63.162(b).	[G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	[G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
VCM-9	EU	63H-ALL-VCM-23	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(c) § 63.172(e) [G]§ 63.172(h) § 63.172(m)	Enclosed combustion devices shall be designed and operated to reduce the organic HAP or VOC emissions vented to them with requirements as specified in this section.	§ 63.172(e) [G]§ 63.172(h) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) § 63.181(g)(1)(iv) [G]§ 63.181(g)(2)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-23	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.173 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Agitators gas/vapor service and in light liquid service. §63.173(a)-(j).	[G]§ 63.173 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-23	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.174 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Connectors in gas/vapor service and in light liquid service. §63.174(a)-(j)	[G]§ 63.174 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-23	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.163 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.176	Standards: Pumps in light liquid service. §63.163(a)-(j)	[G]§ 63.163 [G]§ 63.176 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(3) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7) § 63.181(h)(8)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
VCM-9	EU	63H-ALL-VCM-23	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.167 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Open-ended valves or lines. §63.167(a)-(e).	[G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCM-9	EU	63H-ALL-VCM-23	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.168 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Valves in gas/vapor service and in light liquid service. §63.168(a)-(j)	[G]§ 63.168 [G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCMHE	EU	R5211-12	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(b)(1) § 115.212(b)(1)(A) § 115.212(b)(2) § 115.212(b)(3)(A) § 115.212(b)(3)(A)(i) § 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.212(b)(3)(D) § 115.212(b)(3)(E) § 115.214(b)(1)(B) § 115.214(b)(1)(C)	In Aransas, Bexar, Calhoun, Gregg, Matagorda, Nueces, San Patricio, Travis and Victoria Counties, vapors caused by the loading of VOC with a TVP of 1.5 psia or greater must be controlled by one of the following.	§ 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.214(b)(1)(A)(ii) § 115.214(b)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
VCMHE	EU	R5211-17	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(b)(1) § 115.212(b)(1)(A) § 115.212(b)(2) § 115.212(b)(3)(A) § 115.212(b)(3)(A)(i) § 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.212(b)(3)(D) § 115.212(b)(3)(E) § 115.214(b)(1)(B) § 115.214(b)(1)(C)	In Aransas, Bexar, Calhoun, Gregg, Matagorda, Nueces, San Patricio, Travis and Victoria Counties, vapors caused by the loading of VOC with a TVP of 1.5 psia or greater must be controlled by one of the following.	§ 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.214(b)(1)(A)(ii) § 115.214(b)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
VCMHE	EU	R5211-5	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(b)(1) § 115.212(b)(1)(A) § 115.212(b)(2) § 115.212(b)(3)(A) § 115.212(b)(3)(A)(i) § 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.212(b)(3)(D) § 115.212(b)(3)(E) § 115.214(b)(1)(B) § 115.214(b)(1)(C)	In Aransas, Bexar, Calhoun, Gregg, Matagorda, Nueces, San Patricio, Travis and Victoria Counties, vapors caused by the loading of VOC with a TVP of 1.5 psia or greater must be controlled by one of the following.	§ 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.214(b)(1)(A)(ii) § 115.214(b)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
VCMHE	EU	63G-12	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic	[G]§ 63.116(c) [G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(1)	§ 63.127(a)(1) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.129(a)(1)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(4) § 63.129(a)(4)(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.126(b)(1) § 63.126(d)(1) § 63.126(d)(1)(i) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	HAPs.	§ 63.127(a)(1)(i) § 63.127(a)(4) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.127(a)(4)(ii)(A) § 63.127(a)(4)(ii)(B) § 63.127(a)(4)(ii)(C) § 63.127(e) § 63.128(a)(1) § 63.128(a)(2) § 63.128(a)(3) § 63.128(a)(4) § 63.128(d)(1) § 63.128(d)(2) § 63.128(d)(3) § 63.128(d)(4) § 63.128(d)(5) § 63.128(e)(2) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCMHE	EU	63G-3	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2)	For Group 1 transfer racks shall operate a vapor collection system and	[G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(1)	§ 63.127(a)(1) § 63.127(a)(4)(i) § 63.127(a)(4)(ii)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.126(a)(3) § 63.126(b)(1) § 63.126(d)(1) § 63.126(d)(1)(ii) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	control device for organic HAPs.	§ 63.127(a)(1)(i) § 63.127(a)(4) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.127(a)(4)(ii)(A) § 63.127(a)(4)(ii)(B) § 63.127(a)(4)(ii)(C) § 63.127(e) § 63.128(d)(1) § 63.128(d)(2) § 63.128(d)(3) § 63.128(d)(4) § 63.128(d)(5) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.129(a)(1) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCMHE	EU	63G-8	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1)	For Group 1 transfer racks shall operate a vapor	[G]§ 63.126(d)(3) § 63.127(a)	§ 63.127(a)(1) § 63.127(a)(4)(i)	§ 63.129(a)(2) § 63.129(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.126(a)(2) § 63.126(a)(3) § 63.126(b)(1) § 63.126(d)(1) § 63.126(d)(1)(ii) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	collection system and control device for organic HAPs.	§ 63.127(a)(1) § 63.127(a)(1)(i) § 63.127(a)(4) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.127(a)(4)(ii)(A) § 63.127(a)(4)(ii)(B) § 63.127(a)(4)(ii)(C) § 63.127(e) § 63.128(d)(1) § 63.128(d)(2) § 63.128(d)(3) § 63.128(d)(4) § 63.128(d)(5) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.127(a)(4)(ii) § 63.129(a)(1) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
VCMLE	EU	R5211-13	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(b)(1) § 115.212(b)(1)(A) § 115.212(b)(2) § 115.212(b)(3)(A) § 115.212(b)(3)(A)(i) § 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.212(b)(3)(D) § 115.212(b)(3)(E) § 115.214(b)(1)(B) § 115.214(b)(1)(C)	In Aransas, Bexar, Calhoun, Gregg, Matagorda, Nueces, San Patricio, Travis and Victoria Counties, vapors caused by the loading of VOC with a TVP of 1.5 psia or greater must be controlled by one of the following.	§ 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.214(b)(1)(A)(ii) § 115.214(b)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
VCMLE	EU	R5211-18	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(b)(1) § 115.212(b)(1)(A) § 115.212(b)(2) § 115.212(b)(3)(A) § 115.212(b)(3)(A)(i) § 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.212(b)(3)(D) § 115.212(b)(3)(E) § 115.214(b)(1)(B) § 115.214(b)(1)(C)	In Aransas, Bexar, Calhoun, Gregg, Matagorda, Nueces, San Patricio, Travis and Victoria Counties, vapors caused by the loading of VOC with a TVP of 1.5 psia or greater must be controlled by one of the following.	§ 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.214(b)(1)(A)(ii) § 115.214(b)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
VCMLE	EU	R5211-6	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(b)(1) § 115.212(b)(1)(A) § 115.212(b)(2) § 115.212(b)(3)(A)	In Aransas, Bexar, Calhoun, Gregg, Matagorda, Nueces, San Patricio, Travis and Victoria Counties, vapors	§ 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.214(b)(1)(A) § 115.214(b)(1)(A)(i)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.212(b)(3)(A)(i) § 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.212(b)(3)(D) § 115.212(b)(3)(E) § 115.214(b)(1)(B) § 115.214(b)(1)(C)	caused by the loading of VOC with a TVP of 1.5 psia or greater must be controlled by one of the following.	§ 115.214(b)(1)(A)(ii) § 115.214(b)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i)	§ 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	
VCMLE	EU	63G-13	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) § 63.126(b)(1) § 63.126(d)(1) § 63.126(d)(1)(i) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.116(c) [G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(1) § 63.127(a)(1)(i) § 63.127(a)(4) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.127(a)(4)(ii)(A) § 63.127(a)(4)(ii)(B) § 63.127(a)(4)(ii)(C) § 63.127(e) § 63.128(a)(1) § 63.128(a)(2) § 63.128(a)(3) § 63.128(a)(4) § 63.128(d)(1) § 63.128(d)(2) § 63.128(d)(3) § 63.128(d)(4) § 63.128(d)(5) § 63.128(e)(2) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii)	§ 63.127(a)(1) § 63.127(a)(4)(i) § 63.129(a)(1) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCMLE	EU	63G-4	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) § 63.126(b)(1) § 63.126(d)(1) § 63.126(d)(1)(ii) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(1) § 63.127(a)(1)(i) § 63.127(a)(4) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.127(a)(4)(ii)(A) § 63.127(a)(4)(ii)(B) § 63.127(a)(4)(ii)(C) § 63.127(e) § 63.128(d)(1) § 63.128(d)(2) § 63.128(d)(3) § 63.128(d)(4) § 63.128(d)(5) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g)	§ 63.127(a)(1) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.129(a)(1) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCMLE	EU	63G-9	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) § 63.126(b)(1) § 63.126(d)(1) § 63.126(d)(1)(ii) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(1) § 63.127(a)(1)(i) § 63.127(a)(4) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.127(a)(4)(ii)(A) § 63.127(a)(4)(ii)(B) § 63.127(a)(4)(ii)(C) § 63.127(e) § 63.128(d)(1) § 63.128(d)(2) § 63.128(d)(3) § 63.128(d)(4) § 63.128(d)(5) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2)	§ 63.127(a)(1) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.129(a)(1) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	[G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCMML	EU	R5211-14	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(b)(1) § 115.212(b)(1)(A) § 115.212(b)(2) § 115.212(b)(3)(A) § 115.212(b)(3)(A)(i) § 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.212(b)(3)(D) § 115.212(b)(3)(E) § 115.214(b)(1)(B) § 115.214(b)(1)(C)	In Aransas, Bexar, Calhoun, Gregg, Matagorda, Nueces, San Patricio, Travis and Victoria Counties, vapors caused by the loading of VOC with a TVP of 1.5 psia or greater must be controlled by one of the following.	§ 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.214(b)(1)(A)(ii) § 115.214(b)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
VCMML	EU	R5211-19	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(b)(1) § 115.212(b)(1)(A) § 115.212(b)(2) § 115.212(b)(3)(A) § 115.212(b)(3)(A)(i)	In Aransas, Bexar, Calhoun, Gregg, Matagorda, Nueces, San Patricio, Travis and Victoria Counties, vapors caused by the loading of	§ 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.214(b)(1)(A)(ii)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i) § 115.216(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.212(b)(3)(D) § 115.212(b)(3)(E) § 115.214(b)(1)(B) § 115.214(b)(1)(C)	VOC with a TVP of 1.5 psia or greater must be controlled by one of the following.	§ 115.214(b)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i)	§ 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	
VCMML	EU	R5211-7	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(b)(1) § 115.212(b)(1)(A) § 115.212(b)(2) § 115.212(b)(3)(A) § 115.212(b)(3)(A)(i) § 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.212(b)(3)(D) § 115.212(b)(3)(E) § 115.214(b)(1)(B) § 115.214(b)(1)(C)	In Aransas, Bexar, Calhoun, Gregg, Matagorda, Nueces, San Patricio, Travis and Victoria Counties, vapors caused by the loading of VOC with a TVP of 1.5 psia or greater must be controlled by one of the following.	§ 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.214(b)(1)(A)(ii) § 115.214(b)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
VCMML	EU	63G-10	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) § 63.126(b)(1) § 63.126(d)(1) § 63.126(d)(1)(ii) [G]§ 63.126(d)(3) § 63.126(f)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(1) § 63.127(a)(1)(i) § 63.127(a)(4) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.127(a)(4)(ii)(A) § 63.127(a)(4)(ii)(B)	§ 63.127(a)(1) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.129(a)(1) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(d)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.126(g) § 63.126(h) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)		§ 63.127(a)(4)(ii)(C) § 63.127(e) § 63.128(d)(1) § 63.128(d)(2) § 63.128(d)(3) § 63.128(d)(4) § 63.128(d)(5) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.129(a)(7) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCMML	EU	63G-14	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) § 63.126(b)(1) § 63.126(d)(1) § 63.126(d)(1)(i) [G]§ 63.126(d)(3)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.116(c) [G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(1) § 63.127(a)(1)(i) § 63.127(a)(4) § 63.127(a)(4)(i) § 63.127(a)(4)(ii)	§ 63.127(a)(1) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.129(a)(1) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.126(f) § 63.126(g) § 63.126(h) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)		§ 63.127(a)(4)(ii)(A) § 63.127(a)(4)(ii)(B) § 63.127(a)(4)(ii)(C) § 63.127(e) § 63.128(a)(1) § 63.128(a)(2) § 63.128(a)(3) § 63.128(a)(4) § 63.128(d)(1) § 63.128(d)(2) § 63.128(d)(3) § 63.128(d)(4) § 63.128(d)(5) § 63.128(e)(2) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	[G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCMML	EU	63G-5	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) § 63.126(b)(1) § 63.126(d)(1) § 63.126(d)(1)(ii)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(1) § 63.127(a)(1)(i) § 63.127(a)(4) § 63.127(a)(4)(i) § 63.127(a)(4)(ii)	§ 63.127(a)(1) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.129(a)(1) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)		§ 63.127(a)(4)(ii)(A) § 63.127(a)(4)(ii)(B) § 63.127(a)(4)(ii)(C) § 63.127(e) § 63.128(d)(1) § 63.128(d)(2) § 63.128(d)(3) § 63.128(d)(4) § 63.128(d)(5) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.129(a)(7) § 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCMRAIL	EU	R5211-11	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(b)(1) § 115.212(b)(1)(A) § 115.212(b)(3)(A) § 115.212(b)(3)(A)(i) § 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C)	In Aransas, Bexar, Calhoun, Gregg, Matagorda, Nueces, San Patricio, Travis and Victoria Counties, vapors caused by the loading of VOC with a TVP of 1.5 psia	§ 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.214(b)(1)(A)(ii) § 115.214(b)(1)(A)(iii)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i) § 115.216(2) § 115.216(3)(A)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.212(b)(3)(E) § 115.214(b)(1)(B)	or greater must be controlled by one of the following.	§ 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i)	§ 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	
VCMRAIL	EU	R5211-16	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(b)(1) § 115.212(b)(1)(A) § 115.212(b)(3)(A) § 115.212(b)(3)(A)(i) § 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.212(b)(3)(E) § 115.214(b)(1)(B)	In Aransas, Bexar, Calhoun, Gregg, Matagorda, Nueces, San Patricio, Travis and Victoria Counties, vapors caused by the loading of VOC with a TVP of 1.5 psia or greater must be controlled by one of the following.	§ 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.214(b)(1)(A)(ii) § 115.214(b)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
VCMRAIL	EU	R5211-4	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(b)(1) § 115.212(b)(1)(A) § 115.212(b)(3)(A) § 115.212(b)(3)(A)(i) § 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.212(b)(3)(E) § 115.214(b)(1)(B)	In Aransas, Bexar, Calhoun, Gregg, Matagorda, Nueces, San Patricio, Travis and Victoria Counties, vapors caused by the loading of VOC with a TVP of 1.5 psia or greater must be controlled by one of the following.	§ 115.212(b)(3)(B) [G]§ 115.212(b)(3)(C) § 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.214(b)(1)(A)(ii) § 115.214(b)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 115.215(4) § 115.215(5) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(i)		
VCMRAIL	EU	63G-11	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) § 63.126(b)(1) § 63.126(d)(1) § 63.126(d)(1)(i) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.116(c) [G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(1) § 63.127(a)(1)(i) § 63.127(a)(4) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.127(a)(4)(ii)(A) § 63.127(a)(4)(ii)(B) § 63.127(a)(4)(ii)(C) § 63.127(e) § 63.128(a)(1) § 63.128(a)(2) § 63.128(a)(3) § 63.128(a)(4) § 63.128(d)(1) § 63.128(d)(2) § 63.128(d)(3) § 63.128(d)(4) § 63.128(d)(5) § 63.128(e)(2) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h)	§ 63.127(a)(1) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.129(a)(1) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) [G]§ 63.182(a) [G]§ 63.182(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	[G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCMRAIL	EU	63G-2	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) § 63.126(b)(1) § 63.126(d)(1) § 63.126(d)(1)(ii) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(1) § 63.127(a)(1)(i) § 63.127(a)(4) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.127(a)(4)(ii)(A) § 63.127(a)(4)(ii)(B) § 63.127(a)(4)(ii)(C) § 63.127(e) § 63.128(d)(1) § 63.128(d)(2) § 63.128(d)(3) § 63.128(d)(4) § 63.128(d)(5) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.127(a)(1) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.129(a)(1) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii) [G]§ 63.172(k) [G]§ 63.172(l)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) [G]§ 63.182(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCMRAIL	EU	63G-7	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) § 63.126(b)(1) § 63.126(d)(1) § 63.126(d)(1)(ii) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(1) § 63.127(a)(1)(i) § 63.127(a)(4) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.127(a)(4)(ii)(A) § 63.127(a)(4)(ii)(B) § 63.127(a)(4)(ii)(C) § 63.127(e) § 63.128(d)(1) § 63.128(d)(2) § 63.128(d)(3) § 63.128(d)(4) § 63.128(d)(5) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.127(a)(1) § 63.127(a)(4)(i) § 63.127(a)(4)(ii) § 63.129(a)(1) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii) [G]§ 63.172(k)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(ii) § 63.129(a)(4)(iii) [G]§ 63.129(a)(6) § 63.129(a)(7) § 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								[G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
VCMSHIP	EU	63Y-2	EXEMPT	40 CFR Part 63, Subpart Y	§ 63.560(a)(2) § 153.282 § 63.560(a)(4)	Existing sources with emissions less than 10 and 25 tons must meet the submerged fill standards of 46 CFR 153.282. This submerged fill requirement does not apply to petroleum refineries.	§ 63.565(l)	§ 63.567(j)(4)	None
VCMSHIP	EU	63Y-4	EXEMPT	40 CFR Part 63, Subpart Y	§ 63.560(a)(2) § 153.282 § 63.560(a)(4)	Existing sources with emissions less than 10 and 25 tons must meet the submerged fill standards of 46 CFR 153.282. This submerged fill requirement does not apply to petroleum refineries.	§ 63.565(l)	§ 63.567(j)(4)	None
VCMSHIP	EU	63Y-5	EXEMPT	40 CFR Part 63, Subpart Y	§ 63.560(a)(2) § 153.282 § 63.560(a)(4)	Existing sources with emissions less than 10 and 25 tons must meet the submerged fill standards of 46 CFR 153.282. This submerged fill requirement does not apply to petroleum refineries.	§ 63.565(l)	§ 63.567(j)(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
YARDBLAST	EU	R1111-YARDBLAST	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(8)(A)	Visible emissions shall not be permitted to exceed an opacity of 30% for any six-minute period from all other sources not specified in this section.	§ 111.111(a)(8)(A) ** See Periodic Monitoring Summary	None	None
YARDENG	EU	60IIII-BLSTCOMP	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	§ 60.4209(b)	§ 60.4214(c)	None
YARDENG	EU	60IIII-BLSTCOMP	NMHC and NO_X	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 75 KW but less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 - 2013 model year must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102.	§ 60.4209(b)	§ 60.4214(c)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
YARDENG	EU	60IIII-BLSTCOMP	PM	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2011 model year and later must comply with a PM emission limit of 0.02 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	§ 60.4209(b)	§ 60.4214(c)	None
YARDENG	EU	63ZZZZ-EMERCOMP	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
YARDPAINT	EU	R1111-YDPAINT	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(8)(A)	Visible emissions shall not be permitted to exceed an opacity of 30% for any six-minute period from all other sources not specified in this section.	§ 111.111(a)(8)(A) ** See Periodic Monitoring Summary	None	None

Additional Monitoring Requirements

CAM Summary

Unit/Group/Process Information	
ID No.: PRE-VCM-1	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Vent Gas Controls	SOP Index No.: R5121-VCM-1
Pollutant: VOC	Main Standard: § 115.121(c)(1)
Monitoring Information	
Indicator: Firebox temperature	
Minimum Frequency: Four times per hour	
Averaging Period: n/a	
Deviation Limit: Incinerator firebox temperature must be maintained at not less than 1,300 degrees F.	
CAM Text: The temperature measurement device shall be installed, calibrated, and maintained according to accepted practice and the manufacturer's specifications. The device shall have an accuracy of the greater of +/-0.75 percent of the temperature being measured expressed in degrees Celsius or =/-2.5 degrees C. Quality assured (or valid) data must be generated when the facility is operating except during the performance of a daily zero and span check. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted provided it does not exceed 5 percent of the time (in minutes) that the facility operated over the previous rolling 12 month period. The measurements missed shall be estimated using engineering judgement and the methods used recorded. The incinerator's firebox exit temperature shall be continuously monitored and recorded. The incinerator firebox exit temperature shall be maintained at not less than 1,300 degrees F while feeding vent gas or liquid feed.	

CAM Summary

Unit/Group/Process Information	
ID No.: PRE-VCM-2	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Vent Gas Controls	SOP Index No.: R5121-VCM-2
Pollutant: VOC	Main Standard: § 115.121(c)(1)
Monitoring Information	
Indicator: Firebox temperature	
Minimum Frequency: Four times per hour	
Averaging Period: n/a	
Deviation Limit: Incinerator firebox temperature must be maintained at not less than 1,300 degrees F.	
CAM Text: The temperature measurement device shall be installed, calibrated, and maintained according to accepted practice and the manufacturer's specifications. The device shall have an accuracy of the greater of +/-0.75 percent of the temperature being measured expressed in degrees Celsius or =/-2.5 degrees C. Quality assured (or valid) data must be generated when the facility is operating except during the performance of a daily zero and span check. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted provided it does not exceed 5 percent of the time (in minutes) that the facility operated over the previous rolling 12 month period. The measurements missed shall be estimated using engineering judgement and the methods used recorded. The incinerator's firebox exit temperature shall be continuously monitored and recorded. The incinerator firebox exit temperature shall be maintained at not less than 1,300 degrees F while feeding vent gas or liquid feed.	

CAM Summary

Unit/Group/Process Information	
ID No.: PRE-VCM-23	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Vent Gas Controls	SOP Index No.: R5121-VCM-23
Pollutant: VOC	Main Standard: § 115.121(c)(1)
Monitoring Information	
Indicator: Firebox temperature	
Minimum Frequency: Four times per hour	
Averaging Period: n/a	
Deviation Limit: Incinerator firebox temperature must be maintained at not less than 1,300 degrees F.	
CAM Text: The temperature measurement device shall be installed, calibrated, and maintained according to accepted practice and the manufacturer's specifications. The device shall have an accuracy of the greater of +/-0.75 percent of the temperature being measured expressed in degrees Celsius or =/-2.5 degrees C. Quality assured (or valid) data must be generated when the facility is operating except during the performance of a daily zero and span check. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted provided it does not exceed 5 percent of the time (in minutes) that the facility operated over the previous rolling 12 month period. The measurements missed shall be estimated using engineering judgement and the methods used recorded. The incinerator's firebox exit temperature shall be continuously monitored and recorded. The incinerator firebox exit temperature shall be maintained at not less than 1,300 degrees F while feeding vent gas or liquid feed.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-253	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-13
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-253	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-13
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Failure to repair the fill pipe prior to refilling the storage tank.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-253	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-13
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Failure to keep a record of tank construction specifications.	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-253	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-7
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-253	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-7
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Failure to repair the fill pipe prior to refilling the storage tank.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-253	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-7
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Failure to keep a record of tank construction specifications.	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-253	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-5
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-253	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-5
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Failure to repair the fill pipe prior to refilling the storage tank.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-253	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-5
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Failure to keep a record of tank construction specifications.	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-710	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-23
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-710	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-16
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-710	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-11
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-711	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-24
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-711	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-17
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-711	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-12
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-712A	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-19
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-712A	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-12
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-712A	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-8
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-712B	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-20
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-712B	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-13
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-712B	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-9
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-714	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-25
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-714	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-18
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-714	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-13
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720A	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-15
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720A	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-40
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720A	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-40
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Failure to repair the fill pipe prior to refilling the storage tank.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720A	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-40
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Record of Tank Construction Specifications	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720A	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-29
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720A	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-29
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Failure to repair the fill pipe prior to refilling the storage tank.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720A	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-29
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Record of Tank Construction Specifications	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720A	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-8
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720A	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-19
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720A	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-19
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Failure to repair the fill pipe prior to refilling the storage tank.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720A	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-19
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Record of Tank Construction Specifications	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720A	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-6
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-16
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-16
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Failure to repair the fill pipe prior to refilling the storage tank.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-16
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Failure to keep a record of tank construction specifications.	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-41
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-41
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Failure to repair the fill pipe prior to refilling the storage tank.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-41
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Failure to keep a record of tank construction specifications.	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-30
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-9
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-9
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Failure to repair the fill pipe prior to refilling the storage tank.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-9
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Failure to keep a record of tank construction specifications.	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-20
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-7
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-7
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Failure to repair the fill pipe prior to refilling the storage tank.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: C-720B	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-7
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: n/a	
Averaging Period: n/a	
Deviation Limit: Failure to keep a record of tank construction specifications.	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-104A	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-33
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: n/a	
Deviation Limit: It is a deviation if the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, if the seals are detached, or if there are holes or tears in the seal fabric.	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-104B	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-34
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: n/a	
Deviation Limit: It is a deviation if the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, if the seals are detached, or if there are holes or tears in the seal fabric	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-104C	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-35
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: n/a	
Deviation Limit: It is a deviation if the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, if the seals are detached, or if there are holes or tears in the seal fabric	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-2525A	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-29
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-2525A	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-21
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-2525A	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-14
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-2525B	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-30
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-2525B	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-22
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-2525B	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-15
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-525A	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-31
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-525A	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-23
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-525A	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-16
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-525B	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-32
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-525B	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-24
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-525B	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-17
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-540	
Control Device ID No.: VCM-1	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1-7
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-540	
Control Device ID No.: VCM-2	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2-2
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: D-540	
Control Device ID No.: VCM-23	Control Device Type: Thermal Incinerator (Direct Flame Incinerator/Regenerative Thermal Oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-3-1
Pollutant: VOC	Main Standard: § 115.112(c)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Once per week	
Averaging Period: n/a*	
Deviation Limit: It is a deviation if the combustion temperature < 1300 F.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber. The monitoring instrumentation shall be maintained, calibrated and operated in accordance with manufacturer's specifications or other written procedures. Any monitoring data below the minimum limit shall be considered and reported as a deviation.	

*The permit holder may elect to collect monitoring data on a more frequent basis and calculate the average as specified by the minimum frequency, for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis and shall not be collected and used in particular instances to avoid reporting deviations.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: PLTBLAST	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-PLTBLAST
Pollutant: OPACITY	Main Standard: § 111.111(a)(8)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: quarterly	
Averaging Period: n/a	
Deviation Limit: Opacity limit of 30% for abrasive blast operations.	
Periodic Monitoring Text: An observation of visible emissions from the source shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter. Records of all observations shall be maintained. Visible emissions observations of the source operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions shall be determined with the source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from the source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. The determination of visible emissions shall be made at the nearest property line downwind of the source or within 500 feet of the source, whichever is closer to the source. A certified opacity reader is not required for visible emissions observations. If visible emissions are not present at the prescribed points of observation, the RO may certify the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A). However, if visible emissions are present at the points of observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(s). The opacity test must be performed by a certified opacity reader.	

Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: PLTPAINT	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-PLTPAINT
Pollutant: OPACITY	Main Standard: § 111.111(a)(8)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: quarterly	
Averaging Period: n/a	
Deviation Limit: Opacity limit of 30% for paint operations.	
Periodic Monitoring Text: An observation of visible emissions from the source shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter. Records of all observations shall be maintained. Visible emissions observations of the source operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions shall be determined with the source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from the source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. The determination of visible emissions shall be made at the nearest property line downwind of the source or within 500 feet of the source, whichever is closer to the source. A certified opacity reader is not required for visible emissions observations. If visible emissions are not present at the prescribed points of observation, the RO may certify the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A). However, if visible emissions are present at the points of observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(s). The opacity test must be performed by a certified opacity reader.	

Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: UNIT 1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-GT
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel type	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: It is a deviation if a fuel other than natural gas or hydrogen is fired, either alone or in combination with these gases.	
Periodic Monitoring Text: Record the type of fuel used by the unit. If a fuel other than natural gas or hydrogen is fired, either alone or in combination with these gases, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: UNIT 2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-GT
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel type	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: It is a deviation if a fuel other than natural gas or hydrogen is fired, either alone or in combination with these gases.	
Periodic Monitoring Text: Record the type of fuel used by the unit. If a fuel other than natural gas or hydrogen is fired, either alone or in combination with these gases, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: VCM-20	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-VCM-20
Pollutant: OPACITY	Main Standard: § 111.111(a)(8)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: quarterly	
Averaging Period: n/a	
Deviation Limit: Opacity limit of 30% for limestone unloading operations.	
Periodic Monitoring Text: An observation of visible emissions from the source shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter. Records of all observations shall be maintained. Visible emissions observations of the source operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions shall be determined with the source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from the source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. The determination of visible emissions shall be made at the nearest property line downwind of the source or within 500 feet of the source, whichever is closer to the source. A certified opacity reader is not required for visible emissions observations. If visible emissions are not present at the prescribed points of observation, the RO may certify the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A). However, if visible emissions are present at the points of observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(s). The opacity test must be performed by a certified opacity reader.	

Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: VCM-21	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-VCM-21
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel type	
Minimum Frequency: quarterly	
Averaging Period: n/a	
Deviation Limit: It is a deviation if a fuel other than natural gas is fired.	
Periodic Monitoring Text: Record the type of fuel used by the unit. If a fuel other than natural gas is fired it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: VCM-4	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-VCM-4
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel type	
Minimum Frequency: quarterly	
Averaging Period: n/a	
Deviation Limit: It is a deviation if a fuel other than natural gas is fired.	
Periodic Monitoring Text: Record the type of fuel used by the unit. If a fuel other than natural gas is fired it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: YARDBLAST	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-YARDBLAST
Pollutant: OPACITY	Main Standard: § 111.111(a)(8)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: quarterly	
Averaging Period: n/a	
Deviation Limit: Opacity limit of 30% for abrasive blast operations.	
Periodic Monitoring Text: An observation of visible emissions from the source shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter. Records of all observations shall be maintained. Visible emissions observations of the source operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions shall be determined with the source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from the source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. The determination of visible emissions shall be made at the nearest property line downwind of the source or within 500 feet of the source, whichever is closer to the source. A certified opacity reader is not required for visible emissions observations. If visible emissions are not present at the prescribed points of observation, the RO may certify the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A). However, if visible emissions are present at the points of observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(s). The opacity test must be performed by a certified opacity reader.	

Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: YARDPAINT	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-YDPAINT
Pollutant: OPACITY	Main Standard: § 111.111(a)(8)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: n/a	
Averaging Period: quarterly	
Deviation Limit: Opacity limit of 30% for abrasive blast operations.	
Periodic Monitoring Text: An observation of visible emissions from the source shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter. Records of all observations shall be maintained. Visible emissions observations of the source operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions shall be determined with the source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from the source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. The determination of visible emissions shall be made at the nearest property line downwind of the source or within 500 feet of the source, whichever is closer to the source. A certified opacity reader is not required for visible emissions observations. If visible emissions are not present at the prescribed points of observation, the RO may certify the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A). However, if visible emissions are present at the points of observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(s). The opacity test must be performed by a certified opacity reader.	

Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.

New Source Review Authorization References

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Prevention of Significant Deterioration (PSD) Permits	
PSD Permit No.: PSDTX880	Issuance Date: 03/02/2012
Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 18432	Issuance Date: 08/18/2006
Authorization No.: 19169	Issuance Date: 05/05/2011
Authorization No.: 2339A	Issuance Date: 08/17/2009
Authorization No.: 35335	Issuance Date: 03/02/2012
Authorization No.: 47668	Issuance Date: 11/30/2006
Authorization No.: 90302	Issuance Date: 09/18/2009
Authorization No.: 136971	Issuance Date: 11/23/2015
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.227	Version No./Date: 09/04/2000
Number: 106.261	Version No./Date: 03/14/1997
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 11/01/2003
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.265	Version No./Date: 09/04/2000
Number: 106.355	Version No./Date: 11/01/2001
Number: 106.371	Version No./Date: 03/14/1997
Number: 106.373	Version No./Date: 09/04/2000
Number: 106.412	Version No./Date: 09/04/2000
Number: 106.433	Version No./Date: 09/04/2000
Number: 106.452	Version No./Date: 09/04/2000
Number: 106.454	Version No./Date: 09/04/2000
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 09/04/2000
Number: 106.512	Version No./Date: 06/13/2001

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Number: 61	Version No./Date: 09/12/1989
Number: 118	Version No./Date: 06/07/1996
Municipal Solid Waste and Industrial Hazardous Waste Permits With an Air Addendum	
Permit No.: HW50322	

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
263	GEN #1; P-710-1	2339A
354	GEN #2; P-810-1	2339A
C-2521	WASTE WATER STRIPPER FEED TANK	19169
C-253	MOTHER LIQUOR STORAGE VESSEL	19169
C-521	WASTE WATER STRIPPER TANK	19169
C-710	WET CRUDE EDC STORAGE TANK	19169
C-711	DRY CRUDE EDC STORAGE TANK	19169
C-712A	FURNACE FEED TANK	19169
C-712B	FURNACE FEED TANK	19169
C-714	WET CRUDE EDC STORAGE TANK	19169
C-720A	VCM LIGHT ENDS TANK	19169
C-720B	VCM HEAVY ENDS TANK	19169
CTG-1LV	NO. 1 GAS TURBINE LUBE VENT	106.262/11/01/2003
CTG-2LV	NO. 2 GAS TURBINE LUBE VENT	106.262/11/01/2003
D-002	NO. 2 SWITCHGR DIESEL STORAGE TANK	2339A
D-005	ABOVE GROUND GAS STORAGE TANK	2339A
D-006	ABOVE GROUND DIESEL FUEL TANK	2339A
D-104A	EDC STORAGE TANK 104-A	18432

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
D-104B	EDC STORAGE TANK 104-B	18432
D-104C	EDC STORAGE TANK 104-C	18432
D-104	SOLVENT RECOVERY SYSTEM, SOUTH SHOP	118/06/07/1996
D-2525A	STORMWATER TANK	19169
D-2525B	STORMWATER TANK	19169
D-525A	STORMWATER TANK	19169
D-525B	STORMWATER TANK	19169
D-540	METHANOL TANK	19169
D-750	FUEL OIL TANK. SWITHGEAR GENERATOR B	2339A
D-751	750 OUTSIDE FUEL OIL, SWITCHGEAR 1 GENERATOR B	2339A
DB-1	DUCT BURNER	35335, PSDTX880
DB-2	DUCT BURNER	35335, PSDTX880
EDC-7	EDC FUGITIVES	18432
EGEN-4	GEN VCM; V-680	106.511/09/04/2000
ENGSTK1	T&D FIREWATER; G-174A	106.511/09/04/2000
ENGSTK2	T&D FIREWATER; G-174B	106.511/09/04/2000
ENGSTK3	T&D FIREWATER; G-174C	106.511/09/04/2000
ENGSTK4	VCM FIREWATER; G-619A	106.511/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
ENGSTK5	VCM FIREWATER; G-619B	106.511/09/04/2000
ENGSTK6	VCM FIREWATER; G-619C	106.511/09/04/2000
ENGSTK7	VCM FIREWATER; G-619D	106.511/09/04/2000
F-2410	PROCESS HEATER F-2410	19169
F-2420	PROCESS HEATER F-2420	19169
F-410	PROCESS HEATER F-410	19169
F-420	PROCESS HEATER F-420	19169
F-430	PROCESS HEATER F-430	19169
F-440	PROCESS HEATER F-440	19169
LVPTRANSFER	LOW VAPOR TRANSFER	106.472/09/04/2000
PLTBLAST	IN-PLANT BLAST OPERATIONS	106.263/11/01/2001
PLTPAINT	IN-PLANT PAINT OPERATIONS	106.263/11/01/2001
PRE-VCM-1	VCM PLANT 1 & 2 VENT HEADER SYSTEM	19169
PRE-VCM-23	VCM PLANT 1 & 2 VENT HEADER SYSTEM	19169
PRE-VCM-2	VCM PLANT 1 & 2 VENT HEADER SYSTEM	19169
STG-1LV	STEAM TURBINE LUBE VENT	106.262/11/01/2003
STG-2LV	STEAM TURBINE LUBE VENT	106.262/11/01/2003
UNIT 1	NO. 1 GAS TURBINE	35335, PSDTX880

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
UNIT 2	NO. 2 GAS TURBINE	35335, PSDTX880
VCM-1	VCM PLANT 1&2 INCINERATOR	19169
VCM1	VCM1 PLANT AREA	19169
VCM-20	LIMESTONE UNLOADING	19169
VCM-21	VCM FURNACES, VCM PLANT 2	19169
VCM-22	DECOKE DRUM	19169
VCM-2	VCM PLANT 1&2 INCINERATOR	19169
VCM2	VCM2 PLANT AREA	19169
VCM-4	VCM FURNACES, VCM PLANT 1	19169
VCM-5	DECOKE DRUM-STACK	19169
VCM-6	DECOKE DRUM-STACK	19169
VCM-9	VCM FUGITIVES	19169
VCMHE	VCM HEAVY ENDS LOADING	19169
VCMLE	VCM LIGHT ENDS LOADING	19169
VCMML	VCM MOTHER LIQUOR LOADING	19169
VCMRAIL	VCM RAIL CAR LOADING	19169
VCMSHIP	VCM SHIP LOADING	19169
YARDBLAST	ABRASIVE BLAST YARD OPERATIONS	106.452/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
YARDENG	BLAST YARD COMPRESSOR ENGINE	106.512/06/13/2001
YARDPAINT	PAINT YARD OPERATIONS	106.433/09/04/2000

Alternative Requirement

TEXAS NATURAL RESOURCE CONSERVATION COMMISSION

Protecting Texas by Reducing and Preventing Pollution

RECEIVED
MAY 2 2 2002

May 15, 2002

Ms. Karen M. Sinard
Environmental Engineer
Occidental Chemical Corporation
P.O. Box CC
Ingleside, TX 78362-0710

RE: Custom Fuel Monitoring for Quarterly Sampling for Six Quarters for Occidental Chemical Corporation (OxyChem) at Ingleside Cogeneration Facility, San Patricio County, Texas. Texas Natural Resources Conservation Commission (TNRCC) Air Permit No. 35335/PSD-TX-880, TNRCC Account No. SD-0092-F, under Title 40 Code of Federal Regulations Part 60 (40 CFR 60) Subpart GG, Section 60.334(b).

Dear Ms. Sinard:

We have received the data associated with the Custom Fuel Monitoring Schedule (CFMS) issued on June 10, 1999. The data included the sulfur content of the natural gas used at the Ingleside Cogeneration Facility for six quarters. OxyChem sampled the fuel at least once each quarter from March 6, 2001 through May 7, 2002. After reviewing the data, TNRCC concluded that the monitoring data show little variability in the sulfur content, and indicate consistent compliance with 40 CFR 60, Subpart GG, Section 60.333(b). Therefore, OxyChem may proceed to conduct sulfur monitoring at the Ingleside Cogeneration Facility twice per year during the first and third quarters beginning in the third quarter of 2002.

After completing the sulfur monitoring twice per year during the first and third quarters, please send the TNRCC a copy of the laboratory fuel sulfur test results to ensure compliance with the terms of the CFMS.

If you have any questions, please contact me at the letterhead address, MC-171, or at (512) 239-4620.
Sincerely,

Lindsey Renfro

Lindsey Renfro
Engineering Services Team
Enforcement Division

LDR/kh

cc: Ms. Donna Ascenzi, Chief, Air Enforcement Branch, U. S. Environmental Protection Agency, Region 6

Appendix A

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM ..... actual cubic feet per minute
AMOC ..... alternate means of control
ARP ..... Acid Rain Program
ASTM ..... American Society of Testing and Materials
B/PA ..... Beaumont/Port Arthur (nonattainment area)
CAM ..... Compliance Assurance Monitoring
CD ..... control device
COMS ..... continuous opacity monitoring system
CVS ..... closed-vent system
D/FW ..... Dallas/Fort Worth (nonattainment area)
DR ..... Designated Representative
ElP ..... El Paso (nonattainment area)
EP ..... emission point
EPA ..... U.S. Environmental Protection Agency
EU ..... emission unit
FCAA Amendments ..... Federal Clean Air Act Amendments
FOP ..... federal operating permit
GF ..... grandfathered
gr/100 scf ..... grains per 100 standard cubic feet
HAP ..... hazardous air pollutant
H/G/B ..... Houston/Galveston/Brazoria (nonattainment area)
H_2S ..... hydrogen sulfide
ID No. ..... identification number
lb/hr ..... pound(s) per hour
MMBtu/hr ..... Million British thermal units per hour
MRRT ..... monitoring, recordkeeping, reporting, and testing
NA ..... nonattainment
N/A ..... not applicable
NADB ..... National Allowance Data Base
NO_x ..... nitrogen oxides
NSPS ..... New Source Performance Standard (40 CFR Part 60)
NSR ..... New Source Review
ORIS ..... Office of Regulatory Information Systems
Pb ..... lead
PBR ..... Permit By Rule
PM ..... particulate matter
ppmv ..... parts per million by volume
PSD ..... prevention of significant deterioration
RO ..... Responsible Official
SO_2 ..... sulfur dioxide
TCEQ ..... Texas Commission on Environmental Quality
TSP ..... total suspended particulate
TVP ..... true vapor pressure
U.S.C. ..... United States Code
VOC ..... volatile organic compound

Appendix B

NSR Summary Table

Permit Number: 35335 and PSDTX880 (Version Date: **3/2/2012**)							
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY**	Spec. Cond.	Spec. Cond.	Spec. Cond.
CG-1	GE-7231FA Turbine +	NOx	181.74	-	**5, 10,** 12, 13, 14, 15	**5, 10,** 12, 13, **15,** 17, 18	**10,** 12, 13, 19
	Duct Burner	**NOx (MSS)**	**200.00**		**5, 9, 13, 14, 15, 25**	**5, 9, 13, 15, 17, 18, 23, 24, 25**	**13, 19**
		CO	85.84	-	**5,** 12, 13, 14, 15	**5,** 12, 13, **15,** 17, 18	12, 13, 19
		CO (MSS)	**250.00**		**5, 13, 14, 15, 25**	**5, 13, 15, 17, 18, 23, 24, 25**	**13, 19**
		VOC	9.11	-	**5,** 12, 15	**5,** 12, **15,** 17, 18**, 23, 24, 25**	**10,** 12
		SO2	1.6	-	**5, 10,** 12, 15, 16	**5, 10,** 12, **15,** 17, 18**, 23, 24, 25**	**10,** 12, 16
		PM10	18.89	-	**5, 9,** 12, 15**, 25**	**5, 9, 10,** 12, **15,** 17, 18**, 23, 24, 25**	**10,** 12
		H2SO4	0.25	-	**5,** 15, 16	**5, 15,** 18**, 23, 24, 25**	-
		HCl	<0.01	-	**5,** 15	**5, 15,** 18**, 23, 24, 25**	-
CG-2	GE-7231FA Turbine +	NOx	181.74	-	**5, 10,** 12, 13, 14, 15	**5, 10,** 12, 13, **15,** 17, 18	**10,** 12, 13, 19
	Duct Burner	**NOx (MSS)**	**200.00**		**5, 9, 13, 14, 15, 25**	**5, 9, 13, 15, 17, 18, 23, 24, 25**	**13, 19**
		CO	85.84	-	**5,** 12, 13, 14, 15	**5,** 12, 13, **15,** 17, 18	12, 13, 19
		CO (MSS)	**250.00**		**5, 13, 14, 15, 25**	**5, 13, 15, 17, 18, 23, 24, 25**	**13, 19**
		VOC	9.11	-	**5,** 12, 15	**5,** 12, **15,** 17, 18**, 23, 24, 25**	**10,** 12
		SO2	1.6	-	**5, 10,** 12, 15, 16	**5, 10,** 12, **15,** 17, 18**, 23, 24, 25**	**10,** 12, 16
		PM10	18.89	-	**5, 9,** 12, 15**, 25**	**5, 9, 10,** 12, **15,** 17, 18**, 23, 24, 25**	**10,** 12
		H2SO4	0.25	-	**5,** 15, 16	**5, 15,** 18**, 23, 24, 25**	-
		HCl	<0.01	-	**5,** 15	**5, 15,** 18**, 23, 24, 25**	-

CG-1 and CG-2	Combined Annual Emissions	NOx	-	1,386.88	13, 14, 15	13, 15, 17, 18**, 23, 24, 25**	13, 19
		CO	-	733.38	13, 14, 15	13, 15, 17, 18**, 23, 24, 25**	13, 19
		VOC	-	76.12	15	15, 17, 18**, 23, 24, 25**	-
		SO2	-	12.67	15, 16	15, 17, 18**, 23, 24, 25**	16
		PM10	-	144.02	15	15, 17, 18**, 23, 24, 25**	-
		H2SO4	-	1.94	15,16	**15,** 18**, 23, 24, 25**	-
		HCl	-	<0.01	15	**15,** 18**, 23, 24, 25**	-
CU-1	Carbonation Unit	NOx	1.42	5.41	12, 13, 14, 15	12, 13, **15,** 17, 18	12, 13
		CO	0.67	2.86	12, 13, 14, 15	12, 13, **15,** 17, 18	12, 13
		VOC	0.07	0.3	12, 15	12, **15,** 17, 18	12
		SO2	0.01	0.05	12, 15, 16	12, **15,** 17, 18	12, 16
		PM10	0.15	0.56	12, 15	12, **15,** 17, 18	12
		H2SO4	<0.01	0.01	15,16	**15,** 18	-
CG-FUG	Fugitive Emissions	VOC	0.03	0.11	**5**	5	-

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.
(2) Specific point source name. For fugitive sources, use area name or fugitive source name.
(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § **101.1**
NO_x - total oxides of nitrogen
SO_2 - sulfur dioxide
PM - total particulate matter, suspended in the atmosphere, including PM_{10} and $PM_{2.5}$, as represented
PM_{10} - total particulate matter equal to or less than 10 microns in diameter, including $PM_{2.5}$, as represented
$PM_{2.5}$ - particulate matter equal to or less than 2.5 microns in diameter
CO - carbon monoxide
HCl - hydrogen chloride
H_2SO_4 - sulfuric acid
(4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
(5) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission rate.
(6) MSS – Maintenance, startup, and shutdown.
(7) The annual emission limits specified in the MAERT for CG-1 and CG-2 include emissions from the units during both normal operations and planned MSS activities. The hourly emission limits specified in the MAERT for CG-1 and CG-2 include emissions from the facility during both normal operations and planned MSS activities, except for NOx and CO.
(8) For each pollutant whose emissions during planned MSS activities are measured using a CEMS, the MSS lb/hr limits apply only during each clock hour that includes one or more minutes of MSS activities. During all other clock hours, the normal lb/hr limits apply.

Special Conditions

Permit Numbers 35335 and PSDTX880

Emission Standards and Operating Specifications

1. The two combustion turbine generator (CTG) units authorized by this permit are each rated for a nominal maximum power output of 166 megawatts (MW) (72°F case) and 185 MW (20°F case). **(03/08)**

2. The two heat recovery steam generating units (HRSGUs) are each limited to a maximum heat input capacity of 608 million British thermal units per hour (MMBtu/hr) based on the higher heating value of natural gas or a mixture of natural gas and hydrogen gas (H_2). The maximum amount of H_2 gas allowed for firing in the duct burners is 6,544 pounds per hour (lbs/hr) (20,694 standard cubic feet per minute H_2 gas). The total quantity of H_2 gas may be divided between the duct burners for Emission Point Nos. (EPNs) CG-1 and CG-2 or may all be sent to one duct burner as required for operational flexibility. **(10/09)**

3. The cogeneration train shall normally operate at 100 percent base load except for periods of startup or shutdown. Reduced load operation is authorized to accommodate periods of reduced power and steam demands provided the maximum lbs/hr emission rates specified on the attached table entitled "Emission Sources - Maximum Allowable Emissions Rates" (MAERT) for EPN CG-1 or EPN CG-2 are not exceeded. **(03/12)**

4. Fuel for CTGs and HRSGU duct burners is limited to pipeline-quality natural gas containing no more than 0.25 grain total sulfur per 100 dry standard cubic feet. The HRSGU duct burners may also fire a mix of natural gas and H_2 gas or 100 percent H_2 gas. The hydrogen gas shall be essentially 100 percent H_2 with trace amounts of salts, chlorides, oxygen (O_2), and nitrogen.

5. Upon request by the Executive Director of the Texas Commission On Environmental Quality (TCEQ) or any local air pollution control program having jurisdiction, the holder of this permit shall provide a sample and/or an analysis of the fuels fired in the gas turbines and duct burners or shall allow air pollution control agency representatives to obtain a sample for analysis.

6. CTG Emission Limits

   A. Emissions of nitrogen oxides (NO_x) shall not exceed 15 parts per million by volume dry basis (ppmvd) when corrected to 15 percent O_2, without correction to International Standards Organization (ISO) conditions, at any load except during periods of startup or shutdown.

B. Emissions of carbon monoxide (CO) shall not exceed 20 ppmvd when corrected to 15 percent O_2, at full load except during periods of startup or shutdown.

C. Emissions of volatile organic compounds (VOC), defined as total hydrocarbons minus methane and ethane, shall not exceed 1.51 ppmvd when corrected to 15 percent O_2, at full load except during periods of startup or shutdown.

7. HRSGU Duct Burner Emission Limits

Emissions from the HRSGU duct burners shall not exceed the following limits in lb/MMBtu, based on the higher heating value of natural gas and H_2 gas. (Note: the combined natural gas and H_2 emission limits are based on the maximum expected emissions as either fuel component approaches concentrations resulting in maximum emission conditions.) **(04/08)**

Pollutant	Natural Gas	H_2 Gas	Natural Gas and H_2 Gas
NO_x	0.08	0.18	0.18
CO	0.08	0.04	0.08
VOC	0.012	0.008	0.012
PM_{10}	0.01	0.02	0.02

8. Combined CTG and HRSGU Duct Burner Stack Emission Limits

A. Emissions of NO_x shall not exceed 22.4 ppmvd when corrected to 15 percent O_2, without correction to ISO conditions, at any load except during periods of startup or shutdown.

B. Emissions of CO shall not exceed 23.5 ppmvd when corrected to 15 percent O_2, at full load except during periods of startup or shutdown.

C. Emissions of VOC shall not exceed 5.6 ppmvd when corrected to 15 percent O_2, at full load except during periods of startup or shutdown.

9. Except during maintenance, startup, and shutdown (MSS) activities, the opacity shall not exceed five percent averaged over a six-minute period from EPNs CG-1, CG-2, and CU-1. During MSS activities, the opacity shall not exceed 15 percent. Each determination shall be made by first observing for visible emissions while each facility is in operation. All observations shall be made at least 15 feet and no more than 0.25 miles from the emission point. If visible emissions are observed from an emission point, then the opacity shall be determined and documented within 24 hours for that emission point using Title 40 Code of Federal Regulations Part 60 (40 CFR Part 60), Appendix A, Test Method 9. Contributions from uncombined water shall not be included in determining compliance with this condition. Observations shall be performed and recorded quarterly unless the emission unit is not

operated at all during the entire quarter. If the opacity exceeds five percent during normal operations or 15 percent during MSS activities, corrective action to eliminate the source of visible emissions shall be taken promptly and documented within one week of first observation. **(03/12)**

Federal Applicability

10. These facilities shall comply with applicable requirements of the following US Environmental Protection Agency (EPA) Regulations: **(03/12)**

    A. Standards of Performance for New Stationary Sources, 40 CFR Part 60:

        (1) Subpart A, General Conditions,

        (2) Subpart Db, Industrial-Commercial-Institutional Steam Generating Units, and

        (3) Subpart GG, Stationary Gas Turbines.

    B. National Emission Standards for Hazardous Air Pollutants, 40 CFR Part 63:

        (1) Subpart A, General Provisions, and

        (2) Subpart YYYY, Stationary Combustion Turbines.

    If any condition of this permit is more stringent than the regulations so incorporated, then for the purposes of complying with this permit, the permit shall govern and be the standard by which compliance shall be demonstrated.

Initial Determination of Compliance

11. Sampling ports and platforms shall be incorporated into the design of both Cogeneration Units Exhaust Stacks (EPNs CG-1 and CG-2) and sampling ports shall be incorporated into the design of the Carbonation Unit Exhaust Stack (EPN CU-1). Sampling ports and platforms shall conform to the specifications set forth in the attachment entitled "Chapter 2, Stack Sampling Facilities." Alternate sampling facility designs may be submitted for approval by the TCEQ Regional Director.

12. The holder of this permit shall perform stack sampling and other testing as required to establish the actual quantities of air contaminants being emitted into the atmosphere from

EPNs CG-1 and CG-2. Sampling shall be conducted in accordance with the appropriate procedures of the TCEQ Sampling Procedures Manual and in accordance with the appropriate EPA Reference Methods 201A and 202 or Reference Method 5, modified to include back-half condensibles, for the concentration of particulate matter less than ten microns in diameter (PM_{10}); Reference Method 8 or Reference Methods 6 or 6c for sulfur dioxide (SO_2); Reference Method 9 for opacity (consisting of 30 six-minute readings as provided in 40 CFR 60.11[b]); Reference Method 10 for the concentration of CO; Reference Method 25A, modified to exclude methane and ethane, for the concentration of VOC (to measure total carbon as propane); and Reference Method 20 for the concentrations of NO_x and O_2 or equivalent methods. **(05/99)**

Fuel sampling using the methods and procedures of 40 CFR 60.335(d) may be conducted in lieu of stack sampling for SO_2. If fuel sampling is used, compliance with New Source Performance Standards (NSPS), Subpart GG, SO_2 limits shall be based on 100 percent conversion of the sulfur in the fuel to SO_2. Any deviations from those procedures must be approved by the Executive Director of the TCEQ prior to sampling. The TCEQ Executive Director or his designated representative shall be afforded the opportunity to observe all such sampling. The holder of this permit is responsible for providing sampling and testing facilities and conducting the sampling and testing operations at his expense.

A. The TCEQ Corpus Christi Regional Office shall be contacted as soon as testing is scheduled but not less than 45 days prior to sampling to schedule a pretest meeting.

   The notice shall include:

   (1) Date for pretest meeting.
   (2) Date sampling will occur.
   (3) Name of firm conducting sampling.
   (4) Type of sampling equipment to be used.
   (5) Method or procedure to be used in sampling.
   (6) Procedure used to determine the turbine loads during and after the sampling period.
   (7) Method to determine ambient concentration of particulate matter.

   The purpose of the pretest meeting is to review the necessary sampling and testing procedures, to provide the proper data forms for recording pertinent data, and to review the format procedures for submitting the test reports. A written proposed description of any deviation from sampling procedures specified in permit conditions or TCEQ or EPA sampling procedures shall be made available to the TCEQ prior to the pretest meeting. The TCEQ Regional Director shall approve or disapprove of any deviation from specified

sampling procedures. Requests to waive testing for any pollutant specified in this condition shall be submitted to the TCEQ Air Permits Division. Test waivers and alternate/equivalent procedure proposals for NSPS testing which must have EPA approval shall be submitted to the TCEQ Regional Director.

B. Air emissions from each CTG (duct burners off) shall be tested while firing at full load for the ambient conditions at the time of testing. Air emissions to be sampled and analyzed while at full load include (but are not limited to) NO_x, O_2, CO, VOC, SO_2, PM_{10}, and opacity. (Fuel sampling using the methods and procedures of 40 CFR § 60.335[d] may be conducted in lieu of stack sampling for SO_2).

C. Air emissions from each CTG (duct burners off) shall be tested while firing at three partial load conditions in the normal operating range of the gas turbine, including the minimum point in the range, corrected to ISO conditions. The normal operating range consistent with emission limits is to be determined during stack testing. Contaminants for which partial load sampling is required shall be sampled at the load predicted to have the highest emission rate for each individual contaminant, per information obtained from the turbine manufacturer. Each tested load shall be identified in the sampling report.

   Air emissions to be sampled and analyzed while at partial load include (but are not limited to) NO_x, O_2, CO, and VOC. **(5/99)**

D. Air emissions from the HRSGU duct burners shall be tested while firing at maximum rated heat capacity with a mix of natural gas and H_2 gas that will produce at the highest allowable emission rate considering the ambient conditions at the time of testing. Air emissions to be sampled and analyzed include (but are not limited to) NO_x, O_2, CO, VOC, SO_2, PM_{10}, and opacity. (Fuel sampling using the methods and procedures of 40 CFR § 60.335[d] may be conducted in lieu of stack sampling for SO_2.)

   The HRSGU duct burner emissions shall be calculated as the remainder of emissions when subtracting the CTG stack emissions with the duct burners out of service from the CTG stack emissions with the duct burners in service. The CTG must be operating at a maximum rate for the ambient conditions and shall be fired with natural gas. For the purposes of demonstrating initial compliance, emissions from the HRSGU duct burners shall not exceed the limits in Special Condition Nos. 7 and 8.

E. Sampling of each gas turbine and duct burner shall occur within 60 days after achieving the maximum production rate at which each gas turbine and duct burner will be operated

   but no later than 180 days after initial startup of each unit. Additional sampling shall occur as may be required by the TCEQ or EPA.

F. Within 60 days after the completion of the testing and sampling required herein, three copies of the sampling reports shall be distributed as follows: **(03/12)**

One copy to the TCEQ Corpus Christi Regional Office.
One copy to the TCEQ Austin Office of Air, Air Permits Division.
One copy to the EPA Region 6 Office, Dallas.

Continuous Determination of Compliance for CO and NOx

13. The holder of this permit shall install, calibrate, maintain, and operate a continuous emission monitoring system (CEMS) to measure and record the concentrations of NO_x, CO, and O_2 from each Cogeneration Unit Stack (EPNs CG-1 and CG-2).

A. Monitored NO_x and CO concentrations shall be corrected and reported in dimensional units corresponding to the emission rate and concentration limits established for the gas turbines and duct burners in this permit.

B. The CEMS shall meet the applicable quality-assurance requirements specified in 40 CFR Part 60, Appendix F, Procedure 1. Relative accuracy exceedances, as specified in 40 CFR Part 60, Appendix F, Section 5.2.3 and any CEMS downtime shall be reported to the appropriate TCEQ Regional Director, and necessary corrective action shall be taken. Supplemental stack concentration measurements may be required at the discretion of the appropriate TCEQ Regional Director.

C. The monitoring data shall be reduced to hourly average values at least once everyday, using a minimum of four equally-spaced data points from each one-hour period. Two valid data points shall be generated during the hourly period in which zero and span is performed.

D. All monitoring data and quality-assurance data shall be maintained by the source for a period of two years and shall be made available to the TCEQ Executive Director or his designated representative upon request. The data from the CEMS may, at the discretion of the TCEQ, be used to determine compliance with the conditions of this permit. Hourly average concentrations from EPNs CG-1 and CG-2 shall be summed to tons per year and used to determine compliance with the emission limits of this permit.

E. The appropriate TCEQ Regional Office shall be notified at least 30 days prior to any required relative accuracy test audit in order to provide them the opportunity to observe

the testing.

F. If applicable, the CEMS will be required to meet the design and performance specifications, pass the field tests, and meet the installation requirements and data analysis and reporting requirements specified in the applicable performance specifications in 40 CFR 75, Appendix A.

14. If any emission monitor fails to meet specified performance, it shall be repaired or replaced immediately, but no later than seven days after it was first detected by any employee at the facility, unless written permission is obtained from the TCEQ which allows for a longer repair/replacement time. The holder of this permit shall develop an operation and maintenance program (including stocking necessary spare parts) to ensure that the continuous monitors are available as required.

15. The holder of this permit shall additionally install, calibrate, maintain, and operate continuous monitoring systems to monitor and record the average hourly natural gas consumption of the gas turbines and the average hourly consumption of natural gas and/or H_2 gas of the duct burners. The systems shall be accurate to ± 5.0 percent of the unit's maximum flow.

16. The holder of this permit shall monitor the fuels fired in the equipment authorized by this permit for fuel-bound sulfur as specified in 40 CFR § 60.334(b). Any request for a custom monitoring schedule shall be made in writing and directed to the Executive Director of the TCEQ, although authority for granting such custom schedules remains with the EPA. Any custom schedule approved by the EPA pursuant to 40 CFR § 60.334(b) will be recognized as enforceable conditions of this permit provided that the holder of this permit demonstrates that the conditions of such custom schedule will be adequate to demonstrate continuous compliance with Special Condition No. 4.

Recordkeeping Requirements

17. The following records shall be kept at the plant for the life of the permit. All records required in this permit shall be made available at the request of personnel from the TCEQ, EPA, or any air pollution control agency with jurisdiction.

A. A copy of this permit.

B. Permit application dated April 18, 1997, and subsequent representations submitted to the TCEQ.

C. A complete copy of the testing reports and records of the initial performance testing completed pursuant to Special Condition No. 12 to demonstrate initial compliance.

D. Stack sampling results or other testing (other than CEMS data) that may be conducted on units authorized under this permit after the date of issuance of this permit.

18. The following information shall be maintained by the holder of this permit in a form suitable for inspection for a period of five years after collection and shall be made immediately available upon request to representatives of the TCEQ, EPA, or any local air pollution control program having jurisdiction:

A. The CEMS data of NO_x, CO, and O_2 emissions from EPNs CG-1 and CG-2 to demonstrate compliance with the MAERT.

B. Raw data files of all CEMS data including calibration checks and adjustments and maintenance performed on these systems in a permanent form suitable for inspection.

C. Records of the hours of operation and average daily quantity of natural gas and H_2 gas fired in the CTGs and HRSGU duct burners.

D. Records of MSS events including the date, duration, type of activity, and emissions associated with the event. **(03/12)**

E. Records of visible emission/opacity observations as specified in Special Condition No. 9. **(03/12)**

F. Records to demonstrate compliance with Special Condition Nos. 23 and 24. **(03/12)**

Reporting

19. The holder of this permit shall submit to the TCEQ Corpus Christi Regional Office and the Air Enforcement Branch of EPA in Dallas quarterly reports as described in 40 CFR § 60.7. Such reports are required for each emission unit which is required to be continuously monitored pursuant to this permit. In addition to the information specified in 40 CFR § 60.7(c), each report shall contain the hours of operation of the equipment authorized by this permit and a report summary of the periods of non-complying emissions and CEMS downtimes by cause.

Maintenance, Startup, and Shutdown Requirements

20. This permit authorizes the emissions from the planned MSS activities listed in Attachment A and the MAERT attached to this permit. Attachment A identifies the planned maintenance activities that are non-inherently low emitting (non-ILE) planned maintenance activities that this permit authorizes to be performed. **(03/12)**

21. The holder of this permit shall minimize emissions during planned MSS activities by operating the facility and associated air pollution control equipment in accordance with good air pollution control practices, safe operating practices, and protection of the facility. **(03/12)**

22. Emissions during planned startup and shutdown activities for the gas-fired turbines will be minimized by limiting the duration of operation in planned startup and shutdown mode as follows: **(03/12)**

    A. A planned startup of the CTGs associated with EPNs CG-1 and CG-2 is defined as the period that begins when natural gas is introduced into the turbine and ends when the turbine reaches an output of 95 MW. A planned cold startup (a startup after the gas turbine has been down for a period of 24 hours or more) is limited to 12 hours per event. A planned warm startup (a startup that is not a cold startup) is limited to 6 hours per event.

    B. A planned shutdown of the CTGs associated with EPNs CG-1 and CG-2 shall not exceed 10 hours. A planned shutdown for each turbine is defined as the period that begins when the turbine output falls below 95 MW and ends when the natural gas is cut-off to the turbine.

    C. Emissions from combustion turbine optimization activities as defined in Attachment A, shall be subject to the hourly emission limits for MSS activities from gas turbines as listed on the MAERT.

23. Compliance with the emissions limits for planned MSS activities identified in the MAERT attached to this permit may be demonstrated as follows. **(03/12)**

    A. For each pollutant emitted during non-ILE planned maintenance activities (See Attachment A) whose emissions are measured using a CEMS, the permit holder shall not exceed the pollutant's short-term (hourly) emissions during planned maintenance activities as measured by the CEMS to the applicable short-term planned MSS emissions limit in the MAERT.

B. For each pollutant emitted during non-ILE planned maintenance activities (See Attachment A) whose emissions occur through a stack, but are not measured using CEMS, the permit holder shall do the following for each calendar month.

(1) Determine the total emissions of the pollutant through the stack that result from such non-ILE planned maintenance activities in accordance with Special Condition No. 24B.

(2) Once monthly emissions have been determined in accordance with Special Condition No. 23B(1) for 12 months after the MSS permit amendment has been issued, the permit holder shall add the rolling 12-month MSS emissions for the pollutant to the 12-month emissions (same 12 month period) that occurred and were emitted through the same stack during other operations. This total annual emission rate for the stack shall not exceed the applicable annual emission limit specified in the MAERT.

24. The permit holder shall determine the emissions during planned MSS activities for use in Special Condition No. 23 as follows. **(03/12)**

A. For each pollutant whose emissions during normal facility operations are measured with a CEMS that has been certified to measure the pollutant's emissions over the entire range of a planned MSS activity, the permit holder shall measure the emissions of the pollutant during the planned MSS activity using the CEMS that have been described in Special Condition No. 13.

B. For each pollutant not described in Special Condition No. 24A, the permit holder shall calculate the pollutant's emissions during all occurrences of each type of planned MSS activity for each calendar month using the frequency of the planned MSS activity identified in work orders or equivalent records and the emissions of the pollutant during the planned MSS activity as represented in the planned MSS permit application. In lieu of using the emissions of the pollutant during the planned MSS activity as represented in the planned MSS permit application to calculate such emissions, the permit holder may determine the emissions of the pollutant during the planned MSS activity using an appropriate method, including but not limited to, any of the methods described in paragraphs 1 through 3 below, provided that the permit holder maintains appropriate records supporting such determination:

(1) Use of emission factor(s), facility-specific parameter(s), and/or engineering knowledge of the facility's operations.

(2) Use of emissions data measured (by a CEMS or during emissions testing) during the same type of planned MSS activity occurring at or on a similar facility, and correlation of that data with the facility's relevant operating parameters, including, but not limited to, electric load, temperature, fuel input, and fuel sulfur content.

(3) Use of emissions testing data collected during a planned MSS activity occurring at or on the facility, and correlation of that data with the facility's relevant operating parameters, including, but not limited to, electric load, temperature, fuel input, and fuel sulfur content.

25. With the exception of the emission limits in the MAERT attached to the newly authorized permit, the permit conditions relating to planned MSS activities do not become effective until 180 days after issuance of the permit amendment that added such conditions. **(03/12)**

Date: March 2, 2012

Attachment A
Permit Numbers 35335 and PSDTX880
Non-ILE Planned Maintenance Activities

Planned Maintenance Activity	Emissions				
	VOC	NO_X	CO	PM	SO_2
Combustion turbine optimization[1]	X	X	X	X	X

Notes:

1. Includes, but is not limited to, (i) leak and operability checks (e.g., turbine over-speed tests, troubleshooting), (ii) balancing, and (iii) tuning activities that occur during seasonal tuning or after the completion of initial construction, a combustor change-out, a major repair, maintenance to a combustor, or other similar circumstances.

Date: March 2, 2012

Emission Sources - Maximum Allowable Emission Rates

Permit Number 35335 and PSDTX880

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
CG-1	GE-7231FA Turbine and Duct Burner (7)	NO_X	181.74	--
		NO_X (MSS) (6)(8)	220.0	--
		CO	85.84	--
		CO (MSS) (8)	250.0	--
		VOC	9.11	--
		SO_2	1.60	--
		PM_{10}	18.89	--
		H_2SO_4	0.25	--
		HCl	<0.01	--
CG-2	GE-7231FA Turbine and Duct Burner (7)	NO_X	181.74	--
		NO_X (MSS) (8)	220.0	--
		CO	85.84	--
		CO (MSS) (8)	250.0	--
		VOC	9.11	--
		SO_2	1.60	--
		PM_{10}	18.89	--
		H_2SO_4	0.25	--
		HCl	<0.01	--
CG-1 and CG-2	Combined Annual Emissions (7)	NO_X	--	1386.88
		CO	--	733.38

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
CG-1 and CG-2	Combined Annual Emissions	VOC	--	76.12
		SO_2	--	12.67
		PM_{10}	--	144.02
		H_2SO_4	--	1.94
		HCl	--	<0.01
CU-1	Carbonation Unit	NO_X	1.42	5.41
		CO	0.67	2.86
		VOC	0.07	0.30
		SO_2	0.01	0.05
		PM_{10}	0.15	0.56
		H_2SO_4	<0.01	0.01
CG-FUG	Fugitive Emissions (5)	VOC	0.03	0.11

Emission Sources - Maximum Allowable Emission Rates

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.
(2) Specific point source name. For fugitive sources, use area name or fugitive source name.
(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
NO_x - total oxides of nitrogen
SO_2 - sulfur dioxide
PM - total particulate matter, suspended in the atmosphere, including PM_{10} and $PM_{2.5}$, as represented
PM_{10} - total particulate matter equal to or less than 10 microns in diameter, including $PM_{2.5}$, as represented
$PM_{2.5}$ - particulate matter equal to or less than 2.5 microns in diameter
CO - carbon monoxide
HCl - hydrogen chloride
H_2SO_4 - sulfuric acid
(4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
(5) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission rate.
(6) MSS – Maintenance, startup, and shutdown.
(7) The annual emission limits specified in the MAERT for CG-1 and CG-2 include emissions from the units during both normal operations and planned MSS activities. The hourly emission limits specified in the MAERT for CG-1 and CG-2 include emissions from the facility during both normal operations and planned MSS activities, except for NO_X and CO.
(8) For each pollutant whose emissions during planned MSS activities are measured using a CEMS, the MSS lb/hr limits apply only during each clock hour that includes one or more minutes of MSS activities. During all other clock hours, the normal lb/hr limits apply.

Date: March 2, 2012