

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
Pasadena Cogeneration L.P.

AUTHORIZING THE OPERATION OF
Pasadena Cogeneration
Electric Services

LOCATED AT
Harris County, Texas
Latitude 29° 43' 32" Longitude 95° 10' 37"
Regulated Entity Number: RN100222041

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site, emission units and affected source listed in this permit. Operations of the site, emission units and affected source listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site, emission units and affected source authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site, emission units and affected source.

Permit No: 01797 Issuance Date: _____

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements	8
New Source Review Authorization Requirements.....	9
Compliance Requirements	10
Risk Management Plan	11
Protection of Stratospheric Ozone	12
Permit Location.....	12
Permit Shield (30 TAC § 122.148)	12
Acid Rain Permit Requirements	12
Clean Air Interstate Rule Permit Requirements	16
Attachments.....	22
Applicable Requirements Summary.....	23
Additional Monitoring Requirements	56
Permit Shield	65
New Source Review Authorization References	67
Appendix A	71
Acronym List	72
Appendix B	73

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.

- D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.
 - E. Emission units subject to 40 CFR Part 63, Subpart ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.
 - F. For the purpose of generating emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 1 (Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
 - (i) Title 30 TAC § 101.302 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.303 (relating to Emission Reduction Credit Generation Certification)
 - (iii) Title 30 TAC § 101.304 (relating to Mobile Emission Reduction Credit Generation and Certification)
 - (iv) Title 30 TAC § 101.309 (relating to Emission Credit Banking and Trading)
 - (v) The terms and conditions by which the emission limits are established to generate the reduction credit are applicable requirements of this permit
 - G. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 3 (Mass Emission Cap and Trade Program) Requirements:
 - (i) Title 30 TAC § 101.352 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.353 (relating to Allocation of Allowances)
 - (iii) Title 30 TAC § 101.354 (relating to Allowance Deductions)
 - (iv) Title 30 TAC § 101.356 (relating to Allowance Banking and Trading)
 - (v) Title 30 TAC § 101.358 (relating to Emission Monitoring and Compliance Demonstration)
 - (vi) Title 30 TAC § 101.359 (relating to Reporting)
 - (vii) Title 30 TAC § 101.360 (relating to Level of Activity Certification)
 - (viii) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit
2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
- A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)

- C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
- A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1 , shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
 - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
 - (ii) Title 30 TAC § 111.111(a)(1)(E)
 - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
 - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the “Applicable Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:
 - (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar

quarter unless the emission unit is not operating for the entire quarter.

- (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (5) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the

source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)

- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)

- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:

- (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.

- (2) Records of all observations shall be maintained.

- (3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a

position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A)
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader

C. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)
- (iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
 - (1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be

conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.

- (2) Records of all observations shall be maintained.
 - (3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
 - (4) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- D. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).
- E. Permit holders for sites that have materials handling, construction, roads, streets, alleys, and parking lots shall comply with the following requirements:

- (i) Title 30 TAC § 111.145 (relating to Construction and Demolition)
 - (ii) Title 30 TAC § 111.147 (relating to Roads, Streets, and Alleys)
 - (iii) Title 30 TAC § 111.149 (relating to Parking Lots)
- F. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
- (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)
 - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
4. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
- A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
 - B. Title 40 CFR § 60.8 (relating to Performance Tests)
 - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
 - F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
5. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.

Additional Monitoring Requirements

6. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the

averaging time specified in the “Periodic Monitoring Summary,” for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

7. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule, standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
 - A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
8. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
9. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit’s compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
10. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
 - A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
 - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
 - C. Requirements of the Electric Generating Unit Standard Permit for facilities located in the East Texas region based on the information contained in the registration application.

Compliance Requirements

11. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
12. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:
 - A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
 - (i) For sources in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9020:
 - (1) Title 30 TAC § 117.9020(2)(A), (C), and (D)
 - (ii) For electric generating facilities in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9020(2)(B)
 - B. The permit holder shall comply with the requirements of 30 TAC § 117.354 for Final Control Plan Procedures for Attainment Demonstration Emission Specifications and 30 TAC § 117.356 for Revision of Final Control Plan.
13. Use of Emission Credits to comply with applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) Offsets for Title 30 TAC Chapter 116
 - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)(2)
 - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
 - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)(2)

- (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
- (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)

14. Use of Discrete Emission Credits to comply with the applicable requirements:

- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Risk Management Plan

15. For processes subject to 40 CFR Part 68 and specified in 40 CFR § 68.10, the permit holder shall comply with the requirements of the Accidental Release Prevention Provisions in 40 CFR Part 68. The permit holder shall submit to the appropriate agency either a compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR § 68.10(a), or as part of the compliance certification submitted under this permit, a certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of a risk management plan.

Protection of Stratospheric Ozone

16. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
 - A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.
 - B. The permit holder shall comply with 40 CFR Part 82, Subpart F related to the disposal requirements for appliances using Class I or Class II (ozone-depleting) substances or non-exempt substitutes as specified in 40 CFR §§ 82.150 - 82.166 and the applicable Part 82 Appendices.

Permit Location

17. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

18. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Acid Rain Permit Requirements

19. For units CG-1, CG-2, and CG-3 (identified in the Certificate of Representation as units CG-1, CG-2, and CG-3), located at the affected source identified by ORIS/Facility code 55047, the designated representative and the owner or operator, as applicable, shall comply with the following Acid Rain Permit requirements.
 - A. General Requirements
 - (i) Under 30 TAC § 122.12(1) and 40 CFR Part 72, the Acid Rain Permit requirements contained here are a separable portion of the Federal Operating Permit (FOP) and have an independent public comment process which may be separate from, or combined with the FOP.
 - (ii) The owner and operator shall comply with the requirements of 40 CFR Part 72 and 40 CFR Part 76. Any noncompliance with the Acid

Rain Permit will be considered noncompliance with the FOP and may be subject to enforcement action.

- (iii) The owners and operators of the affected source shall operate the source and the unit in compliance with the requirements of this Acid Rain Permit and all other applicable State and federal requirements.
- (iv) The owners and operators of the affected source shall comply with the General Terms and Conditions of the FOP that incorporates this Acid Rain Permit.
- (v) The term for the Acid Rain permit shall commence with the issuance of the FOP that incorporates the Acid Rain permit and shall be run concurrent with the remainder of the term of the FOP. Renewal of the Acid Rain permit shall coincide with the renewal of the FOP that incorporates the Acid Rain permit and subsequent terms shall be no more than five years from the date of renewal of the FOP and run concurrent with the permit term of the FOP.

B. Monitoring Requirements

- (i) The owners and operators, and the designated representative, of the affected source and each affected unit at the source shall comply with the monitoring requirements contained 40 CFR Part 75.
- (ii) The emissions measurements recorded and reported in accordance with 40 CFR Part 75 and any other credible evidence shall be used to determine compliance by the affected source with the acid rain emissions limitations and emissions reduction requirements for SO₂ and NO_x under the ARP.
- (iii) The requirements of 40 CFR Part 75 shall not affect the responsibility of the owners and operators to monitor emission of other pollutants or other emissions characteristics at the unit under other applicable requirements of the FCAA Amendments (42 U.S.C. 7401, as amended November 15, 1990) and other terms and conditions of the operating permit for the source.

C. SO₂ emissions requirements

- (i) The owners and operators of each source and each affected unit at the source shall comply with the applicable acid rain emissions limitations for SO₂.
- (ii) As of the allowance transfer deadline the owners and operators of the affected source and each affected unit at the source shall hold, in the unit's compliance subaccount, allowances in an amount not less than the total annual emissions of SO₂ for the previous calendar year.
- (iii) Each ton of SO₂ emitted in excess of the acid rain emissions limitations for SO₂ shall constitute a separate violation of the FCAA amendments.
- (iv) An affected unit shall be subject to the requirements under (i) and (ii) of the SO₂ emissions requirements as follows:

- (1) Starting January 1, 2000, an affected unit under 40 CFR § 72.6(a)(2); or
 - (2) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR Part 75, an affected unit under 40 CFR § 72.6(a)(3).
- (v) Allowances shall be held in, deducted from, or transferred into or among Allowance Tracking System accounts in accordance with the requirements of the ARP.
 - (vi) An allowance shall not be deducted, for compliance with the requirements of this permit, in a calendar year before the year for which the allowance was allocated.
 - (vii) An allowance allocated by the EPA Administrator or under the ARP is a limited authorization to emit SO₂ in accordance with the ARP. No provision of the ARP, Acid Rain permit application, this Acid Rain Permit, or an exemption under 40 CFR §§ 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
 - (viii) An allowance allocated by the EPA Administrator under the ARP does not constitute a property right.

D. NO_x Emission Requirements

- (i) The owners and operators of the source and each affected unit at the source shall comply with the applicable acid rain emissions limitations for NO_x under 40 CFR Part 76.

E. Excess emissions requirements for SO₂ and NO_x.

- (i) The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77.
- (ii) If an affected source has excess emissions in any calendar year shall, as required by 40 CFR Part 77:
 - (1) Pay, without demand, the penalty required and pay, upon demand, the interest on that penalty.
 - (2) Comply with the terms of an approved offset plan.

F. Recordkeeping and Reporting Requirements

- (i) Unless otherwise provided, the owners and operators of the affected source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the permitting authority or the EPA Administrator.

- (1) The certificate of representation for the designated representative for the source and each affected unit and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR § 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative.
 - (2) All emissions monitoring information, in accordance with 40 CFR Part 75, provided that to the extent that 40 CFR Part 75 provides for a 3-year period for recordkeeping (rather than a five-year period cited in 30 TAC § 122.144), the 3-year period shall apply.
 - (3) Copies of all reports, compliance certifications, and other submissions and all records made or required under the ARP or relied upon for compliance certification.
 - (4) Copies of all documents used to complete an acid rain permit application and any other submission under the ARP or to demonstrate compliance with the requirements of the ARP.
- (ii) The designated representative of an affected source and each affected unit at the source shall submit the reports required under the ARP including those under 40 CFR Part 72, Subpart I and 40 CFR Part 75.

G. Liability

- (i) Any person who knowingly violates any requirement or prohibition of the ARP, a complete acid rain permit application, an acid rain permit, or a written exemption under 40 CFR §§ 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to FCAA § 113(c).
- (ii) Any person who knowingly makes a false, material statement in any record, submission, or report under the ARP shall be subject to criminal enforcement pursuant to FCAA § 113(c) and 18 U.S.C. 1001.
- (iii) No permit revision shall excuse any violation of the requirements of the ARP that occurs prior to the date that the revision takes effect.
- (iv) The affected source and each affected unit shall meet the requirements of the ARP contained in 40 CFR Parts 72 through 78.
- (v) Any provision of the ARP that applies to an affected source or the designated representative of an affected source shall also apply to the owners and operators of such source and of the affected units at the source.
- (vi) Any provision of the ARP that applies to an affected unit (including a provision applicable to the DR of an affected unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR § 72.44 (Phase II repowering extension plans) and 40 CFR § 76.11 (NO_x averaging plans), and except with regard to the requirements

applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR §§ 75.16, 75.17, and 75.18), the owners and operators and the DR of one affected unit shall not be liable for any violation by any other affected unit of which they are not owners or operators or the DR and that is located at a source of which they are not owners or operators or the DR.

- (vii) Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or DR of such source or unit, shall be a separate violation of the FCAA Amendments.
- H. Effect on other authorities. No provision of the ARP, an acid rain permit application, an acid rain permit, or an exemption under 40 CFR §§ 72.7 or 72.8 shall be construed as:
- (i) Except as expressly provided in Title IV of the FCAA Amendments, exempting or excluding the owners and operators and, to the extent applicable, the DR of an affected source or affected unit from compliance with any other provision of the FCAA Amendments, including the provisions of Title I of the FCAA Amendments relating to applicable National Ambient Air Quality Standards or State Implementation Plans.
 - (ii) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the FCAA Amendments.
 - (iii) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law.
 - (iv) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
 - (v) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established.
- I. The number of SO₂ allowances allocated by the EPA in 40 CFR Part 73 is enforceable only by the EPA Administrator.

Clean Air Interstate Rule Permit Requirements

20. For units CG-1, CG-2, and CG-3 (identified in the Certificate of Representation as units CG-1, CG-2, and CG-3), located at the site identified by ORIS/Facility code 55047, the designated representative and the owner or operator, as applicable, shall comply with the following Clean Air Interstate Rule (CAIR) Permit requirements. Until approval of the Texas CAIR SIP by EPA, the permit holder shall comply with the equivalent requirements of 40 CFR Part 97 in place of the referenced 40 CFR Part 96 requirements in the Texas CAIR permit and 30 TAC Chapter 122 requirements.

A. General Requirements

- (i) Under 30 TAC § 122.420(b) and 40 CFR §§ 96.120(b) and 96.220(b) the CAIR Permit requirements contained here are a separable portion of the Federal Operating Permit (FOP).
- (ii) The owners and operators of the CAIR NO_x and the CAIR SO₂ source shall operate the source and the unit in compliance with the requirements of this CAIR permit and all other applicable State and federal requirements.
- (iii) The owners and operators of the CAIR NO_x and the CAIR SO₂ source shall comply with the General Terms and Conditions of the FOP that incorporates this CAIR Permit.
- (iv) The term for the initial CAIR permit shall commence with the issuance of the revision containing the CAIR permit and shall be the remaining term for the FOP that incorporates the CAIR permit. Renewal of the initial CAIR permit shall coincide with the renewal of the FOP that incorporates the CAIR permit and subsequent terms shall be no more than five years from the date of renewal of the FOP and run concurrent with the permit term of the FOP.

B. Monitoring and Reporting Requirements

- (i) The owners and operators, and the CAIR designated representative, of the CAIR NO_x source and each CAIR NO_x unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements contained 40 CFR Part 96, Subpart HH.
- (ii) The owners and operators, and the CAIR designated representative, of the CAIR SO₂ source and each CAIR SO₂ unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements contained 40 CFR Part 96, Subpart HHH.
- (iii) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HH and any other credible evidence shall be used to determine compliance by the CAIR NO_x source with the CAIR NO_x emissions limitation.
- (iv) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHH and any other credible evidence shall be used to determine compliance by the CAIR SO₂ source with the CAIR SO₂ emissions limitation.

C. NO_x emissions requirements

- (i) As of the allowance transfer deadline for a control period, the owners and operators of the CAIR NO_x source and each CAIR NO_x unit at the source shall hold, in the source's compliance account, CAIR NO_x allowances available for compliance deductions for the control period under 40 CFR § 96.154(a) in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NO_x units at the source, as determined in accordance with the requirements of 40 CFR Part 96, Subpart HH.

- (ii) A CAIR NO_x unit shall be subject to the requirements of paragraph C.(i) of this CAIR Permit starting on the later of January 1, 2009, or the deadline for meeting the unit's monitor certification requirements under 40 CFR § 96.170(b)(1), (2), or (5).
- (iii) A CAIR NO_x allowance shall not be deducted, for compliance with the requirements of this permit, for a control period in a calendar year before the year for which the CAIR NO_x allowance was allocated.
- (iv) CAIR NO_x allowances shall be held in, deducted from or transferred into or among CAIR NO_x Allowance Tracking System accounts in accordance with the requirements of 40 CFR Part 96, Subpart FF or Subpart GG.
- (v) A CAIR NO_x allowance is a limited authorization to emit one ton of nitrogen oxides in accordance with the CAIR NO_x Annual Trading Program. No provision of the CAIR NO_x Annual Trading Program, the CAIR permit application, the CAIR permit, or an exemption under 40 CFR § 96.105 and no provision of law shall be construed to limit the authority of the State or the United States to terminate or limit such authorization.
- (vi) A CAIR NO_x allowance does not constitute a property right.
- (vii) Upon recordation by the Administrator under 40 CFR Part 96, Subpart FF or Subpart GG, every allocation, transfer, or deduction of a CAIR NO_x allowance to or from a CAIR NO_x unit's compliance account is incorporated automatically in this CAIR permit.

D. NO_x excess emissions requirement

- (i) If a CAIR NO_x source emits nitrogen oxides during any control period in excess of the CAIR NO_x emissions limitation, the owners and operators of the source and each CAIR NO_x unit at the source shall surrender the CAIR NO_x allowances required for deduction under 40 CFR § 96.154(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable State law.
- (ii) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AA, the Clean Air Act, and applicable State law.

E. SO₂ emissions requirements

- (i) As of the allowance transfer deadline for a control period, the owners and operators of the CAIR SO₂ source and each CAIR SO₂ unit at the source shall hold, in the source's compliance account, CAIR SO₂ allowances available for compliance deductions for the control period under 40 CFR § 96.254(a) and (b) in an amount not less than the tons of total sulfur dioxides emissions for the control period from all CAIR SO₂ units at the source, as determined in accordance with the requirements of 40 CFR Part 96, Subpart HHH.

- (ii) A CAIR SO₂ unit shall be subject to the requirements of paragraph E.(i) of this CAIR Permit starting on the later of January 1, 2010, or the deadline for meeting the unit's monitor certification requirements under 40 CFR § 96.270(b)(1), (2), or (5).
- (iii) A CAIR SO₂ allowance shall not be deducted, for compliance with the requirements of this permit, for a control period in a calendar year before the year for which the CAIR SO₂ allowance was allocated.
- (iv) CAIR SO₂ allowances shall be held in, deducted from, or transferred into or among CAIR SO₂ Allowance Tracking System accounts in accordance with the requirements of 40 CFR Part 96, Subpart FFF or Subpart GGG.
- (v) A CAIR SO₂ allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO₂ Trading Program. No provision of the CAIR SO₂ Trading Program, the CAIR permit application, the CAIR permit, or an exemption under 40 CFR § 96.205 and no provision of law shall be construed to limit the authority of the State or the United States to terminate or limit such authorization.
- (vi) A CAIR SO₂ allowance does not constitute a property right.
- (vii) Upon recordation by the Administrator under 40 CFR Part 96, Subpart FFF or Subpart GGG, every allocation, transfer, or deduction of a CAIR SO₂ allowance to or from a CAIR SO₂ unit's compliance account is incorporated automatically in this CAIR permit.

F. SO₂ excess emissions requirements

- (i) If a CAIR SO₂ source emits sulfur dioxides during any control period in excess of the CAIR SO₂ emissions limitation, the owners and operators of the source and each CAIR SO₂ unit at the source shall surrender the CAIR SO₂ allowances required for deduction under 40 CFR § 96.254(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable State law.
- (ii) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAA, the Clean Air Act, and applicable State law.

G. Recordkeeping and Reporting Requirements

- (i) Unless otherwise provided, the owners and operators of the CAIR NO_x source and each CAIR NO_x unit at the source and the CAIR SO₂ source and each CAIR SO₂ unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the permitting authority or the Administrator.
 - (1) The certificate of representation under 40 CFR §§ 96.113 and 96.213 for the CAIR NO_x designated representative for the source and each CAIR NO_x unit and the CAIR SO₂ designated

representative for the source and each CAIR SO₂ unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5 year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR §§ 96.113 and 96.213 changing the CAIR designated representative.

- (2) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HH and Subpart HHH, provided that to the extent that these subparts provide for a 3-year period for recordkeeping, the 3-year period shall apply.
 - (3) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x Annual Trading Program and CAIR SO₂ Trading Program or relied upon for compliance determinations.
 - (4) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NO_x Annual Trading Program and CAIR SO₂ Trading Program or to demonstrate compliance with the requirements of the CAIR NO_x Annual Trading Program and CAIR SO₂ Trading Program.
- (ii) The CAIR designated representative of a CAIR NO_x source and each CAIR NO_x unit at the source and a CAIR SO₂ source and each CAIR SO₂ unit at the source shall submit the reports required under the CAIR NO_x Annual Trading Program and the CAIR SO₂ Trading Program including those under 40 CFR Part 96, Subpart HH and Subpart HHH.
- H. The CAIR NO_x source and each CAIR NO_x unit shall meet the requirements of the CAIR NO_x Annual Trading Program contained in 40 CFR Part 96, Subparts AA through II.
- I. The CAIR SO₂ source and each CAIR SO₂ unit shall meet the requirements of the CAIR SO₂ Trading Program contained in 40 CFR Part 96, Subparts AAA through III.
- J. Any provision of the CAIR NO_x Annual Trading Program and the CAIR SO₂ Trading Program that applies to a CAIR NO_x source or CAIR SO₂ source or the CAIR designated representative of a CAIR NO_x source or CAIR SO₂ source shall also apply to the owners and operators of such source and the units at the source.
- K. Any provision of the CAIR NO_x Annual Trading Program and the CAIR SO₂ Trading Program that applies to a CAIR NO_x unit or CAIR SO₂ unit or the CAIR designated representative of a CAIR NO_x unit or CAIR SO₂ unit shall also apply to the owners and operators of such unit.
- L. No provision of the CAIR NO_x Annual Trading Program, CAIR SO₂ Trading Program, a CAIR permit application, a CAIR permit, or an exemption under 40 CFR §§ 96.105 or 96.205 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO_x

source or CAIR NO_x unit or a CAIR SO₂ source or CAIR SO₂ unit from compliance with any other provision of the applicable, approved State implementation plan, a federally enforceable permit, or the Clean Air Act.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Applicable Requirements Summary

Unit Summary 24

Applicable Requirements Summary 28

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
B-1	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1151-1	30 TAC Chapter 111, Nonagricultural Processes	No changing attributes.
B-1	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
CG-1	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1151-1	30 TAC Chapter 111, Nonagricultural Processes	No changing attributes.
CG-1	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
CG-1	STATIONARY TURBINES	N/A	R7ICI-1	30 TAC Chapter 117, Subchapter B	CO Emission Limitation = Title 30 TAC § 117.310(c)(1)., NH3 Emission Limitation = Title 30 TAC § 117.310(c)(2).
CG-1	STATIONARY TURBINES	N/A	R7ICI-MSS	30 TAC Chapter 117, Subchapter B	CO Emission Limitation = Unit is complying with an Alternative Case Specific Specification under Title 30 TAC §§ 117.125, 117.325 or 117.425., NH3 Emission Limitation = Unit is complying with an Alternative Case Specific Specification under Title 30 TAC §§ 117.125, 117.325 or 117.425.
CG-1	STATIONARY TURBINES	N/A	60KKKK-1	40 CFR Part 60, Subpart KKKK	No changing attributes.
CG-1	STATIONARY TURBINES	N/A	60KKKK-2	40 CFR Part 60, Subpart	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				KKKK	
CG-2	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1151-1	30 TAC Chapter 111, Nonagricultural Processes	No changing attributes.
CG-2	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
CG-2	STATIONARY TURBINES	N/A	R7ICI-1	30 TAC Chapter 117, Subchapter B	CO Emission Limitation = Title 30 TAC § 117.310(c)(1)., NH3 Emission Limitation = Title 30 TAC § 117.310(c)(2).
CG-2	STATIONARY TURBINES	N/A	R7ICI-MSS	30 TAC Chapter 117, Subchapter B	CO Emission Limitation = Unit is complying with an Alternative Case Specific Specification under Title 30 TAC §§ 117.125, 117.325 or 117.425., NH3 Emission Limitation = Unit is complying with an Alternative Case Specific Specification under Title 30 TAC §§ 117.125, 117.325 or 117.425.
CG-2	STATIONARY TURBINES	N/A	60GG-1	40 CFR Part 60, Subpart GG	No changing attributes.
CG-3	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1151-1	30 TAC Chapter 111, Nonagricultural Processes	No changing attributes.
CG-3	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
CG-3	STATIONARY TURBINES	N/A	R7ICI-1	30 TAC Chapter 117, Subchapter B	CO Emission Limitation = Title 30 TAC § 117.310(c)(1)., NH3 Emission Limitation = Title 30 TAC § 117.310(c)(2).
CG-3	STATIONARY TURBINES	N/A	R7ICI-MSS	30 TAC Chapter 117, Subchapter B	CO Emission Limitation = Unit is complying with an Alternative Case Specific Specification under Title 30 TAC §§ 117.125, 117.325 or 117.425., NH3 Emission Limitation = Unit is complying with an Alternative Case Specific Specification under Title 30 TAC §§ 117.125, 117.325 or 117.425.
CG-3	STATIONARY TURBINES	N/A	60GG-1	40 CFR Part 60, Subpart GG	No changing attributes.
DIST-TK	STORAGE TANKS/VESSELS	N/A	115TK-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EGICE	SRIC ENGINES	N/A	R7ICI-1	30 TAC Chapter 117, Subchapter B	No changing attributes.
EGICE	SRIC ENGINES	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRPB-1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	B-1A, B-1B, B-1C	R7ICI-1	30 TAC Chapter 117, Subchapter B	CO Emission Limitation = Title 30 TAC § 117.310(c)(1) 400 ppmv option.
GRPB-1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	B-1A, B-1B, B-1C	R7ICI-MSS	30 TAC Chapter 117, Subchapter B	CO Emission Limitation = Unit is complying with an Alternative Case Specific Specification under 30 TAC §§ 117.125(a), 117.325(a)

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					or 117.425(a).
GRPB-1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	B-1A, B-1B, B-1C	60Db-1	40 CFR Part 60, Subpart Db	No changing attributes.
LOAD-1	LOADING/UNLOADING OPERATIONS	N/A	115-LOAD1	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
LOAD-2	LOADING/UNLOADING OPERATIONS	N/A	115-LOAD2	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
SEP-1	VOLATILE ORGANIC COMPOUND WATER SEPARATORS	N/A	R5131-1	30 TAC Chapter 115, Water Separation	No changing attributes.
SEP-2	VOLATILE ORGANIC COMPOUND WATER SEPARATORS	N/A	R5131-1	30 TAC Chapter 115, Water Separation	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
B-1	EP	R1151-1	PM	30 TAC Chapter 111, Nonagricultural Processes	§ 111.151(a) § 111.151(c)	No person may cause, suffer, allow, or permit emissions of particulate matter from any source to exceed the allowable rates specified in Table 1 as follows, except as provided by §111.153 of this title (relating to Emissions Limits for Steam Generators).	** See Periodic Monitoring Summary	None	None
B-1	EP	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
CG-1	EP	R1151-1	PM	30 TAC Chapter 111, Nonagricultural Processes	§ 111.151(a) § 111.151(c)	No person may cause, suffer, allow, or permit emissions of particulate matter from any source to exceed the allowable rates specified in Table 1 as follows, except as provided by §111.153 of this title (relating to Emissions Limits for Steam Generators).	** See Periodic Monitoring Summary	None	None
CG-1	EP	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.			
CG-1	EU	R7ICI-1	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(10)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E)	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(6)		
CG-1	EU	R7ICI-1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG-1	EU	R7ICI-1	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(B) § 117.340(f)(1)	For stationary gas turbines that inject urea or ammonia into the	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b)	§ 117.345(a) § 117.345(f) § 117.345(f)(11)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						exhaust stream for NO _x control, ammonia emissions must not exceed 10 ppmv at 15% O ₂ , dry.	§ 117.335(c) § 117.335(d) § 117.335(g) § 117.340(d) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8130 § 117.8130(4)	[G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	[G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG-1	EU	R7ICI-MSS	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(10)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2)	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		[G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG-1	EU	R7ICI-MSS	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) §	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)		§ 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG-1	EU	R7ICI-MSS	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the ammonia specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the ammonia specifications in § 117.310(c) of this title for that unit.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(g) § 117.340(d) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8130 § 117.8130(4)		
CG-1	EU	60KKKK-1	NO _x	40 CFR Part 60, Subpart KKKK	§ 60.4320(a)-Table 1 § 60.4320(a) § 60.4320(b) § 60.4325 § 60.4333(a) § 60.4333(b)(1) § 60.4335(b)(1) § 60.4335(b)(2) § 60.4335(b)(3) § 60.4335(b)(4) [G]§ 60.4345	Turbines operating at less than 75 percent of peak load, or turbines operating at temperatures less than 0 degrees F with greater than 30 MW output must meet the nitrogen oxides emission standard of 590 ng/J of useful output (4.7 lb/MWh).	§ 60.4333(b)(1) § 60.4335(b)(1) § 60.4335(b)(2) § 60.4335(b)(3) § 60.4335(b)(4) [G]§ 60.4345 § 60.4350(a) § 60.4350(b) § 60.4350(c) § 60.4350(d) § 60.4350(e) § 60.4350(f) § 60.4350(f)(2) § 60.4350(h) [G]§ 60.4400(a) § 60.4400(b) § 60.4400(b)(1) § 60.4400(b)(4) § 60.4400(b)(5) § 60.4400(b)(6) [G]§ 60.4405	[G]§ 60.4345 § 60.4350(b)	[G]§ 60.4345 § 60.4350(d) § 60.4375(a) § 60.4380 [G]§ 60.4380(b) § 60.4395
CG-1	EU	60KKKK-1	SO ₂	40 CFR Part 60, Subpart KKKK	§ 60.4330(a)(2) § 60.4333(a)	You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO ₂ /J (0.060 lb SO ₂ /MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel	§ 60.4365 § 60.4365(b) § 60.4415(a) § 60.4415(a)(1) § 60.4415(a)(1)(ii)	§ 60.4365(b)	§ 60.4375(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						must meet this requirement.			
CG-1	EU	60KKKK-2	NO _x	40 CFR Part 60, Subpart KKKK	§ 60.4320(a)-Table 1 § 60.4320(a) § 60.4320(b) § 60.4325 § 60.4333(a) § 60.4333(b)(1) § 60.4335(b)(1) § 60.4335(b)(2) § 60.4335(b)(3) § 60.4335(b)(4) [G]§ 60.4345	New, modified, or reconstructed turbine firing natural gas with a heat input at peak load > 850 MMBtu/h must meet the nitrogen oxides emission standard of 54 ng/J of useful output (0.43 lb/MWh).	§ 60.4333(b)(1) § 60.4335(b)(1) § 60.4335(b)(2) § 60.4335(b)(3) § 60.4335(b)(4) [G]§ 60.4345 § 60.4350(a) § 60.4350(b) § 60.4350(c) § 60.4350(d) § 60.4350(e) § 60.4350(f) § 60.4350(f)(2) § 60.4350(h) [G]§ 60.4400(a) § 60.4400(b) § 60.4400(b)(1) § 60.4400(b)(4) § 60.4400(b)(5) § 60.4400(b)(6) [G]§ 60.4405	[G]§ 60.4345 § 60.4350(b)	[G]§ 60.4345 § 60.4350(d) § 60.4375(a) § 60.4380 [G]§ 60.4380(b) § 60.4395
CG-1	EU	60KKKK-2	SO ₂	40 CFR Part 60, Subpart KKKK	§ 60.4330(a)(2) § 60.4333(a)	You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO ₂ /J (0.060 lb SO ₂ /MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.	§ 60.4365 § 60.4365(b) § 60.4415(a) § 60.4415(a)(1) § 60.4415(a)(1)(ii)	§ 60.4365(b)	§ 60.4375(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CG-2	EP	R1151-1	PM	30 TAC Chapter 111, Nonagricultural Processes	§ 111.151(a) § 111.151(c)	No person may cause, suffer, allow, or permit emissions of particulate matter from any source to exceed the allowable rates specified in Table 1 as follows, except as provided by §111.153 of this title (relating to Emissions Limits for Steam Generators).	** See Periodic Monitoring Summary	None	None
CG-2	EP	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
CG-2	EU	R7ICI-1	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(10)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1)	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		[G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG-2	EU	R7ICI-1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)		[G]§ 117.8010(8) § 117.8100(c)
CG-2	EU	R7ICI-1	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(B) § 117.340(f)(1)	For stationary gas turbines that inject urea or ammonia into the exhaust stream for NO _x control, ammonia emissions must not exceed 10 ppmv at 15% O ₂ , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(g) § 117.340(d) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8130 § 117.8130(4)		
CG-2	EU	R71CI-MSS	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(10)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CG-2	EU	R7ICI-MSS	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG-2	EU	R7ICI-MSS	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the ammonia specifications of §	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) [G]§ 117.345(f)(2) § 117.345(f)(8)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						117.310(c) of this title the executive director may approve emission specifications different from the ammonia specifications in § 117.310(c) of this title for that unit.	§ 117.335(g) § 117.340(d) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8130 § 117.8130(4)	§ 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG-2	EU	60GG-1	SO ₂	40 CFR Part 60, Subpart GG	§ 60.333(a)	No stationary gas turbine shall cause to be discharged into the atmosphere any gases which contain sulfur dioxide in excess of 0.015% by volume at 15% O ₂ dry basis.	§ 60.334(h) [G]§ 60.334(h)(3)	None	None
CG-2	EU	60GG-1	NO _x	40 CFR Part 60, Subpart GG	§ 60.332(a)(1) § 60.332(a)(3)	No owner or operator shall discharge into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of the amount as	[G]§ 60.334(b) § 60.334(j) § 60.334(j)(1) [G]§ 60.334(j)(1)(iii) [G]§ 60.335(a) § 60.335(b)(1) § 60.335(b)(2)	[G]§ 60.334(b)	§ 60.334(j) § 60.334(j)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						determined from the specified equation.	§ 60.335(c)(1)		
CG-3	EP	R1151-1	PM	30 TAC Chapter 111, Nonagricultural Processes	§ 111.151(a) § 111.151(c)	No person may cause, suffer, allow, or permit emissions of particulate matter from any source to exceed the allowable rates specified in Table 1 as follows, except as provided by §111.153 of this title (relating to Emissions Limits for Steam Generators).	** See Periodic Monitoring Summary	None	None
CG-3	EP	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
CG-3	EU	R7ICI-1	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(10)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2)	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		[G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG-3	EU	R7ICI-1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) §	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)		§ 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG-3	EU	R7ICI-1	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(B) § 117.340(f)(1)	For stationary gas turbines that inject urea or ammonia into the exhaust stream for NO _x control, ammonia emissions must not exceed 10 ppmv at 15% O ₂ , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(g) § 117.340(d) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8130 § 117.8130(4)		
CG-3	EU	R7ICI-MSS	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(10)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E)	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(6)		
CG-3	EU	R7ICI-MSS	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG-3	EU	R7ICI-MSS	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b)	§ 117.345(a) § 117.345(f) § 117.345(f)(11)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						attain the ammonia specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the ammonia specifications in § 117.310(c) of this title for that unit.	§ 117.335(c) § 117.335(d) § 117.335(g) § 117.340(d) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8130 § 117.8130(4)	[G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	[G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG-3	EU	60GG-1	SO ₂	40 CFR Part 60, Subpart GG	§ 60.333(a)	No stationary gas turbine shall cause to be discharged into the atmosphere any gases which contain sulfur dioxide in excess of 0.015% by volume at 15% O ₂ dry basis.	§ 60.334(h) [G]§ 60.334(h)(3)	None	None
CG-3	EU	60GG-1	NO _x	40 CFR Part 60, Subpart GG	§ 60.332(a)(1) § 60.332(a)(3)	No owner or operator shall discharge into the atmosphere from any stationary gas turbine, any gases which contain	[G]§ 60.334(b) § 60.334(j) § 60.334(j)(1) [G]§ 60.334(j)(1)(iii) [G]§ 60.335(a)	[G]§ 60.334(b)	§ 60.334(j) § 60.334(j)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						nitrogen oxides in excess of the amount as determined from the specified equation.	§ 60.335(b)(1) § 60.335(b)(2) § 60.335(c)(1)		
DIST-TK	EU	115TK-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
EGICE	EU	R7ICI-1	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(6)	None
EGICE	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table2d.5 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e)	For each existing emergency stationary SI RICE; black start stationary SI RICE; non-emergency, non-black start 4SLB stationary	§ 63.6625(f) § 63.6625(j) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-	§ 63.6625(j) § 63.6655(a) § 63.6655(a)(1) § 63.6655(d) § 63.6655(e) § 63.6655(f)	§ 63.6640(b) § 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6625(h) § 63.6625(j) § 63.6640(b) § 63.6640(f)(1) [G]§ 63.6640(f)(2) [G]§ 63.6640(f)(4)	RICE with a site rating greater than 500 HP that operates 24 hours or less per calendar year; non-emergency, non-black start 4SRB stationary RICE with a site rating greater than 500 HP that operates 24 hours or less per calendar year, located at an area source, you must comply with the requirements as specified in Table 2d.5.a-c.	Table 6.9.a.ii § 63.6640(b)	§ 63.6660(a) § 63.6660(b) § 63.6660(c)	
GRPB-1	EU	R7ICI-1	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						§ 117.320.	§ 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		
GRPB-1	EU	R7ICI-1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120(1) § 117.8120(1)(A)		
GRPB-1	EU	R7ICI-MSS	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		
GRPB-1	EU	R7ICI-MSS	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8120 § 117.8120(1) § 117.8120(1)(A)		
GRPB-1	EU	60Db-1	SO ₂	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
GRPB-1	EU	60Db-1	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
GRPB-1	EU	60Db-1	PM (OPACITY)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
GRPB-1	EU	60Db-1	NO _x	40 CFR Part 60, Subpart Db	§ 60.44b(a)(1)(ii) § 60.44b(h)	Except as in §60.44b(k), (l), on/after §60.8 test,	§ 60.46b(c) § 60.46b(e)	[G]§ 60.48b(b) § 60.48b(c)	§ 60.49b(a) § 60.49b(a)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.44b(i) § 60.46b(a)	no facility combusting natural gas and distillate oil (high heat release rate) shall discharge gases containing NOx in excess of 86 ng/J heat input.	§ 60.46b(e)(1) § 60.46b(e)(4) [G]§ 60.48b(b) § 60.48b(c) § 60.48b(d) § 60.48b(e) [G]§ 60.48b(e)(2) § 60.48b(e)(3) § 60.48b(f) § 60.48b(g)(1)	[G]§ 60.49b(d) [G]§ 60.49b(g) § 60.49b(o)	§ 60.49b(a)(3) § 60.49b(b) § 60.49b(h) § 60.49b(h)(4) § 60.49b(i) § 60.49b(v) § 60.49b(w)
LOAD-1	EU	115-LOAD1	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(2)(A) [G]§ 115.212(a)(7) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Any plant, excluding gasoline bulk plants, which loads less than 20,000 gpd of VOC with a true vapor pressure of 0.5 psia or greater is exempt from the requirements of this division, except for the specified requirements.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B) § 115.216(3)(D)	None
LOAD-2	EU	115-LOAD2	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
SEP-1	EU	R5131-1	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						equipment is exempt from §115.132(a).			
SEP-2	EU	R5131-1	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None

Additional Monitoring Requirements

Periodic Monitoring Summary 57

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B-1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Use of Alternate Fuel	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B-1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Nonagricultural Processes	SOP Index No.: R1151-1
Pollutant: PM	Main Standard: § 111.151(a)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Use of Alternate Fuel	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CG-1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Use of alternate fuel	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CG-1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Nonagricultural Processes	SOP Index No.: R1151-1
Pollutant: PM	Main Standard: § 111.151(a)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Use of Alternate Fuel	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CG-2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Use of alternate fuel	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CG-2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Nonagricultural Processes	SOP Index No.: R1151-1
Pollutant: PM	Main Standard: § 111.151(a)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Use of Alternate Fuel	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CG-3	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Use of alternate fuel	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CG-3	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Nonagricultural Processes	SOP Index No.: R1151-1
Pollutant: PM	Main Standard: § 111.151(a)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Use of Alternate Fuel	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Permit Shield

Permit Shield 66

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
COOLTWR-1	N/A	40 CFR Part 63, Subpart Q	The cooling tower does not use chromium-based water treatment chemicals.
COOLTWR-2	N/A	40 CFR Part 63, Subpart Q	The cooling tower does not use chromium-based water treatment chemicals.
F-1	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	The site is not a petroleum refinery, a synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process, or a natural gas/gasoline processing operation.
F-2	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	The site is not a petroleum refinery, a synthetic organic chemical, polymer, resin or methyl-tert-butyl ether manufacturing process, or a natural gas/gasoline processing operation.

New Source Review Authorization References

New Source Review Authorization References..... 68

New Source Review Authorization References by Emission Unit 69

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Prevention of Significant Deterioration (PSD) Permits	
PSD Permit No.: PSDTX915	Issuance Date: 04/13/2016
Nonattainment (NA) Permits	
NA Permit No.: N015	Issuance Date: 04/13/2016
Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 37283	Issuance Date: 04/13/2016
Authorization No.: 91385	Issuance Date: 12/16/2009
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.227	Version No./Date: 03/14/1997
Number: 106.261	Version No./Date: 03/14/1997
Number: 106.262	Version No./Date: 03/14/1997
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.264	Version No./Date: 03/14/1997
Number: 106.265	Version No./Date: 03/14/1997
Number: 106.371	Version No./Date: 03/14/1997
Number: 106.372	Version No./Date: 03/14/1997
Number: 106.472	Version No./Date: 03/14/1997
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.477	Version No./Date: 09/04/2000
Number: 106.478	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 03/14/1997
Number: 106.532	Version No./Date: 03/14/1997

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
B-1A	1A AUXILIARY BOILER	37283, PSDTX915
B-1	AUXILIARY BOILERS STACK	37283, PSDTX915
B-1B	1B AUXILIARY BOILER	37283, PSDTX915
B-1C	1C AUXILIARY BOILER	37283, PSDTX915
CG-1	TURBINE/HRSG	37283, 91385, PSDTX915
CG-1	TURBINE/HRSG STACK	37283, 91385, PSDTX915
CG-2	TURBINE/HRSG	37283, N015, PSDTX915
CG-2	TURBINE/HRSG STACK	37283, N015, PSDTX915
CG-3	TURBINE/HRSG	37283, N015, PSDTX915
CG-3	TURBINE/HRSG STACK	37283, N015, PSDTX915
COOLTWR-1	COOLING TOWER	106.371/03/14/1997
COOLTWR-2	COOLING TOWER	106.371/03/14/1997
DIST-TK	DISTILLATE TANK FOR NATURAL GAS LIQUIDS	106.473/09/04/2000
EGICE	EMERGENCY GENERATOR IC ENGINE	106.511/03/14/1997
F-1	FUGITIVES	37283, N015, PSDTX915
F-2	FUGITIVES	37283, N015, PSDTX915
LOAD-1	VOLATILE ORGANIC LIQUID LOADING POINTS	106.473/09/04/2000
LOAD-2	VOLATILE ORGANIC LIQUID LOADING AND UNLOADING PTS	106.472/03/14/1997
SEP-1	LUBE OIL/WATER SEPARATOR	106.532/03/14/1997

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
SEP-2	LUBE OIL/WATER SEPARATOR	106.532/03/14/1997

Appendix A

Acronym List 72

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
COMS	continuous opacity monitoring system
CVS	closed-vent system
D/FW	Dallas/Fort Worth (nonattainment area)
DR	Designated Representative
EIP	El Paso (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
GF	grandfathered
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MMBtu/hr	Million British thermal units per hour
MRRT	monitoring, recordkeeping, reporting, and testing
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PM	particulate matter
ppmv	parts per million by volume
PSD	prevention of significant deterioration
RO	Responsible Official
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound

Appendix B

Major NSR Summary Table 74

Major NSR Summary Table

Permit Number: 37283, PSDTX915, N015					Issuance Date: 04/13/2016		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Spec. Cond.	Spec. Cond.	Spec. Cond.
Turbines and Auxiliary Boilers Normal Operation Limits							
CG-1	Turbine/HRSG	NO _v	56.51	-	3, 7, 15, 17, 18, 19, 20, 21	7, 15, 17, 18, 19, 20, 21, 30, 31	15, 17, 18, 19, 20, 32, 33
		CO (6)	36.00	-			
		CO (7)	317.00	-			
		SO ₂	1.25	-			
		VOC	5.80	-			
		PM ₁₀	9.00	-			
		NH ₃	21.55	-			
B-1	Auxiliary Boilers (Three auxiliary gas boilers venting through a common stack)	NO _v	42.47	-	3, 7, 15, 17, 18, 21, 34	7, 15, 17, 18, 21, 30, 31, 34	15, 17, 18, 32, 33, 34
		CO	25.85	-			
		SO ₂	0.24	-			
		VOC	5.83	-			
		PM ₁₀	4.67	-			
CG-1, B-1	Turbine/HRSG and Auxiliary Boilers (5)(8)	NO _x	98.98				
		CO (6)	61.85				
		CO (7)	342.85				
		SO ₂	1.49				
		VOC	11.64				

Major NSR Summary Table

Permit Number: 37283, PSDTX915, N015					Issuance Date: 04/13/2016		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Spec. Cond.	Spec. Cond.	Spec. Cond.
		PM ₁₀	13.67				
		NH ₃	21.55				
CG-1, B-1	Turbine/HRSG and Auxiliary Boilers (8)	NO _x	-	284.70			
		CO (6)	-	127.77			
		CO (7)	-	319.74			
		SO ₂	-	5.54			
		VOC	-	24.80			
		PM ₁₀	-	41.54			
		NH ₃	-	94.40			
CG-2	Turbine/HRSG (8)	NO _x	87.49	265.32	3, 7, 15, 17, 18, 19, 20, 21	7, 15, 17, 18, 19, 20, 21, 30, 31	15, 17, 18, 19, 20, 32, 33
		CO	398.00	773.80			
		SO ₂	28.27	5.72			
		VOC	9.00	35.07			
		PM ₁₀	18.30	72.32			
		NH ₃	26.93	108.80			
		H ₂ SO ₄	1.36	0.88			
CG-3	Turbine/HRSG (8)	NO _x	65.62	176.88	3, 7, 15, 17, 18, 19, 20, 21	7, 15, 17, 18, 19, 20, 21, 30,	15, 17, 18, 19, 20, 32, 33
		CO	398.00	773.80			

Major NSR Summary Table

Permit Number: 37283, PSDTX915, N015					Issuance Date: 04/13/2016		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Spec. Cond.	Spec. Cond.	Spec. Cond.
		SO ₂	28.27	5.72		31	
		VOC	9.00	35.07			
		PM ₁₀	18.30	72.32			
		NH ₃	26.93	108.80			
		H ₂ SO ₄	1.36	0.88			
Turbines and Auxiliary Boilers Planned Maintenance, Startup, and Shutdown Limits (9)							
CG-1	Turbine/HRSG MSS	NO _x	350.00	-	26, 27	24, 25, 26, 27, 30, 31	27
		CO	3200.00	-			
		SO ₂	1.25	-			
		VOC	183.49	-			
		PM ₁₀	9.00	-			
		NH ₃	50.00	-			
B-1	Auxiliary Boilers - MSS (Three auxiliary gas boilers venting through a common stack)	NO _x	42.47	-	26, 27	24, 25, 26, 27, 30, 31	27
		CO	150.00	-			
		SO ₂	0.24	-			
		VOC	7.00	-			
		PM ₁₀	4.67	-			

Major NSR Summary Table

Permit Number: 37283, PSDTX915, N015					Issuance Date: 04/13/2016		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Spec. Cond.	Spec. Cond.	Spec. Cond.
CG-1, B-1	Turbine/HRSG and Auxiliary Boilers MSS (5)	NO _x	392.47				
		CO	3350				
		SO ₂	1.49				
		VOC	190.49				
		PM ₁₀	13.67				
		NH ₃	50.00				
CG-2	Turbine/HRSG - MSS	NO _x	350.00	-	26, 27	24, 25, 26, 27, 30, 31	27
		CO	3200.00	-			
		SO ₂	28.27	-			
		VOC	183.49	-			
		PM ₁₀	18.30	-			
		NH ₃	50.00	-			
		H ₂ SO ₄	1.36	-			
CG-3	Turbine/HRSG - MSS	NO _x	350.00	-	26, 27	24, 25, 26, 27, 30, 31	27
		CO	3200.00	-			
		SO ₂	28.27	-			
		VOC	183.49	-			
		PM ₁₀	18.30	-			

Major NSR Summary Table

Permit Number: 37283, PSDTX915, N015					Issuance Date: 04/13/2016		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)			
		NH ₃	50.00	-			
		H ₂ SO ₄	1.36	-			
Fugitive Sources							
F-1	Fugitives (10) (11)	VOC	0.04	0.19	11	30, 31	
F-2	Fugitives (10) (11)	VOC	0.008	0.034	11	30, 31	
MSSFUG	MSS-Related Fugitives	NO _x	<0.01	<0.01		30, 31	
		CO	<0.01	<0.01			
		VOC	3.52	0.02			
		PM ₁₀ /PM _{2.5}	0.11	0.03			
		NH ₃	2.66	<0.01			

Footnotes:

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) NO_x - total oxides of nitrogen
- CO - carbon monoxide
- SO₂ - sulfur dioxide

VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code §101.1

PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented

PM_{2.5} - total particulate matter equal to or less than 2.5 microns in diameter

NH₃ - ammonia

H₂SO₄ - sulfuric acid

- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
- (5) If the Gas Turbine (EPN CG-1) and any of the auxiliary boilers are fired above 13 MMBtu/hr at the same time, then the combined emissions of the Gas Turbine (EPN CG-1), the auxiliary boilers being fired, and the auxiliary boilers not being fired (above 13 MMBtu/hr) will not exceed the sum of the maximum allowable emissions from EPNs CG-1 and B-1 on a pound per hour or TPY basis.
- (6) Maximum allowable CO emission rate at loads greater than 70 percent of the gas turbine's baseload.
- (7) Maximum allowable CO emission rate at turndown load (which is 40 to 70 percent of the gas turbine's baseload).
- (8) Emission Point Numbers (EPNs) CG-2 and CG-3 underwent Nonattainment New Source Review (NNSR). EPNs CG-1 and B-1 were not subject to NNSR.
- (9) For each pollutant whose emissions during planned MSS activities are measured using a CEMS, the MSS lb/hr limits apply only during each clock hour that includes one or more minutes of MSS activities. During all other clock hours, the normal lb/hr limits apply.
- (10) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission rate.
- (11) The lb/hr and tpy emission limit specified in the MAERT for this facility includes emissions from the facility during both normal operations and planned MSS activities.



Texas Commission on Environmental Quality Air Quality Permit

A Permit Is Hereby Issued To
Pasadena Cogeneration L.P.
Authorizing the Construction and Operation of
Pasadena Cogeneration
Located at Pasadena, Harris County, Texas
Latitude 30° 12' 33" Longitude -95° 18' 9"

Permits: 37283, PSDTX915 and N015

Revision Date: April 13, 2016

Expiration Date: February 16, 2019

A handwritten signature in black ink, appearing to read "R. D. A. Hyle".

For the Commission

- Facilities** covered by this permit shall be constructed and operated as specified in the application for the permit. All representations regarding construction plans and operation procedures contained in the permit application shall be conditions upon which the permit is issued. Variations from these representations shall be unlawful unless the permit holder first makes application to the Texas Commission on Environmental Quality (commission) Executive Director to amend this permit in that regard and such amendment is approved. [Title 30 Texas Administrative Code (TAC) Section 116.116 (30 TAC § 116.116)]¹
- Voiding of Permit.** A permit or permit amendment is automatically void if the holder fails to begin construction within 18 months of the date of issuance, discontinues construction for more than 18 months prior to completion, or fails to complete construction within a reasonable time. Upon request, the executive director may grant an 18-month extension. Before the extension is granted the permit may be subject to revision based on best available control technology, lowest achievable emission rate, and netting or offsets as applicable. One additional extension of up to 18 months may be granted if the permit holder demonstrates that emissions from the facility will comply with all rules and regulations of the commission, the intent of the Texas Clean Air Act (TCAA), including protection of the public's health and physical property; and (b)(1) the permit holder is a party to litigation not of the permit holder's initiation regarding the issuance of the permit; or (b)(2) the permit holder has spent, or committed to spend, at least 10 percent of the estimated total cost of the project up to a maximum of \$5 million. A permit holder granted an extension under subsection (b)(1) of this section may receive one subsequent extension if the permit holder meets the conditions of subsection (b)(2) of this section. [30 TAC § 116.120]
- Construction Progress.** Start of construction, construction interruptions exceeding 45 days, and completion of construction shall be reported to the appropriate regional office of the commission not later than 15 working days after occurrence of the event. [30 TAC § 116.115(b)(2)(A)]
- Start-up Notification.** The appropriate air program regional office shall be notified prior to the commencement of operations of the facilities authorized by the permit in such a manner that a representative of the commission may be present. The permit holder shall provide a separate notification for the commencement of operations for each unit of phased construction, which may involve a series of units commencing operations at different times. Prior to operation of the facilities authorized by the permit, the permit holder shall identify the source or sources of allowances to be utilized for compliance with Chapter 101, Subchapter H, Division 3 of this title (relating to Mass Emissions Cap and Trade Program). [30 TAC § 116.115(b)(2)(B)]
- Sampling Requirements.** If sampling is required, the permit holder shall contact the commission's Office of Compliance and Enforcement prior to sampling to obtain the proper data forms and procedures. All sampling and testing procedures must be approved by the executive director and coordinated with the regional representatives of the commission. The permit holder is also responsible for providing sampling

facilities and conducting the sampling operations or contracting with an independent sampling consultant. [30 TAC § 116.115(b)(2)(C)]

6. **Equivalency of Methods.** The permit holder must demonstrate or otherwise justify the equivalency of emission control methods, sampling or other emission testing methods, and monitoring methods proposed as alternatives to methods indicated in the conditions of the permit. Alternative methods shall be applied for in writing and must be reviewed and approved by the executive director prior to their use in fulfilling any requirements of the permit. [30 TAC § 116.115(b)(2)(D)]
7. **Recordkeeping.** The permit holder shall maintain a copy of the permit along with records containing the information and data sufficient to demonstrate compliance with the permit, including production records and operating hours; keep all required records in a file at the plant site. If, however, the facility normally operates unattended, records shall be maintained at the nearest staffed location within Texas specified in the application; make the records available at the request of personnel from the commission or any air pollution control program having jurisdiction in a timely manner; comply with any additional recordkeeping requirements specified in special conditions in the permit; and retain information in the file for at least two years following the date that the information or data is obtained. [30 TAC § 116.115(b)(2)(E)]
8. **Maximum Allowable Emission Rates.** The total emissions of air contaminants from any of the sources of emissions must not exceed the values stated on the table attached to the permit entitled “Emission Sources--Maximum Allowable Emission Rates.” [30 TAC § 116.115(b)(2)(F)]¹
9. **Maintenance of Emission Control.** The permitted facilities shall not be operated unless all air pollution emission capture and abatement equipment is maintained in good working order and operating properly during normal facility operations. The permit holder shall provide notification in accordance with 30 TAC §101.201, 101.211, and 101.221 of this title (relating to Emissions Event Reporting and Recordkeeping Requirements; Scheduled Maintenance, Startup, and Shutdown Reporting and Recordkeeping Requirements; and Operational Requirements). [30 TAC§ 116.115(b)(2)(G)]
10. **Compliance with Rules.** Acceptance of a permit by an applicant constitutes an acknowledgment and agreement that the permit holder will comply with all rules and orders of the commission issued in conformity with the TCAA and the conditions precedent to the granting of the permit. If more than one state or federal rule or regulation or permit condition is applicable, the most stringent limit or condition shall govern and be the standard by which compliance shall be demonstrated. Acceptance includes consent to the entrance of commission employees and agents into the permitted premises at reasonable times to investigate conditions relating to the emission or concentration of air contaminants, including compliance with the permit. [30 TAC § 116.115(b)(2)(H)]
11. **This** permit may not be transferred, assigned, or conveyed by the holder except as provided by rule. [30 TAC § 116.110(e)]
12. **There** may be additional special conditions attached to a permit upon issuance or modification of the permit. Such conditions in a permit may be more restrictive than the requirements of Title 30 of the Texas Administrative Code. [30 TAC § 116.115(c)]
13. **Emissions** from this facility must not cause or contribute to “air pollution” as defined in Texas Health and Safety Code (THSC) §382.003(3) or violate THSC § 382.085. If the executive director determines that such a condition or violation occurs, the holder shall implement additional abatement measures as necessary to control or prevent the condition or violation.
14. **The** permit holder shall comply with all the requirements of this permit. Emissions that exceed the limits of this permit are not authorized and are violations of this permit.¹

¹ Please be advised that the requirements of this provision of the general conditions may not be applicable to greenhouse gas emissions.

Special Conditions

Permit Numbers 37283, PSDTX915, and N015

Emission Standards and Operating Specifications

1. This permit covers only those sources of emissions listed in the attached table entitled "Emission Sources - Maximum Allowable Emission Rates," and those sources are limited to the emission limits and other conditions specified in the attached table. The annual rates are based on a rolling 12-month period.
2. Fuel for the gas turbines and the auxiliary boilers authorized by this permit is limited to pipeline-quality natural gas containing no more than 5.0 grains total sulfur per 100 dscf. Firing of any other fuel will require authorization from the permitting authority. **(8/03)**
3. Upon request by the Executive Director of the Texas Commission on Environmental Quality (TCEQ) or any air pollution control program having jurisdiction, the holder of this permit shall provide a sample and/or an analysis of the fuel-fired in the gas turbines or shall allow air pollution control agency representatives to obtain a sample for analysis. **(8/03)**
4. Each cogeneration train's normal operating range is from 70 to 100 percent base load except for periods of maintenance, startup, or shutdown (MSS). However, reduced load operation below 70 percent of base load not associated with MSS is authorized to accommodate periods of reduced power and steam demands provided the maximum pounds per hour (lbs/hr) emission rates specified in the attached table entitled "Emission Sources - Maximum Allowable Emissions Rates" are not exceeded. Gas turbine emissions out of each Stack (Emission Point Nos. [EPNs] CG-1, CG-2 or CG-3) shall not exceed the annual average or maximum hourly concentrations per stack in ppmvd as follows: **(12/11)**
 - A. Concentrations of nitrogen oxides (NO_x) from EPN CG-3 shall not exceed 6.0 ppmvd on an annual average basis or 9.0 ppmvd on a maximum hourly basis when corrected to 15 percent oxygen (O₂), without correction to International Standards Organization (ISO) conditions, at any load except during periods of MSS.
 - B. Concentrations of NO_x from EPN CG-2 shall not exceed 9.0 ppmvd on an annual average basis or 12.0 ppmvd on a maximum hourly basis when corrected to 15 percent O₂, without correction to ISO conditions, at any load except during periods of MSS.
 - C. The concentration of nitrogen oxides (NO_x) in the stack gases from EPN CG-1 that exit through the Heat Recovery Steam Generator (HRSG) Stack (EPN CG-1) shall not exceed 12 parts per million by volume (ppmv) at 15 percent O₂ on a dry basis (ppmvd) at any load except during periods of MSS.
 - D. The concentration of carbon monoxide (CO) from each EPN CG-2 or CG-3 shall not exceed 25 ppmvd at 15 percent O₂ when operating at normal operating loads above 75 percent of the turbine base load. The CO concentration shall not exceed 124 ppmvd from each EPN CG-2 or CG-3, when operating below 75

percent of the turbine, when corrected to 15 percent O₂ except during periods of MSS.

- E. The concentration of carbon monoxide (CO) in the stack gases from EPN CG-1 that exit through the heat recovery steam generator (HRSG) Stack shall not exceed 20 ppmvd when operating at normal operating loads above 70 percent of the turbine baseload. The CO concentration shall not exceed 124 ppmvd when operated between 40 and 70 percent of the turbine baseload.
5. The auxiliary boilers shall each be limited to a maximum heat input capacity of 250 million British thermal units per hour (MMBtu/hr), higher heating value (HHV). Emission concentrations from the boilers shall be corrected to 3 percent O₂. **(7/07)**
6. The permit holder may fire any combination of Gas Turbine (EPN CG-1) and auxiliary boilers (if fired above 13 MMBtu/hr), provided the combined emissions from the gas turbine and auxiliary boilers being fired does not exceed the sum of the maximum allowable emissions from EPN CG-1 and B-1 on a pound per hour (lb/hr) or ton per year (TPY) basis. If the gas turbine is out of operation or in the process of being shutdown, any combination of auxiliary boilers may be fired, provided emissions from the boilers alone will not exceed the sum of the maximum allowable emissions from EPN CG-1 and B-1 on a lb/hr or TPY basis. **(4/16)**
7. Opacity of emissions from each stack or vent shall not exceed 5 percent averaged over a six-minute period, except during periods of MSS. The opacity shall not exceed 15 percent averaged over a six-minute period during periods of MSS. Each determination shall be made by observing for visible emissions while each facility is in operation. Observations shall be made at least 15 feet and no more than 0.25 miles from the emission point. If visible emissions are observed from an emission point, then the presence of visible emissions shall be documented for that observation, and corrective action must be taken to eliminate the visible emissions within 24 hours. If the corrective action fails to eliminate the visible emissions within 24 hours of first observing the visible emissions, an opacity reading using Title 40 Code of Federal Regulations Part 60 (40 CFR Part 60), Appendix A, Test Method 9 must be conducted and the results documented. Contributions from uncombined water shall not be included in determining compliance with this condition. Observations shall be performed and recorded quarterly. **(12/11)**

Anhydrous Ammonia (NH₃)

8. Concentrations of NH₃ from EPNs CG-1, CG-2, and CG-3 shall not exceed 10 ppmvd on an annual average or maximum hourly basis when corrected to 15 percent O₂ at any load except during periods of MSS.
9. The permit holder shall maintain a quantity of no more than 12,500 gallons of NH₃ on-site per cogeneration train at any time. Additionally, the permit holder shall maintain prevention and protection measures for the NH₃ storage system as

represented in the permit application which includes (but is not limited to) the following:

- A. The NH₃ storage tank area will be marked and secured so as to protect the NH₃ storage tank from accidents that could cause a rupture.
 - B. A water deluge system shall be installed to cover the tank and loading area to mitigate any airborne releases of NH₃. The water deluge system must activate when a level of 200 parts per million by volume (ppmv) of NH₃ is detected.
10. In the event of a release of the NH₃ from the liquid fill line, pressure vessel due to over pressurization, process line to the selective catalytic reduction (SCR) system or the vapor return lines from the vaporizer, or any other accidental release of NH₃, the permit holder shall follow the mitigation procedures set out in the permit application and follow the contingency plan that will be complete before startup of the plant.
 11. In addition to the requirements of Special Condition Nos. 9 and 10, the permit holder shall maintain the piping and valves in NH₃ service as follows:
 - A. All operating practices and procedures relating to the handling and storage of NH₃ shall conform to the safety recommendations specified for that compound by guidelines of the American National Standards Institute and the Compressed Gas Association.
 - B. Audio, olfactory, and visual checks for NH₃ leaks within the operating area shall be made every 12 hours. If the site is utilizing 12-hour shifts, conducting the checks once per shift is sufficient to meet this condition. **(4/16)**
 - C. No later than one hour following the detection of a leak, plant personnel shall take the following actions:
 - (1) Locate and isolate the leak, if necessary.
 - (2) Commence repair or replacement of the leaking component.
 - (3) Use a leak collection/containment system to control the leak until repair or replacement can be made if immediate repair is not possible.
 12. All necessary plant employees shall undergo proper training in the maintenance, mitigation, and contingency procedures necessary to prevent, control, or handle accidental releases of NH₃.

Nonattainment New Source Review (NNSR) - Emission Reductions

13. The authorization for the constructions of EPNs CG-2 and CG-3 is issued based on the permanent retirement of TCEQ Emission Reduction Credit Certificate (ERCC) Number 1117 for 98.0 tpy of volatile organic compounds (VOC) emissions. This ERCC provides offsets at the rate of 1.3:1.0 for the 75.4 tpy of VOC emissions originally authorized for EPNs CG-2 and CG-3 under this permit. **(2/09)**

14. The NNSR Permit Numbers 37283, PSDTX915, and N015 are issued based on the permanent retirement of TCEQ ERCC Nos. 1220, 1216, and 1293 for 982.0 tpy of NO_x emissions. These ERCCs provide offsets at the rate of 1.3:1.0 for the 755.1 tpy of NO_x emissions authorized by both permits. The 182(f) and nonattainment NO_x offset requirements for both permits have been fulfilled with the submittal of the above listed ERCCs. **(3/00)**

Federal Applicability

15. These facilities shall comply with applicable requirements of the EPA regulations on Standards of Performance for New Stationary Sources, Title 40 Code of Federal Regulations Part 60 (40 CFR Part 60), promulgated for:
 - A. General Conditions, Subpart A.
 - B. The auxiliary boilers are subject to the requirements of Subpart Db, Standards of Performance for Industrial-Commercial Institutional Steam Generating Units.
 - C. The gas turbine is subject to the requirements of Subpart GG, Standards of Performance for Stationary Gas Turbines.

If any condition of this permit is more stringent than the regulations so incorporated, then for the purposes of complying with this permit, the permit shall govern and be the standard by which compliance shall be demonstrated.

Initial Determination of Compliance

The initial compliance testing was completed in September to October of 1999 for EPN CG-1 and in November to December of 2000 for EPNs CG-2 and CG-3. **(12/11)**

16. Sampling ports and platforms shall be incorporated into the design of all exhaust stacks according to the specifications set forth in the attachment entitled "Chapter 2, Stack Sampling Facilities." Alternate sampling facility designs may be submitted for approval by the TCEQ Houston Regional Director.
17. The holder of this permit shall perform stack sampling and other testing as required to establish the actual quantities of air contaminants being emitted into the atmosphere from EPNs CG-1, CG-2, CG-3 and B-1. Sampling shall be conducted in accordance with the appropriate procedures of the TCEQ Sampling Procedures Manual and in accordance with the appropriate EPA RMs 201A and 202 or RM 5, modified to include back-half condensibles, for the concentration of particulate matter less than 10 microns in diameter (PM₁₀) with the allowance for ambient particulates (i.e., subtracting out particulates entering the turbine); RM 8 or RMs 6 or 6c for sulfur dioxide (SO₂); RM 9 for opacity (consisting of 30 six-minute readings as provided in 40 CFR Part 60.11[b]); RM 10 for the concentration of CO; RM 25A, modified to exclude methane and ethane, for the concentration of VOC (to measure

total carbon as propane); and RM 20 for the concentrations of NO_x and O₂ or equivalent methods.

Fuel sampling using the methods and procedures of 40 CFR § 60.335(d) may be conducted in lieu of stack sampling for SO₂. If fuel sampling is used, compliance with 40 CFR Part 60, Subpart GG, SO₂ limits shall be based on 100 percent conversion of the sulfur in the fuel to SO₂. Any deviations from those procedures must be approved by the Executive Director of the TCEQ prior to sampling. The TCEQ Executive Director or designated representative shall be afforded the opportunity to observe all such sampling.

The holder of this permit is responsible for providing sampling and testing facilities and conducting the sampling and testing operations at his expense.

- A. The TCEQ Houston Regional Office shall be contacted as soon as testing is scheduled but not less than 45 days prior to sampling to schedule a pretest meeting.

The notice shall include:

- (1) Date for pretest meeting.
- (2) Date sampling will occur.
- (3) Name of firm conducting sampling.
- (4) Type of sampling equipment to be used.
- (5) Method or procedure to be used in sampling.
- (6) Procedure used to determine turbine loads during and after the sampling period.

The purpose of the pretest meeting is to review the necessary sampling and testing procedures, to provide the proper data forms for recording pertinent data, and to review the format procedures for submitting the test reports. A written proposed description of any deviation from sampling procedures specified in permit conditions or TCEQ or EPA sampling procedures shall be made available to the TCEQ prior to the pretest meeting. The TCEQ Regional Director shall approve or disapprove of any deviation from specified sampling procedures. Requests to waive testing for any pollutant specified in this condition shall be submitted to the TCEQ Office of Air, Air Permits Division. Test waivers and alternate/equivalent procedure proposals for New Source Performance Standards testing which must have the EPA approval shall be submitted to the TCEQ Regional Director.

- B. Air contaminants emitted from each cogeneration train to be tested for include (but are not limited to) NO_x, CO, SO₂, PM₁₀, NH₃, O₂, and opacity. In addition, VOC testing is required for EPNs CG-2 and CG-3. Each gas turbine shall be tested at a minimum of four points in the normal operating range including full load for the atmospheric conditions which exist during testing. The NO_x, CO,

SO₂, PM₁₀, NH₃, O₂, and opacity shall be tested at full load. The NO_x, CO, and O₂ shall be tested at the other three loads in the normal operating range.

- C. Sampling of each gas turbine shall occur within 60 days after achieving the maximum production rate at which each will be operated but no later than 180 days after initial startup of each unit. Additional sampling shall occur as may be required by the TCEQ or EPA. **(8/03)**
- D. Air contaminants emitted from the boiler to be tested for at a maximum firing rate of 250 MMBtu/hr (HHV) include (but are not limited to) NO_x, CO, PM₁₀, VOC, O₂, SO₂, and opacity. Only one of the three identical auxiliary boilers must be tested (instead of all three boilers) to show initial compliance. Stack sampling results from the tested boiler may be used to show compliance for the two boilers not tested.
- E. Within 60 days after the completion of the testing and sampling required herein, two copies of the sampling reports shall be distributed as follows:
 - One copy to the EPA Region 6 Office, Dallas.
 - One copy to the TCEQ Houston Regional Office.

Continuous Determination of Compliance

- 18. The holder of this permit shall install, calibrate, maintain, and operate a continuous emission monitoring system (CEMS) to:
 - A. Measure and record the concentrations of NO_x, CO, and diluent gas (O₂ or carbon dioxide [CO₂]) at the gas turbine exhaust stacks. The NO_x and CO concentrations shall be corrected and reported in accordance with Special Condition No. 4. **(8/07)**
 - B. Measure and record the concentrations of NO_x, CO, and diluent gas (O₂ or CO₂) at the auxiliary boiler exhaust stack. The NO_x and CO concentrations shall be corrected in accordance with Special Condition No. 5. **(2/09)**
 - C. The CEMS shall meet the design and performance specifications, pass the field tests, and meet the installation requirements and the data analysis and reporting requirements specified in the applicable Performance Specification Nos. 1 through 9, 40 CFR Part 60, Appendix B. If there are no applicable performance specifications in 40 CFR Part 60, Appendix B, contact the TCEQ Office of Air, Air Permits Division in Austin for requirements to be met. The CEMS will be required to meet the design and performance specifications, pass the field tests, and meet the installation requirements and data analysis and reporting requirements specified in the applicable performance specifications in 40 CFR Part 75, Appendix A, 40 CFR Part 75 is deemed an acceptable alternative to the performance specifications and quality assurance requirements of 40 CFR Part 60. The CEMS required in Special Condition No. 18A shall comply with the following requirements:

- (1) The system shall be zeroed and spanned daily and corrective action taken when the 24-hour span drift exceeds two times the amounts specified in the applicable Performance Specification Nos. 1 through 9, 40 CFR Part 60, Appendix B, or as specified by the TCEQ if not specified in Appendix B. Zero and span is not required on weekends and plant holidays if instrument technicians are not normally scheduled on those days.
 - (2) Each monitor shall be quality-assured at least quarterly using cylinder gas audits (CGA) in accordance with 40 CFR Part 60, Appendix F, Procedure 1, Section 5.1.2. 40 CFR Part 75 may be considered an acceptable alternative to the certification and quality assurance/quality control standards (CGA) for the NO_x and O₂ CEMS for EPNs CTG1, CTG2, and CTG3. A relative accuracy test audit is required once every four operating quarters, as specified in 40 CFR Part 75. Successive quarterly audits shall occur no closer than two months. **(2/09)**
 - (3) All CGA exceedances of ±15 percent accuracy or 5 ppm, whichever is greater, and any CEMS downtime shall be reported as necessary to the appropriate TCEQ Regional Director, and necessary corrective action shall be taken. Supplemental stack concentration measurements may be required at the discretion of the appropriate TCEQ Regional Director. Compliance with the reporting requirements of 40 CFR Part 60, Subpart A and Special Condition No. 24 will satisfy the requirements of this condition. **(2/09)**
- D. The CEMS required in Special Condition No. 18B shall comply with the following requirements:
- The holder of this permit shall assure that the CEMS meets the applicable quality-assurance requirements specified in 40 CFR Part 60, Appendix F, Procedure 1. Relative accuracy exceedances, as specified in 40 CFR Part 60, Appendix F, Section 5.2.3 and any CEMS downtime shall be reported to the appropriate TCEQ Regional Director; and necessary corrective action shall be taken. Supplemental stack concentration measurements may be required at the discretion of the appropriate TCEQ Regional Director.
- E. The monitoring data shall be reduced to hourly average concentrations at least once every day, using a minimum of four equally-spaced data points from each one-hour period. Two valid data points shall be generated during the hourly period in which zero and span is performed.
- F. All monitoring data and quality-assurance data shall be maintained by the source for a period of two years and shall be made available to the TCEQ Executive Director or designated representative upon request. The data from the CEMS may, at the discretion of the TCEQ, be used to determine compliance with the conditions of this permit.
- G. The appropriate TCEQ Regional Office shall be notified at least 30 days prior to any required RATA in order to provide them the opportunity to observe the testing.

19. The holder of this permit shall additionally install, calibrate, maintain, and operate continuous monitoring systems to monitor and record the average hourly fuel consumption in the gas turbine. The systems shall be accurate to ± 5.0 percent, and the system shall be approved by the TCEQ Executive Director prior to conducting the initial compliance demonstration required by Special Condition No. 17.
20. The NH_3 concentration in each Cogeneration Train's Exhaust Stack (EPNs CG-1, CG-2, and CG-3) shall be tested or calculated according to one of the three methods listed below:
 - A. The holder of this permit may install, calibrate, maintain, and operate a CEMS to measure and record the concentrations NH_3 . The NH_3 concentrations shall be corrected and reported in accordance with Special Condition No. 8.
 - B. If a sorbent tube device specific for NH_3 is used, the frequency of the sorbent tube testing shall be daily for the first 60 days of cogeneration operation, after which, the frequency of the sorbent tube testing may be reduced from daily to weekly after operating procedures have been developed to prevent excess amounts of NH_3 from being introduced in the SCR unit, and when operation of the SCR unit has been proven successful with regard to controlling NH_3 slippage. Daily sorbent tube testing shall resume when the catalyst is within 30 days of its useful life expectancy.
 - C. As an approved alternative to sorbent tube testing, the permit holder may install and operate a second NO_x CEMS probe located between the combustion turbine outlet and the SCR, upstream of the stack NO_x CEMS, which may be used in association with the SCR efficiency and NH_3 injection rate to estimate NH_3 slip. This condition shall not be construed to set a minimum NO_x reduction efficiency on the SCR unit. **(8/03)**
 - D. If the hourly average measured or calculated NH_3 slip concentration exceeds 8 parts per million (ppm) during normal operation, the permit holder shall conduct testing by the Phenol-Nitroprusside Method, the Indophenol Method, or the EPA Conditional Test Method (CTM) 27 on a quarterly basis. These results shall be recorded and used to determine compliance with Special Condition No. 8. This condition does not apply if either of the continuous monitoring methods of 20(A) or 20(C) is used to determine compliance with Special Condition No. 8. **(12/11)**
 - E. Any other method used for measuring NH_3 slippage shall require prior approval from the TCEQ.
21. The holder of this permit shall either measure or develop a program to calculate the total mass flow rate through the HRSG stacks and the boiler stack to ensure continuous compliance with Special Condition No. 1.
 - A. The exhaust emissions from EPNs CG-1, CG-2, CG-3, and B-1 shall be calculated on an hourly basis in lb/hr using the measured or calculated flow

rate and the concentrations of NO_x and CO from the CEMS required in Special Condition No. 18. **(2/09)**

- B. The hourly calculated values will be cumulatively added during each hour of the month and stored in the computer hard drive and on individually stored discs or other TCEQ-accepted computer media. Records of this information will also be available in a form suitable for inspection. **(8/07)**

Maintenance, Startup, and Shutdown

- 22. This permit authorizes the emissions from the planned MSS activities listed in Attachment A, Attachment B, and the MAERT attached to this permit. Attachment A identifies the inherently low emitting (ILE) planned maintenance activities that this permit authorizes to be performed. Attachment B identifies the non-ILE planned maintenance activities that this permit authorizes to be performed. **(12/11)**
- 23. The emission limits that are identified in Special Condition No. 4 do not apply during periods of planned MSS activities. **(12/11)**
- 24. The holder of this permit shall minimize emissions during planned MSS activities by operating the facility and associated air pollution control equipment in accordance with good air pollution control practices, safe operating practices, and protection of the facility. **(12/11)**
- 25. Emissions during planned MSS activities will be minimized by limiting the duration of operation in planned startup and shutdown mode as follows: **(12/11)**
 - A. A planned cold startup (a startup after the steam turbine associated with the gas turbine has been down for a period of 24 hours or more) is limited to 480 minutes per event. The steam turbine is determined to be down when the associated steam turbine generator breaker is in the open state. A planned warm startup (a startup that is not a cold startup) is limited to 180 minutes per event. Startups are defined as follows: **(4/16)**
 - (1) A startup period for EPN CG-1 begins when the Data Acquisition and Handling System (DAHS) records measureable fuel flow to the turbine, and ends when the combustion turbine output reaches 105 MW and the steam turbine output reaches 40 MW.
 - (2) A startup period for EPNs CG-2 and CG-3 begins when the DAHS records measureable fuel flow to the turbine, and ends when three conditions are met: the turbine reaches 105 MW, the associated steam turbine generator breaker is closed, and the reheat bypass valve is closed. **(4/16)**
 - B. A planned shutdown of EPNs CG-1, CG-2, and CG-3 is defined as the period that begins when the gas turbine output drops below 75 MW and ends when the DAHS no longer records measureable fuel flow to the turbine. A planned shutdown for each EGF is limited to 180 minutes per event.

- C. Emissions from combustion turbine optimization activities, as defined in Attachment B, shall be subject to the hourly emission limits for MSS activities from gas turbines listed on the MAERT. The emissions from such activities shall not exceed the hourly emission limits for non-MSS activities for more than eight hours per calendar day.
 - D. Emission from combustion turbine diagnostic load reduction activities, as identified in Attachment B, shall be subject to the hourly MSS emission rates listed on the MAERT and shall not exceed 54 hours per calendar year for all gas turbines combined. **(4/16)**
 - E. A planned startup of the auxiliary boilers with EPN B-1 is defined as the period that begins when the DAHS detects measurable fuel flow to the boiler and ends when the boiler reaches hot standby or the fuel flow at which the boiler will operate. All planned startups for each auxiliary boiler shall be limited to 120 minutes per event.
 - F. A planned shutdown of the auxiliary boilers with EPN B-1 is defined as the period that begins when the boiler drops below the hot standby fuel flow level and ends when no fuel flow is detected. A planned shutdown for each auxiliary boiler shall be limited to 60 minutes per event.
26. Compliance with the emissions limits for planned MSS activities identified in the MAERT attached to this permit shall be demonstrated as follows: **(12/11)**
- A. The permit holder shall annually confirm the continued validity of the estimated potential to emit represented in the permit application for all ILE planned maintenance activities. The total emissions from all ILE planned maintenance activities (see Attachment A) shall be considered to be no more than the estimated potential to emit for those activities that are represented in the permit application.
 - B. For each pollutant emitted during non-ILE planned maintenance activities (see Attachment B) whose emissions are measured using a CEMS, as per Special Condition No. 27(A), the permit holder shall compare the pollutant's short-term (hourly) emissions during planned maintenance activities as measured by the CEMS to the applicable short-term planned MSS emissions limit in the MAERT for each calendar month.
 - C. For each pollutant emitted during non-ILE planned maintenance activities (see Attachment B) whose emissions occur through a stack but are not measured using CEMS as per Special Condition No. 27(A), the permit holder shall determine the total emissions of the pollutant through the stack that result from such non-ILE planned maintenance activities in accordance with Special Condition No. 26(B) for each calendar quarter.
27. The permit holder shall determine the emissions during planned MSS activities for use in Special Condition No. 26 as follows: **(12/11)**

- A. For each pollutant whose emissions during normal facility operations are measured with a CEMS that has been certified to measure the pollutant's emissions over the entire range of a planned MSS activity, the permit holder shall measure the emissions of the pollutant during the planned MSS activity using the CEMS.
 - B. For each pollutant not described in Special Condition No. 27(A), the permit holder shall calculate the pollutant's emissions during all occurrences of each type of planned MSS activity for each calendar month using the frequency of the planned MSS activity identified in work orders or equivalent records and the emissions of the pollutant during the planned MSS activity as represented in the planned MSS permit application. In lieu of using the emissions of the pollutant during the planned MSS activity as represented in the planned MSS permit application to calculate such emissions, the permit holder may determine the emissions of the pollutant during the planned MSS activity using an appropriate method, including but not limited to, any of the methods described in paragraphs 1 through 3 below, provided that the permit holder maintains appropriate records supporting such determination.
 - (1) Use of emission factor(s), facility specific parameter(s), and/or engineering knowledge of the facility's operations;
 - (2) Use of emissions data measured (by a CEMS or during emissions testing) during the same type of planned MSS activity occurring at or on a similar facility, and correlation of that data with the facility's relevant operating parameters, including, but not limited to, electric load, temperature, fuel input, and fuel sulfur content; or
 - (3) Use of emissions testing data collected during a planned MSS activity occurring at or on the facility, and correlation of that data with the facility's relevant operating parameters, including, but not limited to, electric load, temperature, fuel input, and fuel sulfur content.
28. With the exception of the emission limits in the MAERT attached to this permit, the permit conditions relating to planned MSS activities do not become effective until 180 days after issuance of the permit amendment that added such conditions. **(12/11)**
29. The CO and NH₃ mass emissions limits in the MAERT attached to this permit that apply during planned MSS activities constitute alternative case specific specifications for the CO and NH₃ concentration limits in Title 30 Texas Administrative Code (30 TAC) Chapter 117.310(c) during planned MSS activities. **(12/11)**

Recordkeeping Requirements

30. The following records shall be kept at the plant for the life of the permit. All records required in this permit shall be made available at the request of personnel from the TCEQ, EPA, or any air pollution control agency with jurisdiction.

- A. A copy of this permit.
 - B. Permit applications dated March 27, 1996 and December 12, 1997 and subsequent representations submitted to the TCEQ.
 - C. A complete copy of the testing reports and records of the initial performance testing completed pursuant to Special Condition No. 17 to demonstrate initial compliance.
 - D. Stack sampling results or other air emissions testing (other than CEMS data) that may be conducted on units authorized under this permit after the date of issuance of this permit.
31. The following information shall be maintained by the holder of this permit in a form suitable for inspection for a period of five years after collection, and shall be made immediately available upon request to representatives of the TCEQ, EPA, or any local air pollution control program having jurisdiction:
- A. The NO_x, CO, and dilutant gases, O₂ or CO₂, CEMS emissions data from EPNs B-1, CG-1, CG-2 and CG-3 to demonstrate compliance with the emission rates listed in the maximum allowable emission rates table (MAERT);
 - B. Raw data files of all CEMS data including calibration checks and adjustments and maintenance performed on these systems of devices in a permanent form suitable for inspection;
 - C. Records of the hours of operation and average daily quantity of natural gas-fired in the turbines; **(8/03)**
 - D. Records of fuel sampling conducted pursuant to Special Condition No. 3;
 - E. Records of NH₃ emissions sampling and calculations pursuant to Special Condition No. 20;
 - F. Written records of any accidental releases, spills, or venting of NH₃ and the corrective action taken in accordance with Special Condition No. 10;
 - G. Written records of maintenance performed to any piping and valves in NH₃ service pursuant to Special Condition No. 11;
 - H. Calculations of predicted hourly NO_x and CO emissions from the HRSG exhaust stack when required by Special Condition No. 21; **(2/09)**
 - I. Written records of inspections conducted pursuant to Special Condition No. 11B;
 - J. Records of the number and duration of warm starts and cold starts; **(12/11)**
 - K. Records of opacity observations, in compliance with Special Condition No. 7; **(12/11)**
 - L. Records to demonstrate compliance with Special Condition No. 25; and **(12/11)**

- M. Records of emission calculations and/or emissions data specified in Special Condition No. 26(B), if applicable. **(12/11)**

Reporting

- 32. The holder of this permit shall submit to the TCEQ Houston Regional Office reports as described in 40 CFR § 60.7 in accordance with NSPS requirements. Such reports are required for each emission unit which is required to be continuously monitored pursuant to this permit. In addition to the information specified in 40 CFR § 60.7(c), each report shall contain the hours of operation of the facility and a report summary of the periods of noncomplying emissions and CEMS downtimes by cause. Additionally, the report shall contain the duration, cause, and corrective action taken for any accidental release of NH₃. **(2/06)**
- 33. If the average NO_x or NH₃ stack outlet concentration exceeds permitted concentrations identified in Special Condition No. 4 or 8 for more than one hour, the holder of this permit shall investigate and determine the reason for the exceedance and, if needed, make necessary repairs to the SCR unit and/or its associated equipment as soon as possible. The holder of this permit will take appropriate steps, as necessary, to ensure the SCR unit is operating in compliance until repairs can be made. **(8/07)**

Auxiliary Boiler Tube Replacement - Recordkeeping

- 34. The boiler tube replacements in the auxiliary boilers (EPN B1), authorized by the alteration dated September 28, 2010, was determined not to be subject to major new source review by identifying projected actual emission rates for the facilities potentially affected by the project identified in the alteration. Actual emissions from those facilities shall be monitored, recorded and reports made in accordance with 30 TAC § 116.121 for the period specified in 30 TAC § 116.121(b)(1). **(10/10)**

General Requirements

35. The following facilities are authorized by permits by rule under 30 TAC Chapter 106.
(12/11)

Facilities	Authorization
Water and Wastewater Treatment	§ 106.532
Brazing, Soldering, and Welding Equipment	§ 106.227
Outdoor Abrasive Blasting	§ 106.452
Solvent Cleaning, Parts Degreaser	§ 106.454
Portable Small Engines > 12 months	§ 106.511
Emergency Engines	§ 106.511
Emergency Engines	§ 106.263
Routine Maintenance, Startup, and Shutdown of Facilities and Temporary Maintenance Facilities	§ 106.263
Anhydrous Ammonia Storage	§ 106.477
Organic and Inorganic Liquid Loading and Unloading	§ 106.472

Date: April 13, 2016

Attachment A

Permit Numbers 37283, PSDTX915, and N015

Inherently Low Emitting Planned Maintenance Activities

Planned Maintenance Activity	Emissions						
	NO _x	CO	SO ₂	PM	Opacity	VOC	NH ₃
Gaseous fuel venting ¹						x	
Turbine Washing, Unit On-Line ²				x			
Air Intake Filter Maintenance				x	x		
Annual Catalyst Handling and Maintenance ³				x			
Boiler Tube Cleaning						x	
CEMS Calibration	x	x					
Analytical Equipment and Process Instruments						x	
Small Equipment Maintenance - Natural Gas ⁴						x	
Small Equipment Maintenance - High Vapor Pressure VOC ⁴						x	
Small Equipment Maintenance - Low Vapor Pressure VOC ⁴						x	
Small Equipment Maintenance - NH ₃ ⁴							x

Notes:

1. Includes, but is not limited to, venting prior to pipeline pigging and meter proving
2. Involves use of water only
3. Includes, but is not limited to, replacement, cleaning, activation, and deactivation of SCR.
4. Includes, but is not limited to, (i) repair/replacement of pumps, compressors, valves, pipes, flanges, transport lines, filters and screens in natural gas, fuel oil, diesel oil, ammonia, and lube oil service and (ii) vehicle and mobile equipment maintenance which may involve small VOC emissions, such as oil changes, transmission service, and hydraulic system service

Date: December 12, 2011

Attachment B

Permit Numbers 37283, PSDTX915, and N015

Non-Inherently Low Emitting Planned Maintenance Activities

Planned Maintenance Activity	Emissions					
	VOC	NO _x	CO	PM	SO ₂	NH ₃
Combustion Turbine Optimization ^{1, 2}	x	x	x	x		x
SCR Maintenance, Unit On-Line		x				x
Auxiliary Boiler Optimization	x	x	x			
Diagnostic Load Reduction Activities ^{2,3}	x	x	x	x	x	

Notes:

1. Includes, but is not limited to, (i) leak and operability checks (e.g., turbine over-speed tests, troubleshooting), (ii) balancing, and (iii) tuning activities that occur during seasonal tuning or after the completion of initial construction, a combustor change-out, a major repair, maintenance to a combustor, or other similar circumstances.
2. Hourly emissions from these activities will be subject to the hourly emission limit for MSS activities from gas turbines listed on the MAERT.
3. Includes, but is not limited to combustion turbine load reductions (runbacks) associated with: initiation of steam turbine operation, low load steam turbine operation, variability in water or fuel supply, electric generator protection, and variation in turbine operations (which includes but is not limited to, combustor flashback, primary combustion zone re-ignition, or combustion exhaust blade path spread).

Date: April 13, 2016

Emission Sources - Maximum Allowable Emission Rates

Permit Numbers 37283, PSDTX915, and N015

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
Turbines and Auxiliary Boilers Normal Operation Limits				
CG-1	Turbine/HRSG	NO _x	56.51	---
		CO (6)	36.00	---
		CO (7)	317.00	---
		SO ₂	1.25	---
		VOC	5.80	---
		PM ₁₀	9.00	---
		NH ₃	21.55	---
B-1	Auxiliary Boilers (Three auxiliary gas boilers venting through a common stack)	NO _x	42.47	---
		CO	25.85	---
		SO ₂	0.24	---
		VOC	5.83	---
		PM ₁₀	4.67	---
CG-1, B-1	Turbine/HRSG and Auxiliary Boilers (5)(8)	NO _x	98.98	---
		CO (6)	61.85	---
		CO (7)	342.85	---
		SO ₂	1.49	---
		VOC	11.64	---
		PM ₁₀	13.67	---
		NH ₃	21.55	---

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
CG-1, B-1	Turbine/HRSG and Auxiliary Boilers (8)	NO _x	---	284.70
		CO (6)	---	127.77
		CO (7)	---	319.74
		SO ₂	---	5.54
		VOC	---	24.80
		PM ₁₀	---	41.54
		NH ₃	---	94.40
CG-2	Turbine/HRSG (8)	NO _x	87.49	265.32
		CO	398.00	773.80
		SO ₂	28.27	5.72
		VOC	9.00	35.07
		PM ₁₀	18.30	72.32
		NH ₃	26.93	108.80
		H ₂ SO ₄	1.36	0.88
CG-3	Turbine/HRSG (8)	NO _x	65.62	176.88
		CO	398.00	773.80
		SO ₂	28.27	5.72
		VOC	9.00	35.07
		PM ₁₀	18.30	72.32
		NH ₃	26.93	108.80
		H ₂ SO ₄	1.36	0.88
Turbines and Auxiliary Boilers Planned Maintenance, Startup, and Shutdown Limits (9)				
CG-1	Turbine/HRSG MSS	NO _x	350.00	---

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
		CO	3200.00	---
		SO ₂	1.25	---
		VOC	183.49	---
		PM ₁₀	9.00	---
		NH ₃	50.00	---
B-1	Auxiliary Boilers - MSS (Three auxiliary gas boilers venting through a common stack)	NO _x	42.47	---
		CO	150.00	---
		SO ₂	0.24	---
		VOC	7.00	---
		PM ₁₀	4.67	---
CG-1, B-1	Turbine/HRSG and Auxiliary Boilers MSS(5)	NO _x	392.47	---
		CO	3350	---
		SO ₂	1.49	---
		VOC	190.49	---
		PM ₁₀	13.67	---
		NH ₃	50.00	---
CG-2	Turbine/HRSG - MSS	NO _x	350.00	---
		CO	3200.00	---
		SO ₂	28.27	---
		VOC	183.49	---
		PM ₁₀	18.30	---
		NH ₃	50.00	---
		H ₂ SO ₄	1.36	---

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
CG-3	Turbine/HRSG - MSS	NO _x	350.00	---
		CO	3200.00	---
		SO ₂	28.27	---
		VOC	183.49	---
		PM ₁₀	18.30	---
		NH ₃	50.00	---
		H ₂ SO ₄	1.36	---
Fugitive Sources				
F-1	Fugitives (10) (11)	VOC	0.04	0.19
F-2	Fugitives (10) (11)	VOC	0.008	0.034
MSSFUG	MSS-Related Fugitives	NO _x	<0.01	<0.01
		CO	<0.01	<0.01
		VOC	3.52	0.02
		PM ₁₀ /PM _{2.5}	0.11	0.03
		NH ₃	2.66	<0.01

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) NO_x - total oxides of nitrogen
 CO - carbon monoxide
 SO₂ - sulfur dioxide
 VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1SO₂
 PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented
 PM_{2.5} - total particulate matter equal to or less than 2.5 microns in diameter
 NH₃ - ammonia
 H₂SO₄ - sulfuric acid
- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
- (5) If the Gas Turbine (EPN CG-1) and any of the auxiliary boilers are fired above 13 MMBtu/hr at the same time, then the combined emissions of the Gas Turbine (EPN CG-1), the auxiliary boilers being

Emission Sources - Maximum Allowable Emission Rates

fired, and the auxiliary boilers not being fired (above 13 MMBtu/hr) will not exceed the sum of the maximum allowable emissions from EPNs CG-1 and B-1 on a pound per hour or TPY basis.

- (6) Maximum allowable CO emission rate at loads greater than 70 percent of the gas turbine's baseload.
- (7) Maximum allowable CO emission rate at turndown load (which is 40 to 70 percent of the gas turbine's baseload).
- (8) Emission Point Numbers (EPNs) CG-2 and CG-3 underwent Nonattainment New Source Review (NNSR). EPNs CG-1 and B-1 were not subject to NNSR.
- (9) For each pollutant whose emissions during planned MSS activities are measured using a CEMS, the MSS lb/hr limits apply only during each clock hour that includes one or more minutes of MSS activities. During all other clock hours, the normal lb/hr limits apply.
- (10) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission rate.
- (11) The lb/hr and tpy emission limit specified in the MAERT for this facility includes emissions from the facility during both normal operations and planned MSS activities.

Date: April 13, 2016