FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
Equistar Chemicals, LP

AUTHORIZING THE OPERATION OF
Equistar Chemicals Channelview Complex
Equistar Channelview Facility
Petrochemical Manufacturing

LOCATED AT
Harris County, Texas
Latitude 29° 49' 52" Longitude 95° 7' 32"
Regulated Entity Number: RN100542281

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: O1426 Issuance Date: November 16, 2016

For the Commission

Table of Contents

Section **Page**

General Terms and Conditions 1

Special Terms and Conditions: 1
- Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting 1
- Additional Monitoring Requirements 17
- New Source Review Authorization Requirements 18
- Compliance Requirements 19
- Risk Management Plan 21
- Protection of Stratospheric Ozone 21
- Alternative Requirements 21
- Permit Location 21
- Permit Shield (30 TAC § 122.148) 22

Attachments 23
- Applicable Requirements Summary 24
- Additional Monitoring Requirements 584
- Permit Shield 630
- New Source Review Authorization References 657
- Schedules 701
- Alternative Requirement 703

Appendix A 714
- Acronym List 715

Appendix B 716

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:

    A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.

    B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.

    C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.

    D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.

    E. Emission units subject to 40 CFR Part 63, Subparts A, F, G, H, Y, YY, and FFFF as identified in the attached Applicable Requirements Summary table are subject to

30 TAC Chapter 113, Subchapter C, §113.100, §113.110, §113.120, §113.130, §113.300, §113.560, and §113.890 respectively, which incorporates the 40 CFR Part 63 Subpart by reference.

F. Emission units subject to 40 CFR Part 63, Subpart DDDDD as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1130 which incorporates the 40 CFR Part 63 Subpart by reference.

G. Emission units subject to 40 CFR Part 63, Subpart ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.

H. For the purpose of generating emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 1 (Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:

(i) Title 30 TAC § 101.302 (relating to General Provisions)

(ii) Title 30 TAC § 101.303 (relating to Emission Reduction Credit Generation Certification)

(iii) Title 30 TAC § 101.304 (relating to Mobile Emission Reduction Credit Generation and Certification)

(iv) Title 30 TAC § 101.309 (relating to Emission Credit Banking and Trading)

(v) The terms and conditions by which the emission limits are established to generate the reduction credit are applicable requirements of this permit

I. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 3 (Mass Emission Cap and Trade Program) Requirements:

(i) Title 30 TAC § 101.352 (relating to General Provisions)

(ii) Title 30 TAC § 101.353 (relating to Allocation of Allowances)

(iii) Title 30 TAC § 101.354 (relating to Allowance Deductions)

(iv) Title 30 TAC § 101.356 (relating to Allowance Banking and Trading)

(v) Title 30 TAC § 101.358 (relating to Emission Monitoring and Compliance Demonstration)

(vi) Title 30 TAC § 101.359 (relating to Reporting)

(vii) Title 30 TAC § 101.360 (relating to Level of Activity Certification)

(viii) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit

J. For the purpose of generating discrete emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 4 (Discrete Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:

(i) Title 30 TAC § 101.372 (relating to General Provisions)

(ii) Title 30 TAC § 101.373 (relating to Discrete Emission Reduction Credit Generation and Certification)

(iii) Title 30 TAC § 101.374 (relating to Mobile Discrete Emission Reduction Credit Generation and Certification)

(iv) Title 30 TAC § 101.378 (relating to Discrete Emission Credit Banking and Trading)

(v) The terms and conditions by which the emission limits are established to generate the discrete reduction credit are applicable requirements of this permit

K. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 6 (Highly Reactive Volatile Organic Compound Emissions Cap and Trade Program) requirements:

(i) Title 30 TAC § 101.393 (relating to General Provisions)

(ii) Title 30 TAC § 101.394 (relating to Allocation of Allowances)

(iii) Title 30 TAC § 101.396 (relating to Allowance Deductions)

(iv) Title 30 TAC § 101.399 (relating to Allowance Banking and Trading)

(v) Title 30 TAC § 101.400 (relating to Reporting)

(vi) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit

2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):

A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements

B. Title 30 TAC § 101.3 (relating to Circumvention)

C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ

D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ

E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)

F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)

G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)

H. Title 30 TAC § 101.221 (relating to Operational Requirements)

I. Title 30 TAC § 101.222 (relating to Demonstrations)

J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)

3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:

A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:

(i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)

(ii) Title 30 TAC § 111.111(a)(1)(E)

(iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)

(iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the “Applicable Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:

(1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.

(2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.

(3) Records of all observations shall be maintained.

(4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear

view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(5) Compliance Certification:

(a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).

(b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

(c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

(i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)

(ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)

(iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:

(1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.

(2) Records of all observations shall be maintained.

(3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

(a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A)

(b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

C. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

(i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)

(ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)

(iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:

(1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.

(2) Records of all observations shall be maintained.

(3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

(a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)

(b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

D. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.

E. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).

F. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:

(i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)

(ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)

(iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)

G. Outdoor burning, as stated in 30 TAC § 111.201, shall not be authorized unless the following requirements are satisfied:

(i) Title 30 TAC § 111.205 (relating to Exception for Fire Training)

(ii) Title 30 TAC § 111.207 (relating to Exception for Recreation, Ceremony, Cooking, and Warmth)

(iii) Title 30 TAC § 111.219 (relating to General Requirements for Allowable Outdoor Burning)

(iv) Title 30 TAC § 111.221 (relating to Responsibility for Consequences of Outdoor Burning)

4. For storage vessels maintaining working pressure as specified in 30 TAC Chapter 115, Subchapter B, Division 1: Storage of Volatile Organic Compounds, the permit holder shall comply with the requirements of 30 TAC § 115.112(e)(1).

5. For industrial wastewater specified in 30 TAC Chapter 115, Subchapter B, the permit holder shall comply with the following requirements for wastewater drains, junction boxes, lift stations and weirs:

A. Title 30 TAC § 115.142 (relating to Control Requirements)

B. Title 30 TAC § 115.142(1)(A) - (D) (relating to Control Requirements)

C. Title 30 TAC § 115.142(1)(E) and (F) (relating to Control Requirements)

D. Title 30 TAC § 115.145 (relating to Approved Test Methods)

E. Title 30 TAC § 115.146 (relating to Recordkeeping Requirements)

F. Title 30 TAC § 115.147(2) (relating to Exemptions), for streams with an annual VOC loading of 10 megagrams (11.03 tons) or less

G. Title 30 TAC § 115.148 (relating to Determination of Wastewater Characteristics)

6. Permit holder shall comply with the following 30 TAC Chapter 115, Subchapter C requirements:

A. When filling stationary gasoline storage vessels (Stage I) for motor vehicle fuel dispensing facilities specified in 30 TAC Chapter 115, Subchapter C, the permit holder shall comply with the following requirements:

(i) Title 30 TAC § 115.221 (relating to Emission Specifications)

(ii) Title 30 TAC § 115.222 (relating to Control Requirements)

(iii) Title 30 TAC § 115.223 (relating to Alternate Control Requirements)

(iv) Title 30 TAC § 115.224 (relating to Inspection Requirements)

(v) Title 30 TAC § 115.225 (relating to Testing Requirements)

(vi) Title 30 TAC § 115.226 (relating to Recordkeeping Requirements)

B. For filling of motor vehicle fuel tanks (Stage II) at motor vehicle fuel dispensing facilities constructed after May 16, 2012 as specified in 30 TAC Chapter 115, Subchapter C, the permit holder shall comply with the following requirements:

(i) Title 30 TAC § 115.241 (relating to Decommissioning of Stage II Vapor Recovery Equipment)

(ii) Title 30 TAC § 115.242 (relating to Control Requirements)

(iii) Title 30 TAC § 115.243 (relating to Alternate Control Requirements)

(iv) Title 30 TAC § 115.244 (relating to Inspection Requirements)

(v) Title 30 TAC § 115.245 (relating to Testing Requirements)

(vi) Title 30 TAC § 115.246 (relating to Recordkeeping Requirements)

7. The permit holder shall comply with the following requirements of 30 TAC Chapter 115, Subchapter F, Division 3, Degassing of Storage Tanks, Transport Vessels and Marine Vessels:

A. For degassing of stationary VOC storage tanks, the permit holder shall comply with the following requirements:

(i) Title 30 TAC § 115.541(a) - (c) (relating to Emission Specifications)

(ii) Title 30 TAC § 115.541(f) (relating to Emission Specifications), for floating roof storage tanks

(iii) Title 30 TAC § 115.542(a) and (a)(1), (a)(2), (a)(3) or (a)(4) (relating to Control Requirements). Where the requirements of 30 TAC Chapter 115, Subchapter F contain multiple compliance options, the permit holder shall keep records of when each compliance option was used.

(iv) Title 30 TAC § 115.542(b) - (d), (relating to Control Requirements)

(v) Title 30 TAC § 115.543 (relating to Alternate Control Requirements)

(vi) Title 30 TAC § 115.544(a)(1) and (a)(2) (relating to Inspection, Monitoring, and Testing Requirements), for inspections

(vii) Title 30 TAC § 115.544(b) (relating to Inspection, Monitoring, and Testing Requirements), for monitoring

(viii) Title 30 TAC § 115.544(b)(1) and (b)(2) (relating to Inspection, Monitoring, and Testing Requirements), for monitoring of control devices

(ix) Title 30 TAC § 115.544(b)(2)(A) - (J) (relating to Inspection, Monitoring, and Testing Requirements), for monitoring (as appropriate to the control device)

(x) Title 30 TAC § 115.544(b)(3), (b)(4) and (b)(6) (relating to Inspection, Monitoring, and Testing Requirements), for VOC concentration or lower explosive limit threshold monitoring

(xi) Title 30 TAC § 115.544(c), and (c)(1) - (c)(3) (relating to Inspection, Monitoring, and Testing Requirements), for testing of control devices used to comply with 30 TAC § 115.542(a)(1)

(xii) Title 30 TAC § 115.545(1) - (7), (9) - (11) and (13) (relating to Approved Test Methods)

(xiii) Title 30 TAC § 115.546(a), (a)(1) and (a)(3) (relating to Recordkeeping and Notification Requirements), for recordkeeping

(xiv) Title 30 TAC § 115.546(a)(2) and (a)(2)(A) - (J) (relating to Recordkeeping and Notification Requirements), for recordkeeping (as appropriate to the control device)

(xv) Title 30 TAC § 115.546(a)(4) (relating to Recordkeeping and Notification Requirements), for recordkeeping of testing of control devices used to comply with 30 TAC § 115.542(a)(1)

(xvi) Title 30 TAC § 115.546(b) (relating to Recordkeeping and Notification Requirements), for notification

(xvii) Title 30 TAC § 115.547(4) (relating to Exemptions)

8. The permit holder shall comply with the following requirements of 30 TAC Chapter 115, Subchapter H, Division 1 for pressure relief devices not controlled by a flare:

A. Title 30 TAC § 115.725(c)

B. Title 30 TAC § 115.725(c)(1), (c)(1)(A) - (C)

C. Title 30 TAC § 115.725(c)(2)

D. Title 30 TAC § 115.725(c)(3), (c)(3)(A) - (E)

E. Title 30 TAC § 115.725(c)(4)

F. Title 30 TAC § 115.725(l)

G. Title 30 TAC § 115.726(c), (c)(1) - (4)

9. The permit holder shall comply with the requirements of 30 TAC § 115.726(e)(3)(A) for vent streams having no potential to emit HRVOC.

10. The permit holder shall comply with the requirements of 30 TAC § 115.726(e)(3)(A) for vent streams from sources exempt under 30 TAC § 115.727(c)(3).

11. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:

    A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)

    B. Title 40 CFR § 60.8 (relating to Performance Tests)

    C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)

    D. Title 40 CFR § 60.12 (relating to Circumvention)

    E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)

    F. Title 40 CFR § 60.14 (relating to Modification)

    G. Title 40 CFR § 60.15 (relating to Reconstruction)

    H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)

12. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 61, unless otherwise stated in the applicable subpart:

    A. Title 40 CFR § 61.05 (relating to Prohibited Activities)

    B. Title 40 CFR § 61.07 (relating to Application for Approval of Construction or Modification)

    C. Title 40 CFR § 61.09 (relating to Notification of Start-up)

    D. Title 40 CFR § 61.10 (relating to Source Reporting and Request Waiver)

    E. Title 40 CFR § 61.12 (relating to Compliance with Standards and Maintenance Requirements)

    F. Title 40 CFR § 61.13 (relating to Emissions Tests and Waiver of Emission Tests)

    G. Title 40 CFR § 61.14 (relating to Monitoring Requirements)

    H. Title 40 CFR § 61.15 (relating to Modification)

    I. Title 40 CFR § 61.19 (relating to Circumvention)

13. For the benzene transfer operations to and from railcars and tank trucks specified in 40 CFR Part 61, Subpart BB, the permit holder shall comply with the following requirements:

    A. Title 40 CFR § 61.302(d) (relating to Standards)

B. Title 40 CFR § 61.305(g) - (h) (relating to Reporting and Recordkeeping)

14. For the benzene transfer operations to and from marine vessels specified in 40 CFR Part 61, Subpart BB, the permit holder shall comply with the following requirements:

A. Title 40 CFR § 61.302(e) (relating to Standards)

B. Title 40 CFR § 61.303(f) (relating to Monitoring Requirements)

C. Title 40 CFR § 61.304(f) (relating to Test Methods and Procedures)

D. Title 40 CFR § 61.305(g) - (h) (relating to Reporting and Recordkeeping)

15. For facilities where total annual benzene quantity from waste is greater than or equal to 10 megagrams per year and subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:

A. Title 40 CFR § 61.342(c)(1)(i) - (iii) (relating to Standards: General)

B. Title 40 CFR § 61.342(e)(1) (relating to Standards: General)

C. Title 40 CFR § 61.342(e)(2)(i) - (ii) (relating to Standards: General)

D. Title 40 CFR § 61.342(g) (relating to Standards: General)

E. Title 40 CFR § 61.350(a) and (b) (relating to Standards: Delay of Repair)

F. Title 40 CFR § 61.355(a)(1)(iii), (a)(2), (a)(6), (b), and (c)(1) - (3) (relating to Test Methods, Procedures, and Compliance Provisions)

G. Title 40 CFR § 61.355(k)(1) - (6), and (7)(i) - (iv) (relating to Test Methods, Procedures, and Compliance Provisions), for calculation procedures

H. Title 40 CFR § 61.356(a) (relating to Recordkeeping Requirements)

I. Title 40 CFR § 61.356(b), and (b)(1) (relating to Recordkeeping Requirements)

J. Title 40 CFR § 61.356(b)(4) (relating to Recordkeeping Requirements)

K. Title 40 CFR § 61.356(b)(5) (relating to Recordkeeping Requirements)

L. Title 40 CFR § 61.357(a), (d)(1), (d)(2) (d)(6) and (d)(8) (relating to Reporting Requirements)

M. Title 40 CFR § 61.357(d)(5) (relating to Reporting Requirements)

N. Waste generated by remediation activities at these facilities are subject to the requirements identified under 40 CFR § 61.342 for treatment and management of waste

16. For facilities with containers subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:

A. Title 40 CFR § 61.345(a)(1) - (3), (b), and (c) (relating to Standards: Containers)

B. Title 40 CFR § 61.355(h) (relating to Test Methods, Procedures and Compliance Provisions)

C. Title 40 CFR § 61.356(g) (relating to Recordkeeping Requirements)

D. Title 40 CFR § 61.356(h) (relating to Recordkeeping Requirements)

17. For facilities with individual drain systems subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:

A. Title 40 CFR § 61.346(a)(1)(i)(A), (B), (ii), (2), and (3) (relating to Standards: Individual Drain Systems)

B. Title 40 CFR § 61.346(b)(1), (2), (2)(i), (3), (4)(i) - (iv), and (5) (relating to Standards: Individual Drain Systems)

C. Title 40 CFR § 61.346(b)(2)(ii)(A) (relating to Standards: Individual Drain Systems), for junction boxes

D. Title 40 CFR § 61.346(b)(2)(ii)(B) (relating to Standards: Individual Drain Systems), for junction boxes

E. Title 40 CFR § 61.355(h) (relating to Test Methods, Procedures and Compliance Provisions)

F. Title 40 CFR § 61.356(g) (relating to Recordkeeping Requirements)

G. Title 40 CFR § 61.356(h) (relating to Recordkeeping Requirements)

18. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.

19. For the chemical manufacturing process specified in 40 CFR Part 63, Subpart F, the permit holder shall comply with 40 CFR § 63.103(a) (relating to General Compliance, Reporting, and Recordkeeping Provisions) (Title 30 TAC Chapter 113, Subchapter C, § 113.110 incorporated by reference).

20. For the chemical manufacturing facilities subject to provisions in 40 CFR Parts 260 - 272, the permit holder shall comply with the following requirements:

A. Title 40 CFR § 63.110(e)(2)(i) (relating to Applicability), for 40 CFR Part 63, Subpart G applicability to Group 1 or 2 Wastewater Streams

B. Title 40 CFR § 63.110(e)(2)(ii)(A) and (B) (relating to Applicability), for 40 CFR Part 63, Subpart G applicability to Group 1 or 2 Wastewater Streams

21. For the chemical manufacturing facilities with a 40 CFR Part 63, Subpart G Group 1 or Group 2 wastewater streams that are also subject to 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):

A. Title 40 CFR § 63.110(e)(1) (relating to Applicability), for 40 CFR Part 63, Subpart G applicability to Group 1 or 2 Wastewater Streams

22. For the chemical manufacturing facilities with a 40 CFR Part 63, Subpart G Group 2 wastewater stream, the permit holder shall comply with (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):

    A. Title 40 CFR § 63.132(a), (a)(1), and (a)(1)(i) (relating to Process Wastewater Provisions - General)

    B. Title 40 CFR § 63.146(b)(1) (relating to Process Wastewater Provisions - Reporting)

    C. Title 40 CFR § 63.147(b)(8) (relating to Process Wastewater Provisions - Recordkeeping)

23. For the transfer of Group 1 wastewater streams or residuals from Group 1 wastewater streams the permit holder shall comply with the following requirements:

    A. Title 40 CFR § 63.132(g) (relating to Process Wastewater Provisions - General)

    B. Title 40 CFR § 63.152(b)(5) and (c)(4)(iv) (relating to General Reporting and Continuous Records)

24. For the chemical manufacturing facilities subject to leak detection requirements in 40 CFR Part 63, Subpart G, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):

    A. General Leak Detection Requirements:

        (i) Title 40 CFR § 63.148(d)(1) - (3), and (e) (relating to Leak Inspection Provisions)

        (ii) Title 40 CFR § 63.148(c), (g), (g)(2), (h), and (h)(2) (relating to Leak Inspection Provisions), for monitoring and testing requirements

        (iii) Title 40 CFR §§ 63.148(g)(2), (h)(2), (i)(1) - (2), (i)(4)(i) - (viii), (i)(5), and 63.152(a)(1) - (5), for recordkeeping requirements

        (iv) Title 40 CFR §§ 63.148(j), 63.151(a)(6)(i) - (iii), (b)(1) - (2), (j)(1) - (3), 63.152(a)(1) - (5), (b), (b)(1)(i) - (ii), and (b)(4), for reporting requirements

    B. For closed vent system or vapor collection systems constructed of hard piping:

        (i) Title 40 CFR § 63.148(b)(1)(ii) (relating to Leak Inspection Provisions), for monitoring and testing requirements

        (ii) Title 40 CFR § 63.148(i)(6) (relating to Leak Inspection Provisions), for recordkeeping requirements

    C. For facilities operating flow indicators:

        (i) Title 40 CFR § 63.148(f)(1) (relating to Leak Inspection Provisions), for monitoring and testing requirements

        (ii) Title 40 CFR § 63.148(f)(1), (i)(3)(i) (relating to Leak Inspection Provisions), for recordkeeping requirements

        (iii) Title 40 CFR § 63.148(j)(2) (relating to Leak Inspection Provisions), for reporting requirements

D. For facilities not operating flow indicators:

(i) Title 40 CFR § 63.148(f)(2) (relating to Leak Inspection Provisions), for monitoring and testing requirements

(ii) Title 40 CFR § 63.148(i)(3)(ii) (relating to Leak Inspection Provisions), for recordkeeping requirements

(iii) Title 40 CFR § 63.148(j)(3) (relating to Leak Inspection Provisions), for reporting requirements

25. For the chemical manufacturing facilities subject to transfer operations requirements in 40 CFR Part 63, Subpart G, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):

A. Title 40 CFR § 63.126(e)(1) - (2), and (f) (relating to Transfer Operations Provisions Reference Control Technology)

B. Title 40 CFR § 63.128(f)(1) - (2) (relating to Transfer Operations Provisions - Test Methods and Procedures)

C. Title 40 CFR § 63.130(e) (relating to Transfer Operations Provisions - Periodic Recordkeeping and Reporting)

26. For the chemical manufacturing facilities subject to wastewater operations requirements in 40 CFR Part 63, Subpart G, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):

A. Title 40 CFR § 63.135(a) - (f) (relating to Process Wastewater Provisions - Containers)

B. Title 40 CFR § 63.136(a) (relating to Process Wastewater Provisions - Individual Drain Systems)

C. Title 40 CFR § 63.136(b) - (d) (relating to Process Wastewater Provisions - Individual Drain Systems)

D. Title 40 CFR § 63.136(e) - (g) (relating to Process Wastewater Provisions - Individual Drain Systems)

27. For the operations pertaining to the loading and unloading of marine tank vessels specified in 40 CFR Part 63, Subpart Y, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.300 incorporated by reference):

A. Title 40 CFR § 63.560(c) (relating to Designation of Affected Source), for applicability of the General Provisions of Subpart A

B. Title 40 CFR § 63.563(a)(4) (relating to Compliance and Performance Testing), for vapor tightness requirements of the marine vessels

C. Title 40 CFR § 63.564(a)(1) and (d) (relating to Monitoring Requirements)

D. Title 40 CFR § 63.565(a) (relating to Test Methods and Procedures), for performance testing requirements

E. Title 40 CFR § 63.565(c) (relating to Test Methods and Procedures), for vapor tightness requirements of the marine vessels

F. Title 40 CFR § 63.566 (relating to Construction and Reconstruction)

G. Title 40 CFR § 63.567(a) - (b) and (h) - (i) (relating to Reporting and Recordkeeping Requirements)

28. For transfer of waste from ethylene production facilities subject to 40 CFR Part 63, Subpart YY the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.560 incorporated by reference):

A. Title 40 CFR § 63.1096(a) - (d) (Title 30 TAC Chapter 113, Subchapter C, § 113.550 incorporated by reference)

B. Title 40 CFR § 63.1109(a) and (c)

29. For benzene laden waste streams from ethylene process facilities subject to 40 CFR Part 63, Subpart YY with total annual benzene quantity from the facility of 10 megagrams per year or more the permit holder shall comply with the following requirements as specified in 40 CFR § 63.1095(b)(2) (Title 30 TAC Chapter 113, Subchapter C, § 113.560 incorporated by reference):

A. For facilities with waste managed in containers the permit holder shall comply with the following requirements:

(i) Title 40 CFR § 61.355(h) (relating to Test Methods, Procedures and Compliance Provisions)

(ii) Title 40 CFR § 61.356(g) (relating to Recordkeeping Requirements)

(iii) Title 40 CFR § 61.356(h) (relating to Recordkeeping Requirements)

B. For facilities with waste managed in individual drain systems the permit holder shall comply with the following requirements:

(i) Title 40 CFR § 61.346(a)(1)(i)(A), (B), (ii), (2), and (3) (relating to Standards: Individual Drain Systems)

(ii) Title 40 CFR § 61.346(b)(1), (2), (2)(i), (3), (4)(i) - (iv), and (5) (relating to Standards: Individual Drain Systems)

(iii) Title 40 CFR § 61.346(b)(2)(ii)(A) (relating to Standards: Individual Drain Systems), for junction boxes

(iv) Title 40 CFR § 61.346(b)(2)(ii)(B) (relating to Standards: Individual Drain Systems), for junction boxes

(v) Title 40 CFR § 61.355(h) (relating to Test Methods, Procedures and Compliance Provisions)

(vi) Title 40 CFR § 61.356(g) (relating to Recordkeeping Requirements)

(vii) Title 40 CFR § 61.356(h) (relating to Recordkeeping Requirements)

30. For miscellaneous chemical process facilities subject to maintenance wastewater requirements as specified in 40 CFR § 63.2485, Table 7, the permit holder shall comply with the requirements of 40 CFR § 63.105 (relating to Maintenance Wastewater Requirements) (Title 30 TAC Chapter 113, Subchapter C, § 113.890 incorporated by reference).

31. For the transfer of Group 1 wastewater streams or residuals from Group 1 wastewater streams subject to the requirements in 40 CFR § 63.2485, Table 7 the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.670 incorporated by reference):

    A. Title 40 CFR § 63.132(g) and (g)(1) (relating to Process Wastewater Provisions - General)

    B. Title 40 CFR § 63.132(g)(2) (relating to Process Wastewater Provisions - General)

32. For miscellaneous chemical process facilities with Group 2 wastewater streams subject to wastewater operations requirements in 40 CFR Part 63, Subpart FFFF, the permit holder shall comply with the requirements of 40 CFR § 63.132(a), (a)(1), (a)(1)(i), and (a)(3) as specified in § 63.2485(a) (Title 30 TAC Chapter 113, Subchapter C, § 113.890 incorporated by reference).

33. For the miscellaneous chemical process facilities subject to process wastewater operations requirements as specified in 40 CFR § 63.2485, Table 7, the permit holder shall comply with the following requirements or 40 CFR Part 63, Subpart G (Title 30 TAC Chapter 113, Subchapter C, § 113.890 incorporated by reference).

    A. Title 40 CFR § 63.135(a) - (f) (relating to Process Wastewater Provisions - Container)

    B. Title 40 CFR § 63.136(a) (relating to Process Wastewater Provisions - Individual Drain Systems)

    C. Title 40 CFR § 63.136(b) - (d) (relating to Process Wastewater Provisions - Individual Drain Systems)

    D. Title 40 CFR § 63.136(e) - (g) (relating to Process Wastewater Provisions - Individual Drain Systems)

34. For miscellaneous chemical product process facilities subject to requirements of liquid streams in open systems of 40 CFR § 63.2485, Table 7, the permit holder shall comply with the requirements of 40 CFR § 63.149(a) except as specified in 40 CFR § 63.2485(l) (Title 30 TAC Chapter 113, Subchapter C, § 113.670 incorporated by reference).

Additional Monitoring Requirements

35. Unless otherwise specified, the permit holder shall comply with the compliance assurance monitoring requirements as specified in the attached “CAM Summary” upon issuance of the permit. In addition, the permit holder shall comply with the following:

    A. The permit holder shall comply with the terms and conditions contained in 30 TAC § 122.147 (General Terms and Conditions for Compliance Assurance Monitoring).

    B. The permit holder shall report, consistent with the averaging time identified in the “CAM Summary,” deviations as defined by the deviation limit in the “CAM Summary.” Any monitoring data below a minimum limit or above a maximum limit, that is collected in accordance with the requirements specified in 40 CFR § 64.7(c), shall be reported as a

deviation. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

C. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time specified in the "CAM Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances in order to avoid reporting deviations. All monitoring data shall be collected in accordance with the requirements specified in 40 CFR § 64.7(c).

D. The permit holder shall operate the monitoring, identified in the attached "CAM Summary," in accordance with the provisions of 40 CFR § 64.7.

E. Except for emission units using a CEMS, COMS or PEMS which meets the requirements of 40 CFR § 64.3(d)(2), the permit holder shall conduct a once a month visual, audible, and/or olfactory inspection of the capture system to detect leaking components for any capture system associated with the control device subject to CAM. If the results of the following inspections indicate that the capture system is not working properly, the permit holder shall promptly take necessary corrective actions.

F. The permit holder shall comply with the requirements of 40 CFR § 70.6(a)(3)(ii)(A) and 30 TAC § 122.144(1)(A)-(F) for documentation of all required inspections.

36. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

37. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule, standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:

A. Are incorporated by reference into this permit as applicable requirements

B. Shall be located with this operating permit

C. Are not eligible for a permit shield

38. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.

39. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that is representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).

40. The permit holder shall comply with the following requirements for Air Quality Standard Permits:

    A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit

    B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit

    C. Applicable requirements of 30 TAC § 116.617 for Pollution Control Projects based on the information contained in the registration application.

    D. Requirements of the non-rule Air Quality Standard Permit for Pollution Control Projects

Compliance Requirements

41. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.

42. The permit holder shall adhere to the provisions in the Compliance Schedule attachment of this permit and submit certified progress reports consistent with the schedule established under 30 TAC § 122.132(e)(4)(C) and including the information specified in 30 TAC § 122.142(e)(2). Those emission units listed in the Compliance Schedule attachment shall adhere with the requirements in the Compliance Schedule attachment until operating fully in compliance with the applicable requirements.

43. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:

    A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:

        (i) For sources in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9020:

            (1) Title 30 TAC § 117.9020(2)(A), (C), and (D)

    B. The permit holder shall comply with the Initial Control Plan unit listing requirement in 30 TAC § 117.350(c) and (c)(1).

C. The permit holder shall comply with the requirements of 30 TAC § 117.354 for Final Control Plan Procedures for Attainment Demonstration Emission Specifications and 30 TAC § 117.356 for Revision of Final Control Plan.

44. Use of Emission Credits to comply with applicable requirements:

A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:

(i) Title 30 TAC Chapter 115

(ii) Title 30 TAC Chapter 117

(iii) Offsets for Title 30 TAC Chapter 116

B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:

(i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)

(ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1

(iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)

(iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122

(v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)

45. Use of Discrete Emission Credits to comply with the applicable requirements:

A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:

(i) Title 30 TAC Chapter 115

(ii) Title 30 TAC Chapter 117

(iii) If applicable, offsets for Title 30 TAC Chapter 116

(iv) Temporarily exceed state NSR permit allowables

B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:

(i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)

(ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4

(iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)

(iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122

(v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Risk Management Plan

46. For processes subject to 40 CFR Part 68 and specified in 40 CFR § 68.10, the permit holder shall comply with the requirements of the Accidental Release Prevention Provisions in 40 CFR Part 68. The permit holder shall submit to the appropriate agency either a compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR § 68.10(a), or as part of the compliance certification submitted under this permit, a certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of a risk management plan.

Protection of Stratospheric Ozone

47. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:

    A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.

    B. The permit holder shall comply with 40 CFR Part 82, Subpart H related to Halon Emissions Reduction requirements as specified in 40 CFR § 82.250 - § 82.270 and the applicable Part 82 Appendices.

Alternative Requirements

48. The permit holder shall comply with the approved alternative means of control (AMOC); alternative monitoring, recordkeeping, or reporting requirements; or requirements determined to be equivalent to an otherwise applicable requirement contained in the Alternative Requirements attachment of this permit. Units complying with an approved alternative requirement have reference to the approval in the Applicable Requirements summary listing for the unit. The permit holder shall maintain the original documentation, from the EPA Administrator and TCEQ Executive Director), demonstrating the method or limitation utilized. Documentation shall be maintained and made available in accordance with 30 TAC § 122.144.

Permit Location

49. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

50. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Schedules

Alternative Requirement

Applicable Requirements Summary

Unit Summary **25**

Applicable Requirements Summary **175**

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EALSP4066	Emission Points/Stationary Vents/Process Vents	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
EALSP4066	Emission Points/Stationary Vents/Process Vents	N/A	R5121-1	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
EALTK17	Storage Tanks/Vessels	N/A	R5112-4A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EALTK17	Storage Tanks/Vessels	N/A	R5112-4B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EALTK17	Storage Tanks/Vessels	N/A	R5112-4C	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EALTK17	Storage Tanks/Vessels	N/A	R5112-4D	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EALTK32	Storage Tanks/Vessels	N/A	R5112-2	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EALTK32	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
EALTK33	Storage Tanks/Vessels	N/A	R5112-2	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EALTK33	Storage Tanks/Vessels	N/A	60Kb-1	40 CFR Part 60, Subpart Kb	No changing attributes.
EALTK33	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
EALTK37	Storage Tanks/Vessels	N/A	R5112-8	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EALTK37	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EALTK402	Storage Tanks/Vessels	N/A	R5112-5A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EALTK402	Storage Tanks/Vessels	N/A	R5112-5B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EALTK402	Storage Tanks/Vessels	N/A	R5112-5C	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EALTK402	Storage Tanks/Vessels	N/A	R5112-5D	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EALTK402	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
EALTK7	Storage Tanks/Vessels	N/A	R5112-4A	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EALTK7	Storage Tanks/Vessels	N/A	R5112-4B	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EALTK7	Storage Tanks/Vessels	N/A	R5112-4C	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Other vapor destruction unit
EALTK7	Storage Tanks/Vessels	N/A	R5112-4D	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EALTK7	Storage Tanks/Vessels	N/A	R5112-4E	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EALTK8	Storage Tanks/Vessels	N/A	R5112-4A	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EALTK8	Storage Tanks/Vessels	N/A	R5112-4B	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EALTK8	Storage Tanks/Vessels	N/A	R5112-4C	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Other vapor destruction unit
EALTK8	Storage Tanks/Vessels	N/A	R5112-4D	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EALTK8	Storage Tanks/Vessels	N/A	R5112-4E	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EBGEG6901	SRIC Engines	N/A	R7300-10	30 TAC Chapter 117, Subchapter B	No changing attributes.
EBGEG6901	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EBGTK6902	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EBGTK6904	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EBGTK6905	Storage Tanks/Vessels	N/A	R5112-2	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EBGVC6904	Incinerator	N/A	R7300-9	30 TAC Chapter 117, Subchapter B	No changing attributes.
EC4DM21	Storage Tanks/Vessels	N/A	R5112-1A	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EC4DM21	Storage Tanks/Vessels	N/A	R5112-1B	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EC4DM21	Storage Tanks/Vessels	N/A	R5112-1C	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Other vapor destruction unit
EC4DM21	Storage Tanks/Vessels	N/A	R5112-1D	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EC4DM21	Storage Tanks/Vessels	N/A	R5112-1E	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EC4DM21	Storage Tanks/Vessels	N/A	63G-1B	40 CFR Part 63, Subpart G	Emission Control Type = Closed vent system (CVS) and control device (fixed roof), Control Device Type = Flare

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EC4DM21	Storage Tanks/Vessels	N/A	63G-1C	40 CFR Part 63, Subpart G	Emission Control Type = Emissions routed to a fuel gas system, Hard Piping = The closed vent system is constructed of hard piping.
EC4DM21	Storage Tanks/Vessels	N/A	63G-1D	40 CFR Part 63, Subpart G	Emission Control Type = Closed vent system (CVS) and control device (fixed roof), Control Device Type = Flare
EC4DM21	Storage Tanks/Vessels	N/A	63G-1E	40 CFR Part 63, Subpart G	Emission Control Type = Closed vent system (CVS) and control device (fixed roof), Control Device Type = Flare
EC4DM3075	Storage Tanks/Vessels	N/A	R5112-2A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC4DM3075	Storage Tanks/Vessels	N/A	R5112-2B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC4DM3075	Storage Tanks/Vessels	N/A	R5112-2C	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC4DM3075	Storage Tanks/Vessels	N/A	R5112-2D	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC4DM3075	Storage Tanks/Vessels	N/A	63G-1A	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa)
EC4DM3075	Storage Tanks/Vessels	N/A	63G-1B	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa)
EC4DM3075	Storage Tanks/Vessels	N/A	63G-1C	40 CFR Part 63, Subpart	Maximum TVP = Maximum true

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				G	vapor pressure of the total organic HAP in the liquid is greater than or equal to 11.11 psi (76.6 kPa)
EC4DM3075	Storage Tanks/Vessels	N/A	63G-1D	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is greater than or equal to 11.11 psi (76.6 kPa)
EC4DM3075	Storage Tanks/Vessels	N/A	63G-1E	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa)
EC4DM3075	Storage Tanks/Vessels	N/A	63G-1F	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is greater than or equal to 11.11 psi (76.6 kPa)
EC4DM3075	Storage Tanks/Vessels	N/A	63G-1G	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa)
EC4DM3075	Storage Tanks/Vessels	N/A	63G-1H	40 CFR Part 63, Subpart G	Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is greater than or equal to 11.11 psi (76.6 kPa)
EC4DM59	Storage Tanks/Vessels	N/A	R5112-10A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC4DM59	Storage Tanks/Vessels	N/A	R5112-10B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EC4DM59	Storage Tanks/Vessels	N/A	63G-10A	40 CFR Part 63, Subpart G	No changing attributes.
EC4DM59	Storage Tanks/Vessels	N/A	63G-10B	40 CFR Part 63, Subpart G	No changing attributes.
EC4DM59	Storage Tanks/Vessels	N/A	63G-10C	40 CFR Part 63, Subpart G	No changing attributes.
EC4DM59	Storage Tanks/Vessels	N/A	63G-10D	40 CFR Part 63, Subpart G	No changing attributes.
EC4HT1202	Emission Points/Stationary Vents/Process Vents	N/A	R1111-6	30 TAC Chapter 111, Visible Emissions	No changing attributes.
EC4HT1203	Process Heaters/Furnaces	N/A	R7ICI-17	30 TAC Chapter 117, Subchapter B	No changing attributes.
EC4HT1203	Process Heaters/Furnaces	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
EC4HT302	Process Heaters/Furnaces	N/A	R7300-2	30 TAC Chapter 117, Subchapter B	No changing attributes.
EC4HT302	Process Heaters/Furnaces	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
EC4LTMISC1	Loading/Unloading Operations	N/A	R5211-25	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EC4LTMISC1	Loading/Unloading Operations	N/A	R5211-25A	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
EC4LTMISC1	Loading/Unloading Operations	N/A	R5211-25B	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = No control device., Control Options = Pressurized loading system., Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
EC4LTMISC1	Loading/Unloading Operations	N/A	R5211-25C	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
EC4LTMISC1	Loading/Unloading Operations	N/A	R5211-25D	30 TAC Chapter 115, Loading and Unloading of	Chapter 115 Control Device Type = Vapor control system

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				VOC	with a flare., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
EC4LTMISC1	Loading/Unloading Operations	N/A	R5211-25E	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = No control device., Control Options = Pressurized loading system., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
EC4LTMISC2	Loading/Unloading Operations	N/A	R5211-26	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
EC4LTMISC2	Loading/Unloading Operations	N/A	R5211-26A	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare., Control Options = Vapor control system that

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					maintains a control efficiency of at least 90%., Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
EC4LTMISC2	Loading/Unloading Operations	N/A	R5211-26B	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = No control device., Control Options = Pressurized loading system., Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
EC4LTMISC2	Loading/Unloading Operations	N/A	R5211-26C	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
EC4LTMISC2	Loading/Unloading Operations	N/A	R5211-26D	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
EC4LTMISC2	Loading/Unloading Operations	N/A	R5211-26E	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = No control device., Control Options = Pressurized loading system., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
EC4RX1208	Emission Points/Stationary Vents/Process Vents	N/A	R5720-2	30 TAC Chapter 115, HRVOC Vent Gas	Vent Gas Stream Control = Vent gas stream is controlled by a flare.
EC4RX1208	Emission Points/Stationary Vents/Process Vents	N/A	R5720-4	30 TAC Chapter 115, HRVOC Vent Gas	Vent Gas Stream Control = Vent gas stream is controlled by a control device other than a flare.
EC4RX1208	Emission Points/Stationary Vents/Process Vents	N/A	R5121-1	30 TAC Chapter 115, Vent Gas Controls	Control Device Type = Vapor combustor not considered to be a flare.
EC4RX1208	Emission Points/Stationary Vents/Process Vents	N/A	R5121-2	30 TAC Chapter 115, Vent Gas Controls	Control Device Type = Vapor combustor not considered to be a flare.
EC4RX1208	Emission Points/Stationary Vents/Process Vents	N/A	R5121-4	30 TAC Chapter 115, Vent Gas Controls	Control Device Type = Smokeless flare
EC4TK3941	Storage Tanks/Vessels	N/A	R5112-10A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EC4TK3941	Storage Tanks/Vessels	N/A	R5112-10B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC4TK3941	Storage Tanks/Vessels	N/A	63G-5A	40 CFR Part 63, Subpart G	No changing attributes.
EC4TK3941	Storage Tanks/Vessels	N/A	63G-5B	40 CFR Part 63, Subpart G	No changing attributes.
EC4TK3942	Storage Tanks/Vessels	N/A	R5112-10A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC4TK3942	Storage Tanks/Vessels	N/A	R5112-10B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC4TK3942	Storage Tanks/Vessels	N/A	63G-5A	40 CFR Part 63, Subpart G	No changing attributes.
EC4TK3942	Storage Tanks/Vessels	N/A	63G-5B	40 CFR Part 63, Subpart G	No changing attributes.
EC4TO	Emission Points/Stationary Vents/Process Vents	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
EC5DM56	Storage Tanks/Vessels	N/A	R5112-1A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC5DM56	Storage Tanks/Vessels	N/A	R5112-1B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC5SP334	Emission Points/Stationary Vents/Process Vents	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
EC5SP334	Emission Points/Stationary Vents/Process Vents	N/A	R5122-1	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
EC5SP349	Emission Points/Stationary	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	Vents/Process Vents				
EC5SP349	Emission Points/Stationary Vents/Process Vents	N/A	R5122-1	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
EC5TK21	Storage Tanks/Vessels	N/A	R5112-2A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC5TK21	Storage Tanks/Vessels	N/A	R5112-2B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC5TK27	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC5TK30	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC5TK31	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC5TK3116	Storage Tanks/Vessels	N/A	R5112-3	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC5TK317	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EC5TK36	Storage Tanks/Vessels	N/A	R5112-5	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia
EC5TK36	Storage Tanks/Vessels	N/A	R5112-5B	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.0 psia but less than 1.5 psia
ECUCT1701A	Industrial Process Cooling Towers	N/A	R5760-7	30 TAC Chapter 115, HRVOC Cooling Towers	No changing attributes.
ECUCT1701B	Industrial Process Cooling Towers	N/A	R5760-8	30 TAC Chapter 115, HRVOC Cooling Towers	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
ECUCT604	Industrial Process Cooling Towers	N/A	R5760-1	30 TAC Chapter 115, HRVOC Cooling Towers	No changing attributes.
ECULR1C4	Loading/Unloading Operations	N/A	R5211-2A	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare.
ECULR1C4	Loading/Unloading Operations	N/A	R5211-2B	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare.
ECULR1C4	Loading/Unloading Operations	N/A	R5211-2C	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Control device other than a flare, vapor combustor, catalytic incinerator, direct flame incinerator, chiller, or carbon adsorption system.
ECULR1C4	Loading/Unloading Operations	N/A	63G-2	40 CFR Part 63, Subpart G	No changing attributes.
ECULR1CBD	Loading/Unloading Operations	N/A	R5211-3A	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare.
ECULR1CBD	Loading/Unloading Operations	N/A	R5211-3B	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare.
ECULR1CBD	Loading/Unloading Operations	N/A	R5211-3C	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Control device other than a flare, vapor combustor, catalytic incinerator, direct flame incinerator, chiller, or carbon adsorption system.
ECULR1CBD	Loading/Unloading Operations	N/A	63G-3	40 CFR Part 63, Subpart G	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
ECULR2C4	Loading/Unloading Operations	N/A	R5211-4A	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare.
ECULR2C4	Loading/Unloading Operations	N/A	R5211-4B	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare.
ECULR2C4	Loading/Unloading Operations	N/A	R5211-4C	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Control device other than a flare, vapor combustor, catalytic incinerator, direct flame incinerator, chiller, or carbon adsorption system.
ECULR2C4	Loading/Unloading Operations	N/A	63G-4	40 CFR Part 63, Subpart G	No changing attributes.
ECULR2CBD	Loading/Unloading Operations	N/A	R5211-5A	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare.
ECULR2CBD	Loading/Unloading Operations	N/A	R5211-5B	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare.
ECULR2CBD	Loading/Unloading Operations	N/A	R5211-5C	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Control device other than a flare, vapor combustor, catalytic incinerator, direct flame incinerator, chiller, or carbon adsorption system.
ECULR2CBD	Loading/Unloading Operations	N/A	63G-5	40 CFR Part 63, Subpart G	No changing attributes.
ECULR2MEOH	Loading/Unloading Operations	N/A	R5211-6	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a chiller., Transfer Type =

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					Loading and unloading., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
ECULR2MEOH	Loading/Unloading Operations	N/A	R5211-7	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare., Transfer Type = Only loading., Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
ECULR2MEOH	Loading/Unloading Operations	N/A	63G-6	40 CFR Part 63, Subpart G	Closed Vent System = Closed vent system is operated and maintained under negative pressure., Control Device = Condenser., Title 40 § 63.128(h) Option = The transfer rack is complying with 40 CFR § 63.128(a) or (b)., Alternate Parameter Monitoring = Approval has not been sought or has not been granted by the EPA Administrator to monitor a parameter other than those specified in 40 CFR § 63.127(a) - (b)., Shared Control Device = The control device is shared between transfer racks and process vents., Multiple Arms =

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					Control device is shared between multiple arms loading simultaneously.
ECULR2MEOH	Loading/Unloading Operations	N/A	63G-7	40 CFR Part 63, Subpart G	Closed Vent System = Closed vent system is subject to § 63.172 of Subpart H., Control Device = Flare.
ECULRACID	Loading/Unloading Operations	N/A	R5211-1A	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
ECULRACID	Loading/Unloading Operations	N/A	R5211-1B	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
ECULRACN	Loading/Unloading Operations	N/A	63G-9	40 CFR Part 63, Subpart G	No changing attributes.
ECULRVOC	Loading/Unloading Operations	N/A	R5211-7A	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control Device Type = Vapor control system with a flare., Transfer Type = Loading and unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					make vapor-tight connections that close automatically when disconnected.
ECULRVOC	Loading/Unloading Operations	N/A	R5211-7B	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control Device Type = Vapor control system with a chiller., Transfer Type = Only loading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
ECULRVOC	Loading/Unloading Operations	N/A	R5211-7C	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure less than 0.5 psia., Transfer Type = Only loading.
ECULRVOC	Loading/Unloading Operations	N/A	R5211-7D	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC §

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control Device Type = Vapor control system with a flare., Transfer Type = Loading and unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
ECULRVOC	Loading/Unloading Operations	N/A	R5211-7E	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control Device Type = Control device other than a flare, vapor combustor, catalytic incinerator, direct flame incinerator, chiller, or carbon adsorption system., Transfer Type = Loading and unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					that close automatically when disconnected.
ECULTC4	Loading/Unloading Operations	N/A	R5211-8A	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare.
ECULTC4	Loading/Unloading Operations	N/A	R5211-8B	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Vapor control system with a flare.
ECULTC4	Loading/Unloading Operations	N/A	R5211-8C	30 TAC Chapter 115, Loading and Unloading of VOC	Chapter 115 Control Device Type = Control device other than a flare, vapor combustor, catalytic incinerator, direct flame incinerator, chiller, or carbon adsorption system.
ECULTC4	Loading/Unloading Operations	N/A	63G-7	40 CFR Part 63, Subpart G	No changing attributes.
ECULTMEOH	Loading/Unloading Operations	N/A	R5211-9A	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure less than 0.5 psia.
ECULTMEOH	Loading/Unloading Operations	N/A	R5211-9B	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control Device Type = Vapor control system with a chiller., Control Options = Vapor control system that maintains a control efficiency of at least 90%.,

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
ECULTMEOH	Loading/Unloading Operations	N/A	R5211-9C	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control Device Type = Vapor control system with a flare., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
ECULTMEOH	Loading/Unloading Operations	N/A	63G-8	40 CFR Part 63, Subpart G	Control Device = Condenser., Shared Control Device = The control device is shared between transfer racks and process vents., Multiple Arms = Control device is shared between multiple arms loading simultaneously.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
ECULTMEOH	Loading/Unloading Operations	N/A	63G-8A	40 CFR Part 63, Subpart G	Control Device = Flare.
ECULTNOHAP	Loading/Unloading Operations	N/A	R5211-10A	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control Device Type = Vapor control system with a flare., Transfer Type = Loading and unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
ECULTNOHAP	Loading/Unloading Operations	N/A	R5211-10B	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure less than 0.5 psia., Transfer Type = Only loading.
ECULTNOHAP	Loading/Unloading Operations	N/A	R5211-10C	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					not utilized., Chapter 115 Control Device Type = Vapor control system with a flare., Transfer Type = Loading and unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
ECULTNOHAP	Loading/Unloading Operations	N/A	R5211-10D	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control Device Type = Control device other than a flare, vapor combustor, catalytic incinerator, direct flame incinerator, chiller, or carbon adsorption system., Transfer Type = Loading and unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					disconnected.
ECULTVOC	Loading/Unloading Operations	N/A	R5211-11A	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control Device Type = Vapor control system with a flare., Transfer Type = Loading and unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
ECULTVOC	Loading/Unloading Operations	N/A	R5211-11B	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure less than 0.5 psia., Transfer Type = Only loading.
ECULTVOC	Loading/Unloading Operations	N/A	R5211-11C	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					Control Device Type = Vapor control system with a chiller., Transfer Type = Loading and unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
ECULTVOC	Loading/Unloading Operations	N/A	R5211-11D	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control Device Type = Vapor control system with a flare., Transfer Type = Loading and unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
ECULTVOC	Loading/Unloading Operations	N/A	R5211-11E	30 TAC Chapter 115, Loading and Unloading of	True Vapor Pressure = True vapor pressure greater than or

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				VOC	equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control Device Type = Control device other than a flare, vapor combustor, catalytic incinerator, direct flame incinerator, chiller, or carbon adsorption system., Transfer Type = Loading and unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
ECUSUEAPI	Volatile Organic Compound Water Separators	N/A	R5131-2	30 TAC Chapter 115, Water Separation	No changing attributes.
ECUSUWAPI	Volatile Organic Compound Water Separators	N/A	R5131-1	30 TAC Chapter 115, Water Separation	No changing attributes.
EMERFLARE	Flares	N/A	R1111-2	30 TAC Chapter 111, Visible Emissions	No changing attributes.
EMERFLARE	Flares	N/A	60A-1A	40 CFR Part 60, Subpart A	Flare Exit Velocity = Flare exit velocity is less than 60 ft/s (18.3 m/sec)

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EMERFLARE	Flares	N/A	60A-1B	40 CFR Part 60, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is greater than 1000 Btu/scf (37.3 MJ/scm)
EMERFLARE	Flares	N/A	60A-1C	40 CFR Part 60, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is less than or equal to 1000 Btu/scf (37.3 MJ/scm).
EMERFLARE	Flares	N/A	63A-1A	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is less than 60 ft/s (18.3 m/sec)
EMERFLARE	Flares	N/A	63A-1B	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is greater than 1000 Btu/scf (37.3 MJ/scm).
EMERFLARE	Flares	N/A	63A-1C	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is less than or equal to 1000 Btu/scf (37.3 MJ/scm).
EMTTK12	Storage Tanks/Vessels	N/A	R5112-3A	30 TAC Chapter 115,	Control Device Type = Flare

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				Storage of VOCs	
EMTTK12	Storage Tanks/Vessels	N/A	R5112-3B	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EMTTK12	Storage Tanks/Vessels	N/A	R5112-3C	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Other vapor destruction unit
EMTTK12	Storage Tanks/Vessels	N/A	R5112-3D	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EMTTK12	Storage Tanks/Vessels	N/A	R5112-3E	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EMTTK18	Storage Tanks/Vessels	N/A	R5112-4A	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EMTTK18	Storage Tanks/Vessels	N/A	R5112-4B	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EMTTK18	Storage Tanks/Vessels	N/A	R5112-4C	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Other vapor destruction unit
EMTTK18	Storage Tanks/Vessels	N/A	R5112-4D	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EMTTK18	Storage Tanks/Vessels	N/A	R5112-4E	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EMTTK19	Storage Tanks/Vessels	N/A	R5112-5A	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EMTTK19	Storage Tanks/Vessels	N/A	R5112-5B	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EMTTK19	Storage Tanks/Vessels	N/A	R5112-5C	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Other vapor destruction unit
EMTTK19	Storage Tanks/Vessels	N/A	R5112-5D	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EMTTK19	Storage Tanks/Vessels	N/A	R5112-5E	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EMTTK26	Storage Tanks/Vessels	N/A	R5112-7	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EMTTK26	Storage Tanks/Vessels	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
EMTTK4	Storage Tanks/Vessels	N/A	R5112-9A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EMTTK4	Storage Tanks/Vessels	N/A	R5112-9B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EMTTK4	Storage Tanks/Vessels	N/A	R5112-9C	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EMTTK4	Storage Tanks/Vessels	N/A	R5112-9D	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EMTTK4	Storage Tanks/Vessels	N/A	63G-9A	40 CFR Part 63, Subpart G	No changing attributes.
EMTTK4	Storage Tanks/Vessels	N/A	63G-9B	40 CFR Part 63, Subpart G	No changing attributes.
EMTTK4	Storage Tanks/Vessels	N/A	63G-9C	40 CFR Part 63, Subpart G	No changing attributes.
EMTTK4	Storage Tanks/Vessels	N/A	63G-9D	40 CFR Part 63, Subpart G	No changing attributes.
EMTTK47	Storage Tanks/Vessels	N/A	R5112-13	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EMTTK47	Storage Tanks/Vessels	N/A	63G-1	40 CFR Part 63, Subpart G	Process Wastewater = The tank receives, manages, or treats process wastewater streams, Wastewater Tank Usage = The wastewater tank is not used for

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					heating wastewater, treating by means of an exothermic reaction, nor are the contents of the tank are sparged., Wastewater Tank Properties = Properties do not qualify for exemption, Emission Control Type = Fixed-roof tank equipped with an internal floating roof that meets the requirements specified in 40 CFR § 63.119(b), New Source = The source is an existing source.
EMTTK47	Storage Tanks/Vessels	N/A	63G-9	40 CFR Part 63, Subpart G	MACT Subpart F/G Applicability = The unit is a Group 1 vessel (as defined in Table 5 for existing sources or Table 6 for new sources of 40 CFR 63, Subpart G)., NESHAP Subpart Y Applicability = The unit is not subject to 40 CFR Part 61, Subpart Y., Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa), Emission Control Type = Internal floating roof, Seal Type = Metallic shoe seal (as defined in 40 CFR § 63.111)
EMTTK5	Storage Tanks/Vessels	N/A	R5112-10A	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EMTTK5	Storage Tanks/Vessels	N/A	R5112-10B	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EMTTK5	Storage Tanks/Vessels	N/A	R5112-10C	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Other vapor destruction unit
EMTTK5	Storage Tanks/Vessels	N/A	R5112-10D	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
EMTTK5	Storage Tanks/Vessels	N/A	R5112-10E	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
ENGADMIN	SRIC Engines	N/A	R7471-6	30 TAC Chapter 117, Subchapter B	No changing attributes.
ENGADMIN	SRIC Engines	N/A	60IIII-1	40 CFR Part 60, Subpart IIII	No changing attributes.
ENGADMIN	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EUTDM01086	Wastewater Units	N/A	R5140-16A	30 TAC Chapter 115, Industrial Wastewater	Wastewater Component Type = A wastewater component that is exempted from the control requirements of 30 TAC § 115.142 because it handles only exempted wastewater streams under 30 TAC § 115.147(2).
EUTDM01086	Wastewater Units	N/A	R5140-16B	30 TAC Chapter 115, Industrial Wastewater	Roof or Seal Type = The wastewater component does not have a floating roof or internal floating roof., Control Devices = Flare., Monitoring Type = The monitoring requirements of 30 TAC §§ 115.144(3)(A) - (H) are being used., Wastewater Component Type = The component is not a wet weather retention basin, exempted by §115.147(2), not a biotreatment

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					unit.
EUTDM01086	Wastewater Units	N/A	R5140-16C	30 TAC Chapter 115, Industrial Wastewater	Roof or Seal Type = The wastewater component does not have a floating roof or internal floating roof., Control Devices = Flare., Monitoring Type = The monitoring requirements of 30 TAC §§ 115.144(3)(A) - (H) are being used., Wastewater Component Type = The component is not a wet weather retention basin, exempted by §115.147(2), not a biotreatment unit.
EUTDM01086	Storage Tanks/Vessels	N/A	60Kb-39A	40 CFR Part 60, Subpart Kb	No changing attributes.
EUTDM01086	Storage Tanks/Vessels	N/A	60Kb-39E	40 CFR Part 60, Subpart Kb	No changing attributes.
EUTDM01086	Storage Tanks/Vessels	N/A	60Kb-39F	40 CFR Part 60, Subpart Kb	No changing attributes.
EUTDM01086	Storage Tanks/Vessels	N/A	61FF-18A	40 CFR Part 61, Subpart FF	No changing attributes.
EUTDM01086	Storage Tanks/Vessels	N/A	61FF-18B	40 CFR Part 61, Subpart FF	No changing attributes.
EUTDM01086	Storage Tanks/Vessels	N/A	63G-28A	40 CFR Part 63, Subpart G	Wastewater Tank Properties = Volume of the wastewater tank is greater than 75m^3 but less than 151m^3 and vapor pressure of liquid stored is less than 13.1 kPa
EUTDM01086	Storage Tanks/Vessels	N/A	63G-28B	40 CFR Part 63, Subpart	Alternate Monitoring Parameters

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				G	= Alternate monitoring parameters for the control device have not been requested or approved., Monitoring Options = Control device is using the monitoring parameters specified in Table 13 of Subpart G., Closed Vent System = Closed vent system is not maintained under negative pressure and is subject to 40 CFR § 63.172, By-pass Lines = Closed vent system has no by-pass lines, Control Device Type = Flare, Wastewater Tank Properties = Properties do not qualify for exemption, Emission Control Type = Fixed roof tank vented through a closed vent system that routes the organic HAP vapors vented from the wastewater tank to a control device, New Source = The source is an existing source., Negative Pressure = The fixed roof and closed vent systems are not operated and maintained under negative pressure., Combination of Control Devices = The vent stream is treated using a single control device.
EUTDM01086	Storage Tanks/Vessels	N/A	63G-28C	40 CFR Part 63, Subpart G	Alternate Monitoring Parameters = Alternate monitoring parameters for the control

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					device have not been requested or approved., Monitoring Options = Control device is using the monitoring parameters specified in Table 13 of Subpart G., Closed Vent System = Closed vent system is not maintained under negative pressure and is subject to 40 CFR § 63.172, By-pass Lines = Closed vent system has no by-pass lines, Control Device Type = Flare, Wastewater Tank Properties = Properties do not qualify for exemption, Emission Control Type = Fixed roof tank vented through a closed vent system that routes the organic HAP vapors vented from the wastewater tank to a control device, New Source = The source is an existing source., Negative Pressure = The fixed roof and closed vent systems are not operated and maintained under negative pressure., Combination of Control Devices = The vent stream is treated using a single control device.
EUTDM0701	Wastewater Units	N/A	R5140-16A	30 TAC Chapter 115, Industrial Wastewater	Wastewater Component Type = A wastewater component that is exempted from the control requirements of 30 TAC § 115.142 because it handles only

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					exempted wastewater streams under 30 TAC § 115.147(2).
EUTDM0701	Wastewater Units	N/A	R5140-16B	30 TAC Chapter 115, Industrial Wastewater	Roof or Seal Type = The wastewater component does not have a floating roof or internal floating roof., Control Devices = Flare., Monitoring Type = The monitoring requirements of 30 TAC §§ 115.144(3)(A) - (H) are being used., Wastewater Component Type = The component is not a wet weather retention basin, exempted by §115.147(2), not a biotreatment unit.
EUTDM0701	Wastewater Units	N/A	R5140-16C	30 TAC Chapter 115, Industrial Wastewater	Roof or Seal Type = The wastewater component does not have a floating roof or internal floating roof., Control Devices = Flare., Monitoring Type = The monitoring requirements of 30 TAC §§ 115.144(3)(A) - (H) are being used., Wastewater Component Type = The component is not a wet weather retention basin, exempted by §115.147(2), not a biotreatment unit.
EUTDM0701	Volatile Organic Compound Water Separators	N/A	61FF-19A	40 CFR Part 61, Subpart FF	No changing attributes.
EUTDM0701	Volatile Organic Compound Water	N/A	61FF-19B	40 CFR Part 61, Subpart FF	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	Separators				
EUTDM0701	Volatile Organic Compound Water Separators	N/A	63G-29A	40 CFR Part 63, Subpart G	No changing attributes.
EUTDM0701	Volatile Organic Compound Water Separators	N/A	63G-29B	40 CFR Part 63, Subpart G	No changing attributes.
EUTDM0801	Wastewater Units	N/A	R5140-16A	30 TAC Chapter 115, Industrial Wastewater	Wastewater Component Type = A wastewater component that is exempted from the control requirements of 30 TAC § 115.142 because it handles only exempted wastewater streams under 30 TAC § 115.147(2).
EUTDM0801	Wastewater Units	N/A	R5140-16B	30 TAC Chapter 115, Industrial Wastewater	Roof or Seal Type = The wastewater component does not have a floating roof or internal floating roof., Control Devices = Flare., Monitoring Type = The monitoring requirements of 30 TAC §§ 115.144(3)(A) - (H) are being used., Wastewater Component Type = The component is not a wet weather retention basin, exempted by §115.147(2), not a biotreatment unit.
EUTDM0801	Wastewater Units	N/A	R5140-16C	30 TAC Chapter 115, Industrial Wastewater	Roof or Seal Type = The wastewater component does not have a floating roof or internal floating roof., Control Devices = Flare., Monitoring Type = The

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					monitoring requirements of 30 TAC §§ 115.144(3)(A) - (H) are being used., Wastewater Component Type = The component is not a wet weather retention basin, exempted by §115.147(2), not a biotreatment unit.
EUTDM0801	Volatile Organic Compound Water Separators	N/A	61FF-19A	40 CFR Part 61, Subpart FF	No changing attributes.
EUTDM0801	Volatile Organic Compound Water Separators	N/A	61FF-19B	40 CFR Part 61, Subpart FF	No changing attributes.
EUTDM0801	Volatile Organic Compound Water Separators	N/A	63G-29A	40 CFR Part 63, Subpart G	No changing attributes.
EUTDM0801	Volatile Organic Compound Water Separators	N/A	63G-29B	40 CFR Part 63, Subpart G	No changing attributes.
EUTDM8801	Wastewater Units	N/A	R5140-16A	30 TAC Chapter 115, Industrial Wastewater	Wastewater Component Type = A wastewater component that is exempted from the control requirements of 30 TAC § 115.142 because it handles only exempted wastewater streams under 30 TAC § 115.147(2).
EUTDM8801	Wastewater Units	N/A	R5140-16B	30 TAC Chapter 115, Industrial Wastewater	Roof or Seal Type = The wastewater component does not have a floating roof or internal floating roof., Control Devices = Flare., Monitoring Type = The

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					monitoring requirements of 30 TAC §§ 115.144(3)(A) - (H) are being used., Wastewater Component Type = The component is not a wet weather retention basin, exempted by §115.147(2), not a biotreatment unit.
EUTDM8801	Wastewater Units	N/A	R5140-16C	30 TAC Chapter 115, Industrial Wastewater	Roof or Seal Type = The wastewater component does not have a floating roof or internal floating roof., Control Devices = Flare., Monitoring Type = The monitoring requirements of 30 TAC §§ 115.144(3)(A) - (H) are being used., Wastewater Component Type = The component is not a wet weather retention basin, exempted by §115.147(2), not a biotreatment unit.
EUTDM8801	Volatile Organic Compound Water Separators	N/A	61FF-19A	40 CFR Part 61, Subpart FF	No changing attributes.
EUTDM8801	Volatile Organic Compound Water Separators	N/A	61FF-19B	40 CFR Part 61, Subpart FF	No changing attributes.
EUTDM8801	Volatile Organic Compound Water Separators	N/A	63G-29A	40 CFR Part 63, Subpart G	No changing attributes.
EUTDM8801	Volatile Organic Compound Water	N/A	63G-29B	40 CFR Part 63, Subpart G	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	Separators				
EUTDM8804	Wastewater Units	N/A	R5140-16A	30 TAC Chapter 115, Industrial Wastewater	Wastewater Component Type = A wastewater component that is exempted from the control requirements of 30 TAC § 115.142 because it handles only exempted wastewater streams under 30 TAC § 115.147(2).
EUTDM8804	Wastewater Units	N/A	R5140-16B	30 TAC Chapter 115, Industrial Wastewater	Roof or Seal Type = The wastewater component does not have a floating roof or internal floating roof., Control Devices = Flare., Monitoring Type = The monitoring requirements of 30 TAC §§ 115.144(3)(A) - (H) are being used., Wastewater Component Type = The component is not a wet weather retention basin, exempted by §115.147(2), not a biotreatment unit.
EUTDM8804	Wastewater Units	N/A	R5140-16C	30 TAC Chapter 115, Industrial Wastewater	Roof or Seal Type = The wastewater component does not have a floating roof or internal floating roof., Control Devices = Flare., Monitoring Type = The monitoring requirements of 30 TAC §§ 115.144(3)(A) - (H) are being used., Wastewater Component Type = The component is not a wet weather retention basin, exempted by §115.147(2), not a biotreatment

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					unit.
EUTDM8804	Volatile Organic Compound Water Separators	N/A	61FF-19A	40 CFR Part 61, Subpart FF	No changing attributes.
EUTDM8804	Volatile Organic Compound Water Separators	N/A	61FF-19B	40 CFR Part 61, Subpart FF	No changing attributes.
EUTDM8804	Volatile Organic Compound Water Separators	N/A	63G-29A	40 CFR Part 63, Subpart G	No changing attributes.
EUTDM8804	Volatile Organic Compound Water Separators	N/A	63G-29B	40 CFR Part 63, Subpart G	No changing attributes.
EUTEN1	SRIC Engines	N/A	R71C1-1	30 TAC Chapter 117, Subchapter B	No changing attributes.
EUTEN1	SRIC Engines	N/A	60IIII-1	40 CFR Part 60, Subpart IIII	No changing attributes.
EUTEN1	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EUTENEOC	SRIC Engines	N/A	R7471-6	30 TAC Chapter 117, Subchapter B	No changing attributes.
EUTENEOC	SRIC Engines	N/A	60IIII-1	40 CFR Part 60, Subpart IIII	No changing attributes.
EUTENEOC	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EUTENEOC	SRIC Engines	N/A	R7471-6	30 TAC Chapter 117, Subchapter B	No changing attributes.
EUTENEOC	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EUTENLAB	SRIC Engines	N/A	R7471-5	30 TAC Chapter 117, Subchapter B	No changing attributes.
EUTENLAB	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EUTENPMDI	SRIC Engines	N/A	R7471-4	30 TAC Chapter 117, Subchapter B	No changing attributes.
EUTENPMDI	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EUTFL1701	Flares	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
EUTFL1701	Flares	N/A	R5720-1	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
EUTFL1701	Flares	N/A	60A-1A	40 CFR Part 60, Subpart A	Flare Exit Velocity = Flare exit velocity is less than 60 ft/s (18.3 m/sec)
EUTFL1701	Flares	N/A	60A-1B	40 CFR Part 60, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is greater than 1000 Btu/scf (37.3 MJ/scm)
EUTFL1701	Flares	N/A	60A-1C	40 CFR Part 60, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is less than or equal to 1000 Btu/scf (37.3 MJ/scm).
EUTFL1701	Flares	N/A	63A-1A	40 CFR Part 63, Subpart	Flare Exit Velocity = Flare exit

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				A	velocity is less than 60 ft/s (18.3 m/sec)
EUTFL1701	Flares	N/A	63A-1B	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is greater than 1000 Btu/scf (37.3 MJ/scm).
EUTFL1701	Flares	N/A	63A-1C	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is less than or equal to 1000 Btu/scf (37.3 MJ/scm).
EUTFL1701V	Emission Points/Stationary Vents/Process Vents	N/A	R5720-1	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
EUTFL1701V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-1	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10., Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
EUTFL1701V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-3	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule.
EUTFL1701V	Emission Points/Stationary Vents/Process Vents	N/A	63FFFF-2	40 CFR Part 63, Subpart FFFF	No changing attributes.
EUTFL1701V	Emission Points/Stationary Vents/Process Vents	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EUTG1110	SRIC Engines	N/A	R7471-10	30 TAC Chapter 117, Subchapter B	No changing attributes.
EUTG1110	SRIC Engines	N/A	60IIII-1	40 CFR Part 60, Subpart IIII	No changing attributes.
EUTG1110	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EUTG1111	SRIC Engines	N/A	R7471-11	30 TAC Chapter 117, Subchapter B	No changing attributes.
EUTG1111	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EUTP3301B	SRIC Engines	N/A	R7471-12	30 TAC Chapter 117, Subchapter B	No changing attributes.
EUTP3301B	SRIC Engines	N/A	60IIII-1	40 CFR Part 60, Subpart IIII	No changing attributes.
EUTP3301B	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EUTP803A	SRIC Engines	N/A	R7471-13	30 TAC Chapter 117, Subchapter B	No changing attributes.
EUTP803A	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EUTP803B	SRIC Engines	N/A	R7471-14	30 TAC Chapter 117, Subchapter B	No changing attributes.
EUTP803B	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EUTTK1101A	Storage Tanks/Vessels	N/A	61FF-1A	40 CFR Part 61, Subpart FF	No changing attributes.
EUTTK1101B	Storage Tanks/Vessels	N/A	61FF-1A	40 CFR Part 61, Subpart FF	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EUTTK88014	Wastewater Units	N/A	R5140-16A	30 TAC Chapter 115, Industrial Wastewater	Wastewater Component Type = A wastewater component that is exempted from the control requirements of 30 TAC § 115.142 because it handles only exempted wastewater streams under 30 TAC § 115.147(2).
EUTTK88014	Wastewater Units	N/A	R5140-16B	30 TAC Chapter 115, Industrial Wastewater	Roof or Seal Type = The wastewater component does not have a floating roof or internal floating roof., Control Devices = Flare., Monitoring Type = The monitoring requirements of 30 TAC §§ 115.144(3)(A) - (H) are being used., Wastewater Component Type = The component is not a wet weather retention basin, exempted by §115.147(2), not a biotreatment unit.
EUTTK88014	Wastewater Units	N/A	R5140-16C	30 TAC Chapter 115, Industrial Wastewater	Roof or Seal Type = The wastewater component does not have a floating roof or internal floating roof., Control Devices = Flare., Monitoring Type = The monitoring requirements of 30 TAC §§ 115.144(3)(A) - (H) are being used., Wastewater Component Type = The component is not a wet weather retention basin, exempted by §115.147(2), not a biotreatment unit.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EUTTK88014	Storage Tanks/Vessels	N/A	60Kb-39A	40 CFR Part 60, Subpart Kb	No changing attributes.
EUTTK88014	Storage Tanks/Vessels	N/A	60Kb-39C	40 CFR Part 60, Subpart Kb	No changing attributes.
EUTTK88014	Storage Tanks/Vessels	N/A	60Kb-39D	40 CFR Part 60, Subpart Kb	No changing attributes.
EUTTK88014	Storage Tanks/Vessels	N/A	61FF-18A	40 CFR Part 61, Subpart FF	No changing attributes.
EUTTK88014	Storage Tanks/Vessels	N/A	61FF-18B	40 CFR Part 61, Subpart FF	No changing attributes.
EUTTK88014	Storage Tanks/Vessels	N/A	63G-28A	40 CFR Part 63, Subpart G	Wastewater Tank Properties = Volume of the wastewater tank greater than or equal to 151m3 and vapor pressure of liquid stored is less than 5.2 kPa
EUTTK88014	Storage Tanks/Vessels	N/A	63G-28B	40 CFR Part 63, Subpart G	Alternate Monitoring Parameters = Alternate monitoring parameters for the control device have not been requested or approved., Monitoring Options = Control device is using the monitoring parameters specified in Table 13 of Subpart G., Closed Vent System = Closed vent system is not maintained under negative pressure and is subject to 40 CFR § 63.172, By-pass Lines = Closed vent system has no by-pass lines, Control Device Type = Flare, Wastewater Tank Properties = Properties do not

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					qualify for exemption, Emission Control Type = Fixed roof tank vented through a closed vent system that routes the organic HAP vapors vented from the wastewater tank to a control device, New Source = The source is an existing source., Negative Pressure = The fixed roof and closed vent systems are not operated and maintained under negative pressure., Combination of Control Devices = The vent stream is treated using a single control device.
EUTTK88014	Storage Tanks/Vessels	N/A	63G-28C	40 CFR Part 63, Subpart G	Alternate Monitoring Parameters = Alternate monitoring parameters for the control device have not been requested or approved., Monitoring Options = Control device is using the monitoring parameters specified in Table 13 of Subpart G., Closed Vent System = Closed vent system is not maintained under negative pressure and is subject to 40 CFR § 63.172, By-pass Lines = Closed vent system has no by-pass lines, Control Device Type = Flare, Wastewater Tank Properties = Properties do not qualify for exemption, Emission Control Type = Fixed roof tank

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					vented through a closed vent system that routes the organic HAP vapors vented from the wastewater tank to a control device, New Source = The source is an existing source., Negative Pressure = The fixed roof and closed vent systems are not operated and maintained under negative pressure., Combination of Control Devices = The vent stream is treated using a single control device.
EUTTW8801	Wastewater Units	N/A	R5140-17A	30 TAC Chapter 115, Industrial Wastewater	Control Devices = Steam stripper.
EUTTW8801	Wastewater Units	N/A	R5140-17B	30 TAC Chapter 115, Industrial Wastewater	Control Devices = Flare.
EUTTW8801	Wastewater Units	N/A	R5140-17C	30 TAC Chapter 115, Industrial Wastewater	Control Devices = Flare.
EUTTW8801	Treatment Process	N/A	63G-30A	40 CFR Part 63, Subpart G	Wastewater Stream Designation = Group1 for Table 9 compounds.
EUTTW8801	Treatment Process	N/A	63G-30B	40 CFR Part 63, Subpart G	Wastewater Stream Designation = Designated as Group 1 per 40 CFR § 63.132(e).
EUTTW8801	Treatment Process	N/A	63G-30C	40 CFR Part 63, Subpart G	Wastewater Stream Designation = Group1 for Table 9 compounds.
EUTTW8801	Treatment Process	N/A	63G-30D	40 CFR Part 63, Subpart G	Wastewater Stream Designation = Designated as Group 1 per 40

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					CFR § 63.132(e).
EUTTW8802	Wastewater Units	N/A	R5140-18A	30 TAC Chapter 115, Industrial Wastewater	Control Devices = Steam stripper.
EUTTW8802	Wastewater Units	N/A	R5140-18B	30 TAC Chapter 115, Industrial Wastewater	Control Devices = Flare.
EUTTW8802	Wastewater Units	N/A	R5140-18C	30 TAC Chapter 115, Industrial Wastewater	Control Devices = Flare.
EUTTW8802	Treatment Process	N/A	63G-30A	40 CFR Part 63, Subpart G	Wastewater Stream Designation = Group1 for Table 9 compounds.
EUTTW8802	Treatment Process	N/A	63G-30B	40 CFR Part 63, Subpart G	Wastewater Stream Designation = Designated as Group 1 per 40 CFR § 63.132(e).
EUTTW8802	Treatment Process	N/A	63G-30C	40 CFR Part 63, Subpart G	Wastewater Stream Designation = Group1 for Table 9 compounds.
EUTTW8802	Treatment Process	N/A	63G-30D	40 CFR Part 63, Subpart G	Wastewater Stream Designation = Designated as Group 1 per 40 CFR § 63.132(e).
FUGITIVES	Fugitive Emission Units	N/A	R5780-ALL	30 TAC Chapter 115, HRVOC Fugitive Emissions	No changing attributes.
FUGITIVES	Fugitive Emission Units	N/A	R5352ALL	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	No changing attributes.
FUGITIVES	Fugitive Emission Units	N/A	60VVALL	40 CFR Part 60, Subpart VV	No changing attributes.
FUGITIVES	Fugitive Emission Units	N/A	61J-ALL	40 CFR Part 61, Subpart J	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
FUGITIVES	Fugitive Emission Units	N/A	61V-ALL	40 CFR Part 61, Subpart V	No changing attributes.
FUGITIVES	Fugitive Emission Units	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
FUGITIVES	Fugitive Emission Units	N/A	63HALL	40 CFR Part 63, Subpart H	
FUGITIVES	Fugitive Emission Units	N/A	63HALL-VNT	40 CFR Part 63, Subpart H	ANY (CLOSED VENT SYSTEMS) = COMPONENT PRESENT, REC/RECAP DEV (CVS) = COMPONENT NOT PRESENT, ENCL COMB DEV (CVS) = COMPONENT NOT PRESENT, FLARES (CVS) = COMPONENT PRESENT, BYPASS LINES = FUGITIVE UNIT WITH A CLOSED-VENT SYSTEM DOES NOT CONTAIN A BY-PASS LINE THAT COULD DIVERT A VENT STREAM AWAY FROM THE CONTROL DEVICE AND TO THE ATMOSPHERE, UNSAFE TO INSPECT = FOR A FUGITIVE UNIT THAT CONTAINS ANY CLOSED-VENT SYSTEM, THERE ARE NO PARTS DESIGNATED AS UNSAFE TO INSPECT, DIFFICULT TO INSPECT = FOR A FUGITIVE UNIT THAT CONTAINS ANY CLOSED-VENT SYSTEM, THERE ARE NO PARTS DESIGNATED AS

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					DIFFICULT TO INSPECT, EQUIPMENT TYPE = FUGITIVE UNIT CONTAINS EQUIPMENT LISTED IN 40 CFR § 63.160(A) WHICH IS OPERATED IN ORGANIC HAZARDOUS AIR POLLUTANT SERVICE, NON R&D/BATCH PROCESSES = FUGITIVE UNIT CONTAINS PROCESSES OTHER THAN RESEARCH AND DEVELOPMENT FACILITIES AND BENCH-SCALE BATCH PROCESSES, VACUUM SERVICE = NOT ALL OF THE EQUIPMENT IN THE FUGITIVE UNIT IS IN VACUUM SERVICE, < 300 OPERATING HOURS = THE FUGITIVE UNIT DOES NOT CONTAIN ANY EQUIPMENT IN ORGANIC HAZARDOUS AIR POLLUTANT (HAP) SERVICE THAT IS INTENDED TO OPERATE LESS THAN 300 HOURS PER CALENDAR YEAR
GRPALZVENT	Emission Points/Stationary Vents/Process Vents	EALPVJ310, EALPVJ402, EC4D3001, EC4PV08040, EC4PV08041, EC4PVJ1205, EC4PVJ1206, EC4PVJ304, EC4PVJ309, EC4PVJ316, EC4PVJ317, EMTPVJ1204, EMTPVJ1207, EMTPVJ1210, EMTPVJ4203, MBTPV4001B, MBTPVJ4001, MBTPVJ4002,	R5720-5	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		OP1PV38055, OP1PVJ3402, OP1PVJ3403, OP1PVJ3404, OP1PVJ3405, OP1PVJ3406, OP1PVJ3409, OP1PVJ3410, OP1PVJ3415, OP1PVJ3501, OP1PVJ3602, OP1PVJ3603, OP1PVJ3604, OP1PVJ3605, OP1PVJ3606, OP1PVJ3904, OP2PV48055, OP2PVJ4301, OP2PVJ4303, OP2PVJ4308, OP2PVJ4402, OP2PVJ4403, OP2PVJ4404, OP2PVJ4405, OP2PVJ4406, OP2PVJ4407, OP2PVJ4408, OP2PVJ4409, OP2PVJ4410, OP2PVJ4415, OP2PVJ4501, OP2PVJ4602, OP2PVJ4603, OP2PVJ4604, OP2PVJ4605, OP2PVJ4606, OP2PVJ4607, OP2PVJ4611, OP2VJ48013			
GRPALZVENT	Emission Points/Stationary Vents/Process Vents	EALPVJ310, EALPVJ402, EC4D3001, EC4PV08040, EC4PV08041, EC4PVJ1205, EC4PVJ1206, EC4PVJ304, EC4PVJ309, EC4PVJ316, EC4PVJ317, EMTPVJ1204, EMTPVJ1207, EMTPVJ1210, EMTPVJ4203, MBTPV4001B, MBTPVJ4001, MBTPVJ4002, OP1PV38055, OP1PVJ3402, OP1PVJ3403, OP1PVJ3404, OP1PVJ3405, OP1PVJ3406, OP1PVJ3409, OP1PVJ3410, OP1PVJ3415, OP1PVJ3501, OP1PVJ3602, OP1PVJ3603,	R5121-1	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		OP1PVJ3604, OP1PVJ3605, OP1PVJ3606, OP1PVJ3904, OP2PV48055, OP2PVJ4301, OP2PVJ4303, OP2PVJ4308, OP2PVJ4402, OP2PVJ4403, OP2PVJ4404, OP2PVJ4405, OP2PVJ4406, OP2PVJ4407, OP2PVJ4408, OP2PVJ4409, OP2PVJ4410, OP2PVJ4415, OP2PVJ4501, OP2PVJ4602, OP2PVJ4603, OP2PVJ4604, OP2PVJ4605, OP2PVJ4606, OP2PVJ4607, OP2PVJ4611, OP2VJ48013			
GRPBOILER	Boilers/Steam Generators/Steam Generating Units	OP1BL3803A, OP1BL3803B, OP2BL4803A, OP2BL4803B	R7ICI-1A	30 TAC Chapter 117, Subchapter B	Fuel Type #1 = Gaseous fuel other than natural gas landfill gas or renewable non-fossil fuel gases.
GRPBOILER	Boilers/Steam Generators/Steam Generating Units	OP1BL3803A, OP1BL3803B, OP2BL4803A, OP2BL4803B	R7ICI-1B	30 TAC Chapter 117, Subchapter B	Fuel Type #1 = Liquid fuel
GRPBOILER	Boilers/Steam Generators/Steam Generating Units	OP1BL3803A, OP1BL3803B, OP2BL4803A, OP2BL4803B	60D-1A	40 CFR Part 60, Subpart D	No changing attributes.
GRPBTBZTK	Storage Tanks/Vessels	MBTTK3111A, MBTTK3111B	R5112-3	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPBTBZTK	Storage Tanks/Vessels	MBTTK3111A, MBTTK3111B	63G-3	40 CFR Part 63, Subpart G	No changing attributes.
GRPBZTW	Treatment Process	OP2TW4407, OP2TW4453	61FF-8A	40 CFR Part 61, Subpart FF	Treatment Process Engineering Calculations = Engineering calculations show that the treatment process or

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					wastewater treatment system unit is proven to achieve its emission limitation.
GRPBZTW	Treatment Process	OP2TW4407, OP2TW4453	61FF-8B	40 CFR Part 61, Subpart FF	Treatment Process Engineering Calculations = Engineering calculations show that the treatment process or wastewater treatment system unit is proven to achieve its emission limitation.
GRPBZTW	Treatment Process	OP2TW4407, OP2TW4453	61FF-8C	40 CFR Part 61, Subpart FF	Treatment Process Engineering Calculations = Performance tests are used to show that the treatment process or wastewater treatment system unit achieves its emission limitation.
GRPBZTW	Treatment Process	OP2TW4407, OP2TW4453	61FF-8D	40 CFR Part 61, Subpart FF	Treatment Process Engineering Calculations = Performance tests are used to show that the treatment process or wastewater treatment system unit achieves its emission limitation.
GRPBZTW	Treatment Process	OP2TW4407, OP2TW4453	63G-7A	40 CFR Part 63, Subpart G	Treatment Process Design Evaluation = Compliance for the treatment process will be demonstrated using design evaluation.
GRPBZTW	Treatment Process	OP2TW4407, OP2TW4453	63G-7B	40 CFR Part 63, Subpart G	Treatment Process Design Evaluation = Compliance for the treatment process will be

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					demonstrated by performance test.
GRPBZTW	Treatment Process	OP2TW4407, OP2TW4453	63G-7C	40 CFR Part 63, Subpart G	Treatment Process Design Evaluation = Compliance for the treatment process will be demonstrated using design evaluation.
GRPBZTW	Treatment Process	OP2TW4407, OP2TW4453	63G-7D	40 CFR Part 63, Subpart G	Treatment Process Design Evaluation = Compliance for the treatment process will be demonstrated by performance test.
GRPBZTW	Treatment Process	OP2TW4407, OP2TW4453	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
GRPC4MTTK1	Storage Tanks/Vessels	EC4TK11, EC4TK14, EC4TK16, EC4TK20, EC4TK3, EC4TK41, EC4TK42, EC4TK43, EC4TK44, EC4TK6, EMTTK1, EMTTK10, EMTTK2, EMTTK9	R5112-4A	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
GRPC4MTTK1	Storage Tanks/Vessels	EC4TK11, EC4TK14, EC4TK16, EC4TK20, EC4TK3, EC4TK41, EC4TK42, EC4TK43, EC4TK44, EC4TK6, EMTTK1, EMTTK10, EMTTK2, EMTTK9	R5112-4B	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
GRPC4MTTK1	Storage Tanks/Vessels	EC4TK11, EC4TK14, EC4TK16, EC4TK20, EC4TK3, EC4TK41, EC4TK42, EC4TK43, EC4TK44, EC4TK6, EMTTK1, EMTTK10, EMTTK2, EMTTK9	R5112-4C	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Other vapor destruction unit
GRPC4MTTK1	Storage Tanks/Vessels	EC4TK11, EC4TK14, EC4TK16, EC4TK20, EC4TK3, EC4TK41,	R5112-4D	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		EC4TK42, EC4TK43, EC4TK44, EC4TK6, EMTTK1, EMTTK10, EMTTK2, EMTTK9			
GRPC4MTTK1	Storage Tanks/Vessels	EC4TK11, EC4TK14, EC4TK16, EC4TK20, EC4TK3, EC4TK41, EC4TK42, EC4TK43, EC4TK44, EC4TK6, EMTTK1, EMTTK10, EMTTK2, EMTTK9	R5112-4E	30 TAC Chapter 115, Storage of VOCs	Control Device Type = Flare
GRPC4MTTK1	Storage Tanks/Vessels	EC4TK11, EC4TK14, EC4TK16, EC4TK20, EC4TK3, EC4TK41, EC4TK42, EC4TK43, EC4TK44, EC4TK6, EMTTK1, EMTTK10, EMTTK2, EMTTK9	63G-1A	40 CFR Part 63, Subpart G	Emission Control Type = Closed vent system (CVS) and control device (fixed roof), Control Device Type = Flare
GRPC4MTTK1	Storage Tanks/Vessels	EC4TK11, EC4TK14, EC4TK16, EC4TK20, EC4TK3, EC4TK41, EC4TK42, EC4TK43, EC4TK44, EC4TK6, EMTTK1, EMTTK10, EMTTK2, EMTTK9	63G-1B	40 CFR Part 63, Subpart G	Emission Control Type = Closed vent system (CVS) and control device (fixed roof), Control Device Type = Flare
GRPC4MTTK1	Storage Tanks/Vessels	EC4TK11, EC4TK14, EC4TK16, EC4TK20, EC4TK3, EC4TK41, EC4TK42, EC4TK43, EC4TK44, EC4TK6, EMTTK1, EMTTK10, EMTTK2, EMTTK9	63G-1C	40 CFR Part 63, Subpart G	Emission Control Type = Emissions routed to a fuel gas system, Hard Piping = The closed vent system is constructed of hard piping.
GRPC4MTTK1	Storage Tanks/Vessels	EC4TK11, EC4TK14, EC4TK16, EC4TK20, EC4TK3, EC4TK41, EC4TK42, EC4TK43, EC4TK44, EC4TK6, EMTTK1, EMTTK10, EMTTK2, EMTTK9	63G-1D	40 CFR Part 63, Subpart G	Emission Control Type = Emissions routed to a fuel gas system, Hard Piping = The closed vent system is constructed of hard piping.
GRPC4MTTK1	Storage Tanks/Vessels	EC4TK11, EC4TK14, EC4TK16, EC4TK20, EC4TK3, EC4TK41, EC4TK42, EC4TK43, EC4TK44, EC4TK6, EMTTK1, EMTTK10,	63G-1E	40 CFR Part 63, Subpart G	Emission Control Type = Closed vent system (CVS) and control device (fixed roof), Control Device Type = Flare

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		EMTTK2, EMTTK9			
GRPC4MTTK1	Storage Tanks/Vessels	EC4TK11, EC4TK14, EC4TK16, EC4TK20, EC4TK3, EC4TK41, EC4TK42, EC4TK43, EC4TK44, EC4TK6, EMTTK1, EMTTK10, EMTTK2, EMTTK9	63G-1F	40 CFR Part 63, Subpart G	Emission Control Type = Closed vent system (CVS) and control device (fixed roof), Control Device Type = Flare
GRPC4RXR2	Reactor	EC4RX1208A, EC4RX1208B	60RRR-1A	40 CFR Part 60, Subpart RRR	No changing attributes.
GRPC4VENT1	Emission Points/Stationary Vents/Process Vents	EC4RX1201, EC4RX309	R5720-2	30 TAC Chapter 115, HRVOC Vent Gas	Vent Gas Stream Control = Vent gas stream is controlled by a flare.
GRPC4VENT1	Emission Points/Stationary Vents/Process Vents	EC4RX1201, EC4RX309	R5720-4	30 TAC Chapter 115, HRVOC Vent Gas	Vent Gas Stream Control = Vent gas stream is controlled by a control device other than a flare.
GRPC4VENT1	Emission Points/Stationary Vents/Process Vents	EC4RX1201, EC4RX309	R5121-1	30 TAC Chapter 115, Vent Gas Controls	Control Device Type = Vapor combustor not considered to be a flare.
GRPC4VENT1	Emission Points/Stationary Vents/Process Vents	EC4RX1201, EC4RX309	R5121-2	30 TAC Chapter 115, Vent Gas Controls	Control Device Type = Vapor combustor not considered to be a flare.
GRPC4VENT1	Emission Points/Stationary Vents/Process Vents	EC4RX1201, EC4RX309	R5121-4	30 TAC Chapter 115, Vent Gas Controls	Control Device Type = Smokeless flare
GRPC5TK1	Storage Tanks/Vessels	EC5TK13, EC5TK28, EC5TK29	R5112-4A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPC5TK1	Storage Tanks/Vessels	EC5TK13, EC5TK28, EC5TK29	R5112-4B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPC5TK2	Storage Tanks/Vessels	EC5DM12, EC5DM14, EC5DM304	R5112-4A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRPC5TK2	Storage Tanks/Vessels	EC5DM12, EC5DM14, EC5DM304	R5112-4B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPC5TK2	Storage Tanks/Vessels	EC5DM12, EC5DM14, EC5DM304	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
GRPCARFLR	Miscellaneous Units	MEOHFLAREV, OP1FL3801V, OP2FL4801V	65CAR-FL	40 CFR Part 65, Subpart D	No changing attributes.
GRPCARFURN	Emission Points/Stationary Vents/Process Vents	OP1HT3401V, OP1HT3402V, OP1HT3403V, OP1HT3404V, OP1HT3405V	65CAR-FUR	40 CFR Part 65, Subpart D	No changing attributes.
GRPCARFURN	Miscellaneous Units	MEOHT7001V, OP1HT3406V, OP1HT3407V, OP1HT3408V, OP1HT3409V, OP1HT3410V, OP1HT3411V, OP1HT3412V, OP1HT3413V, OP1HT3414V, OP1HT3415V, OP1HT3418V, OP1HT3419V, OP1HT3601V, OP1HT3701V, OP1HT804AV, OP1HT804BV, OP2HT4401V, OP2HT4402V, OP2HT4403V, OP2HT4404V, OP2HT4405V, OP2HT4406V, OP2HT4407V, OP2HT4408V, OP2HT4409V, OP2HT4410V, OP2HT4411V, OP2HT4412V, OP2HT4413V, OP2HT4414V, OP2HT4415V, OP2HT4418V, OP2HT4419V, OP2HT4601V, OP2HT804AV, OP2HT804BV	65CAR-FUR	40 CFR Part 65, Subpart D	No changing attributes.
GRPECUDM	Storage Tanks/Vessels	ECUDM82, ECUDM83	R5112-1A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPECUDM	Storage Tanks/Vessels	ECUDM82, ECUDM83	R5112-1B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRPECUDM	Storage Tanks/Vessels	ECUDM82, ECUDM83	60Kb-1A	40 CFR Part 60, Subpart Kb	No changing attributes.
GRPECUDM	Storage Tanks/Vessels	ECUDM82, ECUDM83	60Kb-1B	40 CFR Part 60, Subpart Kb	No changing attributes.
GRPECUDM	Storage Tanks/Vessels	ECUDM82, ECUDM83	60Kb-1C	40 CFR Part 60, Subpart Kb	No changing attributes.
GRPECUDM	Storage Tanks/Vessels	ECUDM82, ECUDM83	60Kb-1D	40 CFR Part 60, Subpart Kb	No changing attributes.
GRPECUDM	Storage Tanks/Vessels	ECUDM82, ECUDM83	61FF-1A	40 CFR Part 61, Subpart FF	No changing attributes.
GRPECUDM	Storage Tanks/Vessels	ECUDM82, ECUDM83	61FF-1B	40 CFR Part 61, Subpart FF	No changing attributes.
GRPECUDM	Storage Tanks/Vessels	ECUDM82, ECUDM83	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
GRPLDBGDK	Loading/Unloading Operations	EBGDOCK1&2, EBGDOCK3&4	R5211-1	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure less than 0.5 psia., Transfer Type = Loading and unloading.
GRPLDBGDK	Loading/Unloading Operations	EBGDOCK1&2, EBGDOCK3&4	R5211-2	30 TAC Chapter 115, Loading and Unloading of VOC	Marine Terminal Exemptions = The marine terminal is not claiming one or more of the exemptions in 30 TAC § 115.217(a)(5)(B)., True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(B), (b)(3)(B), (a)(2)(A), and (b)(3)(A) exemptions do not apply to marine terminals or gasoline

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					terminals., Chapter 115 Control Device Type = Vapor control system with a vapor combustor., Transfer Type = Loading and unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
GRPLDBGDK	Loading/Unloading Operations	EBGDOCK1&2, EBGDOCK3&4	R5211-3	30 TAC Chapter 115, Loading and Unloading of VOC	Marine Terminal Exemptions = The marine terminal is claiming one or more of the exemptions in 30 TAC § 115.217(a)(5)(B)., True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(B), (b)(3)(B), (a)(2)(A), and (b)(3)(A) exemptions do not apply to marine terminals or gasoline terminals., VOC Flash Point = Flash point less than 150° F., Transfer Type = Only unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%.
GRPLDBGDK	Loading/Unloading	EBGDOCK1&2, EBGDOCK3&4	61BB-1	40 CFR Part 61, Subpart	Benzene By Weight =

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	Operations			BB	Concentration of benzene by weight in the liquid which is loaded is greater than or equal to 70% benzene by weight., Loading Location = Marine loading only., Subpart BB Control Device Type = Incinerator other than a catalytic incinerator., Intermittent Control Device = The control device does not operate intermittently., Diverted Gas Stream = The vent gas stream cannot be diverted from the control device.
GRPLDBGDK	Loading/Unloading Operations	EBGDOCK1&2, EBGDOCK3&4	61BB-2	40 CFR Part 61, Subpart BB	Benzene By Weight = Concentration of benzene by weight in the liquid which is loaded is less than 70% benzene by weight.
GRPLDBGDK	Loading/Unloading Operations	EBGDOCK1&2, EBGDOCK3&4	63Y-3	40 CFR Part 63, Subpart Y	No changing attributes.
GRPLIQFURN	Emission Points/Stationary Vents/Process Vents	OP1HT3411, OP1HT3412	R1111-5	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRPLIQFURN	Process Heaters/Furnaces	OP1HT3411, OP1HT3412	R7ICI-4B	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRPLOADBD	Loading/Unloading Operations	ECULR1BD, ECULR2BD, ECULTBD	R5211-1	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure less than 0.5 psia.
GRPLOADBD	Loading/Unloading Operations	ECULR1BD, ECULR2BD, ECULTBD	R5211-2	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control Device Type = Vapor control system with a flare., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
GRPLOADBD	Loading/Unloading Operations	ECULR1BD, ECULR2BD, ECULTBD	R5211-3	30 TAC Chapter 115, Loading and Unloading of VOC	True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(A) or 30 TAC § 115.217(b)(3)(A) exemption is not utilized., Chapter 115 Control Device Type = Vapor control system with a flare., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = Not all liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRPLOADBD	Loading/Unloading Operations	ECULR1BD, ECULR2BD, ECULTBD	63G-1A	40 CFR Part 63, Subpart G	Emissions Routing = Emissions of organic hazardous air pollutants are not routed to a fuel gas system nor to a process where the organic hazardous air pollutants meet one or more of the ends specified in 40 CFR § 63.126(b)(4)(i) - (iv)., Halogenated Emissions = There are no halogenated emission streams from the transfer rack., Control Device = Flare.
GRPLOADBD	Loading/Unloading Operations	ECULR1BD, ECULR2BD, ECULTBD	63G-1B	40 CFR Part 63, Subpart G	Emissions Routing = Emissions of organic hazardous air pollutants are not routed to a fuel gas system nor to a process where the organic hazardous air pollutants meet one or more of the ends specified in 40 CFR § 63.126(b)(4)(i) - (iv)., Halogenated Emissions = There are no halogenated emission streams from the transfer rack., Control Device = Flare.
GRPLOADBD	Loading/Unloading Operations	ECULR1BD, ECULR2BD, ECULTBD	63G-1C	40 CFR Part 63, Subpart G	Emissions Routing = Emissions of organic hazardous air pollutants are routed to a fuel gas system or to a process where the organic hazardous air pollutants meet one or more of the ends specified in 40 CFR § 63.126(b)(4)(i) - (iv).
GRPLOADOP1	Loading/Unloading	OP1LDRC, OP1LDTT	R5211-1	30 TAC Chapter 115,	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	Operations			Loading and Unloading of VOC	
GRPLOADPBD	Loading/Unloading Operations	MPBLDRC, MPBLDTT	R5211-1	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
GRPMEOTK	Storage Tanks/Vessels	MEOTK3122, MEOTK5101, MEOTK5102	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPMEOTK	Storage Tanks/Vessels	MEOTK3122, MEOTK5101, MEOTK5102	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
GRPMTTK1	Storage Tanks/Vessels	MBTTK3101, MBTTK3102	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPMTTK1	Storage Tanks/Vessels	MBTTK3101, MBTTK3102	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
GRPMTTK2	Storage Tanks/Vessels	EMTTK48, EMTTK49	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPMTTK2	Storage Tanks/Vessels	EMTTK48, EMTTK49	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
GRPMTVENT1	Emission Points/Stationary Vents/Process Vents	EMTR1202AV, EMTR1202BV, EMTR1202CV, EMTR1202DV	R5720-4	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
GRPMTVENT1	Emission Points/Stationary Vents/Process Vents	EMTR1202AV, EMTR1202BV, EMTR1202CV, EMTR1202DV	R5121-2	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
GRPOL1FURV	Emission Points/Stationary Vents/Process Vents	OP1HT3401V, OP1HT3402V, OP1HT3403V, OP1HT3404V, OP1HT3405V, OP1HT3406V, OP1HT3407V, OP1HT3408V, OP1HT3409V, OP1HT3410V, OP1HT3413V, OP1HT3414V, OP1HT3415V, OP1HT3418V	R5720-6	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRPOL1FURV	Emission Points/Stationary Vents/Process Vents	OP1HT3401V, OP1HT3402V, OP1HT3403V, OP1HT3404V, OP1HT3405V, OP1HT3406V, OP1HT3407V, OP1HT3408V, OP1HT3409V, OP1HT3410V, OP1HT3413V, OP1HT3414V, OP1HT3415V, OP1HT3418V	R5121-2	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10., Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRPOL1FURV	Emission Points/Stationary Vents/Process Vents	OP1HT3401V, OP1HT3402V, OP1HT3403V, OP1HT3404V, OP1HT3405V, OP1HT3406V, OP1HT3407V, OP1HT3408V, OP1HT3409V, OP1HT3410V, OP1HT3413V, OP1HT3414V, OP1HT3415V, OP1HT3418V	R5121-28	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule.
GRPOL1FURV	Emission Points/Stationary Vents/Process Vents	OP1HT3401V, OP1HT3402V, OP1HT3403V, OP1HT3404V, OP1HT3405V, OP1HT3406V, OP1HT3407V, OP1HT3408V, OP1HT3409V, OP1HT3410V, OP1HT3413V, OP1HT3414V, OP1HT3415V, OP1HT3418V	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
GRPOL2FURV	Emission Points/Stationary Vents/Process Vents	OP2HT4401V, OP2HT4402V, OP2HT4403V, OP2HT4404V, OP2HT4405V, OP2HT4406V, OP2HT4407V, OP2HT4408V, OP2HT4409V, OP2HT4410V, OP2HT4411V, OP2HT4412V, OP2HT4413V, OP2HT4414V, OP2HT4415V, OP2HT4418V	R5121-2	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10., Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
GRPOL2FURV	Emission Points/Stationary Vents/Process Vents	OP2HT4401V, OP2HT4402V, OP2HT4403V, OP2HT4404V, OP2HT4405V, OP2HT4406V, OP2HT4407V, OP2HT4408V, OP2HT4409V, OP2HT4410V, OP2HT4411V, OP2HT4412V, OP2HT4413V, OP2HT4414V, OP2HT4415V, OP2HT4418V	R5121-28	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule.
GRPOL2FURV	Emission Points/Stationary Vents/Process Vents	OP2HT4401V, OP2HT4402V, OP2HT4403V, OP2HT4404V, OP2HT4405V, OP2HT4406V, OP2HT4407V, OP2HT4408V, OP2HT4409V, OP2HT4410V, OP2HT4411V, OP2HT4412V, OP2HT4413V, OP2HT4414V, OP2HT4415V, OP2HT4418V	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
GRPOLFUR2	Process Heaters/Furnaces	OP1HT3419, OP2HT4419	R7301	30 TAC Chapter 117, Subchapter B	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRPOLFUR2	Emission Points/Stationary Vents/Process Vents	OP1HT3419, OP2HT4419	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
GRPOLFUR2V	Emission Points/Stationary Vents/Process Vents	OP1HT3419V, OP2HT4419V	R1111	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRPOLFUR2V	Emission Points/Stationary Vents/Process Vents	OP1HT3419V, OP2HT4419V	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
GRPOLFURN	Emission Points/Stationary Vents/Process Vents	OP1HT3401, OP1HT3402, OP1HT3403, OP1HT3404, OP1HT3405, OP1HT3406, OP1HT3407, OP1HT3408, OP1HT3409, OP1HT3410, OP1HT3413, OP1HT3414, OP1HT3418, OP2HT4410, OP2HT4401, OP2HT4402, OP2HT4403, OP2HT4404, OP2HT4405, OP2HT4406, OP2HT4407, OP2HT4408, OP2HT4409, OP2HT4411, OP2HT4412, OP2HT4413, OP2HT4414, OP2HT4415, OP2HT4418	R1111-3	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRPOLFURN	Process Heaters/Furnaces	OP1HT3401, OP1HT3402, OP1HT3403, OP1HT3404, OP1HT3405, OP1HT3406, OP1HT3407, OP1HT3408, OP1HT3409, OP1HT3410, OP1HT3413, OP1HT3414, OP1HT3418, OP2HT4401, OP2HT4402, OP2HT4403, OP2HT4404, OP2HT4405,	R7ICI-1	30 TAC Chapter 117, Subchapter B	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		OP2HT4406, OP2HT4407, OP2HT4408, OP2HT4409, OP2HT4410, OP2HT4411, OP2HT4412, OP2HT4413, OP2HT4414, OP2HT4415, OP2HT4418			
GRPOLFURN	Emission Points/Stationary Vents/Process Vents	OP1HT3401, OP1HT3402, OP1HT3403, OP1HT3404, OP1HT3405, OP1HT3406, OP1HT3407, OP1HT3408, OP1HT3409, OP1HT3410, OP1HT3413, OP1HT3414, OP1HT3418, OP2HT4410, OP2HT4401, OP2HT4402, OP2HT4403, OP2HT4404, OP2HT4405, OP2HT4406, OP2HT4407, OP2HT4408, OP2HT4409, OP2HT4411, OP2HT4412, OP2HT4413, OP2HT4414, OP2HT4415, OP2HT4418	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
GRPOLSEALV	Emission Points/Stationary Vents/Process Vents	OP1SEAL1, OP1SEAL2, OP1SEAL3	R5121-1	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
GRPOLSUHT	Emission Points/Stationary Vents/Process Vents	OP1HT3804A, OP1HT3804B, OP2HT4804A, OP2HT4804B	R1111-4	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRPOLSUHT	Process Heaters/Furnaces	OP1HT3804A, OP1HT3804B, OP2HT4804A, OP2HT4804B	R7ICI-2B	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRPOLSUHT	Process Heaters/Furnaces	OP1HT3804A, OP1HT3804B, OP2HT4804A, OP2HT4804B	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
GRPOLSUHTV	Emission	OP1HT804AV, OP1HT804BV,	R5720-1	30 TAC Chapter 115,	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	Points/Stationary Vents/Process Vents	OP2HT804AV, OP2HT804BV		HRVOC Vent Gas	
GRPOLSUHTV	Emission Points/Stationary Vents/Process Vents	OP1HT804AV, OP1HT804BV, OP2HT804AV, OP2HT804BV	R5121-29	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule.
GRPOLSUHTV	Emission Points/Stationary Vents/Process Vents	OP1HT804AV, OP1HT804BV, OP2HT804AV, OP2HT804BV	R5121-3	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10., Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
GRPOLTKHVY	Storage Tanks/Vessels	OP1TK38301, OP1TK38302, OP1TK3913, OP1TK3914, OP2TK48302, OP2TK48304, OP2TK48305	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPOLTKHVY	Storage Tanks/Vessels	OP1TK38301, OP1TK38302, OP1TK3913, OP1TK3914, OP2TK48302, OP2TK48304, OP2TK48305	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
GRPOLTKIFR	Storage Tanks/Vessels	OP1TK3906, OP1TK3907, OP2TK4906, OP2TK4907	R5112-3	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPOLTKIFR	Storage Tanks/Vessels	OP1TK3906, OP1TK3907, OP2TK4906, OP2TK4907	60K-3A	40 CFR Part 60, Subpart K	No changing attributes.
GRPOLTKIFR	Storage Tanks/Vessels	OP1TK3906, OP1TK3907, OP2TK4906, OP2TK4907	60K-3B	40 CFR Part 60, Subpart K	No changing attributes.
GRPOLTKIFR	Storage Tanks/Vessels	OP1TK3906, OP1TK3907, OP2TK4906, OP2TK4907	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
GRPOP1TK1	Wastewater Units	OP1TK3901, OP1TK3902, OP1TK3904, OP1TK3905	R5140-8	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
GRPOP1TK1	Storage Tanks/Vessels	OP1TK3901, OP1TK3902, OP1TK3904, OP1TK3905	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPOP1TK1	Storage Tanks/Vessels	OP1TK3901, OP1TK3902,	60K-1A	40 CFR Part 60, Subpart	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		OP1TK3904, OP1TK3905		K	
GRPOP1TK1	Storage Tanks/Vessels	OP1TK3901, OP1TK3902, OP1TK3904, OP1TK3905	60K-1B	40 CFR Part 60, Subpart K	No changing attributes.
GRPOP1TK1	Storage Tanks/Vessels	OP1TK3901, OP1TK3902, OP1TK3904, OP1TK3905	61FF-17	40 CFR Part 61, Subpart FF	No changing attributes.
GRPOP1TK1	Storage Tanks/Vessels	OP1TK3901, OP1TK3902, OP1TK3904, OP1TK3905	63G-27	40 CFR Part 63, Subpart G	No changing attributes.
GRPOP1TK1	Storage Tanks/Vessels	OP1TK3901, OP1TK3902, OP1TK3904, OP1TK3905	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
GRPOP1TK5	Storage Tanks/Vessels	OP1DM3530, OP1SMLTK03, OP1SMLTK04, OP1SMLTK07, OP1SMLTK13, OP1SMLTK15, OP1SMLTK16, OP1SMLTK17, OP1SMLTK18, OP1TK3462, OP1TK3504X, OP1TK3602X, OP1TK3604X, OP1TK3609, OP1TK3701, OP1TK3701X	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPOP1TK5	Storage Tanks/Vessels	OP1DM3530, OP1SMLTK03, OP1SMLTK04, OP1SMLTK07, OP1SMLTK13, OP1SMLTK15, OP1SMLTK16, OP1SMLTK17, OP1SMLTK18, OP1TK3462, OP1TK3504X, OP1TK3602X, OP1TK3604X, OP1TK3609, OP1TK3701, OP1TK3701X	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
GRPOP1TK6	Wastewater Units	OP1TK38010, OP1TK38011	R5140-3	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
GRPOP1TK6	Storage Tanks/Vessels	OP1TK38010, OP1TK38011	60Kb-3A	40 CFR Part 60, Subpart Kb	No changing attributes.
GRPOP1TK6	Storage Tanks/Vessels	OP1TK38010, OP1TK38011	60Kb-3B	40 CFR Part 60, Subpart	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				Kb	
GRPOP1TK6	Storage Tanks/Vessels	OP1TK38010, OP1TK38011	61FF-4	40 CFR Part 61, Subpart FF	No changing attributes.
GRPOP1TK6	Storage Tanks/Vessels	OP1TK38010, OP1TK38011	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
GRPOP1TK6	Storage Tanks/Vessels	OP1TK38010, OP1TK38011	63G-4	40 CFR Part 63, Subpart G	No changing attributes.
GRPOP1TK6	Storage Tanks/Vessels	OP1TK38010, OP1TK38011	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
GRPOP2TK1	Storage Tanks/Vessels	OP2TK4902, OP2TK4903, OP2TK4904, OP2TK4905	R5112-2	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPOP2TK1	Storage Tanks/Vessels	OP2TK4902, OP2TK4903, OP2TK4904, OP2TK4905	60K-1B	40 CFR Part 60, Subpart K	No changing attributes.
GRPOP2TK1	Storage Tanks/Vessels	OP2TK4902, OP2TK4903, OP2TK4904, OP2TK4905	60K-2A	40 CFR Part 60, Subpart K	No changing attributes.
GRPOP2TK1	Storage Tanks/Vessels	OP2TK4902, OP2TK4903, OP2TK4904, OP2TK4905	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
GRPOP2TK2	Storage Tanks/Vessels	OP2TK4917, OP2TK4919	R5112-5	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPOP2TK2	Storage Tanks/Vessels	OP2TK4917, OP2TK4919	63G-2	40 CFR Part 63, Subpart G	No changing attributes.
GRPOP2TK5	Storage Tanks/Vessels	OP2SMLTK08, OP2SMLTK10, OP2SMLTK12, OP2SMLTK13, OP2SMLTK16, OP2SMLTK17, OP2TK4462, OP2TK4504X, OP2TK4511, OP2TK4602X, OP2TK4604X, OP2TK4607, OP2TK48616	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPOP2TK5	Storage Tanks/Vessels	OP2SMLTK08, OP2SMLTK10,	63YY-1	40 CFR Part 63, Subpart	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		OP2SMLTK12, OP2SMLTK13, OP2SMLTK16, OP2SMLTK17, OP2TK4462, OP2TK4504X, OP2TK4511, OP2TK4602X, OP2TK4604X, OP2TK4607, OP2TK48616		YY	
GRPOP2TK6	Wastewater Units	OP2TK48010, OP2TK48011	R5140-3	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
GRPOP2TK6	Storage Tanks/Vessels	OP2TK48010, OP2TK48011	60Kb-8	40 CFR Part 60, Subpart Kb	No changing attributes.
GRPOP2TK6	Storage Tanks/Vessels	OP2TK48010, OP2TK48011	61FF-5	40 CFR Part 61, Subpart FF	No changing attributes.
GRPOP2TK6	STORAGE TANKS/VESSELS	OP2TK48010, OP2TK48011	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
GRPOP2TK6	Storage Tanks/Vessels	OP2TK48010, OP2TK48011	63G-11	40 CFR Part 63, Subpart G	Wastewater Tank Properties = Volume of the wastewater tank is less than 75m^3 and storing liquid with any vapor pressure
GRPOP2TK6	Storage Tanks/Vessels	OP2TK48010, OP2TK48011	63G-7	40 CFR Part 63, Subpart G	Wastewater Tank Properties = Properties do not qualify for exemption, Emission Control Type = Fixed-roof tank equipped with an internal floating roof that meets the requirements specified in 40 CFR § 63.119(b), New Source = The source is an existing source.
GRPOP2TK6	Storage Tanks/Vessels	OP2TK48010, OP2TK48011	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
GRPOP2TK7	Storage Tanks/Vessels	OP2SMLTK01, OP2SMLTK02, OP2SMLTK04, OP2TK48620	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRPSMAPMV	Emission Points/Stationary Vents/Process Vents	MSMM2862B, MSMM2862C, MSMM2862D, MSMM2863, MSMM2868, MSMM2872, MSMX2802	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRPSMAPMV	Emission Points/Stationary Vents/Process Vents	MSMM2862B, MSMM2862C, MSMM2862D, MSMM2863, MSMM2868, MSMM2872, MSMX2802	R5121-4	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
GRPSMLTANK	Storage Tanks/Vessels	EALSMLTK01, EALSMLTK02, EALSMLTK03, EALSMLTK04, EALSMLTK06, EC4SMLTK01, EC4SMLTK02, EC4SMLTK03, EC4SMLTK04, EC4SMLTK13, EC5SMLTK01, ECUSMLTK15, ECUSMLTK16, ECUSMLTK17, ECUSMLTK18, ECUSMLTK19, ECUSMLTK20, ECUSMLTK22, ECUSMLTK23, ECUSMLTK26, EMTSMLTK01, EMTSMLTK02, MBTSMLTK02, MBTSMLTK03, MEOSMLTK03, MEOSMLTK04, MEOSMLTK05, MEOSMLTK06, MEOSMLTK07, MPBDM3223, MPBTK3201, MPBTK3202A, MPBTK3202B, MSMDM2805, MSMDM2814, MSMTK2804A, MSMTK2804B, OP1SMLTK12, OP1SMLTK19, OP2SMLTK03, OP2SMLTK05, OP2SMLTK15, OP2TK48615	R5112-1	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.0 psia but less than 1.5 psia, Tank Description = Tank does not require emission controls
GRPSMLTANK	Storage Tanks/Vessels	EALSMLTK01, EALSMLTK02, EALSMLTK03, EALSMLTK04, EALSMLTK06, EC4SMLTK01,	R5112-2	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia, Tank

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		EC4SMLTK02, EC4SMLTK03, EC4SMLTK04, EC4SMLTK13, EC5SMLTK01, ECUSMLTK15, ECUSMLTK16, ECUSMLTK17, ECUSMLTK18, ECUSMLTK19, ECUSMLTK20, ECUSMLTK22, ECUSMLTK23, ECUSMLTK26, EMTSMLTK01, EMTSMLTK02, MBTSMLTK02, MBTSMLTK03, MEOSMLTK03, MEOSMLTK04, MEOSMLTK05, MEOSMLTK06, MEOSMLTK07, MPBDM3223, MPBTK3201, MPBTK3202A, MPBTK3202B, MSMDM2805, MSMDM2814, MSMTK2804A, MSMTK2804B, OP1SMLTK12, OP1SMLTK19, OP2SMLTK03, OP2SMLTK05, OP2SMLTK15, OP2TK48615			Description = Tank using a submerged fill pipe
MBTCT2402	Industrial Process Cooling Towers	N/A	R5760-4	30 TAC Chapter 115, HRVOC Cooling Towers	No changing attributes.
MBTDM4009	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MBTDM4009	Storage Tanks/Vessels	N/A	63G-10	40 CFR Part 63, Subpart G	No changing attributes.
MBTSP4010	Emission Points/Stationary Vents/Process Vents	N/A	R5121-1	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
MBTSP4010	Emission Points/Stationary Vents/Process Vents	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
MBTTK3112	Storage Tanks/Vessels	N/A	R5112-2	30 TAC Chapter 115,	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				Storage of VOCs	
MBTTK3112	Storage Tanks/Vessels	N/A	63G-2	40 CFR Part 63, Subpart G	No changing attributes.
MBTTK3113	Storage Tanks/Vessels	N/A	R5112-4	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MBTTK3113	Storage Tanks/Vessels	N/A	63G-4	40 CFR Part 63, Subpart G	No changing attributes.
MBTTK3114	Storage Tanks/Vessels	N/A	R5112-6	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MBTTK3114	Storage Tanks/Vessels	N/A	63G-6	40 CFR Part 63, Subpart G	No changing attributes.
MBTTK3115	Storage Tanks/Vessels	N/A	R5112-5	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MBTTK3115	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
MBTTK3115	Storage Tanks/Vessels	N/A	63G-2	40 CFR Part 63, Subpart G	No changing attributes.
MBTTK4002	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MBTTK4002	Storage Tanks/Vessels	N/A	63G-6	40 CFR Part 63, Subpart G	No changing attributes.
MBTTK4003	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MBTTK4003	Storage Tanks/Vessels	N/A	63G-7	40 CFR Part 63, Subpart G	No changing attributes.
MBTTK4004	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
MBTTK4004	Storage Tanks/Vessels	N/A	63G-8	40 CFR Part 63, Subpart G	No changing attributes.
MBTTK4011	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MBTWWCPI	Volatile Organic Compound Water Separators	N/A	R5131-1	30 TAC Chapter 115, Water Separation	No changing attributes.
MEOHANLZ	Emission Points/Stationary Vents/Process Vents	N/A	R5121-1B	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
MEOHFLARE	Flares	N/A	R1111-2	30 TAC Chapter 111, Visible Emissions	No changing attributes.
MEOHFLARE	Miscellaneous Units	N/A	65CAR-FL	40 CFR Part 65, Subpart G	No changing attributes.
MEOHT7001	Process Heaters/Furnaces	N/A	R7301	30 TAC Chapter 117, Subchapter B	No changing attributes.
MEOHT7001	Process Heaters/Furnaces	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
MEOHT7001	Miscellaneous Units	N/A	65RRRCAR	40 CFR Part 65, Subpart D	No changing attributes.
MEOHT7001V	Emission Points/Stationary Vents/Process Vents	N/A	R1111	30 TAC Chapter 111, Visible Emissions	No changing attributes.
MEOHT7001V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-2	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
MEOPM3314	SRIC Engines	N/A	R7471	30 TAC Chapter 117, Subchapter B	No changing attributes.
MEOPM3314	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				ZZZZ	
MEORXR7001	Miscellaneous Units	N/A	65RRRCAR	40 CFR Part 65, Subpart D	No changing attributes.
MEOSP3101	Volatile Organic Compound Water Separators	N/A	R5131-1	30 TAC Chapter 115, Water Separation	No changing attributes.
MEOSP7045	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MEOTW7001	Miscellaneous Units	N/A	65NNNCAR	40 CFR Part 65, Subpart D	No changing attributes.
MEOTW7002	Miscellaneous Units	N/A	65NNNCAR	40 CFR Part 65, Subpart D	No changing attributes.
MIPCT2401	Industrial Process Cooling Towers	N/A	R5760-5	30 TAC Chapter 115, HRVOC Cooling Towers	No changing attributes.
MIPFL2501	Flares	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
MIPFL2501	Flares	N/A	R5720-1	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
MIPFL2501	Flares	N/A	63A-1A	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is less than 60 ft/s (18.3 m/sec)
MIPFL2501	Flares	N/A	63A-1B	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is greater than 1000 Btu/scf (37.3 MJ/scm).
MIPFL2501	Flares	N/A	63A-1C	40 CFR Part 63, Subpart	Flare Exit Velocity = Flare exit

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				A	velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is less than or equal to 1000 Btu/scf (37.3 MJ/scm).
MIPFL2501V	Emission Points/Stationary Vents/Process Vents	N/A	R5720-1	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
MIPFL2501V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-1	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
MIPFL2501V	Emission Points/Stationary Vents/Process Vents	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
MIPTK2615	Storage Tanks/Vessels	N/A	R5112-2	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MIPTK2615	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
MIPTK3105	Storage Tanks/Vessels	N/A	R5112-3	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MIPTK3105	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
MIPTK3106	Storage Tanks/Vessels	N/A	R5112-4	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MIPTK3107	Storage Tanks/Vessels	N/A	R5112-5	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MIPTK3108	Storage Tanks/Vessels	N/A	R5112-6	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
MIPTK3109	Storage Tanks/Vessels	N/A	R5112-7	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MIPTK3110	Storage Tanks/Vessels	N/A	R5112-4	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MIPTK3110	Storage Tanks/Vessels	N/A	61FF-1	40 CFR Part 61, Subpart FF	No changing attributes.
MIPTK3110	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
MIPTK3123	Storage Tanks/Vessels	N/A	R5112-7	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MIPTK3123	Storage Tanks/Vessels	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
MIPTK3124	Storage Tanks/Vessels	N/A	R5112-7	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MIPTK3124	Storage Tanks/Vessels	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
MPBDAPI	Volatile Organic Compound Water Separators	N/A	R5131-1	30 TAC Chapter 115, Water Separation	No changing attributes.
MPBDM3219	Emission Points/Stationary Vents/Process Vents	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
MPBDM3219	Storage Tanks/Vessels	N/A	R5112-2	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBFL2502	Flares	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
MPBFL2502	Flares	N/A	R5720-1	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
MPBFL2502	Flares	N/A	63A-1A	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is less than 60 ft/s (18.3 m/sec)
MPBFL2502	Flares	N/A	63A-1B	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is greater than 1000 Btu/scf (37.3 MJ/scm).
MPBFL2502	Flares	N/A	63A-1C	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is less than or equal to 1000 Btu/scf (37.3 MJ/scm).
MPBFL2502V	Emission Points/Stationary Vents/Process Vents	N/A	R5720-1	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
MPBFL2502V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-1	30 TAC Chapter 115, Vent Gas Controls	Alternate Control Requirement = Alternate control is not used., Control Device Type = Smokeless flare
MPBFL2502V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-2	30 TAC Chapter 115, Vent Gas Controls	Combined 24-Hour VOC Weight = Combined VOC weight is less than or equal to 100 pounds (45.4 kg)., VOC Concentration = VOC concentration is less than 612 ppmv., VOC Concentration/Emission Rate @ Max Operating Conditions = The

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					VOC concentration or emission rate is less than the applicable exemption limit at maximum actual operating conditions and the alternate recordkeeping requirements of 30 TAC § 115.126(4) are being selected.
MPBFL2502V	Emission Points/Stationary Vents/Process Vents	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
MPBTK3205	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3207	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3208	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3209	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3210	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3211	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3212	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3213	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3214	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3215	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115,	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				Storage of VOCs	
MPBTK3216	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3217	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3218	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3219	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3221	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3224	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTK3226	Emission Points/Stationary Vents/Process Vents	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
MPBTK3226	Emission Points/Stationary Vents/Process Vents	N/A	R5121-3	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
MPBTK3233X	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MPBTRAILER	Storage Tanks/Vessels	N/A	R5112-16	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MSMDM2801	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MSMDM2802	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MSMHT2801A	Process	N/A	R7300-1	30 TAC Chapter 117,	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	Heaters/Furnaces			Subchapter B	
MSMHT2801B	Process Heaters/Furnaces	N/A	R7300-1	30 TAC Chapter 117, Subchapter B	No changing attributes.
MSMHT2801B	Process Heaters/Furnaces	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
MSMLDMISC	Loading/Unloading Operations	N/A	R5211-10	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
MSMTK2801	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MSMTK2802	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MSMTK2803	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
MSMTK2811	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OFXDM4310	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OFXDM4310	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OFXDM4311	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OFXDM4311	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OFXDM4383	Storage Tanks/Vessels	N/A	R5112-8A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OFXDM4383	Storage Tanks/Vessels	N/A	R5112-8B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OFXDM4383	Storage Tanks/Vessels	N/A	61FF-1A	40 CFR Part 61, Subpart FF	No changing attributes.
OFXDM4383	Storage Tanks/Vessels	N/A	61FF-1B	40 CFR Part 61, Subpart FF	No changing attributes.
OFXHT4351	Process Heaters/Furnaces	N/A	R7ICI-3	30 TAC Chapter 117, Subchapter B	No changing attributes.
OFXHT4351	Process Heaters/Furnaces	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
OFXHT4360	Process Heaters/Furnaces	N/A	R7ICI-4	30 TAC Chapter 117, Subchapter B	No changing attributes.
OFXHT4360	Process Heaters/Furnaces	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
OFXHT4360C	Process Heaters/Furnaces	N/A	R7ICI-5	30 TAC Chapter 117, Subchapter B	No changing attributes.
OFXHT4360C	Process Heaters/Furnaces	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
OFXHT4361	Process Heaters/Furnaces	N/A	R7ICI-6	30 TAC Chapter 117, Subchapter B	No changing attributes.
OFXHT4361	Process Heaters/Furnaces	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
OFXR4360AV	Emission Points/Stationary Vents/Process Vents	N/A	R5720-4	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
OFXR4360AV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-16	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OFXR4360BV	Emission Points/Stationary Vents/Process Vents	N/A	R5720-4	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OFXR4360BV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-15	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OFXR4360CV	Emission Points/Stationary Vents/Process Vents	N/A	R5720-1	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
OFXR4360CV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-1	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OFXTW4371	Miscellaneous Units	N/A	65NNNCAR	40 CFR Part 65, Subpart D	No changing attributes.
OLH2FLARE	Flares	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
OP1BL803AV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-34	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule.
OP1BL803AV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-4	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10., Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					scm/min or the VOC concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
OP1BL803BV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-31	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule.
OP1BL803BV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-5	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10., Total

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
OP1CT3811	Industrial Process Cooling Towers	N/A	R5760-2	30 TAC Chapter 115, HRVOC Cooling Towers	No changing attributes.
OP1D3626AV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-10	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP1D3626BV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-11	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1D3635AV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-12	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1D3635BV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-13	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1DECOKE2	Emission Points/Stationary Vents/Process Vents	N/A	R5121-9	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1DM3420V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-37	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1DM3422V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-9	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1DM3453	Volatile Organic Compound Water Separators	N/A	61FF-1	40 CFR Part 61, Subpart FF	No changing attributes.
OP1DM3903	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.0 psia but less than 1.5 psia, Tank Description = Tank does not require emission controls
OP1DM3903	Storage Tanks/Vessels	N/A	R5112-2	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia, Tank Description = Tank using a

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					submerged fill pipe
OP1DM3904	Storage Tanks/Vessels	N/A	R5112-24A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1DM3904	Storage Tanks/Vessels	N/A	R5112-24B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1EN1	SRIC Engines	N/A	R7300-1	30 TAC Chapter 117, Subchapter B	No changing attributes.
OP1EN1	SRIC Engines	N/A	60IIII-1	40 CFR Part 60, Subpart IIII	No changing attributes.
OP1EN1	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
OP1EN2	SRIC Engines	N/A	R7300-2	30 TAC Chapter 117, Subchapter B	No changing attributes.
OP1EN2	SRIC Engines	N/A	60IIII-1	40 CFR Part 60, Subpart IIII	No changing attributes.
OP1EN2	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
OP1EN3	SRIC Engines	N/A	R7300-3	30 TAC Chapter 117, Subchapter B	No changing attributes.
OP1EN3	SRIC Engines	N/A	60IIII-1	40 CFR Part 60, Subpart IIII	No changing attributes.
OP1EN3	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
OP1FL3801	Flares	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
OP1FL3801	Flares	N/A	R5720-1	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP1FL3801	Flares	N/A	60A-1A	40 CFR Part 60, Subpart A	Flare Exit Velocity = Flare exit velocity is less than 60 ft/s (18.3 m/sec)
OP1FL3801	Flares	N/A	60A-1B	40 CFR Part 60, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is greater than 1000 Btu/scf (37.3 MJ/scm)
OP1FL3801	Flares	N/A	60A-1C	40 CFR Part 60, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is less than or equal to 1000 Btu/scf (37.3 MJ/scm).
OP1FL3801	Flares	N/A	63A-1A	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is less than 60 ft/s (18.3 m/sec)
OP1FL3801	Flares	N/A	63A-1B	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is greater than 1000 Btu/scf (37.3 MJ/scm).
OP1FL3801	Flares	N/A	63A-1C	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					value is less than or equal to 1000 Btu/scf (37.3 MJ/scm).
OP1FL3801V	Emission Points/Stationary Vents/Process Vents	N/A	R5720-1	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
OP1FL3801V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-1	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10., VOC Concentration = VOC concentration is less than 612 ppmv., Control Device Type = Smokeless flare, Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
OP1FL3801V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-32	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule., Control Device Type = Smokeless flare
OP1FL3801V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-33	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule., Control Device Type = Vapor recovery system, as defined in 30 TAC § 115.10, other than an afterburner, blast furnace combustion device, boiler, catalytic or direct flame incinerator, carbon adsorption system, chiller, flare or vapor combustor., Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
OP1FL3801V	Emission Points/Stationary Vents/Process Vents	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
OP1FL3801V	Emission Points/Stationary Vents/Process Vents	N/A	63G-3	40 CFR Part 63, Subpart G	No changing attributes.
OP1FL3801V	Emission	N/A	63YY-1	40 CFR Part 63, Subpart	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	Points/Stationary Vents/Process Vents			YY	
OP1HT3415	Emission Points/Stationary Vents/Process Vents	N/A	R1111-5	30 TAC Chapter 111, Visible Emissions	No changing attributes.
OP1HT3415	Process Heaters/Furnaces	N/A	R7ICI-8A	30 TAC Chapter 117, Subchapter B	NOx Monitoring System = Continuous emissions monitoring system, NOx Reduction = Post combustion control technique with ammonia injection, NH3 Emission Limitation = Title 30 TAC § 117.310(c)(2), NH3 Monitoring = Mass balance
OP1HT3415	Process Heaters/Furnaces	N/A	R7ICI-8B	30 TAC Chapter 117, Subchapter B	NOx Monitoring System = Predictive emissions monitoring system, NOx Reduction = No NO_x control method
OP1HT3415	Process Heaters/Furnaces	N/A	R7ICI-8C	30 TAC Chapter 117, Subchapter B	NOx Monitoring System = Continuous emissions monitoring system, NOx Reduction = No NO_x control method
OP1HT3415	Emission Points/Stationary Vents/Process Vents	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP1HT3601	Process Heaters/Furnaces	N/A	R7ICI-4	30 TAC Chapter 117, Subchapter B	No changing attributes.
OP1HT3601	Process Heaters/Furnaces	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
OP1HT3601V	Emission	N/A	R5121-33	30 TAC Chapter 115,	Vent Type = Title 30 TAC

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	Points/Stationary Vents/Process Vents			Vent Gas Controls	Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule.
OP1HT3601V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-6	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10., Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
OP1HT3701	Process Heaters/Furnaces	N/A	R7ICI-3	30 TAC Chapter 117, Subchapter B	No changing attributes.
OP1HT3701	Process Heaters/Furnaces	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
OP1HT3701V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-26	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule.
OP1HT3701V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-7	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10., Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
OP1PV3804A	Emission Points/Stationary Vents/Process Vents	N/A	R5121-38	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1PV3804B	Emission Points/Stationary Vents/Process Vents	N/A	R5121-39	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1RX3701V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-14	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1RX3702V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-15	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1SMLTK14	Emission Points/Stationary Vents/Process Vents	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP1SMLTK30	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.0 psia but less than 1.5 psia, Tank Description = Tank does not require emission controls
OP1SMLTK30	Storage Tanks/Vessels	N/A	R5112-2	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia, Tank Description = Tank using a submerged fill pipe
OP1SP3902	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1SU3406	Emission Points/Stationary Vents/Process Vents	N/A	R5121-23	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1SU3406	Storage Tanks/Vessels	N/A	61FF-6	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP1SU3406	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP1SU3406	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP1SU3406	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP1SU3406	Emission Points/Stationary Vents/Process Vents	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP1SU3407	Emission Points/Stationary Vents/Process Vents	N/A	R5121-24	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1SU3407	Storage Tanks/Vessels	N/A	61FF-6	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP1SU3407	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP1SU3407	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP1SU3407	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP1SU3407	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
OP1SU3407	Storage Tanks/Vessels	N/A	63G-11	40 CFR Part 63, Subpart G	No changing attributes.
OP1SU3407	Storage Tanks/Vessels	N/A	63G-12	40 CFR Part 63, Subpart G	No changing attributes.
OP1SU3407	Emission Points/Stationary Vents/Process Vents	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP1SU3502	Emission Points/Stationary Vents/Process Vents	N/A	R5121-26	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1SU3502	Storage Tanks/Vessels	N/A	61FF-6	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP1SU3502	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP1SU3502	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP1SU3502	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP1SU3502	Emission Points/Stationary Vents/Process Vents	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP1SU3671	Emission Points/Stationary Vents/Process Vents	N/A	R5121-25	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1SU3671	Storage Tanks/Vessels	N/A	61FF-6	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP1SU3671	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP1SU3671	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP1SU3671	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP1SU3671	Emission Points/Stationary Vents/Process Vents	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP1SU38094	Wastewater Units	N/A	R5140-6	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
OP1SU38094	Volatile Organic Compound Water Separators	N/A	61FF-5	40 CFR Part 61, Subpart FF	Carbon Replacement Interval = EXHAUST IS MONITORED ON A REGULAR SCHEDULE AND CARBON IS REPLACED IMMEDIATELY UPON BREAKTHROUGH, By-Pass Line = THE CLOSED VENT SYSTEM HAS NO BY-PASS LINE, Engineering Calculations = PERFORANCE TEST IS BEING USED TO DETERMINE COMPLIANCE OF A CONTROL DEVICE, Control Device Type/Operation = CARBON ADSORPTION SYSTEM NOT REGENERATING BED DIRECTLY IN DEVICE
OP1SU38094	Volatile Organic	N/A	61FF-6	40 CFR Part 61, Subpart	Alternate Monitoring Parameters

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	Compound Water Separators			FF	= COMPLYING WITH THE MONITORING REQUIREMENTS OF SUBPART FF, By-Pass Line = THE CLOSED VENT SYSTEM HAS A BY-PASS LINE THAT COULD DIVERT THE STREAM AWAY FROM THE CONTROL DEVICE, By-Pass Line Valve = A FLOW INDICATOR IS INSTALLED AT THE ENTRANCE TO THE BY-PASS LINE., Engineering Calculations = ENGINEERING CALCULATIONS ARE USED TO DEMONSTRATE CONTROL DEVICE PERFORMANCE, Control Device Type/Operation = BOILER OR PROCESS HEATER, DESIGN HEAT INPUT >=44 MW, REDUCING ORGANICS BY 95 WEIGHT PERCENT OR GREATER
OP1SU38094	Volatile Organic Compound Water Separators	N/A	61FF-7	40 CFR Part 61, Subpart FF	Alternate Monitoring Parameters = COMPLYING WITH THE MONITORING REQUIREMENTS OF SUBPART FF, By-Pass Line = THE CLOSED VENT SYSTEM HAS A BY-PASS LINE THAT COULD DIVERT THE STREAM AWAY FROM THE CONTROL DEVICE, By-Pass Line Valve = A FLOW INDICATOR IS

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					INSTALLED AT THE ENTRANCE TO THE BY-PASS LINE., Engineering Calculations = ENGINEERING CALCULATIONS ARE USED TO DEMONSTRATE CONTROL DEVICE PERFORMANCE, Control Device Type/Operation = BOILER OR PROCESS HEATER, DESIGN HEAT INPUT >=44MW, ACHIEVING TOC CONCENTRATION OF 20 PPMV
OP1SU38094	Volatile Organic Compound Water Separators	N/A	61FF-8	40 CFR Part 61, Subpart FF	Alternate Monitoring Parameters = COMPLYING WITH THE MONITORING REQUIREMENTS OF SUBPART FF, By-Pass Line = THE CLOSED VENT SYSTEM HAS A BY-PASS LINE THAT COULD DIVERT THE STREAM AWAY FROM THE CONTROL DEVICE, By-Pass Line Valve = A FLOW INDICATOR IS INSTALLED AT THE ENTRANCE TO THE BY-PASS LINE., Engineering Calculations = PERFORANCE TEST IS BEING USED TO DETERMINE COMPLIANCE OF A CONTROL DEVICE, Control Device Type/Operation = BOILER OR PROCESS HEATER, DESIGN HEAT INPUT >=44 MW,

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					REDUCING ORGANICS BY 95 WEIGHT PERCENT OR GREATER
OP1SU38094	Volatile Organic Compound Water Separators	N/A	61FF-9	40 CFR Part 61, Subpart FF	Alternate Monitoring Parameters = COMPLYING WITH THE MONITORING REQUIREMENTS OF SUBPART FF, By-Pass Line = THE CLOSED VENT SYSTEM HAS A BY-PASS LINE THAT COULD DIVERT THE STREAM AWAY FROM THE CONTROL DEVICE, By-Pass Line Valve = A FLOW INDICATOR IS INSTALLED AT THE ENTRANCE TO THE BY-PASS LINE., Engineering Calculations = PERFORANCE TEST IS BEING USED TO DETERMINE COMPLIANCE OF A CONTROL DEVICE, Control Device Type/Operation = BOILER OR PROCESS HEATER, DESIGN HEAT INPUT >=44MW, ACHIEVING TOC CONCENTRATION OF 20 PPMV
OP1SU38094	Volatile Organic Compound Water Separators	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
OP1SU38094	Volatile Organic Compound Water Separators	N/A	63G-13	40 CFR Part 63, Subpart G	Performance Test =, 95% Reduction Efficiency =

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP1SU38094	Volatile Organic Compound Water Separators	N/A	63G-14	40 CFR Part 63, Subpart G	Performance Test =
OP1SU38094	Emission Points/Stationary Vents/Process Vents	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP1SU38099	Emission Points/Stationary Vents/Process Vents	N/A	R5121-22	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1SU38099	Storage Tanks/Vessels	N/A	61FF-6	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP1SU38099	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					to 3% oxygen
OP1SU38099	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP1SU38099	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP1SU38601	Emission Points/Stationary Vents/Process Vents	N/A	R5121-21	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP1TK3406	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1TK3406	Storage Tanks/Vessels	N/A	61FF-6	40 CFR Part 61, Subpart	Engineering Calculations =

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				FF	Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP1TK3406	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP1TK3406	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					being greater than or equal to 95 weight percent
OP1TK3406	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP1TK3455	Wastewater Units	N/A	R5140-15	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
OP1TK3455	Storage Tanks/Vessels	N/A	60Kb-1	40 CFR Part 60, Subpart Kb	No changing attributes.
OP1TK3455	Storage Tanks/Vessels	N/A	61FF-5	40 CFR Part 61, Subpart FF	No changing attributes.
OP1TK3455	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP1TK3458	Wastewater Units	N/A	R5140-6	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
OP1TK3458	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1TK3458	Storage Tanks/Vessels	N/A	61FF-6	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP1TK3458	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP1TK3458	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP1TK3458	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP1TK3501	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.0 psia but less than 1.5 psia, Tank Description = Tank does not require emission controls
OP1TK3501	Storage Tanks/Vessels	N/A	R5112-2	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia, Tank Description = Tank using a submerged fill pipe
OP1TK3601	Storage Tanks/Vessels	N/A	R5112-6	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia, Tank Description = Tank using a submerged fill pipe
OP1TK3601	Storage Tanks/Vessels	N/A	R5112-6B	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.0 psia but less than 1.5 psia, Tank Description

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					= Tank does not require emission controls
OP1TK38008	Wastewater Units	N/A	R5140-1	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
OP1TK38008	Storage Tanks/Vessels	N/A	61FF-2	40 CFR Part 61, Subpart FF	No changing attributes.
OP1TK38008	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
OP1TK38008	Storage Tanks/Vessels	N/A	63G-2	40 CFR Part 63, Subpart G	No changing attributes.
OP1TK38008	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP1TK38009	Wastewater Units	N/A	R5140-2	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
OP1TK38009	Storage Tanks/Vessels	N/A	61FF-3	40 CFR Part 61, Subpart FF	No changing attributes.
OP1TK38009	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
OP1TK38009	Storage Tanks/Vessels	N/A	63G-3	40 CFR Part 63, Subpart G	No changing attributes.
OP1TK38009	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP1TK38303	Storage Tanks/Vessels	N/A	R5112-12	30 TAC Chapter 115, Storage of VOCs	Tank Description = Tank using an internal floating roof (IFR)
OP1TK38303	Storage Tanks/Vessels	N/A	R5112-12A	30 TAC Chapter 115, Storage of VOCs	Tank Description = Tank does not require emission controls
OP1TK3903	Wastewater Units	N/A	R5140-16A	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP1TK3908	Storage Tanks/Vessels	N/A	R5112-7A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1TK3908	Storage Tanks/Vessels	N/A	R5112-7B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1TK3909	Storage Tanks/Vessels	N/A	R5112-8A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1TK3909	Storage Tanks/Vessels	N/A	R5112-8B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1TK3910	Storage Tanks/Vessels	N/A	R5112-9A	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1TK3910	Storage Tanks/Vessels	N/A	R5112-9B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1TK3911	Storage Tanks/Vessels	N/A	R5112-4	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1TK3911	Storage Tanks/Vessels	N/A	60K-4	40 CFR Part 60, Subpart K	No changing attributes.
OP1TK3911	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP1TK3912	Storage Tanks/Vessels	N/A	R5112-4	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1TK3912	Storage Tanks/Vessels	N/A	60K-5	40 CFR Part 60, Subpart K	No changing attributes.
OP1TK3912	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
OP1TK3943	Storage Tanks/Vessels	N/A	R5112-E1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP1TK3943	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP1TK4501	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.0 psia but less than 1.5 psia, Tank Description = Tank does not require emission controls
OP1TK4501	Storage Tanks/Vessels	N/A	R5112-2	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia, Tank Description = Tank using a submerged fill pipe
OP1TW3407	Treatment Process	N/A	61FF-1A	40 CFR Part 61, Subpart FF	Treatment Process Engineering Calculations = Engineering calculations show that the treatment process or wastewater treatment system unit is proven to achieve its emission limitation.
OP1TW3407	Treatment Process	N/A	61FF-1B	40 CFR Part 61, Subpart FF	Treatment Process Engineering Calculations = Engineering calculations show that the treatment process or wastewater treatment system unit is proven to achieve its emission limitation.
OP1TW3407	Treatment Process	N/A	61FF-1C	40 CFR Part 61, Subpart FF	Treatment Process Engineering Calculations = Performance tests are used to show that the treatment process or wastewater treatment system unit achieves its emission limitation., Continuous Monitoring = The wastewater

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					treatment system unit process parameters are continuously monitored to indicate proper system operation.
OP1TW3407	Treatment Process	N/A	61FF-1D	40 CFR Part 61, Subpart FF	Treatment Process Engineering Calculations = Performance tests are used to show that the treatment process or wastewater treatment system unit achieves its emission limitation., Continuous Monitoring = The wastewater treatment system unit process parameters are continuously monitored to indicate proper system operation.
OP1TW3407	Treatment Process	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
OP1TW3407	Treatment Process	N/A	63FFFF-2	40 CFR Part 63, Subpart FFFF	No changing attributes.
OP1TW3407	Treatment Process	N/A	63G-7A	40 CFR Part 63, Subpart G	Treatment Process Design Evaluation = Compliance for the treatment process will be demonstrated using design evaluation.
OP1TW3407	Treatment Process	N/A	63G-7B	40 CFR Part 63, Subpart G	Treatment Process Design Evaluation = Compliance for the treatment process will be demonstrated by performance test.
OP1TW3407	Treatment Process	N/A	63G-7C	40 CFR Part 63, Subpart G	Treatment Process Design Evaluation = Compliance for the

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					treatment process will be demonstrated using design evaluation.
OP1TW3407	Treatment Process	N/A	63G-7D	40 CFR Part 63, Subpart G	Treatment Process Design Evaluation = Compliance for the treatment process will be demonstrated by performance test.
OP1TW3407	Treatment Process	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP1TW3453	Miscellaneous Units	N/A	65NNNCAR	40 CFR Part 65, Subpart D	No changing requirements.
OP1TW3616	Miscellaneous Units	N/A	65NNNCAR	40 CFR Part 65, Subpart D	No changing requirements.
OP1TW3617	Miscellaneous Units	N/A	65NNNCAR	40 CFR Part 65, Subpart D	No changing requirements.
OP2BL803AV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-31	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule.
OP2BL803AV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-7	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10., Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
OP2BL803BV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-32	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule.
OP2BL803BV	Emission Points/Stationary	N/A	R5121-8	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream originates from a synthetic

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	Vents/Process Vents				organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10., Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
OP2CT4811	Industrial Process Cooling Towers	N/A	R5760-3	30 TAC Chapter 115, HRVOC Cooling Towers	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP2D4626AV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-11	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2D4626BV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-12	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2D4635AV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-13	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2D4635BV	Emission Points/Stationary Vents/Process Vents	N/A	R5121-14	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2DECOKE2	Emission Points/Stationary Vents/Process Vents	N/A	R5121-9	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2DM4420V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-41	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2DM4422V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-40	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2DM4453	Volatile Organic Compound Water Separators	N/A	61FF-1	40 CFR Part 61, Subpart FF	No changing attributes.
OP2EN1	SRIC Engines	N/A	R7300-1	30 TAC Chapter 117, Subchapter B	No changing attributes.
OP2EN1	SRIC Engines	N/A	60IIII-1	40 CFR Part 60, Subpart IIII	No changing attributes.
OP2EN1	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP2EN2	SRIC Engines	N/A	R7300-2	30 TAC Chapter 117, Subchapter B	No changing attributes.
OP2EN2	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
OP2EN3	SRIC Engines	N/A	R7300-3	30 TAC Chapter 117, Subchapter B	No changing attributes.
OP2EN3	SRIC Engines	N/A	60IIII-1	40 CFR Part 60, Subpart IIII	No changing attributes.
OP2EN3	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
OP2FL4801	Flares	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
OP2FL4801	Flares	N/A	R5720-1	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
OP2FL4801	Flares	N/A	60A-1A	40 CFR Part 60, Subpart A	Flare Exit Velocity = Flare exit velocity is less than 60 ft/s (18.3 m/sec)
OP2FL4801	Flares	N/A	60A-1B	40 CFR Part 60, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is greater than 1000 Btu/scf (37.3 MJ/scm)
OP2FL4801	Flares	N/A	60A-1C	40 CFR Part 60, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is less than or equal to

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					1000 Btu/scf (37.3 MJ/scm).
OP2FL4801	Flares	N/A	63A-1A	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is less than 60 ft/s (18.3 m/sec)
OP2FL4801	Flares	N/A	63A-1B	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is greater than 1000 Btu/scf (37.3 MJ/scm).
OP2FL4801	Flares	N/A	63A-1C	40 CFR Part 63, Subpart A	Flare Exit Velocity = Flare exit velocity is greater than or equal to 60 ft/s (18.3 m/sec) but less than 400 ft/s (122 m/sec)., Heating Value of Gas = Heating value is less than or equal to 1000 Btu/scf (37.3 MJ/scm).
OP2FL4801V	Emission Points/Stationary Vents/Process Vents	N/A	R5720-1	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
OP2FL4801V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-10	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule., Control Device Type = Vapor recovery system, as defined in 30 TAC § 115.10, other than an afterburner, blast furnace combustion device, boiler, catalytic or direct flame

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					incinerator, carbon adsorption system, chiller, flare or vapor combustor., Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
OP2FL4801V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-33	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					applicable and the vent is not specifically classified under the rule., Control Device Type = Smokeless flare
OP2FL4801V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-9	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10., Control Device Type = Smokeless flare, Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
OP2FL4801V	Emission Points/Stationary Vents/Process Vents	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
OP2FL4801V	Emission Points/Stationary Vents/Process Vents	N/A	63G-2	40 CFR Part 63, Subpart G	No changing attributes.
OP2FL4801V	Emission Points/Stationary Vents/Process Vents	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP2HT4601	Process Heaters/Furnaces	N/A	R7ICI-7	30 TAC Chapter 117, Subchapter B	No changing attributes.
OP2HT4601	Process Heaters/Furnaces	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
OP2HT4601V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-10	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Vent gas stream originates from a synthetic organic chemical manufacturing industry reactor process or distillation operation, as defined in 30 TAC § 115.10., Total Design Capacity = Total design capacity is greater than or equal to 1,100 tons per year for all chemicals produced within that unit., Flow Rate or VOC Concentration = Flow rate is greater than or equal to 0.011 scm/min or the VOC

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					concentration is greater than or equal to 500 ppmv., 40 CFR 60 Subpart NNN Requirements = The distillation unit vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart NNN: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices., 40 CFR 60 Subpart RRR Requirements = The reactor process vent gas stream satisfies neither of the following requirements of 40 CFR Part 60, Subpart RRR: TRE index value is greater than 8.0; or TRE index value is greater than 1.0 without the use of VOC emission control devices.
OP2HT4601V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-34	30 TAC Chapter 115, Vent Gas Controls	Vent Type = Title 30 TAC Chapter 115, Subchapter B, Vent Gas Control rules are applicable and the vent is not specifically classified under the rule.
OP2LOAD	Loading/Unloading Operations	N/A	R5211-1	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
OP2PV4804A	Emission Points/Stationary Vents/Process Vents	N/A	R5121-42	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP2PV4804B	Emission Points/Stationary Vents/Process Vents	N/A	R5121-43	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2RX4701V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-17	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2RX4703V	Emission Points/Stationary Vents/Process Vents	N/A	R5121-18	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2SMLTK31	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.0 psia but less than 1.5 psia, Tank Description = Tank does not require emission controls
OP2SMLTK31	Storage Tanks/Vessels	N/A	R5112-2	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia, Tank Description = Tank using a submerged fill pipe
OP2SU4406	Emission Points/Stationary Vents/Process Vents	N/A	R5121-26	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2SU4406	Storage Tanks/Vessels	N/A	61FF-6	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					reduction of organics being greater than or equal to 95 weight percent
OP2SU4406	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP2SU4406	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP2SU4406	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP2SU4406	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP2SU4407	Emission Points/Stationary Vents/Process Vents	N/A	R5121-27	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2SU4407	Storage Tanks/Vessels	N/A	61FF-6	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP2SU4407	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP2SU4407	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP2SU4407	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP2SU4407	Storage Tanks/Vessels	N/A	63G-10	40 CFR Part 63, Subpart G	No changing attributes.
OP2SU4407	Storage Tanks/Vessels	N/A	63G-12	40 CFR Part 63, Subpart	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				G	
OP2SU4407	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP2SU4502	Emission Points/Stationary Vents/Process Vents	N/A	R5121-29	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2SU4502	Storage Tanks/Vessels	N/A	61FF-6	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP2SU4502	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP2SU4502	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart	Engineering Calculations =

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				FF	Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP2SU4502	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP2SU4502	Emission Points/Stationary Vents/Process Vents	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP2SU4671	Emission Points/Stationary Vents/Process Vents	N/A	R5121-19	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2SU4671	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP2SU4671	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP2SU4671	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					ppmv on a dry basis corrected to 3% oxygen
OP2SU4671	Emission Points/Stationary Vents/Process Vents	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP2SU48094	Wastewater Units	N/A	R5140-6	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
OP2SU48094	Volatile Organic Compound Water Separators	N/A	R5131-9	30 TAC Chapter 115, Water Separation	No changing attributes.
OP2SU48094	Volatile Organic Compound Water Separators	N/A	61FF-5	40 CFR Part 61, Subpart FF	Carbon Replacement Interval = EXHAUST IS MONITORED ON A REGULAR SCHEDULE AND CARBON IS REPLACED IMMEDIATELY UPON BREAKTHROUGH, By-Pass Line = THE CLOSED VENT SYSTEM HAS NO BY-PASS LINE, Engineering Calculations = PERFORANCE TEST IS BEING USED TO DETERMINE COMPLIANCE OF A CONTROL DEVICE, Control Device Type/Operation = CARBON ADSORPTION SYSTEM NOT REGENERATING BED DIRECTLY IN DEVICE
OP2SU48094	Volatile Organic Compound Water Separators	N/A	61FF-6	40 CFR Part 61, Subpart FF	Alternate Monitoring Parameters = COMPLYING WITH THE MONITORING REQUIREMENTS OF SUBPART FF, By-Pass Line =

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					THE CLOSED VENT SYSTEM HAS A BY-PASS LINE THAT COULD DIVERT THE STREAM AWAY FROM THE CONTROL DEVICE, By-Pass Line Valve = A FLOW INDICATOR IS INSTALLED AT THE ENTRANCE TO THE BY-PASS LINE., Engineering Calculations = ENGINEERING CALCULATIONS ARE USED TO DEMONSTRATE CONTROL DEVICE PERFORMANCE, Control Device Type/Operation = BOILER OR PROCESS HEATER, DESIGN HEAT INPUT >=44 MW, REDUCING ORGANICS BY 95 WEIGHT PERCENT OR GREATER
OP2SU48094	Volatile Organic Compound Water Separators	N/A	61FF-7	40 CFR Part 61, Subpart FF	Alternate Monitoring Parameters = COMPLYING WITH THE MONITORING REQUIREMENTS OF SUBPART FF, By-Pass Line = THE CLOSED VENT SYSTEM HAS A BY-PASS LINE THAT COULD DIVERT THE STREAM AWAY FROM THE CONTROL DEVICE, By-Pass Line Valve = A FLOW INDICATOR IS INSTALLED AT THE ENTRANCE TO THE BY-PASS LINE., Engineering Calculations = ENGINEERING

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					CALCULATIONS ARE USED TO DEMONSTRATE CONTROL DEVICE PERFORMANCE, Control Device Type/Operation = BOILER OR PROCESS HEATER, DESIGN HEAT INPUT >=44MW, ACHIEVING TOC CONCENTRATION OF 20 PPMV
OP2SU48094	Volatile Organic Compound Water Separators	N/A	61FF-8	40 CFR Part 61, Subpart FF	Alternate Monitoring Parameters = COMPLYING WITH THE MONITORING REQUIREMENTS OF SUBPART FF, By-Pass Line = THE CLOSED VENT SYSTEM HAS A BY-PASS LINE THAT COULD DIVERT THE STREAM AWAY FROM THE CONTROL DEVICE, By-Pass Line Valve = A FLOW INDICATOR IS INSTALLED AT THE ENTRANCE TO THE BY-PASS LINE., Engineering Calculations = PERFORANCE TEST IS BEING USED TO DETERMINE COMPLIANCE OF A CONTROL DEVICE, Control Device Type/Operation = BOILER OR PROCESS HEATER, DESIGN HEAT INPUT >=44 MW, REDUCING ORGANICS BY 95 WEIGHT PERCENT OR GREATER

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP2SU48094	Volatile Organic Compound Water Separators	N/A	61FF-9	40 CFR Part 61, Subpart FF	Alternate Monitoring Parameters = COMPLYING WITH THE MONITORING REQUIREMENTS OF SUBPART FF, By-Pass Line = THE CLOSED VENT SYSTEM HAS A BY-PASS LINE THAT COULD DIVERT THE STREAM AWAY FROM THE CONTROL DEVICE, By-Pass Line Valve = A FLOW INDICATOR IS INSTALLED AT THE ENTRANCE TO THE BY-PASS LINE., Engineering Calculations = PERFORANCE TEST IS BEING USED TO DETERMINE COMPLIANCE OF A CONTROL DEVICE, Control Device Type/Operation = BOILER OR PROCESS HEATER, DESIGN HEAT INPUT >=44MW, ACHIEVING TOC CONCENTRATION OF 20 PPMV
OP2SU48094	Volatile Organic Compound Water Separators	N/A	63G-13	40 CFR Part 63, Subpart G	Performance Test =, 95% Reduction Efficiency =
OP2SU48094	Volatile Organic Compound Water Separators	N/A	63G-14	40 CFR Part 63, Subpart G	Performance Test =
OP2SU48099	Emission Points/Stationary Vents/Process Vents	N/A	R5121-25	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP2SU48099	Storage Tanks/Vessels	N/A	61FF-6	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP2SU48099	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP2SU48099	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					and with a reduction of organics being greater than or equal to 95 weight percent
OP2SU48099	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP2SU48099	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP2SU48601	Emission Points/Stationary Vents/Process Vents	N/A	R5121-21	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
OP2TK4451	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP2TK4455	Wastewater Units	N/A	R5140-6	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
OP2TK4455	Storage Tanks/Vessels	N/A	60Kb-3	40 CFR Part 60, Subpart Kb	No changing attributes.
OP2TK4455	Storage Tanks/Vessels	N/A	61FF-2	40 CFR Part 61, Subpart FF	No changing attributes.
OP2TK4455	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP2TK4456	Storage Tanks/Vessels	N/A	R5112-10	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP2TK4458	Wastewater Units	N/A	R5140-6	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
OP2TK4458	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP2TK4458	Storage Tanks/Vessels	N/A	61FF-6	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP2TK4458	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP2TK4458	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart	Engineering Calculations =

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				FF	Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP2TK4458	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP2TK4465	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP2TK4465	Storage Tanks/Vessels	N/A	61FF-6	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP2TK4465	Storage Tanks/Vessels	N/A	61FF-7	40 CFR Part 61, Subpart FF	Engineering Calculations = Engineering calculations show that the control device is proven to achieve its emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP2TK4465	Storage Tanks/Vessels	N/A	61FF-8	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and with a reduction of organics being greater than or equal to 95 weight percent
OP2TK4465	Storage Tanks/Vessels	N/A	61FF-9	40 CFR Part 61, Subpart FF	Engineering Calculations = Results of performance tests are used to demonstrate that

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					the control device achieves emission limitation., Control Device Type/Operations = Boiler or process heater having a design heat input capacity greater than or equal to 44 MW and that achieves a total organic compound concentration of 20 ppmv on a dry basis corrected to 3% oxygen
OP2TK4601	Storage Tanks/Vessels	N/A	R5112-9	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.5 psia, Tank Description = Tank using a submerged fill pipe
OP2TK4601	Storage Tanks/Vessels	N/A	R5112-9B	30 TAC Chapter 115, Storage of VOCs	True Vapor Pressure = True vapor pressure is greater than or equal to 1.0 psia but less than 1.5 psia, Tank Description = Tank does not require emission controls
OP2TK48007	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP2TK48007	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP2TK48008	Wastewater Units	N/A	R5140-1	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
OP2TK48008	Storage Tanks/Vessels	N/A	61FF-2	40 CFR Part 61, Subpart FF	No changing attributes.
OP2TK48008	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
OP2TK48008	Storage Tanks/Vessels	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
OP2TK48008	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP2TK48009	Wastewater Units	N/A	R5140-1	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
OP2TK48009	Storage Tanks/Vessels	N/A	61FF-3	40 CFR Part 61, Subpart FF	No changing attributes.
OP2TK48009	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
OP2TK48009	Storage Tanks/Vessels	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
OP2TK48009	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP2TK48105	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP2TK48303	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP2TK48303	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP2TK4901	Storage Tanks/Vessels	N/A	R5112-1B	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP2TK4901	Storage Tanks/Vessels	N/A	60K-1A	40 CFR Part 60, Subpart K	No changing attributes.
OP2TK4901	Storage Tanks/Vessels	N/A	60K-1B	40 CFR Part 60, Subpart K	No changing attributes.
OP2TK4901	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				YY	
OP2TK4915	Storage Tanks/Vessels	N/A	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP2TK4916	Storage Tanks/Vessels	N/A	R5112-4	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP2TK4916	Storage Tanks/Vessels	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
OP2TK4921	Storage Tanks/Vessels	N/A	R5112-12	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP2TK4921	Storage Tanks/Vessels	N/A	60K-4A	40 CFR Part 60, Subpart K	No changing attributes.
OP2TK4921	Storage Tanks/Vessels	N/A	60K-4B	40 CFR Part 60, Subpart K	No changing attributes.
OP2TK4921	Storage Tanks/Vessels	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
OP2TK4922	Storage Tanks/Vessels	N/A	R5112-6	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
OP2TK4922	Storage Tanks/Vessels	N/A	60Kb-1	40 CFR Part 60, Subpart Kb	No changing attributes.
OP2TK4922	Storage Tanks/Vessels	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
OP2TW4616	Miscellaneous Units	N/A	65NNNCAR	40 CFR Part 65, Subpart D	No changing attributes.
OP2TW4617	Miscellaneous Units	N/A	65NNNCAR	40 CFR Part 65, Subpart D	No changing attributes.
PRO-ALKY	Chemical Manufacturing Process	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
PRO-BT	Chemical Manufacturing Process	N/A	63F-1	40 CFR Part 63, Subpart F	No changing attributes.
PRO-C4	Chemical Manufacturing Process	N/A	63F-1	40 CFR Part 63, Subpart F	No changing attributes.
PRO-C5	Chemical Manufacturing Process	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
PRO-DPG	Chemical Manufacturing Process	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
PRO-FLEX	Chemical Manufacturing Process	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
PRO-IPOH	Chemical Manufacturing Process	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
PRO-MEO	Chemical Manufacturing Process	N/A	63F-1	40 CFR Part 63, Subpart F	No changing attributes.
PRO-MTBE	Chemical Manufacturing Process	N/A	63F-1	40 CFR Part 63, Subpart F	No changing attributes.
PRO-OP1	Chemical Manufacturing Process	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
PRO-OP2	Chemical Manufacturing Process	N/A	63YY-1	40 CFR Part 63, Subpart YY	No changing attributes.
PRO-POLYBD	Chemical Manufacturing Process	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
PRO-SMA	Chemical Manufacturing Process	N/A	63FFFF-1	40 CFR Part 63, Subpart FFFF	No changing attributes.
WASTEWATER	Wastewater Units	N/A	R5140-16A	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
ZMSENAIS	SRIC Engines	N/A	R71C1-1	30 TAC Chapter 117, Subchapter B	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
ZMSENAIS	SRIC Engines	N/A	60IIII-1	40 CFR Part 60, Subpart IIII	No changing attributes.
ZMSENAIS	SRIC Engines	N/A	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
ZMSZZCOAT	Surface Coating Operations	N/A	R5421-1	30 TAC Chapter 115, Surface Coating Operations	Facility Operations = Surface coating of wood parts and products., Wood Coating Type = Enamel or opaque ground coat.
ZMSZZCOAT	Surface Coating Operations	N/A	R5421-2	30 TAC Chapter 115, Surface Coating Operations	Facility Operations = Surface coating of wood parts and products., Wood Coating Type = Semitransparent wiping or glazing stain.
ZMSZZCOAT	Surface Coating Operations	N/A	R5421-3	30 TAC Chapter 115, Surface Coating Operations	Facility Operations = Other miscellaneous metal parts and products coating., Alternate Requirements = No alternate requirement to 30 TAC §§ 115.421(a)(9) or 115.421(b)(8) has been approved or no alternate has been requested., Miscellaneous Coating Type = Extreme performance coating, including chemical milling maskants., Maintenance Shop = Recoating used miscellaneous metal parts and products at an on-site maintenance shop that began operations before January 1, 2012.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EALSP4066	EP	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
EALSP4066	EP	R5121-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
EALTK17	EU	R5112-4A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EALTK17	EU	R5112-4B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EALTK17	EU	R5112-4C	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EALTK17	EU	R5112-4D	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EALTK32	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)
EALTK32	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2470(a)-Table4.1.b.i § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(B) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii)	For each Group 1 storage tank for which the maximum true vapor pressure of total HAP at the storage temperature is < 76.6 kilopascals, you must comply with the requirements of Subpart WW of this part, except as specified in	§ 63.1063(c)(2) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d)	§ 63.1063(c)(2)(iv)(B) [G]§ 63.1066(a) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.2450(q)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(viii) § 63.1063(a)(2)(viii)(A) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2) § 63.2470(a)	§63.2470.			
EALTK33	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)
EALTK33	EU	60Kb-1	VOC	40 CFR Part 60, Subpart Kb	[G]§ 60.112b(a)(2)	Storage vessels specified in §60.112b(a) and equipped with an external floating roof (pontoon or double-deck type) are to meet the specifications of	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B)	§ 60.115b [G]§ 60.115b(b)(3) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						§60.112b(a)(2)(i)-(iii).	[G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) [G]§ 60.113b(b)(6) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3)		
EALTK33	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2470(a)-Table4.1.b.i § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(B) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(viii) § 63.1063(a)(2)(viii)(A) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2) § 63.2470(a)	For each Group 1 storage tank for which the maximum true vapor pressure of total HAP at the storage temperature is < 76.6 kilopascals, you must comply with the requirements of Subpart WW of this part, except as specified in §63.2470.	§ 63.1063(c)(2) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d)	§ 63.1063(c)(2)(iv)(B) [G]§ 63.1066(a) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.2450(q)
EALTK37	EU	R5112-8	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EALTK37	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2470(a)-Table4.1.b.i § 63.1062(a) § 63.1062(a)(1) § 63.1063(a)(1)(i) § 63.1063(a)(1)(i)(B) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(iv) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(viii) § 63.1063(a)(2)(viii)(A) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(e)(1) § 63.1063(e)(2) § 63.2470(a)	For each Group 1 storage tank for which the maximum true vapor pressure of total HAP at the storage temperature is < 76.6 kilopascals, you must comply with the requirements of Subpart WW of this part, except as specified in §63.2470.	§ 63.1063(c)(1) [G]§ 63.1063(c)(1)(i) [G]§ 63.1063(d)(1) § 63.1063(d)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(c) § 63.1065(d)	[G]§ 63.1066(a) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.2450(q)
EALTK402	EU	R5112-5A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EALTK402	EU	R5112-5B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EALTK402	EU	R5112-5C	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EALTK402	EU	R5112-5D	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EALTK402	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2470(a)-Table4.1.a.ii § 63.11(b) § 63.2450(b) § 63.2470(a) § 63.2470(d) § 63.982(b) § 63.983(a)(1) § 63.983(a)(2)	For each Group 1 storage tank for which the maximum true vapor pressure of total HAP at the storage temperature is > 76.6 kilopascals, you must reduce total organic HAP emissions by venting emissions	[G]§ 63.115(d)(2)(v) § 63.115(d)(3)(iii) § 63.2470(c)(1) § 63.983(b) [G]§ 63.983(b)(1) [G]§ 63.983(b)(2) [G]§ 63.983(b)(3) [G]§ 63.983(c)(1) § 63.983(c)(2)	§ 63.2450(f)(2) § 63.2450(f)(2)(i) § 63.2450(f)(2)(ii) § 63.2470(c)(1) § 63.983(b) [G]§ 63.983(d)(2) § 63.987(c) § 63.998(a)(1)(ii) § 63.998(a)(1)(iii)(A)	§ 63.2450(f)(2)(ii) § 63.2450(q) § 63.2470(d) § 63.997(b)(2) § 63.997(c)(3) § 63.998(a)(1)(iii)(A) [G]§ 63.998(b)(3) [G]§ 63.999(a)(1) § 63.999(b)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.983(d)(1) § 63.983(d)(1)(i) [G]§ 63.983(d)(2) § 63.983(d)(3) § 63.987(a) § 63.997(b)(2) § 63.997(b)(3) § 63.997(c)(3)	through a closed vent system to a flare.	§ 63.983(c)(3) § 63.983(d)(1) § 63.983(d)(1)(ii) § 63.987(c) § 63.997(b) § 63.997(c)(2) § 63.997(c)(3) § 63.997(c)(3)(i) § 63.997(c)(3)(ii)	§ 63.998(a)(1)(iii)(B) [G]§ 63.998(b)(1) [G]§ 63.998(b)(2) [G]§ 63.998(b)(3) [G]§ 63.998(b)(5) [G]§ 63.998(c)(1) [G]§ 63.998(d)(1) § 63.998(d)(3)(i) § 63.998(d)(3)(ii) § 63.998(d)(5)	§ 63.999(c)(1) § 63.999(c)(2)(i) § 63.999(c)(3) § 63.999(c)(6) [G]§ 63.999(c)(6)(i) § 63.999(c)(6)(iv) [G]§ 63.999(d)(1) [G]§ 63.999(d)(2)
EALTK7	EU	R5112-4A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EALTK7	EU	R5112-4B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EALTK7	EU	R5112-4C	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(A) § 115.112(e)(3)(A)(i)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(1) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EALTK7	EU	R5112-4D	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EALTK7	EU	R5112-4E	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EALTK8	EU	R5112-4A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EALTK8	EU	R5112-4B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EALTK8	EU	R5112-4C	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(A) § 115.112(e)(3)(A)(i)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(1) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this paragraph for crude oil and condensate.			
EALTK8	EU	R5112-4D	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EALTK8	EU	R5112-4E	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EBGEG6901	EU	R7300-10	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
EBGEG6901	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(b) § 63.6640(f)(1) [G]§ 63.6640(f)(2) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii § 63.6640(b)	§ 63.6625(i) § 63.6655(a) § 63.6655(a)(1) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(b) § 63.6640(e) § 63.6650(f)
EBGTK6902	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
EBGTK6904	EU	R5112-	VOC	30 TAC Chapter	§ 115.111(a)(1)	Except as provided in §	[G]§ 115.117	§ 115.118(a)(1)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		1		115, Storage of VOCs		115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.		§ 115.118(a)(5) § 115.118(a)(7)	
EBGTK6905	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
EBGVC6904	EU	R7300-9	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) [G]§ 117.310(a)(16) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
EBGVC6904	EU	R7300-9	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)		§ 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
EC4DM21	EU	R5112-1A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EC4DM21	EU	R5112-1B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EC4DM21	EU	R5112-1C	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(A) § 115.112(e)(3)(A)(i)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(1) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EC4DM21	EU	R5112-1D	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EC4DM21	EU	R5112-1E	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EC4DM21	EU	63G-1B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								§ 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM21	EU	63G-1C	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(f) § 63.119(a)(2) [G]§ 63.119(f)(1) [G]§ 63.119(f)(3)	Owner or operator who routes emissions to a fuel gas system or to a process, as defined in §63.111, to comply with §63.119(a)(1), or (a)(2) shall comply with §63.119(f)(1)-(3) as applicable.	None	§ 63.123(a) [G]§ 63.123(h) [G]§ 63.152(a)	§ 63.120(f) § 63.122(c)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
EC4DM21	EU	63G-1D	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								[G]§ 63.181(g)(3)	§ 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM21	EU	63G-1E	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM3075	EU	R5112-	VOC	30 TAC Chapter	§ 115.112(e)(1)	No person shall place,	§ 115.115(a)	§ 115.118(a)(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		2A		115, Storage of VOCs	§ 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	
EC4DM3075	EU	R5112-2B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EC4DM3075	EU	R5112-2C	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C)	No person shall place, store, or hold VOC in any storage tank unless	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2)	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.18	the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117	§ 115.118(a)(7)	
EC4DM3075	EU	R5112-2D	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EC4DM3075	EU	63G-1A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	[G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM3075	EU	63G-1B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM3075	EU	63G-1C	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM3075	EU	63G-1D	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	§63.119(e)(1)-(5).	[G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM3075	EU	63G-1E	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM3075	EU	63G-1F	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM3075	EU	63G-1G	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(1) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.172(i) § 63.172(m)		[G]§ 63.180(d)	§ 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM3075	EU	63G-1H	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM59	EU	R5112-10A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EC4DM59	EU	R5112-10B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						oil and condensate.			
EC4DM59	EU	63G-10A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM59	EU	63G-10B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								[G]§ 63.181(g)(3)	§ 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM59	EU	63G-10C	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4DM59	EU	63G-	112(B)	40 CFR Part 63,	§ 63.119(e)	The owner or operator	§ 63.120(e)(1)	§ 63.123(a)	[G]§ 63.120(e)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		10D	HAPS	Subpart G	§ 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	[G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4HT1202	EP	R1111-6	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
EC4HT1203	EU	R7ICI-17	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)		§ 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
EC4HT1203	EU	R7ICI-17	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
EC4HT1203	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					Part 63, Subpart DDDDD				
EC4HT302	EU	R7300-2	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
EC4HT302	EU	R7300-2	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 117.8120(2)(A) § 117.8120(2)(B)		
EC4HT302	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
EC4LTMISC1	EU	R5211-25	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(i) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
EC4LTMISC1	EU	R5211-25A	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(i) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EC4LTMISC1	EU	R5211-25B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(C) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(i) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216 § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
EC4LTMISC1	EU	R5211-25C	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
EC4LTMISC1	EU	R5211-25D	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EC4LTMISC1	EU	R5211-25E	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(C) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216 § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
EC4LTMISC2	EU	R5211-26	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(i) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
EC4LTMISC2	EU	R5211-26A	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(i) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EC4LTMISC2	EU	R5211-26B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(C) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(i) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216 § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
EC4LTMISC2	EU	R5211-26C	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
EC4LTMISC2	EU	R5211-26D	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EC4LTMISC2	EU	R5211-26E	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(C) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216 § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
EC4RX1208	EP	R5720-2	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.722(d) § 115.722(d)(1) § 115.722(d)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(n)	§ 115.726(d)(1) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n)
EC4RX1208	EP	R5720-4	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(a)(2)(A) § 115.725(a)(2)(B) § 115.725(a)(2)(C) § 115.725(a)(2)(D) § 115.725(a)(3) [G]§ 115.725(a)(4) [G]§ 115.725(l) [G]§ 115.726(a)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(a) § 115.725(a)(2)(A) § 115.725(a)(2)(B) § 115.725(a)(2)(C) § 115.725(a)(2)(D) § 115.725(a)(3) § 115.725(a)(3)(B) [G]§ 115.725(a)(4) § 115.725(a)(5) [G]§ 115.725(l) § 115.725(n)	§ 115.726(b)(1) § 115.726(b)(2) § 115.726(b)(3) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	[G]§ 115.725(a)(4) § 115.725(a)(5) § 115.725(n) [G]§ 115.726(a)(2)
EC4RX1208	EP	R5121-1	VOC	30 TAC Chapter 115, Vent Gas	§ 115.122(a)(1) § 115.121(a)(1)	Vent gas affected by §115.121(a)(1) must be	[G]§ 115.125 § 115.126(1)	§ 115.126 § 115.126(1)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Controls	§ 115.122(a)(1)(C)	controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	§ 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	§ 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	
EC4RX1208	EP	R5121-2	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	None
EC4RX1208	EP	R5121-4	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(B) § 60.18	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None
EC4TK3941	EU	R5112-10A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EC4TK3941	EU	R5112-10B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EC4TK3941	EU	63G-5A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4TK3941	EU	63G-5B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4TK3942	EU	R5112-10A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EC4TK3942	EU	R5112-10B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EC4TK3942	EU	63G-5A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	(a)(2) shall comply with §63.119(e)(1)-(5).	[G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	[G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4TK3942	EU	63G-5B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EC4TO	EP	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
EC5DM56	EU	R5112-1A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EC5DM56	EU	R5112-1B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EC5SP334	EP	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
EC5SP334	EP	R5122-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
EC5SP349	EP	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
EC5SP349	EP	R5122-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).			
EC5TK21	EU	R5112-2A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EC5TK21	EU	R5112-2B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this paragraph for crude oil and condensate.			
EC5TK27	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
EC5TK30	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
EC5TK31	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
EC5TK3116	EU	R5112-3	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EC5TK317	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
EC5TK36	EU	R5112-5	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None
EC5TK36	EU	R5112-5B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
ECUCT1701A	EU	R5760-	HIGHLY	30 TAC Chapter	§ 115.767(2)	Any cooling tower heat	None	§ 115.766(b)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		7	REACTIVE VOC	115, HRVOC Cooling Towers		exchange system in which no individual heat exchanger has greater than 100 ppmw HRVOCs in the process side fluid is exempt from the requirements of this division, with the exception of the recordkeeping requirements of §115.766(b) and (c) of this title.		§ 115.766(b)(2) § 115.766(c)	
ECUCT1701B	EU	R5760-8	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Cooling Towers	§ 115.767(2)	Any cooling tower heat exchange system in which no individual heat exchanger has greater than 100 ppmw HRVOCs in the process side fluid is exempt from the requirements of this division, with the exception of the recordkeeping requirements of §115.766(b) and (c) of this title.	None	§ 115.766(b) § 115.766(b)(2) § 115.766(c)	None
ECUCT604	EU	R5760-1	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Cooling Towers	§ 115.761(c)(1) § 115.761(c)(3) § 115.764(a)(1) § 115.766(i)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 1 of this subchapter must not exceed 1,200 pounds of HRVOCs per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.764(a)(1) § 115.764(a)(3) [G]§ 115.764(a)(6) § 115.764(c)	§ 115.766(a)(1) § 115.766(a)(2) § 115.766(a)(3) § 115.766(a)(5) § 115.766(a)(6) § 115.766(c) [G]§ 115.766(g) [G]§ 115.766(h) § 115.766(i)(1)	§ 115.766(i)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ECULR1C4	EU	R5211-2A	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULR1C4	EU	R5211-2B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULR1C4	EU	R5211-2C	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216 § 115.216(1) § 115.216(1)(C) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ECULR1C4	EU	63G-2	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(c)	For each Group 2 transfer rack, maintain records as required in § 63.130(f). No other provisions for transfer racks apply to the Group 2 transfer rack.	None	§ 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(i) § 63.130(f)(3)(ii)	§ 63.152(c)(4)(iii)
ECULR1CBD	EU	R5211-3A	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULR1CBD	EU	R5211-3B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULR1CBD	EU	R5211-3C	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals,	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii)	§ 115.216 § 115.216(1) § 115.216(1)(C) § 115.216(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	
ECULR1CBD	EU	63G-3	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(c)	For each Group 2 transfer rack, maintain records as required in § 63.130(f). No other provisions for transfer racks apply to the Group 2 transfer rack.	None	§ 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(i) § 63.130(f)(3)(ii)	§ 63.152(c)(4)(iii)
ECULR2C4	EU	R5211-4A	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULR2C4	EU	R5211-4B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.18		§ 115.215(9) § 115.216(1) § 115.216(1)(B)		
ECULR2C4	EU	R5211-4C	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216 § 115.216(1) § 115.216(1)(C) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULR2C4	EU	63G-4	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(c)	For each Group 2 transfer rack, maintain records as required in § 63.130(f). No other provisions for transfer racks apply to the Group 2 transfer rack.	None	§ 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(i) § 63.130(f)(3)(ii)	§ 63.152(c)(4)(iii)
ECULR2CBD	EU	R5211-5A	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULR2CBD	EU	R5211-5B	VOC	30 TAC Chapter 115, Loading and	§ 115.212(a)(1) § 115.212(a)(1)(A)	At operations other than gasoline terminals,	§ 115.212(a)(3)(B) § 115.214(a)(1)(A)	§ 115.216 § 115.216(1)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Unloading of VOC	§ 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	
ECULR2CBD	EU	R5211-5C	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216 § 115.216(1) § 115.216(1)(C) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULR2CBD	EU	63G-5	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(c)	For each Group 2 transfer rack, maintain records as required in § 63.130(f). No other provisions for transfer racks apply to the Group 2 transfer rack.	None	§ 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(i) § 63.130(f)(3)(ii)	§ 63.152(c)(4)(iii)
ECULR2MEOH	EU	R5211-6	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(ii) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.214(a)(1)(B) § 115.214(a)(1)(C)		§ 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(ii)	§ 115.216(3)(B)	
ECULR2MEOH	EU	R5211-7	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(i) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULR2MEOH	EU	63G-6	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) § 63.126(b)(1) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.116(c) [G]§ 63.126(d)(3) § 63.127(b) § 63.127(b)(2) § 63.128(a)(1) § 63.128(a)(2) § 63.128(a)(3) § 63.128(a)(4) § 63.128(e)(2) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v)	§ 63.127(b) § 63.127(b)(2) § 63.129(a)(1) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(iii) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(iii) § 63.129(c) § 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								§ 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii)	§ 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii)
ECULR2MEOH	EU	63G-7	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.11 § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) [G]§ 63.126(b)(2) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(2) § 63.127(e) [G]§ 63.128(b) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.129(a)(1) [G]§ 63.129(a)(5) § 63.130(a)(1) § 63.130(a)(2)(i) § 63.130(c) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii)	§ 63.129(a)(2) § 63.129(a)(3) [G]§ 63.129(a)(5) § 63.130(d)(1) § 63.130(d)(2) § 63.130(d)(5) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								[G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	
ECULRACID	EU	R5211-1A	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULRACID	EU	R5211-1B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULRACN	EU	63G-9	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(c)	For each Group 2 transfer rack, maintain records as required in § 63.130(f). No other provisions for transfer racks apply to the Group 2 transfer rack.	None	§ 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(i) § 63.130(f)(3)(ii)	§ 63.152(c)(4)(iii)
ECULRVOC	EU	R5211-	VOC	30 TAC Chapter	§ 115.212(a)(1)	At operations other than	§ 115.212(a)(3)(B)	§ 115.216	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		7A		115, Loading and Unloading of VOC	§ 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	
ECULRVOC	EU	R5211-7B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(ii)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(ii) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULRVOC	EU	R5211-7C	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
ECULRVOC	EU	R5211-7D	VOC	30 TAC Chapter 115, Loading and Unloading of	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2)	At operations other than gasoline terminals, gasoline bulk plants,	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i)	§ 115.216 § 115.216(1) § 115.216(1)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				VOC	§ 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	
ECULRVOC	EU	R5211-7E	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216 § 115.216(1) § 115.216(1)(C) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULTC4	EU	R5211-8A	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULTC4	EU	R5211-8B	VOC	30 TAC Chapter 115, Loading and Unloading of	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2)	At operations other than gasoline terminals, gasoline bulk plants,	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i)	§ 115.216 § 115.216(1) § 115.216(1)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				VOC	§ 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	
ECULTC4	EU	R5211-8C	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216 § 115.216(1) § 115.216(1)(C) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULTC4	EU	63G-7	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(c)	For each Group 2 transfer rack, maintain records as required in § 63.130(f). No other provisions for transfer racks apply to the Group 2 transfer rack.	None	§ 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(i) § 63.130(f)(3)(ii)	§ 63.152(c)(4)(iii)
ECULTMEOH	EU	R5211-9A	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ECULTMEOH	EU	R5211-9B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(ii)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(ii) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULTMEOH	EU	R5211-9C	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULTMEOH	EU	63G-8	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) § 63.126(b)(1) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.116(c) [G]§ 63.126(d)(3) § 63.127(b) § 63.127(b)(2) § 63.128(a)(1) § 63.128(a)(2) § 63.128(a)(3) § 63.128(a)(4) § 63.128(e)(2) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii)	§ 63.127(b) § 63.127(b)(2) § 63.129(a)(1) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(iii) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(4) § 63.129(a)(4)(i) § 63.129(a)(4)(iii) § 63.129(c) § 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v)	[G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii)	[G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii)
ECULTMEOH	EU	63G-8A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.11 § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) [G]§ 63.126(b)(2) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(2) § 63.127(e) [G]§ 63.128(b) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v)	§ 63.129(a)(1) [G]§ 63.129(a)(5) § 63.130(a)(1) § 63.130(a)(2)(i) § 63.130(c) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii)	§ 63.129(a)(2) § 63.129(a)(3) [G]§ 63.129(a)(5) § 63.130(d)(1) § 63.130(d)(2) § 63.130(d)(5) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(g)(2)(i) § 63.152(g)(2)(ii)
ECULTNOHAP	EU	R5211-10A	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULTNOHAP	EU	R5211-10B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
ECULTNOHAP	EU	R5211-10C	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ECULTNOHAP	EU	R5211-10D	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216 § 115.216(1) § 115.216(1)(C) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULTVOC	EU	R5211-11A	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULTVOC	EU	R5211-11B	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
ECULTVOC	EU	R5211-11C	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii)	§ 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(ii) § 115.216(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(ii)	§ 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	
ECULTVOC	EU	R5211-11D	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECULTVOC	EU	R5211-11E	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216 § 115.216(1) § 115.216(1)(C) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
ECUSUEAPI	EU	R5131-2	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).			
ECUSUWAPI	EU	R5131-1	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None
EMERFLARE	EU	R1111-2	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period, except for upset emissions as provided in §101.11(a).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
EMERFLARE	CD	60A-1A	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1) § 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(i) § 60.18(c)(6) § 60.18(e)	Flares shall comply with paragraphs (c)-(f) of § 60.18.	§ 60.18(d) § 60.18(f)(1) § 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4)	None	None
EMERFLARE	CD	60A-1B	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1) § 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(ii) § 60.18(c)(6) § 60.18(e)	Flares shall comply with paragraphs (c)-(f) of § 60.18.	§ 60.18(d) § 60.18(f)(1) § 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4)	None	None
EMERFLARE	CD	60A-1C	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1)	Flares shall comply with paragraphs (c)-(f) of §	§ 60.18(d) § 60.18(f)(1)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(iii) § 60.18(c)(6) § 60.18(e)	60.18.	§ 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4) § 60.18(f)(5)		
EMERFLARE	CD	63A-1A	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(i)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
EMERFLARE	CD	63A-1B	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(ii)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
EMERFLARE	CD	63A-1C	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(iii)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
EMTTK12	EU	R5112-3A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C)	No person shall place, store, or hold VOC in any storage tank unless	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2)	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.18	the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117	§ 115.118(a)(7)	
EMTTK12	EU	R5112-3B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EMTTK12	EU	R5112-3C	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(A) § 115.112(e)(3)(A)(i)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(1) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EMTTK12	EU	R5112-3D	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EMTTK12	EU	R5112-3E	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EMTTK18	EU	R5112-4A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EMTTK18	EU	R5112-4B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EMTTK18	EU	R5112-4C	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(A) § 115.112(e)(3)(A)(i)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(1) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EMTTK18	EU	R5112-4D	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EMTTK18	EU	R5112-4E	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EMTTK19	EU	R5112-5A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EMTTK19	EU	R5112-5B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EMTTK19	EU	R5112-5C	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(A) § 115.112(e)(3)(A)(i)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(1) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EMTTK19	EU	R5112-5D	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EMTTK19	EU	R5112-5E	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this paragraph for crude oil and condensate.			
EMTTK26	EU	R5112-7	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)
EMTTK26	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(c) § 63.119(a)(1) § 63.119(c)(1) § 63.119(c)(1)(i) § 63.119(c)(1)(ii) § 63.119(c)(1)(iii) § 63.119(c)(2)(i) § 63.119(c)(2)(ii) § 63.119(c)(2)(iii) § 63.119(c)(2)(iv) § 63.119(c)(2)(ix) § 63.119(c)(2)(v) § 63.119(c)(2)(vi) § 63.119(c)(2)(vii) § 63.119(c)(2)(viii) § 63.119(c)(2)(x) § 63.119(c)(2)(xi) § 63.119(c)(2)(xii) [G]§ 63.119(c)(3)	Tanks using an external floating roof, (defined in § 63.111), to comply with §63.119(a)(1) shall comply with §63.119(c)(1)-(4).	§ 63.120(b)(1)(i) § 63.120(b)(1)(iii) § 63.120(b)(1)(iv) § 63.120(b)(10) § 63.120(b)(2)(i) § 63.120(b)(2)(ii) § 63.120(b)(2)(iii) § 63.120(b)(3) § 63.120(b)(4)	[G]§ 63.120(b)(7) § 63.120(b)(8) § 63.123(a) § 63.123(d) § 63.123(g) [G]§ 63.152(a)	§ 63.120(b)(10)(ii) § 63.120(b)(10)(iii) § 63.120(b)(9) [G]§ 63.122(e)(1) § 63.122(e)(2) § 63.122(e)(3) § 63.122(e)(3)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.119(c)(4) § 63.120(b)(10)(i) § 63.120(b)(5)(i) § 63.120(b)(5)(ii) § 63.120(b)(6)(i) § 63.120(b)(6)(ii) [G]§ 63.120(b)(7) § 63.120(b)(8)				
EMTTK4	EU	R5112-9A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EMTTK4	EU	R5112-9B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EMTTK4	EU	R5112-9C	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EMTTK4	EU	R5112-9D	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EMTTK4	EU	63G-9A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EMTTK4	EU	63G-9B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.172(m)			§ 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EMTTK4	EU	63G-9C	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.182(c)(4) [G]§ 63.182(d)
EMTTK4	EU	63G-9D	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EMTTK47	EU	R5112-13	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
EMTTK47	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(2)(ii) § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.133(f) § 63.133(h) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a)	A fixed roof and an internal floating roof that meets the requirements specified in Sec. 63.119(b) of this subpart;	§ 63.133(f) § 63.133(g) § 63.133(g)(2) § 63.133(g)(3) § 63.143(a) § 63.143(g)	§ 63.133(h) § 63.147(b) § 63.147(b)(1) § 63.147(b)(6) § 63.147(b)(7) [G]§ 63.152(a)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(c) § 63.146(g) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
EMTTK47	EU	63G-9	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)				§ 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
EMTTK5	EU	R5112-10A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EMTTK5	EU	R5112-10B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						of subsection (a)(1) of this paragraph for crude oil and condensate.			
EMTTK5	EU	R5112-10C	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(A) § 115.112(e)(3)(A)(i)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(1) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
EMTTK5	EU	R5112-10D	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						oil and condensate.			
EMTTK5	EU	R5112-10E	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
ENGADMIN	EU	R7471-6	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)			
ENGADMIN	EU	60IIII-1	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
ENGADMIN	EU	60IIII-1	NMHC and NOX	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ENGADMIN	EU	60IIII-1	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.113(a)(1) § 89.113(a)(2) § 89.113(a)(3)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2) and §89.113(a)(1)-(3) and §1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
ENGADMIN	EU	60IIII-1	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						40 CFR 89.112(a).			
ENGADMIN	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
EUTDM01086	EU	R5140-16A	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.147(2) [G]§ 115.142(4) [G]§ 115.148	An owner or operator may exempt from control requirements of §115.142 one or more affected VOC wastewater streams for which the total annual VOC loading is less than or equal to 10 Mg (11.03 tons).	§ 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(3) § 115.146(4)	[G]§ 115.142(4)
EUTDM01086	EU	R5140-16B	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10)	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)		[G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148		
EUTDM01086	EU	R5140-16C	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
EUTDM01086	EU	60Kb-39A	VOC	40 CFR Part 60, Subpart Kb	§ 60.110b(a)	Except for §60.110b(b), this subpart applies to vessels with a capacity greater than or equal to 75 cubic meters (19,800 gal) used to store VOLs for which construction/reconstruction/modification began after 7/23/84.	§ 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(d) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3)	§ 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.116b(d)
EUTDM01086	EU	60Kb-39E	VOC	40 CFR Part 60, Subpart Kb	[G]§ 60.112b(a)(3) § 60.18	Storage vessels specified in §60.112b(a) and equipped with a closed vent system/control device are to meet the	§ 60.113b(d) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3)	§ 60.115b § 60.115b(d)(2) § 60.116b(a) § 60.116b(b)	§ 60.115b § 60.115b(d)(1) § 60.115b(d)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						specifications of §60.112b(a)(3)(i)-(ii).	[G]§ 60.485(b)		
EUTDM01086	EU	60Kb-39F	VOC	40 CFR Part 60, Subpart Kb	[G]§ 60.112b(a)(3) § 60.18	Storage vessels specified in §60.112b(a) and equipped with a closed vent system/control device are to meet the specifications of §60.112b(a)(3)(i)-(ii).	§ 60.113b(d) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3) [G]§ 60.485(b)	§ 60.115b § 60.115b(d)(2) § 60.116b(a) § 60.116b(b)	§ 60.115b § 60.115b(d)(1) § 60.115b(d)(3)
EUTDM01086	EU	61FF-18A	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 60.18 § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 60.18(f)(2) § 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
EUTDM01086	EU	61FF-18B	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 60.18 § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 60.18(f)(2) § 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EUTDM01086	EU	63G-28A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(1)	A fixed roof shall be operated and maintained except that if the wastewater tank is used for specified purpose, then owner or operator shall comply with requirements of § 63.133(a)(2).	None	None	§ 63.146(b)(2) § 63.146(b)(5) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(c)(1) § 63.152(c)(4)(ii)
EUTDM01086	EU	63G-28B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(2)(i) § 63.11 § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.133(b)(1)(ii) § 63.133(f) § 63.133(h) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	A fixed roof and a closed-vent system that routes the organic hazardous air pollutants vapors vented from the wastewater tank to a control device.	§ 63.133(f) § 63.133(g) § 63.133(g)(3) § 63.139(d)(3) § 63.139(e) § 63.143(a) § 63.143(e) § 63.143(e)(1) § 63.143(g) [G]§ 63.145(j) § 63.148(b)(3) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.133(h) § 63.145(a)(3) [G]§ 63.145(a)(4) § 63.147(b) § 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(6) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.148(i)(6) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) § 63.146(c) § 63.146(e) § 63.146(e)(1) § 63.146(g) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTDM01086	EU	63G-28C	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(2)(i) § 63.11 § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.133(b)(1)(ii) § 63.133(f) § 63.133(h) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	A fixed roof and a closed-vent system that routes the organic hazardous air pollutants vapors vented from the wastewater tank to a control device.	§ 63.133(f) § 63.133(g) § 63.133(g)(3) § 63.139(d)(3) § 63.139(e) § 63.143(a) § 63.143(e) § 63.143(e)(1) § 63.143(g) [G]§ 63.145(j) § 63.148(b)(3) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.133(h) § 63.145(a)(3) [G]§ 63.145(a)(4) § 63.147(b) § 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(6) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.148(i)(6) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) § 63.146(c) § 63.146(e) § 63.146(e)(1) § 63.146(g) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTDM0701	EU	R5140-16A	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.147(2) [G]§ 115.142(4) [G]§ 115.148	An owner or operator may exempt from control requirements of §115.142 one or more	§ 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2)	§ 115.146(1) § 115.146(3) § 115.146(4)	[G]§ 115.142(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						affected VOC wastewater streams for which the total annual VOC loading is less than or equal to 10 Mg (11.03 tons).	[G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148		
EUTDM0701	EU	R5140-16B	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
EUTDM0701	EU	R5140-16C	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
EUTDM0701	EU	61FF-19A	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 60.18	Install, operate, and maintain a fixed-roof	§ 60.18(f)(2) § 61.347(a)(1)(i)(A)	§ 61.354(c) § 61.354(c)(3)	§ 61.357(d)(7) § 61.357(d)(7)(iv)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 61.347(b) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) § 61.354(e) [G]§ 61.355(h)	§ 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7)(iv)(F)
EUTDM0701	EU	61FF-19B	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 60.18 § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 60.18(f)(2) § 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) § 61.354(e) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
EUTDM0701	EU	63G-29A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.137(a)(1) § 63.11 § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.137(b)(1)(ii) § 63.137(d) § 63.137(e)(3) § 63.137(f) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b)	A fixed roof and a closed vent system that routes the organic hazardous air pollutants vapors vented from the oil-water separator to a control device and which meets §63.137(b).	[G]§ 63.137(e)(1) § 63.137(e)(2) § 63.137(e)(3) § 63.139(d)(3) § 63.139(e) § 63.143(a) § 63.143(e) § 63.143(e)(1) § 63.143(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h)	§ 63.147(b) § 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) § 63.146(c) § 63.146(e) § 63.146(e)(1) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)		[G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTDM0701	EU	63G-29B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.137(a)(1) § 63.11 § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.137(b)(1)(ii) § 63.137(d) § 63.137(e)(3) § 63.137(f) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	A fixed roof and a closed vent system that routes the organic hazardous air pollutants vapors vented from the oil-water separator to a control device and which meets §63.137(b).	[G]§ 63.137(e)(1) § 63.137(e)(2) § 63.137(e)(3) § 63.139(d)(3) § 63.139(e) § 63.143(a) § 63.143(e) § 63.143(e)(1) § 63.143(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.147(b) § 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) § 63.146(c) § 63.146(e) § 63.146(e)(1) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTDM0801	EU	R5140-16A	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.147(2) [G]§ 115.142(4) [G]§ 115.148	An owner or operator may exempt from control requirements of §115.142 one or more affected VOC wastewater streams for which the total annual VOC loading is less than or equal to 10 Mg (11.03 tons).	§ 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(3) § 115.146(4)	[G]§ 115.142(4)
EUTDM0801	EU	R5140-16B	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
EUTDM0801	EU	R5140-16C	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)		§ 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148		
EUTDM0801	EU	61FF-19A	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 60.18 § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 60.18(f)(2) § 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) § 61.354(e) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
EUTDM0801	EU	61FF-19B	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 60.18 § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 60.18(f)(2) § 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) § 61.354(e) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
EUTDM0801	EU	63G-	112(B)	40 CFR Part 63,	§ 63.137(a)(1)	A fixed roof and a	[G]§ 63.137(e)(1)	§ 63.147(b)	§ 63.146(b)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		29A	HAPS	Subpart G	§ 63.11 § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.137(b)(1)(ii) § 63.137(d) § 63.137(e)(3) § 63.137(f) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	closed vent system that routes the organic hazardous air pollutants vapors vented from the oil-water separator to a control device and which meets §63.137(b).	§ 63.137(e)(2) § 63.137(e)(3) § 63.139(d)(3) § 63.139(e) § 63.143(a) § 63.143(e) § 63.143(e)(1) § 63.143(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) § 63.146(c) § 63.146(e) § 63.146(e)(1) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTDM0801	EU	63G-29B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.137(a)(1) § 63.11 § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.137(b)(1)(ii) § 63.137(d) § 63.137(e)(3) § 63.137(f) § 63.139(b)	A fixed roof and a closed vent system that routes the organic hazardous air pollutants vapors vented from the oil-water separator to a control device and which meets §63.137(b).	[G]§ 63.137(e)(1) § 63.137(e)(2) § 63.137(e)(3) § 63.139(d)(3) § 63.139(e) § 63.143(a) § 63.143(e) § 63.143(e)(1) § 63.143(g) [G]§ 63.145(j)	§ 63.147(b) § 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) § 63.146(c) § 63.146(e) § 63.146(e)(1) [G]§ 63.151(b) § 63.151(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)		[G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTDM8801	EU	R5140-16A	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.147(2) [G]§ 115.142(4) [G]§ 115.148	An owner or operator may exempt from control requirements of §115.142 one or more affected VOC wastewater streams for which the total annual VOC loading is less than or equal to 10 Mg (11.03 tons).	§ 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(3) § 115.146(4)	[G]§ 115.142(4)
EUTDM8801	EU	R5140-16B	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2)	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 115.148 § 60.18(b)		[G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148		
EUTDM8801	EU	R5140-16C	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
EUTDM8801	EU	61FF-19A	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 60.18 § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 60.18(f)(2) § 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) § 61.354(e) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
EUTDM8801	EU	61FF-19B	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 60.18 § 61.347(a)(1)(i)(A)	Install, operate, and maintain a fixed-roof and closed-vent system	§ 60.18(f)(2) § 61.347(a)(1)(i)(A) § 61.347(b)	§ 61.354(c) § 61.354(c)(3) § 61.356(d)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	that routes all organic vapors vented from the oil-water separator to a control device.	§ 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) § 61.354(e) [G]§ 61.355(h)	§ 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	
EUTDM8801	EU	63G-29A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.137(a)(1) § 63.11 § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.137(b)(1)(ii) § 63.137(d) § 63.137(e)(3) § 63.137(f) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	A fixed roof and a closed vent system that routes the organic hazardous air pollutants vapors vented from the oil-water separator to a control device and which meets §63.137(b).	[G]§ 63.137(e)(1) § 63.137(e)(2) § 63.137(e)(3) § 63.139(d)(3) § 63.139(e) § 63.143(a) § 63.143(e) § 63.143(e)(1) § 63.143(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.147(b) § 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) § 63.146(c) § 63.146(e) § 63.146(e)(1) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.182(c)(4) [G]§ 63.182(d)
EUTDM8801	EU	63G-29B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.137(a)(1) § 63.11 § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.137(b)(1)(ii) § 63.137(d) § 63.137(e)(3) § 63.137(f) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	A fixed roof and a closed vent system that routes the organic hazardous air pollutants vapors vented from the oil-water separator to a control device and which meets §63.137(b).	[G]§ 63.137(e)(1) § 63.137(e)(2) § 63.137(e)(3) § 63.139(d)(3) § 63.139(e) § 63.143(a) § 63.143(e) § 63.143(e)(1) § 63.143(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.147(b) § 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) § 63.146(c) § 63.146(e) § 63.146(e)(1) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTDM8804	EU	R5140-16A	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.147(2) [G]§ 115.142(4) [G]§ 115.148	An owner or operator may exempt from control requirements of §115.142 one or more affected VOC wastewater streams for which the total annual	§ 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5)	§ 115.146(1) § 115.146(3) § 115.146(4)	[G]§ 115.142(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						VOC loading is less than or equal to 10 Mg (11.03 tons).	§ 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148		
EUTDM8804	EU	R5140-16B	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
EUTDM8804	EU	R5140-16C	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
EUTDM8804	EU	61FF-19A	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 60.18 § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the	§ 60.18(f)(2) § 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(e)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	oil-water separator to a control device.	§ 61.349(f) § 61.354(c) § 61.354(c)(3) § 61.354(e) [G]§ 61.355(h)	§ 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	
EUTDM8804	EU	61FF-19B	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 60.18 § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 60.18(f)(2) § 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) § 61.354(e) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
EUTDM8804	EU	63G-29A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.137(a)(1) § 63.11 § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.137(b)(1)(ii) § 63.137(d) § 63.137(e)(3) § 63.137(f) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j)	A fixed roof and a closed vent system that routes the organic hazardous air pollutants vapors vented from the oil-water separator to a control device and which meets §63.137(b).	[G]§ 63.137(e)(1) § 63.137(e)(2) § 63.137(e)(3) § 63.139(d)(3) § 63.139(e) § 63.143(a) § 63.143(e) § 63.143(e)(1) § 63.143(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b)	§ 63.147(b) § 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) § 63.146(c) § 63.146(e) § 63.146(e)(1) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.172(a) [G]§ 63.172(h) § 63.172(i)		[G]§ 63.180(d)	[G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTDM8804	EU	63G-29B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.137(a)(1) § 63.11 § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.137(b)(1)(ii) § 63.137(d) § 63.137(e)(3) § 63.137(f) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	A fixed roof and a closed vent system that routes the organic hazardous air pollutants vapors vented from the oil-water separator to a control device and which meets §63.137(b).	[G]§ 63.137(e)(1) § 63.137(e)(2) § 63.137(e)(3) § 63.139(d)(3) § 63.139(e) § 63.143(a) § 63.143(e) § 63.143(e)(1) § 63.143(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.147(b) § 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) § 63.146(c) § 63.146(e) § 63.146(e)(1) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTEN1	EU	R71C1-1	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(9)(E)(vii)(II) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) [G]§ 117.310(f) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(C) § 117.340(h) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(B) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
EUTEN1	EU	R71C1-1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B)	CO emissions must not exceed 3.0 g/hp-hr for stationary internal combustion engines.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.340(a)(2)(C) § 117.340(h) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)		§ 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
EUTEN1	EU	60IIII-1	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EUTEN1	EU	60IIII-1	NMHC and NO_X	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 75 KW but less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 - 2013 model year must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102.	None	None	None
EUTEN1	EU	60IIII-1	PM	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2011 model year and later must comply with a PM emission limit of 0.02 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	[G]§ 60.4214(d)
EUTEN1	EU	63ZZZZ-1	FORMALDEHYDE	40 CFR Part 63, Subpart ZZZZ	§ 63.6600(b)-Table2a.3.b § 63.6595(c) § 63.6600(b)-Table2b.1.a § 63.6600(b)-	For each new or reconstructed CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP	§ 63.6610(a) § 63.6610(b) § 63.6610(c) § 63.6615 § 63.6620(a) § 63.6620(a)-Table3.3	§ 63.6620(i) § 63.6630(a)-Table5.9.a.iii § 63.6635(a) § 63.6635(c) § 63.6655(a)	§ 63.6620(i) § 63.6630(c) § 63.6640(b) § 63.6640(e) § 63.6645(a) § 63.6645(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					Table2b.1.b § 63.6605(a) § 63.6605(b) § 63.6625(h) § 63.6630(a) § 63.6630(b) § 63.6640(b)	emissions, operating at 100% load plus or minus 10%, you must limit the concentration of formaldehyde in the stationary RICE exhaust to 580 ppbvd or less at 15 % O2.	§ 63.6620(a)-Table4.3.a.i § 63.6620(a)-Table4.3.a.ii § 63.6620(a)-Table4.3.a.iii § 63.6620(a)-Table4.3.a.iv § 63.6620(b) § 63.6620(b)(4) § 63.6620(d) [G]§ 63.6620(e)(2) [G]§ 63.6625(b) § 63.6630(a)-Table5.9.a.i § 63.6630(a)-Table5.9.a.ii § 63.6630(a)-Table5.9.a.iii § 63.6635(a) § 63.6635(b) § 63.6640(a) § 63.6640(a)-Table6.7.a.i § 63.6640(a)-Table6.7.a.ii § 63.6640(a)-Table6.7.a.iii § 63.6640(a)-Table6.7.a.iv § 63.6640(a)-Table6.7.a.v § 63.6640(b)	§ 63.6655(a)(1) § 63.6655(a)(2) § 63.6655(a)(3) § 63.6655(a)(4) § 63.6655(a)(5) § 63.6655(d) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6645(g) § 63.6645(h) § 63.6645(h)(2) § 63.6650(a) § 63.6650(a)-Table7.1.a.i § 63.6650(a)-Table7.1.a.ii § 63.6650(a)-Table7.1.b § 63.6650(a)-Table7.1.c § 63.6650(b) § 63.6650(b)(1) § 63.6650(b)(2) § 63.6650(b)(3) § 63.6650(b)(4) § 63.6650(b)(6) § 63.6650(b)(7) § 63.6650(b)(8) § 63.6650(b)(9) [G]§ 63.6650(c) [G]§ 63.6650(d) § 63.6650(f)
EUTENADMIN	EU	R7ICI-1	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
EUTENADMIN	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
EUTENEOC	EU	R7471-6	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)			
EUTENEOC	EU	60IIII-1	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
EUTENEOC	EU	60IIII-1	NMHC and NOX	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
EUTENEOC	EU	60IIII-1	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.113(a)(1) § 89.113(a)(2) § 89.113(a)(3)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2) and §89.113(a)(1)-(3) and §1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
EUTENEOC	EU	60IIII-1	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
EUTENEOC	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
EUTENLAB	EU	R7471-5	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
EUTENLAB	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.6 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(j) § 63.6640(b) § 63.6640(f)(1) [G]§ 63.6640(f)(2) § 63.6640(f)(3)	For each existing emergency stationary SI RICE and black start stationary SI RICE with a site rating less than or equal to 500 HP, located at a major source, you must comply with the requirements as specified in Table 2c.6.a-c.	§ 63.6625(f) § 63.6625(j) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii § 63.6640(b)	§ 63.6625(j) § 63.6655(a) § 63.6655(a)(1) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(b) § 63.6640(e) § 63.6650(f)
EUTENPMDI	EU	R7471-4	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
EUTENPMDI	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b)	For each existing emergency stationary CI RICE and black start stationary CI RICE,	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i	§ 63.6625(i) § 63.6655(a) § 63.6655(a)(1) § 63.6655(d)	§ 63.6640(b) § 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(b) § 63.6640(f)(1) [G]§ 63.6640(f)(2) § 63.6640(f)(3)	located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6640(a)-Table6.9.a.ii § 63.6640(b)	§ 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	
EUTFL1701	EU	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period, except for upset emissions as provided in §101.11(a).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
EUTFL1701	EP	R5720-1	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(d) § 115.722(d)(1) § 115.722(d)(2) [G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) [G]§ 115.725(l) § 115.725(m)(2)(A) § 115.725(m)(2)(B) [G]§ 115.726(a)(2)	All flares must continuously meet the requirements of 40 CFR § 60.18(c)(2)-(6) and (d) as amended through October 17, 2000 (65 FR 61744) when vent gas containing HRVOC is being routed to the flare.	[G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) § 115.725(d)(3) § 115.725(d)(4) § 115.725(d)(5) § 115.725(d)(6) § 115.725(d)(7) § 115.725(k)(1) [G]§ 115.725(l) § 115.725(m)(1) § 115.725(m)(2)(A) § 115.725(m)(2)(B) § 115.725(n)	§ 115.726(a)(1) § 115.726(a)(1)(A) § 115.726(d)(1) § 115.726(d)(10) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n) § 115.726(a)(1)(B) [G]§ 115.726(a)(2)
EUTFL1701	CD	60A-1A	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1)	Flares shall comply with paragraphs (c)-(f) of §	§ 60.18(d) § 60.18(f)(1)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(i) § 60.18(c)(6) § 60.18(e)	60.18.	§ 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4)		
EUTFL1701	CD	60A-1B	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1) § 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(ii) § 60.18(c)(6) § 60.18(e)	Flares shall comply with paragraphs (c)-(f) of § 60.18.	§ 60.18(d) § 60.18(f)(1) § 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4)	None	None
EUTFL1701	CD	60A-1C	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1) § 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(iii) § 60.18(c)(6) § 60.18(e)	Flares shall comply with paragraphs (c)-(f) of § 60.18.	§ 60.18(d) § 60.18(f)(1) § 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4) § 60.18(f)(5)	None	None
EUTFL1701	CD	63A-1A	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(i)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
EUTFL1701	CD	63A-1B	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(ii)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						shall be used.			
EUTFL1701	CD	63A-1C	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(iii)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
EUTFL1701V	EP	R5720-1	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.722(d) § 115.722(d)(1) § 115.722(d)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(n)	§ 115.726(d)(1) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n)
EUTFL1701V	EP	R5121-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(2) § 115.121(a)(2) § 115.122(a)(2)(A) § 60.18	Vent gas affected by §115.121(a)(2) must be controlled properly with a control efficiency > 98% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2) § 115.126(7)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None
EUTFL1701V	EP	R5121-3	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(B) § 60.18	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency >	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).			
EUTFL1701V	EP	63FFFF-2	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2455(a)-Table 1.1.a.ii § 63.11(b) § 63.2450(b) § 63.2455(a) § 63.2455(b) § 63.2455(b)(1) § 63.982(b) § 63.983(a)(1) § 63.983(a)(2) § 63.983(d)(1) § 63.983(d)(1)(i) [G]§ 63.983(d)(2) § 63.983(d)(3) § 63.987(a) § 63.987(b)(1) § 63.987(b)(3) [G]§ 63.997(c)(1) § 63.997(c)(3)	For each Group 1continuous process vent, the owner or operator must reduce emissions of total organic HAP by venting emissions through a closed vent system to a flare.	[G]§ 63.115(d)(2)(v) § 63.115(d)(3)(iii) § 63.983(b) [G]§ 63.983(b)(1) [G]§ 63.983(b)(2) [G]§ 63.983(b)(3) [G]§ 63.983(c)(1) § 63.983(c)(2) § 63.983(c)(3) § 63.983(d)(1) § 63.983(d)(1)(ii) [G]§ 63.987(b)(3)(i) § 63.987(b)(3)(ii) § 63.987(b)(3)(iii) § 63.987(b)(3)(iv) § 63.987(c) § 63.997(a) [G]§ 63.997(c)(1) § 63.997(c)(2) § 63.997(c)(3) § 63.997(c)(3)(i) § 63.997(c)(3)(ii)	§ 63.2450(f)(2) § 63.2450(f)(2)(i) § 63.2450(f)(2)(ii) § 63.983(b) [G]§ 63.983(d)(2) § 63.987(b)(1) § 63.987(c) § 63.998(a)(1) [G]§ 63.998(a)(1)(i) § 63.998(a)(1)(ii) § 63.998(a)(1)(iii)(A) § 63.998(a)(1)(iii)(B) [G]§ 63.998(b)(1) [G]§ 63.998(b)(2) [G]§ 63.998(b)(3) [G]§ 63.998(b)(5) [G]§ 63.998(d)(1) § 63.998(d)(3)(i) § 63.998(d)(3)(ii) § 63.998(d)(5)	§ 63.2450(f)(2)(ii) § 63.2450(q) § 63.987(b)(1) § 63.997(c)(3) § 63.998(a)(1)(iii)(A) [G]§ 63.998(b)(3) [G]§ 63.999(a)(1) [G]§ 63.999(a)(2) § 63.999(b)(5) § 63.999(c)(1) § 63.999(c)(2)(i) § 63.999(c)(3) § 63.999(c)(6) [G]§ 63.999(c)(6)(i) § 63.999(c)(6)(iv) [G]§ 63.999(d)(1) [G]§ 63.999(d)(2)
EUTFL1701V	EP	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.113(a)(1) § 63.11 § 63.113(h) [G]§ 63.115(f)	Reduce emissions of organic HAP using a flare.§63.113(a)(1)(i)-(ii)	§ 63.114(a) § 63.114(a)(2) [G]§ 63.115(f) [G]§ 63.116(a)	[G]§ 63.117(a)(5) § 63.118(a)(1) § 63.118(a)(2) [G]§ 63.152(a) [G]§ 63.152(f)	§ 63.114(e) [G]§ 63.117(a)(5) § 63.117(f) § 63.118(f)(2) § 63.118(f)(5) [G]§ 63.151(b) § 63.151(e) [G]§ 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
EUTG1110	EU	R7471-10	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
EUTG1110	EU	60IIII-1	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
EUTG1110	EU	60IIII-1	NMHC and NO_X	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
EUTG1110	EU	60IIII-1	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						40 CFR 89.112(a).			
EUTG1110	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
EUTG1111	EU	R7471-11	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						month average.			
EUTG1111	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(b) § 63.6640(f)(1) [G]§ 63.6640(f)(2) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii § 63.6640(b)	§ 63.6625(i) § 63.6655(a) § 63.6655(a)(1) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(b) § 63.6640(e) § 63.6650(f)
EUTP3301B	EU	R7471-12	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
EUTP3301B	EU	60IIII-1	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) § 60.4211(b) § 60.4211(b)(1) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						displacement of less than 30 liters per cylinder and is a 2008 model year or earlier must comply with a CO emission limit of 3.5 g/KW-hr, as listed in Table 4 to this subpart.			
EUTP3301B	EU	60IIII-1	NMHC and NO_X	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) § 60.4211(b) § 60.4211(b)(1) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2008 model year or earlier must comply with an NMHC+NOx emission limit of 10.5 g/KW-hr, as listed in Table 4 to this subpart.	None	None	[G]§ 60.4214(d)
EUTP3301B	EU	60IIII-1	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) § 60.4211(b) § 60.4211(b)(1) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2008 model year or earlier must comply with a PM emission limit of 0.54 g/KW-hr, as listed in Table 4 to this subpart.	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EUTP3301B	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
EUTP803A	EU	R7471-13	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EUTP803A	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(b) § 63.6640(f)(1) [G]§ 63.6640(f)(2) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii § 63.6640(b)	§ 63.6625(i) § 63.6655(a) § 63.6655(a)(1) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(b) § 63.6640(e) § 63.6650(f)
EUTP803B	EU	R7471-14	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
EUTP803B	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(b) § 63.6640(f)(1)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii § 63.6640(b)	§ 63.6625(i) § 63.6655(a) § 63.6655(a)(1) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(b) § 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.6640(f)(2) § 63.6640(f)(3)	2c.1.a-c.			
EUTTK1101A	EU	61FF-1A	Benzene	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 60.18 § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 60.18(f)(2) § 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
EUTTK1101B	EU	61FF-1A	Benzene	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 60.18 § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 60.18(f)(2) § 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
EUTTK88014	EU	R5140-16A	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.147(2) [G]§ 115.142(4) [G]§ 115.148	An owner or operator may exempt from control requirements of §115.142 one or more affected VOC wastewater streams for which the total annual VOC loading is less than or equal to 10 Mg (11.03	§ 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7)	§ 115.146(1) § 115.146(3) § 115.146(4)	[G]§ 115.142(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						tons).	§ 115.145(9) [G]§ 115.148		
EUTTK88014	EU	R5140-16B	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
EUTTK88014	EU	R5140-16C	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
EUTTK88014	EU	60Kb-39A	VOC	40 CFR Part 60, Subpart Kb	§ 60.110b(a)	Except for §60.110b(b), this subpart applies to vessels with a capacity greater than or equal to 75 cubic meters (19,800 gal) used to store VOLs for which	§ 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(d) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3)	§ 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.116b(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						construction/reconstruction/modification began after 7/23/84.			
EUTTK88014	EU	60Kb-39C	VOC	40 CFR Part 60, Subpart Kb	[G]§ 60.112b(a)(3) § 60.18	Storage vessels specified in §60.112b(a) and equipped with a closed vent system/control device are to meet the specifications of §60.112b(a)(3)(i)-(ii).	§ 60.113b(d) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3) [G]§ 60.485(b)	§ 60.115b § 60.115b(d)(2) § 60.116b(a) § 60.116b(b)	§ 60.115b § 60.115b(d)(1) § 60.115b(d)(3)
EUTTK88014	EU	60Kb-39D	VOC	40 CFR Part 60, Subpart Kb	[G]§ 60.112b(a)(3) § 60.18	Storage vessels specified in §60.112b(a) and equipped with a closed vent system/control device are to meet the specifications of §60.112b(a)(3)(i)-(ii).	§ 60.113b(d) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3) [G]§ 60.485(b)	§ 60.115b § 60.115b(d)(2) § 60.116b(a) § 60.116b(b)	§ 60.115b § 60.115b(d)(1) § 60.115b(d)(3)
EUTTK88014	EU	61FF-18A	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 60.18 § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 60.18(f)(2) § 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
EUTTK88014	EU	61FF-18B	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 60.18 § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all	§ 60.18(f)(2) § 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(e)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	organic vapors vented from the tank to a control device.	§ 61.349(f) § 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	
EUTTK88014	EU	63G-28A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(1)	A fixed roof shall be operated and maintained except that if the wastewater tank is used for specified purpose, then owner or operator shall comply with requirements of § 63.133(a)(2).	None	None	§ 63.146(b)(2) § 63.146(b)(5) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(c)(1) § 63.152(c)(4)(ii)
EUTTK88014	EU	63G-28B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(2)(i) § 63.11 § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.133(b)(1)(ii) § 63.133(f) § 63.133(h) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	A fixed roof and a closed-vent system that routes the organic hazardous air pollutants vapors vented from the wastewater tank to a control device.	§ 63.133(f) § 63.133(g) § 63.133(g)(3) § 63.139(d)(3) § 63.139(e) § 63.143(a) § 63.143(e) § 63.143(e)(1) § 63.143(g) [G]§ 63.145(j) § 63.148(b)(3) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.133(h) § 63.145(a)(3) [G]§ 63.145(a)(4) § 63.147(b) § 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(6) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.148(i)(6) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) § 63.146(c) § 63.146(e) § 63.146(e)(1) § 63.146(g) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								§ 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTTK88014	EU	63G-28C	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(2)(i) § 63.11 § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.133(b)(1)(ii) § 63.133(f) § 63.133(h) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	A fixed roof and a closed-vent system that routes the organic hazardous air pollutants vapors vented from the wastewater tank to a control device.	§ 63.133(f) § 63.133(g) § 63.133(g)(3) § 63.139(d)(3) § 63.139(e) § 63.143(a) § 63.143(e) § 63.143(e)(1) § 63.143(g) [G]§ 63.145(j) § 63.148(b)(3) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.133(h) § 63.145(a)(3) [G]§ 63.145(a)(4) § 63.147(b) § 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(6) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.148(i)(6) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) § 63.146(c) § 63.146(e) § 63.146(e)(1) § 63.146(g) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTTW8801	EU	R5140-17A	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(F) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.144(3)(F) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
EUTTW8801	EU	R5140-17B	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
EUTTW8801	EU	R5140-17C	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5)	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)		§ 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(4)	
EUTTW8801	PRO	63G-30A	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.138(d) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	The steam stripper shall be operated and maintained and it shall conform as specified. §63.138(d)(1)-(6)	§ 63.139(d)(3) § 63.139(e) § 63.143(b) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.144(b) § 63.144(b)(1) § 63.144(b)(2) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5) [G]§ 63.144(b)(5)(i) § 63.144(b)(5)(ii) [G]§ 63.144(b)(5)(iii) § 63.144(b)(5)(iv) § 63.144(b)(6) § 63.144(c) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.144(c)(4) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) § 63.145(a)(5) § 63.145(g) [G]§ 63.145(j)	§ 63.143(f) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5)(ii) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.145(a)(3) § 63.147(b) § 63.147(b)(2) § 63.147(b)(4) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) § 63.147(f) [G]§ 63.152(a) [G]§ 63.152(f) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2)	§ 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) [G]§ 63.146(d) § 63.146(e) § 63.146(e)(1) § 63.146(f) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(g) § 63.151(h) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	[G]§ 63.181(g)(3)	§ 63.152(c)(2)(iv) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTTW8801	PRO	63G-30B	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.138(d) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	The steam stripper shall be operated and maintained and it shall conform as specified. §63.138(d)(1)-(6)	§ 63.139(d)(3) § 63.139(e) § 63.143(b) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) § 63.145(a)(5) § 63.145(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.143(f) § 63.145(a)(3) § 63.147(b) § 63.147(b)(2) § 63.147(b)(4) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) § 63.147(f) [G]§ 63.152(a) [G]§ 63.152(f) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) [G]§ 63.146(d) § 63.146(e) § 63.146(e)(1) § 63.146(f) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(g) § 63.151(h) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(c)(2)(iii) § 63.152(c)(2)(iv) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTTW8801	PRO	63G-30C	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.138(d) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	The steam stripper shall be operated and maintained and it shall conform as specified. §63.138(d)(1)-(6)	§ 63.139(d)(3) § 63.139(e) § 63.143(b) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.144(b) § 63.144(b)(1) § 63.144(b)(2) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5) [G]§ 63.144(b)(5)(i) § 63.144(b)(5)(ii) [G]§ 63.144(b)(5)(iii) § 63.144(b)(5)(iv) § 63.144(b)(6) § 63.144(c) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.144(c)(4) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) § 63.145(a)(5)	§ 63.143(f) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5)(ii) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.145(a)(3) § 63.147(b) § 63.147(b)(2) § 63.147(b)(4) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) § 63.147(f) [G]§ 63.152(a) [G]§ 63.152(f) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i)	§ 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) [G]§ 63.146(d) § 63.146(e) § 63.146(e)(1) § 63.146(f) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(g) § 63.151(h) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.145(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(2)(iv) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTTW8801	PRO	63G-30D	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.138(d) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	The steam stripper shall be operated and maintained and it shall conform as specified. §63.138(d)(1)-(6)	§ 63.139(d)(3) § 63.139(e) § 63.143(b) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) § 63.145(a)(5) § 63.145(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.143(f) § 63.145(a)(3) § 63.147(b) § 63.147(b)(2) § 63.147(b)(4) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) § 63.147(f) [G]§ 63.152(a) [G]§ 63.152(f) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) [G]§ 63.146(d) § 63.146(e) § 63.146(e)(1) § 63.146(f) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(g) § 63.151(h) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(2)(iv) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTTW8802	EU	R5140-18A	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(F) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.144(3)(F) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
EUTTW8802	EU	R5140-18B	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4)	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148		
EUTTW8802	EU	R5140-18C	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148 § 60.18(b)	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(E) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
EUTTW8802	PRO	63G-30A	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.138(d) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	The steam stripper shall be operated and maintained and it shall conform as specified. §63.138(d)(1)-(6)	§ 63.139(d)(3) § 63.139(e) § 63.143(b) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.144(b) § 63.144(b)(1) § 63.144(b)(2) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5) [G]§ 63.144(b)(5)(i) § 63.144(b)(5)(ii) [G]§ 63.144(b)(5)(iii) § 63.144(b)(5)(iv) § 63.144(b)(6) § 63.144(c) § 63.144(c)(1)	§ 63.143(f) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5)(ii) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.145(a)(3) § 63.147(b) § 63.147(b)(2) § 63.147(b)(4) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) § 63.147(f) [G]§ 63.152(a) [G]§ 63.152(f) [G]§ 63.172(k)	§ 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) [G]§ 63.146(d) § 63.146(e) § 63.146(e)(1) § 63.146(f) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(g) § 63.151(h) [G]§ 63.151(j) [G]§ 63.152(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.144(c)(2) § 63.144(c)(3) § 63.144(c)(4) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) § 63.145(a)(5) § 63.145(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	[G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(2)(iv) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTTW8802	PRO	63G-30B	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.138(d) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	The steam stripper shall be operated and maintained and it shall conform as specified. §63.138(d)(1)-(6)	§ 63.139(d)(3) § 63.139(e) § 63.143(b) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) § 63.145(a)(5) § 63.145(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l)	§ 63.143(f) § 63.145(a)(3) § 63.147(b) § 63.147(b)(2) § 63.147(b)(4) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) § 63.147(f) [G]§ 63.152(a) [G]§ 63.152(f) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	§ 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) [G]§ 63.146(d) § 63.146(e) § 63.146(e)(1) § 63.146(f) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(g) § 63.151(h) [G]§ 63.151(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(2)(iv) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTTW8802	PRO	63G-30C	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.138(d) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	The steam stripper shall be operated and maintained and it shall conform as specified. §63.138(d)(1)-(6)	§ 63.139(d)(3) § 63.139(e) § 63.143(b) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.144(b) § 63.144(b)(1) § 63.144(b)(2) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5) [G]§ 63.144(b)(5)(i) § 63.144(b)(5)(ii) [G]§ 63.144(b)(5)(iii) § 63.144(b)(5)(iv) § 63.144(b)(6)	§ 63.143(f) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5)(ii) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.145(a)(3) § 63.147(b) § 63.147(b)(2) § 63.147(b)(4) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) § 63.147(f) [G]§ 63.152(a)	§ 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) [G]§ 63.146(d) § 63.146(e) § 63.146(e)(1) § 63.146(f) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(g) § 63.151(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.144(c) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.144(c)(4) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) § 63.145(a)(5) § 63.145(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	[G]§ 63.152(f) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(2)(iv) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
EUTTW8802	PRO	63G-30D	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.138(d) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	The steam stripper shall be operated and maintained and it shall conform as specified. §63.138(d)(1)-(6)	§ 63.139(d)(3) § 63.139(e) § 63.143(b) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) § 63.145(a)(5) § 63.145(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h)	§ 63.143(f) § 63.145(a)(3) § 63.147(b) § 63.147(b)(2) § 63.147(b)(4) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) § 63.147(f) [G]§ 63.152(a) [G]§ 63.152(f) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b)	§ 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) [G]§ 63.146(d) § 63.146(e) § 63.146(e)(1) § 63.146(f) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.151(h) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(2)(iv) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.787(d) § 115.780(b) [G]§ 115.781(a) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.782(c)(1)(C)(i) § 115.782(c)(1)(C)(i)(I) § 115.782(c)(1)(C)(i)(II)	All pumps that are equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal are exempt from the monitoring requirement of §115.781(b) and (c). Submerged pumps or sealless pumps may be used to satisfy the requirements of this subsection.	§ 115.782(d)(2)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) § 115.783(3)(C) [G]§ 115.786(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.782(c)(1)(C)(i)(III) § 115.782(c)(1)(C)(ii) § 115.783(3) [G]§ 115.783(3)(A) [G]§ 115.783(3)(B) § 115.787(b) § 115.787(b)(1) § 115.787(g)				
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.787(d) § 115.780(b) [G]§ 115.781(a) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.782(c)(1)(C)(i) § 115.782(c)(1)(C)(i)(I) § 115.782(c)(1)(C)(i)(II) § 115.782(c)(1)(C)(i)(III) § 115.782(c)(1)(C)(ii) § 115.783(3) [G]§ 115.783(3)(A) [G]§ 115.783(3)(B) § 115.787(b) § 115.787(b)(1) § 115.787(g)	All compressors that are equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal are exempt from the monitoring requirement of §115.781(b) and (c). Submerged pumps or sealless pumps may be used to satisfy the requirements of this subsection.	§ 115.782(d)(2)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) § 115.783(3)(C) [G]§ 115.786(c)
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.787(d) § 115.780(b) [G]§ 115.781(a) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1)	All agitators that are equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal are exempt from the monitoring	§ 115.782(d)(2)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B)	[G]§ 115.782(c)(1)(B)(i) § 115.783(3)(C) [G]§ 115.786(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.782(c)(1)(C)(i) § 115.782(c)(1)(C)(i)(I) § 115.782(c)(1)(C)(i)(II) § 115.782(c)(1)(C)(i)(III) § 115.782(c)(1)(C)(ii) § 115.783(3) [G]§ 115.783(3)(A) [G]§ 115.783(3)(B) § 115.787(b) § 115.787(b)(1) § 115.787(g)	requirement of §115.781(b) and (c). Submerged pumps or sealless pumps may be used to satisfy the requirements of this subsection.		§ 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.783(4)(A)(i) § 115.783(4)(A)(ii) § 115.783(4)(A)(ii)(I) § 115.783(4)(A)(ii)(II) § 115.783(4)(B) § 115.783(4)(B)(i) § 115.783(4)(B)(ii)	Process drains within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(5) § 115.354(6) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(3) § 115.781(b)(4) § 115.781(b)(5) § 115.781(b)(6) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								§ 115.786(g)	
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.787(e) § 115.787(f) § 115.787(g) § 115.788(a) § 115.788(a)(1) § 115.788(a)(2) § 115.788(a)(2)(A) § 115.788(a)(2)(B) § 115.788(a)(2)(C) § 115.788(a)(2)(C)(i) § 115.788(a)(2)(C)(ii) § 115.788(a)(2)(C)(iii) § 115.788(a)(2)(D) § 115.788(a)(3) § 115.788(a)(3)(A) § 115.788(a)(3)(B) [G]§ 115.788(g)	Pressure relief valves (in gaseous service) within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(4) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(b)(8) § 115.781(e) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g) [G]§ 115.788(g)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.788(c) [G]§ 115.788(d) § 115.788(e) [G]§ 115.788(g)
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) [G]§ 115.781(d) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2)	Bypass line valves within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline	§ 115.781(b) § 115.781(b)(10) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) [G]§ 115.781(d) § 115.781(g)	§ 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) § 115.782(c)(2)(A)(ii) § 115.786(a)(1) § 115.786(a)(2)	§ 115.782(c)(2)(A)(ii) [G]§ 115.786(c) § 115.788(c) [G]§ 115.788(d) § 115.788(e) [G]§ 115.788(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.782(c)(2) § 115.782(c)(2)(A) § 115.782(c)(2)(A)(i) § 115.782(c)(2)(A)(ii) § 115.782(c)(2)(B) § 115.783(1) § 115.783(1)(A) § 115.783(1)(B) § 115.783(5) § 115.787(f) § 115.787(f)(4) § 115.787(g) § 115.788(a) § 115.788(a)(1) § 115.788(a)(2) § 115.788(a)(2)(A) § 115.788(a)(2)(B) § 115.788(a)(2)(C) § 115.788(a)(2)(C)(i) § 115.788(a)(2)(C)(ii) § 115.788(a)(2)(C)(iii) § 115.788(a)(2)(D) § 115.788(a)(3) § 115.788(a)(3)(A) § 115.788(a)(3)(B) [G]§ 115.788(g)	processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2) § 115.786(a)(1)	§ 115.786(a)(2)(A) § 115.786(a)(2)(B) § 115.786(b)(1) § 115.786(b)(2) § 115.786(b)(2)(A) § 115.786(b)(2)(B) § 115.786(b)(2)(C) [G]§ 115.786(b)(3) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(2) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g) [G]§ 115.788(g)	
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(2) § 115.782(c)(2)(A) § 115.782(c)(2)(A)(i) § 115.782(c)(2)(A)(ii) § 115.782(c)(2)(B) § 115.783(5) § 115.787(f)	Valves within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(g)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3)	§ 115.782(c)(2)(A)(ii) [G]§ 115.786(c) § 115.788(c) [G]§ 115.788(d) § 115.788(e) [G]§ 115.788(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.787(f)(4) § 115.787(g) § 115.788(a) § 115.788(a)(1) § 115.788(a)(2) § 115.788(a)(2)(A) § 115.788(a)(2)(B) § 115.788(a)(2)(C) § 115.788(a)(2)(C)(i) § 115.788(a)(2)(C)(ii) § 115.788(a)(2)(C)(iii) § 115.788(a)(2)(D) § 115.788(a)(3) § 115.788(a)(3)(A) § 115.788(a)(3)(B) [G]§ 115.788(g)	waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2)	§ 115.782(c)(2)(A)(ii) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(2) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g) [G]§ 115.788(g)	
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv)	Flanges or other connectors within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(11) § 115.354(3) § 115.354(5) § 115.354(6) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(3) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(f) § 115.781(f)(1) § 115.781(f)(2) § 115.781(f)(3) § 115.781(f)(4) § 115.781(f)(5) § 115.781(f)(6) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.789(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 115.782(d)(2) § 115.789(1)(B)		
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.782(c)(1)(C)(i) § 115.782(c)(1)(C)(i)(I) § 115.782(c)(1)(C)(i)(II) § 115.782(c)(1)(C)(i)(III) § 115.782(c)(1)(C)(ii) § 115.783(3) [G]§ 115.783(3)(A) [G]§ 115.783(3)(B) § 115.787(b)	Compressor seals within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(c)(1) § 115.781(c)(2) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) § 115.783(3)(C) [G]§ 115.786(c)
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv)	Pump seals within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(c)(1) § 115.781(c)(2)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3)	[G]§ 115.782(c)(1)(B)(i) § 115.783(3)(C) [G]§ 115.786(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.782(c)(1)(C)(i) § 115.782(c)(1)(C)(i)(I) § 115.782(c)(1)(C)(i)(II) § 115.782(c)(1)(C)(i)(III) § 115.782(c)(1)(C)(ii) § 115.783(3) [G]§ 115.783(3)(A) [G]§ 115.783(3)(B) § 115.787(b) § 115.787(b)(1)	waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.782(c)(1)(C)(i) § 115.782(c)(1)(C)(i)(I) § 115.782(c)(1)(C)(i)(II) § 115.782(c)(1)(C)(i)(III) § 115.782(c)(1)(C)(ii) § 115.783(3) [G]§ 115.783(3)(A) [G]§ 115.783(3)(B) § 115.787(b)	Agitators within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(5) § 115.354(6) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(3) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(c)(1) § 115.781(c)(2) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) § 115.783(3)(C) [G]§ 115.786(c)
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1)	Heat exchanger heads, sight glasses, meters, gauges, sampling connections, bolted manways, hatches, sump covers, junction	§ 115.781(b) § 115.781(b)(10) § 115.781(b)(3) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A)	§ 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.789(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv)	box vents, and covers and seals on VOC water separators within the process unit or processes listed in §115.780(a) in which a HRVOC is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.781(b)(7)(B) § 115.781(f) § 115.781(f)(1) § 115.781(f)(2) § 115.781(f)(3) § 115.781(f)(4) § 115.781(f)(5) § 115.781(f)(6) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2) § 115.789(1)(B)	[G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.358(c)(1) [G]§ 115.358(h) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(2) § 115.782(b)(3) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv)	Components within the process unit or processes listed in §115.780(a) is subject to the requirements of this division. If the owner of operator elects to use the alternative work practice in §115.358 of this title, a leak is defined as specified in §115.358 of this title, including any leak detected using the alternative work practice on a component that is subject to the requirements of this division but not specifically selected for alternative work practice monitoring.	§ 115.354(1) § 115.354(11) § 115.354(13)(A) § 115.354(13)(B) § 115.354(13)(C) § 115.354(13)(D) § 115.354(13)(E) § 115.354(13)(F) § 115.354(4) § 115.354(5) § 115.354(9) § 115.358(c)(2) § 115.358(d) [G]§ 115.358(e) § 115.358(f) § 115.781(b) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2)	§ 115.354(13)(D) § 115.354(13)(E) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) [G]§ 115.356(4) § 115.356(5) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C)	[G]§ 115.358(g) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 115.781(h)(1) § 115.781(h)(2) § 115.781(h)(3) § 115.781(h)(4) § 115.781(h)(5) [G]§ 115.781(h)(6) § 115.782(b)(4) § 115.782(d)(1) § 115.788(h)(1) [G]§ 115.788(h)(2) § 115.788(h)(3)	§ 115.786(e) [G]§ 115.786(f) § 115.786(g)	
FUGITIVES	EU	R5780-ALL	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(2) § 115.782(c)(2)(A) § 115.782(c)(2)(A)(i) § 115.782(c)(2)(A)(ii) § 115.782(c)(2)(B) § 115.783(5) § 115.787(f) § 115.787(f)(2) § 115.787(f)(3) § 115.787(f)(4) § 115.787(g) § 115.788(a) § 115.788(a)(1) § 115.788(a)(2) § 115.788(a)(2)(A) § 115.788(a)(2)(B) § 115.788(a)(2)(C) § 115.788(a)(2)(C)(i) § 115.788(a)(2)(C)(ii) § 115.788(a)(2)(C)(iii) § 115.788(a)(2)(D) § 115.788(a)(3)	Open-ended valves or lines within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(3) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(f) § 115.781(f)(1) § 115.781(f)(2) § 115.781(f)(3) § 115.781(f)(4) § 115.781(f)(5) § 115.781(f)(6) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2) § 115.789(1)(B)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) § 115.782(c)(2)(A)(ii) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(2) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g) [G]§ 115.788(g)	§ 115.782(c)(2)(A)(ii) [G]§ 115.786(c) § 115.788(c) [G]§ 115.788(d) § 115.788(e) [G]§ 115.788(g) § 115.789(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.788(a)(3)(A) § 115.788(a)(3)(B) [G]§ 115.788(g)				
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(6)	Components at a petroleum refinery or synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process, that contact a process fluid that contains less than 10% VOC by weight and components at a natural gas/gasoline processing operation that contact a process fluid that contains less than 1.0% VOC by weight are exempt from the requirements of this division except §115.356(3)(C) of this title.	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(5)	Reciprocating compressors and positive displacement pumps used in natural gas/gasoline processing operations are exempt from the requirements of this division except §115.356(3)(C) of this title.	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(10)	Instrumentation systems, as defined in 40 CFR §63.161 (January 17, 1997), that meet 40 CFR §63.169	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						(June 20, 1996) are exempt from the requirements of this division except §115.356(3)(C) of this title.			
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(11)	Sampling connection systems, as defined in 40 CFR §63.161 (January 17, 1997), that meet the requirements of 40 CFR §63.166(a) and (b) (June 20, 1996) are exempt from the requirements of this division except §115.356(3)(C) of this title.	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(13)	Components/systems that contact a process fluid containing VOC having a true vapor pressure equal to or less than 0.002 psia at 68 degrees Fahrenheit are exempt from the requirements of this division except §115.356(3)(C) of this title.	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(2) § 115.352(9)	Each pressure relief valve equipped with a rupture disk must comply with §115.352(9) and §115.356(3)(C).	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery &	§ 115.353(a) § 115.353(b) § 115.910	For all affected persons in the Beaumont-Port Arthur, Dallas-Fort	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Petrochemicals		Worth, El Paso, and Houston-Galveston areas, as defined in §115.10, any alternate methods of demonstrating and documenting continuous compliance with the applicable control requirements or exemption criteria in this division may be approved by the executive director in accordance with §115.910 if emission reductions are demonstrated to be substantially equivalent.			
FUGITIVES	EU	R5352A LL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(C) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(4) § 115.352(5) § 115.352(6) § 115.352(7) § 115.352(8) § 115.357(8) § 115.358(c)(1) [G]§ 115.358(h)	No component shall be allowed to have a VOC leak, for more than 15 days, after discovery. If the owner or operator elects to use the alternative work practice in §115.358 of this title, any leak detected as defined in §115.358 of this title, including any leak detected using the alternative work practice on a component that is subject to the requirements of this division but not specifically selected for alternative work practice monitoring.	§ 115.354(1) § 115.354(11) § 115.354(13)(A) § 115.354(13)(B) § 115.354(13)(C) § 115.354(13)(D) § 115.354(13)(E) § 115.354(13)(F) § 115.354(4) § 115.354(5) § 115.354(9) [G]§ 115.355 § 115.358(c)(2) § 115.358(d) [G]§ 115.358(e) § 115.358(f)	§ 115.352(7) § 115.354(13)(D) § 115.354(13)(E) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) [G]§ 115.356(4) § 115.356(5)	[G]§ 115.358(g)
FUGITIVES	EU	R5352A	VOC	30 TAC Chapter	§ 115.352(1)(A)	No process drains shall	§ 115.354(1)	§ 115.352(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		LL		115, Pet. Refinery & Petrochemicals	§ 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(3) § 115.352(7) § 115.357(1)	be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	
FUGITIVES	EU	R5352A LL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(3) § 115.352(7)	No process drains shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) § 115.356(5)	None
FUGITIVES	EU	R5352A LL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(5) § 115.352(7) § 115.352(9) § 115.357(1) § 115.357(8) § 115.357(9)	No pressure relief valves shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(4) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(5) § 115.352(7) § 115.352(9) § 115.357(12) § 115.357(8) § 115.357(9)	No pressure relief valves shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(4) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(4) § 115.352(5) § 115.352(6) § 115.352(7) § 115.357(1) § 115.357(8) § 115.357(9)	No open-ended valves or lines shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(4) § 115.352(5) § 115.352(6) § 115.352(7) § 115.357(12)	No open-ended valves or lines shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.357(8) § 115.357(9)	fluid based on sight, smell, or sound.			
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(4) § 115.352(5) § 115.352(6) § 115.352(7) § 115.357(1) § 115.357(8) § 115.357(9)	No valves shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(4) § 115.352(5) § 115.352(6) § 115.352(7) § 115.357(12) § 115.357(8) § 115.357(9)	No valves shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(3) § 115.352(5) § 115.352(7) § 115.352(8)	No flanges or other connectors shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 500 parts per million by volume	§ 115.354(1) § 115.354(11) § 115.354(3) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.357(1) § 115.357(12) § 115.357(8)	above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.			
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(3) § 115.352(5) § 115.352(7) § 115.352(8) § 115.357(12) § 115.357(8)	No flanges or other connectors shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(11) § 115.354(3) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(7) § 115.357(1) § 115.357(12) § 115.357(8)	No agitators shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C)	No agitators shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration	§ 115.354(1) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(7) § 115.357(1) § 115.357(12) § 115.357(8)	greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.		§ 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(7) § 115.357(12) § 115.357(8)	No agitators shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(3) § 115.357(8)	No compressor seals shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	[G]§ 115.355	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	None
FUGITIVES	EU	R5352ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(10) § 115.352(2)	No compressor seals shall be allowed to have a VOC leak, for more than 15 days after	[G]§ 115.355	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(4) § 115.357(8)	discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.		§ 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	
FUGITIVES	EU	R5352A LL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(1) § 115.357(8)	No compressor seals shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	None
FUGITIVES	EU	R5352A LL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(12) § 115.357(8)	No compressor seals shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
FUGITIVES	EU	R5352A	VOC	30 TAC Chapter	§ 115.352(1)(B)	No pump seals shall be	[G]§ 115.355	§ 115.352(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		LL		115, Pet. Refinery & Petrochemicals	§ 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(4) § 115.357(8)	allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.		§ 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	
FUGITIVES	EU	R5352A LL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(1) § 115.357(8)	No pump seals shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	None
FUGITIVES	EU	R5352A LL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(12)	No pump seals shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight,	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.357(8)	smell, or sound.			
FUGITIVES	EU	60VVALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-1(d) § 60.486(k)	Equipment that is in vacuum service is excluded from the requirements of §60.482-2 to §60.482-10, if it is identified as required in §60.486(e)(5).	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(5) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUGITIVES	EU	60VVALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-2(b)(1) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-2(a)(2) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k)	If an instrument reading of 10,000 ppm or greater is measured for pumps in light liquid service, a leak is detected.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-2(a)(1) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUGITIVES	EU	60VVALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-3(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-3(b) § 60.482-3(c)	Each compressor shall be equipped with a seal system that includes a barrier fluid system and that prevents leakage of VOC to the atmosphere,	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	except as provided in §60.482-1(c) and paragraphs (h), (i), and (j) of this section.		[G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	
FUGITIVES	EU	60VVALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-4(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-4(b)(1) § 60.482-4(c) § 60.482-4(d)(1) § 60.482-4(d)(2) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	Except during pressure releases, each pressure relief device in gas/vapor service shall be operated with no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as determined by the methods specified in § 60.485(c).	§ 60.482-4(b)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(3) [G]§ 60.486(e)(4) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUGITIVES	EU	60VVALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-5(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k)	Each sampling connection system shall be equipped with a closed-purge, closed-loop, or closed-vent system, except as provided in §60.482-1(c) and paragraph (c) of this section.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUGITIVES	EU	60VVALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-6(a)(1) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(2)	Each open-ended valve or line shall be equipped with a cap, blind flange, plug, or a second valve, except as provided in	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k)	§60.482-1(c) and paragraphs (d) and (e) of this section.			
FUGITIVES	EU	60VVAL L	VOC	40 CFR Part 60, Subpart VV	§ 60.482-7(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k)	If an instrument reading of 10,000 ppm or greater is measured for valves in gas/vapor service and in light liquid service, a leak is detected.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(ii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUGITIVES	EU	60VVAL L	VOC	40 CFR Part 60, Subpart VV	§ 60.482-8(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k)	For pumps in heavy liquid service, if an instrument reading of 10,000 ppm or greater is measured, a leak is detected.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUGITIVES	EU	60VVAL L	VOC	40 CFR Part 60, Subpart VV	§ 60.482-8(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g)	For valves in heavy liquid service, if an instrument reading of 10,000 ppm or greater is	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.482-9(e) § 60.482-9(f) § 60.486(k)	measured, a leak is detected.	§ 60.485(f)	§ 60.486(e) § 60.486(e)(1) § 60.486(j)	
FUGITIVES	EU	60VVALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-8(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	For pressure relief devices in light liquid or in heavy liquid service, if an instrument reading of 10,000 ppm or greater is measured, a leak is detected.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUGITIVES	EU	60VVALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-8(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	For flanges and other connectors, if an instrument reading of 10,000 ppm or greater is measured, a leak is detected.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUGITIVES	EU	60VVALL	VOC	40 CFR Part 60, Subpart VV	[G]§ 60.482-1(e) § 60.486(k)	Equipment that an owner or operator designates as being in VOC service less than 300 hours (hr)/yr is	None	§ 60.486 [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						excluded from the requirements of §§ 60.482-2 through 60.482-10 if it is identified as required in §60.486(e)(6) and it meets any of the conditions specified in paragraphs (e)(1) through (3) of this section. §60.482-1(e)(1)-(3)		§ 60.486(j)	
FUGITIVES	EU	61J-ALL	BENZENE	40 CFR Part 61, Subpart J	§ 61.112(a) § 61.112(b)	Each owner or operator subject to this subpart shall comply with the requirements of 40 CFR 61, Subpart V - National Emission Standard for Equipment Leaks (Fugitive Emission Sources).	None	None	None
FUGITIVES	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	§ 61.242-1(e)	Equipment that is in vacuum service is excluded from the requirements of §61.242-2 to §61.242-11, if it is identified as required in §61.246(e)(5).	None	[G]§ 61.246(e)	None
FUGITIVES	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-2 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for pumps. §61.242-2(a)-(g)	[G]§ 61.242-2 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(h) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
FUGITIVES	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-3 § 61.242-1(a)	Comply with standards for compressors.	[G]§ 61.242-3 [G]§ 61.245(b)	[G]§ 61.246(a) [G]§ 61.246(b)	[G]§ 61.247(a) [G]§ 61.247(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	§61.242-3(a)-(i)	[G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(h) [G]§ 61.246(i) § 61.246(j)	§ 61.247(c) [G]§ 61.247(e)
FUGITIVES	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-4 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for pressure relief devices in gas/vapor service. §61.242-4(a)-(c)	[G]§ 61.242-4 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
FUGITIVES	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-5 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for sampling connection systems. §61.242-5(a)-(c)	[G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
FUGITIVES	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-6 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for open-ended valves or lines. §61.242-6(a)-(c)	[G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
FUGITIVES	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-7 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10 [G]§ 61.243-1 [G]§ 61.243-2	Comply with standards for valves. §61.242-7(a)-(h)	[G]§ 61.242-7 [G]§ 61.243-1 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(f) [G]§ 61.246(g) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) § 61.247(d) [G]§ 61.247(e)
FUGITIVES	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-8 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for pressure relief devices in liquid service. § 61.242-8(a)-(d)	[G]§ 61.242-8 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
FUGITIVES	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	§ 61.242-9 § 61.242-1(a) § 61.242-1(b)	Each product accumulator vessel shall be equipped with a	[G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.242-1(d)	closed-vent system to capture and transport any leakage from the vessel to a control device as in §61.242-11, except in §61.242-1(c).		§ 61.246(j)	[G]§ 61.247(e)
FUGITIVES	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-8 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for flanges and other connectors. § 61.242-8(a)-(d)	[G]§ 61.242-8 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
FUGITIVES	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-11(f) § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10 [G]§ 61.242-11(f) [G]§ 61.242-11(g) § 61.242-11(h) § 61.242-11(i) [G]§ 61.242-11(j) [G]§ 61.242-11(k) § 61.242-11(m)	Except as provided in §61.242-11(i)-(k), each closed vent system shall be inspected according to the procedures and schedule specified in 61.242-11(f)(1) and (2), as applicable. § 61-242-11(f)(1)-(2)	[G]§ 61.242-11(f) [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.242-11(l) [G]§ 61.246(a) [G]§ 61.246(d) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
FUGITIVES	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2480(a) The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart FFFF	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart FFFF	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart FFFF	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart FFFF	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart FFFF
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.162(e) § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h)	Equipment that is in organic HAP service less than 300 hours per year is excluded from the requirements of §§63.163 - 63.174 and	[G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(i) § 63.181(j)	[G]§ 63.182(a) [G]§ 63.182(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						§63.178 if it is identified as required in §63.181(j).			
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.164 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Compressors. §63.164(a)-(i)	[G]§ 63.164 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.165 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief device in gas/vapor service. §63.165(a)-(d)	[G]§ 63.165 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.166 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Sampling connection systems. §63.166(a)-(c)	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pumps in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Valves in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B)	40 CFR Part 63,	[G]§ 63.169	Standards: Connectors	[G]§ 63.169	§ 63.181(a)	[G]§ 63.182(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
			HAPS	Subpart H	§ 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	in heavy liquid service. §63.169(a)-(d)	[G]§ 63.180(b) [G]§ 63.180(d)	[G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Agitators in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Instrumentation systems. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief devices in liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.170 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Surge control vessels and bottom receivers.	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.173 § 63.162(a) § 63.162(c) [G]§ 63.162(f)	Standards: Agitators gas/vapor service and in light liquid service. §63.173(a)-(j).	[G]§ 63.173 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.162(g) § 63.162(h) [G]§ 63.171				§ 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.174 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Connectors in gas/vapor service and in light liquid service. §63.174(a)-(j)	[G]§ 63.174 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.163 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.176	Standards: Pumps in light liquid service. §63.163(a)-(j)	[G]§ 63.163 [G]§ 63.176 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(3) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7) § 63.181(h)(8)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.167 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Open-ended valves or lines. §63.167(a)-(e).	[G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.168 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h)	Standards: Valves in gas/vapor service and in light liquid service. §63.168(a)-(j)	[G]§ 63.168 [G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(1)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.171 [G]§ 63.175			[G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7)	
FUGITIVES	EU	63HALL-VNT	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	Owners/operators of closed-vent systems and control devices used to comply with provisions of this subpart shall comply with the provisions of this section, except as provided in §63.162(b).	[G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
FUGITIVES	EU	63HALL-VNT	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(d) § 63.11(b) § 63.172(e) [G]§ 63.172(h) § 63.172(m)	Flares used to comply with this subpart shall comply with the requirements of § 63.11(b) of 40 CFR 63, Subpart A.	§ 63.172(e) [G]§ 63.172(h) [G]§ 63.180(b) [G]§ 63.180(d) [G]§ 63.180(e)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) § 63.181(g)(1)(iii) § 63.181(g)(1)(iv) [G]§ 63.181(g)(2)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRPALZVENT	EP	R5720-5	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.727(c)(2)	A vent gas stream that has the potential to emit HRVOCs, but has a concentration less than 100 ppmv at all times or has a maximum potential flow rate equal to or less than 100 dry standard cubic feet per hour is exempt from this division with the exception of § 115.726(e)(3)(A) of this title. The maximum potential HRVOC	None	§ 115.726(e)(3)(A) § 115.726(j)(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						emissions for the sum of all vent gas streams claimed under this exemption, must be less for the account specified in § 115.722(a) or (b) of this title than 0.5 tpy.			
GRPALZVENT	EP	R5121-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
GRPBOILER	EU	R7ICI-1A	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a)(2)(A) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		
GRPBOILER	EU	R7ICI-1A	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a)(2)(A) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPBOILER	EU	R7ICI-1B	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(7) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a)(2)(A) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
GRPBOILER	EU	R7ICI-1B	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.335(g) § 117.340(a)(2)(A) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120(1) § 117.8120(1)(A)		§ 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
GRPBOILER	EU	60D-1A	PM	40 CFR Part 60, Subpart D	§ 60.42(a)(1)	On/after the §60.8 tests, no affected facility shall emit gases containing particulate matter in excess of 43 ng/J heat input (0.10 lb/MMBtu) derived from fossil fuel or fossil fuel and wood residue.	§ 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(2) [G]§ 60.46(d)(1) § 60.46(d)(2) [G]§ 60.46(d)(3) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
GRPBOILER	EU	60D-1A	PM (OPACITY)	40 CFR Part 60, Subpart D	§ 60.42(a)(2)	On/after the performance tests of §60.8, no affected facility shall emit gases exhibiting greater than 20% opacity except for	§ 60.45(b)(1) § 60.45(b)(7) [G]§ 60.45(b)(7)(i) [G]§ 60.45(b)(7)(ii) § 60.45(b)(7)(iii) § 60.45(h)	§ 60.45(h) [G]§ 60.45(h)(1) [G]§ 60.45(h)(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						one six-minute period per hour of not more than 27% opacity.	[G]§ 60.45(h)(1) [G]§ 60.45(h)(2) § 60.46(a) § 60.46(b)(3)		
GRPBOILER	EU	60D-1A	SO_2	40 CFR Part 60, Subpart D	§ 60.40(a)	The affected facility burns fuel (such as only gaseous fuels) that has no specific SO_2 emission requirements.	§ 60.45(b)(1) § 60.45(b)(4)	None	None
GRPBOILER	EU	60D-1A	NO_X	40 CFR Part 60, Subpart D	§ 60.44(a)(1)	On/after the §60.8 tests, no affected facility shall emit gases containing NOx, expressed as NO2, in excess of 86 ng/J heat input (0.2 lb/MMBtu) derived from gaseous fossil fuel.	§ 60.45(a) § 60.45(b)(3) § 60.45(c) § 60.45(c)(1) § 60.45(c)(2) § 60.45(c)(3) § 60.45(c)(3)(i) § 60.45(c)(3)(ii) [G]§ 60.45(e) [G]§ 60.45(f) § 60.45(g) § 60.45(g)(3) § 60.45(g)(3)(i) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(5) [G]§ 60.46(d)(1) § 60.46(d)(5) § 60.46(d)(6) § 60.46(d)(7)	None	§ 60.45(g)
GRPBTBZTK	EU	R5112-3	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
GRPBTBZTK	EU	63G-3	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
GRPBZTW	PRO	61FF-8A	BENZENE	40 CFR Part 61, Subpart FF	§ 61.348(a)(5) § 60.18 § 61.348(b)(1) § 61.348(f) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	An owner or operator that aggregates or mixes any combination of process wastewater, product tank drawdown, or landfill leachate subject to §61.342(c)(1) together with other waste streams to create a combined waste stream for the purpose of facilitating management or treatment of waste in a	§ 60.18(f)(2) § 61.348(f) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(a)(2) [G]§ 61.354(b) § 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.354(a)(2) § 61.354(c) § 61.354(c)(3) § 61.356(e) § 61.356(e)(1) § 61.356(e)(2) § 61.356(f) § 61.356(f)(1) § 61.356(h) [G]§ 61.356(i) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	§ 61.357(d)(7) § 61.357(d)(7)(ii) § 61.357(d)(7)(iii) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						wastewater treatment system shall operate the wastewater treatment system in accordance with §61.348(b). These provisions apply to above- and below-ground level wastewater treatment systems.		§ 61.356(j)(7)	
GRPBZTW	PRO	61FF-8B	BENZENE	40 CFR Part 61, Subpart FF	§ 61.348(a)(5) § 60.18 § 61.348(b)(1) § 61.348(f) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	An owner or operator that aggregates or mixes any combination of process wastewater, product tank drawdown, or landfill leachate subject to §61.342(c)(1) together with other waste streams to create a combined waste stream for the purpose of facilitating management or treatment of waste in a wastewater treatment system shall operate the wastewater treatment system in accordance with §61.348(b). These provisions apply to above- and below-ground level wastewater treatment systems.	§ 60.18(f)(2) § 61.348(f) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(a)(2) [G]§ 61.354(b) § 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.354(a)(2) § 61.354(c) § 61.354(c)(3) § 61.356(e) § 61.356(e)(1) § 61.356(e)(2) § 61.356(f) § 61.356(f)(1) § 61.356(h) [G]§ 61.356(i) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(ii) § 61.357(d)(7)(iii) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
GRPBZTW	PRO	61FF-8C	BENZENE	40 CFR Part 61, Subpart FF	§ 61.348(a)(5) § 60.18 § 61.348(b)(1) § 61.348(f) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv)	An owner or operator that aggregates or mixes any combination of process wastewater, product tank drawdown, or landfill leachate subject to §61.342(c)(1) together with other	§ 60.18(f)(2) § 61.348(f) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(a)(2) [G]§ 61.354(b) § 61.354(c)	§ 61.354(a)(2) § 61.354(c) § 61.354(c)(3) § 61.355(g) § 61.356(e) § 61.356(e)(1) [G]§ 61.356(e)(3) § 61.356(f)	§ 61.357(d)(7) § 61.357(d)(7)(ii) § 61.357(d)(7)(iii) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	waste streams to create a combined waste stream for the purpose of facilitating management or treatment of waste in a wastewater treatment system shall operate the wastewater treatment system in accordance with §61.348(b). These provisions apply to above- and below-ground level wastewater treatment systems.	§ 61.354(c)(3) § 61.355(g) [G]§ 61.355(h)	§ 61.356(f)(1) § 61.356(h) [G]§ 61.356(i) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	
GRPBZTW	PRO	61FF-8D	BENZENE	40 CFR Part 61, Subpart FF	§ 61.348(a)(5) § 60.18 § 61.348(b)(1) § 61.348(f) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	An owner or operator that aggregates or mixes any combination of process wastewater, product tank drawdown, or landfill leachate subject to §61.342(c)(1) together with other waste streams to create a combined waste stream for the purpose of facilitating management or treatment of waste in a wastewater treatment system shall operate the wastewater treatment system in accordance with §61.348(b). These provisions apply to above- and below-ground level wastewater treatment systems.	§ 60.18(f)(2) § 61.348(f) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(a)(2) [G]§ 61.354(b) § 61.354(c) § 61.354(c)(3) § 61.355(g) [G]§ 61.355(h)	§ 61.354(a)(2) § 61.354(c) § 61.354(c)(3) § 61.355(g) § 61.356(e) § 61.356(e)(1) [G]§ 61.356(e)(3) § 61.356(f) § 61.356(f)(1) § 61.356(h) [G]§ 61.356(i) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(ii) § 61.357(d)(7)(iii) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
GRPBZTW	PRO	63G-7A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.138(e)(2) § 63.11	Reduce mass flow rate of Table 8 and/or Table	§ 63.138(j)(1) § 63.139(d)(3)	§ 63.138(j)(1) § 63.144(b)(3)	§ 63.143(d) § 63.146(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	9 compounds in Group 1 wastewater stream as specified. The process efficiency shall be computed as per §63.145(c) or §63.145(d).	§ 63.139(e) § 63.143(d) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.144(b) § 63.144(b)(1) § 63.144(b)(2) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5) [G]§ 63.144(b)(5)(i) § 63.144(b)(5)(ii) [G]§ 63.144(b)(5)(iii) § 63.144(b)(5)(iv) § 63.144(b)(6) § 63.144(c) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.144(c)(4) § 63.145(a) § 63.145(a)(1) § 63.145(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.144(b)(4) § 63.144(b)(5)(ii) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.145(a)(3) [G]§ 63.145(a)(4) § 63.147(b) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) [G]§ 63.152(a) [G]§ 63.152(f) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) § 63.146(b)(9) § 63.146(b)(9)(i) [G]§ 63.146(d) § 63.146(e) § 63.146(e)(1) § 63.146(f) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) § 63.151(e)(5) § 63.151(f) § 63.151(f)(1) § 63.151(f)(2) § 63.151(f)(3) § 63.151(h) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.182(d)
GRPBZTW	PRO	63G-7B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.138(e)(2) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) § 63.145(c)(6) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	Reduce mass flow rate of Table 8 and/or Table 9 compounds in Group 1 wastewater stream as specified. The process efficiency shall be computed as per §63.145(c) or §63.145(d).	§ 63.138(j)(2) § 63.139(d)(3) § 63.139(e) § 63.143(d) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.144(b) § 63.144(b)(1) § 63.144(b)(2) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5) [G]§ 63.144(b)(5)(i) § 63.144(b)(5)(ii) [G]§ 63.144(b)(5)(iii) § 63.144(b)(5)(iv) § 63.144(b)(6) § 63.144(c) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.144(c)(4) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) [G]§ 63.145(a)(4) § 63.145(a)(5) [G]§ 63.145(a)(6) § 63.145(c) § 63.145(c)(1) § 63.145(c)(2) § 63.145(c)(3) § 63.145(c)(4) § 63.145(c)(5) § 63.145(c)(6) § 63.145(g) [G]§ 63.145(j)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)		
GRPBZTW	PRO	63G-7C	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.138(e)(2) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	Reduce mass flow rate of Table 8 and/or Table 9 compounds in Group 1 wastewater stream as specified. The process efficiency shall be computed as per §63.145(c) or §63.145(d).	§ 63.138(j)(1) § 63.139(d)(3) § 63.139(e) § 63.143(d) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.144(b) § 63.144(b)(1) § 63.144(b)(2) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5) [G]§ 63.144(b)(5)(i) § 63.144(b)(5)(ii) [G]§ 63.144(b)(5)(iii) § 63.144(b)(5)(iv) § 63.144(b)(6) § 63.144(c) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.144(c)(4) § 63.145(a) § 63.145(a)(1) § 63.145(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h)	§ 63.138(j)(1) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5)(ii) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.145(a)(3) [G]§ 63.145(a)(4) § 63.147(b) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) [G]§ 63.152(a) [G]§ 63.152(f) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.143(d) § 63.146(a) § 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) § 63.146(b)(9) § 63.146(b)(9)(i) [G]§ 63.146(d) § 63.146(e) § 63.146(e)(1) § 63.146(f) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) § 63.151(e)(5) § 63.151(f) § 63.151(f)(1) § 63.151(f)(2) § 63.151(f)(3) § 63.151(h) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)		§ 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRPBZTW	PRO	63G-7D	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.138(e)(2) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) § 63.145(c)(6) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	Reduce mass flow rate of Table 8 and/or Table 9 compounds in Group 1 wastewater stream as specified. The process efficiency shall be computed as per §63.145(c) or §63.145(d).	§ 63.138(j)(2) § 63.139(d)(3) § 63.139(e) § 63.143(d) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.144(b) § 63.144(b)(1) § 63.144(b)(2) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5) [G]§ 63.144(b)(5)(i) § 63.144(b)(5)(ii) [G]§ 63.144(b)(5)(iii) § 63.144(b)(5)(iv) § 63.144(b)(6) § 63.144(c) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.144(c)(4) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) [G]§ 63.145(a)(4)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.145(a)(5) [G]§ 63.145(a)(6) § 63.145(c) § 63.145(c)(1) § 63.145(c)(2) § 63.145(c)(3) § 63.145(c)(4) § 63.145(c)(5) § 63.145(c)(6) § 63.145(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)		
GRPBZTW	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
GRPC4MTTK1	EU	R5112-4A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
GRPC4MTTK1	EU	R5112-4B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
GRPC4MTTK1	EU	R5112-4C	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(A) § 115.112(e)(3)(A)(i)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(1) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
GRPC4MTTK1	EU	R5112-4D	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
GRPC4MTTK1	EU	R5112-4E	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this paragraph for crude oil and condensate.			
GRPC4MTTK1	EU	63G-1A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRPC4MTTK1	EU	63G-1B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								[G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRPC4MTTK1	EU	63G-1C	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(f) § 63.119(a)(2) [G]§ 63.119(f)(1) [G]§ 63.119(f)(3)	Owner or operator who routes emissions to a fuel gas system or to a process, as defined in §63.111, to comply with §63.119(a)(1), or (a)(2) shall comply with §63.119(f)(1)-(3) as applicable.	None	§ 63.123(a) [G]§ 63.123(h) [G]§ 63.152(a)	§ 63.120(f) § 63.122(c)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
GRPC4MTTK1	EU	63G-1D	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(f) § 63.119(a)(2) [G]§ 63.119(f)(1) [G]§ 63.119(f)(3)	Owner or operator who routes emissions to a fuel gas system or to a process, as defined in §63.111, to comply with §63.119(a)(1), or (a)(2) shall comply with §63.119(f)(1)-(3) as applicable.	None	§ 63.123(a) [G]§ 63.123(h) [G]§ 63.152(a)	§ 63.120(f) § 63.122(c)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPC4MTTK1	EU	63G-1E	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRPC4MTTK1	EU	63G-1F	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(e) § 63.11 § 63.119(a)(2) § 63.119(e)(1) § 63.119(e)(3) § 63.119(e)(4) § 63.119(e)(5) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(m)	The owner or operator who elects to use a closed vent system and control device (defined in § 63.111) to comply with§63.119(a)(1) or (a)(2) shall comply with §63.119(e)(1)-(5).	§ 63.120(e)(1) § 63.120(e)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.123(a) [G]§ 63.123(f)(2) [G]§ 63.152(a) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.120(e)(2) § 63.122(c)(2) [G]§ 63.122(g)(1) [G]§ 63.122(g)(3) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRPC4RXR2	EP	60RRR-1A	VOC/TOC	40 CFR Part 60, Subpart RRR	§ 60.700(c)(5)	Vent streams routed to distillation units subject to subpart NNN with no other air releases except for a pressure relief valve, are exempt from all provisions of this subpart except for §60.705(r).	None	None	§ 60.705(r)
GRPC4VENT1	EP	R5720-2	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.722(d) § 115.722(d)(1) § 115.722(d)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(n)	§ 115.726(d)(1) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n)
GRPC4VENT1	EP	R5720-4	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(a)(2)(A) § 115.725(a)(2)(B) § 115.725(a)(2)(C)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this	§ 115.725(a) § 115.725(a)(2)(A) § 115.725(a)(2)(B) § 115.725(a)(2)(C) § 115.725(a)(2)(D)	§ 115.726(b)(1) § 115.726(b)(2) § 115.726(b)(3) [G]§ 115.726(g) [G]§ 115.726(h)	[G]§ 115.725(a)(4) § 115.725(a)(5) § 115.725(n) [G]§ 115.726(a)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.725(a)(2)(D) § 115.725(a)(3) [G]§ 115.725(a)(4) [G]§ 115.725(l) [G]§ 115.726(a)(2)	subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(a)(3) § 115.725(a)(3)(B) [G]§ 115.725(a)(4) § 115.725(a)(5) [G]§ 115.725(l) § 115.725(n)	§ 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	
GRPC4VENT1	EP	R5121-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	None
GRPC4VENT1	EP	R5121-2	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	None
GRPC4VENT1	EP	R5121-4	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(B) § 60.18	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None
GRPC5TK1	EU	R5112-4A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C)	No person shall place, store, or hold VOC in any storage tank unless	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2)	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.18	the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117	§ 115.118(a)(7)	
GRPC5TK1	EU	R5112-4B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
GRPC5TK2	EU	R5112-4A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
GRPC5TK2	EU	R5112-4B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
GRPC5TK2	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2470(a)-Table4.1.b.iii § 63.11(b) § 63.2450(b) § 63.2470(a) § 63.2470(d)	For each Group 1 storage tank for which the maximum true vapor pressure of total HAP at the storage temperature is < 76.6 kilopascals,	[G]§ 63.115(d)(2)(v) § 63.115(d)(3)(iii) § 63.2470(c)(1) § 63.983(b) [G]§ 63.983(b)(1) [G]§ 63.983(b)(2)	§ 63.2450(f)(2) § 63.2450(f)(2)(i) § 63.2450(f)(2)(ii) § 63.2470(c)(1) § 63.983(b) [G]§ 63.983(d)(2)	§ 63.2450(f)(2)(ii) § 63.2450(q) § 63.2470(d) § 63.997(c)(3) § 63.998(a)(1)(iii)(A) [G]§ 63.998(b)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.982(b) § 63.983(a)(1) § 63.983(a)(2) § 63.983(d)(1) § 63.983(d)(1)(i) [G]§ 63.983(d)(2) § 63.983(d)(3) § 63.987(a) § 63.987(b)(1) § 63.987(b)(3) [G]§ 63.997(c)(1) § 63.997(c)(3)	you may reduce total organic HAP emissions by venting emissions through a closed vent system to a flare.	[G]§ 63.983(b)(3) [G]§ 63.983(c)(1) § 63.983(c)(2) § 63.983(c)(3) § 63.983(d)(1) § 63.983(d)(1)(ii) [G]§ 63.987(b)(3)(i) § 63.987(b)(3)(ii) § 63.987(b)(3)(iii) § 63.987(b)(3)(iv) § 63.987(c) § 63.997(a) [G]§ 63.997(c)(1) § 63.997(c)(2) § 63.997(c)(3) § 63.997(c)(3)(i) § 63.997(c)(3)(ii)	§ 63.987(c) § 63.998(a)(1) [G]§ 63.998(a)(1)(i) § 63.998(a)(1)(ii) § 63.998(a)(1)(iii)(A) § 63.998(a)(1)(iii)(B) [G]§ 63.998(b)(1) [G]§ 63.998(b)(2) [G]§ 63.998(b)(3) [G]§ 63.998(b)(5) [G]§ 63.998(c)(1) [G]§ 63.998(d)(1) § 63.998(d)(3)(i) § 63.998(d)(3)(ii) § 63.998(d)(5)	[G]§ 63.999(a)(1) [G]§ 63.999(a)(2) § 63.999(b)(5) § 63.999(c)(1) § 63.999(c)(2)(i) § 63.999(c)(3) § 63.999(c)(6) [G]§ 63.999(c)(6)(i) § 63.999(c)(6)(iv) [G]§ 63.999(d)(1) [G]§ 63.999(d)(2)
GRPCARFLR	EU	65CAR-FL	VOC	40 CFR Part 65, Subpart D	§ 60.700(a) § 60.660(a) § 60.660(b) § 60.660(d)(1) § 60.660(d)(2) § 60.700(b) § 60.700(d)(1) § 60.700(d)(2) § 65.1(a) § 65.1(b) § 65.1(c) § 65.1(d) § 65.1(e) [G]§ 65.1(f) § 65.140 § 65.142(b)(1) § 65.143(a) § 65.143(a)(1) § 65.143(a)(2) [G]§ 65.147(a) § 65.3(a)(1) § 65.3(a)(3) § 65.3(a)(4)	Owners or operators of process vents that are subject to NSPS subparts NNN or RRR may choose to comply with the provisions of 40 CFR part 65, subpart D, to satisfy the requirements of §§60.662 through 60.665 and 60.668 or §§60.702 through 60.705 and 60.708 as applicable.	§ 65.147(b) § 65.147(c) § 65.157(b) § 65.157(b)(1)	§ 65.147(b)(1) § 65.159(a) [G]§ 65.159(b) [G]§ 65.159(c) [G]§ 65.159(d) § 65.163(c)(1) § 65.163(c)(2) § 65.4(a)(1) § 65.4(b) § 65.4(c) § 65.4(c)(1) § 65.4(c)(3)	§ 60.700(d)(4) § 65.159(d)(1) § 65.165(f) § 65.166(a) § 65.166(c) § 65.167(b) [G]§ 65.5(a) [G]§ 65.5(d) [G]§ 65.5(e) [G]§ 65.5(f) [G]§ 65.5(g) [G]§ 65.5(h) [G]§ 65.5(i) [G]§ 65.6(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 65.3(a)(5) § 65.3(b)(3) [G]§ 65.3(b)(5) § 65.3(c) [G]§ 65.3(d) [G]§ 65.6(b) § 65.62(a) § 65.62(b)(1) § 65.63(a)				
GRPCARFURN	EU	65CAR-FUR	VOC	40 CFR Part 65, Subpart D	§ 60.700(a) § 60.660(a) § 60.660(b) § 60.660(d)(1) § 60.700(b) § 60.700(d)(1) § 60.700(d)(2) § 65.1(a) § 65.1(b) § 65.1(c) § 65.1(d) § 65.1(e) [G]§ 65.1(f) § 65.140 § 65.142(b)(2) § 65.143(a) § 65.143(a)(1) § 65.143(a)(2) [G]§ 65.149(a) § 65.149(b)(2) § 65.149(b)(2)(ii) § 65.3(a)(1) § 65.3(a)(3) § 65.3(a)(4) § 65.3(a)(5) § 65.3(b)(3) [G]§ 65.3(b)(5) § 65.3(c) [G]§ 65.3(d) [G]§ 65.6(b) § 65.62(a)	Owners or operators of process vents that are subject to NSPS subparts NNN or RRR may choose to comply with the provisions of 40 CFR part 65, subpart D, to satisfy the requirements of §§60.662 through 60.665 and 60.668 or §§60.702 through 60.705 and 60.708 as applicable.	None	§ 65.163(c)(1) § 65.163(c)(2) § 65.4(a)(1) § 65.4(b) § 65.4(c) § 65.4(c)(1) § 65.4(c)(3)	§ 60.660(d)(4) § 60.700(d)(4) § 65.165(f) § 65.166(a) § 65.167(b) [G]§ 65.5(a) [G]§ 65.5(d) [G]§ 65.5(e) [G]§ 65.5(f) [G]§ 65.5(g) [G]§ 65.5(h) [G]§ 65.5(i) [G]§ 65.6

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 65.62(b)(1) § 65.63(a) § 65.63(a)(2)				
GRPCARFURN	EU	65CAR-FUR	VOC	40 CFR Part 65, Subpart D	§ 60.700(a) § 60.660(a) § 60.660(b) § 60.660(d)(1) § 60.700(b) § 60.700(d)(1) § 60.700(d)(2) § 65.1(a) § 65.1(b) § 65.1(c) § 65.1(d) § 65.1(e) [G]§ 65.1(f) § 65.140 § 65.142(b)(2) § 65.143(a) § 65.143(a)(1) § 65.143(a)(2) [G]§ 65.149(a) § 65.149(b)(2) § 65.149(b)(2)(ii) § 65.3(a)(1) § 65.3(a)(3) § 65.3(a)(4) § 65.3(a)(5) § 65.3(b)(3) [G]§ 65.3(b)(5) § 65.3(c) [G]§ 65.3(d) [G]§ 65.6(b) § 65.62(a) § 65.62(b)(1) § 65.63(a) § 65.63(a)(2)	Owners or operators of process vents that are subject to NSPS subparts NNN or RRR may choose to comply with the provisions of 40 CFR part 65, subpart D, to satisfy the requirements of §§60.662 through 60.665 and 60.668 or §§60.702 through 60.705 and 60.708 as applicable.	None	§ 65.163(c)(1) § 65.163(c)(2) § 65.4(a)(1) § 65.4(b) § 65.4(c) § 65.4(c)(1) § 65.4(c)(3)	§ 60.660(d)(4) § 60.700(d)(4) § 65.165(f) § 65.166(a) § 65.167(b) [G]§ 65.5(a) [G]§ 65.5(d) [G]§ 65.5(e) [G]§ 65.5(f) [G]§ 65.5(g) [G]§ 65.5(h) [G]§ 65.5(i) [G]§ 65.6
GRPECUDM	EU	R5112-1A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C)	No person shall place, store, or hold VOC in any storage tank unless	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2)	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.18	the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117	§ 115.118(a)(7)	
GRPECUDM	EU	R5112-1B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
GRPECUDM	EU	60Kb-1A	VOC	40 CFR Part 60, Subpart Kb	[G]§ 60.112b(a)(3) § 60.18	Storage vessels specified in §60.112b(a) and equipped with a closed vent system/control device	§ 60.113b(d) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1)	§ 60.115b § 60.115b(d)(2) § 60.116b(a) § 60.116b(b)	§ 60.115b § 60.115b(d)(1) § 60.115b(d)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						are to meet the specifications of §60.112b(a)(3)(i)-(ii).	[G]§ 60.116b(e)(3) [G]§ 60.485(b)		
GRPECUDM	EU	60Kb-1B	VOC	40 CFR Part 60, Subpart Kb	[G]§ 60.112b(a)(3) § 60.18	Storage vessels specified in §60.112b(a) and equipped with a closed vent system/control device are to meet the specifications of §60.112b(a)(3)(i)-(ii).	§ 60.113b(d) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3) [G]§ 60.485(b)	§ 60.115b § 60.115b(d)(2) § 60.116b(a) § 60.116b(b)	§ 60.115b § 60.115b(d)(1) § 60.115b(d)(3)
GRPECUDM	EU	60Kb-1C	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(b)(1) § 60.18	Storage vessels specified in §60.112b(b) and equipped with a closed vent system and control device are to meet the specifications in §60.112b(a)(3).	§ 60.113b(d) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3) [G]§ 60.485(b)	§ 60.115b § 60.115b(d)(2) § 60.116b(a) § 60.116b(b)	§ 60.115b § 60.115b(d)(1) § 60.115b(d)(3)
GRPECUDM	EU	60Kb-1D	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(b)(1) § 60.18	Storage vessels specified in §60.112b(b) and equipped with a closed vent system and control device are to meet the specifications in §60.112b(a)(3).	§ 60.113b(d) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3) [G]§ 60.485(b)	§ 60.115b § 60.115b(d)(2) § 60.116b(a) § 60.116b(b)	§ 60.115b § 60.115b(d)(1) § 60.115b(d)(3)
GRPECUDM	EU	61FF-1A	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 60.18 § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 60.18(f)(2) § 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(g)				
GRPECUDM	EU	61FF-1B	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 60.18 § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 60.18(f)(2) § 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
GRPECUDM	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2470(a)-Table4.1.a.ii § 63.11(b) § 63.2450(b) § 63.2470(a) § 63.2470(d) § 63.982(b) § 63.983(a)(1) § 63.983(a)(2) § 63.983(d)(1) § 63.983(d)(1)(i) [G]§ 63.983(d)(2) § 63.983(d)(3) § 63.987(a) § 63.987(b)(1) § 63.987(b)(3) [G]§ 63.997(c)(1) § 63.997(c)(3)	For each Group 1 storage tank for which the maximum true vapor pressure of total HAP at the storage temperature is > 76.6 kilopascals, you must reduce total organic HAP emissions by venting emissions through a closed vent system to a flare.	[G]§ 63.115(d)(2)(v) § 63.115(d)(3)(iii) § 63.2470(c)(1) § 63.983(b) [G]§ 63.983(b)(1) [G]§ 63.983(b)(2) [G]§ 63.983(b)(3) [G]§ 63.983(c)(1) § 63.983(c)(2) § 63.983(c)(3) § 63.983(d)(1) § 63.983(d)(1)(ii) [G]§ 63.987(b)(3)(i) § 63.987(b)(3)(ii) § 63.987(b)(3)(iii) § 63.987(b)(3)(iv) § 63.987(c) § 63.997(a) [G]§ 63.997(c)(1) § 63.997(c)(2) § 63.997(c)(3) § 63.997(c)(3)(i) § 63.997(c)(3)(ii)	§ 63.2450(f)(2) § 63.2450(f)(2)(i) § 63.2450(f)(2)(ii) § 63.2470(c)(1) § 63.983(b) [G]§ 63.983(d)(2) § 63.987(c) § 63.998(a)(1) [G]§ 63.998(a)(1)(i) § 63.998(a)(1)(ii) § 63.998(a)(1)(iii)(A) § 63.998(a)(1)(iii)(B) [G]§ 63.998(b)(1) [G]§ 63.998(b)(2) [G]§ 63.998(b)(3) [G]§ 63.998(b)(5) [G]§ 63.998(c)(1) [G]§ 63.998(d)(1) § 63.998(d)(3)(i) § 63.998(d)(3)(ii) § 63.998(d)(5)	§ 63.2450(f)(2)(ii) § 63.2450(q) § 63.2470(d) § 63.997(c)(3) § 63.998(a)(1)(iii)(A) [G]§ 63.998(b)(3) [G]§ 63.999(a)(1) [G]§ 63.999(a)(2) § 63.999(b)(5) § 63.999(c)(1) § 63.999(c)(2)(i) § 63.999(c)(3) § 63.999(c)(6) [G]§ 63.999(c)(6)(i) § 63.999(c)(6)(iv) [G]§ 63.999(d)(1) [G]§ 63.999(d)(2)
GRPLDBGDK	EU	R5211-	VOC	30 TAC Chapter	§ 115.217(a)(5)(B)	The marine vessel	§ 115.214(a)(3)(B)	§ 115.216	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		1		115, Loading and Unloading of VOC	§ 115.212(a)(6)(D) § 115.214(a)(3)(C) § 115.214(a)(3)(G) § 115.214(a)(3)(G)(i) § 115.217(a)(5)(B)(iii)	transfer operations specified in § 115.217(a)(5)(B)(i)-(iv) are exempt from the requirements of §§ 115.212(a), 115.214(a), and 115.216 of this title, except as noted.	§ 115.214(a)(3)(B)(i) § 115.215 § 115.215(4)	§ 115.216(2)	
GRPLDBGDK	EU	R5211-1	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(5)(B) § 115.214(a)(3)(C) § 115.214(a)(3)(G) § 115.214(a)(3)(G)(i) § 115.217(a)(5)(B)(i)	The marine vessel transfer operations specified in § 115.217(a)(5)(B)(i)-(iv) are exempt from the requirements of §§ 115.212(a), 115.214(a), and 115.216 of this title, except as noted.	§ 115.214(a)(3)(B) § 115.214(a)(3)(B)(i)	§ 115.216 § 115.216(2)	None
GRPLDBGDK	EU	R5211-2	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(6)(A) § 115.212(a)(6)(B) [G]§ 115.212(a)(6)(C) § 115.212(a)(6)(D) [G]§ 115.214(a)(3)(A) § 115.214(a)(3)(C) § 115.214(a)(3)(D) § 115.214(a)(3)(E)	Emissions shall not exceed 0.09lb/1,000gal loaded, or the vapor control system shall maintain a control efficiency of at least 90%, or a vapor balance system or pressurized loading may be used.	[G]§ 115.214(a)(3)(A) § 115.214(a)(3)(B) § 115.214(a)(3)(B)(i) § 115.214(a)(3)(B)(ii) § 115.214(a)(3)(B)(iii) § 115.214(a)(3)(D) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(7) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(iv) ** See CAM Summary	[G]§ 115.214(a)(3)(A) § 115.214(a)(3)(D) § 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(iv) § 115.216(2) [G]§ 115.216(4)	None
GRPLDBGDK	EU	R5211-3	VOC	30 TAC Chapter 115, Loading and Unloading of	§ 115.217(a)(5)(B) § 115.214(a)(3)(C) § 115.214(a)(3)(G)	The marine vessel transfer operations specified in §	§ 115.214(a)(3)(B) § 115.214(a)(3)(B)(i)	§ 115.216 § 115.216(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				VOC	§ 115.214(a)(3)(G)(i) § 115.217(a)(5)(B)(i)	115.217(a)(5)(B)(i)-(iv) are exempt from the requirements of §§ 115.212(a), 115.214(a), and 115.216 of this title, except as noted.			
GRPLDBGDK	EU	61BB-1	BENZENE	40 CFR Part 61, Subpart BB	[G]§ 61.302(a) § 61.302(b) § 61.302(f) § 61.302(g) § 61.302(j) § 61.302(k)	Equip each loading rack with vapor collection system to collect all displaced benzene vapors and prevent it from passing from one loading rack through another to the atmosphere. § 61.302(a)(1)-(2)	§ 61.302(k) § 61.303(a) § 61.303(a)(1) § 61.304(a)(1) § 61.304(a)(2) § 61.304(a)(4) § 61.304(a)(4)(i) § 61.304(a)(4)(ii) § 61.304(a)(4)(iii) § 61.304(a)(4)(iv) § 61.304(a)(5) § 61.304(a)(6) § 61.304(a)(7) § 61.304(d)(1) § 61.304(d)(2) § 61.304(d)(3) § 61.304(e)	§ 61.304(a)(4)(i) § 61.304(d)(3) § 61.305(a) [G]§ 61.305(a)(1) § 61.305(b) § 61.305(b)(1)	§ 61.305(a) § 61.305(a)(5) § 61.305(b) § 61.305(b)(1) § 61.305(f) § 61.305(f)(1)
GRPLDBGDK	EU	61BB-2	BENZENE	40 CFR Part 61, Subpart BB	§ 61.300(b)	Any affected facility as per § 61.300(a), loading only liquid containing < 70 weight-percent benzene is exempt from this subpart, except for the recordkeeping and reporting in § 61.305(i).	None	[G]§ 61.305(i)	[G]§ 61.305(i)
GRPLDBGDK	EU	63Y-3	EXEMPT	40 CFR Part 63, Subpart Y	§ 63.560(a)(2) § 153.282 § 63.560(a)(4)	Existing sources with emissions less than 10 and 25 tons must meet the submerged fill standards of 46 CFR 153.282. This submerged fill requirement does not	§ 63.565(l)	§ 63.567(j)(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						apply to petroleum refineries.			
GRPLIQFURN	EP	R1111-5	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRPLIQFURN	EU	R7ICI-4B	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(g) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(b) § 117.8100(b)(1) [G]§ 117.8100(b)(1)(A) § 117.8100(b)(1)(B) § 117.8100(b)(2) § 117.8100(b)(3) § 117.8100(b)(3)(A) § 117.8100(b)(3)(B) § 117.8100(b)(4) § 117.8100(b)(4)(A) § 117.8100(b)(4)(A)(i) § 117.8100(b)(4)(A)(i)(I) § 117.8100(b)(4)(A)(i)(II) [G]§ 117.8100(b)(4)(A)(ii) [G]§ 117.8100(b)(4)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(b)(4)(C) § 117.8100(b)(4)(C)(i) § 117.8100(b)(4)(C)(ii) § 117.8100(b)(4)(C)(iii) § 117.8100(b)(4)(C)(iii)(I) § 117.8100(b)(4)(C)(iii)(II) § 117.8100(b)(4)(C)(iii)(II)(-a-) § 117.8100(b)(5) § 117.8100(b)(6)		
GRPLIQFURN	EU	R7ICI-4B	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(7) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRPLOADBD	EU	R5211-1	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPLOADBD	EU	R5211-2	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(i) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure greater than or equal to 0.5 psia must be controlled by one of the specified methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
GRPLOADBD	EU	R5211-3	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C) § 60.18	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure greater than or equal to 0.5 psia must be controlled by one of the specified methods.	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) [G]§ 115.215(3) § 115.215(4) § 115.215(9) § 115.216(1) § 115.216(1)(B)	§ 115.216 § 115.216(1) § 115.216(1)(B) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
GRPLOADBD	EU	63G-1A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.11 § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) [G]§ 63.126(b)(2) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(2) § 63.127(e) [G]§ 63.128(b) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v)	§ 63.129(a)(1) [G]§ 63.129(a)(5) § 63.130(a)(1) § 63.130(a)(2)(i) § 63.130(c) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a)	§ 63.129(a)(2) § 63.129(a)(3) [G]§ 63.129(a)(5) § 63.130(d)(1) § 63.130(d)(2) § 63.130(d)(5) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
								[G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii)	§ 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii)
GRPLOADBD	EU	63G-1B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.11 § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) [G]§ 63.126(b)(2) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.126(d)(3) § 63.127(a) § 63.127(a)(2) § 63.127(e) [G]§ 63.128(b) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v)	§ 63.129(a)(1) [G]§ 63.129(a)(5) § 63.130(a)(1) § 63.130(a)(2)(i) § 63.130(c) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii)	§ 63.129(a)(2) § 63.129(a)(3) [G]§ 63.129(a)(5) § 63.130(d)(1) § 63.130(d)(2) § 63.130(d)(5) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPLOADBD	EU	63G-1C	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.126(a) § 63.126(a)(1) § 63.126(a)(2) § 63.126(a)(3) [G]§ 63.126(b)(4) [G]§ 63.126(d)(3) § 63.126(f) § 63.126(g) § 63.126(h)	For Group 1 transfer racks shall operate a vapor collection system and control device for organic HAPs.	[G]§ 63.126(d)(3) [G]§ 63.128(f) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v)	§ 63.129(a)(1) § 63.130(e) § 63.130(f) § 63.130(f)(1) § 63.130(f)(2) § 63.130(f)(3) § 63.130(f)(3)(ii) [G]§ 63.152(a) [G]§ 63.152(f) § 63.152(g)(1) § 63.152(g)(1)(i) [G]§ 63.152(g)(1)(ii) § 63.152(g)(1)(iii) § 63.152(g)(1)(iv) [G]§ 63.152(g)(1)(v) [G]§ 63.152(g)(1)(vi) § 63.152(g)(2) § 63.152(g)(2)(i) § 63.152(g)(2)(ii) § 63.152(g)(2)(iii)	§ 63.129(a)(2) § 63.129(a)(3) § 63.129(a)(8) § 63.130(d)(1) § 63.130(d)(2) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) § 63.152(g)(1) § 63.152(g)(2)(i) § 63.152(g)(2)(ii)
GRPLOADOP1	EU	R5211-1	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
GRPLOADPBD	EU	R5211-1	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						from the requirements of this division, except as specified.			
GRPMEOTK	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)
GRPMEOTK	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPMTTK1	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
GRPMTTK1	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
GRPMTTK2	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						of subsection (a)(1) of this paragraph for crude oil and condensate.			
GRPMTTK2	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
GRPMTVENT1	EP	R5720-4	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.722(d) § 115.722(d)(1) § 115.722(d)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(n)	§ 115.726(d)(1) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n)
GRPMTVENT1	EP	R5121-2	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(B) § 60.18	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).			
GRPOL1FURV	EP	R5720-6	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(a)(2)(A) § 115.725(a)(2)(B) § 115.725(a)(2)(C) § 115.725(a)(2)(D) § 115.725(a)(3) [G]§ 115.725(a)(4) [G]§ 115.725(l) [G]§ 115.726(a)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(a) § 115.725(a)(2)(A) § 115.725(a)(2)(B) § 115.725(a)(2)(C) § 115.725(a)(2)(D) § 115.725(a)(3) § 115.725(a)(3)(B) [G]§ 115.725(a)(4) § 115.725(a)(5) [G]§ 115.725(l) § 115.725(n)	§ 115.726(b)(1) § 115.726(b)(2) § 115.726(b)(3) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	[G]§ 115.725(a)(4) § 115.725(a)(5) § 115.725(n) [G]§ 115.726(a)(2)
GRPOL1FURV	EP	R5121-2	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(2) § 115.121(a)(2) § 115.122(a)(2)(B)	Vent gas affected by §115.121(a)(2) must be controlled properly with a control efficiency > 98% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
GRPOL1FURV	EP	R5121-28	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPOL1FURV	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
GRPOL2FURV	EP	R5121-2	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(2) § 115.121(a)(2) § 115.122(a)(2)(B)	Vent gas affected by §115.121(a)(2) must be controlled properly with a control efficiency > 98% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
GRPOL2FURV	EP	R5121-28	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
GRPOL2FURV	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPOLFUR2	EU	R7301	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
GRPOLFUR2	EU	R7301	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(b)(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(7) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.340(b)(3) § 117.340(e) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)		§ 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRPOLFUR2	EU	R7301	NH_3	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(A)	For process heaters that inject urea or ammonia into the exhaust stream for NO_x control, ammonia emissions must not exceed 10 ppmv at 3.0% O_2, dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3) § 117.340(d) § 117.8000(b) § 117.8000(c) § 117.8000(c)(3) § 117.8000(c)(4) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8130 § 117.8130(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRPOLFUR2	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPOLFUR2V	EP	R1111	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRPOLFUR2V	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
GRPOLFURN	EP	R1111-3	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRPOLFURN	EU	R7ICI-1	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(g) § 117.340(l)(2) § 117.340(o)(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(p)(1) § 117.8100(b) § 117.8100(b)(1) [G]§ 117.8100(b)(1)(A) § 117.8100(b)(1)(B) § 117.8100(b)(2) § 117.8100(b)(3) § 117.8100(b)(3)(A) § 117.8100(b)(3)(B) § 117.8100(b)(4) § 117.8100(b)(4)(A) § 117.8100(b)(4)(A)(i) § 117.8100(b)(4)(A)(i)(I) § 117.8100(b)(4)(A)(i)(II) [G]§ 117.8100(b)(4)(A)(ii) [G]§ 117.8100(b)(4)(B) § 117.8100(b)(4)(C) § 117.8100(b)(4)(C)(i) § 117.8100(b)(4)(C)(ii) § 117.8100(b)(4)(C)(iii) § 117.8100(b)(4)(C)(iii)(I) § 117.8100(b)(4)(C)(iii)(II) § 117.8100(b)(4)(C)(iii)(II)(-a-) § 117.8100(b)(5) § 117.8100(b)(6)		[G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
GRPOLFURN	EU	R7ICI-1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(7) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)		[G]§ 117.8010(8)
GRPOLFURN	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
GRPOLSEALV	EP	R5121-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
GRPOLSUHT	EP	R1111-4	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRPOLSUHT	EU	R7ICI-2B	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.335(f) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
GRPOLSUHT	EU	R7ICI-2B	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(7) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)		[G]§ 117.8010(7) [G]§ 117.8010(8)
GRPOLSUHT	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
GRPOLSUHTV	EP	R5720-1	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(a)(2)(A) § 115.725(a)(2)(B) § 115.725(a)(2)(C) § 115.725(a)(2)(D) § 115.725(a)(3) [G]§ 115.725(a)(4) [G]§ 115.725(l) [G]§ 115.726(a)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(a) § 115.725(a)(2)(A) § 115.725(a)(2)(B) § 115.725(a)(2)(C) § 115.725(a)(2)(D) § 115.725(a)(3) § 115.725(a)(3)(B) [G]§ 115.725(a)(4) § 115.725(a)(5) [G]§ 115.725(l) § 115.725(n)	§ 115.726(b)(1) § 115.726(b)(2) § 115.726(b)(3) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	[G]§ 115.725(a)(4) § 115.725(a)(5) § 115.725(n) [G]§ 115.726(a)(2)
GRPOLSUHTV	EP	R5121-29	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).			
GRPOLSUHTV	EP	R5121-3	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(2) § 115.121(a)(2) § 115.122(a)(2)(B)	Vent gas affected by §115.121(a)(2) must be controlled properly with a control efficiency > 98% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
GRPOLTKHVY	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
GRPOLTKHVY	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
GRPOLTKIFR	EU	R5112-3	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
GRPOLTKIFR	EU	60K-3A	VOC	40 CFR Part 60, Subpart K	§ 60.112(a)(1)	Storage vessels holding petroleum liquids with a true vapor pressure of 78 mm Hg (1.5 psia) or greater but not greater than 570 mm Hg (11.1 psia) shall have a floating roof, a vapor recovery system, or their equivalents.	§ 60.113(a) § 60.113(b) ** See Periodic Monitoring Summary	§ 60.113(a)	None
GRPOLTKIFR	EU	60K-3B	VOC	40 CFR Part 60, Subpart K	§ 60.110(c) § 60.110(c)(2)	Facilities under §60.110(a) of this section with a capacity, construction or modification date as given in §60.110(c)(1) or §60.110(c)(2) are subject to the requirements of this section.	§ 60.113(a) § 60.113(b)	§ 60.113(a)	None
GRPOLTKIFR	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPOP1TK1	EU	R5140-8	VOC	30 TAC Chapter 115, Industrial Wastewater	[G]§ 115.142(2) § 115.142 [G]§ 115.148	The wastewater component shall be equipped with a floating roof or internal floating cover which meets the requirements listed in §115.142(2)(A)-(F).	§ 115.144(2) § 115.144(2)(B) § 115.144(2)(C) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
GRPOP1TK1	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)
GRPOP1TK1	EU	60K-1A	VOC	40 CFR Part 60, Subpart K	§ 60.112(a)(1)	Storage vessels holding petroleum liquids with a true vapor pressure of 78 mm Hg (1.5 psia) or greater but not greater than 570 mm Hg (11.1 psia) shall have a	§ 60.113(a) § 60.113(b) ** See Periodic Monitoring Summary	§ 60.113(a)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						floating roof, a vapor recovery system, or their equivalents.			
GRPOP1TK1	EU	60K-1B	VOC	40 CFR Part 60, Subpart K	§ 60.110(c) § 60.110(c)(2)	Facilities under §60.110(a) of this section with a capacity, construction or modification date as given in §60.110(c)(1) or §60.110(c)(2) are subject to the requirements of this section.	§ 60.113(a) § 60.113(b)	§ 60.113(a)	None
GRPOP1TK1	EU	61FF-17	BENZENE	40 CFR Part 61, Subpart FF	§ 61.351(a) [G]§ 60.112b(a)(2) § 61.351(a)(2) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) [G]§ 60.113b(b)(6)	§ 60.115b [G]§ 60.115b(b)(3) § 61.356(k)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4) § 61.357(e) § 61.357(f)
GRPOP1TK1	EU	63G-27	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(2)(iii) § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.133(e)(2) § 63.133(f) § 63.133(h) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a)	An external floating roof that meets the requirements specified in §63.119(c), §63.120(b)(5), and §63.120(b)(6) of this subpart; or	§ 63.133(e)(1) § 63.133(f) § 63.133(g) § 63.133(g)(2) § 63.133(g)(3) § 63.143(a) § 63.143(g)	§ 63.133(e)(2) § 63.133(h) § 63.147(b) § 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(6) § 63.147(b)(7) [G]§ 63.152(a)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(c) § 63.146(g) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
GRPOP1TK1	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
GRPOP1TK5	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPOP1TK5	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
GRPOP1TK6	EU	R5140-3	VOC	30 TAC Chapter 115, Industrial Wastewater	[G]§ 115.142(2) § 115.142 [G]§ 115.148	The wastewater component shall be equipped with a floating roof or internal floating cover which meets the requirements listed in §115.142(2)(A)-(F).	§ 115.144(2) § 115.144(2)(B) § 115.144(2)(C) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4)	§ 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148		
GRPOP1TK6	EU	60Kb-3A	VOC	40 CFR Part 60, Subpart Kb	§ 60.110b(a)	Except for §60.110b(b), this subpart applies to vessels with a capacity greater than or equal to 75 cubic meters (19,800 gal) used to store VOLs for which construction/reconstruction/modification began after 7/23/84.	§ 60.116b(a) § 60.116b(b) § 60.116b(d) § 60.116b(f)(2)	§ 60.116b(a) § 60.116b(b)	§ 60.116b(d)
GRPOP1TK6	EU	60Kb-3B	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3) § 60.116b(f)(1)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
GRPOP1TK6	EU	61FF-4	BENZENE	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPOP1TK6	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2485(a) § 63.133(a)(1) § 63.2485(b)	You must meet each requirement in Table 7 to this subpart that applies: §63.133(a)(1) - The owner or operator shall operate and maintain a fixed roof	None	None	§ 63.146(b)(2) § 63.146(b)(5) § 63.2450(q)
GRPOP1TK6	EU	63G-4	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(2)(ii) § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.133(f) § 63.133(h) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a)	A fixed roof and an internal floating roof that meets the requirements specified in Sec. 63.119(b) of this subpart;	§ 63.133(f) § 63.133(g) § 63.133(g)(2) § 63.133(g)(3) § 63.143(a) § 63.143(g)	§ 63.133(h) § 63.147(b) § 63.147(b)(1) § 63.147(b)(6) § 63.147(b)(7) [G]§ 63.152(a)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(c) § 63.146(g) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
GRPOP1TK6	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
GRPOP2TK1	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A)	No person shall place, store, or hold VOC in any storage tank unless	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4)	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(7)	
GRPOP2TK1	EU	60K-1B	VOC	40 CFR Part 60, Subpart K	§ 60.110(c) § 60.110(c)(2)	Facilities under §60.110(a) of this section with a capacity, construction or modification date as given in §60.110(c)(1) or §60.110(c)(2) are subject to the requirements of this section.	§ 60.113(a) § 60.113(b)	§ 60.113(a)	None
GRPOP2TK1	EU	60K-2A	VOC	40 CFR Part 60, Subpart K	§ 60.112(a)(1)	Storage vessels holding petroleum liquids with a true vapor pressure of 78 mm Hg (1.5 psia) or greater but not greater than 570 mm Hg (11.1 psia) shall have a floating roof, a vapor recovery system, or their equivalents.	§ 60.113(a) § 60.113(b) ** See Periodic Monitoring Summary	§ 60.113(a)	None
GRPOP2TK1	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall	The permit holder shall comply with the	The permit holder shall comply with the applicable	The permit holder shall comply with the	The permit holder shall comply with the

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	applicable requirements of 40 CFR Part 63, Subpart YY	monitoring and testing requirements of 40 CFR Part 63, Subpart YY	applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	applicable reporting requirements of 40 CFR Part 63, Subpart YY
GRPOP2TK2	EU	R5112-5	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)
GRPOP2TK2	EU	63G-2	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.120(a)(4) § 63.120(a)(7)				§ 63.152(c)(4)(ii)
GRPOP2TK5	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPOP2TK5	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
GRPOP2TK6	EU	R5140-3	VOC	30 TAC Chapter 115, Industrial Wastewater	[G]§ 115.142(2) § 115.142 [G]§ 115.148	The wastewater component shall be equipped with a floating roof or internal floating cover which meets the requirements listed in §115.142(2)(A)-(F).	§ 115.144(2) § 115.144(2)(B) § 115.144(2)(C) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
GRPOP2TK6	EU	60Kb-8	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(e)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	§60.112b(a)(1)(i)-(ix).	§ 60.116b(e)(1) [G]§ 60.116b(e)(3) § 60.116b(f)(1)		
GRPOP2TK6	EU	61FF-5	BENZENE	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)
GRPOP2TK6	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2485(a) § 63.133(a)(1) § 63.2485(b)	You must meet each requirement in Table 7 to this subpart that applies: §63.133(a)(1) - The owner or operator shall operate and maintain a fixed roof	None	None	§ 63.146(b)(2) § 63.146(b)(5) § 63.2450(q)
GRPOP2TK6	EU	63G-11	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(1)	A fixed roof shall be operated and maintained except that if the wastewater tank is used for specified purpose, then owner or operator shall comply with requirements of § 63.133(a)(2).	None	None	§ 63.146(b)(2) § 63.146(b)(5) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(c)(1) § 63.152(c)(4)(ii)
GRPOP2TK6	EU	63G-7	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(2)(ii) § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B)	A fixed roof and an internal floating roof that meets the requirements	§ 63.133(f) § 63.133(g) § 63.133(g)(2)	§ 63.133(h) § 63.147(b) § 63.147(b)(1)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.132(f) § 63.133(f) § 63.133(h) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a)	specified in Sec. 63.119(b) of this subpart;	§ 63.133(g)(3) § 63.143(a) § 63.143(g)	§ 63.147(b)(6) § 63.147(b)(7) [G]§ 63.152(a)	§ 63.146(c) § 63.146(g) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
GRPOP2TK6	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
GRPOP2TK7	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
GRPSMAPMV	EP	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPSMAPMV	EP	R5121-4	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(B) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream specified in § 115.121(a)(1) of this title with a concentration of VOC < 612 ppmv is exempt from § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
GRPSMLTANK	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPSMLTANK	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117	§ 115.118(a)(5) § 115.118(a)(7)	None
MBTCT2402	EU	R5760-4	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Cooling Towers	§ 115.767(1)	Cooling tower heat exchange systems in which each individual heat exchanger with > 100 ppmw HRVOC in the process side fluid is	None	§ 115.766(b) § 115.766(b)(1) § 115.766(c)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						operated with the minimum pressure on the cooling water side at least five psig greater than the maximum pressure on the process side, as demonstrated by continuous pressure monitoring and recording at all heat exchangers with > 100 ppmw HRVOC in the process side fluid, is exempt from the requirements of this division, with the exception of §115.766(b)-(c).			
MBTDM4009	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MBTDM4009	EU	63G-10	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
MBTSP4010	EP	R5121-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						the requirements of § 115.121(a)(1).			
MBTSP4010	EP	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.113(f) [G]§ 63.115(f)	The owner or operator of a Group 2 process vent with a flow rate < than 0.005 standard m3/min shall maintain a flow rate less than 0.005 standard m3/min and comply with the sections as specified.	[G]§ 63.115(a) [G]§ 63.115(b) § 63.115(e) § 63.115(e)(1) [G]§ 63.115(f)	[G]§ 63.118(d) [G]§ 63.152(a)	§ 63.115(e)(2) § 63.117(c) [G]§ 63.118(g) [G]§ 63.118(i) [G]§ 63.118(k) [G]§ 63.151(b) § 63.151(e) [G]§ 63.151(e)(1) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(4)(i) § 63.152(c)(4)(ii) § 63.152(c)(4)(iii) [G]§ 63.152(c)(6)
MBTTK3112	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						of subsection (a)(1) of this paragraph for crude oil and condensate.			
MBTTK3112	EU	63G-2	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(c) § 63.119(a)(1) § 63.119(c)(1) § 63.119(c)(1)(i) § 63.119(c)(1)(ii) § 63.119(c)(1)(iii) § 63.119(c)(2)(i) § 63.119(c)(2)(ii) § 63.119(c)(2)(iii) § 63.119(c)(2)(iv) § 63.119(c)(2)(ix) § 63.119(c)(2)(v) § 63.119(c)(2)(vi) § 63.119(c)(2)(vii) § 63.119(c)(2)(viii) § 63.119(c)(2)(x) § 63.119(c)(2)(xi) § 63.119(c)(2)(xii) [G]§ 63.119(c)(3) § 63.119(c)(4) § 63.120(b)(10)(i) § 63.120(b)(5)(i) § 63.120(b)(5)(ii) § 63.120(b)(6)(i) § 63.120(b)(6)(ii) [G]§ 63.120(b)(7) § 63.120(b)(8)	Tanks using an external floating roof, (defined in § 63.111), to comply with §63.119(a)(1) shall comply with §63.119(c)(1)-(4).	§ 63.120(b)(1)(i) § 63.120(b)(1)(iii) § 63.120(b)(1)(iv) § 63.120(b)(10) § 63.120(b)(2)(i) § 63.120(b)(2)(ii) § 63.120(b)(2)(iii) § 63.120(b)(3) § 63.120(b)(4)	[G]§ 63.120(b)(7) § 63.120(b)(8) § 63.123(a) § 63.123(d) § 63.123(g) [G]§ 63.152(a)	§ 63.120(b)(10)(ii) § 63.120(b)(10)(iii) § 63.120(b)(9) [G]§ 63.122(e)(1) § 63.122(e)(2) § 63.122(e)(3) § 63.122(e)(3)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
MBTTK3113	EU	R5112-4	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
MBTTK3113	EU	63G-4	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
MBTTK3114	EU	R5112-6	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
MBTTK3114	EU	63G-6	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
MBTTK3115	EU	R5112-5	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						oil and condensate.			
MBTTK3115	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2470(a)-Table4.1.b.i § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(B) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(viii) § 63.1063(a)(2)(viii)(A) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2) § 63.2470(a)	For each Group 1 storage tank for which the maximum true vapor pressure of total HAP at the storage temperature is < 76.6 kilopascals, you must comply with the requirements of Subpart WW of this part, except as specified in §63.2470.	§ 63.1063(c)(2) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d)	§ 63.1063(c)(2)(iv)(B) [G]§ 63.1066(a) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.2450(q)
MBTTK3115	EU	63G-2	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(c) § 63.119(a)(1) § 63.119(c)(1) § 63.119(c)(1)(i) § 63.119(c)(1)(ii) § 63.119(c)(1)(iii) § 63.119(c)(2)(i) § 63.119(c)(2)(ii) § 63.119(c)(2)(iii) § 63.119(c)(2)(iv) § 63.119(c)(2)(ix) § 63.119(c)(2)(v) § 63.119(c)(2)(vi) § 63.119(c)(2)(vii) § 63.119(c)(2)(viii)	Tanks using an external floating roof, (defined in § 63.111), to comply with §63.119(a)(1) shall comply with §63.119(c)(1)-(4).	§ 63.120(b)(1)(i) § 63.120(b)(1)(iii) § 63.120(b)(1)(iv) § 63.120(b)(10) § 63.120(b)(2)(i) § 63.120(b)(2)(ii) § 63.120(b)(2)(iii) § 63.120(b)(3) § 63.120(b)(4)	[G]§ 63.120(b)(7) § 63.120(b)(8) § 63.123(a) § 63.123(d) § 63.123(g) [G]§ 63.152(a)	§ 63.120(b)(10)(ii) § 63.120(b)(10)(iii) § 63.120(b)(9) [G]§ 63.122(e)(1) § 63.122(e)(2) § 63.122(e)(3) § 63.122(e)(3)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.119(c)(2)(x) § 63.119(c)(2)(xi) § 63.119(c)(2)(xii) [G]§ 63.119(c)(3) § 63.119(c)(4) § 63.120(b)(10)(i) § 63.120(b)(5)(i) § 63.120(b)(5)(ii) § 63.120(b)(6)(i) § 63.120(b)(6)(ii) [G]§ 63.120(b)(7) § 63.120(b)(8)				§ 63.152(c)(2) § 63.152(c)(4)(ii)
MBTTK4002	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
MBTTK4002	EU	63G-6	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
MBTTK4003	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
MBTTK4003	EU	63G-7	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a).	None	§ 63.123(a)	§ 63.152(c)(4)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						Not required to comply with §63.119 to §63.123.			
MBTTK4004	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
MBTTK4004	EU	63G-8	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
MBTTK4011	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MBTWWCPI	EU	R5131-1	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None
MEOHANLZ	EP	R5121-1B	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).			
MEOHFLARE	EU	R1111-2	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period, except for upset emissions as provided in §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
MEOHFLARE	EU	65CAR-FL	HAPS	40 CFR Part 65, Subpart G	§ 65.142(b)(1) § 65.147(a)(1) § 65.147(a)(2) § 65.147(a)(3) § 65.147(a)(4)(ii) § 65.147(a)(5) [G]§ 65.147(a)(6) § 65.147(a)(7)	Owners or operators subject to §65.63(a)(1) or 40 CFR 60.562-1(a)(1)(i)(C) who route process vent emissions to a flare shall meet the applicable requirements in §65.143 for closed vent systems; §65.147 for flares; and §65.157(a), (b), and (c) for provisions regarding flare compliance determinations; and the monitoring, recordkeeping, and reporting requirements referenced therein.	[G]§ 65.147(b) § 65.147(c) § 65.164(b)(1)	None	None
MEOHT7001	EU	R7301	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) § 117.340(b)(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		§ 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
MEOHT7001	EU	R7301	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(7) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)		
MEOHT7001	EU	R7301	NH_3	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(A)	For process heaters that inject urea or ammonia into the exhaust stream for NO_x control, ammonia emissions must not exceed 10 ppmv at 3.0% O_2, dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3) § 117.340(d) § 117.8000(b) § 117.8000(c) § 117.8000(c)(3) § 117.8000(c)(4) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8130 § 117.8130(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
MEOHT7001	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
MEOHT7001	EU	65RRRCAR	VOC	40 CFR Part 65, Subpart D	§ 60.700(a) § 60.700(b) § 60.700(d)(1) § 60.700(d)(2)	Owners or operators of process vents that are subject to NSPS subparts RRR may choose to comply with the provisions of 40 CFR part 65, subpart D, to satisfy the	None	None	§ 60.700(d)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						requirements of §§60.702 through 60.705 and 60.708 as applicable.			
MEOHT7001V	EP	R1111	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
MEOHT7001V	EP	R5121-2	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
MEOPM3314	EU	R7471	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
MEOPM3314	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(b) § 63.6640(f)(1) [G]§ 63.6640(f)(2) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii § 63.6640(b)	§ 63.6625(i) § 63.6655(a) § 63.6655(a)(1) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(b) § 63.6640(e) § 63.6650(f)
MEORXR7001	EU	65RRR CAR	VOC	40 CFR Part 65, Subpart D	§ 60.700(a) § 60.700(b) § 60.700(d)(1) § 60.700(d)(2)	Owners or operators of process vents that are subject to NSPS subparts RRR may choose to comply with the provisions of 40 CFR part 65, subpart D, to satisfy the requirements of §§60.702 through 60.705 and 60.708 as applicable.	None	None	§ 60.700(d)(4)
MEOSP3101	EU	R5131-1	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
MEOSP7045	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MEOTW7001	EU	65NNN CAR	VOC	40 CFR Part 65, Subpart D	§ 60.660(a) § 60.660(b) § 60.660(d)(1) § 60.660(d)(2)	Owners or operators of process vents that are subject to NSPS subparts NNN may choose to comply with the provisions of 40 CFR part 65, subpart D, to satisfy the requirements of §§60.662 through 60.665 and 60.668.	None	None	§ 60.660(d)(4)
MEOTW7002	EU	65NNN CAR	VOC	40 CFR Part 65, Subpart D	§ 60.660(a) § 60.660(b) § 60.660(d)(1) § 60.660(d)(2)	Owners or operators of process vents that are subject to NSPS subparts NNN may choose to comply with the provisions of 40 CFR part 65, subpart D, to satisfy the requirements of §§60.662 through 60.665 and 60.668.	None	None	§ 60.660(d)(4)
MIPCT2401	EU	R5760-5	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Cooling Towers	§ 115.767(1)	Cooling tower heat exchange systems in which each individual heat exchanger with > 100 ppmw HRVOC in the process side fluid is operated with the minimum pressure on the cooling water side at least five psig greater	None	§ 115.766(b) § 115.766(b)(1) § 115.766(c)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						than the maximum pressure on the process side, as demonstrated by continuous pressure monitoring and recording at all heat exchangers with > 100 ppmw HRVOC in the process side fluid, is exempt from the requirements of this division, with the exception of §115.766(b)-(c).			
MIPFL2501	EU	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period, except for upset emissions as provided in §101.11(a).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
MIPFL2501	EP	R5720-1	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(d) § 115.722(d)(1) § 115.722(d)(2) [G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) [G]§ 115.725(l) § 115.725(m)(2)(A) § 115.725(m)(2)(B) [G]§ 115.726(a)(2)	All flares must continuously meet the requirements of 40 CFR § 60.18(c)(2)-(6) and (d) as amended through October 17, 2000 (65 FR 61744) when vent gas containing HRVOC is being routed to the flare.	[G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) § 115.725(d)(3) § 115.725(d)(4) § 115.725(d)(5) § 115.725(d)(6) § 115.725(d)(7) § 115.725(k)(1) [G]§ 115.725(l)	§ 115.726(a)(1) § 115.726(a)(1)(A) § 115.726(d)(1) § 115.726(d)(10) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n) § 115.726(a)(1)(B) [G]§ 115.726(a)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 115.725(m)(1) § 115.725(m)(2)(A) § 115.725(m)(2)(B) § 115.725(n)		
MIPFL2501	CD	63A-1A	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(i)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
MIPFL2501	CD	63A-1B	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(ii)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
MIPFL2501	CD	63A-1C	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(iii)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
MIPFL2501V	EP	R5720-1	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.722(d)	HRVOC emissions at each site located in Harris County that is	§ 115.725(n)	§ 115.726(d)(1) § 115.726(d)(2) § 115.726(d)(3)	§ 115.725(n)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.722(d)(1) § 115.722(d)(2)	subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.		§ 115.726(d)(4) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	
MIPFL2501V	EP	R5121-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(B) § 60.18	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None
MIPFL2501V	EP	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2455(a)-Table 1.1.a.ii § 63.11(b) § 63.2450(b) § 63.2455(a) § 63.2455(b) § 63.2455(b)(1) § 63.982(b) § 63.983(a)(1) § 63.983(a)(2) § 63.983(d)(1) § 63.983(d)(1)(i) [G]§ 63.983(d)(2) § 63.983(d)(3) § 63.987(a) § 63.997(b)(2) § 63.997(b)(3) § 63.997(c)(3)	For each Group 1continuous process vent, the owner or operator must reduce emissions of total organic HAP by venting emissions through a closed vent system to a flare.	[G]§ 63.115(d)(2)(v) § 63.115(d)(3)(iii) § 63.983(b) [G]§ 63.983(b)(1) [G]§ 63.983(b)(2) [G]§ 63.983(b)(3) [G]§ 63.983(c)(1) § 63.983(c)(2) § 63.983(c)(3) § 63.983(d)(1) § 63.983(d)(1)(ii) § 63.987(c) § 63.997(b) § 63.997(c)(2) § 63.997(c)(3) § 63.997(c)(3)(i) § 63.997(c)(3)(ii)	§ 63.2450(f)(2) § 63.2450(f)(2)(i) § 63.2450(f)(2)(ii) § 63.983(b) [G]§ 63.983(d)(2) § 63.987(c) § 63.998(a)(1)(ii) § 63.998(a)(1)(iii)(A) § 63.998(a)(1)(iii)(B) [G]§ 63.998(b)(1) [G]§ 63.998(b)(2) [G]§ 63.998(b)(3) [G]§ 63.998(b)(5) [G]§ 63.998(d)(1) § 63.998(d)(3)(i) § 63.998(d)(3)(ii) § 63.998(d)(5)	§ 63.2450(f)(2)(ii) § 63.2450(q) § 63.997(b)(2) § 63.997(c)(3) § 63.998(a)(1)(iii)(A) [G]§ 63.998(b)(3) [G]§ 63.999(a)(1) § 63.999(b)(5) § 63.999(c)(1) § 63.999(c)(2)(i) § 63.999(c)(3) § 63.999(c)(6) [G]§ 63.999(c)(6)(i) § 63.999(c)(6)(iv) [G]§ 63.999(d)(1) [G]§ 63.999(d)(2)
MIPTK2615	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of	§ 115.112(e)(1) § 115.112(e)(2)	No person shall place, store, or hold VOC in	§ 115.114(a)(1) § 115.114(a)(1)(A)	§ 115.118(a)(3) § 115.118(a)(5)	§ 115.114(a)(1)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				VOCs	§ 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117	§ 115.118(a)(6)(C) § 115.118(a)(7)	
MIPTK2615	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2470(a)-Table4.1.b.i § 63.1062(a) § 63.1062(a)(1) § 63.1063(a)(1)(i) § 63.1063(a)(1)(i)(B) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(iv) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(e)(1) § 63.1063(e)(2) § 63.2470(a)	For each Group 1 storage tank for which the maximum true vapor pressure of total HAP at the storage temperature is < 76.6 kilopascals, you must comply with the requirements of Subpart WW of this part, except as specified in §63.2470.	§ 63.1063(c)(1) [G]§ 63.1063(c)(1)(i) [G]§ 63.1063(d)(1) § 63.1063(d)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(c) § 63.1065(d)	[G]§ 63.1066(a) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.2450(q)
MIPTK3105	EU	R5112-	VOC	30 TAC Chapter	§ 115.112(e)(1)	No person shall place,	§ 115.114(a)(1)	§ 115.118(a)(3)	§ 115.114(a)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		3		115, Storage of VOCs	§ 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.118(a)(3)
MIPTK3105	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2470(a)-Table4.1.b.i § 63.1062(a) § 63.1062(a)(1) § 63.1063(a)(1)(i) § 63.1063(a)(1)(i)(B) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(iv) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(viii) § 63.1063(a)(2)(viii)(A) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(e)(1) § 63.1063(e)(2) § 63.2470(a)	For each Group 1 storage tank for which the maximum true vapor pressure of total HAP at the storage temperature is < 76.6 kilopascals, you must comply with the requirements of Subpart WW of this part, except as specified in §63.2470.	§ 63.1063(c)(1) [G]§ 63.1063(c)(1)(i) [G]§ 63.1063(d)(1) § 63.1063(d)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(c) § 63.1065(d)	[G]§ 63.1066(a) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.2450(q)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
MIPTK3106	EU	R5112-4	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)
MIPTK3107	EU	R5112-5	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)
MIPTK3108	EU	R5112-6	VOC	30 TAC Chapter 115, Storage of	§ 115.112(e)(1) § 115.112(e)(2)	No person shall place, store, or hold VOC in	§ 115.114(a)(1) § 115.114(a)(1)(A)	§ 115.118(a)(3) § 115.118(a)(5)	§ 115.114(a)(1)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				VOCs	§ 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117	§ 115.118(a)(6)(C) § 115.118(a)(7)	
MIPTK3109	EU	R5112-7	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)
MIPTK3110	EU	R5112-4	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
MIPTK3110	EU	61FF-1	BENZENE	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)
MIPTK3110	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2470(a)-Table4.1.b.i § 63.1062(a) § 63.1062(a)(1) § 63.1063(a)(1)(i) § 63.1063(a)(1)(i)(B) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(iv) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v)	For each Group 1 storage tank for which the maximum true vapor pressure of total HAP at the storage temperature is < 76.6 kilopascals, you must comply with the requirements of Subpart WW of this part, except as specified in §63.2470.	§ 63.1063(c)(1) [G]§ 63.1063(c)(1)(i) [G]§ 63.1063(d)(1) § 63.1063(d)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(c) § 63.1065(d)	[G]§ 63.1066(a) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.2450(q)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1063(a)(2)(vi) § 63.1063(a)(2)(viii) § 63.1063(a)(2)(viii)(A) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(e)(1) § 63.1063(e)(2) § 63.2470(a)				
MIPTK3123	EU	R5112-7	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)
MIPTK3123	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)				[G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
MIPTK3124	EU	R5112-7	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)
MIPTK3124	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.120(a)(4) § 63.120(a)(7)				§ 63.152(c)(4)(ii)
MPBDAPI	EU	R5131-1	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None
MPBDM3219	EP	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
MPBDM3219	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None
MPBFL2502	EU	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						more than five minutes in any two-hour period, except for upset emissions as provided in §101.11(a).			
MPBFL2502	EP	R5720-1	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(d) § 115.722(d)(1) § 115.722(d)(2) [G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) [G]§ 115.725(l) § 115.725(m)(2)(A) § 115.725(m)(2)(B) [G]§ 115.726(a)(2)	All flares must continuously meet the requirements of 40 CFR § 60.18(c)(2)-(6) and (d) as amended through October 17, 2000 (65 FR 61744) when vent gas containing HRVOC is being routed to the flare.	[G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) § 115.725(d)(3) § 115.725(d)(4) § 115.725(d)(5) § 115.725(d)(6) § 115.725(d)(7) § 115.725(k)(1) [G]§ 115.725(l) § 115.725(m)(1) § 115.725(m)(2)(A) § 115.725(m)(2)(B) § 115.725(n)	§ 115.726(a)(1) § 115.726(a)(1)(A) § 115.726(d)(1) § 115.726(d)(10) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n) § 115.726(a)(1)(B) [G]§ 115.726(a)(2)
MPBFL2502	CD	63A-1A	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(i)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
MPBFL2502	CD	63A-1B	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1)	Flares shall be designed and operated with no	§ 63.11(b)(4) § 63.11(b)(5)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(ii)	visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(7)(i)		
MPBFL2502	CD	63A-1C	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(iii)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
MPBFL2502V	EP	R5720-1	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.722(d) § 115.722(d)(1) § 115.722(d)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(n)	§ 115.726(d)(1) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n)
MPBFL2502V	EP	R5121-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(B) § 60.18	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						combustion devices).			
MPBFL2502V	EP	R5121-2	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
MPBFL2502V	EP	R5121-2	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(B) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream specified in § 115.121(a)(1) of this title with a concentration of VOC < 612 ppmv is exempt from § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
MPBFL2502V	EP	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2455(a)-Table 1.1.a.ii § 63.11(b) § 63.2450(b) § 63.2455(a) § 63.2455(b) § 63.2455(b)(1) § 63.982(b) § 63.983(a)(1) § 63.983(a)(2) § 63.983(d)(1) § 63.983(d)(1)(i) [G]§ 63.983(d)(2) § 63.983(d)(3) § 63.987(a) § 63.997(b)(2) § 63.997(b)(3) § 63.997(c)(3)	For each Group 1continuous process vent, the owner or operator must reduce emissions of total organic HAP by venting emissions through a closed vent system to a flare.	[G]§ 63.115(d)(2)(v) § 63.115(d)(3)(iii) § 63.983(b) [G]§ 63.983(b)(1) [G]§ 63.983(b)(2) [G]§ 63.983(b)(3) [G]§ 63.983(c)(1) § 63.983(c)(2) § 63.983(c)(3) § 63.983(d)(1) § 63.983(d)(1)(ii) § 63.987(c) § 63.997(b) § 63.997(c)(2) § 63.997(c)(3) § 63.997(c)(3)(i) § 63.997(c)(3)(ii)	§ 63.2450(f)(2) § 63.2450(f)(2)(i) § 63.2450(f)(2)(ii) § 63.983(b) [G]§ 63.983(d)(2) § 63.987(c) § 63.998(a)(1)(ii) § 63.998(a)(1)(iii)(A) § 63.998(a)(1)(iii)(B) [G]§ 63.998(b)(1) [G]§ 63.998(b)(2) [G]§ 63.998(b)(3) [G]§ 63.998(b)(5) [G]§ 63.998(d)(1) § 63.998(d)(3)(i) § 63.998(d)(3)(ii) § 63.998(d)(5)	§ 63.2450(f)(2)(ii) § 63.2450(q) § 63.997(b)(2) § 63.997(c)(3) § 63.998(a)(1)(iii)(A) [G]§ 63.998(b)(3) [G]§ 63.999(a)(1) § 63.999(b)(5) § 63.999(c)(1) § 63.999(c)(2)(i) § 63.999(c)(3) § 63.999(c)(6) [G]§ 63.999(c)(6)(i) § 63.999(c)(6)(iv) [G]§ 63.999(d)(1) [G]§ 63.999(d)(2)
MPBTK3205	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						vapor pressure less than 1.5 psia is exempt from the requirements of this division.			
MPBTK3207	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MPBTK3208	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MPBTK3209	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MPBTK3210	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
MPBTK3211	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
MPBTK3212	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MPBTK3213	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
MPBTK3214	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MPBTK3215	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				VOCs		storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.		§ 115.118(a)(6)(A) § 115.118(a)(7)	
MPBTK3216	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MPBTK3217	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MPBTK3218	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MPBTK3219	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MPBTK3221	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						1.5 psia is exempt from the requirements of this division.			
MPBTK3224	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MPBTK3226	EP	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
MPBTK3226	EP	R5121-3	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
MPBTK3233X	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MPBTRAILER	EU	R5112-16	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
MSMDM2801	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MSMDM2802	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MSMHT2801A	EU	R7300-1	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)		[G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
MSMHT2801A	EU	R7300-1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
MSMHT2801B	EU	R7300-1	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)		[G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
MSMHT2801B	EU	R7300-1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
MSMHT2801B	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
MSMLDMISC	EU	R5211-10	VOC	30 TAC Chapter 115, Loading and	§ 115.212(a)(1) § 115.212(a)(1)(B)	At operations other than gasoline terminals,	§ 115.212(a)(3)(B) § 115.214(a)(1)(A)	§ 115.216 § 115.216(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Unloading of VOC	§ 115.212(a)(2) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(i) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(D) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	gasoline bulk plants, and marine terminals, vapors of VOC with a true vapor pressure of 0.5 psia or greater, must be controlled by one of the following methods.	§ 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	
MSMTK2801	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MSMTK2802	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MSMTK2803	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
MSMTK2811	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OFXDM4310	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None
OFXDM4310	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OFXDM4311	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
OFXDM4311	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OFXDM4383	EU	R5112-8A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
OFXDM4383	EU	R5112-8B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
OFXDM4383	EU	61FF-1A	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 60.18 § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 60.18(f)(2) § 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
OFXDM4383	EU	61FF-1B	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 60.18 § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 60.18(f)(2) § 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(f) § 61.349(g)				
OFXHT4351	EU	R7ICI-3	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OFXHT4351	EU	R7ICI-3	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 117.8120(2)(A) § 117.8120(2)(B)		
OFXHT4351	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
OFXHT4360	EU	R7ICI-4	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OFXHT4360	EU	R7ICI-4	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)		§ 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OFXHT4360	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
OFXHT4360C	EU	R7ICI-5	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.8000(d)		
OFXHT4360C	EU	R7ICI-5	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OFXHT4360C	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
OFXHT4361	EU	R7ICI-6	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)		§ 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OFXHT4361	EU	R7ICI-6	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OFXHT4361	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OFXR4360AV	EP	R5720-4	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) [G]§ 115.725(a)(4) [G]§ 115.725(l) [G]§ 115.726(a)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(a) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) § 115.725(a)(3)(B) [G]§ 115.725(a)(4) § 115.725(a)(5) [G]§ 115.725(l) § 115.725(n)	§ 115.726(b)(1) § 115.726(b)(2) § 115.726(b)(3) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	[G]§ 115.725(a)(4) § 115.725(a)(5) § 115.725(n) [G]§ 115.726(a)(2)
OFXR4360AV	EP	R5121-16	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OFXR4360BV	EP	R5720-4	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) [G]§ 115.725(a)(4) [G]§ 115.725(l) [G]§ 115.726(a)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(a) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) § 115.725(a)(3)(B) [G]§ 115.725(a)(4) § 115.725(a)(5) [G]§ 115.725(l) § 115.725(n)	§ 115.726(b)(1) § 115.726(b)(2) § 115.726(b)(3) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	[G]§ 115.725(a)(4) § 115.725(a)(5) § 115.725(n) [G]§ 115.726(a)(2)
OFXR4360BV	EP	R5121-15	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) <	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).			
OFXR4360CV	EP	R5720-1	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) [G]§ 115.725(a)(4) [G]§ 115.725(l) [G]§ 115.726(a)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(a) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) § 115.725(a)(3)(B) [G]§ 115.725(a)(4) § 115.725(a)(5) [G]§ 115.725(l) § 115.725(n)	§ 115.726(b)(1) § 115.726(b)(2) § 115.726(b)(3) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	[G]§ 115.725(a)(4) § 115.725(a)(5) § 115.725(n) [G]§ 115.726(a)(2)
OFXR4360CV	EP	R5121-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OFXTW4371	EU	65NNNCAR	VOC	40 CFR Part 65, Subpart D	§ 60.660(a) § 60.660(b) § 60.660(d)(1) § 60.660(d)(2)	Owners or operators of process vents that are subject to NSPS subparts NNN may choose to comply with the provisions of 40 CFR part 65, subpart D, to satisfy the requirements of §§60.662 through 60.665 and 60.668.	None	None	§ 60.660(d)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OLH2FLARE	EU	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period, except for upset emissions as provided in §101.11(a).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
OP1BL803AV	EP	R5121-34	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(A)	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	None
OP1BL803AV	EP	R5121-4	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(2) § 115.121(a)(2) § 115.122(a)(2)(B)	Vent gas affected by §115.121(a)(2) must be controlled properly with a control efficiency > 98% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	None
OP1BL803BV	EP	R5121-31	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(A)	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	None
OP1BL803BV	EP	R5121-5	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(2) § 115.121(a)(2) § 115.122(a)(2)(B)	Vent gas affected by §115.121(a)(2) must be controlled properly with	[G]§ 115.125 § 115.126(1) § 115.126(1)(A)	§ 115.126 § 115.126(1) § 115.126(1)(A)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						a control efficiency > 98% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	§ 115.126(1)(A)(i) § 115.126(2)	§ 115.126(1)(A)(i) § 115.126(2)	
OP1CT3811	EU	R5760-2	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Cooling Towers	§ 115.761(c)(1) § 115.761(c)(3) § 115.766(i)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 1 of this subchapter must not exceed 1,200 pounds of HRVOCs per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.764(a)(3) [G]§ 115.764(a)(6) § 115.764(c) § 115.764(e)(1)	§ 115.766(a)(1) § 115.766(a)(2) § 115.766(a)(3) § 115.766(a)(5) § 115.766(a)(6) § 115.766(c) [G]§ 115.766(e) [G]§ 115.766(g) [G]§ 115.766(h) § 115.766(i)(1)	§ 115.766(i)(2)
OP1D3626AV	EP	R5121-10	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP1D3626BV	EP	R5121-11	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP1D3635AV	EP	R5121-	VOC	30 TAC Chapter	§ 115.127(a)(2)(A)	A vent gas stream	[G]§ 115.125	§ 115.126	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		12		115, Vent Gas Controls	[G]§ 115.122(a)(4) § 115.127(a)(2)	having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	§ 115.126(2)	§ 115.126(2) § 115.126(4)	
OP1D3635BV	EP	R5121-13	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP1DECOKE2	EP	R5121-9	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP1DM3420V	EP	R5121-37	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP1DM3422V	EP	R5121-9	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).			
OP1DM3453	EU	61FF-1	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 60.18 § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 60.18(f)(2) § 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) § 61.354(e) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
OP1DM3903	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
OP1DM3903	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements	[G]§ 115.117	§ 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
OP1DM3904	EU	R5112-24A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
OP1DM3904	EU	R5112-24B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
OP1EN1	EU	R7300-1	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(9)(E)(vii)(II) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) [G]§ 117.310(f) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(C) § 117.340(h) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(B) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OP1EN1	EU	R7300-1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B)	CO emissions must not exceed 3.0 g/hp-hr for stationary internal combustion engines.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.340(a)(2)(C) § 117.340(h) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)		§ 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OP1EN1	EU	60IIII-1	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP1EN1	EU	60IIII-1	NMHC and NO_X	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 75 KW but less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 - 2013 model year must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102.	None	None	None
OP1EN1	EU	60IIII-1	PM	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2011 model year and later must comply with a PM emission limit of 0.02 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	[G]§ 60.4214(d)
OP1EN1	EU	63ZZZZ-1	FORMALDEHYDE	40 CFR Part 63, Subpart ZZZZ	§ 63.6600(b)-Table2a.3.b § 63.6595(c) § 63.6600(b)-Table2b.1.a § 63.6600(b)-	For each new or reconstructed CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP	§ 63.6610(a) § 63.6610(b) § 63.6610(c) § 63.6615 § 63.6620(a) § 63.6620(a)-Table3.3	§ 63.6620(i) § 63.6630(a)-Table5.9.a.iii § 63.6635(a) § 63.6635(c) § 63.6655(a)	§ 63.6620(i) § 63.6630(c) § 63.6640(b) § 63.6640(e) § 63.6645(a) § 63.6645(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					Table2b.1.b § 63.6605(a) § 63.6605(b) § 63.6625(h) § 63.6630(a) § 63.6630(b) § 63.6640(b)	emissions, operating at 100% load plus or minus 10%, you must limit the concentration of formaldehyde in the stationary RICE exhaust to 580 ppbvd or less at 15 % O2.	§ 63.6620(a)-Table4.3.a.i § 63.6620(a)-Table4.3.a.ii § 63.6620(a)-Table4.3.a.iii § 63.6620(a)-Table4.3.a.iv § 63.6620(b) § 63.6620(b)(4) § 63.6620(d) [G]§ 63.6620(e)(2) [G]§ 63.6625(b) § 63.6630(a)-Table5.9.a.i § 63.6630(a)-Table5.9.a.ii § 63.6630(a)-Table5.9.a.iii § 63.6635(a) § 63.6635(b) § 63.6640(a) § 63.6640(a)-Table6.7.a.i § 63.6640(a)-Table6.7.a.ii § 63.6640(a)-Table6.7.a.iii § 63.6640(a)-Table6.7.a.iv § 63.6640(a)-Table6.7.a.v § 63.6640(b)	§ 63.6655(a)(1) § 63.6655(a)(2) § 63.6655(a)(3) § 63.6655(a)(4) § 63.6655(a)(5) § 63.6655(d) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6645(g) § 63.6645(h) § 63.6645(h)(2) § 63.6650(a) § 63.6650(a)-Table7.1.a.i § 63.6650(a)-Table7.1.a.ii § 63.6650(a)-Table7.1.b § 63.6650(a)-Table7.1.c § 63.6650(b) § 63.6650(b)(1) § 63.6650(b)(2) § 63.6650(b)(3) § 63.6650(b)(4) § 63.6650(b)(6) § 63.6650(b)(7) § 63.6650(b)(8) § 63.6650(b)(9) [G]§ 63.6650(c) [G]§ 63.6650(d) § 63.6650(f)
OP1EN2	EU	R7300-2	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
OP1EN2	EU	60IIII-1	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) § 60.4211(b) § 60.4211(b)(1) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2008 model year or earlier must comply with a CO emission limit of 3.5 g/KW-hr, as listed in Table 4 to this subpart.	None	None	[G]§ 60.4214(d)
OP1EN2	EU	60IIII-1	NMHC and NO_X	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) § 60.4211(b) § 60.4211(b)(1) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2008 model year or earlier must comply with an NMHC+NOx emission limit of 10.5 g/KW-hr, as listed in Table 4 to this subpart.	None	None	[G]§ 60.4214(d)
OP1EN2	EU	60IIII-1	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) § 60.4211(b)	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4211(b)(1) [G]§ 60.4211(f) § 60.4218	greater than or equal to130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2008 model year or earlier must comply with a PM emission limit of 0.54 g/KW-hr, as listed in Table 4 to this subpart.			
OP1EN2	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
OP1EN3	EU	R7300-3	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
OP1EN3	EU	60IIII-1	NMHC and NO_X	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as listed in Table 4 to this subpart.	None	None	[G]§ 60.4214(d)
OP1EN3	EU	60IIII-1	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year and later must comply with a PM emission limit of 0.20	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						g/KW-hr, as listed in Table 4 to this subpart.			
OP1EN3	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
OP1FL3801	EU	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period, except for upset emissions as provided in §101.11(a).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
OP1FL3801	EP	R5720-1	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(d) § 115.722(d)(1) § 115.722(d)(2) [G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv)	All flares must continuously meet the requirements of 40 CFR § 60.18(c)(2)-(6) and (d) as amended through October 17, 2000 (65 FR 61744) when vent gas containing HRVOC is being routed to the	[G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii)	§ 115.726(a)(1) § 115.726(a)(1)(A) § 115.726(d)(1) § 115.726(d)(10) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) § 115.726(i) § 115.726(j)(1)	§ 115.725(n) § 115.726(a)(1)(B) [G]§ 115.726(a)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) [G]§ 115.725(l) § 115.725(m)(2)(A) § 115.725(m)(2)(B) [G]§ 115.726(a)(2)	flare.	§ 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) § 115.725(d)(3) § 115.725(d)(4) § 115.725(d)(5) § 115.725(d)(6) § 115.725(d)(7) § 115.725(k)(1) [G]§ 115.725(l) § 115.725(m)(1) § 115.725(m)(2)(A) § 115.725(m)(2)(B) § 115.725(n)	§ 115.726(j)(2)	
OP1FL3801	CD	60A-1A	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1) § 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(i) § 60.18(c)(6) § 60.18(e)	Flares shall comply with paragraphs (c)-(f) of § 60.18.	§ 60.18(d) § 60.18(f)(1) § 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4)	None	None
OP1FL3801	CD	60A-1B	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1) § 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(ii) § 60.18(c)(6) § 60.18(e)	Flares shall comply with paragraphs (c)-(f) of § 60.18.	§ 60.18(d) § 60.18(f)(1) § 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4)	None	None
OP1FL3801	CD	60A-1C	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1) § 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(iii) § 60.18(c)(6) § 60.18(e)	Flares shall comply with paragraphs (c)-(f) of § 60.18.	§ 60.18(d) § 60.18(f)(1) § 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4) § 60.18(f)(5)	None	None
OP1FL3801	CD	63A-1A	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3)	Flares shall be designed and operated with no visible emissions, except for periods of a	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(i)	total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.			
OP1FL3801	CD	63A-1B	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(ii)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
OP1FL3801	CD	63A-1C	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(iii)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
OP1FL3801V	EP	R5720-1	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.722(d) § 115.722(d)(1) § 115.722(d)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(n)	§ 115.726(d)(1) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP1FL3801V	EP	R5121-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(2) § 115.121(a)(2) § 115.122(a)(2)(A) § 60.18	Vent gas affected by §115.121(a)(2) must be controlled properly with a control efficiency > 98% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2) § 115.126(7)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None
OP1FL3801V	EP	R5121-32	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(B) § 60.18	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None
OP1FL3801V	EP	R5121-33	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
OP1FL3801V	EP	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2455(a)-Table 1.1.a.ii § 63.11(b) § 63.2450(b) § 63.2455(a) § 63.2455(b) § 63.2455(b)(1) § 63.982(b)	For each Group 1continuous process vent, the owner or operator must reduce emissions of total organic HAP by venting emissions through a closed vent system to a	[G]§ 63.115(d)(2)(v) § 63.115(d)(3)(iii) § 63.983(b) [G]§ 63.983(b)(1) [G]§ 63.983(b)(2) [G]§ 63.983(b)(3) [G]§ 63.983(c)(1) § 63.983(c)(2)	§ 63.2450(f)(2) § 63.2450(f)(2)(i) § 63.2450(f)(2)(ii) § 63.983(b) [G]§ 63.983(d)(2) § 63.987(c) § 63.998(a)(1)(ii) § 63.998(a)(1)(iii)(A)	§ 63.2450(f)(2)(ii) § 63.2450(q) § 63.997(b)(2) § 63.997(c)(3) § 63.998(a)(1)(iii)(A) [G]§ 63.998(b)(3) [G]§ 63.999(a)(1) § 63.999(b)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.983(a)(1) § 63.983(a)(2) § 63.983(d)(1) § 63.983(d)(1)(i) [G]§ 63.983(d)(2) § 63.983(d)(3) § 63.987(a) § 63.997(b)(2) § 63.997(b)(3) § 63.997(c)(3)	flare.	§ 63.983(c)(3) § 63.983(d)(1) § 63.983(d)(1)(ii) § 63.987(c) § 63.997(b) § 63.997(c)(2) § 63.997(c)(3) § 63.997(c)(3)(i) § 63.997(c)(3)(ii)	§ 63.998(a)(1)(iii)(B) [G]§ 63.998(b)(1) [G]§ 63.998(b)(2) [G]§ 63.998(b)(3) [G]§ 63.998(b)(5) [G]§ 63.998(d)(1) § 63.998(d)(3)(i) § 63.998(d)(3)(ii) § 63.998(d)(5)	§ 63.999(c)(1) § 63.999(c)(2)(i) § 63.999(c)(3) § 63.999(c)(6) [G]§ 63.999(c)(6)(i) § 63.999(c)(6)(iv) [G]§ 63.999(d)(1) [G]§ 63.999(d)(2)
OP1FL3801V	EP	63G-3	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.113(a)(1) § 63.11 § 63.113(h) [G]§ 63.115(f)	Reduce emissions of organic HAP using a flare.§63.113(a)(1)(i)-(ii)	§ 63.114(a) § 63.114(a)(2) [G]§ 63.115(f) [G]§ 63.116(a)	[G]§ 63.117(a)(5) § 63.118(a)(1) § 63.118(a)(2) [G]§ 63.152(a) [G]§ 63.152(f)	§ 63.114(e) [G]§ 63.117(a)(5) § 63.117(f) § 63.118(f)(2) § 63.118(f)(5) [G]§ 63.151(b) § 63.151(e) [G]§ 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
OP1FL3801V	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP1HT3415	EP	R1111-5	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
OP1HT3415	EU	R7ICI-8A	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(6)		
OP1HT3415	EU	R7ICI-8A	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(7) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OP1HT3415	EU	R7ICI-8A	NH_3	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(A)	For process heaters that inject urea or ammonia into the exhaust stream for NO_x control, ammonia emissions must not exceed 10 ppmv at 3.0% O_2, dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3) § 117.340(d) § 117.8000(b) § 117.8000(c) § 117.8000(c)(3) § 117.8000(c)(4) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8130 § 117.8130(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP1HT3415	EU	R7ICI-8B	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(g) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(b) § 117.8100(b)(1) [G]§ 117.8100(b)(1)(A) § 117.8100(b)(1)(B) § 117.8100(b)(2) § 117.8100(b)(3) § 117.8100(b)(3)(A) § 117.8100(b)(3)(B) § 117.8100(b)(4) § 117.8100(b)(4)(A) § 117.8100(b)(4)(A)(i) § 117.8100(b)(4)(A)(i)(I) § 117.8100(b)(4)(A)(i)(II) [G]§ 117.8100(b)(4)(A)(ii) [G]§ 117.8100(b)(4)(B) § 117.8100(b)(4)(C) § 117.8100(b)(4)(C)(i) § 117.8100(b)(4)(C)(ii) § 117.8100(b)(4)(C)(iii) § 117.8100(b)(4)(C)(iii)(I) § 117.8100(b)(4)(C)(iii)(II) § 117.8100(b)(4)(C)(iii)(II)(-a-) § 117.8100(b)(5) § 117.8100(b)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
OP1HT3415	EU	R7ICI-	CO	30 TAC Chapter	§ 117.310(c)(1)	CO emissions must not	[G]§ 117.335(a)(1)	§ 117.345(a)	§ 117.335(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		8B		117, Subchapter B	§ 117.310(c)(1)(B) § 117.310(c)(3)	exceed 400 ppmv at 3.0% O 2, dry basis.	§ 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(f) § 117.345(f)(1) § 117.345(f)(7) § 117.345(f)(9)	§ 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OP1HT3415	EU	R7ICI-8C	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in §	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						117.9800 to comply with § 117.320.	§ 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		
OP1HT3415	EU	R7ICI-8C	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(7) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OP1HT3415	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					Part 63, Subpart YY				
OP1HT3601	EU	R7ICI-4	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OP1HT3601	EU	R7ICI-4	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8120(2)(B)		
OP1HT3601	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
OP1HT3601V	EP	R5121-33	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
OP1HT3601V	EP	R5121-6	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(2) § 115.121(a)(2) § 115.122(a)(2)(B)	Vent gas affected by §115.121(a)(2) must be controlled properly with a control efficiency > 98% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
OP1HT3701	EU	R7ICI-3	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)		[G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OP1HT3701	EU	R7ICI-3	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OP1HT3701	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					requirements of 40 CFR Part 63, Subpart DDDDD			DDDDD	
OP1HT3701V	EP	R5121-26	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
OP1HT3701V	EP	R5121-7	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(2) § 115.121(a)(2) § 115.122(a)(2)(B)	Vent gas affected by §115.121(a)(2) must be controlled properly with a control efficiency > 98% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
OP1PV3804A	EP	R5121-38	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP1PV3804B	EP	R5121-39	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) <	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).			
OP1RX3701V	EP	R5121-14	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP1RX3702V	EP	R5121-15	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP1SMLTK14	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP1SMLTK30	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP1SMLTK30	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117	§ 115.118(a)(5) § 115.118(a)(7)	None
OP1SP3902	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
OP1SU3406	EP	R5121-23	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP1SU3406	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d)	§ 61.357(d)(7) § 61.357(d)(7)(iv)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	system that routes all organic vapors vented from the tank to a control device.	§ 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP1SU3406	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	None
OP1SU3406	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)		§ 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	
OP1SU3406	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	None
OP1SU3406	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP1SU3407	EP	R5121-	VOC	30 TAC Chapter	§ 115.127(a)(2)(A)	A vent gas stream	[G]§ 115.125	§ 115.126	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		24		115, Vent Gas Controls	[G]§ 115.122(a)(4) § 115.127(a)(2)	having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	§ 115.126(2)	§ 115.126(2) § 115.126(4)	
OP1SU3407	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	§ 61.357(d)(7) § 61.357(d)(7)(iv)
OP1SU3407	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(g)				
OP1SU3407	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)
OP1SU3407	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 61.355(i)(3)(iv) § 61.355(i)(4)		
OP1SU3407	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2485(a) § 63.133(a)(1) § 63.2485(b)	You must meet each requirement in Table 7 to this subpart that applies: §63.133(a)(1) - The owner or operator shall operate and maintain a fixed roof	None	None	§ 63.146(b)(2) § 63.146(b)(5) § 63.2450(q)
OP1SU3407	EU	63G-11	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(1)	A fixed roof shall be operated and maintained except that if the wastewater tank is used for specified purpose, then owner or operator shall comply with requirements of § 63.133(a)(2).	None	None	§ 63.146(b)(2) § 63.146(b)(5) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(c)(1) § 63.152(c)(4)(ii)
OP1SU3407	EU	63G-12	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(1)	A fixed roof shall be operated and maintained except that if the wastewater tank is used for specified purpose, then owner or operator shall comply with requirements of § 63.133(a)(2).	None	None	§ 63.146(b)(2) § 63.146(b)(5) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(c)(1) § 63.152(c)(4)(ii)
OP1SU3407	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					equipment specification requirements of 40 CFR Part 63, Subpart YY			CFR Part 63, Subpart YY	YY
OP1SU3502	EP	R5121-26	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP1SU3502	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	§ 61.357(d)(7) § 61.357(d)(7)(iv)
OP1SU3502	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)		[G]§ 61.355(h)	§ 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	
OP1SU3502	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)
OP1SU3502	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(f) § 61.349(g)		§ 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP1SU3502	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP1SU3671	EP	R5121-25	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP1SU3671	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	§ 61.357(d)(7) § 61.357(d)(7)(iv)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(g)			§ 61.356(j)(3)(ii) § 61.356(j)(6)	
OP1SU3671	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	None
OP1SU3671	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)
OP1SU3671	EU	61FF-9	BENZENE	40 CFR Part 61,	§ 61.343(a)(1)	The owner or operator	§ 61.343(a)(1)(i)(A)	§ 61.349(a)(1)(ii)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Subpart FF	§ 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP1SU3671	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP1SU38094	EU	R5140-6	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(A) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6)	[G]§ 115.142(1)(H) § 115.144(3)(A) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 115.145(7) § 115.145(9) [G]§ 115.148		
OP1SU38094	EU	61FF-5	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(ii) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(d) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(G) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(10) § 61.356(j)(2) § 61.356(j)(3)	None
OP1SU38094	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	None
OP1SU38094	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 61.347(a)(1)(i)(A)	Install, operate, and maintain a fixed-roof	§ 61.347(a)(1)(i)(A) § 61.347(b)	§ 61.349(a)(1)(ii) § 61.354(c)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP1SU38094	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	None
OP1SU38094	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the	§ 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	oil-water separator to a control device.	§ 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP1SU38094	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2485(a) § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.137(a)(1) § 63.137(b)(1)(ii) § 63.137(d) § 63.137(e)(3) § 63.137(f) § 63.139(b) § 63.139(d)(4)(i) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) § 63.144(a)(2) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(j)(1) § 63.2450(b) § 63.2485(b)	You must meet each requirement in Table 7 to this subpart that applies: §63.137(a)(1) - The owner or shall operate and maintain a fixed roof and a closed vent system that routes the organic hazardous air pollutants vapors vented from the oil-water separator to a control device	[G]§ 63.115(d)(2)(v) § 63.115(d)(3)(iii) § 63.137(e)(2) § 63.137(e)(3) § 63.139(e) § 63.143(a) § 63.144(b) § 63.144(b)(1) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5) [G]§ 63.144(b)(5)(i) § 63.144(b)(5)(ii) [G]§ 63.144(b)(5)(iii) § 63.144(b)(5)(iv) § 63.144(b)(6) § 63.144(c) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.144(c)(4) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g)	§ 63.118(a)(3) § 63.144(b)(4) § 63.144(b)(5)(ii) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.147(b) § 63.147(b)(1) § 63.147(b)(2) § 63.147(b)(7) § 63.172(j)(1) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(c) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d) § 63.2450(q)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.172(h) § 63.172(j)(1) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d) § 63.2485(h)(1) § 63.2485(h)(2)		
OP1SU38094	EU	63G-13	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.137(a)(1) § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.137(b)(1)(ii) § 63.137(d) § 63.137(e)(3) § 63.137(f) § 63.139(b) § 63.139(d)(4)(i) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(j)(1)	A fixed roof and a closed vent system that routes the organic hazardous air pollutants vapors vented from the oil-water separator to a control device and which meets §63.137(b).	[G]§ 63.137(e)(1) § 63.137(e)(2) § 63.137(e)(3) § 63.143(a) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) § 63.172(j)(1) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.118(a)(3) § 63.147(b) § 63.147(b)(1) § 63.147(b)(2) [G]§ 63.152(a) § 63.172(j)(1) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(c) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
OP1SU38094	EU	63G-14	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.137(a)(1) § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.137(b)(1)(ii)	A fixed roof and a closed vent system that routes the organic hazardous air pollutants vapors vented from the	[G]§ 63.137(e)(1) § 63.137(e)(2) § 63.137(e)(3) § 63.143(a) [G]§ 63.172(f)(1)	§ 63.118(a)(3) § 63.147(b) § 63.147(b)(1) § 63.147(b)(2) [G]§ 63.152(a)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(c) [G]§ 63.151(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.137(d) § 63.137(e)(3) § 63.137(f) § 63.139(b) § 63.139(d)(4)(i) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(j)(1)	oil-water separator to a control device and which meets §63.137(b).	[G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) § 63.172(j)(1) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.172(j)(1) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
OP1SU38094	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP1SU38099	EP	R5121-22	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP1SU38099	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	§ 61.357(d)(7) § 61.357(d)(7)(iv)
OP1SU38099	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	None
OP1SU38099	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	control device.	§ 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	
OP1SU38099	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	None
OP1SU38601	EP	R5121-21	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						period is exempt from the requirements of § 115.121(a)(1).			
OP1TK3406	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
OP1TK3406	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	§ 61.357(d)(7) § 61.357(d)(7)(iv)
OP1TK3406	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)			§ 61.356(j)(2) § 61.356(j)(3)	
OP1TK3406	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)
OP1TK3406	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(g)		§ 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP1TK3455	EU	R5140-15	VOC	30 TAC Chapter 115, Industrial Wastewater	[G]§ 115.142(2) § 115.142 [G]§ 115.148	The wastewater component shall be equipped with a floating roof or internal floating cover which meets the requirements listed in §115.142(2)(A)-(F).	§ 115.144(2) § 115.144(2)(B) § 115.144(2)(C) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
OP1TK3455	EU	60Kb-1	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3) § 60.116b(f)(1)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
OP1TK3455	EU	61FF-5	BENZENE	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)				
OP1TK3455	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP1TK3458	EU	R5140-6	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(A) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.144(3)(A) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
OP1TK3458	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
OP1TK3458	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B)	The owner or operator shall install, operate, and maintain a fixed-	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5)	§ 61.357(d)(7) § 61.357(d)(7)(iv)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP1TK3458	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	None
OP1TK3458	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)		§ 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	
OP1TK3458	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	None
OP1TK3501	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
OP1TK3501	EU	R5112-	VOC	30 TAC Chapter	§ 115.112(e)(1)	No person shall place,	[G]§ 115.117	§ 115.118(a)(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		2		115, Storage of VOCs		store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.		§ 115.118(a)(7)	
OP1TK3601	EU	R5112-6	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None
OP1TK3601	EU	R5112-6B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						vapor pressure less than 1.5 psia is exempt from the requirements of this division.			
OP1TK38008	EU	R5140-1	VOC	30 TAC Chapter 115, Industrial Wastewater	[G]§ 115.142(2) § 115.142 [G]§ 115.148	The wastewater component shall be equipped with a floating roof or internal floating cover which meets the requirements listed in §115.142(2)(A)-(F).	§ 115.144(2) § 115.144(2)(B) § 115.144(2)(C) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
OP1TK38008	EU	61FF-2	BENZENE	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)
OP1TK38008	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2485(a) § 63.133(a)(1) § 63.2485(b)	You must meet each requirement in Table 7 to this subpart that applies: §63.133(a)(1) - The owner or operator shall operate and maintain a fixed roof	None	None	§ 63.146(b)(2) § 63.146(b)(5) § 63.2450(q)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP1TK38008	EU	63G-2	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(1)	A fixed roof shall be operated and maintained except that if the wastewater tank is used for specified purpose, then owner or operator shall comply with requirements of § 63.133(a)(2).	None	None	§ 63.146(b)(2) § 63.146(b)(5) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(c)(1) § 63.152(c)(4)(ii)
OP1TK38008	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP1TK38009	EU	R5140-2	VOC	30 TAC Chapter 115, Industrial Wastewater	[G]§ 115.142(2) § 115.142 [G]§ 115.148	The wastewater component shall be equipped with a floating roof or internal floating cover which meets the requirements listed in §115.142(2)(A)-(F).	§ 115.144(2) § 115.144(2)(B) § 115.144(2)(C) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
OP1TK38009	EU	61FF-3	BENZENE	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	of the following §61.351(a)(1)-(3):			§ 61.357(e) § 61.357(f)
OP1TK38009	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2485(a) § 63.133(a)(1) § 63.2485(b)	You must meet each requirement in Table 7 to this subpart that applies: §63.133(a)(1) - The owner or operator shall operate and maintain a fixed roof	None	None	§ 63.146(b)(2) § 63.146(b)(5) § 63.2450(q)
OP1TK38009	EU	63G-3	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(1)	A fixed roof shall be operated and maintained except that if the wastewater tank is used for specified purpose, then owner or operator shall comply with requirements of § 63.133(a)(2).	None	None	§ 63.146(b)(2) § 63.146(b)(5) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(c)(1) § 63.152(c)(4)(ii)
OP1TK38009	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP1TK38303	EU	R5112-12	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						vapor pressure less than 1.5 psia is exempt from the requirements of this division.			
OP1TK38303	EU	R5112-12A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
OP1TK3903	EU	R5140-16A	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.147(2) [G]§ 115.142(4) [G]§ 115.148	An owner or operator may exempt from control requirements of §115.142 one or more affected VOC wastewater streams for which the total annual VOC loading is less than or equal to 10 Mg (11.03 tons).	§ 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(3) § 115.146(4)	[G]§ 115.142(4)
OP1TK3908	EU	R5112-7A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						of subsection (a)(1) of this paragraph for crude oil and condensate.			
OP1TK3908	EU	R5112-7B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
OP1TK3909	EU	R5112-8A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						oil and condensate.			
OP1TK3909	EU	R5112-8B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
OP1TK3910	EU	R5112-9A	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP1TK3910	EU	R5112-9B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(3) § 115.112(e)(3)(C) § 60.18	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(2) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
OP1TK3911	EU	R5112-4	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)
OP1TK3911	EU	60K-4	VOC	40 CFR Part 60, Subpart K	§ 60.112(a)(1)	Storage vessels holding petroleum liquids with a	§ 60.113(a) § 60.113(b)	§ 60.113(a)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						true vapor pressure of 78 mm Hg (1.5 psia) or greater but not greater than 570 mm Hg (11.1 psia) shall have a floating roof, a vapor recovery system, or their equivalents.	** See Periodic Monitoring Summary		
OP1TK3911	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP1TK3912	EU	R5112-4	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)
OP1TK3912	EU	60K-5	VOC	40 CFR Part 60, Subpart K	§ 60.112(a)(1)	Storage vessels holding petroleum liquids with a true vapor pressure of 78 mm Hg (1.5 psia) or	§ 60.113(a) § 60.113(b) ** See Periodic Monitoring Summary	§ 60.113(a)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						greater but not greater than 570 mm Hg (11.1 psia) shall have a floating roof, a vapor recovery system, or their equivalents.			
OP1TK3912	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2470(a)-Table4.1.b.i § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(B) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(viii) § 63.1063(a)(2)(viii)(A) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2) § 63.2470(a)	For each Group 1 storage tank for which the maximum true vapor pressure of total HAP at the storage temperature is < 76.6 kilopascals, you must comply with the requirements of Subpart WW of this part, except as specified in §63.2470.	§ 63.1063(c)(2) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d)	§ 63.1063(c)(2)(iv)(B) [G]§ 63.1066(a) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.2450(q)
OP1TK3943	EU	R5112-E1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
OP1TK3943	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall	The permit holder shall comply with the	The permit holder shall comply with the applicable	The permit holder shall comply with the	The permit holder shall comply with the

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	applicable requirements of 40 CFR Part 63, Subpart YY	monitoring and testing requirements of 40 CFR Part 63, Subpart YY	applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP1TK4501	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
OP1TK4501	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117	§ 115.118(a)(5) § 115.118(a)(7)	None
OP1TW3407	PRO	61FF-1A	BENZENE	40 CFR Part 61, Subpart FF	§ 61.348(a)(5) § 60.18 § 61.348(b)(1) § 61.348(f) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii)	An owner or operator that aggregates or mixes any combination of process wastewater, product tank drawdown, or landfill leachate subject to §61.342(c)(1)	§ 60.18(f)(2) § 61.348(f) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(a)(2) [G]§ 61.354(b)	§ 61.354(a)(2) § 61.354(c) § 61.354(c)(3) § 61.356(e) § 61.356(e)(1) § 61.356(e)(2) § 61.356(f)	§ 61.357(d)(7) § 61.357(d)(7)(ii) § 61.357(d)(7)(iii) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	together with other waste streams to create a combined waste stream for the purpose of facilitating management or treatment of waste in a wastewater treatment system shall operate the wastewater treatment system in accordance with §61.348(b). These provisions apply to above- and below-ground level wastewater treatment systems.	§ 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.356(f)(1) § 61.356(h) [G]§ 61.356(i) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	
OP1TW3407	PRO	61FF-1B	BENZENE	40 CFR Part 61, Subpart FF	§ 61.348(a)(5) § 60.18 § 61.348(b)(1) § 61.348(f) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	An owner or operator that aggregates or mixes any combination of process wastewater, product tank drawdown, or landfill leachate subject to §61.342(c)(1) together with other waste streams to create a combined waste stream for the purpose of facilitating management or treatment of waste in a wastewater treatment system shall operate the wastewater treatment system in accordance with §61.348(b). These provisions apply to above- and below-ground level wastewater treatment systems.	§ 60.18(f)(2) § 61.348(f) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(a)(2) [G]§ 61.354(b) § 61.354(c) § 61.354(c)(3) [G]§ 61.355(h)	§ 61.354(a)(2) § 61.354(c) § 61.354(c)(3) § 61.356(e) § 61.356(e)(1) § 61.356(e)(2) § 61.356(f) § 61.356(f)(1) § 61.356(h) [G]§ 61.356(i) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(ii) § 61.357(d)(7)(iii) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
OP1TW3407	PRO	61FF-	BENZENE	40 CFR Part 61,	§ 61.348(a)(5)	An owner or operator	§ 60.18(f)(2)	§ 61.354(a)(2)	§ 61.357(d)(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		1C		Subpart FF	§ 60.18 § 61.348(b)(1) § 61.348(f) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	that aggregates or mixes any combination of process wastewater, product tank drawdown, or landfill leachate subject to §61.342(c)(1) together with other waste streams to create a combined waste stream for the purpose of facilitating management or treatment of waste in a wastewater treatment system shall operate the wastewater treatment system in accordance with §61.348(b). These provisions apply to above- and below-ground level wastewater treatment systems.	§ 61.348(f) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(a)(2) [G]§ 61.354(b) § 61.354(c) § 61.354(c)(3) § 61.355(g) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.355(g) § 61.356(e) § 61.356(e)(1) [G]§ 61.356(e)(3) § 61.356(f) § 61.356(f)(1) § 61.356(h) [G]§ 61.356(i) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7)(ii) § 61.357(d)(7)(iii) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
OP1TW3407	PRO	61FF-1D	BENZENE	40 CFR Part 61, Subpart FF	§ 61.348(a)(5) § 60.18 § 61.348(b)(1) § 61.348(f) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	An owner or operator that aggregates or mixes any combination of process wastewater, product tank drawdown, or landfill leachate subject to §61.342(c)(1) together with other waste streams to create a combined waste stream for the purpose of facilitating management or treatment of waste in a wastewater treatment system shall operate the wastewater treatment system in accordance	§ 60.18(f)(2) § 61.348(f) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(a)(2) [G]§ 61.354(b) § 61.354(c) § 61.354(c)(3) § 61.355(g) [G]§ 61.355(h)	§ 61.354(a)(2) § 61.354(c) § 61.354(c)(3) § 61.355(g) § 61.356(e) § 61.356(e)(1) [G]§ 61.356(e)(3) § 61.356(f) § 61.356(f)(1) § 61.356(h) [G]§ 61.356(i) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(ii) § 61.357(d)(7)(iii) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						with §61.348(b). These provisions apply to above- and below-ground level wastewater treatment systems.			
OP1TW3407	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2485(a) [G]§ 63.132(f) § 63.138(e)(2) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) § 63.145(c)(6) § 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.2450(b) § 63.2485(b)	You must meet each requirement in Table 7 to this subpart that applies: §63.138(e)(2) - The owner or operator shall reduce, by removal or destruction, the mass flow rate of subpart G Table 8 and/or subpart FFFF Tables 8 and 9 compounds by at least the fraction removal (Fr) values specified in subpart G Table 9	§ 63.11(b)(4) § 63.11(b)(6) § 63.11(b)(7)(i) § 63.11(b)(7)(iii) § 63.11(b)(8) [G]§ 63.115(d)(2)(v) § 63.115(d)(3)(iii) § 63.138(j)(2) § 63.139(d)(3) § 63.139(e) § 63.143(d) § 63.143(f) § 63.143(g) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) [G]§ 63.145(a)(4) § 63.145(a)(5) [G]§ 63.145(a)(6) § 63.145(b) § 63.145(c) § 63.145(c)(1) § 63.145(c)(2) § 63.145(c)(3) § 63.145(c)(4) § 63.145(c)(5) § 63.145(c)(6) § 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l)	§ 63.145(a)(3) [G]§ 63.145(a)(4) § 63.147(b) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3) § 63.2450(f)(2) § 63.2450(f)(2)(i) § 63.2450(f)(2)(ii)	§ 63.143(d) § 63.146(a) § 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) § 63.146(b)(9) § 63.146(b)(9)(ii) [G]§ 63.146(d) § 63.146(f) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d) § 63.2450(f)(2)(ii) § 63.2450(q)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.180(b) [G]§ 63.180(d)		
OP1TW3407	EU	63FFFF-2	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2485(a) [G]§ 63.132(f) § 63.138(e)(2) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) § 63.145(c)(6) § 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.2450(b) § 63.2485(b)	You must meet each requirement in Table 7 to this subpart that applies: §63.138(e)(2) - The owner or operator shall reduce, by removal or destruction, the mass flow rate of subpart G Table 8 and/or subpart FFFF Tables 8 and 9 compounds by at least the fraction removal (Fr) values specified in subpart G Table 9	§ 63.11(b)(4) § 63.11(b)(6) § 63.11(b)(7)(i) § 63.11(b)(7)(iii) § 63.11(b)(8) [G]§ 63.115(d)(2)(v) § 63.115(d)(3)(iii) § 63.138(j)(2) § 63.139(d)(3) § 63.139(e) § 63.143(d) § 63.143(f) § 63.143(g) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) [G]§ 63.145(a)(4) § 63.145(a)(5) [G]§ 63.145(a)(6) § 63.145(b) § 63.145(c) § 63.145(c)(1) § 63.145(c)(2) § 63.145(c)(3) § 63.145(c)(4) § 63.145(c)(5) § 63.145(c)(6) § 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.145(a)(3) [G]§ 63.145(a)(4) § 63.147(b) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3) § 63.2450(f)(2) § 63.2450(f)(2)(i) § 63.2450(f)(2)(ii)	§ 63.143(d) § 63.146(a) § 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) § 63.146(b)(9) § 63.146(b)(9)(ii) [G]§ 63.146(d) § 63.146(f) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d) § 63.2450(f)(2)(ii) § 63.2450(q)
OP1TW3407	PRO	63G-7A	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.138(e)(2) § 63.11	Reduce mass flow rate of Table 8 and/or Table	§ 63.138(j)(1) § 63.139(d)(3)	§ 63.138(j)(1) § 63.144(b)(3)	§ 63.143(d) § 63.146(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	9 compounds in Group 1 wastewater stream as specified. The process efficiency shall be computed as per §63.145(c) or §63.145(d).	§ 63.139(e) § 63.143(d) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.144(b) § 63.144(b)(1) § 63.144(b)(2) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5) [G]§ 63.144(b)(5)(i) § 63.144(b)(5)(ii) [G]§ 63.144(b)(5)(iii) § 63.144(b)(5)(iv) § 63.144(b)(6) § 63.144(c) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.144(c)(4) § 63.145(a) § 63.145(a)(1) § 63.145(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.144(b)(4) § 63.144(b)(5)(ii) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.145(a)(3) [G]§ 63.145(a)(4) § 63.147(b) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) [G]§ 63.152(a) [G]§ 63.152(f) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) § 63.146(b)(9) § 63.146(b)(9)(i) [G]§ 63.146(d) § 63.146(e) § 63.146(e)(1) § 63.146(f) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) § 63.151(e)(5) § 63.151(f) § 63.151(f)(1) § 63.151(f)(2) § 63.151(f)(3) § 63.151(h) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.182(d)
OP1TW3407	PRO	63G-7B	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.138(e)(2) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) § 63.145(c)(6) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	Reduce mass flow rate of Table 8 and/or Table 9 compounds in Group 1 wastewater stream as specified. The process efficiency shall be computed as per §63.145(c) or §63.145(d).	§ 63.138(j)(2) § 63.139(d)(3) § 63.139(e) § 63.143(d) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.144(b) § 63.144(b)(1) § 63.144(b)(2) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5) [G]§ 63.144(b)(5)(i) § 63.144(b)(5)(ii) [G]§ 63.144(b)(5)(iii) § 63.144(b)(5)(iv) § 63.144(b)(6) § 63.144(c) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.144(c)(4) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) [G]§ 63.145(a)(4) § 63.145(a)(5) [G]§ 63.145(a)(6) § 63.145(c) § 63.145(c)(1) § 63.145(c)(2) § 63.145(c)(3) § 63.145(c)(4) § 63.145(c)(5) § 63.145(c)(6) § 63.145(g) [G]§ 63.145(j)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)		
OP1TW3407	PRO	63G-7C	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.138(e)(2) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	Reduce mass flow rate of Table 8 and/or Table 9 compounds in Group 1 wastewater stream as specified. The process efficiency shall be computed as per §63.145(c) or §63.145(d).	§ 63.138(j)(1) § 63.139(d)(3) § 63.139(e) § 63.143(d) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.144(b) § 63.144(b)(1) § 63.144(b)(2) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5) [G]§ 63.144(b)(5)(i) § 63.144(b)(5)(ii) [G]§ 63.144(b)(5)(iii) § 63.144(b)(5)(iv) § 63.144(b)(6) § 63.144(c) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.144(c)(4) § 63.145(a) § 63.145(a)(1) § 63.145(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h)	§ 63.138(j)(1) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5)(ii) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.145(a)(3) [G]§ 63.145(a)(4) § 63.147(b) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(d)(1) § 63.147(e) [G]§ 63.152(a) [G]§ 63.152(f) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.143(d) § 63.146(a) § 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) § 63.146(b)(7) [G]§ 63.146(b)(7)(i) [G]§ 63.146(b)(8) § 63.146(b)(9) § 63.146(b)(9)(i) [G]§ 63.146(d) § 63.146(e) § 63.146(e)(1) § 63.146(f) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) § 63.151(e)(5) § 63.151(f) § 63.151(f)(1) § 63.151(f)(2) § 63.151(f)(3) § 63.151(h) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)		§ 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
OP1TW3407	PRO	63G-7D	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.138(e)(2) § 63.11 [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(3) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) § 63.145(c)(6) [G]§ 63.145(j) § 63.172(a) [G]§ 63.172(h) § 63.172(i)	Reduce mass flow rate of Table 8 and/or Table 9 compounds in Group 1 wastewater stream as specified. The process efficiency shall be computed as per §63.145(c) or §63.145(d).	§ 63.138(j)(2) § 63.139(d)(3) § 63.139(e) § 63.143(d) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.144(b) § 63.144(b)(1) § 63.144(b)(2) § 63.144(b)(3) § 63.144(b)(4) § 63.144(b)(5) [G]§ 63.144(b)(5)(i) § 63.144(b)(5)(ii) [G]§ 63.144(b)(5)(iii) § 63.144(b)(5)(iv) § 63.144(b)(6) § 63.144(c) § 63.144(c)(1) § 63.144(c)(2) § 63.144(c)(3) § 63.144(c)(4) § 63.145(a) § 63.145(a)(1) § 63.145(a)(3) [G]§ 63.145(a)(4)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.145(a)(5) [G]§ 63.145(a)(6) § 63.145(c) § 63.145(c)(1) § 63.145(c)(2) § 63.145(c)(3) § 63.145(c)(4) § 63.145(c)(5) § 63.145(c)(6) § 63.145(g) [G]§ 63.145(j) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)		
OP1TW3407	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP1TW3453	EU	65NNN CAR	VOC	40 CFR Part 65, Subpart D	§ 60.660(a) § 60.660(b) § 60.660(d)(1) § 60.660(d)(2)	Owners or operators of process vents that are subject to NSPS subparts NNN may choose to comply with the provisions of 40 CFR part 65, subpart D, to satisfy the requirements of §§60.662 through 60.665 and 60.668.	None	None	§ 60.660(d)(4)
OP1TW3616	EU	65NNN	VOC	40 CFR Part 65,	§ 60.660(a)	Owners or operators of	None	None	§ 60.660(d)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		CAR		Subpart D	§ 60.660(b) § 60.660(d)(1) § 60.660(d)(2)	process vents that are subject to NSPS subparts NNN may choose to comply with the provisions of 40 CFR part 65, subpart D, to satisfy the requirements of §§60.662 through 60.665 and 60.668.			
OP1TW3617	EU	65NNN CAR	VOC	40 CFR Part 65, Subpart D	§ 60.660(a) § 60.660(b) § 60.660(d)(1) § 60.660(d)(2)	Owners or operators of process vents that are subject to NSPS subparts NNN may choose to comply with the provisions of 40 CFR part 65, subpart D, to satisfy the requirements of §§60.662 through 60.665 and 60.668.	None	None	§ 60.660(d)(4)
OP2BL803AV	EP	R5121-31	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(A)	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	None
OP2BL803AV	EP	R5121-7	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(2) § 115.121(a)(2) § 115.122(a)(2)(B)	Vent gas affected by §115.121(a)(2) must be controlled properly with a control efficiency > 98% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP2BL803BV	EP	R5121-32	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(A)	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	None
OP2BL803BV	EP	R5121-8	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(2) § 115.121(a)(2) § 115.122(a)(2)(B)	Vent gas affected by §115.121(a)(2) must be controlled properly with a control efficiency > 98% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(i) § 115.126(2)	None
OP2CT4811	EU	R5760-3	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Cooling Towers	§ 115.761(c)(1) § 115.761(c)(3) § 115.766(i)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 1 of this subchapter must not exceed 1,200 pounds of HRVOCs per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.764(a)(3) [G]§ 115.764(a)(6) § 115.764(c) § 115.764(e)(1)	§ 115.766(a)(1) § 115.766(a)(2) § 115.766(a)(3) § 115.766(a)(5) § 115.766(a)(6) § 115.766(c) [G]§ 115.766(e) [G]§ 115.766(g) [G]§ 115.766(h) § 115.766(i)(1)	§ 115.766(i)(2)
OP2D4626AV	EP	R5121-11	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of §	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						115.121(a)(1).			
OP2D4626BV	EP	R5121-12	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP2D4635AV	EP	R5121-13	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP2D4635BV	EP	R5121-14	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP2DECOKE2	EP	R5121-9	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP2DM4420V	EP	R5121-41	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP2DM4422V	EP	R5121-40	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP2DM4453	EU	61FF-1	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 60.18 § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 60.18(f)(2) § 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(3) § 61.354(e) [G]§ 61.355(h)	§ 61.354(c) § 61.354(c)(3) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(7)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(F)
OP2EN1	EU	R7300-1	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(9)(E)(vii)(II) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(C)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(B) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 117.310(e)(3) § 117.310(e)(4) [G]§ 117.310(f) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(h) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)		§ 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OP2EN1	EU	R7300-1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B)	CO emissions must not exceed 3.0 g/hp-hr for stationary internal combustion engines.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(C) § 117.340(h) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)		
OP2EN1	EU	60IIII-1	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None
OP2EN1	EU	60IIII-1	NMHC and NO_X	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 75 KW but less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 - 2013 model year must comply with an NMHC+NOx emission	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						limit of 4.0 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102.			
OP2EN1	EU	60IIII-1	PM	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2011 model year and later must comply with a PM emission limit of 0.02 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None
OP2EN1	EU	63ZZZZ-1	Formaldehyde	40 CFR Part 63, Subpart ZZZZ	§ 63.6600(b)-Table2a.3.b § 63.6595(c) § 63.6600(b)-Table2b.1.a § 63.6600(b)-Table2b.1.b § 63.6605(a) § 63.6605(b) § 63.6625(h) § 63.6630(a) § 63.6630(b) § 63.6640(b)	For each new or reconstructed CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, operating at 100% load plus or minus 10%, you must limit the concentration of formaldehyde in the stationary RICE exhaust to 580 ppbvd or less at 15 % O2.	§ 63.6610(a) § 63.6610(b) § 63.6610(c) § 63.6615 § 63.6620(a) § 63.6620(a)-Table3.3 § 63.6620(a)-Table4.3.a.i § 63.6620(a)-Table4.3.a.ii § 63.6620(a)-Table4.3.a.iii § 63.6620(a)-Table4.3.a.iv § 63.6620(b) § 63.6620(b)(4) § 63.6620(d) [G]§ 63.6620(e)(2) [G]§ 63.6625(b) § 63.6630(a)-Table5.9.a.i § 63.6630(a)-Table5.9.a.ii § 63.6630(a)-Table5.9.a.iii	§ 63.6620(i) § 63.6630(a)-Table5.9.a.iii § 63.6635(a) § 63.6635(c) § 63.6655(a) § 63.6655(a)(1) § 63.6655(a)(2) § 63.6655(a)(3) § 63.6655(a)(4) § 63.6655(a)(5) § 63.6655(d) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6620(i) § 63.6630(c) § 63.6640(b) § 63.6640(e) § 63.6645(a) § 63.6645(c) § 63.6645(g) § 63.6645(h) § 63.6645(h)(2) § 63.6650(a) § 63.6650(a)-Table7.1.a.i § 63.6650(a)-Table7.1.b § 63.6650(a)-Table7.1.c § 63.6650(b) § 63.6650(b)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.6635(a) § 63.6635(b) § 63.6640(a) § 63.6640(a)-Table6.7.a.i § 63.6640(a)-Table6.7.a.ii § 63.6640(a)-Table6.7.a.iii § 63.6640(a)-Table6.7.a.iv § 63.6640(a)-Table6.7.a.v § 63.6640(b)		§ 63.6650(b)(2) § 63.6650(b)(3) § 63.6650(b)(4) [G]§ 63.6650(c) [G]§ 63.6650(d) § 63.6650(f)
OP2EN2	EU	R7300-2	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
OP2EN2	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(b) § 63.6640(f)(1) [G]§ 63.6640(f)(2) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii § 63.6640(b)	§ 63.6625(i) § 63.6655(a) § 63.6655(a)(1) § 63.6655(d) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(b) § 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP2EN3	EU	R7300-3	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
OP2EN3	EU	60IIII-1	NMHC and NO_X	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as listed in Table 4 to this subpart.	None	None	[G]§ 60.4214(d)
OP2EN3	EU	60IIII-1	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a)	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4211(c) [G]§ 60.4211(f) § 60.4218	greater than or equal to 130 KW and less than or equal to 560 KW and a displacement of less than 30 liters per cylinder and is a 2009 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as listed in Table 4 to this subpart.			
OP2EN3	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
OP2FL4801	EU	R1111-1	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period, except for upset emissions as provided in §101.11(a).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP2FL4801	EP	R5720-1	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(d) § 115.722(d)(1) § 115.722(d)(2) [G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) [G]§ 115.725(l) § 115.725(m)(2)(A) § 115.725(m)(2)(B) [G]§ 115.726(a)(2)	All flares must continuously meet the requirements of 40 CFR § 60.18(c)(2)-(6) and (d) as amended through October 17, 2000 (65 FR 61744) when vent gas containing HRVOC is being routed to the flare.	[G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) § 115.725(d)(3) § 115.725(d)(4) § 115.725(d)(5) § 115.725(d)(6) § 115.725(d)(7) § 115.725(k)(1) [G]§ 115.725(l) § 115.725(m)(1) § 115.725(m)(2)(A) § 115.725(m)(2)(B) § 115.725(n)	§ 115.726(a)(1) § 115.726(a)(1)(A) § 115.726(d)(1) § 115.726(d)(10) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n) § 115.726(a)(1)(B) [G]§ 115.726(a)(2)
OP2FL4801	CD	60A-1A	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1) § 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(i) § 60.18(c)(6) § 60.18(e)	Flares shall comply with paragraphs (c)-(f) of § 60.18.	§ 60.18(d) § 60.18(f)(1) § 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4)	None	None
OP2FL4801	CD	60A-1B	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1) § 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(ii) § 60.18(c)(6) § 60.18(e)	Flares shall comply with paragraphs (c)-(f) of § 60.18.	§ 60.18(d) § 60.18(f)(1) § 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4)	None	None
OP2FL4801	CD	60A-1C	OPACITY	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1)	Flares shall comply with paragraphs (c)-(f) of §	§ 60.18(d) § 60.18(f)(1)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(iii) § 60.18(c)(6) § 60.18(e)	60.18.	§ 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4) § 60.18(f)(5)		
OP2FL4801	CD	63A-1A	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(i)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
OP2FL4801	CD	63A-1B	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(ii)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
OP2FL4801	CD	63A-1C	112(B) HAPS	40 CFR Part 63, Subpart A	§ 63.11(b)(4) § 63.11(b)(1) § 63.11(b)(2) § 63.11(b)(3) § 63.11(b)(5) § 63.11(b)(6)(ii) § 63.11(b)(7)(iii)	Flares shall be designed and operated with no visible emissions, except for periods of a total of 5 minutes or less during any 2 consecutive hrs. Test Method 22 in App. A of part 60 of this chapter shall be used.	§ 63.11(b)(4) § 63.11(b)(5) § 63.11(b)(7)(i)	None	None
OP2FL4801V	EP	R5720-1	HIGHLY REACTIVE VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.722(d)	HRVOC emissions at each site located in Harris County that is	§ 115.725(n)	§ 115.726(d)(1) § 115.726(d)(2) § 115.726(d)(3)	§ 115.725(n)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.722(d)(1) § 115.722(d)(2)	subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.		§ 115.726(d)(4) [G]§ 115.726(g) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	
OP2FL4801V	EP	R5121-10	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
OP2FL4801V	EP	R5121-33	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(B) § 60.18	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None
OP2FL4801V	EP	R5121-9	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(2) § 115.121(a)(2) § 115.122(a)(2)(A) § 60.18	Vent gas affected by §115.121(a)(2) must be controlled properly with a control efficiency > 98% or to a VOC concentration of no more than 20 ppmv (dry,	[G]§ 115.125 § 115.126(1) § 115.126(1)(B) § 115.126(2) § 115.126(7)	§ 115.126 § 115.126(1) § 115.126(1)(B) § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						corrected to 3% O2 for combustion devices).			
OP2FL4801V	EP	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2455(a)-Table 1.1.a.ii § 63.11(b) § 63.2450(b) § 63.2455(a) § 63.2455(b) § 63.2455(b)(1) § 63.982(b) § 63.983(a)(1) § 63.983(a)(2) § 63.983(d)(1) § 63.983(d)(1)(i) [G]§ 63.983(d)(2) § 63.983(d)(3) § 63.987(a) § 63.997(b)(2) § 63.997(b)(3) § 63.997(c)(3)	For each Group 1continuous process vent, the owner or operator must reduce emissions of total organic HAP by venting emissions through a closed vent system to a flare.	[G]§ 63.115(d)(2)(v) § 63.115(d)(3)(iii) § 63.983(b) [G]§ 63.983(b)(1) [G]§ 63.983(b)(2) [G]§ 63.983(b)(3) [G]§ 63.983(c)(1) § 63.983(c)(2) § 63.983(c)(3) § 63.983(d)(1) § 63.983(d)(1)(ii) § 63.987(c) § 63.997(b) § 63.997(c)(2) § 63.997(c)(3) § 63.997(c)(3)(i) § 63.997(c)(3)(ii)	§ 63.2450(f)(2) § 63.2450(f)(2)(i) § 63.2450(f)(2)(ii) § 63.983(b) [G]§ 63.983(d)(2) § 63.987(c) § 63.998(a)(1)(ii) § 63.998(a)(1)(iii)(A) § 63.998(a)(1)(iii)(B) [G]§ 63.998(b)(1) [G]§ 63.998(b)(2) [G]§ 63.998(b)(3) [G]§ 63.998(b)(5) [G]§ 63.998(d)(1) § 63.998(d)(3)(i) § 63.998(d)(3)(ii) § 63.998(d)(5)	§ 63.2450(f)(2)(ii) § 63.2450(q) § 63.997(b)(2) § 63.997(c)(3) § 63.998(a)(1)(iii)(A) [G]§ 63.998(b)(3) [G]§ 63.999(a)(1) § 63.999(b)(5) § 63.999(c)(1) § 63.999(c)(2)(i) § 63.999(c)(3) § 63.999(c)(6) [G]§ 63.999(c)(6)(i) § 63.999(c)(6)(iv) [G]§ 63.999(d)(1) [G]§ 63.999(d)(2)
OP2FL4801V	EP	63G-2	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.113(a)(1) § 63.11 § 63.113(h) [G]§ 63.115(f)	Reduce emissions of organic HAP using a flare.§63.113(a)(1)(i)-(ii)	§ 63.114(a) § 63.114(a)(2) [G]§ 63.115(f) [G]§ 63.116(a)	[G]§ 63.117(a)(5) § 63.118(a)(1) § 63.118(a)(2) [G]§ 63.152(a) [G]§ 63.152(f)	§ 63.114(e) [G]§ 63.117(a)(5) § 63.117(f) § 63.118(f)(2) § 63.118(f)(5) [G]§ 63.151(b) § 63.151(e) [G]§ 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
OP2FL4801V	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP2HT4601	EU	R7ICI-7	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OP2HT4601	EU	R7ICI-7	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)		§ 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
OP2HT4601	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
OP2HT4601V	EP	R5121-10	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(2) § 115.121(a)(2) § 115.122(a)(2)(B)	Vent gas affected by §115.121(a)(2) must be controlled properly with a control efficiency > 98% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None
OP2HT4601V	EP	R5121-34	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a	[G]§ 115.125 § 115.126(1) § 115.126(1)(C) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(C) § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						dry basis corrected to 3.0% oxygen for combustion devices).			
OP2LOAD	EU	R5211-1	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
OP2PV4804A	EP	R5121-42	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP2PV4804B	EP	R5121-43	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP2RX4701V	EP	R5121-17	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of §	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						115.121(a)(1).			
OP2RX4703V	EP	R5121-18	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP2SMLTK31	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
OP2SMLTK31	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117	§ 115.118(a)(5) § 115.118(a)(7)	None
OP2SU4406	EP	R5121-26	VOC	30 TAC Chapter 115, Vent Gas	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4)	A vent gas stream having a combined	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Controls	§ 115.127(a)(2)	weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).		§ 115.126(4)	
OP2SU4406	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	§ 61.357(d)(7) § 61.357(d)(7)(iv)
OP2SU4406	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP2SU4406	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)
OP2SU4406	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 61.355(i)(4)		
OP2SU4406	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP2SU4407	EP	R5121-27	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP2SU4407	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	§ 61.357(d)(7) § 61.357(d)(7)(iv)
OP2SU4407	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B)	The owner or operator shall install, operate, and maintain a fixed-	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	
OP2SU4407	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)
OP2SU4407	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	control device.	§ 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP2SU4407	EU	63G-10	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(1)	A fixed roof shall be operated and maintained except that if the wastewater tank is used for specified purpose, then owner or operator shall comply with requirements of § 63.133(a)(2).	None	None	§ 63.146(b)(2) § 63.146(b)(5) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(c)(1) § 63.152(c)(4)(ii)
OP2SU4407	EU	63G-12	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(1)	A fixed roof shall be operated and maintained except that if the wastewater tank is used for specified purpose, then owner or operator shall comply with requirements of § 63.133(a)(2).	None	None	§ 63.146(b)(2) § 63.146(b)(5) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(c)(1) § 63.152(c)(4)(ii)
OP2SU4407	EU	63YY-1	112(B)	40 CFR Part 63,	§ 63.1103	The permit holder shall	The permit holder shall	The permit holder shall	The permit holder shall

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
			HAPS	Subpart YY	The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	comply with the applicable requirements of 40 CFR Part 63, Subpart YY	comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP2SU4502	EP	R5121-29	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP2SU4502	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	§ 61.357(d)(7) § 61.357(d)(7)(iv)
OP2SU4502	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	from the tank to a control device.	§ 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	
OP2SU4502	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)
OP2SU4502	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)		[G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP2SU4502	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP2SU4671	EP	R5121-19	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C) § 115.126(1)(A)(iv)(II)	Vent gas affected by §115.121(a)(1) must be controlled properly with a control efficiency > 90% or to a VOC concentration of no more than 20 ppmv (dry, corrected to 3% O2 for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(2)	None
OP2SU4671	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h) § 61.356(j)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)			§ 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	
OP2SU4671	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)
OP2SU4671	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(g)		§ 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP2SU4671	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP2SU48094	EU	R5140-6	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) [G]§ 115.142(1)(H) [G]§ 115.148	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3)(A) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.144(3)(A) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
OP2SU48094	EU	R5131-9	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(3) § 115.131(a)	VOC water separator compartments must be equipped with a vapor recovery system which satisfies the provisions of §115.131(a) of this title.	[G]§ 115.135(a) § 115.136(a)(2) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(2) § 115.136(a)(3) § 115.136(a)(4)	None
OP2SU48094	EU	61FF-5	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 61.347(a)(1)(i)(A)	Install, operate, and maintain a fixed-roof	§ 61.347(a)(1)(i)(A) § 61.347(b)	§ 61.355(i)(1) § 61.355(i)(3)(ii)(A)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(ii) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(d) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(G) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(10) § 61.356(j)(2) § 61.356(j)(3)	
OP2SU48094	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	None
OP2SU48094	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)		§ 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP2SU48094	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	None
OP2SU48094	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.347(a)(1) § 61.347(a)(1)(i)(A) § 61.347(a)(1)(i)(B) § 61.347(b) § 61.347(c) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii)	Install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the oil-water separator to a control device.	§ 61.347(a)(1)(i)(A) § 61.347(b) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)		[G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP2SU48094	EU	63G-13	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.137(a)(1) § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.137(b)(1)(ii) § 63.137(d) § 63.137(e)(3) § 63.137(f) § 63.139(b) § 63.139(d)(4)(i) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(j)(1)	A fixed roof and a closed vent system that routes the organic hazardous air pollutants vapors vented from the oil-water separator to a control device and which meets §63.137(b).	[G]§ 63.137(e)(1) § 63.137(e)(2) § 63.137(e)(3) § 63.143(a) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) § 63.172(j)(1) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.118(a)(3) § 63.147(b) § 63.147(b)(1) § 63.147(b)(2) [G]§ 63.152(a) § 63.172(j)(1) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(c) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
OP2SU48094	EU	63G-14	112(B)	40 CFR Part 63,	§ 63.137(a)(1)	A fixed roof and a	[G]§ 63.137(e)(1)	§ 63.118(a)(3)	§ 63.146(b)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
			HAPS	Subpart G	§ 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.137(b)(1)(ii) § 63.137(d) § 63.137(e)(3) § 63.137(f) § 63.139(b) § 63.139(d)(4)(i) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) § 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(j)(1)	closed vent system that routes the organic hazardous air pollutants vapors vented from the oil-water separator to a control device and which meets §63.137(b).	§ 63.137(e)(2) § 63.137(e)(3) § 63.143(a) [G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) § 63.172(j)(1) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.147(b) § 63.147(b)(1) § 63.147(b)(2) [G]§ 63.152(a) § 63.172(j)(1) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	§ 63.146(b)(5) § 63.146(b)(6) § 63.146(c) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6) [G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
OP2SU48099	EP	R5121-25	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2) § 115.126(4)	None
OP2SU48099	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f)	§ 61.357(d)(7) § 61.357(d)(7)(iv)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	organic vapors vented from the tank to a control device.	§ 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP2SU48099	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	None
OP2SU48099	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)		§ 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	
OP2SU48099	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	None
OP2SU48099	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP2SU48601	EP	R5121-21	VOC	30 TAC Chapter 115, Vent Gas	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4)	A vent gas stream having a combined	[G]§ 115.125 § 115.126(2)	§ 115.126 § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Controls	§ 115.127(a)(2)	weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).		§ 115.126(4)	
OP2TK4451	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
OP2TK4455	EU	R5140-6	VOC	30 TAC Chapter 115, Industrial Wastewater	[G]§ 115.142(2) § 115.142 [G]§ 115.148	The wastewater component shall be equipped with a floating roof or internal floating cover which meets the requirements listed in §115.142(2)(A)-(F).	§ 115.144(2) § 115.144(2)(B) § 115.144(2)(C) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
OP2TK4455	EU	60Kb-3	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3) § 60.116b(f)(1)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP2TK4455	EU	61FF-2	BENZENE	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)
OP2TK4455	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP2TK4456	EU	R5112-10	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP2TK4458	EU	R5140-6	VOC	30 TAC Chapter 115, Industrial Wastewater	[G]§ 115.142(2) § 115.142 [G]§ 115.148	The wastewater component shall be equipped with a floating roof or internal floating cover which meets the requirements listed in §115.142(2)(A)-(F).	§ 115.144(2) § 115.144(2)(B) § 115.144(2)(C) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
OP2TK4458	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None
OP2TK4458	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)	§ 61.357(d)(7) § 61.357(d)(7)(iv)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	control device.	§ 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	
OP2TK4458	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	None
OP2TK4458	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 61.349(f) § 61.349(g)		§ 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	
OP2TK4458	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	None
OP2TK4465	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
OP2TK4465	EU	61FF-6	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(C) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	§ 61.357(d)(7) § 61.357(d)(7)(iv)
OP2TK4465	EU	61FF-7	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP2TK4465	EU	61FF-8	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(A) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(1) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv) § 61.355(i)(4)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(1) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(4)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)
OP2TK4465	EU	61FF-9	BENZENE	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(B) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(2)(i)(B) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(5) § 61.354(f)(2) [G]§ 61.355(h) § 61.355(i)(1) § 61.355(i)(2) § 61.355(i)(3)(i) § 61.355(i)(3)(ii) § 61.355(i)(3)(ii)(A) § 61.355(i)(3)(ii)(B) § 61.355(i)(3)(ii)(C) § 61.355(i)(3)(iii) § 61.355(i)(3)(iv)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(5) § 61.355(i)(1) § 61.355(i)(3)(ii)(A) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2)(i)(C) [G]§ 61.356(f)(3) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 61.355(i)(4)		
OP2TK4601	EU	R5112-9	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None
OP2TK4601	EU	R5112-9B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
OP2TK48007	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
OP2TK48007	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation,	The permit holder shall comply with the applicable requirements of 40 CFR Part 63,	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR	The permit holder shall comply with the applicable recordkeeping	The permit holder shall comply with the applicable reporting requirements of 40

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	Subpart YY	Part 63, Subpart YY	requirements of 40 CFR Part 63, Subpart YY	CFR Part 63, Subpart YY
OP2TK48008	EU	R5140-1	VOC	30 TAC Chapter 115, Industrial Wastewater	[G]§ 115.142(2) § 115.142 [G]§ 115.148	The wastewater component shall be equipped with a floating roof or internal floating cover which meets the requirements listed in §115.142(2)(A)-(F).	§ 115.144(2) § 115.144(2)(B) § 115.144(2)(C) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
OP2TK48008	EU	61FF-2	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)
OP2TK48008	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2485(a) § 63.133(a)(1) § 63.2485(b)	You must meet each requirement in Table 7 to this subpart that applies: §63.133(a)(1) - The owner or operator shall operate and maintain a fixed roof	None	None	§ 63.146(b)(2) § 63.146(b)(5) § 63.2450(q)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP2TK48008	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(1)	A fixed roof shall be operated and maintained except that if the wastewater tank is used for specified purpose, then owner or operator shall comply with requirements of § 63.133(a)(2).	None	None	§ 63.146(b)(2) § 63.146(b)(5) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(c)(1) § 63.152(c)(4)(ii)
OP2TK48008	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP2TK48009	EU	R5140-1	VOC	30 TAC Chapter 115, Industrial Wastewater	[G]§ 115.142(2) § 115.142 [G]§ 115.148	The wastewater component shall be equipped with a floating roof or internal floating cover which meets the requirements listed in §115.142(2)(A)-(F).	§ 115.144(2) § 115.144(2)(B) § 115.144(2)(C) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
OP2TK48009	EU	61FF-3	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	of the following §61.351(a)(1)-(3):			§ 61.357(e) § 61.357(f)
OP2TK48009	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2485(a) § 63.133(a)(1) § 63.2485(b)	You must meet each requirement in Table 7 to this subpart that applies: §63.133(a)(1) - The owner or operator shall operate and maintain a fixed roof	None	None	§ 63.146(b)(2) § 63.146(b)(5) § 63.2450(q)
OP2TK48009	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(1)	A fixed roof shall be operated and maintained except that if the wastewater tank is used for specified purpose, then owner or operator shall comply with requirements of § 63.133(a)(2).	None	None	§ 63.146(b)(2) § 63.146(b)(5) [G]§ 63.151(b) § 63.151(e) § 63.151(e)(1) § 63.151(e)(2) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(c)(1) § 63.152(c)(4)(ii)
OP2TK48009	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP2TK48105	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						vapor pressure less than 1.5 psia is exempt from the requirements of this division.			
OP2TK48303	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)
OP2TK48303	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP2TK4901	EU	R5112-1B	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
OP2TK4901	EU	60K-1A	VOC	40 CFR Part 60, Subpart K	§ 60.110(c) § 60.110(c)(2)	Facilities under §60.110(a) of this section with a capacity, construction or modification date as given in §60.110(c)(1) or §60.110(c)(2) are subject to the requirements of this section.	§ 60.113(a) § 60.113(b) ** See Periodic Monitoring Summary	§ 60.113(a)	None
OP2TK4901	EU	60K-1B	VOC	40 CFR Part 60, Subpart K	§ 60.110(c) § 60.110(c)(2)	Facilities under §60.110(a) of this section with a capacity, construction or modification date as given in §60.110(c)(1) or §60.110(c)(2) are subject to the requirements of this section.	§ 60.113(a) § 60.113(b)	§ 60.113(a)	None
OP2TK4901	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OP2TK4915	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
OP2TK4916	EU	R5112-4	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B) § 115.118(a)(3)
OP2TK4916	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)				§ 63.152(c)(2) § 63.152(c)(4)(ii)
OP2TK4921	EU	R5112-12	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)
OP2TK4921	EU	60K-4A	VOC	40 CFR Part 60, Subpart K	§ 60.112(a)(1)	Storage vessels holding petroleum liquids with a true vapor pressure of 78 mm Hg (1.5 psia) or greater but not greater than 570 mm Hg (11.1 psia) shall have a floating roof, a vapor recovery system, or their equivalents.	§ 60.113(a) § 60.113(b) ** See Periodic Monitoring Summary	§ 60.113(a)	None
OP2TK4921	EU	60K-4B	VOC	40 CFR Part 60, Subpart K	§ 60.110(c) § 60.110(c)(2)	Facilities under §60.110(a) of this section with a capacity, construction or modification date as given in §60.110(c)(1) or §60.110(c)(2) are	§ 60.113(a) § 60.113(b)	§ 60.113(a)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						subject to the requirements of this section.			
OP2TK4921	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2470(a)-Table4.1.b.i § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(B) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(viii) § 63.1063(a)(2)(viii)(A) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2) § 63.2470(a)	For each Group 1 storage tank for which the maximum true vapor pressure of total HAP at the storage temperature is < 76.6 kilopascals, you must comply with the requirements of Subpart WW of this part, except as specified in §63.2470.	§ 63.1063(c)(2) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d)	§ 63.1063(c)(2)(iv)(B) [G]§ 63.1066(a) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.2450(q)
OP2TK4922	EU	R5112-6	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.			
OP2TK4922	EU	60Kb-1	VOC	40 CFR Part 60, Subpart Kb	[G]§ 60.112b(a)(2)	Storage vessels specified in §60.112b(a) and equipped with an external floating roof (pontoon or double-deck type) are to meet the specifications of §60.112b(a)(2)(i)-(iii).	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) [G]§ 60.113b(b)(6) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3)	§ 60.115b [G]§ 60.115b(b)(3) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4)
OP2TK4922	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1103 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
OP2TW4616	EU	65NNN CAR	VOC	40 CFR Part 65, Subpart D	§ 60.660(a) § 60.660(b) § 60.660(d)(1) § 60.660(d)(2)	Owners or operators of process vents that are subject to NSPS subparts NNN may choose to comply with the provisions of 40 CFR part 65, subpart D, to satisfy the	None	None	§ 60.660(d)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						requirements of §§60.662 through 60.665 and 60.668.			
OP2TW4617	EU	65NNN CAR	VOC	40 CFR Part 65, Subpart D	§ 60.660(a) § 60.660(b) § 60.660(d)(1) § 60.660(d)(2)	Owners or operators of process vents that are subject to NSPS subparts NNN may choose to comply with the provisions of 40 CFR part 65, subpart D, to satisfy the requirements of §§60.662 through 60.665 and 60.668.	None	None	§ 60.660(d)(4)
PRO-ALKY	EU	63FFFF -1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2440(a) § 63.2450(a) § 63.2450(l)	This subpart applies to each miscellaneous organic chemical manufacturing affected source.	§ 63.2445(d)	§ 63.2525 § 63.2525(a) [G]§ 63.2525(b) § 63.2525(c) § 63.2525(f) § 63.2525(j)	§ 63.2435(d) § 63.2445(c) § 63.2450(g)(5) § 63.2450(m) § 63.2450(m)(1) § 63.2450(m)(2) § 63.2515(a) § 63.2515(b)(1) § 63.2515(c) § 63.2520(a) [G]§ 63.2520(b) [G]§ 63.2520(c) [G]§ 63.2520(d) § 63.2520(e) § 63.2520(e)(1) [G]§ 63.2520(e)(10) § 63.2520(e)(2) § 63.2520(e)(3) § 63.2520(e)(4) § 63.2520(e)(5) § 63.2520(e)(5)(i) [G]§ 63.2520(e)(5)(ii) [G]§ 63.2520(e)(5)(iii) § 63.2520(e)(6) § 63.2520(e)(7) § 63.2520(e)(9)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
PRO-BT	PRO	63F-1	112(B) HAPS	40 CFR Part 63, Subpart F	§ 63.100(b) [G]§ 63.102(a) [G]§ 63.102(c) § 63.104(a) [G]§ 63.104(d) § 63.104(e) § 63.104(e)(1) [G]§ 63.104(e)(2) § 63.105(d)	Except as provided in paragraphs (b)(4) and (c) of this section, the provisions of subparts F, G, and H apply to chemical manufacturing process units that meet the criteria.	§ 63.103(b)(1) § 63.103(b)(3) § 63.103(b)(4) [G]§ 63.103(b)(5) § 63.103(b)(6) [G]§ 63.104(b)	[G]§ 63.103(c) [G]§ 63.104(e)(2) [G]§ 63.104(f)(1) [G]§ 63.105(b) § 63.105(c) § 63.105(e)	§ 63.103(b)(2) [G]§ 63.103(b)(5) [G]§ 63.103(d) [G]§ 63.104(f)(2)
PRO-C4	PRO	63F-1	112(B) HAPS	40 CFR Part 63, Subpart F	§ 63.100(b) [G]§ 63.102(a) [G]§ 63.102(c) § 63.104(a) [G]§ 63.104(d) § 63.104(e) § 63.104(e)(1) [G]§ 63.104(e)(2) § 63.105(d)	Except as provided in paragraphs (b)(4) and (c) of this section, the provisions of subparts F, G, and H apply to chemical manufacturing process units that meet the criteria.	§ 63.103(b)(1) § 63.103(b)(3) § 63.103(b)(4) [G]§ 63.103(b)(5) § 63.103(b)(6) [G]§ 63.104(b)	[G]§ 63.103(c) [G]§ 63.104(e)(2) [G]§ 63.104(f)(1) [G]§ 63.105(b) § 63.105(c) § 63.105(e)	§ 63.103(b)(2) [G]§ 63.103(b)(5) [G]§ 63.103(d) [G]§ 63.104(f)(2)
PRO-C5	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2440(a) § 63.2450(a) § 63.2450(l)	This subpart applies to each miscellaneous organic chemical manufacturing affected source.	§ 63.2445(d)	§ 63.2525 § 63.2525(a) [G]§ 63.2525(b) § 63.2525(c) § 63.2525(f) § 63.2525(j)	§ 63.2435(d) § 63.2445(c) § 63.2450(g)(5) § 63.2450(m) § 63.2450(m)(1) § 63.2450(m)(2) § 63.2515(a) § 63.2515(b)(1) § 63.2515(c) § 63.2520(a) [G]§ 63.2520(b) [G]§ 63.2520(c) [G]§ 63.2520(d) § 63.2520(e) § 63.2520(e)(1) [G]§ 63.2520(e)(10) § 63.2520(e)(2) § 63.2520(e)(3) § 63.2520(e)(4) § 63.2520(e)(5) § 63.2520(e)(5)(i) [G]§ 63.2520(e)(5)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									[G]§ 63.2520(e)(5)(iii) § 63.2520(e)(6) § 63.2520(e)(7) § 63.2520(e)(9)
PRO-DPG	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2440(a) § 63.2450(a) § 63.2450(l)	This subpart applies to each miscellaneous organic chemical manufacturing affected source.	§ 63.2445(d)	§ 63.2525 § 63.2525(a) [G]§ 63.2525(b) § 63.2525(c) § 63.2525(f) § 63.2525(j)	§ 63.2435(d) § 63.2445(c) § 63.2450(g)(5) § 63.2450(m) § 63.2450(m)(1) § 63.2450(m)(2) § 63.2515(a) § 63.2515(b)(1) § 63.2515(c) § 63.2520(a) [G]§ 63.2520(b) [G]§ 63.2520(c) [G]§ 63.2520(d) § 63.2520(e) § 63.2520(e)(1) [G]§ 63.2520(e)(10) § 63.2520(e)(2) § 63.2520(e)(3) § 63.2520(e)(4) § 63.2520(e)(5) § 63.2520(e)(5)(i) [G]§ 63.2520(e)(5)(ii) [G]§ 63.2520(e)(5)(iii) § 63.2520(e)(6) § 63.2520(e)(7) § 63.2520(e)(9)
PRO-FLEX	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1100 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
PRO-IPOH	EU	63FFFF	112(B)	40 CFR Part 63,	§ 63.2440(a)	This subpart applies to	§ 63.2445(d)	§ 63.2525	§ 63.2435(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		-1	HAPS	Subpart FFFF	§ 63.2450(a) § 63.2450(l)	each miscellaneous organic chemical manufacturing affected source.		§ 63.2525(a) [G]§ 63.2525(b) § 63.2525(c) § 63.2525(f) § 63.2525(j)	§ 63.2445(c) § 63.2450(g)(5) § 63.2450(m) § 63.2450(m)(1) § 63.2450(m)(2) § 63.2515(a) § 63.2515(b)(1) § 63.2515(c) § 63.2520(a) [G]§ 63.2520(b) [G]§ 63.2520(c) [G]§ 63.2520(d) § 63.2520(e) § 63.2520(e)(1) [G]§ 63.2520(e)(10) § 63.2520(e)(2) § 63.2520(e)(3) § 63.2520(e)(4) § 63.2520(e)(5) § 63.2520(e)(5)(i) [G]§ 63.2520(e)(5)(ii) [G]§ 63.2520(e)(5)(iii) § 63.2520(e)(6) § 63.2520(e)(7) § 63.2520(e)(9)
PRO-MEO	PRO	63F-1	112(B) HAPS	40 CFR Part 63, Subpart F	§ 63.100(b) [G]§ 63.102(a) [G]§ 63.102(c) § 63.104(a) [G]§ 63.104(d) § 63.104(e) § 63.104(e)(1) [G]§ 63.104(e)(2) § 63.105(d)	Except as provided in paragraphs (b)(4) and (c) of this section, the provisions of subparts F, G, and H apply to chemical manufacturing process units that meet the criteria.	§ 63.103(b)(1) § 63.103(b)(3) § 63.103(b)(4) [G]§ 63.103(b)(5) § 63.103(b)(6) [G]§ 63.104(b)	[G]§ 63.103(c) [G]§ 63.104(e)(2) [G]§ 63.104(f)(1) [G]§ 63.105(b) § 63.105(c) § 63.105(e)	§ 63.103(b)(2) [G]§ 63.103(b)(5) [G]§ 63.103(d) [G]§ 63.104(f)(2)
PRO-MTBE	PRO	63F-1	112(B) HAPS	40 CFR Part 63, Subpart F	§ 63.100(b) [G]§ 63.102(a) [G]§ 63.102(c) § 63.104(a) [G]§ 63.104(d) § 63.104(e)	Except as provided in paragraphs (b)(4) and (c) of this section, the provisions of subparts F, G, and H apply to chemical manufacturing	§ 63.103(b)(1) § 63.103(b)(3) § 63.103(b)(4) [G]§ 63.103(b)(5) § 63.103(b)(6) [G]§ 63.104(b)	[G]§ 63.103(c) [G]§ 63.104(e)(2) [G]§ 63.104(f)(1) [G]§ 63.105(b) § 63.105(c) § 63.105(e)	§ 63.103(b)(2) [G]§ 63.103(b)(5) [G]§ 63.103(d) [G]§ 63.104(f)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.104(e)(1) [G]§ 63.104(e)(2) § 63.105(d)	process units that meet the criteria.			
PRO-OP1	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1100 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
PRO-OP2	EU	63YY-1	112(B) HAPS	40 CFR Part 63, Subpart YY	§ 63.1100 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart YY	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart YY
PRO-POLYBD	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2440(a) § 63.2450(a) § 63.2450(l) § 63.2460(c)(1)	This subpart applies to each miscellaneous organic chemical manufacturing affected source.	§ 63.2445(d) § 63.2460(c)(2)(v)	§ 63.2525 § 63.2525(a) [G]§ 63.2525(b) § 63.2525(c) § 63.2525(f) § 63.2525(j)	§ 63.2435(d) § 63.2445(c) § 63.2450(g)(5) § 63.2450(m) § 63.2450(m)(1) § 63.2450(m)(2) § 63.2460(c)(1) § 63.2515(a) § 63.2515(b)(1) § 63.2515(c) § 63.2520(a) [G]§ 63.2520(b) [G]§ 63.2520(c) [G]§ 63.2520(d) § 63.2520(e) § 63.2520(e)(1) [G]§ 63.2520(e)(10) § 63.2520(e)(2) § 63.2520(e)(3) § 63.2520(e)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 63.2520(e)(5) § 63.2520(e)(5)(i) [G]§ 63.2520(e)(5)(ii) [G]§ 63.2520(e)(5)(iii) § 63.2520(e)(6) § 63.2520(e)(7) § 63.2520(e)(9)
PRO-SMA	EU	63FFFF-1	112(B) HAPS	40 CFR Part 63, Subpart FFFF	§ 63.2440(a) § 63.2450(a) § 63.2450(l)	This subpart applies to each miscellaneous organic chemical manufacturing affected source.	§ 63.2445(d)	§ 63.2525 § 63.2525(a) [G]§ 63.2525(b) § 63.2525(c) § 63.2525(f) § 63.2525(j)	§ 63.2435(d) § 63.2445(c) § 63.2450(g)(5) § 63.2450(m) § 63.2450(m)(1) § 63.2450(m)(2) § 63.2515(a) § 63.2515(b)(1) § 63.2515(c) § 63.2520(a) [G]§ 63.2520(b) [G]§ 63.2520(c) [G]§ 63.2520(d) § 63.2520(e) § 63.2520(e)(1) [G]§ 63.2520(e)(10) § 63.2520(e)(2) § 63.2520(e)(3) § 63.2520(e)(4) § 63.2520(e)(5) § 63.2520(e)(5)(i) [G]§ 63.2520(e)(5)(ii) [G]§ 63.2520(e)(5)(iii) § 63.2520(e)(6) § 63.2520(e)(7) § 63.2520(e)(9)
WASTEWATER	EU	R5140-16A	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.147(2) [G]§ 115.142(4) [G]§ 115.148	An owner or operator may exempt from control requirements of §115.142 one or more affected VOC wastewater streams for	§ 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4)	§ 115.146(1) § 115.146(3) § 115.146(4)	[G]§ 115.142(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						which the total annual VOC loading is less than or equal to 10 Mg (11.03 tons).	§ 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148		
ZMSENAIS	EU	R71C1-1	NO_X	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(9)(E)(vii)(II) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) [G]§ 117.310(f) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO_x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(C) § 117.340(h) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(B) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
ZMSENAIS	EU	R71C1-1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B)	CO emissions must not exceed 3.0 g/hp-hr for stationary internal combustion engines.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.340(a)(2)(C) § 117.340(h) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)		§ 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
ZMSENAIS	EU	60IIII-1	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
ZMSENAIS	EU	60IIII-1	NMHC and NO_X	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 75 KW but less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 - 2013 model year must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102.	None	None	None
ZMSENAIS	EU	60IIII-1	PM	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2011 model year and later must comply with a PM emission limit of 0.02 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	[G]§ 60.4214(d)
ZMSENAIS	EU	63ZZZZ -1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1)	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
ZMSZZCOAT	PRO	R5421-1	VOC	30 TAC Chapter 115, Surface Coating Operations	§ 115.420 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 30 TAC Chapter 115, Surface Coating Operations	The permit holder shall comply with the applicable requirements of 30 TAC Chapter 115, Surface Coating Operations	The permit holder shall comply with the applicable monitoring and testing requirements of 30 TAC Chapter 115, Surface Coating Operations	The permit holder shall comply with the applicable recordkeeping requirements of 30 TAC Chapter 115, Surface Coating Operations	The permit holder shall comply with the applicable reporting requirements of 30 TAC Chapter 115, Surface Coating Operations
ZMSZZCOAT	PRO	R5421-2	VOC	30 TAC Chapter 115, Surface Coating Operations	§ 115.420 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 30 TAC Chapter 115, Surface Coating Operations	The permit holder shall comply with the applicable requirements of 30 TAC Chapter 115, Surface Coating Operations	The permit holder shall comply with the applicable monitoring and testing requirements of 30 TAC Chapter 115, Surface Coating Operations	The permit holder shall comply with the applicable recordkeeping requirements of 30 TAC Chapter 115, Surface Coating Operations	The permit holder shall comply with the applicable reporting requirements of 30 TAC Chapter 115, Surface Coating Operations
ZMSZZCOAT	PRO	R5421-3	VOC	30 TAC Chapter 115, Surface Coating Operations	§ 115.420 The permit holder shall comply with the applicable limitation, standard and/or equipment specification	The permit holder shall comply with the applicable requirements of 30 TAC Chapter 115, Surface Coating Operations	The permit holder shall comply with the applicable monitoring and testing requirements of 30 TAC Chapter 115, Surface Coating Operations	The permit holder shall comply with the applicable recordkeeping requirements of 30 TAC Chapter 115,	The permit holder shall comply with the applicable reporting requirements of 30 TAC Chapter 115, Surface Coating

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					requirements of 30 TAC Chapter 115, Surface Coating Operations			Surface Coating Operations	Operations

Additional Monitoring Requirements

Compliance Assurance Monitoring Summary **585**

Periodic Monitoring Summary **586**

CAM Summary

Unit/Group/Process Information	
ID No.: GRPLDBGDK	
Control Device ID No.: EBGVC6904	Control Device Type: Vapor Combustor
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Loading and Unloading of VOC	SOP Index No.: R5211-2
Pollutant: VOC	Main Standard: § 115.212(a)(6)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Once per day	
Averaging Period: N/A	
Deviation Limit: The presence of visible emissions is a deviation unless visible emissions are determined consistent with Test Method 22 or Test Method 9 and found in compliance with 30 TAC 111.111(a)(4)(A).	
CAM Text: Operator training and procedures are in place to conduct the daily visible emission check. Operation logs are reviewed periodically to verify completion of task at least 98% of the time. Presence of Visible Emissions Visible Emission observations shall be made and recorded in the operation log. A daily notation in the log should include the time of day and whether or not there were visible emissions. The operator shall record at least 98% of these required observations.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: EALSP4066	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per quarter	
Averaging Period: n/a	
Deviation Limit: The presence of any visible emissions shall be considered a deviation unless a Method 9 observation is performed. If a Method 9 observation is performed, then the deviation limit shall be 30% opacity.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If a Test Method 9 is performed, the opacity limit is the corresponding opacity limit associated with the particulate matter standard in the underlying applicable requirement. If there is no corresponding opacity limit in the underlying applicable requirement, the maximum opacity will be established using the most recent performance test. If the result of the Test Method 9 is opacity above the corresponding opacity limit (associated with the particulate matter standard in the underlying applicable requirement or as identified as a result of a previous performance test to establish the maximum opacity limit), the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: EC4HT1202	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-6
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: n/a	
Deviation Limit: Visible emissions.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: EC4TO	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: n/a	
Deviation Limit: The presence of any visible emissions shall be considered a deviation unless a Method 9 observation is performed. If a Method 9 observation is performed, then the deviation limit shall be 20% opacity.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: EC5SP334	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per quarter	
Averaging Period: n/a	
Deviation Limit: The presence of any visible emissions shall be considered a deviation unless a Method 9 observation is performed. If a Method 9 observation is performed, then the deviation limit shall be 30% opacity.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If a Test Method 9 is performed, the opacity limit is the corresponding opacity limit associated with the particulate matter standard in the underlying applicable requirement. If there is no corresponding opacity limit in the underlying applicable requirement, the maximum opacity will be established using the most recent performance test. If the result of the Test Method 9 is opacity above the corresponding opacity limit (associated with the particulate matter standard in the underlying applicable requirement or as identified as a result of a previous performance test to establish the maximum opacity limit), the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: EC5SP349	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per quarter	
Averaging Period: n/a	
Deviation Limit: The presence of any visible emissions shall be considered a deviation unless a Method 9 observation is performed. If a Method 9 observation is performed, then the deviation limit shall be 30% opacity.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If a Test Method 9 is performed, the opacity limit is the corresponding opacity limit associated with the particulate matter standard in the underlying applicable requirement. If there is no corresponding opacity limit in the underlying applicable requirement, the maximum opacity will be established using the most recent performance test. If the result of the Test Method 9 is opacity above the corresponding opacity limit (associated with the particulate matter standard in the underlying applicable requirement or as identified as a result of a previous performance test to establish the maximum opacity limit), the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: EC5TK36	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-5
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Fill pipe not integral and not repaired before refill is a deviation.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: EC5TK36	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-5
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Liquid Level	
Minimum Frequency: Once per day	
Averaging Period: n/a	
Deviation Limit: Fill pipe not submerged in liquid is a deviation.	
Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Monitor and record the depth of the liquid using an automated/remote sounding device or liquid level sensing alarm/monitor. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPBOILER	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60D-1A
Pollutant: PM	Main Standard: § 60.42(a)(1)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Once per week	
Averaging Period: n/a	
Deviation Limit: The presence of any visible emissions shall be considered a deviation unless a method 9 observation is performed. If a Method 9 observation is performed, then the deviation limit shall be 15% opacity.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is an opacity above the corresponding opacity limit, the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPLIQFURN	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-5
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Once per week	
Averaging Period: n/a	
Deviation Limit: The presence of any visible emissions shall be considered a deviation unless a Method 9 observation is performed. If a Method 9 observation is performed, then the deviation limit shall be 15% opacity.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is an opacity above the corresponding opacity limit, the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPOLFUR2V	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Once per week	
Averaging Period: n/a	
Deviation Limit: Visible emissions opacity reading greater than 15%.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is an opacity above the corresponding opacity limit, the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPOLFURN	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-3
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Once per week	
Averaging Period: n/a	
Deviation Limit: The presence of any visible emissions shall be considered a deviation unless a Method 9 observation is performed. If a Method 9 observation is performed, then the deviation limit shall be 15% opacity.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is an opacity above the corresponding opacity limit, the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPOLSUHT	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-4
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Once per week	
Averaging Period: n/a	
Deviation Limit: The presence of any visible emissions shall be considered a deviation unless a Method 9 observation is performed. If a Method 9 observation is performed, then the deviation limit shall be 15% opacity.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is an opacity above the corresponding opacity limit, the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPOLTKIFR	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart K	SOP Index No.: 60K-3A
Pollutant: VOC	Main Standard: § 60.112(a)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed.	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure the roof is floating on the surface of the VOC and not on the leg supports, liquid has not accumulated on the floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed as specified in 40 CFR 63.1063 shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPOP1TK1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart K	SOP Index No.: 60K-1A
Pollutant: VOC	Main Standard: § 60.112(a)(1)
Monitoring Information	
Indicator: External Floating Roof	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed.	
Periodic Monitoring Text: Visually inspect and record the inspection of the floating roof to ensure the roof is floating on the surface of the VOC and not on the leg supports, liquid has not accumulated on the floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed as specified in 40 CFR 63.1063 shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPOP2TK1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart K	SOP Index No.: 60K-2A
Pollutant: VOC	Main Standard: § 60.112(a)(1)
Monitoring Information	
Indicator: External Floating Roof	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed.	
Periodic Monitoring Text: Visually inspect and record the inspection of the floating roof to ensure the roof is floating on the surface of the VOC and not on the leg supports, liquid has not accumulated on the floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed as specified in 40 CFR 63.1063 shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPSMAPMV	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per quarter	
Averaging Period: n/a	
Deviation Limit: The presence of any visible emissions shall be considered a deviation unless a Method 9 observation is performed. If a Method 9 observation is performed, then the deviation limit shall be 30% opacity.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If a Test Method 9 is performed, the opacity limit is the corresponding opacity limit associated with the particulate matter standard in the underlying applicable requirement. If there is no corresponding opacity limit in the underlying applicable requirement, the maximum opacity will be established using the most recent performance test. If the result of the Test Method 9 is opacity above the corresponding opacity limit (associated with the particulate matter standard in the underlying applicable requirement or as identified as a result of a previous performance test to establish the maximum opacity limit), the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: MEOHT7001V	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Once per week	
Averaging Period: n/a	
Deviation Limit: Visible emissions opacity reading greater than 15%.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is an opacity above the corresponding opacity limit, the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: MIPTK3110	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-4
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Fill pipe not integral and not repaired before refill is a deviation.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: MIPTK3110	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-4
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Liquid Level	
Minimum Frequency: Once per day	
Averaging Period: n/a	
Deviation Limit: Fill pipe not submerged in liquid is a deviation.	
Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Monitor and record the depth of the liquid using an automated/remote sounding device or liquid level sensing alarm/monitor. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: MPBDM3219	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per quarter	
Averaging Period: n/a	
Deviation Limit: The presence of any visible emissions shall be considered a deviation unless a Method 9 observation is performed. If a Method 9 observation is performed, then the deviation limit shall be 30% opacity.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If a Test Method 9 is performed, the opacity limit is the corresponding opacity limit associated with the particulate matter standard in the underlying applicable requirement. If there is no corresponding opacity limit in the underlying applicable requirement, the maximum opacity will be established using the most recent performance test. If the result of the Test Method 9 is opacity above the corresponding opacity limit (associated with the particulate matter standard in the underlying applicable requirement or as identified as a result of a previous performance test to establish the maximum opacity limit), the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: MPBDM3219	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Fill pipe not integral and not repaired before refill is a deviation.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: MPBDM3219	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Liquid Level	
Minimum Frequency: Once per day	
Averaging Period: n/a	
Deviation Limit: Fill pipe not submerged in liquid is a deviation.	
Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Monitor and record the depth of the liquid using an automated/remote sounding device or liquid level sensing alarm/monitor. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: MPBTK3210	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Fill pipe not integral and not repaired before refill is a deviation.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: MPBTK3210	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Liquid Level	
Minimum Frequency: Once per day	
Averaging Period: n/a	
Deviation Limit: Fill pipe not submerged in liquid is a deviation.	
Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Monitor and record the depth of the liquid using an automated/remote sounding device or liquid level sensing alarm/monitor. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: MPBTK3226	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per quarter	
Averaging Period: n/a	
Deviation Limit: The presence of any visible emissions shall be considered a deviation unless a Method 9 observation is performed. If a Method 9 observation is performed, then the deviation limit shall be 30% opacity.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If a Test Method 9 is performed, the opacity limit is the corresponding opacity limit associated with the particulate matter standard in the underlying applicable requirement. If there is no corresponding opacity limit in the underlying applicable requirement, the maximum opacity will be established using the most recent performance test. If the result of the Test Method 9 is opacity above the corresponding opacity limit (associated with the particulate matter standard in the underlying applicable requirement or as identified as a result of a previous performance test to establish the maximum opacity limit), the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OFXDM4310	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Fill pipe not integral and not repaired before refill is a deviation.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OFXDM4310	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Liquid Level	
Minimum Frequency: Once per day	
Averaging Period: n/a	
Deviation Limit: Fill pipe not submerged in liquid is a deviation.	
Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Monitor and record the depth of the liquid using an automated/remote sounding device or liquid level sensing alarm/monitor. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OFXDM4311	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Fill pipe not integral and not repaired before refill is a deviation.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OFXDM4311	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Liquid Level	
Minimum Frequency: Once per day	
Averaging Period: n/a	
Deviation Limit: Fill pipe not submerged in liquid is a deviation.	
Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Monitor and record the depth of the liquid using an automated/remote sounding device or liquid level sensing alarm/monitor. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP1HT3415	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-5
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Once per week	
Averaging Period: n/a	
Deviation Limit: The presence of any visible emissions shall be considered a deviation unless a Method 9 observation is performed. If a Method 9 observation is performed, then the deviation limit shall be 15% opacity.	
Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is an opacity above the corresponding opacity limit, the permit holder shall report a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP1TK3601	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-6
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Fill pipe not integral and not repaired before refill is a deviation.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP1TK3601	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-6
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Liquid Level	
Minimum Frequency: Once per day	
Averaging Period: n/a	
Deviation Limit: Fill pipe not submerged in liquid is a deviation.	
Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Monitor and record the depth of the liquid using an automated/remote sounding device or liquid level sensing alarm/monitor. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP1TK3911	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart K	SOP Index No.: 60K-4
Pollutant: VOC	Main Standard: § 60.112(a)(1)
Monitoring Information	
Indicator: External Floating Roof	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed.	
Periodic Monitoring Text: Visually inspect and record the inspection of the floating roof to ensure the roof is floating on the surface of the VOC and not on the leg supports, liquid has not accumulated on the floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed as specified in 40 CFR 63.1063 shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP1TK3912	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart K	SOP Index No.: 60K-5
Pollutant: VOC	Main Standard: § 60.112(a)(1)
Monitoring Information	
Indicator: External Floating Roof	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed as specified.	
Periodic Monitoring Text: Visually inspect and record the inspection of the floating roof to ensure the roof is floating on the surface of the VOC and not on the leg supports, liquid has not accumulated on the floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed as specified in 40 CFR 63.1063 shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP2TK4456	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-10
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Fill pipe not integral and not repaired before refill is a deviation.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP2TK4456	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-10
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Liquid Level	
Minimum Frequency: Once per day	
Averaging Period: n/a	
Deviation Limit: Fill pipe not submerged in liquid is a deviation.	
Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Monitor and record the depth of the liquid using an automated/remote sounding device or liquid level sensing alarm/monitor. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP2TK4458	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Fill pipe not integral and not repaired before refill is a deviation.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP2TK4458	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Liquid Level	
Minimum Frequency: Once per day	
Averaging Period: n/a	
Deviation Limit: Fill pipe not submerged in liquid is a deviation.	
Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Monitor and record the depth of the liquid using an automated/remote sounding device or liquid level sensing alarm/monitor. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP2TK4465	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: Fill pipe not integral and not repaired before refill is a deviation.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP2TK4465	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-1
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Liquid Level	
Minimum Frequency: Once per day	
Averaging Period: n/a	
Deviation Limit: Fill pipe not submerged in liquid is a deviation.	
Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Monitor and record the depth of the liquid using an automated/remote sounding device or liquid level sensing alarm/monitor. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP2TK4601	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-9
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: n/a	
Deviation Limit: It is a deviation if the fill pipe is damaged and not repaired.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP2TK4601	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-9
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Liquid Level	
Minimum Frequency: Once per day	
Averaging Period: n/a	
Deviation Limit: Fill pipe not submerged in liquid is a deviation.	
Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Monitor and record the depth of the liquid using an automated/remote sounding device or liquid level sensing alarm/monitor. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP2TK4901	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart K	SOP Index No.: 60K-1A
Pollutant: VOC	Main Standard: § 60.110(c)
Monitoring Information	
Indicator: External Floating Roof	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed.	
Periodic Monitoring Text: Visually inspect and record the inspection of the floating roof to ensure the roof is floating on the surface of the VOC and not on the leg supports, liquid has not accumulated on the floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed as specified in 40 CFR 63.1063 shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: OP2TK4921	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart K	SOP Index No.: 60K-4A
Pollutant: VOC	Main Standard: § 60.112(a)(1)
Monitoring Information	
Indicator: External Floating Roof	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed as specified.	
Periodic Monitoring Text: Visually inspect and record the inspection of the floating roof to ensure the roof is floating on the surface of the VOC and not on the leg supports, liquid has not accumulated on the floating roof., the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the floating roof, the seals are detached, or if there are holes or tears in the seal fabric and repairs are not completed as specified in 40CFR 63.1063 shall be considered and reported as a deviation.	

Permit Shield

Permit Shield **631**

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
EALTK17	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
EALTK32	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
EALTK37	N/A	40 CFR Part 60, Subpart Kb	HON Group 1 storage vessel also subject to 40 CFR 60 Subpart Kb is only required to comply with the requirements of HON.
EALTK7	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
EALTK8	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
EALTW312	N/A	40 CFR Part 60, Subpart NNN	The affected process does not produce any of the chemicals listed in 60.667 as a product, by-product or intermediate.
EALTW410	N/A	40 CFR Part 60, Subpart NNN	The affected process does not produce any of the chemicals listed in 60.667 as a product, by-product or intermediate.
EBGTK6901	N/A	40 CFR Part 60, Subpart Kb	Vessel capacity is less than 75 cubic meters (19,800 gal).

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
EBGTK6902	N/A	40 CFR Part 60, Subpart Kb	Vessel capacity is less than 75 cubic meters (19,800 gal).
EBGTK6902	N/A	40 CFR Part 61, Subpart FF	The storage vessel does not store benzene-containing hazardous waste.
EBGTK6904	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
EBGTK6905	N/A	40 CFR Part 60, Subpart Kb	Vessel constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K and Ka.
EBGTK6905	N/A	40 CFR Part 61, Subpart FF	The storage vessel does not store benzene-containing hazardous waste.
EC4DM21	N/A	40 CFR Part 60, Subpart Kb	HON tank not subject to NSPS Kb applicability.
EC4DM3075	N/A	40 CFR Part 60, Subpart Kb	HON tank not subject to NSPS Kb applicability.
EC4RX1208	N/A	40 CFR Part 63, Subpart F	This vent is not a continuous vent stream and therefore does not meet the 63.101 definition of process vent.
EC4TK3941	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not subject to NSPS Subpart K or Ka.
EC4TK3942	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not subject to NSPS Subpart K or Ka.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
EC4TW1202	N/A	40 CFR Part 60, Subpart NNN	Distillation unit was constructed before 12/30/1983 without reconstruction or modification after 12/30/1983.
EC4TW1204	N/A	40 CFR Part 60, Subpart NNN	Distillation unit was constructed before 12/30/1983 without reconstruction or modification after 12/30/1983.
EC4TW301	N/A	40 CFR Part 60, Subpart NNN	Distillation unit was constructed before 12/30/1983 without reconstruction or modification after 12/30/1983.
EC4TW3011	N/A	40 CFR Part 60, Subpart NNN	Tower has no associated vent stream other than potential releases from relief valves, which are excluded from the definition of “vent stream.”
EC5DM56	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
EC5RXD301	N/A	40 CFR Part 60, Subpart RRR	This reactor was constructed prior to 6/23/1990 without reconstruction or modification after 6/23/1990.
EC5RXD3037	N/A	40 CFR Part 60, Subpart RRR	This reactor was constructed prior to 6/23/1990 without reconstruction or modification after 6/23/1990.
EC5TK21	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
EC5TK27	N/A	40 CFR Part 60, Subpart Kb	Vessel is not subject to NSPS Kb because capacity > 40,000 gal and vapor pressure < 0.5 psia.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
EC5TK30	N/A	40 CFR Part 60, Subpart Kb	Vessel is not subject to NSPS Kb because capacity > 40,000 gal and vapor pressure < 0.5 psia.
EC5TK31	N/A	40 CFR Part 60, Subpart Kb	Vessel is not subject to NSPS Kb because capacity > 40,000 gal and vapor pressure < 0.5 psia.
EC5TK3116	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
EC5TK317	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
EC5TK36	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
EC5TW3009	N/A	40 CFR Part 60, Subpart NNN	Separation is achieved using liquid/liquid phases. This column does not perform a distillation operation as defined in 40 CFR 60 Subpart NNN.
EC5TW314	N/A	40 CFR Part 60, Subpart NNN	Separation is achieved using liquid/liquid phases. This column does not perform a distillation operation as defined in 40 CFR 60 Subpart NNN.
ECUCT1701A	N/A	40 CFR Part 63, Subpart Q	Chromium-based water treatment chemicals have not been used on or after September 8, 1994.
ECUCT1701B	N/A	40 CFR Part 63, Subpart Q	Chromium-based water treatment chemicals have not been used on or after September 8, 1994.
ECUCT604	N/A	40 CFR Part 63, Subpart Q	Chromium based water treatment chemicals have not been used on or after September 8, 1994.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
ECUDM3301	N/A	30 TAC Chapter 115, Storage of VOCs	Tank is located at a motor vehicle fuel dispensing facility with a capacity less than 25,000 gallons.
ECUDM3301	N/A	40 CFR Part 60, Subpart Kb	Storage vessel is located at a gasoline service station.
ECUDM3302	N/A	30 TAC Chapter 115, Storage of VOCs	Tank is located at a motor vehicle fuel dispensing facility with a capacity less than 25,000 gallons.
ECUDM3302	N/A	40 CFR Part 60, Subpart Kb	Storage vessel is located at a gasoline service station.
ECULRVOC	N/A	40 CFR Part 63, Subpart FFFF	Transfer rack does not load a HAP.
ECULRVOC	N/A	40 CFR Part 63, Subpart G	Transfer rack is not part of a HON CMPU.
ECULTNOHAP	N/A	40 CFR Part 63, Subpart G	Not subject to 40 CFR 63 Subpart F - transfer rack is not a HON Group 1 or Group 2 transfer rack.
ECULTVOC	N/A	40 CFR Part 63, Subpart FFFF	Transfer rack does not load a HAP.
ECULTVOC	N/A	40 CFR Part 63, Subpart G	Transfer rack is not part of a HON CMPU.
EMTTK12	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
EMTTK18	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
EMTTK19	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
			NSPS Subpart K or Ka.
EMTTK26	N/A	40 CFR Part 60, Subpart Kb	HON Group 1 storage vessel also subject to 40 CFR 60 Subpart Kb is only required to comply with the requirements of HON.
EMTTK4	N/A	40 CFR Part 60, Subpart Kb	HON Group 1 storage vessel also subject to 40 CFR 60 Subpart Kb is only required to comply with the requirements of HON.
EMTTK47	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
EMTTK5	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
GRPALREACT	EALRX402, EALRX403, EALRX404, EALRX405, EALRX467, EALRX468	40 CFR Part 60, Subpart RRR	These reactors are not part of a process unit that produces a SOCMI chemical as a product, co-product or by-product.
GRPBOILER	OP1BL3803A, OP1BL3803B, OP2BL4803A, OP2BL4803B	30 TAC Chapter 112, Sulfur Compounds	Only fired with gaseous fuels: no solid or liquid fuels.
GRPBTBZTK	MBTTK3111A, MBTTK3111B	40 CFR Part 60, Subpart Kb	HON Group 1 storage vessel also subject to 40 CFR 60 Subpart Kb is only required to comply with the requirements of HON.
GRPBTBZTK	MBTTK3111A, MBTTK3111B	40 CFR Part 61, Subpart Y	Compliance with 40 CFR 63, Subpart G shall be deemed to constitute compliance with 40 CFR 61, Subpart Y.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
GRPC4MTTK1	EC4TK11, EC4TK14, EC4TK16, EC4TK20, EC4TK3, EC4TK41, EC4TK42, EC4TK43, EC4TK44, EC4TK6, EMTTK1, EMTTK10, EMTTK2, EMTTK9	40 CFR Part 60, Subpart Kb	HON tank not subject to NSPS Kb applicability.
GRPC4REACT	EC4RX1201A, EC4RX1201B, EC4RX1201C, EC4RX1201D, EC4RX309A, EC4RX309B, EC4RX309C	40 CFR Part 60, Subpart RRR	This reactor was constructed prior to 6/23/1990 without reconstruction or modification after 6/23/1990.
GRPC4TWR1	EC4TW1205, EC4TW1207, EC4TW3013, EC4TW3014, EC4TW3016, EC4TW3017, EC4TW3018, EC4TW3019, EC4TW303	40 CFR Part 60, Subpart NNN	A Group 1 process vent subject to 40 CFR 60 NNN is required to comply only with the provisions of the HON.
GRPC4TWR2	EC4TW3015, EC4TW317, EC4TW318, EC4TW319	40 CFR Part 60, Subpart NNN	Separation is achieved using liquid/liquid phases. This column does not perform a distillation operation as defined in 40 CFR 60 Subpart NNN.
GRPC4VENT1	EC4RX1201, EC4RX309	40 CFR Part 63, Subpart F	This vent is not a continuous vent stream and therefore does not meet the 63.101 definition of process vent.
GRPC5TK1	EC5TK13, EC5TK28, EC5TK29	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
GRPC5TK2	EC5DM12, EC5DM14, EC5DM304	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
GRPC5TWR	EC5TW1201, EC5TW3005, EC5TW3006, EC5TW3010, EC5TW305, EC5TW308, EC5TW309, EC5TW310, EC5TW313,	40 CFR Part 60, Subpart NNN	Distillation unit was constructed before 12/30/1983 without reconstruction or modification after 12/30/1983

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
	EC5TW315		
GRPLIQFURN	OP1HT3411, OP1HT3412	40 CFR Part 60, Subpart RRR	Reactors were constructed prior to 6/29/1990 without reconstruction or modification after 6/29/1990.
GRPMEOTK	MEOTK3122, MEOTK5101, MEOTK5102	40 CFR Part 60, Subpart Kb	HON Group 1 storage vessel also subject to 40 CFR 60 Subpart Kb is only required to comply with the requirements of HON.
GRPMTRXR1	EMTRX1202A, EMTRX1202B, EMTRX1202C, EMTRX1204, EMTRX4201A, EMTRX4201B, EMTRX4202A, EMTRX4202B	40 CFR Part 60, Subpart RRR	Reactor has no associated vent stream other than potential releases from relief valves, which are excluded from the definition of “vent stream” under NSPS RRR, as well as HON.
GRPMTRXR2	EMTRX1202D, EMTRX1203	40 CFR Part 60, Subpart RRR	HON Group 1 streams also subject to the provisions of NSPS RRR are required only to comply with the provisions of HON.
GRPMTTK1	MBTTK3101, MBTTK3102	40 CFR Part 60, Subpart Kb	HON Group 1 storage vessel also subject to 40 CFR 60 Subpart Kb is only required to comply with the requirements of HON.
GRPMTTK2	EMTTK48, EMTTK49	40 CFR Part 60, Subpart Kb	HON Group 1 storage vessel also subject to 40 CFR 60 Subpart Kb is only required to comply with the requirements of HON.
GRPMTTWR	EMTTW1208, EMTTW4201, EMTTW4202, EMTTW4205, EMTTW4206	40 CFR Part 60, Subpart NNN	HON Group 1 streams also subject to the provisions of NSPS NNN are required only to comply with the provisions of HON.
GRPMTWR2	EMTTW1215, EMTTW1216, EMTTW4203, EMTTW4207	40 CFR Part 60, Subpart NNN	HON Group 1 streams also subject to the provisions of NSPS NNN are required only to comply with the provisions of HON.
GRPNONAFF	ECUTK1708, ECUTK1709A, ECUTK1709B,	30 TAC Chapter 115, Storage of	The wastewater streams are not considered affected

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
	ECUTK1713, ECUTK1714, ECUTK1715, ECUTK1716, ECUTK1717, ECUTK1718, ECUTK1719, ECUTK1720, ECUTK1721, ECUTK1722, ECUTK1723, ECUTK1724, ECUTK1725, ECUTK1726, ECUTK1729, ECUTK1730, ECUTK1731, ECUTK1732, ECUTK1733, ECUTK1734, ECUTK1735, ECUTK1736, ECUTK1739, ECUTK1740A, ECUTK1740B, ECUTK1750, ECUTK1759, ECUTK2612, ECUTK2613, ECUTKPOND1, ECUTKPOND2	VOCs	VOC wastewater streams since all streams either have a VOC concentration <10,000 ppm and a flow rate less than 2.64 gpm, or have a VOC concentration <1,000 ppm at any flow rate.
GRPOLFUR2	OP1HT3419, OP2HT4419	40 CFR Part 63, Subpart DDDDD	Furnaces are ethylene cracking furnaces regulated by MACT YY.
GRPOLFURN	OP1HT3401, OP1HT3402, OP1HT3403, OP1HT3404, OP1HT3405, OP1HT3406, OP1HT3407, OP1HT3408, OP1HT3409, OP1HT3410, OP1HT3413, OP1HT3414, OP1HT3418, OP2HT4401, OP2HT4402, OP2HT4403, OP2HT4404, OP2HT4405, OP2HT4406, OP2HT4407, OP2HT4408, OP2HT4409, OP2HT4410, OP2HT4411, OP2HT4412, OP2HT4413, OP2HT4414, OP2HT4415, OP2HT4418	40 CFR Part 60, Subpart RRR	Reactors were constructed prior to 6/29/1990 without reconstruction or modification after 6/29/1990.
GRPOLFURN	OP1HT3401, OP1HT3402, OP1HT3403, OP1HT3404, OP1HT3405, OP1HT3406, OP1HT3407, OP1HT3408, OP1HT3409, OP1HT3410, OP1HT3413, OP1HT3414, OP1HT3418, OP2HT4401, OP2HT4402, OP2HT4403, OP2HT4404, OP2HT4405,	40 CFR Part 63, Subpart DDDDD	Furnaces are ethylene cracking furnaces regulated by MACT YY.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
	OP2HT4406, OP2HT4407, OP2HT4408, OP2HT4409, OP2HT4410, OP2HT4411, OP2HT4412, OP2HT4413, OP2HT4414, OP2HT4415, OP2HT4418		
GRPOLREACT	OFXRXD4320, OFXRXD4352, OFXRXD4360, OP1RXD3601, OP1RXD3626, OP1RXD3635, OP1RXD3652, OP1RXD3701, OP1RXD3702, OP2RX4701, OP2RX4703, OP2RXD4601, OP2RXD4626, OP2RXD4635, OP2RXD4652	40 CFR Part 60, Subpart RRR	Reactors were constructed prior to 6/29/1990 without reconstruction or modification after 6/29/1990.
GRPOLSUHT	OP1HT3804A, OP1HT3804B, OP2HT4804A, OP2HT4804B	30 TAC Chapter 112, Sulfur Compounds	Only fired with gaseous fuels: no solid or liquid fuels.
GRPOLTKHVY	OP1TK38301, OP1TK38302, OP1TK3913, OP1TK3914, OP2TK48302, OP2TK48304, OP2TK48305	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
GRPOP1TK5	OP1DM3530, OP1SMLTK03, OP1SMLTK04, OP1SMLTK07, OP1SMLTK13, OP1SMLTK15, OP1SMLTK16, OP1SMLTK17, OP1SMLTK18, OP1TK3462, OP1TK3504X, OP1TK3602X, OP1TK3604X, OP1TK3609, OP1TK3701, OP1TK3701X	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
GRPOP1TWR	OP1DM3609, OP1TW3401, OP1TW3402, OP1TW3403, OP1TW3405, OP1TW3450, OP1TW3502, OP1TW3504, OP1TW3507, OP1TW35203, OP1TW3601, OP1TW3602, OP1TW3604, OP1TW3605, OP1TW3606, OP1TW3608, OP1TW3614, OP1TW3615, OP1TW3618, OP1TW3701, OP1TW3702	40 CFR Part 60, Subpart NNN	Distillation unit was constructed before 12/30/1983 without reconstruction or modification after 12/30/1983.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
GRPOP2TK2	OP2TK4917, OP2TK4919	40 CFR Part 60, Subpart Kb	HON tank not subject to NSPS Kb applicability.
GRPOP2TK5	OP2SMLTK08, OP2SMLTK10, OP2SMLTK12, OP2SMLTK13, OP2SMLTK16, OP2SMLTK17, OP2TK4462, OP2TK4504X, OP2TK4511, OP2TK4602X, OP2TK4604X, OP2TK4607, OP2TK48616	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
GRPOP2TK7	OP2SMLTK01, OP2SMLTK02, OP2SMLTK04, OP2TK48620	30 TAC Chapter 115, Storage of VOCs	Vessel has a capacity less than 1,000 gallons.
GRPOP2TK7	OP2SMLTK01, OP2SMLTK02, OP2SMLTK04, OP2TK48620	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
GRPOP2TWR1	OP2DM4609, OP2DM4643, OP2TW4403, OP2TW4502, OP2TW4504, OP2TW4601, OP2TW4602, OP2TW4604, OP2TW4605, OP2TW4606, OP2TW4608A, OP2TW4608B, OP2TW4618, OP2TW4701	40 CFR Part 60, Subpart NNN	Distillation unit was constructed before 12/30/1983 without reconstruction or modification after 12/30/1983.
GRPOP2TWR2	OFXTW4340, OFXTW4340C, OFXTW4370, OFXTW4370C, OFXTW4371C, OP2TW4401, OP2TW4402, OP2TW4405, OP2TW4450, OP2TW4507, OP2TW45203, OP2TW4609, OP2TW4610, OP2TW4614, OP2TW4615	40 CFR Part 60, Subpart NNN	Vessel has no associated vent stream other than potential releases from relief valves, which are excluded from the definition of “vent stream.”
GRPPBDTWR	MPBDM3207, MPBTW3201, MPBTW3203, MPBTW3204	40 CFR Part 60, Subpart NNN	The process unit in which this facility is located does not produce any of the chemicals listed in 60.667 as a product, co-product, by-product, or intermediate.
GRPRX3201	MPBRX3201A, MPBRX3201B, MPBRX3201C, MPBRX3201D, MPBRX3201E	40 CFR Part 60, Subpart RRR	The process unit in which this facility is located does not produce any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
GRPSMLTANK	EALSMLTK01, EALSMLTK02, EALSMLTK03, EALSMLTK04, EALSMLTK06, EC4SMLTK01, EC4SMLTK02, EC4SMLTK03, EC4SMLTK04, EC4SMLTK13, EC5SMLTK01, ECUSMLTK15, ECUSMLTK16, ECUSMLTK17, ECUSMLTK18, ECUSMLTK19, ECUSMLTK20, ECUSMLTK22, ECUSMLTK23, ECUSMLTK26, EMTSMLTK01, EMTSMLTK02, MBTSMLTK02, MBTSMLTK03, MEOSMLTK03, MEOSMLTK04, MEOSMLTK05, MEOSMLTK06, MEOSMLTK07, MPBDM3223, MPBTK3201, MPBTK3202A, MPBTK3202B, MSMDM2805, MSMDM2814, MSMTK2804A, MSMTK2804B, OP1SMLTK12, OP1SMLTK19, OP2SMLTK03, OP2SMLTK05, OP2SMLTK15, OP2TK48615	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 40 cubic meters (10,560 gallons).
GRPSMLTANK	EALSMLTK01, EALSMLTK02, EALSMLTK03, EALSMLTK04, EALSMLTK06, EC4SMLTK01, EC4SMLTK02, EC4SMLTK03, EC4SMLTK04, EC4SMLTK13, EC5SMLTK01, ECUSMLTK15, ECUSMLTK16, ECUSMLTK17, ECUSMLTK18, ECUSMLTK19, ECUSMLTK20, ECUSMLTK22, ECUSMLTK23, ECUSMLTK26, EMTSMLTK01, EMTSMLTK02, MBTSMLTK02, MBTSMLTK03, MEOSMLTK03, MEOSMLTK04, MEOSMLTK05, MEOSMLTK06, MEOSMLTK07, MPBDM3223, MPBTK3201, MPBTK3202A, MPBTK3202B, MSMDM2805, MSMDM2814, MSMTK2804A, MSMTK2804B, OP1SMLTK12, OP1SMLTK19, OP2SMLTK03, OP2SMLTK05, OP2SMLTK15, OP2TK48615	40 CFR Part 63, Subpart F	Tank does not meet the MACT F definition of a storage tank because capacity is less than 38 cubic meters (10,040 gal).

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
GRPTKNOAPP	EALSMLTK05, EC4SMLTK05, EC4SMLTK09, EC4SMLTK14, ECUSMLTK03, ECUSMLTK24, ECUSMLTK25, ECUSMLTK29, ECUSMLTK30, MBTDM4043, MEOTK7017X, MEOTK7018X, MPBSMLTK01, MPBSMLTK02, MSMTK2824, OP1SMLTK01, OP1SMLTK02	30 TAC Chapter 115, Storage of VOCs	Vessel has a capacity less than 1,000 gal.
GRPTKNOAPP	EALSMLTK05, EC4SMLTK05, EC4SMLTK09, EC4SMLTK14, ECUSMLTK03, ECUSMLTK24, ECUSMLTK25, ECUSMLTK29, ECUSMLTK30, MBTDM4043, MEOTK7017X, MEOTK7018X, MPBSMLTK01, MPBSMLTK02, MSMTK2824, OP1SMLTK01, OP1SMLTK02	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (10,560 gallons).
GRPTKNOAPP	EALSMLTK05, EC4SMLTK05, EC4SMLTK09, EC4SMLTK14, ECUSMLTK03, ECUSMLTK24, ECUSMLTK25, ECUSMLTK29, ECUSMLTK30, MBTDM4043, MEOTK7017X, MEOTK7018X, MPBSMLTK01, MPBSMLTK02, MSMTK2824, OP1SMLTK01, OP1SMLTK02	40 CFR Part 63, Subpart F	Tank does not meet the MACT F definition of storage tank because capacity is less than 38 cubic meters (10040 gal).
MBTCT2402	N/A	40 CFR Part 63, Subpart Q	Cooling Tower does not use chromium based chemicals.
MBTDM4009	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 40 cubic meters (10,560 gallons).
MBTDM4009	N/A	40 CFR Part 63, Subpart F	Tank does not meet the MACT F definition of “storage tank” because its capacity is less than 38 cubic meters (10,040 gal).
MBTLDTT1	N/A	40 CFR Part 63, Subpart F	The unloading spot does not meet the definition of a transfer rack as defined in 63.101.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
MBTTK3112	N/A	40 CFR Part 60, Subpart Kb	HON Group 1 storage vessel also subject to 40 CFR 60 Subpart Kb is only required to comply with the requirements of HON.
MBTTK3113	N/A	40 CFR Part 60, Subpart Kb	HON Group 1 storage vessel also subject to 40 CFR 60 Subpart Kb is only required to comply with the requirements of HON.
MBTTK3113	N/A	40 CFR Part 61, Subpart Y	Compliance with 40 CFR 63, Subpart G shall be deemed to constitute compliance with 40 CFR 61, Subpart Y.
MBTTK3114	N/A	40 CFR Part 60, Subpart Kb	HON Group 1 storage vessel also subject to 40 CFR 60 Subpart Kb is only required to comply with the requirements of HON.
MBTTK3115	N/A	40 CFR Part 60, Subpart Kb	Vessel constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K and Ka.
MBTTK4002	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
MBTTK4003	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
MBTTK4004	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
			NSPS Subpart K or Ka.
MBTTK4011	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
MBTTW4001	N/A	40 CFR Part 60, Subpart NNN	The process unit in which this facility is located does not produce any of the chemicals listed in 60.667 as a product, co-product, by-product, or intermediate.
MBTTW4002	N/A	40 CFR Part 60, Subpart NNN	Separation is achieved using liquid/liquid phases. This column does not perform a distillation operation as defined in 40 CFR 60 Subpart NNN.
MBTTW4004	N/A	40 CFR Part 60, Subpart NNN	Separation is achieved using liquid/liquid phases. This column does not perform a distillation operation as defined in 40 CFR 60 Subpart NNN.
MBTTW4005	N/A	40 CFR Part 60, Subpart NNN	Tower has no associated vent stream as defined in NSPS NNN.
MBTTW4006	N/A	40 CFR Part 60, Subpart NNN	Tower has no associated vent stream as defined in NSPS NNN.
MBTTW4007	N/A	40 CFR Part 60, Subpart NNN	Tower has no associated vent stream as defined in NSPS NNN.
MBTTW4009	N/A	40 CFR Part 60, Subpart NNN	Tower has no associated vent stream as defined in NSPS NNN.
MBTTW4010	N/A	40 CFR Part 60, Subpart NNN	Tower has no associated vent stream as defined in NSPS NNN.
MBTTW4011	N/A	40 CFR Part 60, Subpart NNN	Tower has no associated vent stream as defined in

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
			NSPS NNN.
MBTTW4012	N/A	40 CFR Part 60, Subpart NNN	As HON Group 1 process vent, distillation unit is required to comply only with the provisions of HON.
MBTTW4022	N/A	40 CFR Part 60, Subpart NNN	The process unit in which this facility is located does not produce any of the chemicals listed in 60.667 as a product, co-product, by-product, or intermediate.
MEOCT7003	N/A	40 CFR Part 63, Subpart Q	Chromium was not used in the cooling tower on or after 9/8/1994.
MEODM7004B	N/A	40 CFR Part 60, Subpart RRR	Vessel has no associated vent stream other than potential releases from relief valves, which are excluded from the definitions of “vent stream.”
MEODM7055	N/A	40 CFR Part 60, Subpart Kb	Vessel capacity is less than 40 cubic meters (10,560 gallons).
MEODM7059	N/A	40 CFR Part 60, Subpart RRR	Vessel has no associated vent stream other than potential releases from relief valves, which are excluded from the definitions of “vent stream.”
MEOHT7001	N/A	30 TAC Chapter 112, Sulfur Compounds	Liquid fuel is not used in the Reformer Furnace.
MEOSP7045	N/A	40 CFR Part 60, Subpart Kb	Vessel capacity is less than 40 cubic meters (10,560 gal).
MEOWW	N/A	30 TAC Chapter 115, Industrial Wastewater	Wastewater streams with either less than 1,000 ppm of VOC; or less than 10,000 ppm of VOC and less than 2.64 gpm of flow.
MIPCT2401	N/A	40 CFR Part 63, Subpart Q	Chromium-based water treatment chemicals have not been used on or after September 8, 1994.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
MIPFL2501	N/A	40 CFR Part 60, Subpart A	Flare does not receive waste gas from any sources subject to the subparts of 40 CFR 60 or 40 CFR 61.
MIPLDDM	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	Drum loading does not involve loading a transport vessel.
MIPRX2606A	N/A	40 CFR Part 60, Subpart RRR	The reactor was constructed prior to 6/29/90, and no modifications have occurred since that time.
MIPRX2606B	N/A	40 CFR Part 60, Subpart RRR	The reactor was constructed prior to 6/29/90, and no modifications have occurred since that time.
MIPTK3105	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MIPTK3106	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MIPTK3107	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MIPTK3108	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MIPTK3109	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also,

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
			vessel stores VOL and is not potentially subject to NSPS K or Ka.
MIPTK3110	N/A	40 CFR Part 60, Subpart Kb	Vessel is not subject to NSPS Kb because capacity < 20,000 gal.
MIPTK3123	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MIPTK3124	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MIPTW2602	N/A	40 CFR Part 60, Subpart NNN	The distillation unit was constructed prior to 12/30/83, and no modifications have occurred since this date.
MIPTW2603	N/A	40 CFR Part 60, Subpart NNN	The distillation unit was constructed prior to 12/30/83, and no modifications have occurred since this date.
MIPTW2604	N/A	40 CFR Part 60, Subpart NNN	The distillation unit was constructed prior to 12/30/83, and no modifications have occurred since this date.
MIPTW2605	N/A	40 CFR Part 60, Subpart NNN	The distillation unit was constructed prior to 12/30/83, and no modifications have occurred since this date.
MPBCMPU	N/A	40 CFR Part 60, Subpart DDD	Unit does not produce polypropylene, polyethylene, polystyrene or poly (ethylene teraphthalate).
MPBCMPU	N/A	40 CFR Part 63, Subpart U	Process unit is not defined as an elastomer product process unit since it does not manufacture an elastomer product. Polybutadiene Resin is a different product than Polybutadiene Rubber/Styrene

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
			Butadiene rubber by Solution.
MPBDM3219	N/A	40 CFR Part 60, Subpart Kb	This storage vessel has a capacity less than 10,600 gallons. Therefore, it is not an affected facility.
MPBFL2502	N/A	40 CFR Part 60, Subpart A	Flare does not receive waste gasses from any source subject to 40 CFR 60 NSPS or 40 CFR 61 NESHAP control requirements.
MPBLDDM	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	Drum loading does not involve a transport vessel.
MPBRX3201F	N/A	40 CFR Part 60, Subpart RRR	The process unit in which this facility is located does not produce any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
MPBRX3201G	N/A	40 CFR Part 60, Subpart RRR	The process unit in which this facility is located does not produce any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
MPBTK3205	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MPBTK3207	N/A	40 CFR Part 60, Subpart Kb	Vessel capacity is less than 40 cubic meters (10,560 gal).
MPBTK3208	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MPBTK3209	N/A	40 CFR Part 60, Subpart Kb	Vessel capacity is less than 40 cubic meters (10,560 gal).

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
MPBTK3210	N/A	40 CFR Part 60, Subpart Kb	Vessel capacity is less than 40 cubic meters (10,560 gal).
MPBTK3211	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MPBTK3212	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MPBTK3213	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MPBTK3214	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MPBTK3215	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MPBTK3216	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MPBTK3217	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
			reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MPBTK3218	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MPBTK3219	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MPBTK3221	N/A	40 CFR Part 60, Subpart Kb	Vessel capacity is less than 40 cubic meters (10,560 gal).
MPBTK3224	N/A	40 CFR Part 60, Subpart Kb	This storage vessel has a capacity less than 10,600 gallons. Therefore, it is not an affected facility.
MPBTW3205	N/A	40 CFR Part 60, Subpart NNN	The process unit in which this facility is located does not produce any of the chemicals listed in 60.667 as a product, co-product, by-product, or intermediate.
MSMDM2801	N/A	40 CFR Part 60, Subpart Kb	Vessel capacity is less than 40 cubic meters (10,560 gal).
MSMDM2802	N/A	40 CFR Part 60, Subpart Kb	Vessel capacity is less than 40 cubic meters (10,560 gal).
MSMHT2801A	N/A	30 TAC Chapter 112, Sulfur Compounds	This heater does not fire liquid fuel.
MSMHT2801A	N/A	40 CFR Part 60, Subpart Dc	Maximum design heat input capacity is less than 10 MMBtu/hr.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
MSMHT2801B	N/A	30 TAC Chapter 112, Sulfur Compounds	This heater does not fire liquid fuel.
MSMHT2801B	N/A	40 CFR Part 60, Subpart Dc	Maximum design heat input capacity is less than 10 MMBtu/hr.
MSMRX2801	N/A	40 CFR Part 60, Subpart RRR	The affected facility is part of a process unit that does not produce any of the chemicals listed in 60.707.
MSMTK2801	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MSMTK2802	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MSMTK2803	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS K or Ka.
MSMTK2811	N/A	40 CFR Part 60, Subpart Kb	Vessel capacity is less than 40 cubic meters (10,560 gal).
MSMTK2812	N/A	40 CFR Part 60, Subpart Kb	Vessel capacity is less than 40 cubic meters (10,560 gal).
OFXDM4383	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
OFXHT4351	N/A	30 TAC Chapter 112, Sulfur Compounds	Only fired with gaseous fuels: no solid or liquid fuels.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
OFXHT4360	N/A	30 TAC Chapter 112, Sulfur Compounds	Only fired with gaseous fuels: no solid or liquid fuels.
OFXHT4360C	N/A	30 TAC Chapter 112, Sulfur Compounds	Only fired with gaseous fuels: no solid or liquid fuels.
OFXHT4361	N/A	30 TAC Chapter 112, Sulfur Compounds	Only fired with gaseous fuels: no solid or liquid fuels.
OFXRX4360C	N/A	40 CFR Part 60, Subpart RRR	Vent only occurs during startup, shutdown, or malfunction in order to avoid safety hazards or equipment damage.
OLH2FLARE	N/A	40 CFR Part 60, Subpart A	Flare does not receive waste gasses from any source subject to 40 CFR 60 NSPS or 40 CFR 61 NESHAP control requirements.
OLH2FLARE	N/A	40 CFR Part 63, Subpart A	Flare does not receive waste gasses from any source subject to 40 CFR 63 MACT control requirements.
OLH2FLAREV	N/A	30 TAC Chapter 115, Vent Gas Controls	The vent stream has a combined weight of VOC equal to or less than 100 pounds in any continuous 24 hour period.
OLH2FLAREV	N/A	40 CFR Part 63, Subpart YY	The vent stream does not contain any HAPs.
OP1CT3811	N/A	40 CFR Part 63, Subpart Q	Chromium was not used in the cooling tower on or after 9/8/1994.
OP1DM3453	N/A	30 TAC Chapter 115, Water Separation	Source is considered part of the process and is not a water separator.
OP1DM3904	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
OP1HT3415	N/A	40 CFR Part 60, Subpart RRR	Reactor vent does not meet definition of “vent

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
			stream."
OP1HT3601	N/A	30 TAC Chapter 112, Sulfur Compounds	Only fired with gaseous fuels; no solid or liquid fuels.
OP1HT3701	N/A	30 TAC Chapter 112, Sulfur Compounds	Only fired with gaseous fuels; no solid or liquid fuels.
OP1SMLTK14	N/A	30 TAC Chapter 115, Storage of VOCs	Vessel has capacity less than 1,000 gallons.
OP1SMLTK14	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
OP1TK3601	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
OP1TK38008	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
OP1TK38009	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
OP1TK38303	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
OP1TK3903	N/A	40 CFR Part 60, Subpart Kb	Maximum true vapor pressure is less than 3.5 kilopascals (0.5 psia).
OP1TK3908	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
OP1TK3909	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
OP1TK3910	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
OP2CT4811	N/A	40 CFR Part 63, Subpart Q	Chromium was not used in the cooling tower on or after 9/8/1994.
OP2DM4453	N/A	30 TAC Chapter 115, Water Separation	Source is considered part of the process and is not a water separator.
OP2HT4601	N/A	30 TAC Chapter 112, Sulfur Compounds	Only fired with gaseous fuels: no solid or liquid fuels.
OP2LOAD	N/A	40 CFR Part 63, Subpart YY	Loading activities are less than 75 cubic meters per day, averaged over 30 days.
OP2TK4451	N/A	40 CFR Part 60, Subpart Kb	Vessel stores VOL with a vapor pressure below 0.5 psia at actual operating conditions.
OP2TK4456	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
OP2TK4601	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
OP2TK48007	N/A	40 CFR Part 60, Subpart Kb	Vessel stores VOL with a vapor pressure below 0.5 psia at actual operating conditions.
OP2TK48008	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
			(19,800 gallons).
OP2TK48009	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
OP2TK48105	N/A	40 CFR Part 60, Subpart Kb	Vessel has a capacity less than 75 cubic meters (19,800 gallons).
OP2TK48303	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
OP2TK4915	N/A	40 CFR Part 60, Subpart Kb	Vessel was constructed before 7/23/1984 without reconstruction or modification after 7/23/1984. Also, vessel stores VOL and is not potentially subject to NSPS Subpart K or Ka.
OP2TK4916	N/A	40 CFR Part 60, Subpart Kb	HON Group 1 storage vessel also subject to 40 CFR 60 Subpart Kb is only required to comply with the requirements of HON.
OP2TK4916	N/A	40 CFR Part 61, Subpart Y	Compliance with 40 CFR 63, Subpart G shall be deemed to constitute compliance with 40 CFR 61, Subpart Y.
OP2TW44104	N/A	40 CFR Part 60, Subpart NNN	Tower has no associated vent stream other than potential releases from relief valves, which are excluded from the definition of “vent stream.”
PRO-OP1	N/A	40 CFR Part 63, Subpart F	Process unit primary product not listed in 63.100 Table 1.
PRO-OP2	N/A	40 CFR Part 63, Subpart F	Process unit primary product not listed in 63.100 Table 1.

New Source Review Authorization References

New Source Review Authorization References 658

New Source Review Authorization References by Emission Unit 661

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Prevention of Significant Deterioration (PSD) Permits	
PSD Permit No.: PSDTX1270	Issuance Date: 09/22/2017
PSD Permit No.: PSDTX1272	Issuance Date: 12/28/2018
PSD Permit No.: PSDTX1280M1	Issuance Date: 02/28/2019
PSD Permit No.: PSD-TX-1272-GHG	Issuance Date: 07/19/2013
PSD Permit No.: PSD-TX-1280-GHG	Issuance Date: 02/14/2013
Nonattainment (NA) Permits	
NA Permit No.: N140	Issuance Date: 09/22/2017
NA Permit No.: N142	Issuance Date: 12/28/2018
NA Permit No.: N144	Issuance Date: 02/28/2019
Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 143753	Issuance Date: 12/22/2016
Authorization No.: 144030	Issuance Date: 01/13/2017
Authorization No.: 146636	Issuance Date: 06/08/2017
Authorization No.: 1768	Issuance Date: 12/28/2018
Authorization No.: 2128	Issuance Date: 05/09/2016
Authorization No.: 22779	Issuance Date: 03/22/2019
Authorization No.: 24677	Issuance Date: 12/12/2018
Authorization No.: 24887	Issuance Date: 11/21/2016
Authorization No.: 2933	Issuance Date: 09/22/2017
Authorization No.: 2936	Issuance Date: 12/21/2012
Authorization No.: 3130A	Issuance Date: 09/02/2015
Authorization No.: 49120	Issuance Date: 05/03/2019
Authorization No.: 49130	Issuance Date: 09/23/2014
Authorization No.: 6245	Issuance Date: 03/22/2019
Authorization No.: 6387	Issuance Date: 07/05/2018
Authorization No.: 8125	Issuance Date: 02/28/2019
Authorization No.: 83799	Issuance Date: 07/17/2018
Authorization No.: 84079	Issuance Date: 05/25/2017
Authorization No.: 148067	Issuance Date: 10/05/2017
Authorization No.: 150877	Issuance Date: 04/13/2018
Authorization No.: 154481	Issuance Date: 01/24/2019

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Authorization No.: 156142	Issuance Date: 05/06/2019
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.183	Version No./Date: 09/04/2000
Number: 106.261	Version No./Date: 12/24/1998
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 12/24/1998
Number: 106.262	Version No./Date: 11/01/2003
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.264	Version No./Date: 09/04/2000
Number: 106.265	Version No./Date: 09/04/2000
Number: 106.371	Version No./Date: 09/04/2000
Number: 106.394	Version No./Date: 09/04/2000
Number: 106.412	Version No./Date: 09/04/2000
Number: 106.433	Version No./Date: 09/04/2000
Number: 106.452	Version No./Date: 09/04/2000
Number: 106.454	Version No./Date: 11/01/2001
Number: 106.472	Version No./Date: 03/14/1997
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.473	Version No./Date: 03/14/1997
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.474	Version No./Date: 09/04/2000
Number: 106.475	Version No./Date: 09/04/2000
Number: 106.476	Version No./Date: 09/04/2000
Number: 106.477	Version No./Date: 09/04/2000
Number: 106.478	Version No./Date: 03/14/1997
Number: 106.478	Version No./Date: 09/04/2000
Number: 106.492	Version No./Date: 09/04/2000
Number: 106.495	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 09/04/2000
Number: 106.512	Version No./Date: 09/04/2000
Number: 106.512	Version No./Date: 06/13/2001
Number: 106.532	Version No./Date: 09/04/2000

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Number: 106.533	Version No./Date: 09/04/2000
Number: 7	Version No./Date: 05/04/1994
Number: 7	Version No./Date: 04/05/1995
Number: 51	Version No./Date: 09/12/1989
Number: 118	Version No./Date: 09/12/1989
Number: 118	Version No./Date: 06/07/1996

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
EALPVJ310	ANALYZER VENT	106.261/11/01/2003, 106.262/11/01/2003
EALPVJ402	ANALYZER VENT	106.261/11/01/2003, 106.262/11/01/2003
EALRX402	E-402, CONTACTOR NO. 1	24887
EALRX403	E-403, CONTACTOR NO. 2	24887
EALRX404	E-404, CONTACTOR NO. 3	24887
EALRX405	E-405, CONTACTOR NO. 6	24887
EALRX467	E-467, CONTACTOR NO. 4	24887
EALRX468	E-468, CONTACTOR NO. 5	24887
EALSMLTK01	MISCELLANEOUS SMALL TANK 01	24887
EALSMLTK02	MISCELLANEOUS SMALL TANK 02	24887
EALSMLTK03	MISCELLANEOUS SMALL TANK 03	24887
EALSMLTK04	MISCELLANEOUS SMALL TANK 04	24887
EALSMLTK05	MISCELLANEOUS SMALL TANK 05	24887
EALSMLTK06	MISCELLANEOUS SMALL TANK 06	24887
EALSP4066	SP-4066 FRESH ACID SCRUBBER	24887
EALTK17	TK-17, MIXED C4 STORAGE SPHERE	24887
EALTK32	TK-32, ALKYLATE STORAGE	24887
EALTK33	TK-33, ALKYLATE STORAGE	24887
EALTK37	TK-37, ALKYLATE STORAGE TANK	24887
EALTK402	TK-402 SPENT SULFURIC ACID	106.476/09/04/2000
EALTK7	TK-7, ISOBUTANE STORAGE SPHERE	24887

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
EALTK8	TK-8, ISOBUTANE STORAGE SPHERE	24887
EALTW312	T-312 DEPROPANIZER	24887
EALTW410	T-410 DEISOBUTANIZER	24887
EBGDOCK1&2	BARGE DOCK LOADING STATION 1 & 2	3130A, 106.261/11/01/2003, 106.262/11/01/2003
EBGDOCK3&4	BARGE DOCK LOADING STATION 3 & 4	3130A, 106.261/11/01/2003, 106.262/11/01/2003
EBGEG6901	EMERGENCY ENGINE	106.511/09/04/2000
EBGTK6901	TK-6901 STORMWATER RUNOFF TANK	3130A
EBGTK6902	TK-6902 STORMWATER RUNOFF TANK	3130A
EBGTK6904	FIRE FIGHTING FOAM SOLUTION TANK	106.472/09/04/2000
EBGTK6905	TK-6905 PFO-PGO TANK	3130A
EBGVC6904	FL-6904, BARGE DOCK VAPOR COMBUSTOR	3130A, 148067, 106.261/11/01/2003, 106.262/11/01/2003
EC4D3001	D-3001 O2 ANALYZER VENT	2128
EC4DM21	D-21, BUTADIENE FEED TO POLYBD	2128
EC4DM3075	D-3075, C4/ACN POLYMER STORAGE DRUM	2128
EC4DM59	D-59 SURGE DRUM	2128
EC4HT1202	R-1208 THERMAL OXIDIZER	2128
EC4HT1203	F-1203 REGENERATION HEATER	2128
EC4HT302	F-302 REGENERATION HEATER	2128
EC4LTMISC1	MISC. LOADING SPOT 1 C4 UNIT	2128
EC4LTMISC2	MISC. LOADING SPOT 1 C4 UNIT	2128
EC4PV08040	ANALYZER VENT	2128

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
EC4PV08041	ANALYZER VENT	2128
EC4PVJ1205	ANALYZER VENT	2128
EC4PVJ1206	ANALYZER VENT	2128
EC4PVJ304	ANALYZER VENT	2128
EC4PVJ309	ANALYZER VENT	2128
EC4PVJ316	ANALYZER VENT	106.261/11/01/2003, 106.262/11/01/2003
EC4PVJ317	ANALYZER VENT	2128
EC4RX1201A	REACTOR R-1201A	2128
EC4RX1201B	REACTOR R-1201B	2128
EC4RX1201C	REACTOR R-1201C	2128
EC4RX1201D	REACTOR R-1201D	2128
EC4RX1201	R-1201 REGENERATION GAS FLOW	2128
EC4RX1208A	REACTOR R-1208A	2128
EC4RX1208B	REACTOR R-1208B	2128
EC4RX1208	R-1208 D/E REGENERATION GAS FLOW	2128
EC4RX309A	REACTOR R-309A	2128
EC4RX309B	REACTOR R-309B	2128
EC4RX309C	REACTOR R-309C	2128
EC4RX309	R-309 A/B/C REGENERATION GAS FLOW	2128
EC4SMLTK01	MISCELLANEOUS SMALL TANK 01	106.478/09/04/2000
EC4SMLTK02	MISCELLANEOUS SMALL TANK 02	106.478/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
EC4SMLTK03	MISCELLANEOUS SMALL TANK 03	106.478/09/04/2000
EC4SMLTK04	MISCELLANEOUS SMALL TANK 04	106.478/09/04/2000
EC4SMLTK05	MISCELLANEOUS SMALL TANK 05	106.472/09/04/2000
EC4SMLTK09	MISCELLANEOUS SMALL TANK 09	106.472/09/04/2000
EC4SMLTK13	SMALL STORAGE TANK	106.261/11/01/2003
EC4SMLTK14	MISCELLANEOUS SMALL TANK 14	106.261/11/01/2003
EC4TK11	TK-11, CRUDE C4 FEED	2128
EC4TK14	TK-14, CRUDE C4 FEED	2128
EC4TK16	TK-16, OFF-SPEC BD	2128, 106.261/11/01/2003, 106.262/11/01/2003
EC4TK20	TK-20, C4 UNIT SLOP ACN	2128
EC4TK3941	TK-3941, CRUDE C4 STORAGE SPHERE	1768, N142, PSDTX1272
EC4TK3942	TK-3942, CRUDE C4 STORAGE SPHERE	1768, N142, PSDTX1272
EC4TK3	TK-3, CRUDE C4S	2128
EC4TK41	TK-41, BD PRODUCT	2128
EC4TK42	TK-42, BD PRODUCT	2128
EC4TK43	TK-43, BD PRODUCT	2128, 106.261/11/01/2003, 106.262/11/01/2003
EC4TK44	TK-44, BD PRODUCT	2128
EC4TK6	TK-6, CRUDE C4S	2128
EC4TO	THERMAL OXIDIZER	2128
EC4TW1202	T-1202/1203 WEST ABSORBER	2128
EC4TW1204	T-1204 WEST STRIPPER	2128

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
EC4TW1205	T-1205 M/A COLUMN (1200 AREA)	2128
EC4TW1207	T-1206/T-1207 BD COLUMN	2128
EC4TW3011	T-3011 GREEN OIL TOWER	2128
EC4TW3013	T-3013 BD ABSORBER TOWER	2128
EC4TW3014	T-3014 BD STRIPPER TOWER	2128
EC4TW3015	T-3015 WATER WASH COLUMN	2128
EC4TW3016	T-3016 SOLVENT RECOVERY TOWER	2128
EC4TW3017	T-3017 BD ACN COLUMN	2128
EC4TW3018	T-3018 BD WASH COLUMN	2128
EC4TW3019	T-3019 REGEN WASH TOWER	2128
EC4TW301	T-301/302/3001/3002 BD COLUMN	2128
EC4TW303	T-303 DEOILER COLUMN	2128
EC4TW317	T-317 BD WATER WASH COLUMN	2128
EC4TW318	T-318 BD WASH COLUMN	2128
EC4TW319	T-319 BD WATER WASH COLUMN	2128
EC5DM12	D-12, C5 UNIT SLOP ACN	6245
EC5DM14	D-14, C5 UNIT SLOP ACN	6245
EC5DM304	D-304, C5 UNIT ACN STORAGE	6245
EC5DM56	D-56, PENTANES TO OP1	6245
EC5RXD301	D-301 DIMERIZATION REACTOR	6245
EC5RXD3037	D-3037 DIMERIZATION REACTOR	6245

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
EC5SMLTK01	MISCELLANEOUS SMALL TANK 01	6245
EC5SP334	SP-334, BHT BLEND POT	6245
EC5SP349	SP-349, BHT BLEND POT	6245
EC5TK13	TK-13, ISOPRENE UNIT OFF-TEST SPHERE	6245
EC5TK21	TK-21, C5 RAFFINATE	6245, 106.476/09/04/2000
EC5TK27	TK-27, DCPD STORAGE TANK	6245
EC5TK28	TK-28, ISOPRENE STORAGE SPHERE	6245
EC5TK29	TK-29, PIPERYLENES STORAGE SPHERE	6245
EC5TK30	TK-30, DCPD STORAGE TANK	6245
EC5TK3116	TK-3116, ISOPRENE STORAGE SPHERE	6245
EC5TK317	TK-317, BHT BLEND TANK	6245
EC5TK31	TK-31, DCPD	6245
EC5TK36	TK-36, SLOP ACN	6245
EC5TW1201	T-1201 DEISOPENTANIZER	6245
EC5TW3005	T-3004/3005 ABSORBER	6245
EC5TW3006	T-3006 SOUTH ACN STRIPPER	6245
EC5TW3009	T-3009 RAFFINATE WATER WASH COLUMN	6245
EC5TW3010	T-3010 DCPD STRIPPER	6245
EC5TW305	T-304/305 C5 SPLITTER	6245
EC5TW308	T-307/T-308 C5 SPLITTER	6245
EC5TW309	T-309 A/B ACN COLUMN	6245

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
EC5TW310	T-310 ACN RERUN STRIPPER	6245
EC5TW313	T-313 PIPERYLENE COLUMN	6245
EC5TW314	T-314 ISOPRENE WATER WASH	6245
EC5TW315	T-315 C5 ACN STRIPPER	6245
ECUCT1701A	ECU COOLING TOWER	106.371/09/04/2000
ECUCT1701B	ECU COOLING TOWER	106.371/09/04/2000
ECUCT604	EAST PLANT COOLING TOWER	6245
ECUDM3301	D-3301, GASOLINE STORAGE DRUM	106.478/09/04/2000
ECUDM3302	D-3302, DIESEL STORAGE DRUM	106.472/09/04/2000
ECUDM82	D-82, VOC STORAGE	2128
ECUDM83	D-83, VOC STORAGE	2128
ECULR1BD	ECU RAIL RACK LOADING BUTADIENE	2128
ECULR1C4	ECU RAIL RACK LOADING CRUDE C4	2128
ECULR1CBD	ECU RAIL RACK LOADING CRUDE BUTADIENE	2128
ECULR2BD	ECU RAIL RACK LOADING BUTADIENE	2128
ECULR2C4	ECU RAIL RACK LOADING CRUDE C4	2128
ECULR2CBD	ECU RAIL RACK LOADING CRUDE BUTADIENE	2128
ECULR2MEOH	ECU RAIL RACK LOADING METHANOL	8125, N144, PSDTX1280M1
ECULRACID	SPENT ACID RAIL RACK LOADING	24887
ECULRACN	ACN RAIL RACK LOADING	2128
ECULRVOC	ECU RAIL RACK LOADING MISC. VOC	2128, 24887, 6245

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
ECULTBD	ECU TRUCK RACK LOADING BUTADIENE	2128
ECULTC4	ECU TRUCK RACK LOADING CRUDE C4	2128, 106.261/11/01/2003, 106.262/11/01/2003
ECULTMEOH	ECU TRUCK RACK LOADING METHANOL	8125, 106.473/09/04/2000, N144, PSDTX1280M1
ECULTNOHAP	ECU TRUCK RACK LOADING IC4 AND B2	2128
ECULTVOC	ECU TRUCK RACK LOADING MISC. VOC	2128, 24887, 6245
ECUSMLTK03	MISCELLANEOUS SMALL TANK 03	106.472/09/04/2000
ECUSMLTK15	MISCELLANEOUS SMALL TANK 15	106.472/09/04/2000
ECUSMLTK16	MISCELLANEOUS SMALL TANK 16	106.472/09/04/2000
ECUSMLTK17	MISCELLANEOUS SMALL TANK 17	106.472/09/04/2000
ECUSMLTK18	MISCELLANEOUS SMALL TANK 18	106.472/09/04/2000
ECUSMLTK19	MISCELLANEOUS SMALL TANK 19	106.472/09/04/2000
ECUSMLTK20	MISCELLANEOUS SMALL TANK 20	106.472/09/04/2000
ECUSMLTK22	MISCELLANEOUS SMALL TANK 22	106.472/09/04/2000
ECUSMLTK23	MISCELLANEOUS SMALL TANK 23	106.472/09/04/2000
ECUSMLTK24	MISCELLANEOUS SMALL TANK 24	106.472/09/04/2000
ECUSMLTK25	MISCELLANEOUS SMALL TANK 25	106.472/09/04/2000
ECUSMLTK26	MISCELLANEOUS SMALL TANK 26	106.472/09/04/2000
ECUSMLTK29	MISCELLANEOUS SMALL TANK 29	106.472/09/04/2000
ECUSMLTK30	DIESEL/ALKYLATE FIRE FIGHTING TANK	106.478/09/04/2000
ECUSUEAPI	EAST API SEPARATOR	49120
ECUSUWAPI	WEST API SEPARATOR	49120

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
ECUTK1708	TK-1708 EQUALIZATION	49120
ECUTK1709A	TK-1709A AERATION TANK	49120
ECUTK1709B	TK-1709B CLARIFIER TANK	49120
ECUTK1713	TK-1713 EQUALIZATION TANK	49120
ECUTK1714	TK-1714 EQUALIZATION TANK	49120
ECUTK1715	TK-1715 EQUALIZATION TANK	49120
ECUTK1716	TK-1716 EAST DIGESTER	49120
ECUTK1717	TK-1717 EAST CLARIFIER	49120
ECUTK1718	TK-1718 SUPERNATE TANK	49120
ECUTK1719	TK-1719 OP-1 EQUALIZATION TANK	49120
ECUTK1720	TK-1720 OP-1 EQUALIZATION TANK	49120
ECUTK1721	TK-1721 OP-1 STABILIZATION TANK	49120
ECUTK1722	TK-1722 OP-1 EQUALIZATION TANK	49120
ECUTK1723	TK-1723 OP-1 TRICKLING FILTER	1768, N142, PSDTX1272
ECUTK1724	TK-1724 OP-1 CLARIFIER	1768, N142, PSDTX1272
ECUTK1725	TK-1725 OP-1 DIGESTER	49120
ECUTK1726	TK-1726 OP-1 THICKENER	49120
ECUTK1729	TK-1729 OP-2 EQUALIZATION TANK	49120
ECUTK1730	TK-1730 OP-2 EQUALIZATION TANK	49120
ECUTK1731	TK-1731 OP-2 STABILIZATION	49120
ECUTK1732	TK-1732 OP-2 EQUALIZATION TANK	49120

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
ECUTK1733	TK-1733 OP-2 TRICKLING FILTER	2933, N140, PSDTX1270
ECUTK1734	TK-1734 OP-2 CLARIFIER	2933, N140, PSDTX1270
ECUTK1735	TK-1735 OP-2 DIGESTER	49120
ECUTK1736	TK-1736 OP-2 THICKENER TANK	49120
ECUTK1739	TK-1739 SUPERNATATE TANK	49120
ECUTK1740A	TK-1740A AERATION TANK	49120
ECUTK1740B	TK-1740B CLARIFIER TANK	49120
ECUTK1750	TK-1750 EQUALIZATION TANK	49120
ECUTK1759	TK-1759 EAST SIDE TRICKLING FILTER	49120
ECUTK2612	TK-2612 WEST API EQUALIZATION TANK	106.472/09/04/2000
ECUTK2613	TK-2613 BLASTING YARD TANK	106.472/09/04/2000
ECUTKPOND1	MIXING BASIN/HOLDING POND 1	49120
ECUTKPOND2	MIXING BASIN/HOLDING POND 2	49120
EMERFLARE	METHANOL EMERGENCY FLARE	8125, N144, PSDTX1280M1
EMTPVJ1204	ANALYZER VENT	6387
EMTPVJ1207	ANALYZER VENT	6387
EMTPVJ1210	ANALYZER VENT	6387
EMTPVJ4203	ANALYZER VENT	6387
EMTR1202AV	R-1202A REGENERATION GAS VENT	6387
EMTR1202BV	R-1202B REGENERATION GAS VENT	6387
EMTR1202CV	R-1202C REGENERATION GAS VENT	6387

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
EMTR1202DV	R-1202D REGENERATION GAS VENT	6387
EMTRX1202A	R-1202A, BD HYDROGENATION REACTOR	6387
EMTRX1202B	R-1202B, BD HYDROGENATION REACTOR	6387
EMTRX1202C	R-1202C, BD HYDROGENATION REACTOR	6387
EMTRX1202D	R-1202D, BD HYDROGENATION REACTOR	6387
EMTRX1203	R-1203, BD HYDRATION REACTOR	6387
EMTRX1204	R-1204, MTBE REACTOR	6387
EMTRX4201A	R-4201A, PRIMARY MTBE REACTOR	6387
EMTRX4201B	R-4201B, PRIMARY MTBE REACTOR	6387
EMTRX4202A	R-4202A, SECONDARY MTBE REACTOR	6387
EMTRX4202B	R-4202B, SECONDARY MTBE REACTOR	6387
EMTSMLTK01	MISCELLANEOUS SMALL TANK 01	106.478/09/04/2000
EMTSMLTK02	MISCELLANEOUS SMALL TANK 02	106.478/09/04/2000
EMTTK10	TK-10 MTBE BUTYLENE FEED STORAGE SPHERE	6387
EMTTK12	TK-12, BUTYLENE SALES STORAGE SPHERE	6387
EMTTK18	TK-18, BUTYLENE SALES STORAGE SPHERE	6387
EMTTK19	TK-19, BUTYLENE SALES STORAGE SPHERE	6387
EMTTK1	TK-1, MTBE BUTYLENE FEED SPHERE	6387
EMTTK26	TANK 26, METHANOL STORAGE TANK	6387
EMTTK2	TK-2 BUTYLENE FEED TO MTBE STORAGE SPHERE	6387, 106.476/09/04/2000
EMTTK47	TANK 47, MEOH/WATER STORAGE TANK	6387

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
EMTTK48	TANK 48, MTBE PRODUCT STORAGE	6387
EMTTK49	TANK 49, MTBE PRODUCT STORAGE	6387
EMTTK4	TK-4, OFF-SPEC BUTYLENE STORAGE SPHERE	6387
EMTTK5	TK-5, ALKY FEED/RAFF-II STORAGE SPHERE	6387, 106.476/09/04/2000
EMTTK9	TK-9	6387
EMTTW1208	T-1208, DEBUTANIZER	6387
EMTTW1215	T-1215, WATER WASH TOWER	6387
EMTTW1216	T-1216, MEOH EXTRACTOR	6387
EMTTW4201	T-4201, A TRAIN DEBUANIZER	6387
EMTTW4202	T-4202, METHANOL/WATER STRIPPER	6387
EMTTW4203	T-4203, B TRAIN WATER EXTRACTOR TOWER	6387
EMTTW4205	T-4205, B TRAIN DME REMOVAL TOWER	6387
EMTTW4206	T-4206, B TRAIN DEC TOWER	6387
EMTTW4207	T-4207, A TRAIN WATER EXTRACTOR TOWER	6387
ENGADMIN	ADMIN ENGINE	106.511/09/04/2000
EUTDM01086	SKIMMING DRUM	106.532/09/04/2000
EUTDM0701	OIL/WATER SEPARATOR	106.532/09/04/2000
EUTDM0801	OIL/WATER SEPARATOR	106.532/09/04/2000
EUTDM8801	STRIPPER FEED DRUM	106.532/09/04/2000
EUTDM8804	MAINTENANCE DRUM	106.532/09/04/2000
EUTEN1	BACKUP DIESEL AIR COMPRESSOR	106.512/06/13/2001

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
EUTENEOC	EOC EMER GEN	106.511/09/04/2000
EUTENLAB	LAB EMER GEN	106.511/09/04/2000
EUTENPMDI	PMDI EMER GEN	106.511/09/04/2000
EUTFL1701	FL-1701, EAST PLANT FLARE	143753, 144030, 2128, 106.261/11/01/2003, 106.262/11/01/2003, 106.532/09/04/2000
EUTFL1701V	PROCESS VENT FOR EUT FLARE FL-1701	143753, 2128, 24887, 6245, 6387, 106.261/11/01/2003, 106.262/11/01/2003, 106.532/09/04/2000
EUTG1110	G-1110 EMER GEN	106.511/09/04/2000
EUTG1111	G-1111 EMER GEN	106.511/09/04/2000
EUTP3301B	P-3301B FIREWATER PUMP	106.511/09/04/2000
EUTP803A	P-803A FIREWATER PUMP	106.511/09/04/2000
EUTP803B	P-803B FIREWATER PUMP	106.511/09/04/2000
EUTTK1101A	LAB WASTE TANK	2128
EUTTK1101B	LAB WASTE TANK	2128
EUTTK88014	WASTEWATER TANK	49120
EUTTW8801	EAST PLANT DESIGN STEAM STRIPPER #1	2128
EUTTW8802	EAST PLANT DESIGN STEAM STRIPPER #2	2128
FUGITIVES	FACILITY FUGITIVES	1768, 2128, 22779, 24677, 24887, 2933, 2936, 3130A, 49120, 49130, 6245, 6387, 8125, 106.261/11/01/2003, 106.262/11/01/2003, N140, N142, N144, PSDTX1270, PSDTX1272, PSDTX1280M1
MBTCT2402	BENZENE/TOLUENE/POLYBUTADIENE COOLING TOWER	22779, 2936, 106.371/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
MBTDM4009	D-4009 SULFOLANE SUMP	106.472/09/04/2000
MBTDM4043	HYDROCARBON BLOWDOWN DRUM	106.472/09/04/2000
MBTLDTT1	SULFOLANE UNLOADING SPOT	2936
MBTPV4001B	BENZENE PIPELINE ANALYZER VENT	2936
MBTPVJ4001	BT ANALYZER VENT	2936
MBTPVJ4002	BT ANALYZER VENT	2936
MBTSMLTK02	MISCELLANEOUS SMALL TANK 02	106.478/09/04/2000
MBTSMLTK03	MISCELLANEOUS SMALL TANK 03	106.472/09/04/2000
MBTSP4010	SP-4010 HOT WELL VENT	2936
MBTTK3101	TOLUENE TANK	2936
MBTTK3102	TOLUENE TANK	2936
MBTTK3111A	BENZENE TANK	2936
MBTTK3111B	BENZENE TANK	2936
MBTTK3112	TANK TK-3112, PY GAS	2936
MBTTK3113	TANK TK-3113, OFF-SPEC BENZENE	2936
MBTTK3114	TANK TK-3114, SULFOLANE/HC	2936
MBTTK3115	TANK TK-3115, PYGAS	2936
MBTTK4002	TANK TK-4002, WET SULFOLANE STORAGE	2936
MBTTK4003	TANK TK-4003, SULFOLANE/WATER STORAGE	2936
MBTTK4004	TANK TK-4004, SULFOLANE STORAGE	2936
MBTTK4011	TK-4011, DRY SOLVENT STORAGE	2936

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
MBTTW4001	T-4001 GASOLINE SPLITTER	2936
MBTTW4002	T-4002 EXTRACTOR	2936
MBTTW4004	T-4004 RAFFINATE WASH TOWER	2936
MBTTW4005	T-4005 EXTRACT STRIPPER	2936
MBTTW4006	T-4006 WATER STRIPPER	2936
MBTTW4007	T-4007 RECOVERY TOWER	2936
MBTTW4009	T-4009 BENZENE I TOWER	2936
MBTTW4010	T-4010 BENZENE II TOWER	2936
MBTTW4011	T-4011 SOLVENT REGENERATOR	2936
MBTTW4012	T-4012 JET VENT SCRUBBER	2936
MBTTW4022	T-4022 GASOLINE SPLITTER II	2936
MBTWWCPI	BT API SEPARATOR	106.532/09/04/2000
MEOCT7003	CT-7003 COOLING TOWER	8125, N144, PSDTX1280M1
MEODM7004B	D-7004B DESULFURIZATION	8125, N144, PSDTX1280M1
MEODM7055	D-7055 NEUTRALIZING AMINE	106.472/09/04/2000
MEODM7059	D-7059 DESULFURIZATION VESSEL	8125, N144, PSDTX1280M1
MEOHANLZ	MEOH ANALYZERS VENTS	8125, N144, PSDTX1280M1
MEOHFLARE	METHANOL FLARE	8125, N144, PSDTX1280M1
MEOHFLAREV	PROCESS VENT FOR METHANOL FLARE	8125, N144, PSDTX1280M1
MEOHT7001	F-7001 REFORMER HEATER	8125, N144, PSDTX1280M1
MEOHT7001V	FUEL GAS VENT FOR REFORMER F-7001	8125, N144, PSDTX1280M1

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
MEOPM3314	P-3301A, NEW DIESEL FIREWATER PUMP FOR TK-3301	106.511/09/04/2000
MEORXR7001	METHANOL CONVERTER	8125, N144, PSDTX1280M1
MEOSMLTK03	MISCELLANEOUS SMALL TANK 3	106.472/09/04/2000
MEOSMLTK04	MISCELLANEOUS SMALL TANK 4	106.472/09/04/2000
MEOSMLTK05	COOLING TOWER CORROSION INHIBITOR	106.472/09/04/2000
MEOSMLTK06	COOLING TOWER CORROSION INHIBITOR	106.472/09/04/2000
MEOSMLTK07	COOLING TOWER DISPERSANT	106.472/09/04/2000
MEOSP3101	SP-3101 A/B MEOH CPI SEPARATOR	106.532/09/04/2000
MEOSP7045	SP-7045 SEAL OIL SKID LUBE OIL RESERVOIR	106.472/09/04/2000
MEOTK3122	TK-3122, SURGE TANK	8125, N144, PSDTX1280M1
MEOTK5101	TK-5101, PRODUCT TANK	8125, 106.261/11/01/2003, 106.478/09/04/2000, N144, PSDTX1280M1
MEOTK5102	TK-5102, PRODUCT TANK	8125, N144, PSDTX1280M1
MEOTK7017X	TK-7017X, RFMR FORCED DRAFT FAN LUBE OIL RSRVR	106.472/09/04/2000
MEOTK7018X	TK-7018X, REFMR INDUCED DRAFT FAN LUBE OIL RSRVR	106.472/09/04/2000
MEOTW7001	T-7001 TOPPING COLUMN	8125, N144, PSDTX1280M1
MEOTW7002	T-7002 REFINING COLUMN	8125, N144, PSDTX1280M1
MEOWW	METHANOL PROCESS WW STREAMS	8125, N144, PSDTX1280
MIPCT2401	CT-2401, IPOH/SMA COOLING TOWER	24677, 49130, 106.371/09/04/2000
MIPFL2501	SP-2501, IPOH FLARE	24677, 49130, 106.261/11/01/2003, 106.262/11/01/2003
MIPFL2501V	PROCESS VENT FOR IPOH FLARE FL-2501	24677, 49130, 106.261/11/01/2003, 106.262/11/01/2003

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
MIPLDDM	ISOPROPANOL DRUM LOADING	106.262/11/01/2003
MIPRX2606A	R-2606A, HYDROGENATION REACTOR	49130
MIPRX2606B	R-2606B, HYDROGENATION REACTOR	49130
MIPTK2615	TK-2615, EQUIPMENT PURGE WATER	106.472/09/04/2000
MIPTK3105	TK-3105, CRUDE ACETONE	49130, 106.261/11/01/2003, 106.262/11/01/2003
MIPTK3106	TK-3106, IPOH RUNDOWN	49130, 106.261/11/01/2003, 106.262/11/01/2003
MIPTK3107	TK-3107, IPOH RUNDOWN	49130, 106.261/11/01/2003, 106.262/11/01/2003
MIPTK3108	TK-3108, OFF-SPEC IPOH	49130, 106.261/11/01/2003, 106.262/11/01/2003
MIPTK3109	TK-3109, IPOH SHIPPING	49130, 106.261/11/01/2003, 106.262/11/01/2003
MIPTK3110	TK-3110, SLOPS	49130, 106.261/11/01/2003, 106.262/11/01/2003
MIPTK3123	TK-3123 PRODUCT DAY TANK	49130, 106.261/11/01/2003, 106.262/11/01/2003
MIPTK3124	TK-3124 PRODUCT DAY TANK	49130, 106.261/11/01/2003, 106.262/11/01/2003
MIPTW2602	T-2602, CRUDE ACETONE TOWER	49130
MIPTW2603	T-2603, ACETONE TOWER	49130
MIPTW2604	T-2604, DEHYDRATION TOWER	49130
MIPTW2605	T-2605, ISOPROPANOL TOWER	49130
MPBCMPU	POLYBD PROCESS UNIT	22779
MPBDAPI	POLY BD API	22779
MPBDM3207	D-3207 EFFLUENT FLASH DRUM	22779
MPBDM3219	D-3219 SOLVENT RERUN DRUM	22779
MPBDM3223	D-3223 POLYMER RECLAIM TANK	22779, 106.472/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
MPBFL2502	POLYBD FLARE	22779
MPBFL2502V	PROCESS VENT FOR POLYBD FLARE, FL-2502	22779
MPBLDDM	POLYBD DRUM LOADING	22779
MPBLDRC	POLYBD RAIL CAR LOADING	22779
MPBLDTT	POLYBD TRUCK LOADING	22779
MPBRX3201A	R-3201A	22779
MPBRX3201B	R-3201B	22779
MPBRX3201C	R-3201C	22779
MPBRX3201D	R-3201D	22779
MPBRX3201E	R-3201E	22779
MPBRX3201F	R-3201F	22779
MPBRX3201G	R-3201G	22779
MPBSMLTK01	MISC. SMALL TANK 01	106.472/09/04/2000
MPBSMLTK02	MISCELLANEOUS SMALL TANK 02	22779
MPBTK3201	TK-3201	22779
MPBTK3202A	V-3202A	22779
MPBTK3202B	V-3202B	22779
MPBTK3205	V-3205 BLENDER	22779
MPBTK3207	TK-3207	22779
MPBTK3208	TK-3208	22779
MPBTK3209	TK-3209	22779

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
MPBTK3210	TK-3210	22779
MPBTK3211	TK-3211	22779
MPBTK3212	TK-3212	22779
MPBTK3213	TK-3213	22779
MPBTK3214	TK-3214	22779
MPBTK3215	TK-3215	22779
MPBTK3216	TK-3216	22779
MPBTK3217	TK-3217	22779
MPBTK3218	TK-3218	22779
MPBTK3219	TK-3219	22779
MPBTK3221	TK-3221	22779
MPBTK3224	TK-3224	22779
MPBTK3226	TK-3226 SIEVE TANK	22779
MPBTK3233X	TK-3233X	22779
MPBTRAILER	POLYBD TRAILER	106.476/09/04/2000
MPBTW3201	T-3201 WIPED FILM EVAPORATOR	22779
MPBTW3203	T-3203 ACETONE TOWER	22779
MPBTW3204	T-3204 SOLVENT REC TOWER	22779
MPBTW3205	T-3205 WIPED FILM EVAPORATOR	22779
MSMDM2801	D-2801	24677
MSMDM2802	D-2802	24677

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
MSMDM2805	D-2805	24677
MSMDM2814	D-2814	106.472/09/04/2000
MSMHT2801A	F-2801A	24677
MSMHT2801B	F-2801B	24677, 007/04/05/1995
MSMLDMISC	TK2812 CUMENE LOADING	24677
MSMM2862B	M-2862B B-BIN VENT FILTER (FOR V-2801B BIN)	24677
MSMM2862C	M-2862C C-BIN VENT FILTER (FOR V-2801C BIN)	24677
MSMM2862D	M-2862D D-BIN VENT FILTER (FOR V-2801D BIN)	24677
MSMM2863	M-2863 BLENDER VENT FILTER (FOR X-2803 BLENDER)	24677
MSMM2868	M-2868 VACUUM DUST COLLECTOR	24677
MSMM2872	M-2872 BAGGING MACHINE DUST COLLECTOR	24677
MSMRX2801	R-2801 SMA REACTOR	24677
MSMTK2801	TK-2801	24677
MSMTK2802	TK-2802	24677
MSMTK2803	TK-2803	24677
MSMTK2804A	TK-2804A	24677
MSMTK2804B	TK-2804B	24677
MSMTK2811	TK-2811	24677
MSMTK2812	TK-2812	24677
MSMTK2824	TK-2824	24677
MSMX2802	X-2802 COOLING BELT & EXTRUDER VENT	24677

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OFXDM4310	D-4310, ALUMINUM CATALYST IN HEXANE	2933, N140, PSDTX1270
OFXDM4311	D-4311, NICKEL CATALYST IN HEXANE	2933, N140, PSDTX1270
OFXDM4383	D-4383, WASTE CAUSTIC	2933, N140, PSDTX1270
OFXHT4351	F-4351 FLEX REGENERATION HEATER	2933, N140, PSDTX1270
OFXHT4360C	F-4360C FLEX ISOM REACTOR FEED HEATER	2933, N140, PSDTX1270
OFXHT4360	F-4360 FLEX ISOM REACTOR FEED HEATER	2933, N140, PSDTX1270
OFXHT4361	F-4361 FLEX REGENERATION HEATER	2933, N140, PSDTX1270
OFXR4360AV	R-4360A, REGEN VENT	2933, N140, PSDTX1270
OFXR4360BV	R-4360B, REGEN VENT	2933, N140, PSDTX1270
OFXR4360CV	R-4360C, REGEN VENT	2933, N140, PSDTX1270
OFXRX4360C	D-4360C FLEX/OP REACTOR	2933, N140, PSDTX1270
OFXRXD4320	D-4320 A/B DIMERIZATION LOOP REACTORS	2933, N140, PSDTX1270
OFXRXD4352	D-4352 A/B FLEX AO TREATERS	2933, N140, PSDTX1270
OFXRXD4360	D-4360 A/B FLEX/OP REACTERS	2933, N140, PSDTX1270
OFXTW4340C	T-4340C BUTENE TOWER	2933, N140, PSDTX1270
OFXTW4340	T-4340 BUTENE TOWER	2933, N140, PSDTX1270
OFXTW4370C	T-4370C DEETHANIZER	2933, N140, PSDTX1270
OFXTW4370	T-4370 DEETHANIZER	2933, N140, PSDTX1270
OFXTW4371C	T-4371C PROPYLENE RECOVERY	2933, N140, PSDTX1270
OFXTW4371	T-4371 PROPYLENE RECOVERY	2933, N140, PSDTX1270
OLH2FLARE	OLEFINS H2 FLARE	106.261/11/01/2003, 106.492/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OLH2FLAREV	PROCESS VENT FOR OLEFINS H2 FLARE	106.261/11/01/2003, 106.492/09/04/2000
OP1BL3803A	B-38001A, BOILER	1768, N142, PSDTX1272
OP1BL3803B	OP1 BOILER (B-38001B)	1768, N142, PSDTX1272
OP1BL803AV	FUEL GAS PROCESS VENT FOR B-38001A	1768, N142, PSDTX1272
OP1BL803BV	FUEL GAS PROCESS VENT FOR B-38001B	1768, N142, PSDTX1272
OP1CT3811	CT-3811, COOLING TOWER	1768, N142, PSDTX1272
OP1D3626AV	D-3626A, REGEN VENT	1768, N142, PSDTX1272
OP1D3626BV	D-3626B, REGEN VENT	1768, N142, PSDTX1272
OP1D3635AV	D-3635A, REGEN VENT	1768, N142, PSDTX1272
OP1D3635BV	D-3635B, REGEN VENT	1768, N142, PSDTX1272
OP1DECOKE2	DECOKING DRUM VENT	1768, N142, PSDTX1272
OP1DM3420V	VENT FOR D-3420	1768, N142, PSDTX1272
OP1DM3422V	D-3422, DECOKING DRUM VENT	1768, N142, PSDTX1272
OP1DM3453	WASTE CAUSTIC COALESCERS	1768, N142, PSDTX1272
OP1DM3530	D-3530, ANTIFOULANT	1768, N142, PSDTX1272
OP1DM3609	D-3609, HYDROGEN/METHANE SEPARATOR	1768, N142, PSDTX1272
OP1DM3903	DRUM 3903	106.472/09/04/2000
OP1DM3904	D-3904, PROPANE BULLET	1768, N142, PSDTX1272
OP1EN1	BACKUP DIESEL AIR COMPRESSOR	1768, 106.512/06/13/2001, N142, PSDTX1272
OP1EN2	P-38201 A FIREWATER PUMP	106.511/09/04/2000
OP1EN3	P-38201 C FIREWATER PUMP	106.511/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP1FL3801	OPI FLARE	1768, 106.261/11/01/2003, N142, PSDTX1272
OP1FL3801V	PROCESS VENT FOR OP1 FLARE FL-3801	1768, 106.261/11/01/2003, N142, PSDTX1272
OP1HT3401	F-3401, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3401V	FUEL GAS PROCESS VENT FOR F-3401	1768, N142, PSDTX1272
OP1HT3402	F-3402, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3402V	FUEL GAS PROCESS VENT FOR F-3402	1768, N142, PSDTX1272
OP1HT3403	F-3403, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3403V	FUEL GAS PROCESS VENT FOR F-3403	1768, N142, PSDTX1272
OP1HT3404	F-3404, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3404V	FUEL GAS PROCESS VENT FOR F-3404	1768, N142, PSDTX1272
OP1HT3405	F-3405, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3405V	FUEL GAS PROCESS VENT FOR F-3405	1768, N142, PSDTX1272
OP1HT3406	F-3406, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3406V	FUEL GAS PROCESS VENT FOR F-3406	1768, N142, PSDTX1272
OP1HT3407	F-3407, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3407V	FUEL GAS PROCESS VENT FOR F-3407	1768, N142, PSDTX1272
OP1HT3408	F-3408, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3408V	FUEL GAS PROCESS VENT FOR F-3408	1768, N142, PSDTX1272
OP1HT3409	F-3409, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3409V	FUEL GAS PROCESS VENT FOR F-3409	1768, N142, PSDTX1272
OP1HT3410	F-3410, CRACKING HEATER	1768, N142, PSDTX1272

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP1HT3410V	FUEL GAS PROCESS VENT FOR F-3410	1768, N142, PSDTX1272
OP1HT3411	F-3411, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3411V	FUEL GAS PROCESS VENT FOR F-3411	1768, N142, PSDTX1272
OP1HT3412	F-3412, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3412V	FUEL GAS PROCESS VENT FOR F-3412	1768, N142, PSDTX1272
OP1HT3413	F-3413, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3413V	FUEL GAS PROCESS VENT FOR F-3413	1768, N142, PSDTX1272
OP1HT3414	F-3414, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3414V	FUEL GAS PROCESS VENT FOR F-3414	1768, N142, PSDTX1272
OP1HT3415	F-3415, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3415V	FUEL GAS PROCESS VENT FOR F-3415	1768, N142, PSDTX1272
OP1HT3418	F-3418, CRACKING HEATER	1768, N142, PSDTX1272
OP1HT3418V	FUEL GAS PROCESS VENT FOR F-3418	1768, N142, PSDTX1272
OP1HT3419	CRACKING HEATER 3419	1768, N142, PSDTX1272
OP1HT3419V	CRACKING HEATER 3419V	1768, N142, PSDTX1272
OP1HT3601	REGENERATION HEATER	1768, N142, PSDTX1272
OP1HT3601V	FUEL GAS PROCESS VENT FOR F-3601	1768, N142, PSDTX1272
OP1HT3701	DPG RECYCLE HEATER	1768, 156142, N142, PSDTX1272
OP1HT3701V	FUEL GAS PROCESS VENT FOR F-3701	1768, N142, PSDTX1272
OP1HT3804A	F-38001A, SUPERHEATER	1768, N142, PSDTX1272
OP1HT3804B	F-38001B, SUPERHEATER	1768, N142, PSDTX1272

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP1HT804AV	FUEL GAS PROCESS VENT FOR F-38001A	1768, N142, PSDTX1272
OP1HT804BV	FUEL GAS PROCESS VENT FOR F-38001B	1768, N142, PSDTX1272
OP1LDRC	OP1 RAILCAR LOADING	1768, N142, PSDTX1272
OP1LDTT	OP1 TRUCK LOADING	1768, N142, PSDTX1272
OP1PV3804A	OLEFIN SUPERHEATER VENT	1768, N142, PSDTX1272
OP1PV3804B	OLEFIN SUPERHEATER VENT	1768, N142, PSDTX1272
OP1PV38055	FLARE O2 ANALYZER	1768, N142, PSDTX1272
OP1PVJ3402	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1PVJ3403	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1PVJ3404	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1PVJ3405	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1PVJ3406	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1PVJ3409	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1PVJ3410	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1PVJ3415	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1PVJ3501	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1PVJ3602	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1PVJ3603	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1PVJ3604	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1PVJ3605	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1PVJ3606	GC ANALYZER VENTS	1768, N142, PSDTX1272

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP1PVJ3904	GC ANALYZER VENTS	1768, N142, PSDTX1272
OP1RX3701V	D-3701, REGEN VENT	1768, N142, PSDTX1272
OP1RX3702V	D-3702, REGEN VENT	1768, N142, PSDTX1272
OP1RXD3601	D-3601 METHANATOR	1768, N142, PSDTX1272
OP1RXD3626	D-3626A/B ACETYLENE CONVERTOR	1768, N142, PSDTX1272
OP1RXD3635	D-3635A/B MAPD CONVERTER	1768, N142, PSDTX1272
OP1RXD3652	D-3652 CPD TO DCPD REACTOR	1768, N142, PSDTX1272
OP1RXD3701	R-3701 DPG REACTOR	1768, N142, PSDTX1272
OP1RXD3702	R-3702 DPG REACTOR	1768, N142, PSDTX1272
OP1SEAL1	SEAL OIL RESERVOIR VENT	1768, N142, PSDTX1272
OP1SEAL2	SEAL OIL RESERVOIR VENT	1768, N142, PSDTX1272
OP1SEAL3	SEAL OIL RESERVOIR VENT	1768, N142, PSDTX1272
OP1SMLTK01	MISCELLANEOUS SMALL TANK 01	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1SMLTK02	MISCELLANEOUS SMALL TANK 02	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1SMLTK03	MISCELLANEOUS SMALL TANK 03	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1SMLTK04	MISCELLANEOUS SMALL TANK 04	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1SMLTK07	MISCELLANEOUS SMALL TANK 07	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1SMLTK12	MISCELLANEOUS SMALL TANK 12	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1SMLTK13	MISCELLANEOUS SMALL TANK 13	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1SMLTK14	MISCELLANEOUS SMALL TANK 14	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1SMLTK15	MISCELLANEOUS SMALL TANK 15	1768, 106.472/09/04/2000, N142, PSDTX1272

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP1SMLTK16	MISCELLANEOUS SMALL TANK 16	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1SMLTK17	MISCELLANEOUS SMALL TANK 17	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1SMLTK18	MISCELLANEOUS SMALL TANK 18	106.472/09/04/2000
OP1SMLTK19	MISCELLANEOUS SMALL TANK 19	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1SMLTK30	MISCELLANEOUS SMALL TANK 30	106.472/09/04/2000
OP1SP3902	FIREWATER FOAM STORAGE TANK	106.472/09/04/2000
OP1SU3406	SP-3406, OPI CPI SEPARATOR	1768, N142, PSDTX1272
OP1SU3407	SP-3407, OPI CPI SEPARATOR	1768, N142, PSDTX1272
OP1SU3502	SP-3502, OPI CPI SEPARATOR	1768, N142, PSDTX1272
OP1SU3671	SP-3671, OPI CPI SEPARATOR	1768, N142, PSDTX1272
OP1SU38094	SP-38094A/B, OPI CPI SEPARATOR	1768, N142, PSDTX1272
OP1SU38099	SP-38099 SURFACE IMPOUNDMENT	1768, N142, PSDTX1272
OP1SU38601	SP-38601, OPI CPI SEPARATOR	1768, N142, PSDTX1272
OP1TK3406	TK-3406	1768, N142, PSDTX1272
OP1TK3455	TK-3455, WASTE CAUSTIC	1768, N142, PSDTX1272
OP1TK3458	TK-3458	1768, N142, PSDTX1272
OP1TK3462	TK-3462, CORROSION INHIBITOR	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1TK3501	MEA TANK	106.472/09/04/2000
OP1TK3504X	TK-3504X, C-4501A/B LUBE OIL RESERVOIR	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1TK3601	TK-3601, ISOPROPANOL	1768, N142, PSDTX1272
OP1TK3602X	TK-3602X, LUBE OIL RESERVOIR	1768, 106.472/09/04/2000, N142, PSDTX1272

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP1TK3604X	TK-3604X, LUBE OIL RESERVOIR	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1TK3609	TK-3609, ANITFOULANT	1768, 106.261/11/01/2003, 106.262/11/01/2003, 106.472/09/04/2000, N142, PSDTX1272
OP1TK3701	TK-3701 LUBE OIL	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1TK3701X	TK-3701X, C-3702 LUBE OIL RESERVOIR	1768, 106.472/09/04/2000, N142, PSDTX1272
OP1TK38008	TK-38008, CPI SLOP OIL SUCT	1768, N142, PSDTX1272
OP1TK38009	TK-38009, CPI WW SUCTION	1768, N142, PSDTX1272
OP1TK38010	TK-38010, PROCESS WW	1768, N142, PSDTX1272
OP1TK38011	TK-38011, PROCESS WW	1768, N142, PSDTX1272
OP1TK38301	TK-38301 PFO	1768, N142, PSDTX1272
OP1TK38302	TK-38302 PGO	1768, N142, PSDTX1272
OP1TK38303	TK-38303, PGO/LRO	1768, 106.261/11/01/2003, 106.262/11/01/2003, 106.472/09/04/2000, N142, PSDTX1272
OP1TK3901	TK-3901, HEATER FEED	1768, N142, PSDTX1272
OP1TK3902	TK-3902, HEATER FEED	1768, N142, PSDTX1272
OP1TK3903	STORMWATER TANK	1768, N142, PSDTX1272
OP1TK3904	TK-3904, HEATER FEED	1768, N142, PSDTX1272
OP1TK3905	TK-3905, HEATER FEED	1768, N142, PSDTX1272
OP1TK3906	TK-3906, HEATER FEED	1768, N142, PSDTX1272
OP1TK3907	TK-3907, HEATER FEED	1768, N142, PSDTX1272
OP1TK3908	TK-3908, BUTENE STORAGE SPHERE	1768, N142, PSDTX1272

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP1TK3909	TK-3909, OFF-SPEC C4 STORAGE SPHERE	1768, N142, PSDTX1272
OP1TK3910	TK-3910, CRUDE C4 STORAGE SPHERE	1768, N142, PSDTX1272
OP1TK3911	TK-3911, PYROLYSIS GASOLINE	1768, N142, PSDTX1272
OP1TK3912	TK-3912, PYROLYSIS GASOLINE	1768, N142, PSDTX1272
OP1TK3913	TK-3913, PYROLYSIS FUEL OIL	1768, N142, PSDTX1272
OP1TK3914	TK-3914, LYONDELL RESIN OIL	1768, N142, PSDTX1272
OP1TK3943	LCO TANK	1768, N142, PSDTX1272
OP1TK4501	MEA TANK	106.472/09/04/2000
OP1TW3401	T-3401 GASOLINE FRACTIONATOR	1768, N142, PSDTX1272
OP1TW3402	T-3402 PYROLYSIS FUEL OIL STRIPPER	1768, N142, PSDTX1272
OP1TW3403	T-3403 QUENCH TOWER	1768, N142, PSDTX1272
OP1TW3405	T-3405 GAS OIL STRIPPER	1768, N142, PSDTX1272
OP1TW3407	T-3407 NESHAP STRIPPER	1768, N142, PSDTX1272
OP1TW3450	T-3450 GASOLINE STRIPPER	1768, N142, PSDTX1272
OP1TW3453	T-3453 LRO STRIPPER	1768, N142, PSDTX1272
OP1TW3502	TW-3502 CONDENSATE STRIPPER	1768, N142, PSDTX1272
OP1TW3504	T-3504 CAUSTIC WASH TOWER	1768, N142, PSDTX1272
OP1TW3507	T-3507 PROCESS WATER STRIPPER	1768, N142, PSDTX1272
OP1TW35203	T-25203	1768, N142, PSDTX1272
OP1TW3601	T-3601 DEMETHANIZER	1768, N142, PSDTX1272
OP1TW3602	T-3602 DEETHANIZER	1768, N142, PSDTX1272

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP1TW3604	T-3604, ETHYLENE FRACTIONATOR	1768, N142, PSDTX1272
OP1TW3605	T-3605 DEBUTANIZER	1768, N142, PSDTX1272
OP1TW3606	T-3606 DEPENTANIZER 1	1768, N142, PSDTX1272
OP1TW3608	T-3608 C3 STRIPPER/GREEN OIL TOWER	1768, N142, PSDTX1272
OP1TW3614	T-3614 METHANE STRIPPER	1768, N142, PSDTX1272
OP1TW3615	T-3615 PRECUT DEMETHANIZER	1768, N142, PSDTX1272
OP1TW3616	T-3616 C2 GREEN OIL TOWER	1768, N142, PSDTX1272
OP1TW3617	T-3617 DEPROPANIZER	1768, N142, PSDTX1272
OP1TW3618	T-3618 DEPENTANIZER 2	1768, N142, PSDTX1272
OP1TW3701	T-3701 H2S STRIPPER	1768, N142, PSDTX1272
OP1TW3702	T-3702 H2S STRIPPER	1768, N142, PSDTX1272
OP2BL4803A	B-48001A, BOILER	2933, N140, PSDTX1270
OP2BL4803B	B-48001B, BOILER	2933, N140, PSDTX1270
OP2BL803AV	FUEL GAS PROCESS VENT FOR B-48001A	2933, N140, PSDTX1270
OP2BL803BV	FUEL GAS PROCESS VENT FOR B-48001B	2933, N140, PSDTX1270
OP2CT4811	OP2 COOLING TOWER	2933, N140, PSDTX1270
OP2D4626AV	D-4626A, REGEN VENT	2933, N140, PSDTX1270
OP2D4626BV	D-4626B, REGEN VENT	2933, N140, PSDTX1270
OP2D4635AV	D-4635A, REGEN VENT	2933, N140, PSDTX1270
OP2D4635BV	D-4635B, REGEN VENT	2933, N140, PSDTX1270
OP2DECOKE2	DECOKING DRUM VENT	2933, N140, PSDTX1270

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP2DM4420V	VENT FOR D-4420	2933, N140, PSDTX1270
OP2DM4422V	D-4422, DECOKING DRUM VENT	84079
OP2DM4453	WASTE CAUSTIC COALESCERS	2933, N140, PSDTX1270
OP2DM4609	D-4609 HYDROGEN/METHANE SEPARATOR	2933, N140, PSDTX1270
OP2DM4643	D-4643, DISTRIBUTOR POT FOR E-4695	2933, N140, PSDTX1270
OP2EN1	BACKUP DIESEL AIR COMPRESSOR	2933, 106.512/06/13/2001, N140, PSDTX1270
OP2EN2	P-48201 A FIREWATER PUMP	106.511/09/04/2000
OP2EN3	P-48201 C FIREWATER PUMP	106.511/09/04/2000
OP2FL4801	OPII FLARE	146636, 2933, 106.261/11/01/2003, 106.262/11/01/2003, N140, PSDTX1270
OP2FL4801V	PROCESS VENT FOR OP2 FLARE FL-4801	146636, 2933, 106.261/11/01/2003, 106.262/11/01/2003, N140, PSDTX1270, PSDTX1272
OP2HT4401	F-4401, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4401V	FUEL GAS PROCESS VENT FOR F-4401	2933, N140, PSDTX1270
OP2HT4402	F-4402, CRACKING HEATER	2933, 150877, N140, PSDTX1270
OP2HT4402V	FUEL GAS PROCESS VENT FOR F-4402	2933, N140, 150877, PSDTX1270
OP2HT4403	F-4403, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4403V	FUEL GAS PROCESS VENT FOR F-4403	2933, N140, PSDTX1270
OP2HT4404	F-4404, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4404V	FUEL GAS PROCESS VENT FOR F-4404	2933, N140, PSDTX1270
OP2HT4405	F-4405, CRACKING HEATER	2933, N140, PSDTX1270

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP2HT4405V	FUEL GAS PROCESS VENT FOR F-4405	2933, N140, PSDTX1270
OP2HT4406	F-4406, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4406V	FUEL GAS PROCESS VENT FOR F-4406	2933, N140, PSDTX1270
OP2HT4407	F-4407, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4407V	FUEL GAS PROCESS VENT FOR F-4407	2933, N140, PSDTX1270
OP2HT4408	F-4408, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4408V	FUEL GAS PROCESS VENT FOR F-4408	2933, N140, PSDTX1270
OP2HT4409	F-4409, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4409V	FUEL GAS PROCESS VENT FOR F-4409	2933, N140, PSDTX1270
OP2HT4410	F-4410, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4410	F-4410, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4410V	FUEL GAS PROCESS VENT FOR F-4410	2933, N140, PSDTX1270
OP2HT4411	F-4411, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4411V	FUEL GAS PROCESS VENT FOR F-4411	2933, N140, PSDTX1270
OP2HT4412	F-4412, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4412V	FUEL GAS PROCESS VENT FOR F-4412	2933, N140, PSDTX1270
OP2HT4413	F-4413, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4413V	FUEL GAS PROCESS VENT FOR F-4413	2933, N140, PSDTX1270
OP2HT4414	F-4414, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4414V	FUEL GAS PROCESS VENT FOR F-4414	2933, N140, PSDTX1270
OP2HT4414V	FUEL GAS PROCESS VENT FOR F-4414	2933, N140, PSDTX1270

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP2HT4415	F-4415, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4415V	FUEL GAS PROCESS VENT FOR F-4415	2933, N140, PSDTX1270
OP2HT4415V	FUEL GAS PROCESS VENT FOR F-4415	2933, N140, PSDTX1270
OP2HT4418	F-4418, CRACKING HEATER	2933, N140, PSDTX1270
OP2HT4418V	FUEL GAS PROCESS VENT FOR F-4418	2933, N140, PSDTX1270
OP2HT4418V	FUEL GAS PROCESS VENT FOR F-4418	2933, N140, PSDTX1270
OP2HT4419	CRACKING HEATER 4419	2933, N140, PSDTX1270
OP2HT4419V	CRACKING HEATER 4419V	2933, N140, PSDTX1270
OP2HT4601	F-4601 REGENERATION HEATER	2933, N140, PSDTX1270
OP2HT4601V	FUEL GAS PROCESS VENT FOR F-4601	2933, N140, PSDTX1270
OP2HT4804A	F-48001A SUPERHEATER	2933, N140, PSDTX1270
OP2HT4804B	F-48001B SUPERHEATER	2933, N140, PSDTX1270
OP2HT804AV	FUEL GAS PROCESS VENT FOR F-48001A	2933, N140, PSDTX1270
OP2HT804BV	FUEL GAS PROCESS VENT FOR F-48001B	2933, N140, PSDTX1270
OP2LOAD	OP-2 TRUCK LOADING	106.472/09/04/2000
OP2PV4804A	OLEFINS VENT	2933, N140, PSDTX1270
OP2PV4804B	OLEFINS VENT	2933, N140, PSDTX1270
OP2PV48055	FLARE O2 ANALYZER	2933, N140, PSDTX1270
OP2PVJ4301	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4303	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4308	ANALYZER VENTS	2933, N140, PSDTX1270

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP2PVJ4402	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4403	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4404	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4405	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4406	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4407	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4408	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4409	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4410	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4415	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4501	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4602	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4603	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4604	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4605	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4606	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4607	ANALYZER VENTS	2933, N140, PSDTX1270
OP2PVJ4611	ANALYZER VENTS	2933, N140, PSDTX1270
OP2RX4701	R-4701 DPG REACTOR	2933, N140, PSDTX1270
OP2RX4701V	R-4701, REGEN VENT	2933, N140, PSDTX1270
OP2RX4703	R-4703 DPG REACTOR	2933, N140, PSDTX1270

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP2RX4703V	R-4703, REGEN VENT	2933, N140, PSDTX1270
OP2RXD4601	D-4601 METHANATOR	2933, N140, PSDTX1270
OP2RXD4626	D-4626A/B ACETYLENE CONVERTER	2933, N140, PSDTX1270
OP2RXD4635	D-4635 A/B MAPD CONVERTOR	2933, N140, PSDTX1270
OP2RXD4652	D-4652 CPD TO DCPD REACTOR	2933, N140, PSDTX1270
OP2SMLTK01	MISCELLANEOUS SMALL TANK 01	2933, 106.472/09/04/2000, N140, PSDTX1270
OP2SMLTK02	MISCELLANEOUS SMALL TANK 02	2933, N140, PSDTX1270
OP2SMLTK03	MISCELLANEOUS SMALL TANK 03	2933, N140, PSDTX1270
OP2SMLTK04	MISCELLANEOUS SMALL TANK 04	2933, N140, PSDTX1270
OP2SMLTK05	MISCELLANEOUS SMALL TANK 05	2933, N140, PSDTX1270
OP2SMLTK08	MISCELLANEOUS SMALL TANK 08	2933, N140, PSDTX1270
OP2SMLTK10	MISCELLANEOUS SMALL TANK 10	2933, N140, PSDTX1270
OP2SMLTK12	MISCELLANEOUS SMALL TANK 12	2933, 106.472/09/04/2000, N140, PSDTX1270
OP2SMLTK13	MISCELLANEOUS SMALL TANK 13	2933, N140, PSDTX1270
OP2SMLTK15	MISCELLANEOUS SMALL TANK 15	2933, N140, PSDTX1270
OP2SMLTK16	MISCELLANEOUS SMALL TANK 16	2933, N140, PSDTX1270
OP2SMLTK17	MISCELLANEOUS SMALL TANK 17	2933, 106.472/09/04/2000, N140, PSDTX1270
OP2SMLTK31	MISCELLANEOUS SMALL TANK 31	106.472/09/04/2000
OP2SU4406	OP2 CPI SEPARATOR (SP-4406)	2933, N140, PSDTX1270
OP2SU4407	OP2 CPI SEPARATOR (SP-4407)	2933, N140, PSDTX1270
OP2SU4502	OP2 CPI SEPARATOR (SP-4502)	2933, N140, PSDTX1270

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP2SU4671	OP2 CPI SEPARATOR (SP-4671)	2933, N140, PSDTX1270
OP2SU48094	OP2 CPI SEPARATOR (SP-48094)	2933, N140, PSDTX1270
OP2SU48099	SP-48099	2933, N140, PSDTX1270
OP2SU48601	OP2 CPI SEPARATOR (SP-48601)	2933, N140, PSDTX1270
OP2TK4451	TK-4451, CAUSTIC	2933, N140, PSDTX1270
OP2TK4455	TK-4455, WASTE CAUSTIC	2933, 106.261/11/01/2003, 106.262/11/01/2003, N140, PSDTX1270
OP2TK4456	TK-4456, WASHWATER	2933, N140, PSDTX1270
OP2TK4458	TK-4458	2933, N140, PSDTX1270
OP2TK4462	TK-4462, CORROSION INHIBITOR	2933, 106.472/09/04/2000, N140, PSDTX1270
OP2TK4465	TK-4465	2933, N140, PSDTX1270
OP2TK4504X	TK-4504X, C4501A/B LUBE OIL RESERVOIR	2933, N140, PSDTX1270
OP2TK4511	TK-4511, ANTIFOULANT	2933, 106.261/11/01/2003, 106.262/11/01/2003, N140, PSDTX1270
OP2TK4601	TK-4601, ISOPROPANOL	2933, N140, PSDTX1270
OP2TK4602X	TK-4602X, LUBE OIL RESERVOIR	2933, N140, PSDTX1270
OP2TK4604X	TK-4604X, LUBE OIL	2933, N140, PSDTX1270
OP2TK4607	TK-4607, ANTIFOULANT	2933, N140, PSDTX1270
OP2TK48007	TK-48007 PFO	2933, N140, PSDTX1270
OP2TK48008	TK-48008, SLOP OIL SUCTION	2933, N140, PSDTX1270
OP2TK48009	TK-48009, SLOP OIL SUCTION	2933, N140, PSDTX1270

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP2TK48010	TK-48010 PROCESS WW AND STORMWATER	2933, N140, PSDTX1270
OP2TK48011	TK-48011 PROCESS WW AND STORMWATER	2933, N140, PSDTX1270
OP2TK48105	TK-48105 LUBE OIL	106.472/09/04/2000
OP2TK48302	TK-48302, PYROLYSIS GAS OIL	2933, N140, PSDTX1270
OP2TK48303	TK-48303 SLOP OIL	2933, N140, PSDTX1270
OP2TK48304	TK-48304, PYROLYSIS FUEL OIL	2933, N140, PSDTX1270
OP2TK48305	TK-48305, PYROLYSIS GAS OIL	2933, 106.472/09/04/2000, N140, PSDTX1270
OP2TK48615	TK-48615, CORROSION INHIBITOR	106.472/09/04/2000
OP2TK48616	TK-48616, CORROSION INHIBITOR	106.472/09/04/2000
OP2TK48620	TK-48620, OXYGEN SCAVENGE	106.472/09/04/2000
OP2TK4901	TK-4901, HEATER FEED	2933, N140, PSDTX1270
OP2TK4902	TK-4902, HEATER FEED	2933, N140, PSDTX1270
OP2TK4903	TK-4903, HEATER FEED	2933, N140, PSDTX1270
OP2TK4904	TK-4904, HEATER FEED	2933, N140, PSDTX1270
OP2TK4905	TK-4905, HEATER FEED	2933, 106.478/09/04/2000, N140, PSDTX1270
OP2TK4906	TK-4906, HEATER FEED	2933, N140, PSDTX1270
OP2TK4907	TK-4907, HEATER FEED	2933, N140, PSDTX1270
OP2TK4915	TK-4915, PYROLYSIS GAS OIL	2933, N140, PSDTX1270
OP2TK4916	TK-4916, BENZENE	2933, 106.261/11/01/2003, 106.262/11/01/2003, N140, PSDTX1270
OP2TK4917	TK-4917, LPG/TOLUENE	2933, 106.261/11/01/2003, 106.262/11/01/2003, N140,

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
		PSDTX1270
OP2TK4919	TK-4919, LPG/TOLUENE	2933, N140, PSDTX1270
OP2TK4921	TK-4921, HEAVY PYROLYSIS GAS	2933, N140, PSDTX1270
OP2TK4922	TK-4922, PYROLYSIS GAS/BENZENE	2933, 106.261/11/01/2003, 106.262/11/01/2003, N140, PSDTX1270
OP2TW4401	T-4401 GASOLINE FRACTIONATOR	2933, N140, PSDTX1270
OP2TW4402	T-4402 PYROLYSIS FUEL OIL STRIPPER	2933, N140, PSDTX1270
OP2TW4403	T-4403 QUENCH TOWER	2933, N140, PSDTX1270
OP2TW4405	T-44O5 GAS OIL STRIPPER	2933, N140, PSDTX1270
OP2TW4407	OP2 BENZENE NESHAPS STRIPPER	2933, N140, PSDTX1270
OP2TW44104	DISTILLATION UNIT	2933, N140, PSDTX1270
OP2TW4450	T-4450 GASOLINE STRIPPER	2933, N140, PSDTX1270
OP2TW4453	OP2 NESHAPS STRIPPER	2933, N140, PSDTX1270
OP2TW4502	T-4502 CONDENSATE STRIPPER	2933, N140, PSDTX1270
OP2TW4504	T-5404 CAUSTIC WASH TOWER	2933, N140, PSDTX1270
OP2TW4507	T-4507 PROCESS WATER STRIPPER	2933, N140, PSDTX1270
OP2TW45203	T-45203 WASH TOWER	2933, N140, PSDTX1270
OP2TW4601	T-4601 DEMETHANIZER	2933, N140, PSDTX1270
OP2TW4602	T-4602 DEETHANIZER	2933, N140, PSDTX1270
OP2TW4604	T-4604 ETHYLENE FRACTIONATOR	2933, N140, PSDTX1270
OP2TW4605	T-4605 DEBUTANIZER	2933, N140, PSDTX1270

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
OP2TW4606	T-4606 DEPENTANIZER 1	2933, N140, PSDTX1270
OP2TW4608A	T-4608A C3 GREEN OIL TOWER	2933, N140, PSDTX1270
OP2TW4608B	T-4608B C3 GREEN OIL TOWER STRIPPER	2933, N140, PSDTX1270
OP2TW4609	T-4609 PROPYLENE FRACTIONATOR	2933, N140, PSDTX1270
OP2TW4610	T-4610 PROPYLENE FRACTIONATOR	2933, N140, PSDTX1270
OP2TW4614	T-4614 ETHYLENE FRACT VENT STRIPPER	2933, N140, PSDTX1270
OP2TW4615	T-4615 PRECUT DEMETHANIZER	2933, N140, PSDTX1270
OP2TW4616	T-4616 C2 GREEN OIL TOWER	2933, N140, PSDTX1270
OP2TW4617	T-4617 DEPROPANIZER	2933, N140, PSDTX1270
OP2TW4618	T-4618 DEPENTANIZER 2	2933, N140, PSDTX1270
OP2TW4701	T-4701 STABILIZER TOWER (H2S STRIPPER)	2933, N140, PSDTX1270
OP2VJ48013	ANALYZER VENTS	2933, N140, PSDTX1270
PRO-ALKY	SITE-WIDE REQUIREMENTS	24887
PRO-BT	BT HON PROCESS UNIT	2936
PRO-C4	C4 CHEMICAL MAUFACTURING PROCESS	2128
PRO-C5	C5 PROCESS UNIT	6245
PRO-DPG	DPG PROCESS AREA	1768, N142, PSDTX1272
PRO-FLEX	OLEFINS FLEX OPERATION AREA	2933, N140, PSDTX1270
PRO-IPOH	IPOH PROCESS UNIT	49130
PRO-MEO	METHANOL PROCESS UNIT	8125, N144, PSDTX1280M1
PRO-MTBE	MTBE HON PROCESS UNIT	6387

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
PRO-OP1	OP1 PROCESS UNIT	1768, N142, PSDTX1272
PRO-OP2	OP2 PROCESS UNIT	2933, N140, PSDTX1270
PRO-POLYBD	SMA PROCESS UNIT	22779
PRO-SMA	SITE-WIDE REQUIREMENTS	24677
WASTEWATER	WASTEWATER	1768, 2933, 8125, 106.262/11/01/2003, N140, N142, N144, PSDTX1270, PSDTX1272, PSDTX1280M1
ZMSENAIS	AIS BASIC DIESEL ENGINE	106.512/06/13/2001
ZMSZZCOAT	FACILITY PAINTING AND COATING	106.433/09/04/2000

Schedules

Compliance Schedule 702

Compliance Schedule

A. Compliance Schedule				
1. Specific Non-Compliance Situation				
Unit/Group/ Process ID. No(s).	**SOP Index No.**	**Pollutant**	**Applicable Requirement**	
			Citation	**Text Description**
EUTFL1701V	N/A	VOC	NSR 2128 SC 11.D	THE ANALYZER SHALL OPERATE AS REQUIRED BY THIS SECTION AT LEAST 95 PERCENT OF THE TIME WHEN THE FLARE IS OPERATIONAL, AVERAGED OVER A ROLLING 12 MONTH PERIOD.

2. Compliance Status Assessment Method and Records Location		
Compliance Status Assessment Method		**Location of Records/Documentation**
Citation	**Text Description**	
NSR 2128 SC 11.D	Monitor on-stream time of flare analyzer monitoring system.	Environmental department files

3. Non-compliance Situation Description
The flare composition analyzer on-stream time is less than 95% over a rolling 12 month period.
4. Corrective Action Plan Description
Equistar will implement process design change to improve the analyzer on-stream reliability.
5. List of Activities/Milestones to Implement the Corrective Action Plan

1	Implementing system design changes where the reported deviation, being subject to rolling 12 month measurement period, will be brought into compliance by 2Q 2017.

6. Previously Submitted Compliance Plan(s)	**Type of Action**	**Date Submitted**
	N/A	

7. Progress Report Submission Schedule	EVERY SIX (6) MONTHS (WITH SEMIANNUAL DEVIATION REPORTS)

Alternative Requirement

Alternative Requirement..... 704

Buddy Garcia, *Chairman*
Larry R. Soward, *Commissioner*
Bryan W. Shaw, Ph.D., *Commissioner*
Glenn Shankle, *Executive Director*

JAN 2 3 2008

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

January 18, 2008

Mr. Don Holloway, P.E.
Environmental Superintendent
Equistar Chemicals, LP
P.O. Box 777
Channelview, TX 77530-0777

Re: Testing Waiver Request for the Olefines Plant 1 Flare, Texas Commission on Environmental Quality (TCEQ) Permit No. 1768, Emission Point Number (EPN) 38E01, Air Account No. HG-0033-B, RN100542281, CN600124705, Subject to title 40 Code of Federal Regulations Parts 60 (40 CFR 60), Subpart NNN and 40 CFR 63, Subparts SS and FFFF.

Dear Mr. Holloway:

The purpose of this letter is to respond to your November 12, 2007 request to waive testing the Olefines Plant 1 Flare, EPN 38E01 based upon 40 CFR 60, Subpart A, section (§) 60.8(b)(4) and 40 CFR 63, Subpart A, 63.7(e)(2)(iv). The flare flow rate and net heating value of the gas combusted are continuously monitored by the instruments noted below:

GE Panametrics ultrasonic flowmeter, Model GM868-1-11-21004-FM-S, Serial # 1024

Siemens Maxum II Gas Chromatograph, Serial # 5059150001

These instruments are installed, operated, and maintained according to the requirements of 30 Texas Administrative Code Chapter 115, §115.725(d), and may demonstrate by other means to the TCEQ that the facility is in compliance with the standard.

By copy of this letter we are informing the Environmental Protection Agency, Region 6, of this decision as required by TCEQ's delegation of authority. If you have any questions, please contact me at (512) 239-1676.

Sincerely,

John R. Smith

John R. Smith
Air Program Support Section
Field Operations Support Division

JRS/

cc: Mr. David Garcia, 6EN-A, USEPA Region 6, 1445 Ross Avenue, Suite 1200, Dallas, Texas 75202-2733

Mr. Joel Anderson, Air Section Manager, TCEQ Field Operations Division, Houston Regional Office

Buddy Garcia, *Chairman*
Larry R. Soward, *Commissioner*
Bryan W. Shaw, Ph.D., *Commissioner*
Glenn Shankle, *Executive Director*

APR - 4 2008

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

March 31, 2008

Mr. Don Holloway, P. E.
Environmental Superintendent
Equistar Chemicals, LP
P.O. Box 777
Channelview, TX 77530-0777

Re: Testing Waiver Request for the Olefins Plant II Flare, Texas Commission on Environmental Quality (TCEQ) Permit No. 2933, Emission Point Number (EPN) 48E01, Air Account No. HG-0033-B, RN 100542281, CN 600124705 Subject to title 40 Code of Federal Regulations Part 63 (40 CFR 63), Subparts SS and FFFF.

Dear Mr. Holloway:

The purpose of this letter is to respond to your March 5, 2008 request to waive testing the Olefins Plant II Flare EPN 48E01 based upon 40 CFR 63, Subpart A, 63.7(e)(2)(iv). The flare flow rate and net heating value of the gas combusted are continuously monitored by the instruments noted below:

GE Panametric Ultrasonic Flowmeter model GF868, Serial No. 1022

Siemens Maxim II Gas Chromatograph, Serial No. 5059150003

These instruments are installed, operated, and maintained according to the requirements of 30 Texas Administrative Code Chapter 115, §115.725(d), and may demonstrate by other means to the TCEQ that the facility is in compliance with the standard.

By copy of this letter we are informing the Environmental Protection Agency, Region 6, of this decision as required by TCEQ's delegation of authority. If you have any questions, please contact me at (512) 239-1676.

Sincerely,

John R. Smith

John R. Smith
Air Program Support Section
Field Operations Support Division

JRS/

cc: Mr. David Garcia, 6EN-A, USEPA Region 6, 1445 Ross Avenue, Suite 1200, Dallas, Texas 75202-2733

Mr. Joel Anderson, Air Section Manager, TCEQ Field Operations Division, Houston Regional Office

APIRT
AUG 18 2008

Buddy Garcia, *Chairman*
Larry R. Soward, *Commissioner*
Bryan W. Shaw, Ph.D., *Commissioner*
Glenn Shankle, *Executive Director*

APR - 4 2008

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

March 31, 2008

Mr. Don Holloway, P. E.
Environmental Superintendent
Equistar Chemicals, LP
P.O. Box 777
Channelview, TX 77530-0777

Re: Testing Waiver Request for the Butadiene Polymer Production Unit Flare, Texas Commission on Environmental Quality (TCEQ) Permit No. 22779, Emission Point Number (EPN) 25E02, Air Account No. HG-0033-B, RN 100542281, CN 600124705 Subject to title 40 Code of Federal Regulations Part 63 (40 CFR 63), Subparts SS and FFFF.

Dear Mr. Holloway:

The purpose of this letter is to respond to your March 5, 2008 request to waive testing the Butadiene Polymer Production Unit Flare EPN 25E02 based upon 40 CFR 63, Subpart A, 63.7(e)(2)(iv). The flare flow rate and net heating value of the gas combusted are continuously monitored by the instruments noted below:

GE Panametric Ultrasonic Flowmeter model GF868, Serial No. 1025

Siemens Maxim II Gas Chromatograph, Serial No. 5059150005

These instruments are installed, operated, and maintained according to the requirements of 30 Texas Administrative Code Chapter 115, §115.725(d), and may demonstrate by other means to the TCEQ that the facility is in compliance with the standard.

By copy of this letter we are informing the Environmental Protection Agency, Region 6, of this decision as required by TCEQ's delegation of authority. If you have any questions, please contact me at (512) 239-1676.

Sincerely,

John R. Smith

John R. Smith
Air Program Support Section
Field Operations Support Division

JRS/

cc: Mr. David Garcia, 6EN-A, USEPA Region 6, 1445 Ross Avenue, Suite 1200, Dallas, Texas 75202-2733

Mr. Joel Anderson, Air Section Manager, TCEQ Field Operations Division, Houston Regional Office

APIRT
AUG 18 2008

Buddy Garcia, *Chairman*
Larry R. Soward, *Commissioner*
Bryan W. Shaw, Ph.D., *Commissioner*
Glenn Shankle, *Executive Director*

APR - 4 2008

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

March 31, 2008

Mr. Don Holloway, P. E.
Environmental Superintendent
Equistar Chemicals, LP
P.O. Box 777
Channelview, TX 77530-0777

Re: Testing Waiver Request for the Isopropyl Alcohol Unit Flare, Texas Commission on Environmental Quality (TCEQ) Permit No. 49130, Emission Point Number (EPN) 25E01, Air Account No. HG-0033-B, RN 100542281, CN 600124705 Subject to title 40 Code of Federal Regulations Part 63 (40 CFR 63), Subparts SS and FFFF.

Dear Mr. Holloway:

The purpose of this letter is to respond to your March 5, 2008 request to waive testing the Isopropyl Alcohol Unit Flare EPN 25E01 based upon 40 CFR 63, Subpart A, 63.7(e)(2)(iv). The flare flow rate and net heating value of the gas combusted are continuously monitored by the instruments noted below:

GE Panametric Ultrasonic Flowmeter model GF868, Serial No. 1026

Siemens Maxim II Gas Chromatograph, Serial No. 5059150006

These instruments are installed, operated, and maintained according to the requirements of 30 Texas Administrative Code Chapter 115, §115.725(d), and may demonstrate by other means to the TCEQ that the facility is in compliance with the standard.

By copy of this letter we are informing the Environmental Protection Agency, Region 6, of this decision as required by TCEQ's delegation of authority. If you have any questions, please contact me at (512) 239-1676.

Sincerely,

John R. Smith

John R. Smith
Air Program Support Section
Field Operations Support Division

APIRT
AUG 18 2008

JRS/

cc: Mr. David Garcia, 6EN-A, USEPA Region 6, 1445 Ross Avenue, Suite 1200, Dallas, Texas 75202-2733

Mr. Joel Anderson, Air Section Manager, TCEQ Field Operations Division, Houston Regional Office

APIRT
AUG 18 2008

Buddy Garcia, *Chairman*
Larry R. Soward, *Commissioner*
Bryan W. Shaw, Ph.D., *Commissioner*
Glenn Shankle, *Executive Director*

APR - 4 2008

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

March 31, 2008

Mr. Don Holloway, P. E.
Environmental Superintendent
Equistar Chemicals, LP
P.O. Box 777
Channelview, TX 77530-0777

Re: Testing Waiver Request for the Alkylation Flare, Texas Commission on Environmental Quality (TCEQ) Permit No. 24877, Emission Point Number (EPN) E607, Air Account No. HG-0033-B, RN 100542281, CN 600124705 Subject to title 40 Code of Federal Regulations Part 63 (40 CFR 63), Subparts SS and FFFF.

Dear Mr. Holloway:

The purpose of this letter is to respond to your March 5, 2008 request to waive testing the Alkylation Flare EPN E607 based upon 40 CFR 63, Subpart A, 63.7(e)(2)(iv). The flare flow rate and net heating value of the gas combusted are continuously monitored by the instruments noted below:

GE Panametric Ultrasonic Flowmeter model GF868, Serial No. 1023

Siemens Maxim II Gas Chromatograph, Serial No. 5059150011

These instruments are installed, operated, and maintained according to the requirements of 30 Texas Administrative Code Chapter 115, §115.725(d), and may demonstrate by other means to the TCEQ that the facility is in compliance with the standard.

By copy of this letter we are informing the Environmental Protection Agency, Region 6, of this decision as required by TCEQ's delegation of authority. If you have any questions, please contact me at (512) 239-1676.

Sincerely,

John R. Smith

John R. Smith
Air Program Support Section
Field Operations Support Division

APIRT
AUG 18 2008

JRS/

cc: Mr. David Garcia, 6EN-A, USEPA Region 6, 1445 Ross Avenue, Suite 1200, Dallas, Texas 75202-2733

Mr. Joel Anderson, Air Section Manager, TCEQ Field Operations Division, Houston Regional Office

APIRT
AUG 18 2008

Appendix A

Acronym List 715

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM ..... actual cubic feet per minute
AMOC ..... alternate means of control
ARP ..... Acid Rain Program
ASTM ..... American Society of Testing and Materials
B/PA ..... Beaumont/Port Arthur (nonattainment area)
CAM ..... Compliance Assurance Monitoring
CD ..... control device
CEMS ..... continuous emissions monitoring system
CFR ..... Code of Federal Regulations
COMS ..... continuous opacity monitoring system
CVS ..... closed vent system
D/FW ..... Dallas/Fort Worth (nonattainment area)
EP ..... emission point
EPA ..... U.S. Environmental Protection Agency
EU ..... emission unit
FCAA Amendments ..... Federal Clean Air Act Amendments
FOP ..... federal operating permit
gr/100 scf ..... grains per 100 standard cubic feet
HAP ..... hazardous air pollutant
H/G/B ..... Houston/Galveston/Brazoria (nonattainment area)
H_2S ..... hydrogen sulfide
ID No. ..... identification number
lb/hr ..... pound(s) per hour
MACT ..... Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr ..... Million British thermal units per hour
NA ..... nonattainment
N/A ..... not applicable
NADB ..... National Allowance Data Base
NESHAP ..... National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO_x ..... nitrogen oxides
NSPS ..... New Source Performance Standard (40 CFR Part 60)
NSR ..... New Source Review
ORIS ..... Office of Regulatory Information Systems
Pb ..... lead
PBR ..... Permit By Rule
PEMS ..... predictive emissions monitoring system
PM ..... particulate matter
ppmv ..... parts per million by volume
PRO ..... process unit
PSD ..... prevention of significant deterioration
psia ..... pounds per square inch absolute
SIP ..... state implementation plan
SO_2 ..... sulfur dioxide
TCEQ ..... Texas Commission on Environmental Quality
TSP ..... total suspended particulate
TVP ..... true vapor pressure
U.S.C. ..... United States Code
VOC ..... volatile organic compound

Appendix B

Major NSR Summary Table 717

Major NSR Summary Table

Permit Numbers: 1768 and PSDTX1272 and N142					Issuance Date: December 28, 2018		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Conditions/ Application Information	Special Conditions/ Application Information	Special Conditions/ Application Information
F34E00	OP1 Fugitives (5)	VOC	73.75	318.55	9, 14, 15, 17, 18, 19, 20	15, 17	
		NH_3	0.12	0.53			
34FGWATER	OP1 Wastewater Fugitives	VOC	1.35	5.89	28	28	
		Acetone	<0.01	<0.01			
EOP1FUGEXP	OP1 Fugitives (5)	VOC	0.46	2.01	21	21	
EFUGNH3	OP1 NH3 Fugitives (5)	NH_3	0.27	1.18	14, 15	15	
34E08	Decoke Vent	CO	132.00	113.75	24		
		PM	36.00	6.50			
		PM_{10}	36.00	6.50			
		$PM_{2.5}$	36.00	6.50			
		VOC	0.11	0.10			
EOP1DECOKE2	Decoke Vent 2	CO	310.00	59.60	24		
		VOC	0.08	0.02			
		PM	1.07	0.10			
		PM_{10}	1.07	0.10			
		$PM_{2.5}$	1.07	0.10			
34E10	Reactor Regeneration Vent	CO	3.56	1.02		25	
		SO_2	9.51	2.23			
		VOC	1.38	0.17			
38E11	OP1 Cooling Tower	VOC	10.58	19.87	26, 27	26, 27	
		PM	6.62	29.00			

Major NSR Summary Table

Permit Numbers: 1768 and PSDTX1272 and N142					Issuance Date: December 28, 2018		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Conditions/ Application Information	Special Conditions/ Application Information	Special Conditions/ Application Information
		PM_{10}	3.31	14.50			
		$PM_{2.5}$	0.01	0.06			
35E03	Seal Oil Reservoir Vent	VOC	0.01	0.01			
35E04	Seal Oil Reservoir Vent	VOC	0.01	0.01			
34PVD3420	Dilution Generator Vent	VOC	1.69	0.14			
		Acetone	0.05	<0.01			
34STMFUG	Dilution Steam Vent	VOC	0.85	1.86			
		Acetone	0.02	0.05			
38HTF3804A/B	Superheater Vents	VOC	3.81	0.01			
34HTHTRS	Pyrolysis and Steam Production Common Stack Cracking Heaters: F-3401 - F-3415; F-3418; F-3419 Common Stack Steam Super Heaters: F380001 A/B	NOx	494.93	2,022.33	11, 13, 22, 23, 24	11, 13, 22, 23, 25	13, 22, 23
		CO	395.03	1,612.25			
		SO_2	33.85	138.17			
		PM	37.61	153.52			
		PM_{10}	37.61	153.52			
		$PM_{2.5}$	37.61	153.52			
		NH_3	1.30	5.26			
		VOC	24.98	99.18			
EF3419	OP-1 Cracking Heater F-3419	NOx	38.40	25.71	11, 13, 22, 23, 24	11, 13, 22, 23, 25	13, 22, 23
		CO	33.88	148.38			
		SO_2	0.38	1.54			
		PM	4.23	17.00			

Major NSR Summary Table

Permit Numbers: 1768 and PSDTX1272 and N142					Issuance Date: December 28, 2018		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Conditions/ Application Information	Special Conditions/ Application Information	Special Conditions/ Application Information
		PM_{10}	4.23	17.00			
		$PM_{2.5}$	4.23	17.00			
		NH_3	2.69	11.78			
		VOC	0.64	2.57			
36E05	Regeneration Heater F-3601	NOx	2.50	2.63	11	11, 25	
		CO	2.06	1.95			
		SO_2	0.18	0.19			
		PM	0.19	0.18			
		PM_{10}	0.19	0.18			
		$PM_{2.5}$	0.19	0.18			
		VOC	0.13	0.12			
37E03	Recycle Heater F-3701	NOx	5.60	24.53	11	11, 25	
		CO	4.61	20.20			
		SO_2	0.40	1.77			
		PM	0.42	1.83			
		PM_{10}	0.42	1.83			
		$PM_{2.5}$	0.42	1.83			
		VOC	0.28	1.23			
38E01	OPI Flare (6)	NOx	104.30	16.30	16, 29	16, 25, 29	
		CO	537.25	81.36			
		SO_2	10.80	3.80			

Major NSR Summary Table

Permit Numbers: 1768 and PSDTX1272 and N142					Issuance Date: December 28, 2018		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Conditions/ Application Information	Special Conditions/ Application Information	Special Conditions/ Application Information
		VOC	1,375.90	49.15			
38E3602	Shelter J-3602	VOC	0.01	0.02			
38E3603	Shelter J-3603	VOC	0.08	0.34			
38E3604	Shelter J-3604	VOC	0.02	0.05			
38E3605	Shelter J-3605	VOC	0.01	0.01			
38E3606	Shelter J-3606	VOC	0.01	0.01			
38E3904	Shelter J-3904	VOC	1.28	5.62			
OP1EN1	Diesel Engine Driven Air Compressor (7)	NOx	1.73	3.88	2, 4	2, 4	
		CO	3.02	6.80			
		SO_2	<0.01	0.01			
		PM	0.02	0.04			
		PM_{10}	0.02	0.04			
		$PM_{2.5}$	0.02	0.04			
		VOC	0.01	0.02			
39E03	Storage Tank 3903 (Wastewater/Storm Water)	VOC	1.93	5.00	6, 7	6, 7	
37E09	Antifoulant Storage Tank 3709	VOC	0.28	0.01	6, 7	6, 7	
38E07	Pyrolysis Gas Oil Tank 38302	VOC	7.38	0.88	6, 7	6, 7	
		Benzene	0.05	0.01			
38E08	Storage Tank 38303	VOC	2.07	0.23	6, 7	6, 7	

Major NSR Summary Table

Permit Numbers: 1768 and PSDTX1272 and N142					Issuance Date: December 28, 2018		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Conditions/ Application Information	Special Conditions/ Application Information	Special Conditions/ Application Information
39E13	Pyrolysis Fuel Oil Tank 3913	VOC	11.58	8.06	6, 7	6, 7	
39E14	Storage Tank 3914	VOC	2.37	1.95	6, 7	6, 7	
39E43	Storage Tank 3943	VOC	2.37	3.64	6, 7	6, 7	
39E01	Storage Tank 3901	VOC	8.38	---	6, 7	6, 7	
		Benzene	2.56	---			
		H_2S	0.01	---			
39E02	Storage Tank 3902	VOC	8.38	---	6, 7	6, 7	
		Benzene	2.56	---			
		H_2S	0.01	---			
39E01 to 39E02	Storage Tanks (2 total)	VOC	---	24.68	6, 7	6, 7	
		Benzene	---	10.62			
		H_2S	---	0.02			
39E04	Storage Tank 3904	VOC	5.45	---	6, 7	6, 7	
		Benzene	1.45	---			
		H_2S	0.01	---			
39E05	Storage Tank 3905	VOC	5.45	---	6, 7	6, 7	
		Benzene	1.45	---			
		H_2S	0.01	---			
39E06	Storage Tank 3906	VOC	5.81	---	6, 7	6, 7	
		Benzene	1.54	---			

Major NSR Summary Table

Permit Numbers: 1768 and PSDTX1272 and N142					Issuance Date: December 28, 2018		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Conditions/ Application Information	Special Conditions/ Application Information	Special Conditions/ Application Information
		H_2S	0.01	---			
39E07	Storage Tank 3907	VOC	5.81	---	6, 7	6, 7	
		Benzene	1.54	---			
		H_2S	0.01	---			
39E04-39E07	Storage Tanks (4 total)	VOC	14.06	38.94	6, 7	6, 7	
		Benzene	1.92	9.61			
		H_2S	0.01	0.01			
39E11	Storage Tank 3911	VOC	2.27	6.84	6, 7	6, 7	
		Benzene	1.59	4.80			
39E12	Storage Tank 3912	VOC	2.67	7.95	6, 7	6, 7	
		Benzene	1.87	5.56			
OP1SMLT10	Antifoulant Tank 68423	VOC	0.32	0.01	6, 7	6, 7	
34E12	Waste Caustic Tank 3455	VOC	0.51	1.62	6, 7	6, 7	
38E008	Slop Oil Tank 38008	VOC	0.35	1.52	6, 7	6, 7	
38E009	Wastewater Tank 38009	VOC	1.03	1.76	6, 7	6, 7	
38E010	Wastewater Tank 38010	VOC	1.46	4.85	6, 7	6, 7	
38E011	Wastewater Tank 38011	VOC	2.80	6.41	6, 7	6, 7	
ENMSSROUT	MSS Vessel	VOC	4.37	0.05	29, 30, 31	29, 30, 31	
EOP1ANALY	Analyzers	VOC	0.03	0.13			
OP1PV38055	Analyzer Vent	VOC	0.08	0.35			
38E3501A	OP-1 Analyzer	VOC	0.01	0.01			

Footnotes:

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name. For fugitive sources, use area name or fugitive source name.

(3)

VOC	-	volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
NOx	-	total oxides of nitrogen
SO2	-	sulfur dioxide
PM	-	total particulate matter, suspended in the atmosphere, including PM10 and PM2.5, as represented
PM10	-	total particulate matter equal to or less than 10 microns in diameter, including PM2.5, as represented
PM2.5	-	particulate matter equal to or less than 2.5 microns in diameter
CO	-	carbon monoxide
HAP	-	hazardous air pollutant as listed in § 112(b) of the Federal Clean Air Act or Title 40 Code of Federal Regulations Part 63, Subpart C
H2S	-	hydrogen sulfide
NH3	-	ammonia

(4) Compliance with annual emission limits (tons per year) is based on a 12-month rolling period.

(5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.

(6) These emission rates include routine (non-MSS) and MSS operations.

(7) The maximum annual operating schedule for EPN OP1EN1 is 4,500 hrs/yr.

Major NSR Summary Table

Permit Numbers: 2933 and PSDTX1270 and N140					Issuance Date: 9/22/2017		
Emission Point No. (1)	**Source Name (2)**	**Air Contaminant Name (3)**	**Emission Rates**		**Monitoring and Testing Requirements**	**Recordkeeping Requirements**	**Reporting Requirements**
			lbs/hour	**TPY ****	**Spec. Cond.**	**Spec. Cond.**	**Spec. Cond.**
48E11	OP2 Cooling Tower	VOC	12.10	22.71	25, 26	24, 25, 26	
		PM	7.88	34.53			
		PM10	3.94	17.26			
		PM2.5	0.02	0.07			
EOP2FUGEXP	OP2 Fugitives (4)	VOC	0.46	2.01	3, 4, 9, 15, 16, 17, 18, 19	3, 4, 15, 18, 19, 27	3, 4, 19
EOP2DECOKE2	Decoke Vent 2	CO	310.00	59.60	28, 29, 31	28, 29, 31	
		VOC	0.08	0.02			
		PM	1.07	0.10			
		PM10	1.07	0.10			
		PM2.5	1.07	0.10			
ENMSSROUT	MSS Vessel – F4419 and Ancillary Piping/Equipment	VOC	4.37	0.05	3, 15, 18, 19, 28, 29, 30, 31	3, 15, 18, 19, 27, 28, 29, 30, 31	2, 3, 19
EOP2ANALY	Analyzers – F4419	VOC	0.03	0.13	31	31	
OP2PV48055	Analyzer Vent	VOC	0.08	0.35			
48E4501A	OP-2 Analyzer	VOC	< 0.01	< 0.01			
48E4301	Shelter J-4301	VOC	0.26	1.09			
48E4303	Shelter J-4303	VOC	0.11	0.48			

Major NSR Summary Table

Permit Numbers: 2933 and PSDTX1270 and N140					Issuance Date: 9/22/2017		
Emission Point No. (1)	**Source Name (2)**	**Air Contaminant Name (3)**	**Emission Rates**		**Monitoring and Testing Requirements**	**Recordkeeping Requirements**	**Reporting Requirements**
			lbs/hour	**TPY ****	**Spec. Cond.**	**Spec. Cond.**	**Spec. Cond.**
48E01	OP-2 Flare	VOC	974.01	104.61	4, 14	4, 14, 24	4
		NOx	142.81	37.96			
		CO	735.64	196.14			
		SO2	15.12	4.02			
43E01	D-4311 NCTBP Tank	VOC	11.96	0.47	2, 5	2, 5	2
43E03	D-4310 EADC Tank	VOC	10.81	0.41	2, 5	2, 5	2
43E02	Aluminum Oxide Treater Regeneration Vent	CO	1.56	0.02			
		VOC	0.97	0.01			
43E04	Regeneration Heater I F-4351	NO_x	1.30	5.69	11, 20	11, 20, 24	20
		SO_2	0.09	0.41			
		CO	1.09	4.78			
		VOC	0.07	0.28			
		PM	0.10	0.46			

Major NSR Summary Table

Permit Numbers: 2933 and PSDTX1270 and N140					Issuance Date: 9/22/2017		
Emission Point No. (1)	**Source Name (2)**	**Air Contaminant Name (3)**	**Emission Rates**		**Monitoring and Testing Requirements**	**Recordkeeping Requirements**	**Reporting Requirements**
			lbs/hour	**TPY ****	**Spec. Cond.**	**Spec. Cond.**	**Spec. Cond.**
43E05	Butane Isomerization Reactor Regeneration Vent	CO	6.92	4.98	4	4	4
		VOC	5.86	5.54			
43E06	DP Heater F-4360	NO_x	1.60	7.01	11, 20	11, 20, 24	20
		SO_2	0.12	0.50			
		CO	1.34	5.89			
		VOC	0.08	0.35			
		PM	0.13	0.56			
43E11	DP Heater F-4360C	NO_x	1.60	7.01	11, 20	11, 20, 24	20
		SO_2	0.12	0.50			
		CO	1.34	5.89			
		VOC	0.08	0.35			
		PM	0.13	0.56			
43E07	Regeneration Heater II F-4361	NO_x	0.40	1.75	11, 20	11, 20, 24	20
		SO_2	0.03	0.13			
		CO	0.34	1.47			
		VOC	0.02	0.09			
		PM	0.03	0.14			

Major NSR Summary Table

Permit Numbers: 2933 and PSDTX1270 and N140					Issuance Date: 9/22/2017		
Emission Point No. (1)	**Source Name (2)**	**Air Contaminant Name (3)**	**Emission Rates**		**Monitoring and Testing Requirements**	**Recordkeeping Requirements**	**Reporting Requirements**
			lbs/hour	**TPY ****	**Spec. Cond.**	**Spec. Cond.**	**Spec. Cond.**
F44E00	Olefins II Unit Fugitives (4) (includes Flex Fugitives F43E00)	VOC	94.60	405.73	3, 4, 9, 15, 16, 17, 18	3, 4, 15, 18	3
F44FGWATER	Olefins II Wastewater Fugitives (4)	VOC	1.15	5.03	3, 9, 15, 16, 17, 18	3, 15, 18	3
44HTHTRS	Pyrolysis and Steam Production Common Stack: Cracking Heaters- *F-4401 and F-4402* *F-4403 and F-4404* *F-4405 and F-4406* *F-4407 and F-4408* *F-4409 and F-3410* *F-4411 and F-4412* *F-4413 and F-4414* Common Stack: Boilers- *B-480001A & B-48001B* Common Stack: Steam Super Heaters- *F-48001 A & B* Ethane Cracking Heater - *F-4418* OP-2 Cracking Heater – *F-4415*	NO_x	588.26	2195.10	2, 4, 11, 12, 20, 21, 22	2, 4, 11, 12, 20, 21, 22, 24	2, 4, 20, 21, 22
		SO_2	34.16	138.73			
		CO	440.52	1696.00			
		VOC	27.94	104.67			
		PM	41.70	161.10			

Major NSR Summary Table

Permit Numbers: 2933 and PSDTX1270 and N140					Issuance Date: 9/22/2017		
Emission Point No. (1)	**Source Name (2)**	**Air Contaminant Name (3)**	**Emission Rates**		**Monitoring and Testing Requirements**	**Recordkeeping Requirements**	**Reporting Requirements**
			lbs/hour	**TPY ****	**Spec. Cond.**	**Spec. Cond.**	**Spec. Cond.**
EF4419	OP-2 Cracking Heater F-4419	NOx	38.40	25.71	11, 12, 20, 21	11, 12, 20, 21, 24	20, 21
		CO	33.88	148.38			
		SO2	0.38	1.54			
		VOC	0.64	2.57			
		PM	4.23	17.00			
		PM10	4.23	17.00			
		PM2.5	4.23	17.00			
		NH3	2.69	11.78			
44E08	Decoke Vent	CO	132.00	113.75			
		PM	36.00	6.50			
		VOC	0.11	0.10			
44E10	Reactor Regenerator Vent	VOC	2.00	0.16			
		CO	82.98	16.55			

Major NSR Summary Table

Permit Numbers: 2933 and PSDTX1270 and N140					Issuance Date: 9/22/2017		
Emission Point No. (1)	**Source Name (2)**	**Air Contaminant Name (3)**	**Emission Rates**		**Monitoring and Testing Requirements**	**Recordkeeping Requirements**	**Reporting Requirements**
			lbs/hour	**TPY ****	**Spec. Cond.**	**Spec. Cond.**	**Spec. Cond.**
46E05	Regeneration Heater F-4601	NO_x	2.50	2.63	11, 20	11, 20, 24	20
		SO_2	0.18	0.19			
		CO	2.10	2.21			
		VOC	0.13	0.13			
		PM	0.20	0.21			
45E11	Antifoulant Storage 4511	VOC	0.30	0.01	2, 4, 5	2, 4, 5	2, 4
46E01	Isopropanol Storage Tank 4601	VOC	0.22	0.03	2, 5	2, 5	2
46E07	Antifoulant Storage 4607	VOC	0.28	0.01	2, 4, 5	2, 4, 5	2, 4
48E105	Lube Oil Storage Tank 48105	VOC	0.28	0.01	2, 5	2, 5	2
48E06	Pyrolysis Fuel Oil Storage Tank 48301	VOC	0.36	1.79	2, 5	2, 5	2
48E07	Pyrolysis Gas Oil Tank 48302	VOC	7.75	2.47	2, 4, 5	2, 4, 5	2, 4
		Benzene	0.04	0.01			
48E08	Slop Oil Tank 48303	VOC	0.08	0.35	2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
		Benzene	0.04	0.16			
48E22	Pyrolysis Fuel Oil Tank 48007	VOC	12.62	14.53	2, 4, 5	2, 4, 5	2, 4

Major NSR Summary Table

Permit Numbers: 2933 and PSDTX1270 and N140					Issuance Date: 9/22/2017		
Emission Point No. (1)	**Source Name (2)**	**Air Contaminant Name (3)**	**Emission Rates**		**Monitoring and Testing Requirements**	**Recordkeeping Requirements**	**Reporting Requirements**
			lbs/hour	**TPY ****	**Spec. Cond.**	**Spec. Cond.**	**Spec. Cond.**
48E20	Pyrolysis Fuel Oil Tank 48304	VOC	12.62	7.54	2, 4, 5	2, 4, 5	2, 4
48E21	Storage Tank 48305	VOC	5.16	4.74	2, 4, 5	2, 4, 5	2, 4
49E01	Storage Tank 4901	VOC	8.38		2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
		Benzene	1.13				
		H2S	<0.01				
49E02	Storage Tank 4902	VOC	8.38		2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
		Benzene	0.20				
		H2S	<0.01				
49E03	Storage Tank 4903	VOC	8.38		2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
		Benzene	2.56				
49E01 to 49E03	Storage Tanks (3 total)	VOC		36.21	2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
		Benzene		1.64			
		H2S		0.02			
49E04	Storage Tank 4904	VOC	6.03		2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
		Benzene	1.60				
		H2S	<0.01				

Major NSR Summary Table

Permit Numbers: 2933 and PSDTX1270 and N140					Issuance Date: 9/22/2017		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY **	Spec. Cond.	Spec. Cond.	Spec. Cond.
49E05	Storage Tank 4905	VOC	6.03		2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
		Benzene	1.60				
		H2S	<0.01				
49E06	Storage Tank 4906	VOC	5.81		2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
		Benzene	1.55				
		H2S	<0.01				
49E07	Storage Tank 4907	VOC	5.12		2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
		Benzene	1.36				
		H2S	<0.01				
49E04 to 49E07	Storage Tanks (4 total)	VOC		37.72	2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
		Benzene		9.38			
		H2S		0.03			
49E08	Storage Tank 4915	VOC	0.14	0.33	2, 4, 5	2, 4, 5	2, 4
49E09	Storage Tank 4916	Benzene	0.71	2.17	2, 3, 5	2, 3, 5	2, 3

Major NSR Summary Table

Permit Numbers: 2933 and PSDTX1270 and N140					Issuance Date: 9/22/2017		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY **	Spec. Cond.	Spec. Cond.	Spec. Cond.
49E10	Storage Tank 4917	VOC	1.84	3.96	2, 5	2, 5	2
		Benzene	0.23	0.47			
49E11	Storage Tank 4919	VOC	1.28	2.69	2, 3, 5	2, 3, 5	2, 3
		Benzene	0.41	0.89			
49E12	Storage Tank 4921	VOC	2.64	2.36	2, 3, 5	2, 3, 5	2, 3
		Benzene	0.73	0.62			
49E13	Storage Tank 4922	VOC	3.21	7.14	2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
		Benzene	2.29	5.02			
45E02	Seal Oil Reservoir Vent	VOC	0.01	0.01			
45E07	Seal Oil Reservoir Vent	VOC	0.01	0.01			
48E4308	Shelter J-4308	VOC	0.01	0.01			
48E4402	Shelter J-4402	VOC	0.01	0.01			
48E4403	Shelter J-4403	VOC	0.01	0.01			
48E4404	Shelter J-4404	VOC	0.01	0.01			
48E4405	Shelter J-4405	VOC	0.01	0.01			
48E4406	Shelter J-4406	VOC	0.01	0.01			
48E4407	Shelter J-4407	VOC	0.01	0.01			

Major NSR Summary Table

Permit Numbers: 2933 and PSDTX1270 and N140					Issuance Date: 9/22/2017		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY **	Spec. Cond.	Spec. Cond.	Spec. Cond.
48E4408	Shelter J-4408	VOC	0.01	0.01			
48E4409	Shelter J-4409	VOC	0.01	0.01			
48E4410	Shelter J-4410	VOC	0.01	0.01			
48E4415	Shelter J-4415	VOC	0.01	0.01			
48E4501	Shelter J-4501	VOC	0.01	0.01			
48E4602	Shelter J-4602	VOC	0.01	0.02			
48E4603	Shelter J-4603	VOC	0.08	0.34			
48E4604	Shelter J-4604	VOC	0.01	0.05			
48E4605	Shelter J-4605	VOC	0.01	0.01			
48E4606	Shelter J-4606	VOC	0.01	0.01			
48E4607	Shelter J-4607	VOC	0.01	0.01			
48E4611	Shelter J-4611	VOC	0.01	0.01			
OP2VJ48013	Shelter J-48013	VOC	0.14	0.56			
OP2SMLTK08	Antifoulant Storage Tank 78782	VOC	0.77	0.05	2, 5	2, 5	2

Major NSR Summary Table

Permit Numbers: 2933 and PSDTX1270 and N140					Issuance Date: 9/22/2017		
Emission Point No. (1)	**Source Name (2)**	**Air Contaminant Name (3)**	**Emission Rates**		**Monitoring and Testing Requirements**	**Recordkeeping Requirements**	**Reporting Requirements**
			lbs/hour	**TPY ****	**Spec. Cond.**	**Spec. Cond.**	**Spec. Cond.**
OP2EN1	Diesel Engine-Driven Air Compressor	NO_x	4.82	10.48			
		CO	2.89	6.50			
		SO_2	0.90	2.02			
		PM_{10}	0.96	2.16			
		VOC	1.10	2.47			
44PVD4420	Dilution Steam Vents	VOC	1.97	1.66			
48HTF4804A/B	Superheater Vents	VOC	3.60	0.01			
OP2SMLTK11	Antifoulant Tote (OP2 Base Dimer Drum)	VOC	1.28	0.01	2, 5	2, 5	2
OP2SMLTK01	Oxygen Scavenger Tank 972392	VOC	2.15	0.01	2, 4, 5	2, 4, 5	2, 4
OP2SMLTK12	Neutralizing Amine Tank 971971	VOC	2.15	0.01	2, 4, 5	2, 4, 5	2, 4
OP2SMLTK13	Corrosion Inhibitor Tank 972389	VOC	2.15	0.01	2, 4, 5	2, 4, 5	2, 4
OP2SMLTK10	Corrosion Inhibitor Tank 972391	VOC	2.15	0.01	2, 4, 5	2, 4, 5	2, 4
OP2SMLTK02	Scale Inhibitor Tank 971927	VOC	2.15	0.01	2, 4, 5	2, 4, 5	2, 4
OP2SMLTK14	Oxygen Scavenger Tank 971977	VOC	2.15	0.01	2, 5	2, 5	2

Major NSR Summary Table

Permit Numbers: 2933 and PSDTX1270 and N140					Issuance Date: 9/22/2017		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY **	Spec. Cond.	Spec. Cond.	Spec. Cond.
OP2SMLTK03	Scale Inhibitor Tank 971978	VOC	2.15	0.01	2, 4, 5	2, 4, 5	2, 4
OP2SMLTK04	Corrosion Inhibitor Tank 971979	VOC	2.15	0.01	2, 4, 5	2, 4, 5	2, 4
OP2SMLTK15	Scale Inhibitor Tank 983321	VOC	2.15	0.01	2, 4, 5	2, 4, 5	2, 4
OP2SMLTK16	Corrosion Inhibitor Tank 983320	VOC	2.15	0.01	2, 4, 5	2, 4, 5	2, 4
OP2SMLTK17	Bio-dispersant Tank 983322	VOC	2.15	0.01	2, 4, 5	2, 4, 5	2, 4
OP2SMLTK05	Corrosion Inhibitor Tank 983323	VOC	2.15	0.01	2, 4, 5	2, 4, 5	2, 4
OP2SMLTK06	Anti-foam Tote (OP-2 Cooling Tower)	VOC	2.15	0.01	2, 5	2, 5	2
44E12	Waste Caustic Tank 4455	VOC	0.18	0.62	2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
44E13	Washwater Re-run Tank 4451	VOC	0.01	0.01	2, 5	2, 5	2
44E14	20 percent Caustic Tank 4459	Sodium Hydroxide	0.01	0.01	2, 5	2, 5	2
44E15	Corrosion Inhibitor Tank	VOC	2.15	0.01	2, 5	2, 5	2
48E008	Slop Oil Storage Tank 48008	VOC	0.35	1.52	2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
48E009	Wastewater Tank 48009	VOC	1.03	1.76	2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
48E010	Wastewater Tank 48010	VOC	1.46	1.91	2, 3, 4, 5	2, 3, 4, 5	2, 3, 4

Major NSR Summary Table

Permit Numbers: 2933 and PSDTX1270 and N140					Issuance Date: 9/22/2017		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY **	Spec. Cond.	Spec. Cond.	Spec. Cond.
48E011	Wastewater Tank 48011	VOC	2.80	3.81	2, 3, 4, 5	2, 3, 4, 5	2, 3, 4
48E053	96 percent Sulfuric Acid Tank 48053	Sulfuric Acid	0.01	0.01	2, 5	2, 5	2
48E054	50 percent Caustic Tank 48054	Sodium Hydroxide	0.02	0.09	2, 5	2, 5	2
48E055	50 percent Caustic Tank 48055	Sodium Hydroxide	0.01	0.01	2, 5	2, 5	2
45E04X	Lube Oil Reservoir 4504X	VOC	0.93	4.05	2, 4, 5	2, 4, 5	2, 4
45E05X	Seal Oil Degassing Tank 4505X	VOC	0.01	0.01	2, 5	2, 5	2
46E02X	Lube Oil Reservoir Tank 4602X	VOC	0.56	2.43	2, 4, 5	2, 4, 5	2, 4
46E04X	Lube Oil Reservoir Tank 4604X	VOC	0.01	0.01	2, 4, 5	2, 4, 5	2, 4
46E05X	Seal Oil Degassing Tank 4605X	VOC	0.01	0.01	2, 5	2, 5	2
46E09	Hydraulic Oil Storage Tank 4609	VOC	0.01	0.01	2, 5	2, 5	2

Footnotes:

(1) Emission point identification - either specific equipment designation or emission point number (EPN) from a plot plan.

(2) Specific point source names. For fugitive sources, use an area name or fugitive source name.

(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code ' 101.1

NO_x - total oxides of nitrogen

SO_2 - sulfur dioxide

PM - particulate matter, suspended in the atmosphere, including PM_{10} and $PM_{2.5}$ as represented.

CO - carbon monoxide

(4) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission rate.

* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

Hrs/day _24_ Days/week _7_ Weeks/year _52_

** Compliance with annual emission limits is based on a rolling 12-month period.

Major NSR Summary Table

Permit Numbers: 8125 and PSDTX1280M1 and N144					Issuance Date: February 28, 2019		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Conditions/ Application Information	Special Conditions/ Application Information	Special Conditions/ Application Information
EHTF7001	Reformer Furnace	VOC	8.71	38.14	8, 14, 15	8, 14, 15	14, 15
		NO_x with SCR	23.00	69.32			
		NO_x in startup/shutdown mode (6)	134.05	6.43			
		SO_2	0.95	4.16			
		PM	5.07	22.21			
		PM_{10}	5.07	22.21			
		$PM_{2.5}$	4.56	19.99			
		CO	27.46	120.25			
		CO in startup/shutdown mode (6)	121.34				
		NH_3	7.78	33.39			
ECTMEOH	Cooling Tower	VOC	2.52	4.73	3, 11	3, 11	3
		PM	0.45	1.97			
		PM_{10}	0.22	0.99			
		$PM_{2.5}$	0.22	0.99			
ETK3122	Surge Tank	VOC	3.24	0.34	2, 3, 5	2, 3, 5	2, 3
ETK5101/ETK5102	Product Tanks	VOC	4.38	8.20	2, 3, 5	2, 3, 5	2, 3
ESP7045	Lube Oil Reservoir	VOC	0.05	0.23	2, 3	2, 3	2, 3
EFUGMEOH	Fugitives (5)	VOC	0.99	4.31	2, 3, 10	2, 3, 10	2, 3, 10
EFUGNH3	Fugitives (5)	NH_3	0.14	0.63	2, 3, 9	2, 3, 9	2, 3

Major NSR Summary Table

Permit Numbers: 8125 and PSDTX1280M1 and N144					Issuance Date: February 28, 2019		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Conditions/ Application Information	Special Conditions/ Application Information	Special Conditions/ Application Information
EMEOHANLZ	Methanol Analyzer Vents	VOC	0.56	2.42	3	3	3
		CO	0.12	0.54			
EMEOHFLARE	Methanol Flare in normal operation	VOC	18.33	6.71	2, 3, 12, 16	2, 3, 12, 16	2, 3
		NOx	12.47	3.88			
		CO	99.36	21.94			
		SO_2	0.10	0.03			
EMEOHFLARE	Methanol Flare in MSS operation	VOC	84.91	1.60	2, 3, 12, 16	2, 3, 12, 16	2,3
		NOx	101.60	3.08			
EEMERFLARE	Emergency Flare	CO	1094.18	17.79			
		SO_2	0.11	0.01			
17E01	East Plant Flare (7)	VOC	0.51	0.77	2, 3, 6, 13	2, 3, 6, 13	2, 3
		NOx	0.03	0.01			
		CO	0.17	0.06			
		SO_2	0.01	0.01			
MSS	MSS (8)	VOC	5.58	0.07	2, 3	2, 3	2, 3

Footnotes:

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name. For fugitive sources, use area name or fugitive source name.

(3)

VOC	-	volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
NOx	-	total oxides of nitrogen
SO_2	-	sulfur dioxide
PM	-	total particulate matter, suspended in the atmosphere, including PM10 and PM2.5, as represented
PM_{10}	-	total particulate matter equal to or less than 10 microns in diameter, including PM2.5, as represented
$PM_{2.5}$	-	particulate matter equal to or less than 2.5 microns in diameter
CO	-	carbon monoxide
NH_3	-	ammonia

(4) Compliance with annual emission limits (tons per year) is based on a 12-month rolling period.

(5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.

(6) Emission rates are based on 172 hours of startup and shutdown per year.

(7) Methanol product loading related emissions only.

(8) Cleanout of vessels and related equipment during process unit turnaround. Annual emission rate is based on 24 hours of operation per rolling 12 months.

Major NSR Summary Table

Permit Number: PSD-TX-1272-GHG **Issuance Date: July 19, 2013**

Emission Point No.	Source Name	Air Contaminant Name	Emission Rates		Monitoring and Testing Requirements Spec. Cond.	Recordkeeping Requirements Spec. Cond.	Reporting Requirements Spec. Cond.
			TPY (1)	TPY CO_2e (1),(2)			
EF3419	Cracking Furnace (OP-1)	CO_2	300,400	300,706	III.A.1, III.B, IV.A, V.A, V.B, V.G	III.A.1, III.B, IV.A, V.A, V.B, V.G	I.D, III.B, IV.A, V.A, V.B, V.C, V.G, VI
		CH_4	5.7				
		N_2O	0.6				
EF4419	Cracking Furnace (OP-2)	CO_2	300,400	300,706	III.A.1, III.B, IV.A, V.A, V.B, V.G	III.A.1, III.B, IV.A, V.A, V.B, V.G	I.D, III.B, IV.A, V.A, V.B, V.C, V.G, VI
		CH_4	5.7				
		N_2O	0.6				
EOP1DECOKE2	Decoke Pot (OP-1)	CO_2	281	281	III.A.1, III.B, IV.A	III.A.1, III.B, IV.A	I.D, III.B, IV.A, VI
EOP2DECOKE2	Decoke Pot (OP-2)	CO_2	281	281	III.A.1, III.B, IV.A	III.A.1, III.B, IV.A	I.D, III.B, IV.A, VI
EOP1FUGEXP	Fugitive Process Emissions (OP-1)	CH_4	No Emission Limit Established(3)	No Emission Limit Established(3)	III.A.2, IV.A	III.A.2, IV.A	III.A.2, I.D, IV.A, VI
EOP2FUGEXP	Fugitive Process Emissions (OP-2)	CH_4	No Emission Limit Established(3)	No Emission Limit Established(3)	III.A.2, IV.A	III.A.2, IV.A	III.A.2, I.D, IV.A, VI
-	Total Emissions(4)	CO_2	601,362	602,000	N/A	N/A	N/A
		CH_4	12.6				

Major NSR Summary Table

Permit Number: PSD-TX-1272-GHG **Issuance Date: July 19, 2013**

Emission Point No.	Source Name	Air Contaminant Name	Emission Rates		Monitoring and Testing Requirements Spec. Cond.	Recordkeeping Requirements Spec. Cond.	Reporting Requirements Spec. Cond.
			TPY (1)	TPY CO_2e (1),(2)			
		N_2O	1.2				

(1) The TPY emission limits specified in this table are not to be exceeded for this facility and include emissions from the facility during all operations and include MSS activities.

(2) Global Warming Potentials (GWP): CH_4 = 21, N_2O = 310

(3) Fugitive process emissions from EPN EOP1FUGEXP and EOP2FUGEXP are estimated for each process unit (OP-1 and OP-2) to be 0.6 TPY of CH4, and 13 TPY CO2e. In lieu of an emission limit, the emissions will be limited by implementing a design/work practice standard as specified in the permit.

(4) Total emissions include the PTE for fugitive emissions. Totals are given for informational purposes only and do not constitute emission limits.

Major NSR Summary Table							
Permit Number: PSD-TX-1280-GHG					Issuance Date: 02/14/2013		
Emission Point No.	**Source Name**	**Air Contaminant Name**	**Emission Rates**		**Monitoring and Testing Requirements**	**Recordkeeping Requirements**	**Reporting Requirements**
			TPY (1)	**TPY CO_2e (1),(2)**	**Spec. Cond.**	**Spec. Cond.**	**Spec. Cond.**
EHTF7001	Reformer Furnace	CO_2	826,600	827,556	IV.A.1, IV.B.1, IV.B.2, IV.B.3, V.A.1, V.A.6, V.A.8, VI.A, VI.B, VI.C, VI.D, VI.F, VI.G, VI.H	IV.A.1, IV.B.1, V.A.1, V.A.2, V.A.3, V.A.6, V.A.7, V.A.8, VI.A, VI.B, VI.D, VI.G	V.A.3,VI.B, VI.C, VI.E, VII
		CH_4	16				
		N_2O	2				
EMEOHFLARE EEMERFLARE	Methanol Flare and Methanol Emergency Flare(3)	CO_2	3,936	3,936	IV.A.2, V.A.1, V.A.6, V.A.8	IV.A.2, V.A.1, V.A.2, V.A.3, V.A.6, V.A.7 V.A.8	V.A.3,VII
		CH_4	Negligible				
		N_2O	Negligible				
EFUGMEOH	Fugitive Process Emissions	CO_2	N/A	N/A	IV.A.3, V.A.1	V.A.1, V.A.2, V.A.3, V.A.7,	V.A.3, VII
		CH_4	N/A				
-	Total Emissions(4)	CO_2	830,614	831,675	N/A	N/A	N/A
		CH_4	21				
		N_2O	2				

(1) The TPY emission limits specified in this table are not to be exceeded for these EPNs and include emissions from the facility during all operations and include

MSS activities.

(2) Global Warming Potentials (GWP): CH_4 = 21, N_2O = 310

(3) The methanol unit waste gas flow may be routed to either flare, or to both flares.

(4) Total emissions include the PTE of 5 TPY CH_4 and 39 TPY CO_2 for fugitive emissions, and 39 TPY CO_2 from the existing East Plant Flare (17E01) for a total of 183 TPY CO_{2e}. Totals are given for informational purposes only and do not constitute emission limits.

Texas Commission on Environmental Quality
Air Quality Permit

A Permit Is Hereby Issued To
Equistar Chemicals, LP
Authorizing the Continued Operation of
Channelview Complex
Located at **Channelview, Harris County, Texas**
Latitude 29° 49′ 56″ Longitude −95° 6′ 43″

Permit: 1768/PSDTX1272/N142

Issuance Date: December 28, 2018

Expiration Date: December 28, 2028

For the Commission

1. **Facilities** covered by this permit shall be constructed and operated as specified in the application for the permit. All representations regarding construction plans and operation procedures contained in the permit application shall be conditions upon which the permit is issued. Variations from these representations shall be unlawful unless the permit holder first makes application to the Texas Commission on Environmental Quality (commission) Executive Director to amend this permit in that regard and such amendment is approved. [Title 30 Texas Administrative Code (TAC) Section 116.116 (30 TAC § 116.116)] [1]
2. **Voiding of Permit**. A permit or permit amendment is automatically void if the holder fails to begin construction within 18 months of the date of issuance, discontinues construction for more than 18 months prior to completion, or fails to complete construction within a reasonable time. Upon request, the executive director may grant an 18-month extension. Before the extension is granted the permit may be subject to revision based on best available control technology, lowest achievable emission rate, and netting or offsets as applicable. One additional extension of up to 18 months may be granted if the permit holder demonstrates that emissions from the facility will comply with all rules and regulations of the commission, the intent of the Texas Clean Air Act (TCAA), including protection of the public's health and physical property; and (b)(1)the permit holder is a party to litigation not of the permit holder's initiation regarding the issuance of the permit; or (b)(2) the permit holder has spent, or committed to spend, at least 10 percent of the estimated total cost of the project up to a maximum of $5 million. A permit holder granted an extension under subsection (b)(1) of this section may receive one subsequent extension if the permit holder meets the conditions of subsection (b)(2) of this section. [30 TAC § 116.120]
3. **Construction Progress**. Start of construction, construction interruptions exceeding 45 days, and completion of construction shall be reported to the appropriate regional office of the commission not later than 15 working days after occurrence of the event. [30 TAC § 116.115(b)(2)(A)]
4. **Start-up Notification**. The appropriate air program regional office shall be notified prior to the commencement of operations of the facilities authorized by the permit in such a manner that a representative of the commission may be present. The permit holder shall provide a separate notification for the commencement of operations for each unit of phased construction, which may involve a series of units commencing operations at different times. Prior to operation of the facilities authorized by the permit, the permit holder shall identify the source or sources of allowances to be utilized for compliance with Chapter 101, Subchapter H, Division 3 of this title (relating to Mass Emissions Cap and Trade Program). [30 TAC § 116.115(b)(2)(B)]
5. **Sampling Requirements**. If sampling is required, the permit holder shall contact the commission's Office of Compliance and Enforcement prior to sampling to obtain the proper data forms and procedures. All sampling and testing procedures must be approved by the executive director and coordinated with the regional representatives of the commission. The permit holder is also responsible for providing sampling facilities and conducting the sampling operations or contracting with an independent sampling consultant. [30 TAC § 116.115(b)(2)(C)]
6. **Equivalency of Methods.** The permit holder must demonstrate or otherwise justify the equivalency of emission control methods, sampling or other emission testing methods, and monitoring methods proposed as alternatives to methods indicated in the conditions of the permit. Alternative methods shall be applied for in writing and must be reviewed and approved by the executive director prior to their use in fulfilling any requirements of the permit. [30 TAC § 116.115(b)(2)(D)]
7. **Recordkeeping.** The permit holder shall maintain a copy of the permit along with records containing the information and data sufficient to demonstrate compliance with the permit, including production records and

operating hours; keep all required records in a file at the plant site. If, however, the facility normally operates unattended, records shall be maintained at the nearest staffed location within Texas specified in the application; make the records available at the request of personnel from the commission or any air pollution control program having jurisdiction in a timely manner; comply with any additional recordkeeping requirements specified in special conditions in the permit; and retain information in the file for at least two years following the date that the information or data is obtained. [30 TAC § 116.115(b)(2)(E)]

8. **Maximum Allowable Emission Rates**. The total emissions of air contaminants from any of the sources of emissions must not exceed the values stated on the table attached to the permit entitled "Emission Sources--Maximum Allowable Emission Rates." [30 TAC § 116.115(b)(2)(F)] [1]
9. **Maintenance of Emission Control**. The permitted facilities shall not be operated unless all air pollution emission capture and abatement equipment is maintained in good working order and operating properly during normal facility operations. The permit holder shall provide notification in accordance with 30 TAC §101.201, 101.211, and 101.221 of this title (relating to Emissions Event Reporting and Recordkeeping Requirements; Scheduled Maintenance, Startup, and Shutdown Reporting and Recordkeeping Requirements; and Operational Requirements). [30 TAC§ 116.115(b)(2)(G)]
10. **Compliance with Rules**. Acceptance of a permit by an applicant constitutes an acknowledgment and agreement that the permit holder will comply with all rules and orders of the commission issued in conformity with the TCAA and the conditions precedent to the granting of the permit. If more than one state or federal rule or regulation or permit condition is applicable, the most stringent limit or condition shall govern and be the standard by which compliance shall be demonstrated. Acceptance includes consent to the entrance of commission employees and agents into the permitted premises at reasonable times to investigate conditions relating to the emission or concentration of air contaminants, including compliance with the permit. [30 TAC § 116.115(b)(2)(H)]
11. **This** permit may not be transferred, assigned, or conveyed by the holder except as provided by rule. [30 TAC § 116.110(e)]
12. **There** may be additional special conditions attached to a permit upon issuance or modification of the permit. Such conditions in a permit may be more restrictive than the requirements of Title 30 of the Texas Administrative Code. [30 TAC § 116.115(c)]
13. **Emissions** from this facility must not cause or contribute to "air pollution" as defined in Texas Health and Safety Code (THSC) §382.003(3) or violate THSC § 382.085. If the executive director determines that such a condition or violation occurs, the holder shall implement additional abatement measures as necessary to control or prevent the condition or violation.
14. **The** permit holder shall comply with all the requirements of this permit. Emissions that exceed the limits of this permit are not authorized and are violations of this permit. [1]

[1] Please be advised that the requirements of this provision of the general conditions may not be applicable to greenhouse gas emissions.

Special Conditions

Permit Numbers 1768/PSDTX1272/N142

1. This permit covers only those sources of emissions listed in the attached table entitled “Emission Sources - Maximum Allowable Emission Rates” (MAERT), and those sources are limited to the emission limits and other conditions specified in that table.

Federal Applicability

2. These facilities shall comply with all applicable requirements of the U.S. Environmental Protection Agency (EPA) regulations on Standards of Performance for New Stationary Sources promulgated in Title 40 Code of Federal Regulations Part 60 (40 CFR Part 60):

   A. Subpart A, General Provisions.

   B. Subpart K, Standards of Performance for Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After June 11, 1973, and Prior to May 19, 1978.

   C. Subpart Kb, Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984.

   D. Subpart VV, Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemical Manufacturing Industry for which Construction, Reconstruction, or Modification Commenced After January 5, 1981, and on or Before November 7, 2006

   E. Subpart IIII, Standards of Performance for Stationary Compression Ignition Internal Combustion Engines.

3. These facilities shall comply with all applicable requirements of the U.S. Environmental Protection Agency (EPA) regulations on National Emission Standards for Hazardous Air Pollutants in 40 CFR Part 61:

   A. Subpart A, General Provisions.

   B. Subpart J, National Emission Standard for Equipment Leaks (Fugitive Emission Sources) of Benzene.

   C. Subpart V, National Emission Standard for Equipment Leaks (Fugitive Emission Sources)

   D. Subpart FF, National Emission Standard for Benzene Waste Operations

4. These facilities shall comply with all applicable requirements of the U.S. Environmental Protection Agency (EPA) regulations on National Emission Standards for Hazardous Air Pollutants for Source Categories in 40 CFR Part 63:

   A. Subpart A, General Provisions.

   B. Subpart G, National Emission Standards for Organic Hazardous Air Pollutants from the Synthetic Organic Chemical Manufacturing Industry for Process Vents, Storage Vessels, Transfer Operations, and Wastewater.

   C. Subpart H, National Emission Standards for Organic Hazardous Air Pollutants for Equipment Leaks.

D. Subpart YY, National Emission Standards for Hazardous Air Pollutants for Source Categories: Generic Maximum Achievable Control Technology Standards.

E. Subpart FFFF, National Emission Standards for Hazardous Air Pollutants: Miscellaneous Organic Chemical Manufacturing.

F. Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.

G. Subpart DDDDD, National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters.

Emission Standards and Operational Specifications

5. Tanks are approved to store the liquids on the Approved Product List represented in the Attachment A.

6. The true vapor pressure of any liquid stored at this facility in an atmospheric tank shall not exceed 11.0 psia.

7. Storage tanks and storage vessel are subject to the following requirements. The control requirements specified in paragraphs A-D of this condition shall not apply (1) where the volatile organic compounds (VOC) has an aggregate partial pressure of less than 0.50 pound per square inch, absolute (psia) at the maximum feed temperature or 95 °F, whichever is greater, or (2) to storage tanks smaller than 25,000 gallons.

   A. The tank emissions must be controlled as specified in one of paragraphs below:

      (1) An internal floating deck or roof or equivalent control shall be installed in all tanks. The floating roof shall be equipped with one of the following closure devices between the wall of the storage vessel and the edge of the internal floating roof: (1) a liquid-mounted seal, (2) two continuous seals mounted one above the other, or (3) a mechanical shoe seal.

      (2) An open-top tank containing a floating roof (external floating roof tank) which uses double seal or secondary seal technology shall be an approved control alternative to an internal floating roof tank provided the primary seal consists of either a mechanical shoe seal or a liquid-mounted seal and the secondary seal is rim-mounted. A weathershield is not approvable as a secondary seal unless specifically reviewed and determined to be vapor-tight.

   B. For any tank equipped with a floating roof, the permit holder shall perform the visual inspections and seal gap measurements as specified in 40 CFR §60.113b, Testing and Procedures, to verify fitting and seal integrity. Records shall be maintained of the dates seals were inspected and seal gap measurements made, results of inspections and measurements made (including raw data), and actions taken to correct any deficiencies noted.

   C. The floating roof design shall incorporate sufficient flotation to conform to the requirements of API Code 650 dated November 1, 1998 except that an internal floating cover need not be designed to meet rainfall support requirements and the materials of construction may be steel or other materials.

D. Except for labels, logos, etc. not exceed 15 percent of tank total surface area, uninsulated tank exterior surfaces exposed to the sun shall be white, gray or specular color. Storage tanks must be equipped with permanent submerged fill pipes.

E. The permit holder shall maintain an emissions record which includes calculated emissions of VOC from all storage tanks during the previous calendar month and the past consecutive 12-month period. The record shall include tank identification number, control method used, tank capacity in gallons, name of the material stored, VOC molecular weight, VOC monthly average temperature in degrees Fahrenheit, VOC vapor pressure at the monthly average material temperature in psia, VOC throughput for the previous month and year-to-date. Records of VOC monthly average temperature are not required to be kept for unheated tanks which receive liquids that are at or below ambient temperatures.

Emissions from tanks shall be calculated using the methods that were used to determine the MAERT limits in the permit application Form PI-1 dated December 5, 2016. Sample calculations from the application shall be attached to a copy of this permit at the plant site.

8. Non-fugitive emissions from relief valves, safety valves, or rupture discs of gases containing VOC at a concentration of greater than 1 percent are not authorized by this permit unless authorized on the maximum allowable emission rates table. Any releases directly to atmosphere from relief valves, safety valves, or rupture discs of gases containing VOC at a concentration greater than one weight percent are not consistent with good practice for minimizing emissions with the exception of safety valves listed below and those that discharge directly to the atmosphere as a result of fire or failure of utilities.

PSV Number	Service	Set	Pressure, psig Operating
38014	TK3912 Make Line	275	25
38065	TK3913 Make Line	250	30
38066	TK3913 to Loading	250	30
38015	P3908A/B Discharge	275	30
38013	TK3911 Make Line	150	25
39021	TK3901 Suction Line	180	25
39022	TK3904 Discharge Line	180	25
39023	P3903A/B Discharge	275	137
38017	P3903A/B Discharge	275	137
39016	TK3902 Suction Line	180	25
38036	TK3901 Make Line	180	25
39001	P3901A/B Discharge	180	30
39017	TK3903 Suction Line	180	25
39036	P3902A/B Discharge	180	48
38012	TK3903 Make Line	180	25
39003	P3902A/B Discharge	180	48
39018	TK3907 Discharge Line	180	25
39043	TK3912 Discharge Line	180	25

39044	P3912A/B/C Discharge	200	156
39040	P3912A/B Discharge	255	53
38016	1st Feed System	275	160
38035	3rd Feed System	720	275
38037	Gas Oil-w Mtr Station	180	50
38068	Treated PY Gas	180	20

9. Atmospheric relief valves in VOC service that are not equipped with rupture disks shall be checked for leaks on a quarterly basis with an approved gas analyzer. A leak shall be defined as 500 parts per million by volume (ppmv). There shall be no variance for inaccessible valves. All leaking valves shall be repaired or replaced at the earliest opportunity but not later than the next scheduled process shutdown.

10. Analyzer sample system vents or speed loops shall be equipped with vapor recovery or liquid recovery systems (vapor samples routed to flare system or liquids samples route back to process). Analyzer (gas chromatographs) vapor sample loops shall depressurize to atmospheric pressure during sample injection only and shall be routed to the flare during periods when a sample is not being injected. The following analyzer is exempt from the vapor recovery or liquid recovery system requirements: J-3904.

11. Cracking heaters and heaters associated with the Olefins Production Unit No. 1 shall not exceed the following firing rates:

EPN	Facility Name	Firing Rate (MMBtu/hr)
34E01	Crack Heaters F3401 / F3402	540*
34E02	Crack Heaters F3403 / F3404	540*
34E03	Crack Heaters F3405 / F3406	540*
34E04	Crack Heaters F3407 / F3408	540*
34E05	Crack Heaters F3409 / F3410	540*
34E06	Crack Heaters F3411 / F3412	540*
34E07	Crack Heaters F3413 / F3414	540*
34E19	Crack Heater F3415	270
34E18	Ethane Cracking Heater F3418	270
38E04	Superheaters F38001A / F38001B	380*
34HTHTRS	34HTHTR Total	4,700

EF3419	Cracking Heater 19	640
Cracking Firing Limit for Cracking Heater 19 and 34HTHTR Total		5,275
36E05	Regen Heater F3601	25
37E03	Recycle Heater F3701	56
Firing Limit Total		5,340

* The firing rates are sum of two heaters' firing rates.

The heating value of the fuel (Btu/scf) and the fuel flow rate shall be continuously monitored for the cracking heaters, ethane heater, and steam superheaters. Quality-assured (or valid) data must be generated when the fired unit is operating. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted provided it does not exceed 5 percent of the time (in minutes) that the fired unit operated over the previous rolling 12-month period. The measurements missed shall be estimated using engineering judgment and the methods used recorded. Compliance with air contaminant emission limits shall be based upon the above firing rate.

12. Purchase gas combusted at this facility shall be sweet natural gas containing no more than five grains of total sulfur per 100 dry standard cubic feet.

13. Concentrations of NH_3 from the Cracking Heaters Stack (Emission Point Nos. EPN 34HTHTRS, EPN EF3419) shall not exceed 10 ppmvd on an hourly basis when corrected to three percent oxygen (O_2). The NH_3 concentration shall be tested or calculated according to one of the three methods listed below:

    A. The holder of this permit may install, calibrate, maintain, and operate a CEMS to measure and record the concentrations of NH_3. The NH_3 concentrations shall be corrected and reported in accordance with Special Condition No. 23.

    B. If a sorbent tube device specific for NH_3 is used, the frequency of the sorbent tube testing shall be daily for the first 60 days of SCR operation, after which, the frequency of the sorbent tube testing may be reduced from daily to weekly after operating procedures have been developed to prevent excess amounts of NH_3 from being introduced, and when operation of the SCR system has been proven successful with regard to controlling NH_3 slippage.

    C. As an approved alternative to sorbent or stain tube testing or an NH_3 CEMS, the permit holder may install and operate a second oxides of nitrogen (NO_x) CEMS probe located upstream of the SCR and the stack NO_x CEMS, which may be used in association with the SCR efficiency and NH_3 injection rate to estimate NH_3 slip.

    D. Any other method used for measuring NH_3 slippage shall require prior approval from the TCEQ.

14. The permit holder shall maintain the piping and valves in NH_3 service as follows:

    A. Audio, olfactory, and visual checks for NH_3 leaks within the operating area shall be made per shift.

B. Immediately, but no later than 24 hours upon detection of a leak, plant personnel shall take one or more of the following actions:

Locate and isolate the leak, if necessary. Commence repair or replacement of the leaking component. Use a leak collection or containment system to control the leak until repair or replacement can be made if immediate repair is not possible.

15. Records of AVO checks, any maintenance performed on piping and valves in NH_3 service, accidental releases, venting, and any corrective actions taken shall be maintained by the holder of this permit.

16. Flare (EPN 38E01) shall be designed and operated in accordance with the following requirements:

A. The flare systems shall be designed such that the combined assist natural gas and waste stream to each flare meets the 40 CFR §60.18 specifications of minimum heating value and maximum tip velocity under normal, upset, and maintenance flow conditions.

The heating value and velocity requirements shall be satisfied during operations authorized by this permit. Flare testing per 40 CFR §60.18(f) may be requested by the appropriate TCEQ Regional Office to demonstrate compliance with these requirements.

B. The flare shall be operated with a flame present at all times and/or have a constant pilot flame. The pilot flame shall be continuously monitored by a thermocouple or an infrared monitor. The time, date, and duration of any loss of pilot flame shall be recorded. Each monitoring device shall be accurate to and shall be calibrated at a frequency in accordance with, the manufacturer's specifications.

C. The flare shall be operated with no visible emissions except periods not to exceed a total of five minutes during any two consecutive hours. This shall be ensured by the use of steam assist to the flare.

D. The permit holder shall install a continuous flow monitor and composition analyzer that provides a record of the vent stream flow and composition to the flare. The flow monitor sensor and analyzer sample points shall be installed in the vent stream as near as possible to the flare inlet such that the total vent stream to the flare is measured and analyzed. Readings shall be taken at least once every 15 minutes and the average hourly values of the flow and composition shall be recorded each hour.

The monitors shall be calibrated on an annual basis to meet the following accuracy specifications: the flow monitor shall be ±5.0 percent, the temperature monitor shall be ±2.0 percent at absolute temperature and the pressure monitor shall be ±5.0 mm Hg.

Calibration of the analyzer shall follow the procedures and requirements of Section 10.0 of 40 CFR Part 60, Appendix B, Performance Specification 9, as amended through October 17, 2000 (65 FR 61744), except that the multi-point calibration procedure in Section 10.1 of Performance Specification 9 shall be performed at least once every calendar quarter instead of once every month, and the mid-level calibration check procedure in Section 10.2 of Performance Specification 9 shall be performed at least once every calendar week instead of once every 24 hours. The calibration gases used for calibration procedures shall be in accordance with Section 7.1 of Performance Specification 9. Net heating value of the gas combusted in the flare shall be calculated according to the equation given in 40 CFR §60.18(f)(3) as amended through October 17, 2000 (65 FR 61744).

The monitors and analyzers shall operate as required by this section at least 95% of the time when the flare is operational, averaged over a rolling 12-month period. Flared gas net heating value and actual exit velocity determined in accordance with 40 CFR §§60.18(f)(3) and 60.18(f)(4) shall be recorded at least once every hour. Hourly mass emission rates shall be determined and recorded using the above readings and the emission factors used in the permit renew and amendment application (PI-1 dated December 05, 2016).

Fugitive Emissions Monitoring

17. Piping, valves, connectors, pumps, agitators, and compressors in VOC service -28VHP

Except as may be provided for in the Special Conditions of this permit, the following requirements apply to the above-referenced equipment:

The following requirements apply to piping, valves, connectors, pumps, agitators, and compressors containing or in contact with fluids that could reasonably be expected to contain greater than or equal to 10 weight percent volatile organic compounds (VOC) at any time.

A. The requirements of paragraphs F and G shall not apply (1) where the Volatile Organic Compound (VOC) has an aggregate partial pressure or vapor pressure of less than 0.044 pounds per square inch, absolute (psia) at 68°F or (2) operating pressure is at least 5 kilopascals (0.725 psi) below ambient pressure. Equipment excluded from this condition shall be identified in a list or by one of the methods described below to be made readily available upon request.

The exempted components may be identified by one or more of the following methods:

- piping and instrumentation diagram (PID);
- a written or electronic database or electronic file;
- color coding;
- a form of weatherproof identification; or
- designation of exempted process unit boundaries.

B. Construction of new and reworked piping, valves, pump systems, and compressor systems shall conform to applicable American National Standards Institute (ANSI), American Petroleum Institute (API), American Society of Mechanical Engineers (ASME), or equivalent codes.

C. New and reworked underground process pipelines shall contain no buried valves such that fugitive emission monitoring is rendered impractical. New and reworked buried connectors shall be welded.

D. To the extent that good engineering practice will permit, new and reworked valves and piping connections shall be so located to be reasonably accessible for leak-checking during plant operation. Difficult-to-monitor and unsafe-to-monitor valves, as defined by Title 30 Texas Administrative Code Chapter 115 (30 TAC Chapter 115), shall be identified in a list to be made readily available upon request. The difficult-to-monitor and unsafe-to-monitor valves may be identified by one or more of the methods described in Paragraph A above. If an unsafe to monitor component is not considered safe to monitor within a calendar year, then it

shall be monitored as soon as possible during safe to monitor times. A difficult to monitor component for which quarterly monitoring is specified may instead be monitored annually.

E. New and reworked piping connections shall be welded or flanged. Screwed connections are permissible only on piping smaller than two-inch diameter. Gas or hydraulic testing of the new and reworked piping connections at no less than operating pressure shall be performed prior to returning the components to service or they shall be monitored for leaks using an approved gas analyzer within 15 days of the components being returned to service. Adjustments shall be made as necessary to obtain leak-free performance. Connectors shall be inspected by visual, audible, and/or olfactory means at least weekly by operating personnel walk-through.

Each open-ended valve or line shall be equipped with an appropriately sized cap, blind flange, plug, or a second valve to seal the line. Except during sampling, both valves shall be closed. If the isolation of equipment for hot work or the removal of a component for repair or replacement results in an open-ended line or valve, it is exempt from the requirement to install a cap, blind flange, plug, or second valve for 72 hours. If the repair or replacement is not completed within 72 hours, the permit holder must complete either of the following actions within that time period;

(1) a cap, blind flange, plug, or second valve must be installed on the line or valve;

or

(2) the open-ended valve or line shall be monitored once for leaks above background for a plant or unit turnaround lasting up to 45 days with an approved gas analyzer and the results recorded. For all other situations, the open-ended valve or line shall be monitored once within the 72 hour period following the creation of the open ended line and monthly thereafter with an approved gas analyzer and the results recorded. For turnarounds and all other situations, leaks are indicated by readings of 500 ppmv and must be repaired within 24 hours or a cap, blind flange, plug, or second valve must be installed on the line or valve.

F. Accessible valves shall be monitored by leak-checking for fugitive emissions at least quarterly using an approved gas analyzer. Sealless/leakless valves (including, but not limited to, welded bonnet bellows and diaphragm valves) and relief valves equipped with a rupture disc upstream or venting to a control device are not required to be monitored. If a relief valve is equipped with rupture disc, a pressure-sensing device shall be installed between the relief valve and rupture disc to monitor disc integrity.

A check of the reading of the pressure-sensing device to verify disc integrity shall be performed at least quarterly and recorded in the unit log or equivalent. Pressure-sensing devices that are continuously monitored with alarms are exempt from recordkeeping requirements specified in this paragraph. All leaking discs shall be replaced at the earliest opportunity but no later than the next process shutdown.

The gas analyzer shall conform to requirements listed in Method 21 of 40 CFR part 60, appendix A. The gas analyzer shall be calibrated with methane. In addition, the response factor of the instrument for a specific VOC of interest shall be determined and meet the requirements of Section 8 of Method 21. If a mixture of VOCs is being monitored, the response factor shall be calculated for the average composition of the process fluid. A calculated average is not required when all of the compounds in the mixture have a response factor less than 10 using methane. If a response factor less than 10 cannot be achieved using methane, then the instrument may be calibrated with one of the VOC to be measured

or any other VOC so long as the instrument has a response factor of less than 10 for each of the VOC to be measured.

Replacements for leaking components shall be re-monitored within 15 days of being placed back into VOC service.

G. Except as may be provided for in the special conditions of this permit, all pump, compressor, and agitator seals shall be monitored with an approved gas analyzer at least quarterly or be equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal. Seal systems designed and operated to prevent emissions or seals equipped with automatic seal failure detection and alarm system need not be monitored. These seal systems may include (but are not limited to) dual pump seals with barrier fluid at higher pressure than process pressure, seals degassing to vent control systems kept in good working order, or seals equipped with an automatic seal failure detection and alarm system. Submerged pumps or sealless pumps (including, but not limited to, diaphragm, canned, or magnetic-driven pumps) may be used to satisfy the requirements of this condition and need not be monitored.

H. Damaged or leaking valves or connectors found to be emitting VOC in excess of 500 parts per million by volume (ppmv) or found by visual inspection to be leaking (e.g., dripping process fluids) shall be tagged and replaced or repaired. Damaged or leaking pump, compressor, and agitator seals found to be emitting VOC in excess of 2,000 ppmv or found by visual inspection to be leaking (e.g., dripping process fluids) shall be tagged and replaced or repaired. A first attempt to repair the leak must be made within 5 days and a record of the attempt shall be maintained.

I. A leaking component shall be repaired as soon as practicable, but no later than 15 days after the leak is found. If the repair of a component would require a unit shutdown that would create more emissions than the repair would eliminate, the repair may be delayed until the next scheduled shutdown. All leaking components which cannot be repaired until a scheduled shutdown shall be identified for such repair by tagging within 15 days of the detection of the leak. A listing of all components that qualify for delay of repair shall be maintained on a delay of repair list. The cumulative daily emissions from all components on the delay of repair list shall be estimated by multiplying by 24 the mass emission rate for each component calculated in accordance with the instructions in 30 TAC 115.782 (c)(1)(B)(i)(II). The calculations of the cumulative daily emissions from all components on the delay of repair list shall be updated within ten days of when the latest leaking component is added to the delay of repair list. When the cumulative daily emission rate of all components on the delay of repair list times the number of days until the next scheduled unit shutdown is equal to or exceeds the total emissions from a unit shut down as calculated in accordance with 30 TAC 115.782 (c)(1)(B)(i)(I), the TCEQ Regional Manager and any local programs shall be notified and may require early unit shut down or other appropriate action based on the number and severity of tagged leaks awaiting shutdown. This notification shall be made within 15 days of making this determination.

J. Records of repairs shall include date of repairs, repair results, justification for delay of repairs, and corrective actions taken for all components. Records of instrument monitoring shall indicate dates and times, test methods, and instrument readings. The instrument monitoring record shall include the time that monitoring took place for no less than 95% of the instrument readings recorded. Records of physical inspections shall be noted in the operator’s log or equivalent.

K. Alternative monitoring frequency schedules of 30 TAC 115.352 - 115.359 or National Emission Standards for Organic Hazardous Air Pollutants, 40 CFR Part 63, Subpart H, may be used in lieu of Items F through G of this condition.

L. Compliance with the requirements of this condition does not assure compliance with requirements of 30 TAC Chapter 115, an applicable New Source Performance Standard (NSPS), or an applicable National Emission Standard for Hazardous Air Pollutants (NESHAPS) and does not constitute approval of alternative standards for these regulations.

18. Pump and compressors equipped with single seals in HRVOC (as defined in 30 TAC §115.10 unless exempted by §115.787) or greater than 10 weight percent benzene service shall be monitored with a leak definition of 500 ppmv rather than the 2,000 ppmv identified in Special Condition No. 17H.

19. In addition to the weekly physical inspection required by Item E of Special Condition No. 17, all connectors in non-HRVOC gas/vapor and light liquid service shall be monitored annually with an approved gas analyzer in accordance with Items F through J of Special Condition No. 17. Alternative monitoring frequency schedules (skip options) of 40 CFR Part 63, Subpart H, National Emission Standards for Organic Hazardous Air Pollutants for Equipment Leaks, may be used in lieu of the monitoring frequency required by this permit condition. Compliance with this condition does not assure compliance with requirements of applicable state or federal regulation and does not constitute approval of alternative standards for these regulations.

20. In addition to the weekly physical inspection required by Item E of Special Condition No. 17, all accessible connectors in HRVOC gas/vapor and light liquid service shall be monitored quarterly with an approved gas analyzer in accordance with Items F through J of Special Condition No. 17.

A. Connectors may be monitored on a semiannual basis if the percent of connectors leaking for two consecutive quarterly monitoring periods is less than 0.5 percent.

Connectors may be monitored on an annual basis if the percent of connectors leaking for two consecutive semiannual monitoring periods is less than 0.5 percent.

If the percent of connectors leaking for any semiannual or annual monitoring period is 0.5 percent or greater, the facility shall revert to quarterly monitoring until the facility again qualifies for the alternative monitoring schedules previously outlined in this paragraph.

B. The percent of connectors leaking used in paragraph A shall be determined using the following formula:

$(Cl + Cs) \times 100/Ct = Cp$

Where:

Cl = the number of connectors found leaking by the end of the monitoring period, either by Method 21 or sight, sound, and smell.

Cs = the number of connectors for which repair has been delayed and are listed on the facility shutdown log.

Ct = the total number of connectors in the facility subject to the monitoring requirements, as of the last day of the monitoring period, not including nonaccessible and unsafe-to-monitor connectors.

Cp = the percentage of leaking connectors for the monitoring period.

21. **Piping, Valves, Pumps, Agitators, and Compressors - Intensive Directed Maintenance - 28LAER**

This special condition applies to components associated with the construction of Cracking Heater F-3419 as submitted in the application dated September 23, 2011.

Except as may be provided for in the special conditions of this permit, the following requirements apply to the above-referenced equipment:

A. The requirements of paragraphs F and G shall not apply (1) where the VOC has an aggregate partial pressure or vapor pressure of less than 0.044 pounds per square inch, absolute (psia) at 68°F or (2) operating pressure is at least 5 kilopascals (0.725 psi) below ambient pressure. Equipment excluded from this condition shall be identified in a list or by one of the methods described below to be made readily available upon request.

The exempted components may be identified by one or more of the following methods:

i. piping and instrumentation diagram (PID);

ii. a written or electronic database or electronic file;

iii. color coding;

iv. a form of weatherproof identification; or

v. designation of exempted process unit boundaries.

B. Construction of new and reworked piping, valves, pump systems, and compressor systems shall conform to applicable American National Standards Institute (ANSI), American Petroleum Institute (API), American Society of Mechanical Engineers (ASME), or equivalent codes.

C. New and reworked underground process pipelines shall contain no buried valves such that fugitive emission monitoring is rendered impractical. New and reworked buried connectors shall be welded.

D. To the extent that good engineering practice will permit, new and reworked valves and piping connections shall be so located to be reasonably accessible for leak-checking during plant operation. Difficult-to-monitor and unsafe-to-monitor valves, as defined by Title 30 Texas Administrative Code Chapter 115 (30 TAC Chapter 115), shall be identified in a list to be made readily available upon request. The difficult-to-monitor and unsafe-to-monitor valves may be identified by one or more of the methods described in subparagraph A above. If an unsafe-to-monitor component is not considered safe to monitor within a calendar year, then it shall be monitored as soon as possible during safe-to-monitor times. A difficult-to-monitor component for which quarterly monitoring is specified may instead be monitored annually.

E. New and reworked piping connections shall be welded or flanged. Screwed connections are permissible only on piping smaller than two-inch diameter. Gas or hydraulic testing of the new and reworked piping connections at no less than operating pressure shall be performed prior to returning the components to service or they shall be monitored for leaks using an approved gas analyzer within 15 days of the components being returned to service. Adjustments shall be made as necessary to obtain leak-free performance.

Connectors shall be inspected by visual, audible, and/or olfactory means at least weekly by operating personnel walk-through. In addition, all connectors shall be monitored by leak-

checking for fugitive emissions at least quarterly using an approved gas analyzer with a directed maintenance program in accordance with items F thru J of this special condition.

In lieu of the monitoring frequency specified above, connectors may be monitored on a semiannual basis if the percent of connectors leaking for two consecutive quarterly monitoring periods is less than 0.5 percent.

Connectors may be monitored on an annual basis if the percent of connectors leaking for two consecutive semiannual monitoring periods is less than 0.5 percent.

If the percent of connectors leaking for any semiannual or annual monitoring period is 0.5 percent or greater, the facility shall revert to quarterly monitoring until the facility again qualifies for the alternative monitoring schedules previously outlined in this paragraph.

The percent of connectors leaking used in paragraph B shall be determined using the following formula:

$(Cl + Cs) \times 100/Ct = Cp$

Where:

Cl = the number of connectors found leaking by the end of the monitoring period, either by Method 21 or sight, sound, and smell.

Cs = the number of connectors for which repair has been delayed and are listed on the facility shutdown log.

Ct = the total number of connectors in the facility subject to the monitoring requirements, as of the last day of the monitoring period, not including non-accessible and unsafe-to-monitor connectors.

Cp = the percentage of leaking connectors for the monitoring period.

Each open-ended valve or line shall be equipped with an appropriately sized cap, blind flange, plug, or a second valve to seal the line. Except during sampling, both valves shall be closed. If the isolation of equipment for hot work or the removal of a component for repair or replacement results in an open ended line or valve, it is exempt from the requirement to install a cap, blind flange, plug, or second valve for 72 hours. If the repair or replacement is not completed within 72 hours, the permit holder must complete either of the following actions within that time period;

i. a cap, blind flange, plug, or second valve must be installed on the line or valve; or

ii. the open-ended valve or line shall be monitored once for leaks

above background for a plant or unit turnaround lasting up to 45 days with an approved gas analyzer and the results recorded. For all other situations, the open-ended valve or line shall be monitored once by the end of the 72 hours period following the creation of the open ended line and monthly thereafter with an approved gas analyzer and the results recorded. For turnarounds and all other situations, leaks are indicated by readings of 500 ppmv and must be repaired within 24 hours or a cap, blind flange, plug, or second valve must be installed on the line or valve.

F. Accessible valves shall be monitored by leak-checking for fugitive

emissions at least quarterly using an approved gas analyzer with a directed maintenance program. Non-accessible valves shall be monitored by leak-checking for fugitive emissions at least annually using an approved gas analyzer with a directed maintenance program. Sealless/leakless valves (including, but not limited to, welded bonnet bellows and diaphragm valves) and relief valves equipped with a rupture disc upstream or venting to a control device are not required to be monitored. For valves equipped with rupture discs, a pressure-sensing device shall be installed between the relief valve and rupture disc to monitor disc integrity. All leaking discs shall be replaced at the earliest opportunity but no later than the next process shutdown. A check of the reading of the pressure-sensing device to verify disc integrity shall be performed at least quarterly and recorded in the unit log or equivalent. Pressure-sensing devices that are continuously monitored with alarms are exempt from recordkeeping requirements specified in this paragraph.

The gas analyzer shall conform to requirements listed in Method 21 of 40 CFR part 60, appendix A. The gas analyzer shall be calibrated with methane. In addition, the response factor of the instrument for a specific VOC of interest shall be determined and meet the requirements of Section 8 of Method 21. If a mixture of VOCs are being monitored, the response factor shall be calculated for the average composition of the process fluid. A calculated average is not required when all of the compounds in the mixture have a response factor less than 10 using methane. If a response factor less than 10 cannot be achieved using methane, than the instrument may be calibrated with one of the VOC to be measured or any other VOC so long as the instrument has a response factor of less than 10 for each of the VOC to be measured.

A directed maintenance program shall consist of the repair and maintenance of components assisted simultaneously by the use of an approved gas analyzer such that a minimum concentration of leaking VOC is obtained for each component being maintained. Replaced components shall be re-monitored within 15 days of being placed back into VOC service.

G. All new and replacement pumps, compressors, and agitators shall be equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal. These seal systems need not be monitored and may include (but are not limited to) dual pump seals with barrier fluid at higher pressure than process pressure, seals degassing to vent control systems kept in good working order, or seals equipped with an automatic seal failure detection and alarm system. Submerged pumps or sealless pumps (including, but not limited to, diaphragm, canned, or magnetic-driven pumps) may be used to satisfy the requirements of this condition and need not be monitored.

All other pump, compressor, and agitator seals shall be monitored with an approved gas analyzer at least quarterly.

H. Damaged or leaking valves, connectors, compressor seals, pump seals, and agitator seals found to be emitting VOC in excess of 500 parts per million by volume (ppmv) or found by visual inspection to be leaking (e.g., dripping process fluids) shall be tagged and replaced or repaired. A first attempt to repair the leak must be made within 5 days. Records of the first attempt to repair shall be maintained. A leaking component shall be repaired as soon as practicable, but no later than 15 days after the leak is found. If the repair of a component would require a unit shutdown that would create more emissions than the repair would eliminate, the repair may be delayed until the next scheduled shutdown. All leaking components which cannot be repaired until a scheduled shutdown shall be identified for such repair by tagging. A listing of all components that qualify for delay of repair shall be maintained on a delay of repair list. The cumulative daily emissions from all components on the delay of repair list shall be estimated by multiplying by 24 the mass emission rate for

each component calculated in accordance with the instructions in 30 TAC 115.782 (c)(1)(B)(i)(II). The calculations of the cumulative daily emissions from all components on the delay of repair list shall be updated within ten days of when the latest leaking component is added to the delay of repair list. When the cumulative daily emission rate of all components on the delay of repair list times the number of days until the next scheduled unit shutdown is equal to or exceeds the total emissions from a unit shutdown as calculated in accordance with 30 TAC 115.782 (c)(1)(B)(i)(I), the TCEQ Regional Manager and any local programs shall be notified and may require early unit shutdown or other appropriate action based on the number and severity of tagged leaks awaiting shutdown. This notification shall be made within 15 days of making this determination.

I. Records of repairs shall include date of repairs, repair results, justification for delay of repairs, and corrective actions taken for all components. Records of instrument monitoring shall indicate dates and times, test methods, and instrument readings. The instrument monitoring record shall include the time that monitoring took place for no less than 95% of the instrument readings recorded. Records of physical inspections shall be noted in the operator's log or equivalent.

J. Compliance with the requirements of this condition does not assure compliance with requirements of 30 TAC Chapter 115, an applicable New Source Performance Standard (NSPS), or an applicable National Emission Standard for Hazardous Air Pollutants (NESHAPS), and does not constitute approval of alternative standards for these regulations.

K. In lieu of the monitoring frequency specified in paragraph F, valves in gas and light liquid service may be monitored on a semiannual basis if the percent of valves leaking for two consecutive quarterly monitoring periods is less than 0.5 percent.

Valves in gas and light liquid service may be monitored on an annual basis if the percent of valves leaking for two consecutive semiannual monitoring periods is less than 0.5 percent.

If the percent of valves leaking for any semiannual or annual monitoring period is 0.5 percent or greater, the facility shall revert to quarterly monitoring until the facility again qualifies for the alternative monitoring schedules previously outlined in this paragraph.

L. The percent of valves leaking used in paragraph K shall be determined using the following formula:

$(Vl + Vs) \times 100/Vt = Vp$

Where:

Vl = the number of valves found leaking by the end of the monitoring period, either by Method 21 or sight, sound, and smell.

Vs = the number of valves for which repair has been delayed and are listed on the facility shutdown log.

Vt = the total number of valves in the facility subject to the monitoring requirements, as of the last day of the monitoring period, not including nonaccessible and unsafe-to-monitor valves.

Vp = the percentage of leaking valves for the monitoring period.

M. Any component found to be leaking by physical inspection (i.e., sight, sound, or smell) shall be repaired or monitored with an approved gas analyzer within 15 days to determine whether the component is leaking in excess of 500 ppmv of VOC. If the component is found to be

leaking in excess of 500 ppmv of VOC, it shall be subject to the repair and replacement requirements contained in this special condition.

Initial Determination of Compliance

22. The holder of this permit shall perform stack sampling and other testing as required to establish the actual pattern and quantities of air contaminants being emitted into the atmosphere from the cracking heaters (EPN 34HTHTRS for F-3401, F-3402, F-3403, F-3404, F-3405, F-3406, F -3407, F-3408, F-3409, F-3410, F-3411, F-3412, F-3413, F-3414, F-3418, and EPN EF3419 for F-3419). Three cracking furnace stacks, to be determined by the permit holder with agreement of the TCEQ Houston Regional Office may be tested as representative of the eight cracking furnace stacks, Ethane Heater (EPN 34E18), and Steam Superheaters (EPN 38E04). The holder of this permit is responsible for providing sampling and testing facilities and conducting the sampling and testing operations at his expense.

A. The appropriate TCEQ Regional Office in the region where the source is located shall be contacted as soon as testing is scheduled, but not less than 45 days prior to sampling to schedule a pretest meeting.

The notice shall include:

(1) Date for pretest meeting.

(2) Date sampling will occur.

(3) Name of firm conducting sampling.

(4) Type of sampling equipment to be used.

(5) Method or procedure to be used in sampling.

The purpose of the pretest meeting is to review the necessary sampling and testing procedures, to provide the proper data forms for recording pertinent data, and to review the format procedures for submitting the test reports.

A written proposed description of any deviation from sampling procedures specified in permit conditions, TCEQ, or EPA sampling procedures shall be made available to the TCEQ prior to the pretest meeting. The TCEQ Regional Director shall approve or disapprove of any deviation from specified sampling procedures.

Requests to waive testing for any pollutant specified in B of this condition shall be submitted to the TCEQ, Office of Permitting and Registration, Austin.

Test waivers and alternate/equivalent procedure proposals for NSPS testing which must have the EPA approval shall be submitted to the TCEQ Houston Regional Office, Houston.

B. Air contaminants emitted from the cracking heaters, ethane heater, and steam superheaters to be tested for include (but are not limited to) NO_x and CO.

C. Sampling may be required by the Executive Director of the TCEQ. Requests for additional time to perform sampling shall be submitted to the TCEQ Regional Office.

D. The source being tested shall operate at maximum represented operating rates during stack emission testing. Primary operating parameters that enable determination of firing rates shall

be monitored and recorded during the stack test. These parameters are to be determined at the pretest meeting.

If the source is unable to operate at maximum represented operating rates during testing, then additional stack testing may be required when higher represented operating rates are achieved.

E. Copies of the final sampling report shall be forwarded to the TCEQ within 60 days after all sampling is completed. Sampling reports shall comply with the attached provisions of Chapter 14 of the TCEQ Sampling Procedures Manual. The reports shall be distributed as follows:

One copy to the TCEQ Houston Regional Office, Houston.

One copy to the Harris County Air Pollution Control Program, Pasadena.

Continuous Demonstration of Compliance

23. The permit holder shall install, calibrate, and maintain a predictive emission monitoring system (PEMS) to measure and record the in-stack concentration of NO_x from the Cracking Heaters (EPN 34HTHTRS for F-3401, F-3402, F-3403, F-3404, F-3405, F-3406, F -3407, F-3408, F-3409, F-3410, F-3411, F-3412, F-3413, F-3414, and F-3418, and EPN EF3419 for F-3419) when in operation.

A. A PEMS may be used for demonstrating continuous compliance if it can be proven to have the same or better accuracy, precision, reliability, accessibility, and timeliness as that provided by a hardware CEMS. All PEMS shall be subject to the approval of the TCEQ Executive Director. Owners or operators must petition the TCEQ Executive Director for approval to use PEMS. The petition must include results of tests conducted beforehand to demonstrate equivalent accuracy and precision of PEMS to that of hardware CEMS. Demonstrating equivalency of PEMS to CEMS shall be met by instantaneously comparing data collected by PEMS with that collected by a certified hardware CEMS or an EPA reference method. For a PEMS replacing a CEMS, both systems shall remain in place for at least an operating quarter collecting valid information before the CEMS is removed.

B. For any unit at which the PEMS is installed, PEMS initial certification by the TCEQ shall occur while the unit is firing its primary fuel. The owner or operator shall:

(1) Conduct relative accuracy testing for NO_x and O_2, or carbon dioxide (CO_2) per 40 CFR Part 60, Appendix B, Performance Specifications 2, 3, and 4, respectively, at low, medium, and high levels of the most significant operating parameter affecting NO_x emissions.

(2) Conduct statistical test analysis at low, medium, and high levels of the most significant operating parameter affecting NO_x emissions. A minimum of 30 successive paired data points which are either 15-minute averages, 20-minute averages, or hourly averages must be collected at each tested level before a reliable statistical test can be performed.

Data collection must be continuous at all times except when calibration of the reference method must be conducted for the purpose of collecting data for relative accuracy test audit (RATA).

The following three tests must be conducted to demonstrate precision:

(i) A T-test for bias per Appendix A, 40 CFR Part 75, § 7.6. The test shall be conducted using all paired data points collected at all three tested levels.

(ii) An F-test per 40 CFR §75.41(c)(1). The F-test must be conducted separately at the three tested levels.

(iii) A correlation analysis per 40 CFR §75.41(c)(2). Calculation of the correlation coefficient (Equation 27) shall be performed using all paired data points collected at all three tested levels.

(3) For NO_x and CO and for the purpose of conducting an F-test, if the standard deviation (SD) of the reference method is less than either 3 percent of the span or 5 parts per million (ppm), use a reference method SD of the greater of 5 ppm or 3 percent of span.

(4) For diluent CO_2 or O_2 and for the purpose of conducting an F-test, if the SD of the reference method is less than 3 percent of span, use a reference method SD of 3 percent of span.

(5) For NO_x at anyone tested level, if the mean value of the reference method is less than either 10 ppm or 5 percent of the standard, all statistical tests are waived for that emission parameter at that specific tested level.

(6) For either O_2 or CO_2 and at anyone tested level, if the mean value of the reference method is less than 3 percent of span, all the statistical tests are waived for that diluent parameter at that specific tested level.

C. The monitoring data shall be reduced to hourly average concentrations at least once every day, using a minimum of four equally-spaced data points from each one-hour period. The individual average concentrations shall be reduced to units of pound per million Btu at least once every week. All monitoring data and quality-assurance data shall be maintained by the permit holder.

D. Any PEMS downtime shall be reported to the appropriate TCEQ Regional Director per §117.345(d)(3) and necessary corrective action shall be taken. Quality-assured (or valid) data must be generated when the cracking heaters (EPN 34HTHTRS and EF3419) are operating except during the performance of a daily zero and span check. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted provided it does not exceed five percent of the time (in minutes) that the cracking heaters (EPN 34HTHTRS and EF3419) operated over the previous rolling 12-month period. Owners or operators shall demonstrate that all missing data can be accounted for in accordance with the applicable missing data procedures of 30 TAC 117.340. Supplemental stack concentration measurements may be required at the discretion of the appropriate TCEQ Regional Director.

E. The appropriate TCEQ Regional Office shall be notified for each annual RATA in order to provide them the opportunity to observe the testing.

F. The owner or operator shall perform daily sensor validation. The owner or operator shall develop and implement plans that will ensure proper functioning of the monitoring systems, ensure proper accuracy and calibration of all operational parameters that affect emissions and serve as input to the predictive monitoring system, and ensure continuous operation within the certified operating range.

G. In accordance with the procedure of § 2.3.1, Appendix B of 40 CFR Part 60, a RATA must be performed every six months for each unit while firing its primary fuel. A RATA may be performed annually if the relative accuracy of the previous audit is 7.5 percent or less.

H. For each of the three successive quarters following the quarter in which initial certification was conducted, RATA and statistical testing must be conducted for at least one unit in a category of units in accordance with the procedures outlined for initial certification under Section B.

I. Any RATA exceeding 20 percent or statistical test exceeding the applicable standard shall be reported to the appropriate TCEQ Regional Director, and necessary corrective action shall be taken.

J. When an alternative fuel is fired in a unit, PEMS must be re-certified in accordance with the certification procedures outlined for initial certification under Section B. Owners or operators may justify to the satisfaction of the TCEQ Executive Director that slight changes in fuel composition do not constitute an alternative fuel. No additional recertification procedures are required if the unit meets the current monitoring requirements when switching back to the normal fuel from an alternate fuel.

K. The system is required to provide valid emission predictions for at least 95 percent of the time that the unit being monitored is operated. The following rules for tuning without recertification shall be followed:

(1) The model did not change fundamentally.

(2) The model continues to operate within the initially certified operating ranges.

Otherwise, the system must be recertified. Any tuning must be documented, and the records must be made available during any future inspection.

L. All owners or operators shall develop a quality-assurance plan or manual that insures continuous and reliable performance of the PEMS. As part of the plan, owners or operators shall recommend a frequency for calibrating each sensor whose readout serves as an input to the model. All sensors, at a minimum, shall be calibrated as often as recommended by the manufacturer.

M. As an alternative to Paragraphs A.-L. of this condition, the permit holder may install a continuous emission monitoring system (CEMS) to measure and record the in-stack concentration of NO_x from the Cracking Heaters (EPN 34HTHTRS for F-3401, F-3402, F-3403, F-3404, F-3405, F-3406, F -3407, F-3408, F-3409, F-3410, F-3411, F-3412, F-3413, F-3414, F-3415, F-3418 and EPN EF3419 for F-3419) when in operation. The CEMS shall meet the requirements in special condition 23 A.-E. of this permit.

24. Opacity of emissions from cracking heaters, heaters, and decoking cyclones shall not exceed 15 percent averaged over a six-minute period except for those periods described in 30 TAC §111.111.

Production Limits and Recordkeeping

25. Production rates shall not exceed 11.3 billion pounds per year of all products. The holder of this permit shall maintain records on the operation of the facility for five years. Records shall include (but are not limited to) hours of operation, production rates, hours of operation of each heater unit, time period pre-regeneration gases are purged to each flare unit, and time period regeneration cycle emits to the atmosphere.

Cooling Tower

26. The VOC associated with cooling tower (EPN 38E11) water shall be monitored monthly with an air stripping system meeting the requirements of the TCEQ Sampling Procedures Manual, Appendix P (dated January 2003 or a later edition) or an approved equivalent sampling method. The results of the monitoring, cooling water flow rate, and maintenance activities on the cooling water system shall be recorded. The monitoring results and cooling water hourly mass flow rate shall be used to determine cooling tower hourly VOC emissions. The rolling 12 month cooling water emission rate shall be recorded on a monthly basis and be determined by summing the VOC emissions between VOC monitoring periods over the rolling 12 month period. The emissions between VOC monitoring periods shall be obtained by multiplying the total cooling water mass flow between cooling water monitoring periods by the higher of the 2 VOC monitored results. Cooling water sampling as required by 30 TAC Chapter 115 Subchapter H may be used in lieu of this special condition.

27. Cooling water shall be sampled once a week for total dissolved solids (TDS) and once a day for conductivity. On-line conductivity meter may be used in lieu of collecting daily sample. Dissolved solids in the cooling water drift are considered to be emitted as PM_{10}. The data shall result from collection of water samples from the cooling tower feed water and represent the water being cooled in the tower. Water samples should be capped upon collection and transferred to a laboratory area for analysis. The analysis method for TDS shall be EPA Method 160.1, ASTM D5907, and SM 2540 C [SM - 19th edition of Standard Methods for Examination of Water]. The analysis method for Conductivity shall be ASTM D1125-95A and SM2510 B. Use of an alternative method shall be approved by the TCEQ Regional Director prior to its implementation.

Wastewater

28. Process wastewater drains shall be equipped with water seals or equivalent; lift stations, manholes, junction boxes, any process wastewater collection system components, and conveyance, shall be equipped with a closed vent system that routes all organic vapor to a control device.

    Water seals shall be checked by visual or physical inspection quarterly for indications of low water levels or other conditions that would reduce the effectiveness of water seal controls. Water seals shall be restored as necessary within 24 hours. Records shall be maintained of these inspections and corrective actions taken.

Maintenance, Start-Up, and Shutdown Operations

29. This permit authorizes the emissions from facilities for the planned maintenance, startup, and shutdown (MSS) activities summarized in the MSS Activity Summary (Attachment C) attached to this permit.

    Routine maintenance activities, as identified in Attachment B of this permit, may be tracked through work orders or their equivalent. Emissions from activities identified in Attachment C shall be calculated using the number of work orders or equivalent that month and the emissions associated with that activity identified in the permit application.

    The performance of each planned MSS activity not identified in Attachment C and the emissions associated with it shall be recorded and include at least the following information:

A. the process unit at which emissions from the MSS activity occurred, including the emission point number and common name of the process unit;

B. the type of planned MSS activity and the reason for the planned activity;

C. the common name and the facility identification number, if applicable, of the facilities at which the MSS activity and emissions occurred;

D. the date and time of the MSS activity and its duration;

E. the estimated quantity of each air contaminant, or mixture of air contaminants, emitted with the data and methods used to determine it. The emissions shall be estimated using the methods identified in the permit application, consistent with good engineering practice.

All MSS emissions shall be summed monthly and the rolling 12-month emissions shall be updated on a monthly basis.

30. Process units and facilities shall be depressurized, emptied, degassed, and placed in service in accordance with the following requirements:

A. The process equipment shall be depressurized to a control device, transferred within the process unit, transferred to another process unit, transferred to a pressurized storage tank, or depressurized to a controlled recovery system prior to venting to atmosphere, degassing, or draining liquid. Equipment that only contains material that is liquid with volatile organic compounds (VOC) partial pressure less than 0.50 pound per square inch, absolute (psia) at the highest of the actual temperature or 95°F may be opened to atmosphere and drained in accordance with Paragraph C of this special condition. The vapor pressure at 95°F may be used if the actual temperature of the liquid is verified to be less than 95°F and the temperature is recorded.

B. If mixed phase materials must be removed from process equipment, the cleared material shall be routed to a knockout drum or equivalent to allow for managed initial phase separation, transferred within the process unit, transferred to another process unit, or transferred to a pressurized storage tank. If the VOC partial pressure is greater than 0.50 psi at either the actual temperature or 95°F, any vents in the system must be routed to a control device or a controlled recovery system. The vapor pressure at 95°F may be used if the actual temperature of the liquid is verified to be less than 95°F and the temperature is recorded. Control must remain in place until degassing has been completed or the system is no longer vented to atmosphere.

C. All liquids from process equipment or storage vessels must be removed to the maximum extent practical prior to opening equipment to commence degassing and/or maintenance. Liquids must be drained into a closed vessel or closed liquid recovery system unless prevented by the physical configuration of the equipment, transferred within the process unit, transferred to another process unit, or transferred to a pressurized or an atmospheric storage tank. If it is necessary to drain liquid into an open pan or sump, the liquid must be covered or transferred to a covered vessel within one hour of being drained.

D. If the VOC partial pressure is greater than 0.50 psi at the normal process temperature or 95°F, facilities shall be degassed using good engineering practice to ensure air contaminants are removed from the system through the control device or controlled recovery system to the extent allowed by process equipment or storage vessel design. The vapor pressure at 95°F may be used if the actual temperature of the liquid is verified to be less than 95°F and the temperature is recorded. The facilities to be degassed shall not be vented directly to atmosphere, except as necessary to establish isolation of the work area or to monitor VOC

concentration following controlled depressurization. The venting shall be minimized to the maximum extent practicable and actions taken recorded. The control device or recovery system utilized shall be recorded with the estimated emissions from controlled and uncontrolled degassing calculated using the methods that were used to determine allowable emissions for the permit application.

(1) For MSS activities identified in Attachment C, the following option may be used in lieu of item (2) below. The facilities being prepared for maintenance shall not be vented directly to atmosphere until the VOC concentration has been verified to be less than 10,000 ppmv or less than 10 percent of the lower explosive limit (LEL) per the site safety procedures.

(2) The locations and/or identifiers where the purge gas or steam enters the process equipment or storage vessel and the exit points for the exhaust gases shall be recorded (process flow diagrams [PFDs] or piping and instrumentation diagrams [P&IDs] may be used to demonstrate compliance with the requirement). If the process equipment is purged with a gas, two system volumes of purge gas must have passed through the control device or controlled recovery system before the vent stream may be sampled to verify acceptable VOC concentration prior to uncontrolled venting. The VOC sampling and analysis shall be performed using an instrument meeting the requirements of SC No. 28. The sampling point shall be upstream of the inlet to the control device or controlled recovery system. The sample ports and the collection system must be designed and operated such that there is no air leakage into the sample probe or the collection system downstream of the process equipment or vessel being purged. The facilities shall be degassed to a control device or controlled recovery system until the VOC concentration is less than 10,000 ppmv or 10 percent of the LEL. Documented site procedures used to de-inventory equipment to a control device for safety purposes (e.g., hot work or vessel entry procedures) that achieve at least the same level of purging may be used in lieu of the above.

E. Gases and vapors with VOC partial pressure greater than 0.50 psi may be vented directly to atmosphere if all the following criteria are met:

(1) It is not technically practicable to depressurize or degas, as applicable, into the process;

(2) There is not an available connection to a plant control system (flare); and

(3) There is no more than 50 lbs of air contaminant to be vented to atmosphere during shutdown or start-up, as applicable.

All instances of venting directly to atmosphere per sub-paragraph E. of this condition must be documented when occurring as part of any MSS activity. The emissions associated with venting without control must be included in the work order or equivalent for those planned MSS activities identified in Attachment C.

31. Air contaminant concentration shall be measured using an instrument/detector meeting one set of requirements specified below.

A. VOC concentration shall be measured using an instrument meeting all the requirements specified in EPA Method 21 (40 CFR Part 60, Appendix A) with the following exceptions:

(1) The instrument shall be calibrated within 24 hours of use with a calibration gas such that the response factor (RF) of the VOC (or mixture of VOCs) to be monitored shall be less than 2.0. The calibration gas and the gas to be measured, and its approximate RF

shall be recorded. If the RF of the VOC (or mixture of VOCs) to be monitored is greater than 2.0, the VOC concentration shall be determined as follows:

VOC Concentration = Concentration as read from the instrument*RF

In no case should a calibration gas be used such that the RF of the VOC (or mixture of VOCs) to be monitored is greater than 5.0.

(2) Sampling shall be performed as directed by this permit in lieu of section 8.3 of Method 21. During sampling, data recording shall not begin until after two times the instrument response time. The date and time shall be recorded, and VOC concentration shall be monitored for at least five minutes, recording VOC concentration each minute. As an alternative the VOC concentration may be monitored over a five-minute period with an instrument designed to continuously measure concentration and record the highest concentration read. The highest measured VOC concentration shall be recorded and shall not exceed the specified VOC concentration limit prior to uncontrolled venting.

B. Colorimetric gas detector tubes may be used to determine air contaminant concentrations if they are used in accordance with the following requirements.

(1) The air contaminant concentration measured as defined in (3) is less than 80 percent of the range of the tube and is at least 20 percent of the maximum range of the tube.

(2) The tube is used in accordance with the manufacturer's guidelines.

(3) At least two samples taken at least five minutes apart must satisfy the following prior to uncontrolled venting:

measured contaminant concentration (ppmv) < release concentration.

Where the release concentration is:

10,000* mole fraction of the total air contaminants present that can be detected by the tube.

The mole fraction may be estimated based on process knowledge. The release concentration and basis for its determination shall be recorded.

Records shall be maintained of the tube type, range, measured concentrations, and time the samples were taken.

C. Lower explosive limit measured with a lower explosive limit detector.

(1) The detector shall be calibrated within 30 days prior to use with a certified pentane gas standard at 58 percent of the LEL for pentane. Records of the calibration date/time and calibration result (pass/fail) shall be maintained.

(2) A functionality test shall be performed within 24 hours prior to use on each detector using the same certified gas standard used for calibration. The LEL monitor shall read no lower than 90 percent of the calibration gas certified value. Records, including the date/time and test results, shall be maintained.

(3) A certified methane gas standard equivalent to 58 percent of the LEL for pentane may be used for calibration and functionality tests provided that the LEL response is within 95 percent of that for pentane.

D. Gas Chromatograph. As an alternative to an instrument/detector, the analysis may be conducted in a laboratory. Bag samples of the gas discharged may be drawn and taken to an onsite laboratory to be analyzed by gas chromatography (GC). A minimum of two bag

samples shall be drawn approximately ten minutes apart. A Tedlar bag, or a bag or glass container appropriate for the material to be sampled, shall be used and shall have a valve to seal gas in the bag or container. The samples shall be drawn as follows:

(1) The sample point on the equipment being cleared shall be purged sufficiently to ensure a representative sample at the sample valve.

(2) The sample bag shall be connected directly to the sample valve or to a pump that is connected directly to the sample valve.

(3) The sample valve and sample bag shall be opened to allow the bag to fill to approximately 80% of capacity. The sample connections shall be fitted such that no air is drawn into the sample bag.

(4) The two valves shall then be closed to seal the sample in the bag.

(5) The sample bag shall then be disconnected and placed in a dark container out of direct sunlight for transport to the analyzer.

(6) This process is repeated to collect additional samples.

(7) The sample shall be analyzed within 12 hours of collection.

(8) If condensation is observed in a bag sample, the sampling must be repeated using one of the modified bag sampling procedures in 40 CFR 60, Appendix A, Method 18 Section 8.

(9) At least two samples taken at least five minutes apart must satisfy the following prior to uncontrolled venting.

The laboratory GC shall meet or exceed the requirements of 40 CFR 60, Appendix A, Method 18 Sections 6 (Equipment and Supplies), 7 (Reagents and Standards), 9 (Quality Control), and 10 (Calibration and Standards). The sample shall be analyzed per Section 8.2.1.5 of Method 18, except the analysis of each bag may be performed in duplicate and use gas tight syringe through septums. The highest measured VOC concentration shall not exceed the specified VOC concentration limit prior to uncontrolled venting. The recovery study for bag sampling and post analysis calibration is only required the first time a vessel is degassed and analyzed if the procedure meets the accuracy specifications of Method 18 and the analytical equipment is not modified. If the material content, temperature and pressure are the same among multiple vessels when sampling occurs, the post analysis calibration need only be conducted on sample(s) from one representative vessel.

32. Additional occurrences of MSS activities authorized by this permit may be authorized under permit by rule only if conducted in compliance with this permit's procedures, emission controls, monitoring, and recordkeeping requirements applicable to the activity.

33. Planned maintenance activities must be conducted in a manner consistent with good practice for minimizing emissions, including the use of air pollution control equipment, practices and processes. All reasonable and practical efforts to comply with Special Condition Nos. 29 through 33 must be used when conducting the planned maintenance activity, until the Commission determines that the efforts are unreasonable or impractical, or that the activity is an unplanned maintenance activity.

Netting & Offsets

34. This Prevention of Significant Deterioration (PSD) permit (PSDTX1272, 25.71 tpy NO_x project increase) is conditioned on the completion of the emission reduction project represented in the permit application (PI-1 dated September 23, 2011) as follows **(11/12)**:

    Methanol Unit Shutdown (November 2008)

    Total NO_x Reduction: 780.4 tpy

    These reductions shall occur prior to the start of operation of the facilities and activities authorized by the indicated PSD permit. The permit holder shall maintain records of these emission reductions.

    Construction of the authorized facilities must begin as defined in 40 CFR § 52.21(b)(9), no later than five years after the all emission reductions identified in the NO_x netting analysis are actually accomplished. If construction does not begin as specified, the netting reductions will no longer be creditable.

    This Nonattainment New Source Review (NNSR) permit (N142) is issued based on the permanent retirement of a TCEQ Emission Reduction Credit (ERC) for 22.42 tpy of VOC emissions reduction at Equistar's Chocolate Bayou Polymer Facility. This ERC provides offsets at the rate of 1.3:1 for the 17.25 tpy of VOC emissions authorized as a project increase by the indicated NNSR permit.

35. The following sources and/or activities are authorized under a Permit by Rule (PBR) by Title 30 Texas Administrative Code Chapter 106 (30 TAC Chapter 106). These lists are not intended to be all inclusive and can be altered without modifications to this permit.

Authorization	Source or Activity
PBR 106675	Authorized a flare that was brought on to control H_2 streams from the process.
PBR 110688	Authorized chemicals used for cooling tower.
PBR 148101	Authorized Dispersant usage.

Date: December 28, 2018

Permit Numbers 1768/PSDTX1272/N142
Attachment A

Approved Chemicals List

Tank	EPN	Material
TK-3455	34E12	Waste Caustic
TK-38008	38E008	Slop Oil
TK-38009	38E009	Wastewater
TK-38010	38E010	Wastewater
TK-38011	38E011	Wastewater
TK-38302	38E07	PGO
TK-38303	38E08	LCO
TK-3901	39E01	Olefins Feedstock, PGO, raw py-gas
TK-3902	39E02	Olefins Feedstock, PGO, raw py-gas
TK-3904	39E04	Olefins Feedstock, PGO, raw py-gas
TK-3905	39E05	Olefins Feedstock, PGO, raw py-gas
TK-3906	39E06	Olefins Feedstock, PGO, raw py-gas
TK-3907	39E07	Olefins Feedstock, PGO, raw py-gas
TK-3911	39E11	Raw PGO, raw pygas
TK-3912	39E12	Treated PGO, raw py-gas, LTPG, raw PGO
TK-3913	39E13	PFO, PGO
TK-3914	39E14	LCO
TK-3943	39E43	LCO

Date: December 28, 2018

Permit Numbers 1768/PSDTX1272/N142
Attachment B

Routine Maintenance Activities

Pump repair/replacement

Fugitive component (valve, pipe, flange) repair/replacement

Compressor repair/replacement

Heat exchanger repair/replacement

Process & Storage Vessel cleaning/repair/replacement

Date: December 28, 2018

Permit Numbers 1768/PSDTX1272/N142
Attachment C

MSS Activity Summary

Facilities	Description	Emissions Activity	EPN
F-3419 and ancillary piping	process unit purge/degas/drain	vent to atmosphere	ENMSSROUT
Flare MSS	Olefins 1 Flare MSS	MSS venting to Flare	38E01

Date: December 28, 2018

Emission Sources - Maximum Allowable Emission Rates

Permit Number 1768/PSDTX1272/N142

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
F34E00	OP1 Fugitives (5)	VOC	73.75	318.55
		NH_3	0.12	0.53
34FGWATER	OP1 Wastewater Fugitives	VOC	1.35	5.89
		Acetone	<0.01	<0.01
EOP1FUGEXP	OP1 Fugitives (5)	VOC	0.46	2.01
EFUGNH3	OP1 NH3 Fugitives (5)	NH_3	0.27	1.18
34E08	Decoke Vent	CO	132.00	113.75
		PM	36.00	6.50
		PM_{10}	36.00	6.50
		$PM_{2.5}$	36.00	6.50
		VOC	0.11	0.10
EOP1DECOKE2	Decoke Vent 2	CO	310.00	59.60
		VOC	0.08	0.02
		PM	1.07	0.10
		PM_{10}	1.07	0.10
		$PM_{2.5}$	1.07	0.10
34E10	Reactor Regeneration Vent	CO	3.56	1.02
		SO_2	9.51	2.23
		VOC	1.38	0.17
38E11	OP1 Cooling Tower	VOC	10.58	19.87
		PM	6.62	29.00
		PM_{10}	3.31	14.50
		$PM_{2.5}$	0.01	0.06
35E03	Seal Oil Reservoir Vent	VOC	0.01	0.01

Emission Sources - Maximum Allowable Emission Rates

35E04	Seal Oil Reservoir Vent	VOC	0.01	0.01
34PVD3420	Dilution Generator Vent	VOC	1.69	0.14
		Acetone	0.05	<0.01
34STMFUG	Dilution Steam Vent	VOC	0.85	1.86
		Acetone	0.02	0.05
38HTF3804A/B	Superheater Vents	VOC	3.81	0.01
34HTHTRS	Pyrolysis and Steam Production Common Stack Cracking Heaters: F-3401 - F-3415; F-3418; F-3419 Common Stack Steam Super Heaters: F380001 A/B	NO_x	494.93	2,022.33
		CO	395.03	1,612.25
		SO_2	33.85	138.17
		PM	37.61	153.52
		PM_{10}	37.61	153.52
		$PM_{2.5}$	37.61	153.52
		NH_3	1.30	5.26
		VOC	24.98	99.18
EF3419	OP-1 Cracking Heater F-3419	NO_x	38.40	25.71
		CO	33.88	148.38
		SO_2	0.38	1.54
		PM	4.23	17.00
		PM_{10}	4.23	17.00
		$PM_{2.5}$	4.23	17.00
		NH_3	2.69	11.78
		VOC	0.64	2.57
36E05	Regeneration Heater F-3601	NO_x	2.50	2.63
		CO	2.06	1.95
		SO_2	0.18	0.19
		PM	0.19	0.18
		PM_{10}	0.19	0.18
		$PM_{2.5}$	0.19	0.18
		VOC	0.13	0.12

Emission Sources - Maximum Allowable Emission Rates

37E03	Recycle Heater F-3701	NO_x	5.60	24.53
		CO	4.61	20.20
		SO_2	0.40	1.77
		PM	0.42	1.83
		PM_{10}	0.42	1.83
		$PM_{2.5}$	0.42	1.83
		VOC	0.28	1.23
38E01	OPI Flare (6)	NOx	104.30	16.30
		CO	537.25	81.36
		SO_2	10.80	3.80
		VOC	1,375.90	49.15
38E3602	Shelter J-3602	VOC	0.01	0.02
38E3603	Shelter J-3603	VOC	0.08	0.34
38E3604	Shelter J-3604	VOC	0.02	0.05
38E3605	Shelter J-3605	VOC	0.01	0.01
38E3606	Shelter J-3606	VOC	0.01	0.01
38E3904	Shelter J-3904	VOC	1.28	5.62
OP1EN1	Diesel Engine Driven Air Compressor (7)	NOx	1.73	3.88
		CO	3.02	6.80
		SO_2	<0.01	0.01
		PM	0.02	0.04
		PM_{10}	0.02	0.04
		$PM_{2.5}$	0.02	0.04
		VOC	0.01	0.02
39E03	Storage Tank 3903 (Wastewater/Storm Water)	VOC	1.93	5.00
37E09	Antifoulant Storage Tank 3709	VOC	0.28	0.01
38E07	Pyrolysis Gas Oil Tank 38302	VOC	7.38	0.88
		Benzene	0.05	0.01

Emission Sources - Maximum Allowable Emission Rates

38E08	Storage Tank 38303	VOC	2.07	0.23
39E13	Pyrolysis Fuel Oil Tank 3913	VOC	11.58	8.06
39E14	Storage Tank 3914	VOC	2.37	1.95
39E43	Storage Tank 3943	VOC	2.37	3.64
39E01	Storage Tank 3901	VOC	8.38	-
		Benzene	2.56	-
		H_2S	0.01	-
39E02	Storage Tank 3902	VOC	8.38	-
		Benzene	2.56	-
		H_2S	0.01	-
39E01 to 39E02	Storage Tanks (2 total)	VOC	-	24.68
		Benzene	-	10.62
		H_2S	-	0.02
39E04	Storage Tank 3904	VOC	5.45	-
		Benzene	1.45	-
		H_2S	0.01	-
39E05	Storage Tank 3905	VOC	5.45	-
		Benzene	1.45	-
		H2S	0.01	-
39E06	Storage Tank 3906	VOC	5.81	-
		Benzene	1.54	-
		H_2S	0.01	-
39E07	Storage Tank 3907	VOC	5.81	-
		Benzene	1.54	-
		H_2S	0.01	-
39E04-39E07	Storage Tanks (4 total)	VOC	14.06	38.94
		Benzene	1.92	9.61
		H_2S	0.01	0.01
39E11	Storage Tank 3911	VOC	2.27	6.84

Emission Sources - Maximum Allowable Emission Rates

		Benzene	1.59	4.80
39E12	Storage Tank 3912	VOC	2.67	7.95
		Benzene	1.87	5.56
OP1SMLT10	Antifoulant Tank 68423	VOC	0.32	0.01
34E12	Waste Caustic Tank 3455	VOC	0.51	1.62
38E008	Slop Oil Tank 38008	VOC	0.35	1.52
38E009	Wastewater Tank 38009	VOC	1.03	1.76
38E010	Wastewater Tank 38010	VOC	1.46	4.85
38E011	Wastewater Tank 38011	VOC	2.80	6.41
ENMSSROUT	MSS Vessel	VOC	4.37	0.05
EOP1ANALY	Analyzers	VOC	0.03	0.13
OP1PV38055	Analyzer Vent	VOC	0.08	0.35
38E3501A	OP-1 Analyzer	VOC	0.01	0.01

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.
(2) Specific point source name. For fugitive sources, use area name or fugitive source name.
(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
NO_x - total oxides of nitrogen
SO_2 - sulfur dioxide
PM - total particulate matter, suspended in the atmosphere, including PM_{10} and $PM_{2.5}$, as represented
PM_{10} - total particulate matter equal to or less than 10 microns in diameter, including $PM_{2.5}$, as represented
$PM_{2.5}$ - particulate matter equal to or less than 2.5 microns in diameter
CO - carbon monoxide
HAP - hazardous air pollutant as listed in § 112(b) of the Federal Clean Air Act or Title 40 Code of Federal Regulations Part 63, Subpart C
H_2S - hydrogen sulfide
NH_3 - ammonia
(4) Compliance with annual emission limits (tons per year) is based on a 12-month rolling period.
(5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.
(6) These emission rates include routine (non-MSS) and MSS operations.
(7) The maximum annual operating schedule for EPN OP1EN1 is 4,500 hrs/yr.

Date: December 28, 2018

Texas Commission on Environmental Quality
Air Quality Permit

A Permit Is Hereby Issued To
Equistar Chemicals, LP
Authorizing the Construction and Operation of
Channelview Complex
Located at **Channelview, Harris County, Texas**
Latitude 29° 49′ 56″ Longitude −95° 6′ 43″

Permits: 2933, N140, and PSDTX1270

Revision Date: September 22, 2017

Expiration Date: May 31, 2017

For the Commission

1. **Facilities** covered by this permit shall be constructed and operated as specified in the application for the permit. All representations regarding construction plans and operation procedures contained in the permit application shall be conditions upon which the permit is issued. Variations from these representations shall be unlawful unless the permit holder first makes application to the Texas Commission on Environmental Quality (commission) Executive Director to amend this permit in that regard and such amendment is approved. [Title 30 Texas Administrative Code (TAC) Section 116.116 (30 TAC § 116.116)] [1]
2. **Voiding of Permit**. A permit or permit amendment is automatically void if the holder fails to begin construction within 18 months of the date of issuance, discontinues construction for more than 18 months prior to completion, or fails to complete construction within a reasonable time. Upon request, the executive director may grant an 18-month extension. Before the extension is granted the permit may be subject to revision based on best available control technology, lowest achievable emission rate, and netting or offsets as applicable. One additional extension of up to 18 months may be granted if the permit holder demonstrates that emissions from the facility will comply with all rules and regulations of the commission, the intent of the Texas Clean Air Act (TCAA), including protection of the public's health and physical property; and (b)(1)the permit holder is a party to litigation not of the permit holder's initiation regarding the issuance of the permit; or (b)(2) the permit holder has spent, or committed to spend, at least 10 percent of the estimated total cost of the project up to a maximum of $5 million. A permit holder granted an extension under subsection (b)(1) of this section may receive one subsequent extension if the permit holder meets the conditions of subsection (b)(2) of this section. [30 TAC § 116.120]
3. **Construction Progress**. Start of construction, construction interruptions exceeding 45 days, and completion of construction shall be reported to the appropriate regional office of the commission not later than 15 working days after occurrence of the event. [30 TAC § 116.115(b)(2)(A)]
4. **Start-up Notification**. The appropriate air program regional office shall be notified prior to the commencement of operations of the facilities authorized by the permit in such a manner that a representative of the commission may be present. The permit holder shall provide a separate notification for the commencement of operations for each unit of phased construction, which may involve a series of units commencing operations at different times. Prior to operation of the facilities authorized by the permit, the permit holder shall identify the source or sources of allowances to be utilized for compliance with Chapter 101, Subchapter H, Division 3 of this title (relating to Mass Emissions Cap and Trade Program). [30 TAC § 116.115(b)(2)(B)]
5. **Sampling Requirements**. If sampling is required, the permit holder shall contact the commission's Office of Compliance and Enforcement prior to sampling to obtain the proper data forms and procedures. All sampling and testing procedures must be approved by the executive director and coordinated with the regional representatives of the commission. The permit holder is also responsible for providing sampling facilities and conducting the sampling operations or contracting with an independent sampling consultant. [30 TAC § 116.115(b)(2)(C)]
6. **Equivalency of Methods.** The permit holder must demonstrate or otherwise justify the equivalency of emission control methods, sampling or other emission testing methods, and monitoring methods proposed as alternatives to methods indicated in the conditions of the permit. Alternative methods shall be applied for in writing and must be reviewed and approved by the executive director prior to their use in fulfilling any requirements of the permit. [30 TAC § 116.115(b)(2)(D)]
7. **Recordkeeping.** The permit holder shall maintain a copy of the permit along with records containing the information and data sufficient to demonstrate compliance with the permit, including production records and

operating hours; keep all required records in a file at the plant site. If, however, the facility normally operates unattended, records shall be maintained at the nearest staffed location within Texas specified in the application; make the records available at the request of personnel from the commission or any air pollution control program having jurisdiction in a timely manner; comply with any additional recordkeeping requirements specified in special conditions in the permit; and retain information in the file for at least two years following the date that the information or data is obtained. [30 TAC § 116.115(b)(2)(E)]

8. **Maximum Allowable Emission Rates**. The total emissions of air contaminants from any of the sources of emissions must not exceed the values stated on the table attached to the permit entitled "Emission Sources--Maximum Allowable Emission Rates." [30 TAC § 116.115(b)(2)(F)] [1]
9. **Maintenance of Emission Control**. The permitted facilities shall not be operated unless all air pollution emission capture and abatement equipment is maintained in good working order and operating properly during normal facility operations. The permit holder shall provide notification in accordance with 30 TAC §101.201, 101.211, and 101.221 of this title (relating to Emissions Event Reporting and Recordkeeping Requirements; Scheduled Maintenance, Startup, and Shutdown Reporting and Recordkeeping Requirements; and Operational Requirements). [30 TAC§ 116.115(b)(2)(G)]
10. **Compliance with Rules**. Acceptance of a permit by an applicant constitutes an acknowledgment and agreement that the permit holder will comply with all rules and orders of the commission issued in conformity with the TCAA and the conditions precedent to the granting of the permit. If more than one state or federal rule or regulation or permit condition is applicable, the most stringent limit or condition shall govern and be the standard by which compliance shall be demonstrated. Acceptance includes consent to the entrance of commission employees and agents into the permitted premises at reasonable times to investigate conditions relating to the emission or concentration of air contaminants, including compliance with the permit. [30 TAC § 116.115(b)(2)(H)]
11. **This** permit may not be transferred, assigned, or conveyed by the holder except as provided by rule. [30 TAC § 116.110(e)]
12. **There** may be additional special conditions attached to a permit upon issuance or modification of the permit. Such conditions in a permit may be more restrictive than the requirements of Title 30 of the Texas Administrative Code. [30 TAC § 116.115(c)]
13. **Emissions** from this facility must not cause or contribute to "air pollution" as defined in Texas Health and Safety Code (THSC) §382.003(3) or violate THSC § 382.085. If the executive director determines that such a condition or violation occurs, the holder shall implement additional abatement measures as necessary to control or prevent the condition or violation.
14. **The** permit holder shall comply with all the requirements of this permit. Emissions that exceed the limits of this permit are not authorized and are violations of this permit. [1]

[1] Please be advised that the requirements of this provision of the general conditions may not be applicable to greenhouse gas emissions.

Special Conditions
Permit Number
2933/PSDTX1270/N140

1. This permit authorizes emissions only from those points listed in the attached table entitled "Emission Sources - Maximum Allowable Emission Rates," and the facilities covered by this permit are authorized to emit subject to the emission rate limits on that table and other operating requirements specified in the special conditions. **(5/07)**

Federal Applicability

2. These facilities shall comply with all requirements of the U.S. Environmental Protection Agency (EPA) regulations on Standards of Performance for New Stationary Sources promulgated in Title 40 Code of Federal Regulations Part 60 (40 CFR Part 60), as applicable, for:

   A. Storage Vessels for Petroleum Liquids, Subparts A, K, Ka, and Kb.

   B. Fossil-Fuel-Fired Steam Generators, Subparts A and D.

3. These facilities shall comply with all requirements of the EPA regulations on National Emission Standards for Hazardous Air Pollutants (NESHAPS) promulgated in 40 CFR Part 61, as applicable, for:

   A. Equipment Leaks (Fugitive Emission Sources) of Benzene, Subparts A and J.

   B. Equipment Leaks (Fugitive Emission Sources), Subpart A and V.

   C. Benzene Emissions From Benzene Storage Vessels, Subparts A and Y.

   D. Benzene Waste Operations, Subparts A and FF.

4. These facilities shall comply with all requirements of the EPA regulations on NESHAPS for source categories promulgated in 40 CFR Part 63, as applicable, for Generic Hazardous Air Pollutants Standards, Subpart YY. **(5/07)**

Emissions Standards and Operating Specifications

5. Storage tanks are subject to the following requirements. The control requirements specified in paragraphs A-D of this condition shall not apply (1) where the volatile organic compounds (VOC) has an aggregate partial pressure of less than 0.50 pound per square inch, absolute (psia) at the maximum feed temperature or 95°F, whichever is greater, or (2) to storage tanks smaller than 25,000 gallons.

   A. An internal floating deck or "roof" or equivalent control shall be installed in all tanks. The floating roof shall be equipped with one of the following closure devices between the wall of the storage vessel and the edge of the internal floating roof: (1) a liquid-mounted seal, (2) two continuous seals mounted one above the other, or (3) a mechanical shoe seal.

   B. An open-top tank containing a floating roof (external floating roof tank) which uses double seal or secondary seal technology shall be an approved control alternative to an internal floating roof tank provided the primary seal consists of either a mechanical shoe seal or a liquid-mounted seal and the secondary seal is rim-mounted. A weather shield is not approvable as a secondary seal unless specifically reviewed and determined to be vapor-tight.

C. For any tank equipped with a floating roof, the permit holder shall perform the visual inspections and seal gap measurements as specified in 40 CFR § 60.113b, Testing and Procedures, to verify fitting and seal integrity. Records shall be maintained of the dates seals were inspected and seal gap measurements made, results of inspections and measurements made (including raw data), and actions taken to correct any deficiencies noted.

D. The floating roof design shall incorporate sufficient flotation to conform to the requirements of American Petroleum Institute (API) Code 650 except that an internal floating cover need not be designed to meet rainfall support requirements and the materials of construction may be steel or other materials.

E. Uninsulated tank exterior surfaces exposed to the sun shall be white, gray, or specular color. Storage tanks must be equipped with permanent submerged fill pipes.

F. The permit holder shall maintain a record of tank throughput for the previous month and the past consecutive 12-month period for each tank in accordance with Attachment A. **(5/07)**

6. Tanks less than 1,000 gallons or containing a mixture of VOCs having a partial vapor pressures less than 0.5 psia or containing only non-VOCs are exempt from the requirements in Special Condition No. 5E. **(1/09)**

7. [Reserved]

8. Non-fugitive emissions from relief valves, safety valves, or rupture discs of gases containing VOC at a concentration of greater than 1 percent are not authorized by this permit unless authorized on the maximum allowable emission rates table. Any releases directly to atmosphere from relief valves, safety valves, or rupture discs of gases containing VOC at a concentration greater than 1 weight percent are not consistent with good practice for minimizing emissions with the exception of safety valves listed below and those that discharge directly to the atmosphere as a result of fire or failure of utilities.

PSV Number	Service	Pressure, psig Set	Pressure, psig Operating
49021	TK-4901 Suction Line	180	25
48036	TK-4901 Feed Line	180	50
49001	P-4901A/B Discharge	180	30
49022	TK-4904 Suction Line	180	25
49017	P-4903A/B Discharge	275	138
49016	TK-4902 Suction Line	50	25
48037	TK-4092 Feed Line	180	50
48012	TK-4903 Feed Line	180	50
49017	TK-4903 Suction Line	50	25
49003	P-4902A/B/C Discharge	180	47
49051	P-4902A Discharge to 16" PL	150	47
39568	P-4902B Suction (Dock)	225	150
49036	P-4902C Suction Line	180	25
49018	TK-4907 Suction Line	180	25
49519	P-4928A/B Discharge (Minimum Flow)	180	140
49514	P-4928A/B Discharge	180	140

49515	P-4928A/B Discharge	180	140	
49516	P-4928A/B Discharge	180	140	
49517	P-4928A/B Discharge	180	140	
48016	1st Feed System	275	160	
48035	3rd Feed System	720	275	
49023	2nd Feed System	275	150	
49513	PGO	180	20	
49518	PGO	180	25	**(5/07)**

9. Atmospheric relief valves in VOC service that are not equipped with rupture disks shall be checked for leaks on a quarterly basis with an approved gas analyzer. A leak shall be defined as 500 parts per million by volume (ppmv). There shall be no variance for inaccessible valves. All leaking valves shall be repaired or replaced at the earliest opportunity but not later than the next scheduled process shutdown.

10. Analyzer sample system vents or speed loops shall be equipped with vapor recovery or liquid recovery systems (vapor samples routed to flare system or liquids samples route back to process). Analyzer (gas chromatographs) vapor sample loops shall depressure to atmospheric pressure during sample injection only and shall be routed to the flare during periods when sample is not being injected. **(5/07)**

11. Cracking heaters, boilers, and heaters associated with the Olefin II and Flex/Isom Units shall not exceed the following firing rates **(11/12)**:

EPN 44HTHTR, EPN EF4419 — 5,275 MMBtu/hr (combined total)*
Pyrolysis/Steam Production Service

EPN 44HTHTR
*Cracking Heaters:
(F-4401, F-4402, F-4403, F-4404, F-4405,
F-4406, F-4407, F-4408, F-4409, F-4410,
F-4411, F-4412, F-4413, F-4414, F-4415)

*Ethane Heater (F4418):
*Superheaters (F48001A, F48001B)
*Boilers (B48001A, B48001B)

Regeneration Heater (F4601):	25 MMBtu/hr
Flex Regeneration Heater I (F4351):	13 MMBtu/hr
Flex Regeneration Heater II (F4361):	4.1 MMBtu/hr **(5/07)**
Flexibility DP Heater I (F4360):	16 MMBtu/hr
Flexibility DP Heater II (F4360C):	16 MMBtu/hr

EPN EF4419
*Cracking Heater: (F-4419) — 640 MMBtu/hr

The heating value of the fuel (Btu/scf) and the fuel flow rate shall be continuously monitored for the cracking heaters, ethane heater, boilers, and steam superheaters. Compliance with air contaminant emission limits shall be based upon the above firing rate. Quality-assured (or valid) data must be generated when the fired unit is operating. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted provided it does not exceed 5 percent of the time (in minutes) that the fired unit operated over the previous rolling 12-month period. The measurements missed shall be estimated using

engineering judgment and the methods used recorded. Compliance with air contaminant emission limits shall be based upon the above firing rate. **(5/07)**

12. Concentrations of NH_3 from the Cracking Heater Stack (Emission Point Nos. EPN 44HTHTRS, EPN EF 4419) shall not exceed 10 ppmvd on an hourly basis when corrected to three percent oxygen (O_2). The NH_3 concentration shall be tested or calculated according to one of the three methods listed below:

    A. The holder of this permit may install, calibrate, maintain, and operate a CEMS to measure and record the concentrations of NH_3. The NH_3 concentrations shall be corrected and reported in accordance with Special Condition No. 22.

    B. If a sorbent tube device specific for NH_3 is used, the frequency of the sorbent tube testing shall be daily for the first 60 days of SCR operation, after which, the frequency of the sorbent tube testing may be reduced from daily to weekly after operating procedures have been developed to prevent excess amounts of NH_3 from being introduced, and when operation of the SCR system has been proven successful with regard to controlling NH_3 slippage.

    C. As an approved alternative to sorbent or stain tube testing or an NH_3 CEMS, the permit holder may install and operate a second oxides of nitrogen (NO_x) CEMS probe located upstream of the SCR and the stack NO_x CEMS, which may be used in association with the SCR efficiency and NH_3 injection rate to estimate NH_3 slip.

    D. Any other method used for measuring NH_3 slippage shall require prior approval from the TCEQ. **(11/12)**

13. Purchased gas combusted at this facility shall be sweet natural gas containing no more than 5 grains of total sulfur per 100 dry standard cubic feet. **(5/07)**

14. Flares shall be designed and operated in accordance with the following requirements:

    A. The flare systems shall be designed such that the combined assist natural gas and waste stream to each flare meets the 40 CFR § 60.18 specifications of minimum heating value and maximum tip velocity under normal, upset, and maintenance flow conditions.

    The heating value and velocity requirements shall be satisfied during operations authorized by this permit. Flare testing per 40 CFR § 60.18(f) may be requested by the appropriate regional office to demonstrate compliance with these requirements.

    B. The flare shall be operated with a flame present at all times and/or have a constant pilot flame. The pilot flame shall be continuously monitored by a thermocouple or an infrared monitor. The time, date, and duration of any loss of pilot flame shall be recorded. Each monitoring device shall be accurate to, and shall be calibrated at, a frequency in accordance with the manufacturer's specifications.

    C. The flare shall be operated with no visible emissions except periods not to exceed a total of five minutes during any two consecutive hours. This shall be ensured by the use of steam assist to the flare.

    D. The permit holder shall install a continuous flow monitor and composition analyzer that provide a record of the vent stream flow and composition to the flare. The flow monitor sensor and analyzer sample points shall be installed in the vent stream as near as possible to

the flare inlet such that the total vent stream to the flare is measured and analyzed. Readings shall be taken at least once every 15 minutes and the average hourly values of the flow and composition shall be recorded each hour.

The monitors shall be calibrated on an annual basis to meet the following accuracy specifications: the flow monitor shall be ±5.0 percent, temperature monitor shall be ±2.0 percent at absolute temperature, and pressure monitor shall be ±5.0 mm Hg;

The analyzer shall be calibrated, installed, operated, and maintained, in accordance with manufacturer recommendations, to calculate and record the net heating value of the gas sent to the flare, in British thermal units/standard cubic foot of the gas.

The monitors and analyzers shall operate as required by this section at least 95 percent of the time when the flare is operational, averaged over a calendar 12-month period. Flared gas net heating value and actual exit velocity determined in accordance with 40 CFR § 60.18(f)(4) shall be recorded at least once every 15 minutes. **(5/07)**

Fugitive Emission Monitoring

15. Piping, Valves, Connectors, Pumps, and Compressors in VOC Service - 28VHP

Except as may be provided for in the special conditions of this permit, the following requirements apply to the above-referenced equipment:

A. These conditions shall not apply (1) where the VOC has an aggregate partial pressure or vapor pressure of less than 0.044 psia at 68°F or (2) operating pressure is at least 5 kilopascals (0.725 psi) below ambient pressure. Equipment excluded from this condition shall be identified in a list to be made available upon request.

B. Construction of new and reworked piping, valves, pump systems, and compressor systems shall conform to applicable American National Standards Institute (ANSI), API, American Society of Mechanical Engineers (ASME), or equivalent codes.

C. New and reworked underground process pipelines shall contain no buried valves such that fugitive emission monitoring is rendered impractical.

D. To the extent that good engineering practice will permit, new and reworked valves and piping connections shall be so located to be reasonably accessible for leak-checking during plant operation. Non-accessible valves, as defined by 30 TAC Chapter 115, shall be identified in a list to be made available upon request.

E. New and reworked piping connections shall be welded or flanged. Screwed connections are permissible only on piping smaller than two-inch diameter. No later than the next scheduled quarterly monitoring after initial installation or replacement, all new or reworked connections shall be gas-tested or hydraulically-tested at no less than normal operating pressure and adjustments made as necessary to obtain leak-free performance. Connectors shall be inspected by visual, audible, and/or olfactory means at least weekly by operating personnel walk-through.

Each open-ended valve or line shall be equipped with a cap, blind flange, plug, or a second valve. Except during sampling, the second valve shall be closed.

F. Accessible valves shall be monitored by leak-checking for fugitive emissions at least quarterly using an approved gas analyzer. Sealless/leakless valves (including, but not limited to, welded bonnet bellows and diaphragm valves) and relief valves equipped with a rupture disc upstream or venting to a control device are not required to be monitored. For valves equipped with rupture discs, a pressure-sensing device shall be installed between the relief valve and rupture disc to monitor disc integrity. All leaking discs shall be replaced at the earliest opportunity but no later than the next process shutdown.

An approved gas analyzer shall conform to requirements listed in 40 CFR § 60.485(a)-(b). Replacements for leaking components shall be re-monitored within 15 days of being placed back into VOC service.

G. Except as may be provided for in the special conditions of this permit, all pump and compressor seals shall be monitored with an approved gas analyzer at least quarterly or be equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal. Seal systems designed and operated to prevent emissions or seals equipped with an automatic seal failure detection and alarm system need not be monitored.

These seal systems may include (but are not limited to) dual pump seals with barrier fluid at higher pressure than process pressure, seals degassing to vent control systems kept in good working order, or seals equipped with an automatic seal failure detection and alarm system. Submerged pumps or sealless pumps (including, but not limited to, diaphragm, canned, or magnetic-driven pumps) may be used to satisfy the requirements of this condition and need not be monitored.

H. Damaged or leaking valves or connectors found to be emitting VOC in excess of 500 ppmv or found by visual inspection to be leaking (e.g., dripping process fluids) shall be tagged and replaced or repaired. Damaged or leaking pump and compressor seals found to be emitting VOC in excess of 2,000 ppmv or found by visual inspection to be leaking (e.g., dripping process fluids) shall be tagged and replaced or repaired.

I. Every reasonable effort shall be made to repair a leaking component, as specified in this paragraph, within 15 days after the leak is found. If the repair of a component would require a unit shutdown, the repair may be delayed until the next scheduled shutdown. All leaking components which cannot be repaired until a scheduled shutdown shall be identified for such repair by tagging. At the discretion of the Texas Commission on Environmental Quality (TCEQ) Executive Director or designated representative, early unit shutdown or other appropriate action may be required based on the number and severity of tagged leaks awaiting shutdown.

J. The results of the required fugitive instrument monitoring and maintenance program shall be made available to the TCEQ Executive Director or designated representative upon request. Records shall indicate appropriate dates, test methods, instrument readings, repair results, justification for delay of repairs, and corrective actions taken for all components. Records of physical inspections are not required unless a leak is detected.

K. Alternative monitoring frequency schedules of 30 TAC §§ 115.352 - 115.359 or National Emission Standards for Organic Hazardous Air Pollutants, 40 CFR Part 63, Subpart H, may be used in lieu of Items F through G of this condition.

L. Compliance with the requirements of this condition does not assure compliance with requirements of 30 TAC Chapter 115, an applicable New Source Performance Standard

(NSPS), or an applicable NESHAPS and does not constitute approval of alternative standards for these regulations. **(5/07)**

16. Pumps and compressors equipped with single seals in HRVOC (as defined in 30 TAC § 115.10 unless exempted by § 115.787) or greater than 10 weight percent benzene service shall be monitored with a leak definition of 500 ppmv rather than the 2,000 ppmv identified in Special Condition No. 15H. The 2,000 ppmv leak definition in Special Condition No. 15H becomes effective on April 1, 2008. **(5/07)**

17. In addition to the weekly physical inspection required by Item E of Special Condition No. 15, all connectors in non-HRVOC gas/vapor and light liquid service shall be monitored annually with an approved gas analyzer in accordance with Items F through J of Special Condition No. 15. Alternative monitoring frequency schedules ("skip options") of 40 CFR Part 63, Subpart H, National Emission Standards for Organic Hazardous Air Pollutants for Equipment Leaks, may be used in lieu of the monitoring frequency required by this permit condition. Compliance with this condition does not assure compliance with requirements of applicable state or federal regulation and does not constitute approval of alternative standards for these regulations. **(5/07)**

18. In addition to the weekly physical inspection required by Item E of Special Condition No. 15, all accessible connectors in HRVOC gas/vapor and light liquid service shall be monitored quarterly with an approved gas analyzer in accordance with Items F through J of Special Condition No. 15.

    A. Connectors may be monitored on a semiannual basis if the percent of connectors leaking for two consecutive quarterly monitoring periods is less than 0.5 percent.

       Connectors may be monitored on an annual basis if the percent of connectors leaking for two consecutive semiannual monitoring periods is less than 0.5 percent.

       If the percent of connectors leaking for any semiannual or annual monitoring period is 0.5 percent or greater, the facility shall revert to quarterly monitoring until the facility again qualifies for the alternative monitoring schedules previously outlined in this paragraph.

    B. The percent of connectors leaking used in paragraph A shall be determined using the following formula:

$$(Cl + Cs) \times 100/Ct = Cp$$

       Where:

       Cl = the number of connectors found leaking by the end of the monitoring period, either by Method 21 or sight, sound, and smell.

       Cs = the number of connectors for which repair has been delayed and are listed on the facility shutdown log.

       Ct = the total number of connectors in the facility subject to the monitoring requirements, as of the last day of the monitoring period, not including nonaccessible and unsafe-to-monitor connectors.

       Cp = the percentage of leaking connectors for the monitoring period. **(5/07)**

19. Piping, Valves, Connectors, Pumps, and Compressors in VOC Service – 28LAER.

This special condition applies to components associated with the construction of F-4419 as submitted in the application dated September 23, 2011. **(11/12)**

Except as may be provided for in the special conditions of this permit, the following requirements apply to the above-referenced equipment:

A. The requirements of paragraphs F and G shall not apply (1) where the VOC has an aggregate partial pressure or vapor pressure of less than 0.044 pounds per square inch, absolute (psia) at 68EF or (2) operating pressure is at least 5 kilopascals (0.725 psi) below ambient pressure. Equipment excluded from this condition shall be identified in a list or by one of the methods described below to be made readily available upon request.

The exempted components may be identified by one or more of the following methods:

i. piping and instrumentation diagram (PID);
ii. a written or electronic database or electronic file;
iii. color coding;
iv. a form of weatherproof identification; or
v. designation of exempted process unit boundaries.

B. Construction of new and reworked piping, valves, pump systems, and compressor systems shall conform to applicable American National Standards Institute (ANSI), American Petroleum Institute (API), American Society of Mechanical Engineers (ASME), or equivalent codes.

C. New and reworked underground process pipelines shall contain no buried valves such that fugitive emission monitoring is rendered impractical. New and reworked buried connectors shall be welded.

D. To the extent that good engineering practice will permit, new and reworked valves and piping connections shall be so located to be reasonably accessible for leak-checking during plant operation. Difficult-to-monitor and unsafe-to-monitor valves, as defined by Title 30 Texas Administrative Code Chapter 115 (30 TAC Chapter 115), shall be identified in a list to be made readily available upon request. The difficult-to-monitor and unsafe-to-monitor valves may be identified by one or more of the methods described in subparagraph A above. If an unsafe-to-monitor component is not considered safe to monitor within a calendar year, then it shall be monitored as soon as possible during safe-to-monitor times. A difficult-to-monitor component for which quarterly monitoring is specified may instead be monitored annually.

E. New and reworked piping connections shall be welded or flanged. Screwed connections are permissible only on piping smaller than two-inch diameter. Gas or hydraulic testing of the new and reworked piping connections at no less than operating pressure shall be performed prior to returning the components to service or they shall be monitored for leaks using an approved gas analyzer within 15 days of the components being returned to service. Adjustments shall be made as necessary to obtain leak-free performance.

Connectors shall be inspected by visual, audible, and/or olfactory means at least weekly by operating personnel walk-through. In addition, all connectors shall be monitored by leak-checking for fugitive emissions at least quarterly using an approved gas analyzer with a directed maintenance program in accordance with items F thru J of this special condition.

In lieu of the monitoring frequency specified above, connectors may be monitored on a semiannual basis if the percent of connectors leaking for two consecutive quarterly monitoring periods is less than 0.5 percent. Connectors may be monitored on an annual basis if the percent of connectors leaking for two consecutive semiannual monitoring periods is less than 0.5 percent.

If the percent of connectors leaking for any semiannual or annual monitoring period is 0.5 percent or greater, the facility shall revert to quarterly monitoring until the facility again qualifies for the alternative monitoring schedules previously outlined in this paragraph.

The percent of connectors leaking used in paragraph B shall be determined using the following formula:

$$(Cl + Cs) \times 100/Ct = Cp$$

Where:

Cl = the number of connectors found leaking by the end of the monitoring period, either by Method 21 or sight, sound, and smell.

Cs = the number of connectors for which repair has been delayed and are listed on the facility shutdown log.

Ct = the total number of connectors in the facility subject to the monitoring requirements, as of the last day of the monitoring period, not including non-accessible and unsafe-to-monitor connectors.

Cp = the percentage of leaking connectors for the monitoring period.

Each open-ended valve or line shall be equipped with an appropriately sized cap, blind flange, plug, or a second valve to seal the line. Except during sampling, both valves shall be closed. If the isolation of equipment for hot work or the removal of a component for repair or replacement results in an open ended line or valve, it is exempt from the requirement to install a cap, blind flange, plug, or second valve for 72 hours. If the repair or replacement is not completed within 72 hours, the permit holder must complete either of the following actions within that time period;

i. a cap, blind flange, plug, or second valve must be installed on the line or valve; or

ii. the open-ended valve or line shall be monitored once for leaks above background for a plant or unit turnaround lasting up to 45 days with an approved gas analyzer and the results recorded. For all other situations, the open-ended valve or line shall be monitored once by the end of the 72 hours period following the creation of the open ended line and monthly thereafter with an approved gas analyzer and the results recorded. For

turnarounds and all other situations, leaks are indicated by readings of 500 ppmv and must be repaired within 24 hours or a cap, blind flange, plug, or second valve must be installed on the line or valve.

F. Accessible valves shall be monitored by leak-checking for fugitive emissions at least quarterly using an approved gas analyzer with a directed maintenance program. Non-accessible valves shall be monitored by leak-checking for fugitive emissions at least annually using an approved gas analyzer with a directed maintenance program. Sealless/leakless valves (including, but not limited to, welded bonnet bellows and diaphragm valves) and relief valves equipped with a rupture disc upstream or venting to a control device are not required to be monitored. For valves equipped with rupture discs, a pressure-sensing device shall be installed between the relief valve and rupture disc to monitor disc integrity. All leaking discs shall be replaced at the earliest opportunity but no later than the next process shutdown. A check of the reading of the pressure-sensing device to verify disc integrity shall be performed at least quarterly and recorded in the unit log or equivalent. Pressure-sensing devices that are continuously monitored with alarms are exempt from recordkeeping requirements specified in this paragraph.

The gas analyzer shall conform to requirements listed in Method 21 of 40 CFR part 60, appendix A. The gas analyzer shall be calibrated with methane. In addition, the response factor of the instrument for a specific VOC of interest shall be determined and meet the requirements of Section 8 of Method 21. If a mixture of VOCs are being monitored, the response factor shall be calculated for the average composition of the process fluid. A calculated average is not required when all of the compounds in the mixture have a response factor less than 10 using methane. If a response factor less than 10 cannot be achieved using methane, than the instrument may be calibrated with one of the VOC to be measured or any other VOC so long as the instrument has a response factor of less than 10 for each of the VOC to be measured.

A directed maintenance program shall consist of the repair and maintenance of components assisted simultaneously by the use of an approved gas analyzer such that a minimum concentration of leaking VOC is obtained for each component being maintained. Replaced components shall be re-monitored within 15 days of being placed back into VOC service.

G. All new and replacement pumps, compressors, and agitators shall be equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal. These seal systems need not be monitored and may include (but are not limited to) dual pump seals with barrier fluid at higher pressure than process pressure, seals degassing to vent control systems kept in good working order, or seals equipped with an automatic seal failure detection and alarm system. Submerged pumps or sealless pumps (including, but not limited to, diaphragm, canned, or magnetic-driven pumps) may be used to satisfy the requirements of this condition and need not be monitored.

All other pump, compressor, and agitator seals shall be monitored with an approved gas analyzer at least quarterly.

H. Damaged or leaking valves, connectors, compressor seals, pump seals, and agitator seals found to be emitting VOC in excess of 500 parts per million by volume (ppmv) or found by visual inspection to be leaking (e.g., dripping process fluids) shall be tagged and replaced or

repaired. A first attempt to repair the leak must be made within 5 days. Records of the first attempt to repair shall be maintained. A leaking component shall be repaired as soon as practicable, but no later than 15 days after the leak is found. If the repair of a component would require a unit shutdown that would create more emissions than the repair would eliminate, the repair may be delayed until the next scheduled shutdown. All leaking components which cannot be repaired until a scheduled shutdown shall be identified for such repair by tagging. A listing of all components that qualify for delay of repair shall be maintained on a delay of repair list. The cumulative daily emissions from all components on the delay of repair list shall be estimated by multiplying by 24 the mass emission rate for each component calculated in accordance with the instructions in 30 TAC 115.782 (c)(1)(B)(i)(II). The calculations of the cumulative daily emissions from all components on the delay of repair list shall be updated within ten days of when the latest leaking component is added to the delay of repair list. When the cumulative daily emission rate of all components on the delay of repair list times the number of days until the next scheduled unit shutdown is equal to or exceeds the total emissions from a unit shutdown as calculated in accordance with 30 TAC 115.782 (c)(1)(B)(i)(I), the TCEQ Regional Manager and any local programs shall be notified and may require early unit shutdown or other appropriate action based on the number and severity of tagged leaks awaiting shutdown. This notification shall be made within 15 days of making this determination.

I. Records of repairs shall include date of repairs, repair results, justification for delay of repairs, and corrective actions taken for all components. Records of instrument monitoring shall indicate dates and times , test methods, and instrument readings. The instrument monitoring record shall include the time that monitoring took place for no less than 95% of the instrument readings recorded. Records of physical inspections shall be noted in the operator=s log or equivalent.

J. Compliance with the requirements of this condition does not assure compliance with requirements of 30 TAC Chapter 115, an applicable New Source Performance Standard (NSPS), or an applicable National Emission Standard for Hazardous Air Pollutants (NESHAPS), and does not constitute approval of alternative standards for these regulations.

K. In lieu of the monitoring frequency specified in paragraph F, valves in gas and light liquid service may be monitored on a semiannual basis if the percent of valves leaking for two consecutive quarterly monitoring periods is less than 0.5 percent.

Valves in gas and light liquid service may be monitored on an annual basis if the percent of valves leaking for two consecutive semiannual monitoring periods is less than 0.5 percent.

Initial Determination of Compliance

20. The holder of this permit shall perform stack sampling and other testing as required to establish the actual pattern and quantities of air contaminants being emitted into the atmosphere from the cracking heaters (EPN 44HTHTRS F-4401, F-4402, F-4403, F-4404, F-4405, F-4406, F -4407, F-4408, F-4409, F-4410, F-4411, F-4412, F-4413, F-4414, F-4418 and EPN EF4419 F-4419). Three cracking heater stacks, to be determined by the permit holder with agreement of the TCEQ Houston Regional Office, may be tested as representative of the eight cracking heater stacks. Ethane Heater (EPN 44E18); Regeneration Heaters (EPNs F4601 and F4361); Flex Regeneration Heaters (EPNs F4351 and F4361); Flexibility DP Heaters (EPNs F4360 and F4360C); and Steam

Superheaters (EPNs 48E001A/B). The holder of this permit is responsible for providing sampling and testing facilities and conducting the sampling and testing operations at his expense. **(11/12)**

A. The appropriate TCEQ Regional Office in the region where the source is located shall be contacted as soon as testing is scheduled, but not less than 45 days prior to sampling to schedule a pretest meeting.

The notice shall include:

(1) Date for pretest meeting.
(2) Date sampling will occur.
(3) Name of firm conducting sampling.
(4) Type of sampling equipment to be used.
(5) Method or procedure to be used in sampling.

The purpose of the pretest meeting is to review the necessary sampling and testing procedures, to provide the proper data forms for recording pertinent data, and to review the format procedures for submitting the test reports.

A written proposed description of any deviation from sampling procedures specified in permit conditions, TCEQ, or EPA sampling procedures shall be made available to the TCEQ prior to the pretest meeting. The TCEQ Regional Director shall approve or disapprove of any deviation from specified sampling procedures.

Requests to waive testing for any pollutant specified in B of this condition shall be submitted to the TCEQ Office of Permitting and Registration, Austin.

Test waivers and alternate/equivalent procedure proposals for NSPS testing which must have the EPA approval shall be submitted to the TCEQ Regional Director.

B. Air contaminants emitted from the cracking heaters, ethane heater, and steam superheaters to be tested for include (but are not limited to) nitrogen oxide (NO_x) and carbon monoxide.

C. Sampling may be required by the Executive Director of the TCEQ. Requests for additional time to perform sampling shall be submitted to the TCEQ Regional Office.

D. The source being tested shall operate at maximum represented operating rates during stack emission testing. Primary operating parameters that enable determination of firing rates shall be monitored and recorded during the stack test. These parameters are to be determined at the pretest meeting.

If the source is unable to operate at maximum represented operating rates during testing, then additional stack testing may be required when higher represented operating rates are achieved.

E. Copies of the final sampling report shall be forwarded to the TCEQ within 60 days after all sampling is completed. Sampling reports shall comply with the attached provisions of Chapter 14 of the TCEQ Sampling Procedures Manual. The reports shall be distributed as follows:

One copy to the TCEQ Houston Regional Office, Houston.
One copy to the Harris County Air Pollution Control Program, Pasadena.

Continuous Determination of Compliance

21. The permit holder shall install, calibrate, and maintain a predictive emission monitoring system (PEMS) to measure and record the in-stack concentration of NO_x from the Cracking Heaters (EPN 44HTHTRS F-4401, F-4402, F-4403, F-4404, F-4405, F-4406, F-4407, F-4408, F-4410, F-4411, F-4412, F-4413, F-4414, F-4415, F-4418 and EPN EF4419 F-4419) when in operation. **(11/12)**

A. A PEMS may be used for demonstrating continuous compliance if it can be proven to have the same or better accuracy, precision, reliability, accessibility, and timeliness as that provided by a hardware CEMS. All PEMS shall be subject to the approval of the TCEQ Executive Director. Owners or operators must petition the TCEQ Executive Director for approval to use PEMS. The petition must include results of tests conducted beforehand to demonstrate equivalent accuracy and precision of PEMS to that of hardware CEMS. Demonstrating equivalency of PEMS to CEMS shall be met by instantaneously comparing data collected by PEMS with that collected by a certified hardware CEMS or an EPA reference method. For a PEMS replacing a CEMS, both systems shall remain in place for at least an operating quarter collecting valid information before the CEMS is removed.

B. For any unit at which the PEMS is installed, PEMS initial certification by the TCEQ shall occur while the unit is firing its primary fuel. The owner or operator shall:

(1) Conduct relative accuracy testing for NO_x and O_2, or carbon dioxide (CO_2) per 40 CFR Part 60, Appendix B, Performance Specifications 2, 3, and 4, respectively, at low, medium, and high levels of the most significant operating parameter affecting NO_x emissions.

(2) Conduct statistical test analysis at low, medium, and high levels of the most significant operating parameter affecting NO_x emissions. A minimum of 30 successive paired data points which are either 15-minute averages, 20-minute averages, or hourly averages must be collected at each tested level before a reliable statistical test can be performed.

Data collection must be continuous at all times except when calibration of the reference method must be conducted for the purpose of collecting data for RATA.

The following three tests must be conducted to demonstrate precision:

a. A T-test for bias per Appendix A, 40 CFR Part 75, § 7.6. The test shall be conducted using all paired data points collected at all three tested levels.

b. An F-test per 40 CFR § 75.41(c)(1). The F-test must be conducted separately at the three tested levels.

c. A correlation analysis per 40 CFR § 75.41(c)(2). Calculation of the correlation coefficient (Equation 27) shall be performed using all paired data points collected at all three tested levels.

(3) For NO_x for the purpose of conducting an F-test, if the standard deviation (SD) of the reference method is less than either 3 percent of the span or 5 parts per million (ppm), use a reference method SD of the greater of 5 ppm or 3 percent of span.

(4) For diluent CO_2 or O_2 and for the purpose of conducting an F-test, if the SD of the reference method is less than 3 percent of span, use a reference method SD of 3 percent of span.

(5) For NO_x at any one tested level, if the mean value of the reference method is less than either 10 ppm or 5 percent of the standard, all statistical tests are waived for that emission parameter at that specific tested level.

(6) For either O_2 or CO_2 and at any one tested level, if the mean value of the reference method is less than 3 percent of span, all the statistical tests are waived for that diluent parameter at that specific tested level.

C. The monitoring data shall be reduced to hourly average concentrations at least once every day, using a minimum of four equally-spaced data points from each one-hour period. The individual average concentrations shall be reduced to units of pound per million Btu at least once every week.

D. All monitoring data and quality-assurance data shall be maintained by the permit holder.

E. Any PEMS downtime shall be reported to the appropriate TCEQ Regional Director per § 117.345(d)(3) and necessary corrective action shall be taken. Quality-assured (or valid) data must be generated when the Cracking Heaters (EPN 44HTHTRS and EF4419) are operating except during the performance of a daily zero and span check. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted provided it does not exceed 5 percent of the time (in minutes) that the Cracking Heaters (EPN 44HTHTRS and EF4419) operated over the previous rolling 12-month period. Owners or operators shall demonstrate that all missing data can be accounted for in accordance with the applicable missing data procedures of 30 TAC 117.340. Supplemental stack concentration measurements may be required at the discretion of the appropriate TCEQ Regional Director. **(9/17)**

F. The appropriate TCEQ Regional Office shall be notified for each annual RATA in order to provide them the opportunity to observe the testing.

G. The owner or operator shall perform daily sensor validation. The owner or operator shall develop and implement plans that will ensure proper functioning of the monitoring systems, ensure proper accuracy and calibration of all operational parameters that affect emissions and serve as input to the predictive monitoring system, and ensure continuous operation within the certified operating range.

H. In accordance with the procedure of § 2.3.1, Appendix B of 40 CFR Part 60, a RATA must be performed every six months for each unit while firing its primary fuel. A RATA may be performed annually if the relative accuracy of the previous audit is 7.5 percent or less.

I. For each of the three successive quarters following the quarter in which initial certification was conducted, RATA and statistical testing must be conducted for at least one unit in a category of units in accordance with the procedures outlined for initial certification under Section B.

J. Any RATA exceeding 20 percent or statistical test exceeding the applicable standard shall be reported to the appropriate TCEQ Regional Director, and necessary corrective action shall be taken.

K. When an alternative fuel is fired in a unit, PEMS must be re-certified in accordance with the certification procedures outlined for initial certification under § B. Owners or operators may justify to the satisfaction of the TCEQ Executive Director that slight changes in fuel composition do not constitute an alternative fuel. No additional recertification procedures are required if the unit meets the current monitoring requirements when switching back to the normal fuel from an alternate fuel.

L. The system is required to provide valid emission predictions for at least 95 percent of the time that the unit being monitored is operated. The following rules for tuning without recertification shall be followed:

(1) The model did not change fundamentally.
(2) The model continues to operate within the initially certified operating ranges.

Otherwise, the system must be recertified. Any tuning must be documented, and the records must be made available during any future inspection.

M. All owners or operators shall develop a quality-assurance plan or manual that insures continuous and reliable performance of the PEMS. As part of the plan, owners or operators shall recommend a frequency for calibrating each sensor whose readout serves as an input to the model. All sensors, at a minimum, shall be calibrated as often as recommended by the manufacturer. **(5/07)**

N. As an alternative to special condition 20 A.-M. the permit holder may install a continuous emission monitoring system (CEMS) to measure and record the in-stack concentration of NOx from the Cracking Heaters (EPN 44HTHTRS: F-4401, F-4402, F-4403, F-4404, F-4405, F-4406, F -4407, F-4408, F-4409, F-4410, F-4411, F-4412, F-4413, F-4414, F-4415, F-4418 and EPN EF4419 F-4419) when in operation. The CEMS shall meet the requirements in special condition 22A.– E.

22. The holder of this permit shall install, calibrate, and maintain a continuous emission monitoring system (CEMS) to measure and record the in-stack concentration of NO_x, SO_2, O_2, and opacity from Boilers B48001 A/B (EPN 48E03) when the boilers are operational. **(5/07)**

A. The CEMS shall meet the design and performance specifications, pass the field tests, and meet the installation requirements and the data analysis and reporting requirements specified in the applicable Performance Specification Nos. 1 through 7, 40 CFR Part 60, Appendix B. If there are no applicable performance specifications in 40 CFR Part 60, Appendix B, contact the TCEQ Office of Permitting and Registration, Air Permits Division (APD) in Austin for requirements to be met. **(02/09)**

B. The system shall be zeroed and spanned daily and corrective action taken when the 24-hour span drift exceeds two times the amounts specified in 40 CFR Part 60, Appendix B, or as specified by the TCEQ if not specified in Appendix B.

Zero and span is not required on weekends and plant holidays if instrument technicians are not normally scheduled on those days, unless the monitor is required by a subpart of NSPS or NESHAPS, in which case zero and span shall be done daily without exception.

Each monitor shall be quality-assured at least quarterly in accordance with 40 CFR Part 60, Appendix F, Procedure 1, § 5.1.2. For non-NSPS sources, an equivalent method approved by the TCEQ may be used.

All cylinder gas audit exceedances of +15 percent accuracy and any CEMS downtime shall be reported to the appropriate TCEQ Regional Manager, and necessary corrective action shall be taken. Supplemental stack concentration measurements may be required at the discretion of the appropriate TCEQ Regional Manager.

C. The monitoring data shall be reduced to hourly average concentrations at least once every day, using a minimum of four equally-spaced data points from each one-hour period. The individual average concentrations shall be reduced to units of the permit allowable emission rate in lb/hr at least once every month.

D. All monitoring data and quality-assurance data shall be maintained by the source for a period of two years and shall be made available to the Executive Director of the TCEQ or his designated representative upon request. The data from the CEMS may, at the discretion of the TCEQ, be used to determine compliance with the conditions of this permit.

E. For NSPS sources subject to Appendix F, the appropriate TCEQ Regional Office shall be notified at least 30 days prior to each annual relative accuracy testing audit in order to provide them the opportunity to observe the testing.

23. Opacity of emissions from cracking heaters, boilers, heaters, and decoking cyclones shall not exceed 15 percent average over a six-minute period except for those periods described in 30 TAC § 111.111.

Production Limits and Recordkeeping

24. Production rates shall not exceed 11.3 billion pounds per year of all products. The holder of this permit shall maintain records on the operation of the facility that shall include (but are not limited to) hours of operation, production rates, hours of operation of each heater unit, time period pre-regeneration gases are purged to each flare unit, and time period regeneration cycle emits to the atmosphere. **(11/12)**

Cooling Towers

25. The VOC associated with cooling tower water shall be monitored monthly with an air stripping system meeting the requirements of the TCEQ Sampling Procedures Manual, Appendix P (dated January 2003 or a later edition) or an approved equivalent sampling method. The results of the monitoring, cooling water flow rate, and maintenance activities on the cooling water system shall

be recorded. The monitoring results and cooling water hourly mass flow rate shall be used to determine cooling tower hourly VOC emissions. The rolling 12 month cooling water emission rate shall be recorded on a monthly basis and be determined by summing the VOC emissions between VOC monitoring periods over the rolling 12 month period. The emissions between VOC monitoring periods shall be obtained by multiplying the total cooling water mass flow between cooling water monitoring periods by the higher of the 2 VOC monitored results. Cooling water sampling as required by 30 TAC Chapter 115 Subchapter H may be used in lieu of this special condition. **(11/12)**

26. Cooling water shall be sampled once a week for total dissolved solids (TDS) and once a day for conductivity. Dissolved solids in the cooling water drift are considered to be emitted as PM_{10}. The data shall result from collection of water samples from the cooling tower feed water and represent the water being cooled in the tower. Water samples should be capped upon collection, and transferred to a laboratory area for analysis. The analysis method for TDS shall be EPA Method 160.1, ASTM D5907, and SM 2540 C [SM - 19th edition of Standard Methods for Examination of Water]. The analysis method for Conductivity shall be ASTM D1125-95A and SM2510 B. Use of an alternative method shall be approved by the TCEQ Regional Director prior to its implementation. **(11/12)**

Maintenance, Start-Up, and Shutdown Operations

27. This permit authorizes the emissions from facilities for the planned maintenance, startup, and shutdown (MSS) activities summarized in the MSS Activity Summary (Attachment C) attached to this permit.

    Routine maintenance activities, as identified in Attachment B of this permit, may be tracked through work orders or their equivalent. Emissions from activities identified in Attachment B shall be calculated using the number of work orders or equivalent that month and the emissions associated with that activity identified in the permit application.

    The performance of each planned MSS activity not identified in Attachment B and the emissions associated with it shall be recorded and include at least the following information:

    A. the process unit at which emissions from the MSS activity occurred, including the emission point number and common name of the process unit;

    B. the type of planned MSS activity and the reason for the planned activity;

    C. the common name and the facility identification number, if applicable, of the facilities at which the MSS activity and emissions occurred;

    D. the date and time of the MSS activity and its duration;

    E. the estimated quantity of each air contaminant, or mixture of air contaminants, emitted with the data and methods used to determine it. The emissions shall be estimated using the methods identified in the permit application, consistent with good engineering practice.

    All MSS emissions shall be summed monthly and the rolling 12-month emissions shall be updated on a monthly basis. **(11/12)**

28. Process units and facilities, shall be depressurized, emptied, degassed, and placed in service in accordance with the following requirements: **(11/12)**

A. The process equipment shall be depressurized to a control device, transferred within the process unit, transferred to another process unit, transferred to a pressurized storage tank, or depressurized to a controlled recovery system prior to venting to atmosphere, degassing, or draining liquid. Equipment that only contains material that is liquid with volatile organic compounds (VOC) partial pressure less than 0.50 pound per square inch, absolute (psia) at the highest of the actual temperature or 95°F may be opened to atmosphere and drained in accordance with Paragraph C of this special condition. The vapor pressure at 95°F may be used if the actual temperature of the liquid is verified to be less than 95°F and the temperature is recorded.

B. If mixed phase materials must be removed from process equipment, the cleared material shall be routed to a knockout drum or equivalent to allow for managed initial phase separation, transferred within the process unit, transferred to another process unit, or transferred to a pressurized storage tank. If the VOC partial pressure is greater than 0.50 psi at either the actual temperature or 95°F, any vents in the system must be routed to a control device or a controlled recovery system. The vapor pressure at 95°F may be used if the actual temperature of the liquid is verified to be less than 95°F and the temperature is recorded. Control must remain in place until degassing has been completed or the system is no longer vented to atmosphere.

C. All liquids from process equipment or storage vessels must be removed to the maximum extent practical prior to opening equipment to commence degassing and/or maintenance. Liquids must be drained into a closed vessel or closed liquid recovery system unless prevented by the physical configuration of the equipment, transferred within the process unit, transferred to another process unit, or transferred to a pressurized or an atmospheric storage tank. If it is necessary to drain liquid into an open pan or sump, the liquid must be covered or transferred to a covered vessel within one hour of being drained.

D. If the VOC partial pressure is greater than 0.50 psi at the normal process temperature or 95°F, facilities shall be degassed using good engineering practice to ensure air contaminants are removed from the system through the control device or controlled recovery system to the extent allowed by process equipment or storage vessel design. The vapor pressure at 95°F may be used if the actual temperature of the liquid is verified to be less than 95°F and the temperature is recorded. The facilities to be degassed shall not be vented directly to atmosphere, except as necessary to establish isolation of the work area or to monitor VOC concentration following controlled depressurization. The venting shall be minimized to the maximum extent practicable and actions taken recorded. The control device or recovery system utilized shall be recorded with the estimated emissions from controlled and uncontrolled degassing calculated using the methods that were used to determine allowable emissions for the permit application.

(1) For MSS activities identified in Attachment B, the following option may be used in lieu of item (2) below. The facilities being prepared for maintenance shall not be vented directly to atmosphere until the VOC concentration has been verified to be less than 10,000 ppmv or less than 10 percent of the lower explosive limit (LEL) per the site safety procedures.

(2) The locations and/or identifiers where the purge gas or steam enters the process equipment or storage vessel and the exit points for the exhaust gases shall be recorded (process flow diagrams [PFDs] or piping and instrumentation diagrams [P&IDs] may be used to demonstrate compliance with the requirement). If the process equipment is purged with a gas, two system volumes of purge gas must have passed through the control device or controlled recovery system before the vent stream may be sampled to verify acceptable-VOC concentration prior to uncontrolled venting. The VOC sampling and analysis shall be performed using an instrument meeting the requirements of SC No. 29. The sampling point shall be upstream of the inlet to the control device or controlled recovery system. The sample ports and the collection system must be designed and operated such that there is no air leakage into the sample probe or the collection system downstream of the process equipment or vessel being purged. The facilities shall be degassed to a control device or controlled recovery system until the VOC concentration is less than 10,000 ppmv or 10 percent of the LEL. Documented site procedures used to de-inventory equipment to a control device for safety purposes (e.g., hot work or vessel entry procedures) that achieve at least the same level of purging may be used in lieu of the above.

E. Gases and vapors with VOC partial pressure greater than 0.50 psi may be vented directly to atmosphere if all the following criteria are met:

(1) It is not technically practicable to depressurize or degas, as applicable, into the process;

(2) There is not an available connection to a plant control system (flare); and

(3) There is no more than 50 lbs of air contaminant to be vented to atmosphere during shutdown or start-up, as applicable.

All instances of venting directly to atmosphere per sub-paragaph E. of this condition must be documented when occurring as part of any MSS activity. The emissions associated with venting without control must be included in the work order or equivalent for those planned MSS activities identified in Attachment B.

29. Air contaminant concentration shall be measured using an instrument/detector meeting one set of requirements specified below. **(11/12)**

A. VOC concentration shall be measured using an instrument meeting all the requirements specified in EPA Method 21 (40 CFR Part 60, Appendix A) with the following exceptions:

(1) The instrument shall be calibrated within 24 hours of use with a calibration gas such that the response factor (RF) of the VOC (or mixture of VOCs) to be monitored shall be less than 2.0. The calibration gas and the gas to be measured, and its approximate RF shall be recorded. If the RF of the VOC (or mixture of VOCs) to be monitored is greater than 2.0, the VOC concentration shall be determined as follows:

VOC Concentration = Concentration as read from the instrument*RF

In no case should a calibration gas be used such that the RF of the VOC (or mixture of VOCs) to be monitored is greater than 5.0.

(2) Sampling shall be performed as directed by this permit in lieu of section 8.3 of Method 21. During sampling, data recording shall not begin until after two times the instrument response time. The date and time shall be recorded, and VOC concentration shall be monitored for at least five minutes, recording VOC concentration each minute. As an alternative the VOC concentration may be monitored over a five-minute period with an instrument designed to continuously measure concentration and record the highest concentration read. The highest measured VOC concentration shall be recorded and shall not exceed the specified VOC concentration limit prior to uncontrolled venting.

B. Colorimetric gas detector tubes may be used to determine air contaminant concentrations if they are used in accordance with the following requirements.

(1) The air contaminant concentration measured as defined in (3) is less than 80 percent of the range of the tube and is at least 20 percent of the maximum range of the tube.

(2) The tube is used in accordance with the manufacturer's guidelines.

(3) At least two samples taken at least five minutes apart must satisfy the following prior to uncontrolled venting:

measured contaminant concentration (ppmv) < release concentration.

Where the release concentration is:

10,000* mole fraction of the total air contaminants present that can be detected by the tube.

The mole fraction may be estimated based on process knowledge. The release concentration and basis for its determination shall be recorded.

Records shall be maintained of the tube type, range, measured concentrations, and time the samples were taken.

C. Lower explosive limit measured with a lower explosive limit detector.

(1) The detector shall be calibrated within 30 days prior to use with a certified pentane gas standard at 58 percent of the LEL for pentane. Records of the calibration date/time and calibration result (pass/fail) shall be maintained.

(2) A functionality test shall be performed within 24 hours prior to use on each detector using the same certified gas standard used for calibration. The LEL monitor shall read no lower than 90 percent of the calibration gas certified value. Records, including the date/time and test results, shall be maintained.

(3) A certified methane gas standard equivalent to 58 percent of the LEL for pentane may be used for calibration and functionality tests provided that the LEL response is within 95 percent of that for pentane.

D. Gas Chromatograph. As an alternative to an instrument/detector, the analysis may be conducted in a laboratory. Bag samples of the gas discharged may be drawn and taken to an

onsite laboratory to be analyzed by gas chromatography (GC). A minimum of two bag samples shall be drawn approximately ten minutes apart. A Tedlar bag, or a bag or glass container appropriate for the material to be sampled, shall be used and shall have a valve to seal gas in the bag or container. The samples shall be drawn as follows:

(1) The sample point on the equipment being cleared shall be purged sufficiently to ensure a representative sample at the sample valve.

(2) The sample bag shall be connected directly to the sample valve or to a pump that is connected directly to the sample valve.

(3) The sample valve and sample bag shall be opened to allow the bag to fill to approximately 80% of capacity. The sample connections shall be fitted such that no air is drawn into the sample bag.

(4) The two valves shall then be closed to seal the sample in the bag.

(5) The sample bag shall then be disconnected and placed in a dark container out of direct sunlight for transport to the analyzer.

(6) This process is repeated to collect additional samples.

(7) The sample shall be analyzed within 12 hours of collection.

(8) If condensation is observed in a bag sample, the sampling must be repeated using one of the modified bag sampling procedures in 40 CFR 60, Appendix A, Method 18 Section 8.

(9) At least two samples taken at least five minutes apart must satisfy the following prior to uncontrolled venting.

The laboratory GC shall meet or exceed the requirements of 40 CFR 60, Appendix A, Method 18 Sections 6 (Equipment and Supplies), 7 (Reagents and Standards), 9 (Quality Control), and 10 (Calibration and Standards). The sample shall be analyzed per Section 8.2.1.5 of Method 18, except the analysis of each bag may be performed in duplicate and use gas tight syringe through septums. The highest measured VOC concentration shall not exceed the specified VOC concentration limit prior to uncontrolled venting. The recovery study for bag sampling and post analysis calibration is only required the first time a vessel is degassed and analyzed if the procedure meets the accuracy specifications of Method 18 and the analytical equipment is not modified. If the material content, temperature and pressure are the same among multiple vessels when sampling occurs, the post analysis calibration need only be conducted on sample(s) from one representative vessel.

30. This condition applies only to piping and components subject to leak detection and repair monitoring requirements. Each open-ended valve or line shall be equipped with an appropriately sized cap, blind flange, plug, or a second valve to seal the line. Except during sampling, both valves shall be closed. If the removal of a component for repair or replacement results in an open-ended line or valve, it is exempt from the requirement to install a cap, blind flange, plug, or second valve for 72 hours. If the repair or replacement is not completed within 72 hours, the permit holder must complete either of the following actions within that time period: **(11/12)**

A. cap, blind flange, plug, or second valve must be installed on the line or valve; or

B. The open-ended valve or line shall be monitored once for leaks above background for a plant or unit turnaround lasting up to 45 days with an approved gas analyzer and the results recorded. For all other situations, the open-ended valve or line shall be monitored once within the 72-hour period following the creation of the open-ended line and monthly thereafter with an approved gas analyzer and the results recorded. For turnarounds and all other situations, leaks are indicated by readings 500 ppmv above background and must be repaired within 24 hours or a cap, blind flange, plug, or second valve must be installed on the line or valve.

31. Additional occurrences of MSS activities authorized by this permit may be authorized under permit by rule only if conducted in compliance with this permit's procedures, emission controls, monitoring, and recordkeeping requirements applicable to the activity. **(11/12)**

32. Planned maintenance activities must be conducted in a manner consistent with good practice for minimizing emissions, including the use of air pollution control equipment, practices and processes. All reasonable and practical efforts to comply with Special Condition Nos. 27 through 32 must be used when conducting the planned maintenance activity, until the Commission determines that the efforts are unreasonable or impractical, or that the activity is an unplanned maintenance activity. **(11/12)**

33. The MSS MAERT emission limitsand permit Special Condition Nos. 27 - 32 become effective upon start-up of the equipment authorized in the application dated September 23, 2011. **(11/12)**

Netting & Offsets

34. This Prevention of Significant Deterioration (PSD) permit (PSD-TX-1270, 25.71 tpy NOx project increase) is conditioned on the completion of the emission reduction project represented in the permit application (PI-1 dated September 23, 2011) as follows **(11/12)**:

Methanol Unit Shutdown	(November 2008)
Total NOx Reduction:	780.4 tpy

These reductions shall occur prior to the start of operation of the facilities and activities authorized by the indicated PSD permit. The permit holder shall maintain records of these emission reductions.

Construction of the authorized facilities must begin as defined in 40 CFR § 52.21(b)(9), no later than five years after the all emission reductions identified in the NOx netting analysis are actually accomplished. If construction does not begin as specified, the netting reductions will no longer be creditable.

This Nonattainment New Source Review (NNSR) permit (N140) is issued based on the permanent retirement of a TCEQ Emission Reduction Credit (ERC) for 25.58 tpy of VOC emissions reduction at Equistar's Chocolate Bayou Polymer Facility. This ERC provides offsets at the rate of 1.3:1 for the 19.68 tpy of VOC emissions authorized as a project increase by the indicated NNSR permit.

Date: September 22, 2017

Permit Number 2933
ATTACHMENT A
Multiple Products Approved For Storage

Olefin Feed Stocks Ranges of Operation:

Tank Nos. 4901, 4902, and 4903

Vapor Pressure (psia @ ℉) Average	Vapor Pressure (psia @ ℉) Maximum	Max Throughput (bbls) **
0.3 - 8.0	0.6 - 10.9	35.0 E+06

Tank Nos. 4904, 4905, 4906, and 4907

Vapor Pressure (psia @ ℉) Average	Vapor Pressure (psia @ ℉) Maximum	Max Throughput (bbls) **
0.3 - 8.0	0.6 - 10.9	35.0 E+06

Tank Nos. 4917 and 4919

Vapor Pressure (psia @ ℉) Average	Vapor Pressure (psia @ ℉) Maximum	Max Throughput (bbls) **
0.5 - 7.2	0.6 - 10.9	9.13 E+06

Other Tanks:

Tank No.	EPN	Tank Description	Annual Throughput (gal.)
TK-4922	49E13	Tank 4922	340,200,000.0
TK-48302	48E07	Tank 48302	110,376,000.0
TK-48304	48E20	Pyrolysis FO	236,572,560.0
TK-48305	48E21	Pyrolysis Gas Oil	165,564,000.0
TK-48007	48E22	Pyrolysis FO	239,148,000.0

** Maximum combined annual throughput of any combination of listed products for the group of tanks.

Date: November 14, 2012

Permit No. 2933
Attachment B
Routine Maintenance Activities

Pump repair/replacement
Fugitive component (valve, pipe, flange) repair/replacement
Compressor repair/replacement
Heat exchanger repair/replacement
Process & Storage Vessel cleaning/repair/replacement

Date: November 14, 2012

Permit No. 2933
Attachment C
Mss Activity Summary

Facilities	Description	Emissions Activity	EPN
F-4419 and ancillary piping	Process unit purge/degas/drain	vent to atmosphere	ENMSSROUT

Date: November 14, 2012

Emission Sources - Maximum Allowable Emission Rates
Permit Number 2933 / PSDTX1270 / N140

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY**
48E11	OP2 Cooling Tower	VOC	12.10	22.71
		PM	7.88	34.53
		PM10	3.94	17.26
		PM2.5	0.02	0.07
EOP2FUGEXP	OP2 Fugitives (4)	VOC	0.46	2.01
EOP2DECOKE2	Decoke Vent 2	CO	310.00	59.60
		VOC	0.08	0.02
		PM	1.07	0.10
		PM10	1.07	0.10
		PM2.5	1.07	0.10
ENMSSROUT	MSS Vessel – F4419 and Ancillary Piping/Equipment	VOC	4.37	0.05
EOP2ANALY	Analyzers – F4419	VOC	0.03	0.13
OP2PV48055	Analyzer Vent	VOC	0.08	0.35
48E4501A	OP-2 Analyzer	VOC	< 0.01	< 0.01
48E4301	Shelter J-4301	VOC	0.26	1.09
48E4303	Shelter J-4303	VOC	0.11	0.48
48E01	OP-2 Flare	VOC	974.01	104.61
		NOx	142.81	37.96
		CO	735.64	196.14
		SO2	15.12	4.02

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY**
43E01	D-4311 NCTBP Tank	VOC	11.96	0.47
43E03	D-4310 EADC Tank	VOC	10.81	0.41
43E02	Aluminum Oxide Treater Regeneration Vent	CO	1.56	0.02
		VOC	0.97	0.01
43E04	Regeneration Heater I F-4351	NO_x	1.30	5.69
		SO_2	0.09	0.41
		CO	1.09	4.78
		VOC	0.07	0.28
		PM	0.10	0.46
43E05	Butane Isomerization Reactor Regeneration Vent	CO	6.92	4.98
		VOC	5.86	5.54
43E06	DP Heater F-4360	NO_x	1.60	7.01
		SO_2	0.12	0.50
		CO	1.34	5.89
		VOC	0.08	0.35
		PM	0.13	0.56
43E11	DP Heater F-4360C	NO_x	1.60	7.01
		SO_2	0.12	0.50
		CO	1.34	5.89
		VOC	0.08	0.35
		PM	0.13	0.56

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY**
43E07	Regeneration Heater II F-4361	NO_x	0.40	1.75
		SO_2	0.03	0.13
		CO	0.34	1.47
		VOC	0.02	0.09
		PM	0.03	0.14
F44E00	Olefins II Unit Fugitives (4) (includes Flex Fugitives F43E00)	VOC	94.60	405.73
F44FGWATER	Olefins II Wastewater Fugitives (4)	VOC	1.15	5.03
44HTHTRS	<u>Pyrolysis and Steam Production</u> Common Stack: Cracking Heaters- *F-4401 and F-4402* *F-4403 and F-4404* *F-4405 and F-4406* *F-4407 and F-4408* *F-4409 and F-3410* *F-4411 and F-4412* *F-4413 and F-4414* Common Stack: Boilers- *B-480001A & B-48001B* Common Stack: Steam Super Heaters- *F-48001 A & B* Ethane Cracking Heater - *F-4418* OP-2 Cracking Heater – *F-4415*	NO_x	588.26	2195.10
		SO_2	34.16	138.73
		CO	440.52	1696.00
		VOC	27.94	104.67
		PM	41.70	161.10

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY**
EF4419	OP-2 Cracking Heater F-4419	NOx	38.40	25.71
		CO	33.88	148.38
		SO2	0.38	1.54
		VOC	0.64	2.57
		PM	4.23	17.00
		PM10	4.23	17.00
		PM2.5	4.23	17.00
		NH3	2.69	11.78
44E08	Decoke Vent	CO	132.00	113.75
		PM	36.00	6.50
		VOC	0.11	0.10
44E10	Reactor Regenerator Vent	VOC	2.00	0.16
		CO	82.98	16.55
46E05	Regeneration Heater F-4601	NO_x	2.50	2.63
		SO_2	0.18	0.19
		CO	2.10	2.21
		VOC	0.13	0.13
		PM	0.20	0.21
45E11	Antifoulant Storage 4511	VOC	0.30	0.01
46E01	Isopropanol Storage Tank 4601	VOC	0.22	0.03
46E07	Antifoulant Storage 4607	VOC	0.28	0.01
48E105	Lube Oil Storage Tank 48105	VOC	0.28	0.01
48E06	Pyrolysis Fuel Oil Storage Tank 48301	VOC	0.36	1.79

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY**
48E07	Pyrolysis Gas Oil Tank 48302	VOC	7.75	2.47
		Benzene	0.04	0.01
48E08	Slop Oil Tank 48303	VOC	0.08	0.35
		Benzene	0.04	0.16
48E22	Pyrolysis Fuel Oil Tank 48007	VOC	12.62	14.53
48E20	Pyrolysis Fuel Oil Tank 48304	VOC	12.62	7.54
48E21	Storage Tank 48305	VOC	5.16	4.74
49E01	Storage Tank 4901	VOC	8.38	
		Benzene	1.13	
		H2S	<0.01	
49E02	Storage Tank 4902	VOC	8.38	
		Benzene	0.20	
		H2S	<0.01	
49E03	Storage Tank 4903	VOC	8.38	
		Benzene	2.56	
49E01 to 49E03	Storage Tanks (3 total)	VOC		36.21
		Benzene		1.64
		H2S		0.02
49E04	Storage Tank 4904	VOC	6.03	
		Benzene	1.60	
		H2S	<0.01	
49E05	Storage Tank 4905	VOC	6.03	

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY**
		Benzene	1.60	
		H2S	<0.01	
49E06	Storage Tank 4906	VOC	5.81	
		Benzene	1.55	
		H2S	<0.01	
49E07	Storage Tank 4907	VOC	5.12	
		Benzene	1.36	
		H2S	<0.01	
49E04 to 49E07	Storage Tanks (4 total)	VOC		37.72
		Benzene		9.38
		H2S		0.03
49E08	Storage Tank 4915	VOC	0.14	0.33
49E09	Storage Tank 4916	Benzene	0.71	2.17
49E10	Storage Tank 4917	VOC	1.84	3.96
		Benzene	0.23	0.47
49E11	Storage Tank 4919	VOC	1.28	2.69
		Benzene	0.41	0.89
49E12	Storage Tank 4921	VOC	2.64	2.36
		Benzene	0.73	0.62
49E13	Storage Tank 4922	VOC	3.21	7.14
		Benzene	2.29	5.02
45E02	Seal Oil Reservoir Vent	VOC	0.01	0.01
45E07	Seal Oil Reservoir Vent	VOC	0.01	0.01

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY**
48E4308	Shelter J-4308	VOC	0.01	0.01
48E4402	Shelter J-4402	VOC	0.01	0.01
48E4403	Shelter J-4403	VOC	0.01	0.01
48E4404	Shelter J-4404	VOC	0.01	0.01
48E4405	Shelter J-4405	VOC	0.01	0.01
48E4406	Shelter J-4406	VOC	0.01	0.01
48E4407	Shelter J-4407	VOC	0.01	0.01
48E4408	Shelter J-4408	VOC	0.01	0.01
48E4409	Shelter J-4409	VOC	0.01	0.01
48E4410	Shelter J-4410	VOC	0.01	0.01
48E4415	Shelter J-4415	VOC	0.01	0.01
48E4501	Shelter J-4501	VOC	0.01	0.01
48E4602	Shelter J-4602	VOC	0.01	0.02
48E4603	Shelter J-4603	VOC	0.08	0.34
48E4604	Shelter J-4604	VOC	0.01	0.05
48E4605	Shelter J-4605	VOC	0.01	0.01
48E4606	Shelter J-4606	VOC	0.01	0.01
48E4607	Shelter J-4607	VOC	0.01	0.01
48E4611	Shelter J-4611	VOC	0.01	0.01
OP2VJ48013	Shelter J-48013	VOC	0.14	0.56
OP2SMLTK08	Antifoulant Storage Tank 78782	VOC	0.77	0.05

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY**
OP2EN1	Diesel Engine-Driven Air Compressor	NO_x	4.82	10.48
		CO	2.89	6.50
		SO_2	0.90	2.02
		PM_{10}	0.96	2.16
		VOC	1.10	2.47
44PVD4420	Dilution Steam Vents	VOC	1.97	1.66
48HTF4804A/B	Superheater Vents	VOC	3.60	0.01
OP2SMLTK11	Antifoulant Tote (OP2 Base Dimer Drum)	VOC	1.28	0.01
OP2SMLTK01	Oxygen Scavenger Tank 972392	VOC	2.15	0.01
OP2SMLTK12	Neutralizing Amine Tank 971971	VOC	2.15	0.01
OP2SMLTK13	Corrosion Inhibitor Tank 972389	VOC	2.15	0.01
OP2SMLTK10	Corrosion Inhibitor Tank 972391	VOC	2.15	0.01
OP2SMLTK02	Scale Inhibitor Tank 971927	VOC	2.15	0.01
OP2SMLTK14	Oxygen Scavenger Tank 971977	VOC	2.15	0.01
OP2SMLTK03	Scale Inhibitor Tank 971978	VOC	2.15	0.01
OP2SMLTK04	Corrosion Inhibitor Tank 971979	VOC	2.15	0.01
OP2SMLTK15	Scale Inhibitor Tank 983321	VOC	2.15	0.01
OP2SMLTK16	Corrosion Inhibitor Tank 983320	VOC	2.15	0.01
OP2SMLTK17	Bio-dispersant Tank 983322	VOC	2.15	0.01
OP2SMLTK05	Corrosion Inhibitor Tank 983323	VOC	2.15	0.01
OP2SMLTK06	Anti-foam Tote (OP-2 Cooling Tower)	VOC	2.15	0.01
44E12	Waste Caustic Tank 4455	VOC	0.18	0.62
44E13	Washwater Re-run Tank 4451	VOC	0.01	0.01

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY**
44E14	20 percent Caustic Tank 4459	Sodium Hydroxide	0.01	0.01
44E15	Corrosion Inhibitor Tank	VOC	2.15	0.01
48E008	Slop Oil Storage Tank 48008	VOC	0.35	1.52
48E009	Wastewater Tank 48009	VOC	1.03	1.76
48E010	Wastewater Tank 48010	VOC	1.46	1.91
48E011	Wastewater Tank 48011	VOC	2.80	3.81
48E053	96 percent Sulfuric Acid Tank 48053	Sulfuric Acid	0.01	0.01
48E054	50 percent Caustic Tank 48054	Sodium Hydroxide	0.02	0.09
48E055	50 percent Caustic Tank 48055	Sodium Hydroxide	0.01	0.01
45E04X	Lube Oil Reservoir 4504X	VOC	0.93	4.05
45E05X	Seal Oil Degassing Tank 4505X	VOC	0.01	0.01
46E02X	Lube Oil Reservoir Tank 4602X	VOC	0.56	2.43
46E04X	Lube Oil Reservoir Tank 4604X	VOC	0.01	0.01
46E05X	Seal Oil Degassing Tank 4605X	VOC	0.01	0.01
46E09	Hydraulic Oil Storage Tank 4609	VOC	0.01	0.01

(1) Emission point identification - either specific equipment designation or emission point number (EPN) from a plot plan.

(2) Specific point source names. For fugitive sources, use an area name or fugitive source name.

(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code ' 101.1
NO_x - total oxides of nitrogen
SO_2 - sulfur dioxide
PM - particulate matter, suspended in the atmosphere, including PM_{10} and $PM_{2.5}$ as represented.
CO - carbon monoxide

(4) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission rate.

Emission Sources - Maximum Allowable Emission Rates

* Emission rates are based on and the facilities are limited by the following maximum operating schedule:
Hrs/day 24 Days/week 7 Weeks/year 52

** Compliance with annual emission limits is based on a rolling 12-month period.

Date: January 5, 2015

Texas Commission on Environmental Quality
Air Quality Permit

A Permit Is Hereby Issued To
Equistar Chemicals, LP
Authorizing the Construction and Operation of
Channelview Complex
Located at **Channelview, Harris County, Texas**
Latitude 29° 49′ 52″ Longitude −95° 7′ 32″

Permit: 8125, PSDTX1280M1, and N144

Amendment Date: February 28, 2019

Expiration Date: May 26, 2019

For the Commission

1. **Facilities** covered by this permit shall be constructed and operated as specified in the application for the permit. All representations regarding construction plans and operation procedures contained in the permit application shall be conditions upon which the permit is issued. Variations from these representations shall be unlawful unless the permit holder first makes application to the Texas Commission on Environmental Quality (commission) Executive Director to amend this permit in that regard and such amendment is approved. [Title 30 Texas Administrative Code (TAC) Section 116.116 (30 TAC § 116.116)] [1]
2. **Voiding of Permit**. A permit or permit amendment is automatically void if the holder fails to begin construction within 18 months of the date of issuance, discontinues construction for more than 18 months prior to completion, or fails to complete construction within a reasonable time. Upon request, the executive director may grant an 18-month extension. Before the extension is granted the permit may be subject to revision based on best available control technology, lowest achievable emission rate, and netting or offsets as applicable. One additional extension of up to 18 months may be granted if the permit holder demonstrates that emissions from the facility will comply with all rules and regulations of the commission, the intent of the Texas Clean Air Act (TCAA), including protection of the public's health and physical property; and (b)(1)the permit holder is a party to litigation not of the permit holder's initiation regarding the issuance of the permit; or (b)(2) the permit holder has spent, or committed to spend, at least 10 percent of the estimated total cost of the project up to a maximum of $5 million. A permit holder granted an extension under subsection (b)(1) of this section may receive one subsequent extension if the permit holder meets the conditions of subsection (b)(2) of this section. [30 TAC § 116.120]
3. **Construction Progress**. Start of construction, construction interruptions exceeding 45 days, and completion of construction shall be reported to the appropriate regional office of the commission not later than 15 working days after occurrence of the event. [30 TAC § 116.115(b)(2)(A)]
4. **Start-up Notification**. The appropriate air program regional office shall be notified prior to the commencement of operations of the facilities authorized by the permit in such a manner that a representative of the commission may be present. The permit holder shall provide a separate notification for the commencement of operations for each unit of phased construction, which may involve a series of units commencing operations at different times. Prior to operation of the facilities authorized by the permit, the permit holder shall identify the source or sources of allowances to be utilized for compliance with Chapter 101, Subchapter H, Division 3 of this title (relating to Mass Emissions Cap and Trade Program). [30 TAC § 116.115(b)(2)(B)]
5. **Sampling Requirements**. If sampling is required, the permit holder shall contact the commission's Office of Compliance and Enforcement prior to sampling to obtain the proper data forms and procedures. All sampling and testing procedures must be approved by the executive director and coordinated with the regional representatives of the commission. The permit holder is also responsible for providing sampling facilities and conducting the sampling operations or contracting with an independent sampling consultant. [30 TAC § 116.115(b)(2)(C)]
6. **Equivalency of Methods.** The permit holder must demonstrate or otherwise justify the equivalency of emission control methods, sampling or other emission testing methods, and monitoring methods proposed as alternatives to methods indicated in the conditions of the permit. Alternative methods shall be applied for in writing and must be reviewed and approved by the executive director prior to their use in fulfilling any requirements of the permit. [30 TAC § 116.115(b)(2)(D)]
7. **Recordkeeping.** The permit holder shall maintain a copy of the permit along with records containing the information and data sufficient to demonstrate compliance with the permit, including production records and

operating hours; keep all required records in a file at the plant site. If, however, the facility normally operates unattended, records shall be maintained at the nearest staffed location within Texas specified in the application; make the records available at the request of personnel from the commission or any air pollution control program having jurisdiction in a timely manner; comply with any additional recordkeeping requirements specified in special conditions in the permit; and retain information in the file for at least two years following the date that the information or data is obtained. [30 TAC § 116.115(b)(2)(E)]

8. **Maximum Allowable Emission Rates**. The total emissions of air contaminants from any of the sources of emissions must not exceed the values stated on the table attached to the permit entitled "Emission Sources--Maximum Allowable Emission Rates." [30 TAC § 116.115(b)(2)(F)] [1]
9. **Maintenance of Emission Control**. The permitted facilities shall not be operated unless all air pollution emission capture and abatement equipment is maintained in good working order and operating properly during normal facility operations. The permit holder shall provide notification in accordance with 30 TAC §101.201, 101.211, and 101.221 of this title (relating to Emissions Event Reporting and Recordkeeping Requirements; Scheduled Maintenance, Startup, and Shutdown Reporting and Recordkeeping Requirements; and Operational Requirements). [30 TAC§ 116.115(b)(2)(G)]
10. **Compliance with Rules**. Acceptance of a permit by an applicant constitutes an acknowledgment and agreement that the permit holder will comply with all rules and orders of the commission issued in conformity with the TCAA and the conditions precedent to the granting of the permit. If more than one state or federal rule or regulation or permit condition is applicable, the most stringent limit or condition shall govern and be the standard by which compliance shall be demonstrated. Acceptance includes consent to the entrance of commission employees and agents into the permitted premises at reasonable times to investigate conditions relating to the emission or concentration of air contaminants, including compliance with the permit. [30 TAC § 116.115(b)(2)(H)]
11. **This** permit may not be transferred, assigned, or conveyed by the holder except as provided by rule. [30 TAC § 116.110(e)]
12. **There** may be additional special conditions attached to a permit upon issuance or modification of the permit. Such conditions in a permit may be more restrictive than the requirements of Title 30 of the Texas Administrative Code. [30 TAC § 116.115(c)]
13. **Emissions** from this facility must not cause or contribute to "air pollution" as defined in Texas Health and Safety Code (THSC) §382.003(3) or violate THSC § 382.085. If the executive director determines that such a condition or violation occurs, the holder shall implement additional abatement measures as necessary to control or prevent the condition or violation.
14. **The** permit holder shall comply with all the requirements of this permit. Emissions that exceed the limits of this permit are not authorized and are violations of this permit. [1]

[1] Please be advised that the requirements of this provision of the general conditions may not be applicable to greenhouse gas emissions.

Special Conditions

Permit Numbers 8125, PSDTX1280M1 and N144

1. This permit covers only those sources of emissions listed in the attached table entitled "Emission Sources - Maximum Allowable Emission Rates," and those sources are limited to the emission limits and other conditions specified in the attached table.

2. These facilities shall comply with all applicable requirements of the U.S. Environmental Protection Agency (EPA) regulations on Standards of Performance for New Stationary Sources promulgated in Title 40 Code of Federal Regulations Part 60 (40 CFR Part 60), Subparts A, Kb, VV and NNN.

3. These facilities shall comply with all applicable requirements of EPA regulations on National Emission Standards for Hazardous Air Pollutants (NESHAP) promulgated in 40 CFR Part 63, Subparts A, F, G and H.

4. Non-fugitive emissions from relief valves, safety valves, or rupture discs of gases containing volatile organic compounds (VOC) at a concentration of greater than one percent are not authorized by this permit unless authorized on the maximum allowable emission rates table (MAERT). Any releases directly to atmosphere from relief valves, safety valves, or rupture discs of gases containing VOC at a concentration greater than one weight percent are not consistent with good practice for minimizing emissions.

5. Storage Tanks ETK3122, ETK5101, and ETK5102:

   A. Storage tank throughput and service shall be limited to the following:

Tank	Service	Tank Capacity (gallons)	Rolling 12-Month Throughput (gallons)
ETK3122	Methanol	798,000	15,960,000
ETK5101	Methyl-tert-butyl Ether (MTBE)	5,460,000	138,000,000
ETK5101	Methanol	5,460,000	273,000,000*
ETK5102	Methanol	5,460,000	

* ETK5101and ETK5102 are operated as a system with regard to methanol service.

   B. Storage Tanks ETK3122, ETK5101 and ETK5102 shall be internal floating roof storage tanks equipped with a mechanical shoe primary seal and a rim mounted secondary seal.

   C. The permit holder shall perform the visual inspections and seal gap measurements as specified in Title 40 Code of Federal Regulations § 60.113b (40 CFR § 60.113b) Testing and Procedures (as amended at 54 FR 32973, Aug. 11, 1989) to verify fitting and seal integrity. Records shall be maintained of the dates seals were inspected and seal gap measurements made, results of inspections and measurements made (including raw data), and date and description of actions taken to correct any deficiencies noted.

   D. The floating roof design shall incorporate sufficient flotation to conform to the requirements of API Code 650 dated November 1, 1998 except that an internal floating cover need not be designed to meet rainfall support requirements and the materials of construction may be steel or other materials.

E. Uninsulated tank exterior surfaces exposed to the sun shall be white or aluminum. Storage tanks must be equipped with permanent submerged fill pipes.

F. The permit holder shall maintain a record of tank throughput for the previous month and the past consecutive 12 month period for each tank.

6. Loading of methanol product into rail cars and truck tanks is authorized. The product loading rate shall not exceed 18,000 gallons per hour.

All loading shall be by submerged filling. VOC loading emissions shall be routed to the East Plant Flare, Emission Point Number (EPN) 17E01.

All lines and connectors shall be visually inspected for any defects prior to hookup. Lines and connectors that are visibly damaged shall be removed from service. Loading operations shall cease immediately upon detection of any liquid leaking from the lines or connections.

The permit holder shall maintain a record of product loading for each day of loading operations including date, loading time, and amount of product loaded.

The permit holder shall maintain and update monthly an emissions record which includes calculated emissions of VOC from all loading operations over the previous rolling 12-month period.

7. The Methanol Reformer Furnace (EPN EHTF7001) shall be fired with natural gas and/or fuel gas containing not more than 2,000 grains of total sulfur per million dry standard cubic feet.

8. The Reformer Furnace and SCR control (EPN EHTF7001) shall meet the following operating limits: **(03/19)**

A. The firing rate shall not exceed 1615 million British Thermal Units per hour (MMBtu/hr) based on the higher heating value (HHV) of the fuel.

B. Nitrogen Oxides (NO_x) shall not exceed 0.016 pounds per million British Thermal Units (lbs/MMBtu) on an hourly average, except during startup or shutdown limited to 172 hours per year.

C. NO_x shall not exceed 0.011 lbs/MMBtu on a 12 month average.

D. Ammonia (NH_3) shall not exceed 10 parts per million by volume dry (ppmvd) at 3% Oxygen (O_2) on an hourly average.

E. Carbon Monoxide (CO) shall not exceed 50 parts per million by volume dry (ppmvd) at 3% O_2, on an hourly average, except during startup or shutdown limited to 172 hours per year.

F. CO shall not exceed 50 parts per million by volume dry at 3% O_2 on a rolling 12-month average.

9. Piping, Valves, Pumps, and Compressors in Ammonia (NH_3) Service

A. Audio, olfactory, and visual checks for NH_3 leaks within the operating area shall be made once every shift.

B. Immediately, but no later than five hours upon detection of a leak, plant personnel shall take the following actions:

(1) Isolate the leak; or,

(2) Commence repair or replacement of the leaking component; or,

(3) Use a leak collection/containment system to prevent the leak until repair or replacement can be made if immediate repair is not possible.

C. Date and time of each inspection shall be noted in the operator's log or equivalent. Records shall be maintained at the plant site of the date, time, and description of all repairs and replacements made due to leaks. These records shall be made available to representatives of the Texas Commission on Environmental Quality (TCEQ) upon request.

10. Piping, Valves, Pumps, Agitators, and Compressors in VOC Service - 28LAER

Except as may be provided for in the special conditions of this permit, the following requirements apply to the above-referenced equipment:

A. The requirements of paragraphs F and G shall not apply (1) where the VOC has an aggregate partial pressure or vapor pressure of less than 0.044 pound per square inch, absolute (psia) at 68oF or (2) operating pressure is at least 5 kilopascals (0.725 psi) below ambient pressure. Equipment excluded from this condition shall be identified in a list or by one of the methods described below to be made readily available upon request.

The exempted components may be identified by one or more of the following methods:

(1) piping and instrumentation diagram (PID);

(2) a written or electronic database or electronic file;

(3) color coding;

(4) a form of weatherproof identification; or

(5) designation of exempted process unit boundaries.

B. Construction of new and reworked piping, valves, pump systems, and compressor systems shall conform to applicable American National Standards Institute (ANSI), American Petroleum Institute (API), American Society of Mechanical Engineers (ASME),, or equivalent codes.

C. New and reworked underground process pipelines shall contain no buried valves such that fugitive emission monitoring is rendered impractical. New and reworked buried connectors shall be welded.

D. To the extent that good engineering practice will permit, new and reworked valves and piping connections shall be so located to be reasonably accessible for leak-checking during plant operation. Difficult-to-monitor and unsafe-to-monitor valves, as defined by Title 30 Texas Administrative Code Chapter 115 (30 TAC Chapter 115), shall be identified in a list to be made readily available upon request. The difficult-to-monitor and unsafe-to-monitor valves may be identified by one or more of the methods described in subparagraph A above. If an unsafe-to-monitor component is not considered safe to monitor within a calendar year, then it shall be monitored as soon as possible during safe-to-monitor times. A difficult-to-monitor component for which quarterly monitoring is specified may instead be monitored annually.

E. New and reworked piping connections shall be welded or flanged. Screwed connections are permissible only on piping smaller than two-inch diameter. Gas or hydraulic testing of the new and reworked piping connections at no less than operating pressure shall be performed

prior to returning the components to service or they shall be monitored for leaks using an approved gas analyzer within 15 days of the components being returned to service. Adjustments shall be made as necessary to obtain leak-free performance.

Connectors shall be inspected by visual, audible, and/or olfactory means at least weekly by operating personnel walk-through. In addition, all connectors shall be monitored by leak-checking for fugitive emissions at least quarterly using an approved gas analyzer with a directed maintenance program in accordance with items F thru J of this special condition.

In lieu of the monitoring frequency specified above, connectors may be monitored on a semiannual basis if the percent of connectors leaking for two consecutive quarterly monitoring periods is less than 0.5 percent.

Connectors may be monitored on an annual basis if the percent of connectors leaking for two consecutive semiannual monitoring periods is less than 0.5 percent.

If the percent of connectors leaking for any semiannual or annual monitoring period is 0.5 percent or greater, the facility shall revert to quarterly monitoring until the facility again qualifies for the alternative monitoring schedules previously outlined in this paragraph.

The percent of connectors leaking used in paragraph B shall be determined using the following formula:

$(Cl + Cs) \times 100/Ct = Cp$

Where:

Cl = the number of connectors found leaking by the end of the monitoring period, either by Method 21 or sight, sound, and smell.

Cs = the number of connectors for which repair has been delayed and are listed on the facility shutdown log.

Ct = the total number of connectors in the facility subject to the monitoring requirements, as of the last day of the monitoring period, not including non-accessible and unsafe-to-monitor connectors.

Cp = the percentage of leaking connectors for the monitoring period.

Each open-ended valve or line shall be equipped with an appropriately sized cap, blind flange, plug, or a second valve to seal the line. Except during sampling, both valves shall be closed. If the isolation of equipment for hot work or the removal of a component for repair or replacement results in an open-ended line or valve, it is exempt from the requirement to install a cap, blind flange, plug, or second valve for 72 hours. If the repair or replacement is not completed within 72 hours, the permit holder must complete either of the following actions within that time period;

(1) a cap, blind flange, plug, or second valve must be installed on the line or valve; or

(2) the open-ended valve or line shall be monitored once for leaks above background for a plant or unit turnaround lasting up to 45 days with an approved gas analyzer and the results recorded. For all other situations, the open-ended valve or line shall be monitored once by the end of the 72 hours period following the creation of the open-ended line and monthly thereafter with an approved gas analyzer and the results recorded. For turnarounds and all other situations, leaks are indicated by readings of 500 ppmv and must be repaired within 24 hours or a cap, blind flange, plug, or second valve must be installed on the line or valve.

F. Accessible valves shall be monitored by leak-checking for fugitive emissions at least quarterly using an approved gas analyzer with a directed maintenance program. Non-accessible valves shall be monitored by leak-checking for fugitive emissions at least annually using an approved gas analyzer with a directed maintenance program. Sealless/leakless valves (including, but not limited to, welded bonnet bellows and diaphragm valves) and relief valves equipped with a rupture disc upstream or venting to a control device are not required to be monitored. For valves equipped with rupture discs, a pressure-sensing device shall be installed between the relief valve and rupture disc to monitor disc integrity. All leaking discs shall be replaced at the earliest opportunity but no later than the next process shutdown. A check of the reading of the pressure-sensing device to verify disc integrity shall be performed at least quarterly and recorded in the unit log or equivalent. Pressure-sensing devices that are continuously monitored with alarms are exempt from recordkeeping requirements specified in this paragraph.

The gas analyzer shall conform to requirements listed in Method 21 of 40 CFR part 60, appendix A. The gas analyzer shall be calibrated with methane. In addition, the response factor of the instrument for a specific VOC of interest shall be determined and meet the requirements of Section 8 of Method 21. If a mixture of VOCs is being monitored, the response factor shall be calculated for the average composition of the process fluid. A calculated average is not required when all of the compounds in the mixture have a response factor less than 10 using methane. If a response factor less than 10 cannot be achieved using methane, than the instrument may be calibrated with one of the VOC to be measured or any other VOC so long as the instrument has a response factor of less than 10 for each of the VOC to be measured.

A directed maintenance program shall consist of the repair and maintenance of components assisted simultaneously by the use of an approved gas analyzer such that a minimum concentration of leaking VOC is obtained for each component being maintained. Replaced components shall be re-monitored within 15 days of being placed back into VOC service.

G. All new and replacement pumps, compressors, and agitators shall be equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal. These seal systems need not be monitored and may include (but are not limited to) dual pump seals with barrier fluid at higher pressure than process pressure, seals degassing to vent control systems kept in good working order, or seals equipped with an automatic seal failure detection and alarm system. Submerged pumps or sealless pumps (including, but not limited to, diaphragm, canned, or magnetic-driven pumps) may be used to satisfy the requirements of this condition and need not be monitored.

All other pump, compressor, and agitator seals shall be monitored with an approved gas analyzer at least quarterly.

H. Damaged or leaking valves, connectors, compressor seals, pump seals, and agitator seals found to be emitting VOC in excess of 500 parts per million by volume (ppmv) or found by visual inspection to be leaking (e.g., dripping process fluids) shall be tagged and replaced or repaired. A first attempt to repair the leak must be made within 5 days. Records of the first attempt to repair shall be maintained. A leaking component shall be repaired as soon as practicable, but no later than 15 days after the leak is found. If the repair of a component would require a unit shutdown that would create more emissions than the repair would eliminate, the repair may be delayed until the next scheduled shutdown. All leaking components which cannot be repaired until a scheduled shutdown shall be identified for such repair by tagging. A listing of all components that qualify for delay of repair shall be maintained on a delay of repair list. The cumulative daily emissions from all components on

the delay of repair list shall be estimated by multiplying by 24 the mass emission rate for each component calculated in accordance with the instructions in 30 TAC 115.782 (c)(1)(B)(i)(II). The calculations of the cumulative daily emissions from all components on the delay of repair list shall be updated within ten days of when the latest leaking component is added to the delay of repair list. When the cumulative daily emission rate of all components on the delay of repair list times the number of days until the next scheduled unit shutdown is equal to or exceeds the total emissions from a unit shutdown as calculated in accordance with 30 TAC 115.782 (c)(1)(B)(i)(I), the TCEQ Regional Manager and any local programs shall be notified and may require early unit shutdown or other appropriate action based on the number and severity of tagged leaks awaiting shutdown. This notification shall be made within 15 days of making this determination.

I. Records of repairs shall include date of repairs, repair results, justification for delay of repairs, and corrective actions taken for all components. Records of instrument monitoring shall indicate dates and times, test methods, and instrument readings. The instrument monitoring record shall include the time that monitoring took place for no less than 95% of the instrument readings recorded. Records of physical inspections shall be noted in the operators log or equivalent.

J. Compliance with the requirements of this condition does not assure compliance with requirements of 30 TAC Chapter 115, an applicable New Source Performance Standard (NSPS), or an applicable National Emission Standard for Hazardous Air Pollutants (NESHAPS), and does not constitute approval of alternative standards for these regulations.

K. In lieu of the monitoring frequency specified in paragraph F, valves in gas and light liquid service may be monitored on a semiannual basis if the percent of valves leaking for two consecutive quarterly monitoring periods is less than 0.5 percent.

Valves in gas and light liquid service may be monitored on an annual basis if the percent of valves leaking for two consecutive semiannual monitoring periods is less than 0.5 percent.

11. Cooling Tower Monitoring:

A. VOC Monitoring: The cooling tower water shall be monitored monthly for VOC leakage from heat exchangers in accordance with the requirements of the TCEQ Sampling Procedures Manual, Appendix P (dated January 2003 or a later edition) or another air stripping method approved by the TCEQ Executive Director.

Cooling water VOC concentrations above 0.08 ppmw indicate faulty equipment. Equipment shall be maintained so as to minimize VOC emissions into the cooling water. Faulty equipment shall be repaired at the earliest opportunity but no later than the next scheduled shutdown of the process unit in which the leak occurs.

Emissions from the cooling tower are not authorized if the VOC concentration of the water returning to the cooling tower exceeds 0.80 ppmw. The VOC concentrations above 0.80 ppmw are not subject to extensions for delay of repair under this permit condition. The date and results of the monitoring and date and description of maintenance efforts shall be recorded.

B. PM_{10} Monitoring - Cooling water shall be sampled once a week for total dissolved solids (TDS) and once a day for conductivity. Dissolved solids in the cooling water drift are considered to be emitted as PM_{10}. The data shall result from collection of water samples from the cooling tower feed water and represent the water being cooled in the tower. Water samples should be capped upon collection, and transferred to a laboratory area for analysis.

The analysis method for TDS shall be EPA Method 160.1, ASTM D5907, and SM 2540 C [SM - 19th edition of Standard Methods for Examination of Water]. The analysis method for Conductivity shall be ASTM D1125-95A and SM2510 B. Use of an alternative method shall be approved by the TCEQ Regional Director prior to its implementation.

C. The date and results of cooling tower monitoring and date and description of maintenance efforts shall be recorded and the records maintained at the plant site.

12. Flares (EPNs EMEOHFLARE and EEMERFLARE) shall be designed and operated in accordance with the following requirements: **(09/18)**

A. Each flare system shall be designed such that the combined assist natural gas and waste stream to each flare meets the 40 CFR § 60.18 specifications of minimum heating value and maximum tip velocity at all times when emissions may be vented to them.

The heating value and velocity requirements shall be satisfied during operations authorized by this permit. Flare testing per 40 CFR § 60.18(f) may be requested by the appropriate regional office to demonstrate compliance with these requirements.

B. Each flare shall be operated with a flame present at all times and/or have a constant pilot flame. The pilot flame shall be continuously monitored by a thermocouple, infrared monitor, or ultraviolet monitor. The time, date, and duration of any loss of pilot flame shall be recorded. Each monitoring device shall be accurate to, and shall be calibrated at a frequency in accordance with, the manufacturer's specifications.

C. Each flare shall be operated with no visible emissions except periods not to exceed a total of five minutes during any two consecutive hours. The continuous Methanol Flare (EPN EMEOHFLARE) will be steam-assisted to ensure no visible emissions.

D. The permit holder shall install a continuous flow monitor and composition analyzer that provides a record of the vent stream flow and composition to the flare. The flow monitor sensor and analyzer sample points shall be installed in the vent stream near to the flare inlet such that the total vent stream to the flare is measured and analyzed. Readings shall be taken at least once every 15 minutes and the average hourly values of the flow and composition shall be recorded each hour.

E. The monitors shall be calibrated or have a calibration check performed on an annual basis to meet the following accuracy specifications: the flow monitor shall be ±5.0%, temperature monitor shall be ±2.0% at absolute temperature, and pressure monitor shall be ±5.0 mm Hg.

F. Calibration of the analyzer shall follow the procedures and requirements of the mid-level calibration check procedure in Section 10.2 of Performance Specification 9 with the following exceptions:

(1) A mid-level calibration check shall be performed at least once every calendar week instead of once every 24 hours.

(2) If the difference between the analyzer response and the cylinder concentration for any target compound is greater than 10 percent, immediately inspect the instrument making any necessary adjustments, and conduct another mid-level calibration within 24 hours.

The calibration gases used for calibration procedures shall be in accordance with Section 7.1 of Performance Specification 9. Net heating value of the gas combusted in

the flare shall be calculated according to the equation given in 40 CFR §60.18(f)(3) as amended through October 17, 2000 (65 FR 61744).

G. The monitors and analyzers shall operate as required by this section at least 95% of the time when the flare is operational, averaged over a rolling 12-month period. Flared gas net heating value and actual exit velocity determined in accordance with 40 CFR § 60.18(f)(3) and 60.18(f)(4) shall be recorded at least once every hour. Hourly mass emission rates shall be determined and recorded using the above readings and the emission factors used in the amendment application dated PI-1 June 20, 2018.

13. Flare (EPN 17E01) shall be designed and operated in accordance with the following requirements: **(09/18)**

A. The flare systems shall be designed such that the combined assist natural gas and waste stream to each flare meets the 40 CFR § 60.18 specifications of minimum heating value and maximum tip velocity at all times when emissions may be vented to them.

The heating value and velocity requirements shall be satisfied during operations authorized by this permit. Flare testing per 40 CFR § 60.18(f) may be requested by the appropriate regional office to demonstrate compliance with these requirements.

B. The flare shall be operated with a flame present at all times and/or have a constant pilot flame. The pilot flame shall be continuously monitored by a thermocouple, infrared monitor, or ultraviolet monitor. The time, date, and duration of any loss of pilot flame shall be recorded. Each monitoring device shall be accurate to, and shall be calibrated at a frequency in accordance with, the manufacturer's specifications.

C. Each flare shall be operated with no visible emissions except periods not to exceed a total of five minutes during any two consecutive hours. This shall be ensured by the use of steam or air assist to the flare.

D. The permit holder shall install a continuous flow monitor and composition analyzer that provide a record of the vent stream flow and composition (total VOC or Btu content) to the flare. The flow monitor sensor and analyzer sample points shall be installed in the vent stream as near as possible to the flare inlet such that the total vent stream to the flare is measured and analyzed. Readings shall be taken at least once every 15 minutes and the average block hourly values of the flow and composition shall be recorded each hour at least 95 percent of the time the flare is operational.

The monitors shall be calibrated on an annual basis to meet the following accuracy specifications: the flow monitor shall be ±5.0%, temperature monitor shall be ±2.0% at absolute temperature, and pressure monitor shall be ±5.0 mm Hg.

Calibration of the analyzer shall follow the procedures and requirements of Section 10.0 of 40 CFR Part 60, Appendix B, Performance Specification 9, as amended through October 17, 2000 (65 FR 61744), except that the multi-point calibration procedure in Section 10.1 of Performance Specification 9 shall be performed at least once every calendar quarter instead of once every month, and the mid-level calibration check procedure in Section 10.2 of Performance Specification 9 shall be performed at least once every calendar week instead of once every 24 hours. The calibration gases used for calibration procedures shall be in accordance with Section 7.1 of Performance Specification 9. Net heating value of the gas combusted in the flare shall be calculated according to the equation given in 40 CFR §60.18(f)(3) as amended through October 17, 2000 (65 FR 61744).

The monitors and analyzers shall operate as required by this section at least 95 percent of the time when the flare is operational, averaged over a rolling 12 month period. Flared gas net heating value and actual exit velocity determined in accordance with 40 CFR §§60.18(f)(3) and 60.18(f)(4) shall be recorded at least once every 15 minutes at least 95 percent of the time the flare is operational. Block hourly mass emission rates shall be determined and recorded using the above readings and the emission factors used in the permit amendment application, PI-1 dated October 25, 2011.

E. During unit shutdowns and startups, waste gas flow and assist gas shall be monitored when degassing process units to ensure adequate Btu/scf at the flare tip.

14. The permit holder shall perform stack sampling and other testing as required to establish the actual pattern and quantities of air contaminants being emitted into the atmosphere from the selective catalytic reduction (SCR) unit which serves the Methanol Reformer Furnace (EPN EHTF7001) to demonstrate compliance with the MAERT. The permit holder is responsible for providing sampling and testing facilities and conducting the sampling and testing operations at his expense. Sampling shall be conducted in accordance with the appropriate procedures of the TCEQ Sampling Procedures Manual and EPA Reference Methods.

Requests to waive testing for any pollutant specified in this condition shall be submitted to the TCEQ Office of Air, Air Permits Division. Test waivers and alternate/equivalent procedure proposals for Title 40 Code of Federal Regulation Part 60 (40 CFR Part 60) testing which must have EPA approval shall be submitted to the TCEQ Regional Director.

A. The appropriate TCEQ Regional Office shall be notified not less than 45 days prior to sampling. The notice shall include:

(1) Proposed date for pretest meeting.

(2) Date sampling will occur.

(3) Name of firm conducting sampling.

(4) Type of sampling equipment to be used.

(5) Method or procedure to be used in sampling.

(6) Description of any proposed deviation from the sampling procedures specified in this permit or TCEQ/EPA sampling procedures.

(7) Procedure/parameters to be used to determine worst case emissions during the sampling period.

The purpose of the pretest meeting is to review the necessary sampling and testing procedures, to provide the proper data forms for recording pertinent data, and to review the format procedures for the test reports. The TCEQ Regional Director must approve any deviation from specified sampling procedures.

B. Air contaminants emitted from EPN EHTF7001 to be tested for include (but are not limited to) nitrogen oxides, carbon monoxide, particulate matter less than 10 microns in diameter, particulate matter less than 2.5 microns in diameter, VOC and ammonia.

C. Sampling shall occur within not later than 180 days after initial start-up of the facilities and at such other times as may be required by the TCEQ Executive Director. During subsequent operations stack sampling shall be performed within 120 days if current production rates

exceed the production rate during stack testing by 10 percent or greater. Requests for additional time to perform sampling shall be submitted to the appropriate regional office.

D. The facility being sampled shall operate at the maximum production rate during stack emission testing. These conditions/parameters and any other primary operating parameters that affect the emission rate shall be monitored and recorded during the stack test. Any additional parameters shall be determined at the pretest meeting and shall be stated in the sampling report. Permit conditions and parameter limits may be waived during stack testing performed under this condition if the proposed condition/parameter range is identified in the test notice specified in paragraph A and accepted by the TCEQ Regional Office. Permit allowable emissions and emission control requirements are not waived and still apply during stack testing periods.

E. Copies of the final sampling report shall be forwarded to the offices below within 60 days after sampling is completed. Sampling reports shall comply with the attached provisions entitled “Chapter 14, Contents of Sampling Reports” of the TCEQ Sampling Procedures Manual. The reports shall be distributed as follows:

One copy to the TCEQ Regional Office

One copy to each appropriate local air pollution control program

One copy to EPA NSR Branch in Dallas, Texas

F. Sampling ports and platforms shall be incorporated into the design of Emission Point EHTF7001according to the specifications set forth in the attachment entitled “Chapter 2, Stack Sampling Facilities” of the TCEQ Sampling Procedures Manual. Alternate sampling facility designs must be submitted for approval to the TCEQ Regional Director.

15. The permit holder shall install, calibrate, maintain and operate continuous emission monitoring systems (CEMS) to measure and record the in-stack concentration of nitrogen oxides (NO_x), carbon monoxide, oxygen (O_2) and ammonia from the SCR which serves the Methanol Reformer Furnace, EPN EHTF7001, and a gas chromatographic CEMS and continuous fuel flow monitor to the Reformer Furnace burners.

The inlet temperature of the gas entering the SCR shall also be continuously measured and recorded when the SCR is in operation.

As an approved alternative to installing and operating a CEMS for monitoring ammonia emissions, the permit holder may install and operate a second NO_x and O_2 CEMS probe located upstream of the SCR and shall also monitor and record the amount of ammonia injected into the SCR system for NO_x control. The two NO_x and O_2 probes may be used to determine the amount of NO_x removed by the SCR, and knowing the amount of ammonia injected into the SCR, the amount of ammonia slip shall be calculated.

When the SCR is in startup mode, the in-stack concentration of nitrogen oxides and carbon monoxide shall be continuously monitored and recorded.

A. The CEMS shall meet the design and performance specifications, pass the field tests, and meet the installation requirements and the data analysis and reporting requirements specified in the applicable Performance Specification Nos. 1 through 9, Title 40 Code of Federal Regulation Part 60 (40 CFR Part 60), Appendix B. If there are no applicable performance

specifications in 40 CFR Part 60, Appendix B, contact the TCEQ Office of Air, Air Permits Division for requirements to be met.

B. Section 1 below applies to sources subject to the quality-assurance requirements of 40 CFR Part 60, Appendix F; section 2 applies to all other sources:

(1) The permit holder shall assure that the CEMS meets the applicable quality-assurance requirements specified in 40 CFR Part 60, Appendix F, Procedure 1. Relative accuracy exceedances, as specified in 40 CFR Part 60, Appendix F, ' 5.2.3 and any CEMS downtime shall be reported to the appropriate TCEQ Regional Manager, and necessary corrective action shall be taken. Supplemental stack concentration measurements may be required at the discretion of the appropriate TCEQ Regional Manager.

(2) The system shall be zeroed and spanned daily, and corrective action taken when the 24-hour span drift exceeds two times the amounts specified in the applicable Performance Specification Nos. 1 through 9, 40 CFR Part 60, Appendix B, or as specified by the TCEQ if not specified in Appendix B. Zero and span is not required on weekends and plant holidays if instrument technicians are not normally scheduled on those days.

Each monitor shall be quality-assured at least quarterly using Cylinder Gas Audits (CGA) in accordance with 40 CFR Part 60, Appendix F, Procedure 1, Section 5.1.2, with the following exception: a relative accuracy test audit (RATA) is not required once every four quarters (i.e., four successive quarterly CGA may be conducted). An equivalent quality-assurance method approved by the TCEQ may also be used. Successive quarterly audits shall occur no closer than two months.

All CGA exceedances of +15 percent accuracy indicate that the CEMS is out of control.

C. The monitoring data shall be reduced to one-hour average concentrations, using a minimum of four equally-spaced data points from each one-hour period. The individual average concentrations shall be used with the fuel flow data to determine and record the hourly furnace HHV firing rate in MMBtu/hr, and the SCR exhaust flow rate by Method 19 in 40 CFR Part 60, Appendix B, to show and record compliance with the hourly Reformer Furnace and SCR operating limits and the MAERT short term lb/hr allowable limits. The hourly emissions shall be combined and recorded to show compliance with the rolling 12 month operating and MAERT limits.

D. All monitoring data and quality-assurance data shall be maintained by the source. The data from the CEMS and fuel flow monitor may, at the discretion of the TCEQ, be used to determine compliance with the conditions of this permit.

E. The appropriate TCEQ Regional Office shall be notified at least 30 days prior to any required RATA in order to provide them the opportunity to observe the testing.

F. Quality-assured (or valid) data must be generated when the Reformer Furnace is operating except during the performance of a daily zero and span check. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted provided it does not exceed 5 percent of the time (in minutes) that the Reformer Furnace operated over the previous rolling 12-month period. The measurements missed shall be estimated using engineering judgment and the methods used recorded.

16. The following requirements apply to VOC off gas capture systems which route these gases to the Methanol Flare (EPN EMEOHFLARE).

    A. VOC piping components associated with the capture system shall be monitored in accordance with Special Condition No. 10 of this permit.

    B. The capture system shall be designed and operated with no bypass of the control device.

    A bypass does not include authorized analyzer vents, highpoint bleeder vents, low point drains, or rupture discs upstream of pressure relief valves if the pressure between the disc and relief valve is monitored and recorded at least weekly.

17. The continuous Methanol Flare (EPN EMEOHFLARE) controls routine vents from the methanol process. **(9/17)**

18. The permit holder must satisfy a 1.3 to 1 NO_x emissions offset through participation in the Mass Emission Cap and Trade (MECT) program in the Houston/Galveston/Brazoria ozone nonattainment area. The permit holder must hold or obtain NO_x MECT allowances equal to 104.30 tpy at the beginning of each MECT compliance period. **(7/13)**

19. This Nonattainment New Source Review permit is approved based on the permanent retirement of 63.14 tpy of VOC emissions from Emission Reduction Credit Certificate (ERCC) Number 2663. **(7/13)**

Date: February 28, 2019

Emission Sources - Maximum Allowable Emission Rates

Permit Numbers 8125, PSDTX1280M1 and N144

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
EHTF7001	Reformer Furnace	VOC	8.71	38.14
		NO_x with SCR operating	23.00	69.32
		NO_x in startup/shutdown mode (6)	134.05	6.43
		SO_2	0.95	4.16
		PM	5.07	22.21
		PM_{10}	5.07	22.21
		$PM_{2.5}$	4.56	19.99
		CO	27.46	120.25
		CO in startup/shutdown mode (6)	121.34	
		NH_3	7.78	33.39
ECTMEOH	Cooling Tower	VOC	2.52	4.73
		PM	0.45	1.97
		PM_{10}	0.22	0.99
		$PM_{2.5}$	0.22	0.99
ETK3122	Surge Tank	VOC	3.24	0.34
ETK5101/ETK5102	Product Tanks	VOC	4.38	8.20
ESP7045	Lube Oil Reservoir	VOC	0.05	0.23
EFUGMEOH	Fugitives (5)	VOC	0.99	4.31
EFUGNH3	Fugitives (5)	NH_3	0.14	0.63
EMEOHANLZ	Methanol Analyzer Vents	VOC	0.56	2.42
		CO	0.12	0.54
EMEOHFLARE	Methanol Flare in normal operation	VOC	18.33	6.71
		NO_x	12.47	3.88
		CO	99.36	21.94

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
		SO_2	0.10	0.03
EMEOHFLARE	Methanol Flare in MSS operation	VOC	84.91	1.60
EEMERFLARE	Emergency Flare	NO_x	101.60	3.08
		CO	1094.18	17.79
		SO_2	0.11	0.01
17E01	East Plant Flare (7)	VOC	0.51	0.77
		NO_x	0.03	0.01
		CO	0.17	0.06
		SO_2	0.01	0.01
MSS	MSS (8)	VOC	5.58	0.07

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.
(2) Specific point source name. For fugitive sources, use area name or fugitive source name.
(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
NO_x - total oxides of nitrogen
SO_2 - sulfur dioxide
PM - total particulate matter, suspended in the atmosphere, including PM_{10} and $PM_{2.5}$, as represented
PM_{10} - total particulate matter equal to or less than 10 microns in diameter, including $PM_{2.5}$, as represented
$PM_{2.5}$ - particulate matter equal to or less than 2.5 microns in diameter
CO - carbon monoxide
NH_3 - ammonia
(4) Compliance with annual emission limits (tons per year) is based on a 12-month rolling period.
(5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.
(6) Emission rates are based on 172 hours of startup and shutdown per year.
(7) Methanol product loading related emissions only.
(8) Cleanout of vessels and related equipment during process unit turnaround. Annual emission rate is based on 24 hours of operation per rolling 12 months.

Date: February 28, 2019

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 6
1445 ROSS AVENUE, SUITE 1200
DALLAS, TX 75202-2733

JUL 19 2013

Mr. Thomas Warnement
Senior Environmental Representative
Equistar Chemicals, LP
P.O. Box 777
Channelview, TX 77530

Dear Mr. Warnement:

In accordance with the Clean Air Act (CAA), as amended (42 U.S.C. 7401 et seq.), the U.S. Environmental Protection Agency has reviewed your application for a CAA Prevention of Significant Deterioration (PSD) for Greenhouse Gas Emissions permit authorizing the construction of two new cracking furnaces, one each at the Olefins Production Unit 1 and the Olefins Production Unit 2 at the Channelview Plant in Channelview, Texas.

The EPA issued and published requests for public comment regarding EPA's proposed action on the above application on May 22, 2013. During the public comment period, no comments were received for this proposed action. However, a few administrative and/or clarifying changes were included and a copy of the Final Permit Revision Summary is enclosed. After consideration of the pertinent Federal statutes, regulations, and additional material relevant to the application contained in our Administrative Record, the EPA hereby issues the enclosed PSD Permit for the facility described above. The final permit, Final Permit Revision Summary and other key documents relevant to the final PSD permit are also available online at http://yosemite.epa.gov/r6/Apermit.nsf/AirP.

In accordance with 40 CFR §124.15(b)(3), this PSD Permit becomes effective immediately upon issuance. If you have any questions regarding this matter, please contact Mr. Jeff Robinson, Chief, Air Permits Section at (214) 665-6435.

Sincerely,

Wren Stenger

Wren Stenger
Director
Multimedia Planning and
Permitting Division

Enclosures:

Recycled/Recyclable • Printed with Vegetable Oil Based Inks on 100% Recycled Paper (40% Postconsumer)

PREVENTION OF SIGNIFICANT DETERIORATION PERMIT FOR GREENHOUSE GAS EMISSIONS ISSUED PURSUANT TO THE REQUIREMENTS AT 40 CFR § 52.21

U.S. ENVIRONMENTAL PROTECTION AGENCY, REGION 6

PSD PERMIT NUMBER: PSD-TX-1272-GHG

PERMITTEE: Equistar Chemicals, LP
P.O. Box 777
Channelview, TX 77530

FACILITY NAME: Equistar Chemicals, LP
Channelview Plant

FACILITY LOCATION: 8280 Sheldon Road, Building 1
Channelview, TX 77530

Pursuant to the provisions of the Clean Air Act (CAA), Subchapter I, Part C (42 U.S.C. Section 7470, *et. Seq.*), and the Code of Federal Regulations (CFR) Title 40, Section 52.21, and the Federal Implementation Plan at 40 CFR § 52.2305 (effective May 1, 2011 and published at 76 FR 25178), the U.S. Environmental Protection Agency, Region 6 is issuing a *Prevention of Significant Deterioration* (PSD) permit to Equistar Chemicals, LP (Equistar) for Greenhouse Gas (GHG) emissions. The Permit applies to the addition of new cracking furnaces at Equistar's Olefins Production units (OP-1 and OP-2) at the Channelview North Plant located in Channelview, Texas.

Equistar is authorized to construct a cracking furnace at each of the OP-1 and OP-2 Olefins Production units as described herein, in accordance with the permit application (and plans submitted with the permit application), the federal PSD regulations at 40 CFR § 52.21, and other terms and conditions set forth in this PSD permit in conjunction with the corresponding Texas Commission on Environmental Quality (TCEQ) PSD permit No. PSD-TX-1272 (for OP-1) and PSD-TX-1270 (for OP-2). Failure to comply with any condition or term set forth in this PSD Permit may result in enforcement action pursuant to Section 113 of the Clean Air Act (CAA). This PSD Permit does not relieve Equistar of the responsibility to comply with any other applicable provisions of the CAA (including applicable implementing regulations in 40 CFR Parts 51, 52, 60, 61, 72 through 75, and 98) or other federal and state requirements (including the state PSD program that remains under approval at 40 CFR § 52.2303).

In accordance with 40 CFR §124.15(b)(3), this PSD Permit becomes effective immediately upon issuance of this final decision.

Wren Stenger

Wren Stenger, Director
Multimedia Planning and Permitting Division

7/19/13
Date

Equistar Chemical Company LP (PSD-TX-1272-GHG)
Prevention of Significant Deterioration Permit
For Greenhouse Gas Emissions
Final Permit Conditions

PROJECT DESCRIPTION

The proposed modification will add a new cracking furnace to each of the existing Olefins Production units (OP-1 and OP-2) at the Channelview North Plant in Channelview, Texas. The Olefins Production units (OP-1 and OP-2) receive hydrocarbon feedstock where it is fed into pyrolysis furnaces. The pyrolysis furnaces, which are fired on natural gas and/or process gas, heat the feedstock to a high temperature where it cracks and reforms primarily as alkenes or olefins. The construction increases the plant's nominal production capacity by 750,000 tpy. The plant also produces other products at varying capacities, but ethylene is the predominant product.

The process effluent from the furnaces is quenched and scrubbed with water. Pyrolysis gasoline is removed as a product during water scrubbing. The quenched gases are compressed, dried, and cooled prior to beginning a series of purification/distillation steps. A hydrogen rich stream from the final chilling step is further purified in a pressure swing absorber to produce hydrogen product.

The purification section consists of a series of distillation columns that separate the process gas stream into acetylene, ethylene, propylene, mixed C4s, and pyrolysis gasoline (pygas) products. Ethane and propane process gas recovered during distillation and separation are recycled as feedstock into the pyrolysis (cracking) furnaces.

Periodically, coke (primarily carbon) deposited in the furnace tubes shall be removed. This decoking operation consists of two steps, of which only the second produces GHG emissions:

- An initial steam purge which moves hydrocarbons and coke particles further into the process, then
- A burn step which produces CO and CO_2, and routes the vent stream including coke particles to a cyclone separator.

EQUIPMENT LIST

The following devices are subject to this GHG PSD permit.

FIN	EPN	Description
EF3419 EF4419	EF3419 EF4419	Two Cracking Furnaces (Combustion Units). Each furnace has a maximum rated capacity of 640 MMBtu/hr, and will be equipped with a Selective Catalytic Reduction (SCR) system.
EOP1DECOKE2 EOP2DECOKE2	EOP1DECOKE2 EOP2DECOKE2	Decoke Pots
EOP1FUGEXP EOP2FUGEXP	EOP1FUGEXP EOP2FUGEXP	Process Fugitives

I. GENERAL PERMIT CONDITIONS

A. PERMIT EXPIRATION

As provided in 40 CFR §52.21(r), this PSD Permit shall become invalid if construction:

1. is not commenced (as defined in 40 CFR §52.21(b)(9)) within 18 months after the approval takes effect; or

2. is discontinued for a period of 18 months or more; or

3. is not completed within a reasonable time.

Pursuant to 40 CFR §52.21(r), EPA may extend the 18-month period upon a written satisfactory showing that an extension is justified.

B. PERMIT NOTIFICATION REQUIREMENTS

Permittee shall notify EPA Region 6 in writing or by electronic mail of the:

1. date construction is commenced, postmarked within 30 days of such date;

2. actual date of initial startup, as defined in 40 CFR §60.2, postmarked within 15 days of such date; and

3. date upon which initial performance tests will commence, in accordance with the provisions of Section V, postmarked not less than 30 days prior to such date. Notification may be provided with the submittal of the performance test protocol required pursuant to Condition V.B.

C. FACILITY OPERATION

At all times, including periods of startup, shutdown, and maintenance, Permittee shall, to the extent practicable, maintain and operate the facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the EPA, which may include, but is not limited to, monitoring results, review of operating maintenance procedures and inspection of the facility.

D. MALFUNCTION REPORTING

1. Permittee shall notify EPA by mail within 48 hours following the discovery of any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner, which results in an increase in GHG emissions above the allowable emission limits stated in Section II and III of this permit.

2. Within 10 days of the restoration of normal operations after any failure described in I.D.1., Permittee shall provide a written supplement to the initial notification that includes a description of the malfunctioning equipment or abnormal operation, the date of the initial malfunction, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed in Section II and III, and the methods utilized to mitigate emissions and restore normal operations.

3. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violation of this permit or any law or regulation such malfunction may cause.

E. RIGHT OF ENTRY

EPA authorized representatives, upon the presentation of credentials, shall be permitted:

1. to enter the premises where the facility is located or where any records are required to be kept under the terms and conditions of this PSD Permit;

2. during normal business hours, to have access to and to copy any records required to be kept under the terms and conditions of this PSD Permit;

3. to inspect any equipment, operation, or method subject to requirements in this PSD Permit; and,

4. to sample materials and emissions from the source(s).

F. TRANSFER OF OWNERSHIP

In the event of any changes in control or ownership of the facilities to be constructed, this PSD Permit shall be binding on all subsequent owners and operators. Permittee shall notify the succeeding owner and/or operator of the existence of the PSD Permit and its conditions by letter; a copy of the letter shall be forwarded to EPA Region 6 within thirty days of the letter signature.

G. SEVERABILITY

The provisions of this PSD Permit are severable, and, if any provision of the PSD Permit is held invalid, the remainder of this PSD Permit shall not be affected.

H. ADHERENCE TO APPLICATION AND COMPLIANCE WITH OTHER ENVIRONMENTAL LAWS

Permittee shall construct this project in compliance with this PSD Permit, the application on which this permit is based, the TCEQ PSD Permits PSD-TX- 1272 and PSD-TX-1270(when issued) and all other applicable federal, state, and local air quality regulations. This PSD permit does not release the Permittee from any liability for compliance with other applicable federal, state and local environmental laws and regulations, including the Clean Air Act.

I. ACRONYMS AND ABBREVIATIONS

AVO	Auditory, Visual, and Olfactory
BACT	Best Available Control Technology
CAA	Clean Air Act
CC	Carbon Content
CCS	Carbon Capture and Sequestration
CEMS	Continuous Emissions Monitoring System
CFR	Code of Federal Regulations
CH_4	Methane
CO_2	Carbon Dioxide
CO_2e	Carbon Dioxide Equivalent
dscf	Dry Standard Cubic Foot
EF	Emission Factor
EPN	Emission Point Number
FIN	Facility Identification Number
FR	Federal Register
GCV	Gross Calorific Value
GHG	Greenhouse Gas
gr	Grains
GWP	Global Warming Potential
HHV	High Heating Value
hr	Hour
HRSG	Heat Recovery Steam Generating
LAER	Lowest Achievable Emission Rate
lb	Pound
LDAR	Leak Detection and Repair
MAPD	Methyl Acetylene Propadiene
MMBtu	Million British Thermal Units
MSS	Maintenance, Start-up and Shutdown
NAAQS	National Ambient Air Quality Standards
NNSR	Nonattainment New Source Review
N_2O	Nitrous Oxides
NSPS	New Source Performance Standards
PSD	Prevention of Significant Deterioration
QA/QC	Quality Assurance and/or Quality Control
SCFH	Standard Cubic Feet per Hour
SCR	Selective Catalytic Reduction
TAC	Texas Administrative Code
TCEQ	Texas Commission on Environmental Quality
TOC	Total Organic Carbon
TPY	Tons per Year
USC	United States Code
VDU	Vapor Destruction Unit
VHP	Very High Pressure
VOC	Volatile Organic Compound

II. Annual Emission Limits

Annual emissions, in tons per year (TPY) on a 12-month, rolling average, shall not exceed the following:

Table 1. Annual Emission Limits

FIN	EPN	Description	GHG Mass Basis		TPY CO_2e[1,2]	BACT Requirements
				TPY[1]		
EF3419	EF3419	Cracking Furnace (OP-1)	CO_2	300,400	300,706	Furnace Gas Exhaust Temperature ≤ 408 °F. Maintain a Minimum Thermal Efficiency of 89.5%. See permit condition III.A.1.m. through o.
			CH_4	5.7		
			N_2O	0.6		
EF4419	EF4419	Cracking Furnace (OP-2)	CO_2	300,400	300,706	Furnace Gas Exhaust Temperature ≤ 408 °F. Maintain a Minimum Thermal Efficiency of 89.5%. See permit condition III.A.1.m. through o.
			CH_4	5.7		
			N_2O	0.6		
EOP1DECOKE2	EOP1DECOKE2	Decoke Pot (OP-1)	CO_2	281	281	Good Combustion Practices. See permit condition III.A.1.
EOP2DECOKE2	EOP2DECOKE2	Decoke Pot (OP-2)	CO_2	281	281	Good Combustion Practices. See permit condition III.A.1.
EOP1FUGEXP	EOP1FUGEXP	Fugitive Process Emissions (OP-1)	CH_4	No Emission Limit Established[3]	No Emission Limit Established[3]	Implementation of LDAR program. See permit condition III.A.2.
EOP2FUGEXP	EOP2FUGEXP	Fugitive Process Emissions (OP-2)	CH_4	No Emission Limit Established[3]	No Emission Limit Established[3]	Implementation of LDAR program. See permit condition III.A.2.
Totals[4]			**CO_2**	**601,362**	**CO_2e 602,000**	
			CH_4	**12.6**		
			N_2O	**1.2**		

1. The TPY emission limits specified in this table are not to be exceeded for this facility and include emissions from the facility during all operations and include MSS activities.
2. Global Warming Potentials (GWP): CH_4 = 21, N_2O = 310
3. Fugitive process emissions from EPN EOP1FUGEXP and EOP2FUGEXP are estimated for each process unit (OP-1 and OP-2) to be 0.6 TPY of CH_4, and 13 TPY CO_2e. In lieu of an emission limit, the emissions will be limited by implementing a design/work practice standard as specified in the permit.
4. Total emissions include the PTE for fugitive emissions. Totals are given for informational purposes only and do not constitute emission limits.

III. SPECIAL PERMIT CONDITIONS

A. Emission Unit Work Practice Standards, Operational Requirements, and Monitoring

1. Cracking Furnaces (EPNs: EF3419 and EF4419) and Decoke Pot (EPNs: EOP1DECOKE2 and EOP2DECOKE2)

a. The cracking furnaces shall combust pipeline quality natural gas and/or process gas (fuel gas).
b. All fuel combustion units identified in this permit shall:

   i. Measure and record the fuel flow rate using an operational non-resettable elapsed flow meter or by recording the flow rate data in an electronic format with individual flow measurements being taken no less frequently than once every 15 minutes. Electronic data may be reduced to hourly averages for recordkeeping purposes.
   ii. Record the total fuel combusted monthly.
   iii. The fuel gross calorific value (GCV) [high heat value (HHV)], carbon content and, if applicable, molecular weight, shall be determined, at a minimum, hourly using an online chromatograph, or by the procedures contained in 40 CFR Part 98.34(b)(3). Records of the fuel GCV shall be maintained for a minimum period of five years. Upon request, Permittee shall provide a sample and/or analysis of the fuel that is fired in any unit covered by this permit at the time of the request, or shall allow a sample to be taken by EPA for analysis.
   iv. The fuel flow of the fuel fired in the cracking furnaces (EF3419 and EF4419) shall be continuously monitored and recorded.

c. Permittee shall calibrate and perform a preventative maintenance check of the fuel gas flow meters and document annually.
d. Permittee shall install, operate, and maintain an O_2 analyzer for the cracking furnace flue gas at a location downstream of the radiant sections of the cracking furnaces (EF3419 and EF4419).
e. Oxygen analyzers shall continuously monitor and record the excess oxygen concentration in the furnace flue gases. The monitoring data shall be reduced to hourly average concentrations at least once every day using a minimum of four equally spaced data points over each one-hour period.
f. Permittee shall perform a preventative maintenance check of oxygen control analyzers and document quarterly.
g. The oxygen analyzers shall be quality-assured at least once per quarter using cylinder gas audits (CGAs) or Relative Accuracy Test Audit (RATA) in accordance with 40 CFR Part 60, Appendix F, Procedure 1.

h. Permittee will validate oxygen analyzers with zero and span gas at least weekly to maintain 1% accuracy.
i. All analyzers identified in this section III.A.1. shall achieve 95 percent on-stream time or greater.
j. Permittee shall utilize insulation materials where practicable to reduce heat loss.
k. The cracking furnaces shall not exceed the one-hour maximum firing rate of 640 MMBtu/hr (HHV).
l. The one-hour maximum firing rate shall be calculated daily to demonstrate compliance with the firing rate conditions in III.A.1.k. The heat input shall be determined using the appropriate procedure as found in 40 CFR Part 75 Appendix F Section 5.
m. Permittee shall continuously monitor and record the furnace gas exhaust temperature and flow rate hourly and limit the exhaust temperature to less than or equal to 408 ^{o}F on a 365-day rolling average basis. This stack temperature is for normal operations and does not include commissioning, startup, shutdown, and decoking operations.
n. The Permittee shall maintain a minimum overall thermal efficiency of 89.5% or greater on a 12-month rolling average basis, calculated monthly, for the furnaces (EF3419 and EF4419) excluding periods of start-up, shutdown, malfunction, and decoking.
o. The furnaces (EF3419 and EF4419) will be continuously monitored for exhaust temperature, input fuel temperature, and stack oxygen. Thermal efficiency for furnaces will be calculated monthly from these parameters using equation G-1 from American Petroleum Institute (API) methods 560 (4th ed.) Annex G.
p. The cracking furnace shall be decoked no more than 26 times per year per furnace. Records shall be maintained of all decokes including the date and duration in hours.
q. CO_2 emissions from the decoke pot shall be limited to 281 tpy for each furnace.
r. The Permittee shall keep records of each MSS event to include the date, time, duration, and estimated emissions.
s. Permittee shall calculate, on a monthly basis, the amount of CO_2 emitted from combustion during normal operations, and from decoking operations, in tons/yr using equation C-5 in 40 CFR Part 98 Subpart C, converted to short tons. Compliance shall be based on a 12-month rolling basis to be updated by the last day of the following month.
t. Permittee shall calculate the CH_4 and N_2O emissions on a 12-month rolling basis to be updated by the last day of the following month. Permittee shall determine compliance with the CH_4 and N_2O emissions limits contained in this section using the default CH_4 and N_2O emission factors contained in Table C-2 and equation C-8 of 40 CFR Part 98 and the measured actual heat input (HHV), converted to short tons.
u. Permittee shall calculate the CO_2e emissions on a 12-month rolling basis, based on the procedures and Global Warming Potentials (GWP) contained in Greenhouse Gas Regulations, 40 CFR Part 98, Subpart A, Table A-1, as published on October 30,

2009 (74 FR 56395). The record shall be updated by the last day of the following month.

2. Piping Fugitives (EPNs: EOP1FUGEXP and EOP2FUGEXP)

a. Permittee shall implement the TCEQ 28LAER leak detection and repair (LDAR) program for fugitive emissions of methane.
b. Permittee shall use high quality components and materials of construction that is compatible with the service in which they are employed.

B. Continuous Emissions Monitoring Systems (CEMS)

1. As an alternative to Special Condition III.A.1.s., Permittee may install a CO_2 CEMS and volumetric stack gas flow monitoring system with an automated data acquisition and handling system for measuring and recording CO_2 emissions discharged to the atmosphere, and use these values to show compliance with the annual emission limit in Table 1.
2. Permittee shall ensure that all required CO_2 monitoring systems/equipment are installed and all certification tests are completed on or before the earlier of 90 unit operating days or 180 calendar days after the date the unit commences operation.
3. Permittee shall ensure compliance with the specifications and test procedures for CO_2 emission monitoring systems at stationary sources, 40 CFR Part 75, or 40 CFR Part 60, Appendix B, Performance Specification numbers 1 through 9, as applicable.

IV. Recordkeeping and Reporting

The requirements of section IV of this permit apply only to the equipment authorized by this permit and listed in Table 1.

A. Records

1. In order to demonstrate compliance with the GHG emission limits in Table 1, the Permittee will monitor the following parameters and summarize the data on a calendar month basis.

    a. Operating hours for the listed air emission sources;
    b. Records of the fuel consumed by the fired emission sources;
    c. The fuel usage for all combustion sources, using continuous fuel flow monitors (a group of equipment can utilize a common fuel flow meter, as long as actual fuel usage is allocated to the individual equipment based upon actual operating hours and maximum firing rate);

d. Daily fuel sampling of plant fuel gas, or other frequencies as allowed by 40 CFR Part 98 Subpart C §98.34(b)(3); and
e. Records of decoking cycle times in hours and frequency.

2. Permittee shall maintain a file of all records, data, measurements, reports, and documents related to the operation of the facility, including, but not limited to, the following: all records or reports pertaining to significant maintenance performed on any system or device at the facility; duration of startup, shutdown; the initial startup period for the emission units; pollution control units; malfunctions; all records relating to performance tests, calibrations, checks, and monitoring of combustion equipment; duration of an inoperative monitoring device and emission units with the required corresponding emission data; and all other information required by this permit recorded in a permanent form suitable for inspection. The file shall be retained for not less than five years following the date of such measurements, maintenance, reports, and/or records.
3. Permittee shall maintain records and submit a written report of all excess emissions to EPA semi-annually except when more frequent reporting is specifically required by an applicable subpart, or the Administrator or authorized representative, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. The report is due on the 30th day following the end of each semi-annual period and shall include the following:

   a. Time intervals, data and magnitude of the excess emissions, the nature and cause (if known) of corrective actions taken and preventive measures adopted;
   b. Applicable time and date of each period during which the monitoring equipment was inoperative (monitoring down-time);
   c. A statement in the report of a negative declaration; that is; a statement when no excess emissions occurred or when the monitoring equipment has not been inoperative, repaired or adjusted;
   d. Any failure to conduct any required source testing, monitoring, or other compliance activities; and
   e. Any violation of limitations on operation.

4. Excess emissions shall be defined as any period in which the facility emissions exceed an emission limit set forth in this permit or a malfunction occurs causing such an emissions exceedance.
5. Excess emissions indicated by GHG emission source certification testing or compliance monitoring shall be considered violations of the applicable emission limit for the purpose of this permit.
6. Instruments and monitoring systems required by this PSD permit shall have a 95% on-stream time on an annual basis.

7. All records required by this PSD Permit shall be retained for not less than 5 years following the date of such measurements, maintenance, and reporting.
8. Continuously means individual measurements no less frequent than once every 15 minutes. Electronic data may be reduced to hourly averages for recordkeeping purposes.

V. Initial Performance Testing Requirements:

A. The Permittee shall perform stack sampling and other testing to establish the actual pattern and quantities of air contaminants being emitted into the atmosphere from the stacks of the Cracking Furnaces (EF3419 and EF4419) to determine the initial compliance with the CO_2 emission limits established in this permit. Sampling shall be conducted in accordance with 40 CFR § 60.8 and EPA Method 3a or 3b for the concentration of CO_2.

1. Multiply the CO_2 hourly average emission rate determined under maximum operating test conditions by 8,760 hours.
2. If the above calculated CO_2 emission total does not exceed the tons per year (TPY) specified on Table 1, no compliance strategy needs to be developed.
3. If the above calculated CO_2 emission total exceeds the tons per year (TPY) specified in Table 1, the facility shall:

    a. Document the potential to exceed in the test report; and
    b. Explain within the report how the facility will assure compliance with the CO_2 emission limit listed in Table 1.

B. No later than 180 days after initial startup, or restart after modification of the facility, performance tests(s) shall be conducted and a written report of the performance testing results furnished to the EPA within 60 days after the testing is completed. During subsequent operations, stack sampling shall be performed within 120 days if current production rates exceed the production rate during stack testing by 10 percent or greater, additional sampling may be required by EPA.

C. Permittee shall submit a performance test protocol to afford the EPA the opportunity to have an observer present and/or to attend a pre-test meeting. The performance test shall be conducted in accordance with the submitted protocol, and any changes required by EPA. If there is a delay in the original test date, the facility must provide at least 7 days prior notice of the rescheduled date of the performance test unless EPA approves an earlier rescheduled date due to unforeseen events, such as delays that are caused by weather.

D. Performance tests shall be conducted under such conditions to ensure representative performance of the affected facility. Permittee shall make available to the EPA such records as may be necessary to determine the conditions of the performance tests.

E. Permittee shall provide, or cause to be provided, performance testing facilities as follows:

1. Sampling ports adequate for test methods applicable to this facility,
2. Safe sampling platform(s),
3. Safe access to sampling platform(s), and
4. Utilities for sampling and testing equipment.

F. Unless otherwise specified, each performance test shall consist of three separate runs using the applicable test method. For purposes of determining compliance with an applicable test method, the arithmetic mean of the results of the three runs shall apply.

G. Emissions testing, as outlined above, shall be performed every five years, plus or minus 6 months, after the previous performance test was performed, or within 180 days after the issuance of a permit renewal, whichever comes later, to verify continued performance at the permitted emission limits.

VI. Agency Notifications

Permittee shall submit GHG permit applications, permit amendments, and other applicable permit information to:

Multi Media Planning and Permitting Division
EPA Region 6
1445 Ross Avenue (6 PD-R)
Dallas, TX 75202
Email: Group R6AirPermits@EPA.gov

Permittee shall submit a copy of all compliance and enforcement correspondence as required by this Approval to Construct to:

Compliance Assurance and Enforcement Division
EPA Region 6
1445 Ross Avenue (6EN)
Dallas, TX 75202

PREVENTION OF SIGNIFICANT DETERIORATION PERMIT FOR GREENHOUSE GAS EMISSIONS ISSUED PURSUANT TO THE REQUIREMENTS AT 40 CFR § 52.21

U.S. ENVIRONMENTAL PROTECTION AGENCY, REGION 6

PSD PERMIT NUMBER: PSD-TX-1280-GHG

PERMITTEE: Equistar Chemicals, LP
P.O. Box 777
Channelview, TX 77530

FACILITY NAME: Equistar Chemicals, LP
Channelview Complex
Channelview North Plant

FACILITY LOCATION: 8280 Sheldon Road, Building 1
Channelview, TX 77530

Pursuant to the provisions of the Clean Air Act (CAA), Subchapter I, Part C (42 U.S.C. Section 7470, *et. Seq.*), and the Code of Federal Regulations (CFR) Title 40, Section 52.21, and the Federal Implementation Plan at 40 CFR § 52.2305 (effective May 1, 2011 and published at 76 FR 25178), the U.S. Environmental Protection Agency, Region 6 is issuing a *Prevention of Significant Deterioration* (PSD) permit to Equistar Chemicals, LP for Greenhouse Gas (GHG) emissions. The Permit applies to the restart of the methanol unit (MeOH Restart Project) at the existing Channelview North Plant located in Channelview, Texas.

Equistar is authorized to modify and construct equipment at the Channelview Complex, Channelview North Plant, as part of the MeOH Restart Project as described herein, in accordance with the permit application (and plans submitted with the permit application), the federal PSD regulations at 40 CFR § 52.21, and other terms and conditions set forth in this PSD permit in conjunction with the corresponding Texas Commission on Environmental Quality (TCEQ) PSD permit No. PSD-TX-1280 and Nonattainment New Source Review permit No. N144. Failure to comply with any condition or terms set forth in this PSD Permit may result in enforcement action pursuant to Section 113 of the Clean Air Act (CAA). This PSD Permit does not relieve Equistar of the responsibility to comply with any other applicable provisions of the CAA (including applicable implementing regulations in 40 CFR Parts 51, 52, 60, 61, 72 through 75, and 98) or other federal and state requirements (including the state PSD program that remains under approval at 40 CFR § 52.2303).

In accordance with 40 CFR §124.15(b)(3), this PSD Permit becomes effective immediately upon issuance of this final decision.

David F. Garcia, Acting Director
Multimedia Planning and Permitting Division

2/14/13
Date

Equistar Chemical Company LP (PSD-TX-748-GHG)
Prevention of Significant Deterioration Permit
For Greenhouse Gas Emissions
Final Permit Conditions

PROJECT DESCRIPTION

With this permit application, Equistar intends to restart the methanol unit (MeOH Restart Project) at the Channelview North Plant in Channelview, Texas. As part of the MeOH Restart Project, Equistar is proposing to transfer the existing equipment from Highly Purified Isobutylene (HPIB) production back to Methanol (MeOH) production. The GHG PSD permit, will allow Equistar to restart the methanol unit at the existing facility at the Channelview Complex located in Channelview, Harris County, Texas. The rated capacity of the Channelview MeOH process unit is approximately 273 million gallons of high purity methanol per year using light hydrocarbon (typically natural gas) as a feedstock. The unit also has the capacity of injecting carbon dioxide as a supplemental feed.

The feedstock is compressed, preheated, and pretreated to remove sulfur and chlorine compounds. The treated feed is then mixed with steam before being sent to the reformer. The reformer consists of a large number of catalyst-filled tubes suspended in the radiant section of a process heater. Process stream containing light hydrocarbons and steam flows into the tubes where it is heated to reaction temperature to produce the synthesis gas.

Steam required to operate the unit is produced from waste heat in the reformer. The synthesis gas is cooled, compressed, reheated, and sent to the conversion reactor. The converter effluent is cooled with the crude methanol, separated as a liquid phase, and sent to product purification. The off-gas is recycled to the methanol converter. The purge gas is used as fuel in the reformer fuel gas.

Light ends are removed in the topping column from the crude methanol and used as fuel in the reformer. The topped product (methanol) is sent to a refining column, where the high purity methanol is removed as the overhead stream, cooled and sent to storage tanks and the bottom stream consisting of water with a trace of hydrocarbons is sent to on-site wastewater treatment. A refining column side stream (fusel oil) containing water and mixed alcohol is returned to the reformer as feed.

EQUIPMENT LIST

The following devices are subject to this GHG PSD permit.

FIN	EPN	Description
HTF7001	EHTF7001	Reformer Furnace (Combustion Unit). The furnace has a maximum design heat input rate of 1,615MMbtu/hr, and will be equipped with a Selective Catalytic Reduction (SCR) system and low NOx burners.
MEOHFLARE	EMEOHFLARE	Methanol (MeOH) Flare (Combustion Unit).
EMERFLARE	EEMERFLARE	Methanol Emergency Flare (Combustion Unit)
FUGMEOH	EFUGMEOH	Process Fugitives

I. GENERAL PERMIT CONDITIONS

A. PERMIT EXPIRATION

As provided in 40 CFR §52.21(r), this PSD Permit shall become invalid if construction:

1. is not commenced (as defined in 40 CFR §52.21(b)(9)) within 18 months after the approval takes effect; or

2. is discontinued for a period of 18 months or more; or

3. is not completed within a reasonable time.

Pursuant to 40 CFR §52.21(r), EPA may extend the 18-month period upon a written satisfactory showing that an extension is justified.

B. PERMIT NOTIFICATION REQUIREMENTS

Permittee shall notify EPA Region 6 in writing or by electronic mail of the:

1. date construction is commenced, postmarked within 30 days of such date;

2. actual date of initial startup, as defined in 40 CFR §60.2, postmarked within 15 days of such date; and

3. date upon which initial performance tests will commence, in accordance with the provisions of Section V, postmarked not less than 30 days prior to such date. Notification may be provided with the submittal of the performance test protocol required pursuant to Condition V.B.

C. FACILITY OPERATION

At all times, including periods of startup, shutdown, and maintenance, Permittee shall, to the extent practicable, maintain and operate the facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the EPA, which may include, but is not limited to, monitoring results, review of operating maintenance procedures and inspection of the facility.

D. MALFUNCTION REPORTING

1. Permittee shall notify EPA by mail within 48 hours following the discovery of any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner, which results in an increase in GHG emissions above the allowable emission limits stated in Section II and III of this permit.

2. Within 10 days of the restoration of normal operations after any failure described in I.D.1., Permittee shall provide a written supplement to the initial notification that includes a description of the malfunctioning equipment or abnormal operation, the date of the initial malfunction, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed in Section II and III, and the methods utilized to mitigate emissions and restore normal operations.

3. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violation of this permit or any law or regulation such malfunction may cause.

E. RIGHT OF ENTRY

EPA authorized representatives, upon the presentation of credentials, shall be permitted:

1. to enter the premises where the facility is located or where any records are required to be kept under the terms and conditions of this PSD Permit;

2. during normal business hours, to have access to and to copy any records required to be kept under the terms and conditions of this PSD Permit;

3. to inspect any equipment, operation, or method subject to requirements in this PSD Permit; and,

4. to sample materials and emissions from the source(s).

F. TRANSFER OF OWNERSHIP

In the event of any changes in control or ownership of the facilities to be constructed, this PSD Permit shall be binding on all subsequent owners and operators. Permittee shall notify the succeeding owner and operator of the existence of the PSD Permit and its conditions by letter; a copy of the letter shall be forwarded to EPA Region 6 within thirty days of the letter signature.

G. SEVERABILITY

The provisions of this PSD Permit are severable, and, if any provision of the PSD Permit is held invalid, the remainder of this PSD Permit shall not be affected.

H. ADHERENCE TO APPLICATION AND COMPLIANCE WITH OTHER ENVIRONMENTAL LAWS

Permittee shall construct this project in compliance with this PSD Permit, the application on which this permit is based, the TCEQ PSD Permit PSD-TX-1280, issued on October 23, 2012 and all other applicable federal, state, and local air quality regulations. This PSD permit does not release the Permittee from any liability for compliance with other applicable federal, state and local environmental laws and regulations, including the Clean Air Act.

I. ACRONYMS AND ABBREVIATIONS

AVO	Auditory, Visual, and Olfactory
BACT	Best Available Control Technology
C_3+	Hydrocarbon with Three or More Carbon Atoms
CAA	Clean Air Act
CC	Carbon Content
CCS	Carbon Capture and Sequestration
CEMS	Continuous Emissions Monitoring System
CFR	Code of Federal Regulations
CH_4	Methane
CO_2	Carbon Dioxide
CO_2e	Carbon Dioxide Equivalent
dscf	Dry Standard Cubic Foot
EF	Emission Factor
EPN	Emission Point Number
FIN	Facility Identification Number
FR	Federal Register
GCV	Gross Calorific Value
GHG	Greenhouse Gas
gr	Grains
GWP	Global Warming Potential
HGB	Houston, Galveston, Brazoria Area
HHV	High Heating Value
HPIB	Highly Purified Isobutylene
hr	Hour
HRSG	Heat Recovery Steam Generating
LAER	Lowest Achievable Emission Rate
lb	Pound
LDAR	Leak Detection and Repair
MeOH	Methanol
MMBtu	Million British Thermal Units
MSS	Maintenance, Start-up and Shutdown
NNSR	Nonattainment New Source Review
N_2O	Nitrous Oxides
NSPS	New Source Performance Standards
PSD	Prevention of Significant Deterioration
QA/QC	Quality Assurance and/or Quality Control
SCFH	Standard Cubic Feet per Hour
SCR	Selective Catalytic Reduction
TAC	Texas Administrative Code
TCEQ	Texas Commission on Environmental Quality
TOC	Total Organic Carbon
TPY	Tons per Year
USC	United States Code
VDU	Vapor Destruction Unit
VHP	Very High Pressure
VOC	Volatile Organic Compound

II. Annual Emission Limits

Annual emissions, in tons per year (TPY) on a 12-month, rolling average, shall not exceed the following:

Table 1. Annual Emission Limits

FIN	EPN	Description	GHG Mass Basis		TPY CO_2e[1,2]
				TPY[1]	
HTF7001	EHTF7001	Reformer Furnace	CO_2	826,600	827,556
			CH_4	16	
			N_2O	2	
MEOHFLARE EMERFLARE	EMEOHFLARE EEMERFLARE	Methanol Flare and Methanol Emergency Flare[3]	CO_2	3,936	3,936
			CH_4	Negligible	
			N_2O	Negligible	
FUGMEOH	EFUGMEOH	Fugitive Process Emissions	CO_2	Not Applicable	Not Applicable
			CH_4	Not Applicable	
Totals[4]			**CO_2**	**830,614**	**CO_2e 831,675**
			CH_4	**21**	
			N_2O	**2**	

1. The TPY emission limits specified in this table are not to be exceeded for these EPNs and include emissions from the facility during all operations and include MSS activities.
2. Global Warming Potentials (GWP): $CH_4 = 21$, $N_2O = 310$
3. The methanol unit waste gas flow may be routed to either flare, or to both flares.
4. Total emissions include the PTE of 5 TPY CH_4 and 39 TPY CO_2 for fugitive emissions, and 39 TPY CO_2 from the existing East Plant Flare (17E01) for a total of 183 TPY CO_2e. Totals are given for informational purposes only and do not constitute emission limits.

III. BACT Limits

BACT requirements for all new and modified units are identified in the table below.

Table 2. BACT Limits

FIN	EPN	Description	BACT Requirements
HTF7001	EHTF7001	Reformer Furnace	Furnace Gas Exhaust Temperature ≤ 320 °F. Maintain Thermal Efficiency of 90%. See permit condition IV.A.1.o.through q.
MEOHFLARE	EMEOHFLARE	Methanol Flare	Good Combustion Practices. See permit condition IV.A.2.
EMERFLARE	EEMERFLARE	Methanol Emergency Flare	Good Combustion Practices. See permit condition IV.A.2.
FUGMEOH	EFUGMEOH	Fugitive Process Emissions	Implementation of LDAR program. See permit condition IV.A.3.

IV. SPECIAL PERMIT CONDITIONS

A. Emission Unit Work Practice Standards, Operational Requirements, and Monitoring

1. Reformer Furnace (EHTF7001)

a. The reformer furnace shall combust pipeline quality natural gas and/or plant produced high hydrogen fuel gas (fuel gas).

b. All fuel combustion units identified in this permit shall have fuel metering for each fuel, and Permittee shall:

   i. Measure and record the fuel flow rate using an operational non-resettable elapsed flow meter or by recording the flow rate data in an electronic format with individual flow measurements being taken no less frequently than once every 15 minutes. Electronic data may be reduced to hourly averages for recordkeeping purposes.

   ii. Record the total fuel combusted for each fuel monthly.

   iii. Analyze fuel gas composition at least hourly.

   iv. The fuel gross calorific value (GCV) [high heat value (HHV)], carbon content and, if applicable, molecular weight, shall be determined, at a minimum, monthly by the procedures contained in 40 CFR Part 98.34(b)(3). Records of the fuel GCV shall be maintained for a minimum period of five years. Upon request, Permittee shall provide a sample and/or analysis of the fuel that is fired in any unit covered by this permit at the time of the request, or shall allow a sample to be taken by EPA for analysis.

   v. Pipeline Quality Natural Gas shall be exempt from this requirement (III.A.1.iii.) provided Permittee receives and maintains quarterly records of the vendor's analysis, and the data is of sufficient quality to yield further analysis as required above.

   vi. The fuel flow of the fuel fired in the reformer furnace (EHTF7001) shall be continuously monitored and recorded at least once every 15 minutes.

c. Permittee shall calibrate and perform preventative maintenance check of the fuel gas flow meters and document biannually.

d. Permittee shall install, operate, and maintain an O_2 analyzer on the furnace flue gas at a location downstream of the radiant sections of the furnace.

e. The oxygen analyzer shall continuously monitor and record the excess oxygen concentration in the combustion gases. The monitoring data shall be reduced to hourly average concentrations at least once every day using a minimum of four equally spaced data points over each one-hour period.

f. Permittee shall perform preventative maintenance check of the oxygen analyzer and document quarterly.

g. The oxygen analyzer shall be quality-assured at least once per quarter using cylinder gas audits (CGAs) in accordance with 40 CFR Part 60, Appendix F, Procedure 1, § 5.1.2, with the following exception: a relative accuracy test audit is not required once every four quarters (i.e., two successive semiannual CGAs may be conducted).

h. The Permittee will validate the oxygen analyzer with zero and span gas at least

weekly to maintain 1% accuracy.

i. Excess oxygen shall be controlled to less than 5% to ensure efficiency.
j. All analyzers identified in this section IV.A.1. shall achieve 95% on-stream time or greater.
k. Permittee shall utilize insulation materials where feasible to reduce heat loss.
l. The reformer furnace shall not exceed the one-hour maximum firing rate of 1,615 MMBtu/hr.
m. The one-hour maximum firing rates shall be determined daily to demonstrate compliance with the firing rate condition in IV.A.1.l.
n. Permittee shall continuously monitor and record the furnace gas exhaust temperature hourly and limit the temperature to less than or equal to 320 °F on a 365-day rolling average basis. This stack temperature is for normal operations and does not include commissioning, startup, and shutdown.
o. The Permittee shall maintain a minimum overall thermal efficiency of 90% on a 12-month rolling average basis, calculated monthly, for the furnace (EHTF7001) excluding periods of start-up, shutdown, and malfunction.
p. The furnace will be continuously monitored for exhaust temperature, input fuel temperature, and stack oxygen. Thermal efficiency for the furnace will be calculated monthly from these parameters using equation G-1 from American Petroleum Institute (API) methods 560 (4th ed.) Annex G.
q. Permittee shall calculate, on a monthly basis, the amount of CO_2 emitted from combustion in tons/yr using equation C-5 in 40 CFR Part 98 Subpart C, converted to short tons. Compliance shall be based on a 12-month rolling basis to be updated by the last day of the following month.
r. Permittee shall calculate the CH_4 and N_2O emissions on a 12-month rolling basis to be updated by the last day of the following month. Permittee shall determine compliance with the CH_4 and N_2O emissions limits contained in this section using the default CH_4 and N_2O emission factors contained in Table C-2 and equation C-8 of 40 CFR Part 98 and the measured HHV, converted to short tons.
s. Permittee shall calculate the CO_2e emissions on a 12-month rolling basis, based on the procedures and Global Warming Potentials (GWP) contained in Greenhouse Gas Regulations, 40 CFR Part 98, Subpart A, Table A-1, as published on October 30, 2009 (74 FR 56395). The record shall be updated by the last day of the following month.

2. Flares (EMEOHFLARE and EEMERFLARE)

a. The flares shall be designed to achieve a minimum destruction and removal efficiency (DRE) of 99% based on flowrate and gas composition measurements.
b. The flares shall only combust pipeline natural gas in the pilots as a continuous stream.
c. The flares shall be designed and operated in accordance with 40 CFR 60.18 including specifications of minimum heating value of the waste gas, maximum tip velocity, and pilot flame monitoring. An infrared monitor is considered equivalent to a thermocouple for pilot flame monitoring purposes.
d. Flare (EMEOHFLARE) shall be situated to receive waste gases from the methanol unit.
    (i) The flare is steam assisted.

(ii) The only gases flowing continuously to the flare are pilot gas and sweep gas (natural gas).

(iii) The waste gas from MSS activities from the Methanol Unit is mixed with sweep gas (natural gas) upstream of a mass flow meter located in the flare header.

(iv) Flare header flow meter will measure flow at least once each 15 minutes. The flow meter shall be calibrated at least biannually.

(v) The flare shall be equipped with a gas composition analyzer. The analyzer shall measure the gas composition at least once per hour and be calibrated monthly.

(vi) Permittee must record the time, date, HHV in MMBtu/hr and duration of each MSS event. The records must include hourly CH_4 emission levels as measured by the in-line gas analyzer (Gas chromatograph or equivalent with volumetric stack gas flowrate) and the calculations based on the actual heat input for the CO_2, N_2O, and CH_4 emissions during each MSS event. These records must be kept for five years following the date of each event.

(vii) CO_2 emissions are calculated using equation Y-1 found in 40 CFR Part 98 Subpart Y, §98.253(b)(1)(ii)(A). CH_4 and N_2O emissions are calculated using equations Y-4 and Y-5 as found in 40 CFR Part 98 Subpart Y.

(viii) Compliance with the annual emission limit shall be determined on a 12-month rolling basis.

e. Flare (EEMERFLARE) is for high waste gas flow rates from the methanol unit. It may share the load with the flare (EMEOHFLARE).

(i) The flare is non-assisted.

(ii) The waste gas from MSS activities from the Methanol Unit is mixed with sweep gas (natural gas) upstream of a mass flow meter located in the flare header.

(iii) Flare header flow meter will measure flow at least once each 15 minutes. The flow meter shall be calibrated at least biannually.

(iv) The flare shall be equipped with a gas composition analyzer. The analyzer shall measure the gas composition at least once per hour and be calibrated monthly.

(v) Permittee must record the time, date, HHV in MMBtu/hr and duration of each MSS event. The records must include hourly CH_4 emission levels as measured by the in-line gas analyzer (Gas chromatograph or equivalent with volumetric stack gas flowrate) and the calculations based on the actual heat input for the CO_2, N_2O, and CH_4 emissions during each MSS event. These records must be kept for five years following the date of each event.

(vi) CO_2 emissions are calculated using equation Y-1 found in 40 CFR Part 98 Subpart Y, §98.253(b)(1)(ii)(A). CH_4 and N_2O emissions are calculated using equations Y-4 and Y-5 as found in 40 CFR Part 98 Subpart Y.

(vii) Compliance with the annual emission limit shall be determined on a 12-month rolling basis.

3. **Process Fugitives (EFUGMEOH)**

   a. The Permittee shall implement the TCEQ 28LAER leak detection and repair (LDAR) program for fugitive emissions of methane.
   b. The Permittee shall implement an as-observed AVO program to monitor for fugitive emissions between instrumented monitoring as required in IV.A.3.a above.
   c. The Permittee shall use high quality components and materials of construction that is compatible with the service in which they are employed.

B. Continuous Emissions Monitoring Systems (CEMS)

1. As an alternative to Special Conditions IV.A.1. p. through IV.A.1.r. Permittee may install a CO_2 CEMS and volumetric stack gas flow monitoring system with an automated data acquisition and handling system for measuring and recording CO_2 emissions discharged to the atmosphere, and use these values to show compliance with the annual emission limit in Table 1.
2. Permittee shall ensure that all required CO_2 monitoring system/equipment are installed and all certification tests are completed on or before the earlier of 90 unit operating days or 180 calendar days after the date the unit commences operation.
3. Permittee shall ensure compliance with the specifications and test procedures for CO_2 emission monitoring system at stationary sources, 40 CFR Part 75, or 40 CFR Part 60, Appendix B, Performance Specification numbers 1 through 9, as applicable.

V. Recordkeeping and Reporting

A. Records

1. In order to demonstrate compliance with the GHG emission limits in Table 1, the Permittee will monitor the following parameters and summarize the data on a calendar month basis.

    a. Operating hours for all air emission sources;
    b. Records of the fuel consumed by each source
    c. The fuel usage for all combustion sources, using continuous fuel flow monitors (a group of equipment can utilize a common fuel flow meter, as long as actual fuel usage is allocated to the individual equipment based upon actual operating hours and maximum firing rate); and
    d. Semi-annual fuel sampling for natural gas, daily fuel sampling of plant fuel gas, or other frequencies as allowed by 40 CFR Part 98 Subpart C §98.34(b)(3).

2. Permittee shall maintain a file of all records, data, measurements, reports, and documents related to the operation of the facility, including, but not limited to, the following: all records or reports pertaining to significant maintenance performed on any system or device at the facility; duration of startup, shutdown; the initial startup period for the emission units; pollution control units; malfunctions; all records relating to performance tests, calibrations, checks, and monitoring of combustion equipment; duration of an inoperative monitoring device and emission units with the required corresponding emission data; and all other information required by this permit recorded in a permanent form suitable for inspection. The file must be retained for not less than five years following the date of such measurements, maintenance, reports, and/or records.
3. Permittee shall maintain records and submit a written report of all excess emissions to EPA semi-annually, except when: more frequent reporting is specifically required by an applicable subpart; or the Administrator or authorized representative, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. The report is due on the 30th day following the end of each semi-annual period and shall include the following:

    a. Time intervals, data and magnitude of the excess emissions, the nature and cause (if known), corrective actions taken and preventive measures adopted;
    b. Applicable time and date of each period during which the monitoring equipment was inoperative (monitoring down-time);
    c. A statement in the report of a negative declaration; that is; a statement when no excess emissions occurred or when the monitoring equipment has not been inoperative, repaired or adjusted;
    d. Any failure to conduct any required source testing, monitoring, or other compliance activities; and
    e. Any violation of limitations on operation.

4. Excess emissions shall be defined as any period in which the facility emissions exceed a maximum emission limit set forth in this permit, or a malfunction occurs causing an

emissions exceedance.

5. Excess emissions indicated by GHG emission source certification testing or compliance monitoring shall be considered violations of the applicable emission limit for the purpose of this permit.
6. Instruments and monitoring systems required by this PSD permit shall have a 95% on-stream time on an annual basis.
7. All records required by this PSD Permit shall be retained for not less than 5 years following the date of such measurements, maintenance, and reporting.
8. Continuously means individual measurement no less frequent than once every 15 minutes. Electronic data may be reduced to hourly averages for recordkeeping purposes.

VI. Initial Performance Testing Requirements:

A. The Permittee shall perform stack sampling and other testing to establish the actual pattern and quantities of air contaminants being emitted into the atmosphere from the stack of the Reformer Furnace (EHTF7001) to determine the initial compliance with the CO_2 emission limits established in this permit. Sampling shall be conducted in accordance with 40 CFR § 60.8 and EPA Method 3a or 3b for the concentration of CO_2.

1. Multiply the CO_2 hourly average emission rate determined under maximum operating test conditions by 8,760 hours.
2. If the above calculated CO_2 emission total does not exceed the tons per year (TPY) specified on Table 1, no compliance strategy needs to be developed.
3. If the above calculated CO_2 emission total exceeds the tons per year (TPY) specified in Table 1, the facility shall:

    a. Document the potential to exceed in the test report; and
    b. Explain within the report how the facility will assure compliance with the CO_2 emission limit listed in Table 1.

B. No later than 180 days after initial start-up, or restart after modification of the facility, performance test(s) must be conducted and a written report of the performance testing results furnished to the EPA with 60 days after the testing is completed. During subsequent operations, stack sampling shall be performed within 120 days if current production rates exceed the production rate during stack testing by 10 percent or greater, additional sampling may be required by TCEQ or EPA.

C. Permittee shall submit a performance test protocol to EPA no later than 30 days prior to the test to allow review of the test plan and to arrange for an observer to be present at the test. The performance test shall be conducted in accordance with the submitted protocol, and any changes required by EPA.

D. Performance tests must be conducted under such conditions to ensure representative performance of the affected facility. The owner or operator must make available to the EPA such records as may be necessary to determine the conditions of the performance tests.

E. The owner or operator must provide the EPA at least 30 days' prior notice of any performance test, except as specified under other subparts, to afford the EPA the opportunity to have an observer present and/or to attend a pre-test meeting. If there is a delay in the

original test date, the facility must provide at least 7 days prior notice of the rescheduled date of the performance test.

F. The owner or operator shall provide, or cause to be provided, performance testing facilities as follows:

1. Sampling ports adequate for test methods applicable to this facility,
2. Safe sampling platform(s),
3. Safe access to sampling platform(s), and
4. Utilities for sampling and testing equipment.

G. Unless otherwise specified, each performance test shall consist of three separate runs using the applicable test method. Each run shall be conducted for the time and under the conditions specified in the applicable standard. For purposes of determining compliance with an applicable standard, the arithmetic mean of the results of the three runs shall apply.

H. Emissions testing, as outlined above, shall be performed every five years, plus or minus 6 months, of when the previous performance test was performed, or within 180 days after the issuance of a permit renewal, whichever comes later to verify continued performance at permitted emission limits.

VII. Agency Notifications

Permittee shall submit GHG permit applications, permit amendments, and other applicable permit information to:

Multi Media Planning and Permitting Division
EPA Region 6
1445 Ross Avenue (6 PD-R)
Dallas, TX 75202
Email: Group R6AirPermits@EPA.gov

Permittee shall submit a copy of all compliance and enforcement correspondence as required by this Approval to Construct to:

Compliance and Enforcement Division
EPA Region 6
1445 Ross Avenue (6EN)
Dallas, TX 75202