

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
TPC Group LLC

AUTHORIZING THE OPERATION OF
Port Neches Operations
PNO-C4 Plant
Other Chemical and Allied Products Merchant Wholesalers

LOCATED AT
Jefferson County, Texas
Latitude 29° 58' 43" Longitude 93° 56' 52"
Regulated Entity Number: RN104964267

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: O1327 Issuance Date: _____

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions:	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements	10
New Source Review Authorization Requirements	10
Compliance Requirements.....	11
Risk Management Plan	13
Protection of Stratospheric Ozone	13
Permit Location	13
Permit Shield (30 TAC § 122.148)	13
Attachments	15
Applicable Requirements Summary.....	16
Additional Monitoring Requirements	59
Permit Shield.....	64
New Source Review Authorization References	70
Schedules	79
Appendix A.....	86
Acronym List	87

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
 - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.

- E. Emission units subject to 40 CFR Part 63, Subpart Y as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, §113.300 which incorporates the 40 CFR Part 63 Subpart by reference.
 - F. Emission units subject to 40 CFR Part 63, Subpart EEEE as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, §113.880 which incorporates the 40 CFR Part 63 Subpart by reference.
 - G. Emission units subject to 40 CFR Part 63, Subpart ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, §113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.
 - H. For the purpose of generating discrete emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 4 (Discrete Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
 - (i) Title 30 TAC § 101.372 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.373 (relating to Discrete Emission Reduction Credit Generation and Certification)
 - (iii) Title 30 TAC § 101.374 (relating to Mobile Discrete Emission Reduction Credit Generation and Certification)
 - (iv) Title 30 TAC § 101.378 (relating to Discrete Emission Credit Banking and Trading)
 - (v) The terms and conditions by which the emission limits are established to generate the discrete reduction credit are applicable requirements of this permit
2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
- A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)

J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)

3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:

A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:

- (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(1)(E)
- (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)

(iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the "Applicable Requirements Summary" attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:

- (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
- (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not

more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(5) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:

- (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.
- (2) Records of all observations shall be maintained.
- (3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (4) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

C. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)

- (ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)
- (iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
 - (1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.
 - (3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
 - (4) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- D. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
 - E. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).
 - F. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
 - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)
 - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
4. For storage vessels maintaining working pressure as specified in 30 TAC Chapter 115, Subchapter B, Division 1: "Storage of Volatile Organic Compounds," the permit holder shall comply with the requirements of 30 TAC § 115.112(a)(1).
 5. Permit holder shall comply with the following 30 TAC Chapter 115, Subchapter C requirements:
 - A. When filling stationary gasoline storage vessels (Stage I) for motor vehicle fuel dispensing facilities specified in 30 TAC Chapter 115, Subchapter C, the permit holder shall comply with the following requirements:
 - (i) Title 30 TAC § 115.221 (relating to Emission Specifications)
 - (ii) Title 30 TAC § 115.222 (relating to Control Requirements)
 - (iii) Title 30 TAC § 115.223 (relating to Alternate Control Requirements)
 - (iv) Title 30 TAC § 115.224 (relating to Inspection Requirements)
 - (v) Title 30 TAC § 115.225 (relating to Testing Requirements)
 - (vi) Title 30 TAC § 115.226 (relating to Recordkeeping Requirements)
 6. The permit holder shall comply with the following 30 TAC Chapter 115, Subchapter F requirements (relating to Cutback Asphalt Requirements):
 - A. Title 30 TAC § 115.512(1) (relating to Control Requirements)
 - B. Title 30 TAC § 115.512(2) (relating to Control Requirements)
 - C. Title 30 TAC § 115.515 (relating to Testing Requirements)
 7. The permit holder shall comply with the following requirements of 30 TAC Chapter 115, Subchapter F, Division 3, Degassing of Storage Tanks, Transport Vessels and Marine Vessels:

- A. For degassing of stationary VOC storage tanks, the permit holder shall comply with the following requirements:
- (i) Title 30 TAC § 115.541(a) - (c) (relating to Emission Specifications)
 - (ii) Title 30 TAC § 115.541(f) (relating to Emission Specifications), for floating roof storage tanks
 - (iii) Title 30 TAC § 115.542(a) and (a)(1), (a)(2), (a)(3) or (a)(4) (relating to Control Requirements). Where the requirements of 30 TAC Chapter 115, Subchapter F contain multiple compliance options, the permit holder shall keep records of when each compliance option was used.
 - (iv) Title 30 TAC § 115.542(b) - (d), (relating to Control Requirements)
 - (v) Title 30 TAC § 115.543 (relating to Alternate Control Requirements)
 - (vi) Title 30 TAC § 115.544(a)(1) and (a)(2) (relating to Inspection, Monitoring, and Testing Requirements), for inspections
 - (vii) Title 30 TAC § 115.544(b) (relating to Inspection, Monitoring, and Testing Requirements), for monitoring
 - (viii) Title 30 TAC § 115.544(b)(1) and (b)(2) (relating to Inspection, Monitoring, and Testing Requirements), for monitoring of control devices
 - (ix) Title 30 TAC § 115.544(b)(2)(A) - (J) (relating to Inspection, Monitoring, and Testing Requirements), for monitoring (as appropriate to the control device)
 - (x) Title 30 TAC § 115.544(b)(3), (b)(4) and (b)(6) (relating to Inspection, Monitoring, and Testing Requirements), for VOC concentration or lower explosive limit threshold monitoring
 - (xi) Title 30 TAC § 115.544(c), and (c)(1) - (c)(3) (relating to Inspection, Monitoring, and Testing Requirements), for testing of control devices used to comply with 30 TAC § 115.542(a)(1)
 - (xii) Title 30 TAC § 115.545(1) - (7), (9) - (11) and (13) (relating to Approved Test Methods)
 - (xiii) Title 30 TAC § 115.546(a), (a)(1) and (a)(3) (relating to Recordkeeping and Notification Requirements), for recordkeeping
 - (xiv) Title 30 TAC § 115.546(a)(2) and (a)(2)(A) - (J) (relating to Recordkeeping and Notification Requirements), for recordkeeping (as appropriate to the control device)
 - (xv) Title 30 TAC § 115.546(a)(4) (relating to Recordkeeping and Notification Requirements), for recordkeeping of testing of control devices used to comply with 30 TAC § 115.542(a)(1)
 - (xvi) Title 30 TAC § 115.547(4) (relating to Exemptions)
- B. For the degassing of all transport vessels with a nominal capacity of 8,000 gallons or more, the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 115.541(a) - (c) and (d) (relating to Emission Specifications)
- (ii) Title 30 TAC § 115.542(a) and (a)(1), (a)(2), (a)(3) or (a)(4) (relating to Control Requirements). Where the requirements of 30 TAC Chapter 115, Subchapter F contain multiple compliance options, the permit holder shall keep records of when each compliance option was used.
- (iii) Title 30 TAC § 115.542(b), (c) and (e) (relating to Control Requirements)
- (iv) Title 30 TAC § 115.543 (relating to Alternate Control Requirements)
- (v) Title 30 TAC § 115.544(a)(1) and (a)(2) (relating to Inspection, Monitoring, and Testing Requirements), for inspections
- (vi) Title 30 TAC § 115.544(b) (relating to Inspection, Monitoring, and Testing Requirements), for monitoring
- (vii) Title 30 TAC § 115.544(b)(1) and (b)(2) (relating to Inspection, Monitoring, and Testing Requirements), for monitoring of control devices
- (viii) Title 30 TAC § 115.544(b)(2)(A) - (J) (relating to Inspection, Monitoring, and Testing Requirements), for monitoring (as appropriate to the control device)
- (ix) Title 30 TAC § 115.544(b)(3), (b)(4) and (b)(6) (relating to Inspection, Monitoring, and Testing Requirements), for VOC concentration or lower explosive limit threshold monitoring
- (x) Title 30 TAC § 115.544(c), and (c)(1) - (c)(3) (relating to Inspection, Monitoring, and Testing Requirements), for testing of control devices used to comply with 30 TAC § 115.542(a)(1)
- (xi) Title 30 TAC § 115.545(1) - (11) and (13) (relating to Approved Test Methods)
- (xii) Title 30 TAC § 115.546(a), (a)(1) and (a)(3) (relating to Recordkeeping and Notification Requirements), for recordkeeping
- (xiii) Title 30 TAC § 115.546(a)(2) and (a)(2)(A) - (J) (relating to Recordkeeping and Notification Requirements), for recordkeeping (as appropriate to the control device)
- (xiv) Title 30 TAC § 115.546(a)(4) (relating to Recordkeeping and Notification Requirements), for recordkeeping of testing of control devices used to comply with 30 TAC § 115.542(a)(1)

8. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:

- A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
- B. Title 40 CFR § 60.8 (relating to Performance Tests)
- C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
- D. Title 40 CFR § 60.12 (relating to Circumvention)

- E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
 - F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
9. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
10. For the operations pertaining to the loading and unloading of marine tank vessels specified in 40 CFR Part 63, Subpart Y, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.300 incorporated by reference):
- A. Title 40 CFR § 63.560(c) (relating to Designation of Affected Source), for applicability of the General Provisions of Subpart A
 - B. Title 40 CFR § 63.563(a)(4) (relating to Compliance and Performance Testing), for vapor tightness requirements of the marine vessels
 - C. Title 40 CFR § 63.564(a)(1) and (d) (relating to Monitoring Requirements)
 - D. Title 40 CFR § 63.565(a) (relating to Test Methods and Procedures), for performance testing requirements
 - E. Title 40 CFR § 63.565(c) (relating to Test Methods and Procedures), for vapor tightness requirements of the marine vessels
 - F. Title 40 CFR § 63.566 (relating to Construction and Reconstruction)
 - G. Title 40 CFR § 63.567(a) - (b) and (h) - (i) (relating to Reporting and Recordkeeping Requirements)

Additional Monitoring Requirements

11. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

12. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule (including the terms, conditions, monitoring, recordkeeping, and reporting identified in registered PBRS and

permits by rule identified in the PBR Supplemental Tables dated August 2, 2023 in the application for project 32065), standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:

- A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
13. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
14. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
15. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
- A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
 - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
 - C. Boiler Standard Permit
 - D. Requirements of the non-rule Air Quality Standard Permit for Pollution Control Projects

Compliance Requirements

16. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
17. The permit holder shall adhere to the provisions in the Compliance Schedule attachment of this permit and submit certified progress reports consistent with the schedule established under 30 TAC § 122.132(d)(4)(C) and including the information specified in 30 TAC § 122.142(d)(2). Those emission units listed in the Compliance Schedule attachment shall adhere with the requirements in the Compliance Schedule attachment until operating fully in compliance with the applicable requirements.

18. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:
 - A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
 - (i) For sources in the Beaumont-Port Arthur Nonattainment area, 30 TAC § 117.9000
 - B. The permit holder shall comply with the Initial Control Plan unit listing requirement in 30 TAC § 117.150(c) and (c)(1).
19. Use of Emission Credits to comply with applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) Offsets for Title 30 TAC Chapter 116
 - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)
 - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
 - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)
20. Use of Discrete Emission Credits to comply with the applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables

- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
- (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Risk Management Plan

21. For processes subject to 40 CFR Part 68 and specified in 40 CFR § 68.10, the permit holder shall comply with the requirements of the Accidental Release Prevention Provisions in 40 CFR Part 68. The permit holder shall submit to the appropriate agency either a compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR § 68.10(a), or as part of the compliance certification submitted under this permit, a certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of a risk management plan.

Protection of Stratospheric Ozone

22. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
- A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.

Permit Location

23. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

24. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the

permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Schedules

Applicable Requirements Summary

Unit Summary 17

Applicable Requirements Summary 24

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
27-TK-219	STORAGE TANKS/VESSELS	N/A	R5112-2021-01	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
27-TK-220	STORAGE TANKS/VESSELS	N/A	R5112-2021-01	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
6-TK-37	STORAGE TANKS/VESSELS	N/A	R5112-063	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
6-TK-38	STORAGE TANKS/VESSELS	N/A	R5112-063	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
6-TK-48	STORAGE TANKS/VESSELS	N/A	R5112-1.5-	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
6-TK-50	STORAGE TANKS/VESSELS	N/A	R5112-1.5-	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
6-TK-55	STORAGE TANKS/VESSELS	N/A	R5112-056	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
6-TK-55	STORAGE TANKS/VESSELS	N/A	63EEEE	40 CFR Part 63, Subpart EEEE	No changing attributes.
6-TK-56	STORAGE TANKS/VESSELS	N/A	R5112-056	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
6-TK-56	STORAGE TANKS/VESSELS	N/A	63EEEE	40 CFR Part 63, Subpart EEEE	No changing attributes.
6-TK-98	STORAGE TANKS/VESSELS	N/A	R5112-063	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
C4BARGE	LOADING/UNLOADING OPERATIONS	N/A	63Y-005	40 CFR Part 63, Subpart Y	No changing attributes.
DIESEL TANK2	STORAGE TANKS/VESSELS	N/A	R5112-2021-02	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
DIESEL TANK3	STORAGE TANKS/VESSELS	N/A	R5112-2021-02	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
DIESEL TANK4	STORAGE TANKS/VESSELS	N/A	R5112-2021-02	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
EMERGEN1	SRIC ENGINES	N/A	ZZZZ-EMERG1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EMERGEN2	SRIC ENGINES	N/A	ZZZZ-EMERG1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
FRAC TANK1	STORAGE TANKS/VESSELS	N/A	R5112-2021-02	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
FRAC TANK2	STORAGE TANKS/VESSELS	N/A	R5112-2021-02	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
FRAC TANK3	STORAGE TANKS/VESSELS	N/A	R5112-2021-02	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
FRAC TANK4	STORAGE TANKS/VESSELS	N/A	R5112-2021-02	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
FW-DOCK	SRIC ENGINES	N/A	IIII-EMERG2	40 CFR Part 60, Subpart IIII	No changing attributes.
FW-DOCK	SRIC ENGINES	N/A	ZZZZ-EMERG3	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
FW1-PH	SRIC ENGINES	N/A	IIII-EMERG2	40 CFR Part 60, Subpart IIII	No changing attributes.
FW1-PH	SRIC ENGINES	N/A	ZZZZ-EMERG3	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
FW1-WW	SRIC ENGINES	N/A	IIII-EMERG2	40 CFR Part 60, Subpart IIII	No changing attributes.
FW1-WW	SRIC ENGINES	N/A	ZZZZ-EMERG3	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
FW2-PH	SRIC ENGINES	N/A	IIII-EMERG2	40 CFR Part 60, Subpart IIII	No changing attributes.
FW2-PH	SRIC ENGINES	N/A	ZZZZ-EMERG3	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
FWENG3-PH	SRIC ENGINES	N/A	ZZZZ-EMERG2	40 CFR Part 63, Subpart	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				ZZZZ	
FWJ-PH	SRIC ENGINES	N/A	IIII-NONEMERG1	40 CFR Part 60, Subpart IIII	No changing attributes.
FWJ-PH	SRIC ENGINES	N/A	ZZZZ-ENG3	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GAS TANK1	STORAGE TANKS/VESSELS	N/A	R5112-2021-02	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPC4FU1	FUGITIVE EMISSION UNITS	BL-13, BL-4, BL-5, BL-7, BL-8, BL-9, FUGRAFF, NDBEFUG, NMTBE, SMTBE	R5352-ALL	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	No changing attributes.
GRPC4TK3	STORAGE TANKS/VESSELS	27-TK-205, 27-TK- 206, 27-TK-207, 27- TK-209, 27-TK-210, 27-TK-211, 27-TK- 212, 27-TK-213, 27- TK-215, 27-TK-216	R5112-056	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPC4TK3	STORAGE TANKS/VESSELS	27-TK-205, 27-TK- 206, 27-TK-207, 27- TK-209, 27-TK-210, 27-TK-211, 27-TK- 212, 27-TK-213, 27- TK-215, 27-TK-216	63EEEE	40 CFR Part 63, Subpart EEEE	No changing attributes.
GRPC4TK4	STORAGE TANKS/VESSELS	6-TK-1, 6-TK-10, 6- TK-100, 6-TK-101, 6-TK-103, 6-TK-104, 6-TK-109, 6-TK-11, 6-TK-12, 6-TK-13, 6- TK-14, 6-TK-15, 6- TK-16, 6-TK-17, 6- TK-18, 6-TK-19, 6-	R5112-063	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		TK-2, 6-TK-20, 6-TK-21, 6-TK-22, 6-TK-23, 6-TK-24, 6-TK-25, 6-TK-26, 6-TK-27, 6-TK-28, 6-TK-29, 6-TK-3, 6-TK-30, 6-TK-31, 6-TK-32, 6-TK-35, 6-TK-36, 6-TK-39, 6-TK-4, 6-TK-40, 6-TK-41, 6-TK-42, 6-TK-5, 6-TK-6, 6-TK-84, 6-TK-85, 6-TK-86, 6-TK-87, 6-TK-88, 6-TK-89, 6-TK-9, 6-TK-90, 6-TK-91, 6-TK-92, 6-TK-96, 6-TK-97, 6-TK-99			
GRPC4TK4	STORAGE TANKS/VESSELS	6-TK-1, 6-TK-10, 6-TK-100, 6-TK-101, 6-TK-103, 6-TK-104, 6-TK-109, 6-TK-11, 6-TK-12, 6-TK-13, 6-TK-14, 6-TK-15, 6-TK-16, 6-TK-17, 6-TK-18, 6-TK-19, 6-TK-2, 6-TK-20, 6-TK-21, 6-TK-22, 6-TK-23, 6-TK-24, 6-TK-25, 6-TK-26, 6-TK-27, 6-TK-28, 6-TK-29, 6-TK-3, 6-TK-30, 6-TK-31, 6-TK-32, 6-TK-35, 6-TK-36, 6-TK-39, 6-	63EEEE	40 CFR Part 63, Subpart EEEE	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		TK-4, 6-TK-40, 6-TK-41, 6-TK-42, 6-TK-5, 6-TK-6, 6-TK-84, 6-TK-85, 6-TK-86, 6-TK-87, 6-TK-88, 6-TK-89, 6-TK-9, 6-TK-90, 6-TK-91, 6-TK-92, 6-TK-96, 6-TK-97, 6-TK-99			
LDGPRSFUG	LOADING/UNLOADING OPERATIONS	N/A	R5211-024	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
LDGPRSFUG	LOADING/UNLOADING OPERATIONS	N/A	63EEEE	40 CFR Part 63, Subpart EEEE	No changing attributes.
LDGTFUG	LOADING/UNLOADING OPERATIONS	N/A	R5217	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
LTGEN	SRIC ENGINES	N/A	IIII-NONEMERG4	40 CFR Part 60, Subpart IIII	No changing attributes.
LTGEN	SRIC ENGINES	N/A	ZZZZ-ENG2	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
N2-D-7	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-VCU	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
N2-F-15	VOLATILE ORGANIC COMPOUND WATER SEPARATORS	N/A	R5131-006	30 TAC Chapter 115, Water Separation	No changing attributes.
N4-D-10	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-VCU	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
N4-D-11	EMISSION	N/A	R5121-VCU	30 TAC Chapter 115, Vent	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	POINTS/STATIONARY VENTS/PROCESS VENTS			Gas Controls	
N6-F-144	VOLATILE ORGANIC COMPOUND WATER SEPARATORS	N/A	R5131-006	30 TAC Chapter 115, Water Separation	No changing attributes.
RSWLDFLR	FLARES	N/A	R1111-002	30 TAC Chapter 111, Visible Emissions	No changing attributes.
RSWLDFLR	FLARES	N/A	60A	40 CFR Part 60, Subpart A	No changing attributes.
RW-1	SRIC ENGINES	N/A	IIII-NONEMERG1	40 CFR Part 60, Subpart IIII	No changing attributes.
RW-1	SRIC ENGINES	N/A	ZZZZ-ENG3	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
RW-2	SRIC ENGINES	N/A	IIII-NONEMERG1	40 CFR Part 60, Subpart IIII	No changing attributes.
RW-2	SRIC ENGINES	N/A	ZZZZ-ENG3	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
SW1-B6	SRIC ENGINES	N/A	IIII-NONEMERG1	40 CFR Part 60, Subpart IIII	No changing attributes.
SW1-B6	SRIC ENGINES	N/A	ZZZZ-ENG3	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
SW2-B6	SRIC ENGINES	N/A	IIII-NONEMERG1	40 CFR Part 60, Subpart IIII	No changing attributes.
SW2-B6	SRIC ENGINES	N/A	ZZZZ-ENG3	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
SWP-B13	SRIC ENGINES	N/A	IIII-NONEMERG3	40 CFR Part 60, Subpart IIII	No changing attributes.
SWP-B13	SRIC ENGINES	N/A	ZZZZ-ENG1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
SWP-B9	SRIC ENGINES	N/A	IIII-NONEMERG2	40 CFR Part 60, Subpart IIII	No changing attributes.
SWP-B9	SRIC ENGINES	N/A	ZZZZ-ENG1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
TO-GEN	SRIC ENGINES	N/A	IIII-NONEMERG1	40 CFR Part 60, Subpart IIII	No changing attributes.
TO-GEN	SRIC ENGINES	N/A	ZZZZ-ENG2	40 CFR Part 63, Subpart ZZZZ	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
27-TK-219	EU	R5112-2021-01	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(a)(1)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None
27-TK-220	EU	R5112-2021-01	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(a)(1)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None
6-TK-37	EU	R5112-063	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(a)(1) § 115.112(a)(3)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(1) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
6-TK-38	EU	R5112-063	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(a)(1) § 115.112(a)(3)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(1) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
6-TK-48	EU	R5112-1.5-	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
6-TK-50	EU	R5112-	VOC	30 TAC Chapter	§ 115.111(a)(1)	Except as provided in §	[G]§ 115.117	§ 115.118(a)(1)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		1.5-		115, Storage of VOCs		115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.		§ 115.118(a)(5) § 115.118(a)(7)	
6-TK-55	EU	R5112-056	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(a)(1) § 115.112(a)(2) § 115.112(a)(2)(A) § 115.112(a)(2)(B) § 115.112(a)(2)(C) § 115.112(a)(2)(D) § 115.112(a)(2)(E) § 115.114(a)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(7)	§ 115.114(a)(1)(B)
6-TK-55	EU	63EEEE	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2338(b) The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart EEEE
6-TK-56	EU	R5112-056	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(a)(1) § 115.112(a)(2) § 115.112(a)(2)(A) § 115.112(a)(2)(B) § 115.112(a)(2)(C) § 115.112(a)(2)(D) § 115.112(a)(2)(E) § 115.114(a)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(7)	§ 115.114(a)(1)(B)
6-TK-56	EU	63EEEE	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2338(b) The permit holder shall comply with the applicable limitation, standard	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable monitoring and testing	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart EEEE

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					and/or equipment specification requirements of 40 CFR Part 63, Subpart EEEE		requirements of 40 CFR Part 63, Subpart EEEE	Part 63, Subpart EEEE	
6-TK-98	EU	R5112-063	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(a)(1) § 115.112(a)(3)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(1) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
C4BARGE	EU	63Y-005	112(B) HAPS	40 CFR Part 63, Subpart Y	§ 63.560(a)(4) § 153.282 § 63.560(a)(2)	Any existing sources with emissions less than 10 tons of any individual HAP and 25 tons of HAP combined must meet the submerged fill standards of 46 CFR 153.282.	§ 63.565(l)	§ 63.567(j)(4)	None
DIESEL TANK2	EU	R5112-2021-02	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
DIESEL TANK3	EU	R5112-2021-02	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
DIESEL TANK4	EU	R5112-2021-02	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						vapor pressure less than 1.5 psia is exempt from the requirements of this division.			
EMERGEN1	EU	ZZZZ-EMERG1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table 2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
EMERGEN2	EU	ZZZZ-EMERG1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table 2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
FRAC TANK1	EU	R5112-2021-02	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FRAC TANK2	EU	R5112-2021-02	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
FRAC TANK3	EU	R5112-2021-02	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
FRAC TANK4	EU	R5112-2021-02	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
FW-DOCK	EU	IIII-EMERG2	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
FW-DOCK	EU	IIII-	NMHC and	40 CFR Part 60,	§ 60.4205(b)	Owners and operators of	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		EMERG2	NO _x	Subpart IIII	§ 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
FW-DOCK	EU	IIII-EMERG2	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
FW-DOCK	EU	IIII-EMERG2	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power >	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 89.113(a)(1) § 89.113(a)(2) § 89.113(a)(3)	2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2) and §89.113(a)(1)-(3) and §1039.105(b)(1)-(3).			
FW-DOCK	EU	ZZZZ-EMERG3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(b)(1) § 63.6595(c) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	An affected source which meets either of the criteria in paragraphs §63.6590(b)(1)(i)-(ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(f).	None	None	§ 63.6645(f)
FW1-PH	EU	IIII-EMERG2	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
FW1-PH	EU	IIII-	NMHC and	40 CFR Part 60,	§ 60.4205(b)	Owners and operators of	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		EMERG2	NO _x	Subpart IIII	§ 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
FW1-PH	EU	IIII-EMERG2	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
FW1-PH	EU	IIII-EMERG2	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power >	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 89.113(a)(1) § 89.113(a)(2) § 89.113(a)(3)	2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2) and §89.113(a)(1)-(3) and §1039.105(b)(1)-(3).			
FW1-PH	EU	ZZZZ-EMERG3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(b)(1) § 63.6595(c) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	An affected source which meets either of the criteria in paragraphs §63.6590(b)(1)(i)-(ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(f).	None	None	§ 63.6645(f)
FW1-WW	EU	IIII-EMERG2	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
FW1-WW	EU	IIII-	NMHC and	40 CFR Part 60,	§ 60.4205(b)	Owners and operators of	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		EMERG2	NO _x	Subpart IIII	§ 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
FW1-WW	EU	IIII-EMERG2	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
FW1-WW	EU	IIII-EMERG2	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power >	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 89.113(a)(1) § 89.113(a)(2) § 89.113(a)(3)	2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2) and §89.113(a)(1)-(3) and §1039.105(b)(1)-(3).			
FW1-WW	EU	ZZZZ-EMERG3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(b)(1) § 63.6595(c) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	An affected source which meets either of the criteria in paragraphs §63.6590(b)(1)(i)-(ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(f).	None	None	§ 63.6645(f)
FW2-PH	EU	IIII-EMERG2	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
FW2-PH	EU	IIII-	NMHC and	40 CFR Part 60,	§ 60.4205(b)	Owners and operators of	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		EMERG2	NO _x	Subpart IIII	§ 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
FW2-PH	EU	IIII-EMERG2	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	None	None	[G]§ 60.4214(d)
FW2-PH	EU	IIII-EMERG2	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power >	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 89.113(a)(1) § 89.113(a)(2) § 89.113(a)(3)	2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2) and §89.113(a)(1)-(3) and §1039.105(b)(1)-(3).			
FW2-PH	EU	ZZZZ-EMERG3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(b)(1) § 63.6595(c) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	An affected source which meets either of the criteria in paragraphs §63.6590(b)(1)(i)-(ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(f).	None	None	§ 63.6645(f)
FWENG3-PH	EU	ZZZZ-EMERG2	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table 2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
FWJ-PH	EU	IIII-NONEMERG1	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a)	Owners and operators of non-emergency stationary CI ICE with a maximum	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.			
FWJ-PH	EU	ZZZZ-ENG3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
GAS TANK1	EU	R5112-2021-02	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPC4FU1	EU	R5352-	VOC	30 TAC Chapter	§ 115.357(10)	Instrumentation systems, as	None	§ 115.356	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		ALL		115, Pet. Refinery & Petrochemicals		defined in 40 CFR §63.161 (January 17, 1997), that meet 40 CFR §63.169 (June 20, 1996) are exempt from the requirements of this division except §115.356(3)(C) of this title.		§ 115.356(3) [G]§ 115.356(3)(C)	
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(11)	Sampling connection systems, as defined in 40 CFR §63.161 (January 17, 1997), that meet the requirements of 40 CFR §63.166(a) and (b) (June 20, 1996) are exempt from the requirements of this division except §115.356(3)(C) of this title.	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(13)	Components/systems that contact a process fluid containing VOC having a true vapor pressure equal to or less than 0.002 psia at 68 degrees Fahrenheit are exempt from the requirements of this division except §115.356(3)(C) of this title.	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(2) § 115.352(9)	Each pressure relief valve equipped with a rupture disk must comply with §115.352(9) and §115.356(3)(C).	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(C) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A)	No component shall be allowed to have a VOC leak, for more than 15 days, after discovery. If the owner or operator elects to use the	§ 115.354(1) § 115.354(11) § 115.354(13)(A) § 115.354(13)(B) § 115.354(13)(C)	§ 115.352(7) § 115.354(13)(D) § 115.354(13)(E) § 115.356 [G]§ 115.356(1)	[G]§ 115.358(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.352(2)(B) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(4) § 115.352(5) § 115.352(6) § 115.352(7) § 115.352(8) § 115.357(8) § 115.358(c)(1) [G]§ 115.358(h)	alternative work practice in §115.358 of this title, any leak detected as defined in §115.358 of this title, including any leak detected using the alternative work practice on a component that is subject to the requirements of this division but not specifically selected for alternative work practice monitoring.	§ 115.354(13)(D) § 115.354(13)(E) § 115.354(13)(F) § 115.354(4) § 115.354(5) § 115.354(9) [G]§ 115.355 § 115.358(c)(2) § 115.358(d) [G]§ 115.358(e) § 115.358(f)	[G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) [G]§ 115.356(4) § 115.356(5)	
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(3) § 115.352(7) § 115.357(1)	No process drains shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(3) § 115.352(7)	No process drains shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) § 115.356(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(5) § 115.352(7) § 115.352(9) § 115.357(1) § 115.357(8) § 115.357(9)	No pressure relief valves shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(4) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(5) § 115.352(7) § 115.352(9) § 115.357(12) § 115.357(8) § 115.357(9)	No pressure relief valves shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(4) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(4) § 115.352(5) § 115.352(6) § 115.352(7) § 115.357(1)	No open-ended valves or lines shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.357(8) § 115.357(9)				
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(4) § 115.352(5) § 115.352(6) § 115.352(7) § 115.357(12) § 115.357(8) § 115.357(9)	No open-ended valves or lines shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(4) § 115.352(5) § 115.352(6) § 115.352(7) § 115.357(1) § 115.357(8) § 115.357(9)	No valves shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(4)	No valves shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B)	[G]§ 115.354(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.352(5) § 115.352(6) § 115.352(7) § 115.357(12) § 115.357(8) § 115.357(9)	the dripping or exuding of process fluid based on sight, smell, or sound.		[G]§ 115.356(3)(C) § 115.356(5)	
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(3) § 115.352(5) § 115.352(7) § 115.352(8) § 115.357(1) § 115.357(12) § 115.357(8)	No flanges or other connectors shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(11) § 115.354(3) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(3) § 115.352(5) § 115.352(7) § 115.352(8) § 115.357(12) § 115.357(8)	No flanges or other connectors shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(11) § 115.354(3) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii)	No agitators shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 500 parts per million by volume above background	§ 115.354(1) § 115.354(10) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.352(2)(C)(iii) § 115.352(3) § 115.352(7) § 115.357(1) § 115.357(12) § 115.357(8)	as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.		[G]§ 115.356(3)(C) § 115.356(5)	
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(7) § 115.357(1) § 115.357(12) § 115.357(8)	No agitators shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(7) § 115.357(12) § 115.357(8)	No agitators shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A)	No compressor seals shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening	[G]§ 115.355	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(3) § 115.357(8)	concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.		[G]§ 115.356(3)(C) § 115.356(5)	
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(4) § 115.357(8)	No compressor seals shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	[G]§ 115.355	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	None
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(1) § 115.357(8)	No compressor seals shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	None
GRPC4FU1	EU	R5352-	VOC	30 TAC Chapter	§ 115.352(1)(B)	No compressor seals shall	§ 115.354(1)	§ 115.352(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		ALL		115, Pet. Refinery & Petrochemicals	§ 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(12) § 115.357(8)	be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(4) § 115.357(8)	No pump seals shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	[G]§ 115.355	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	None
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5)	No pump seals shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or	§ 115.354(1) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 115.352(7) § 115.357(1) § 115.357(8)	sound.			
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(10) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(12) § 115.357(8)	No pump seals shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(6)	Components at a petroleum refinery or synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process, that contact a process fluid that contains less than 10% VOC by weight and components at a natural gas/gasoline processing operation that contact a process fluid that contains less than 1.0% VOC by weight are exempt from the requirements of this division except §115.356(3)(C) of this title.	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None
GRPC4FU1	EU	R5352-ALL	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(5)	Reciprocating compressors and positive displacement pumps used in natural gas/gasoline processing	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						operations are exempt from the requirements of this division except §115.356(3)(C) of this title.			
GRPC4TK3	EU	R5112-056	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(a)(1) § 115.112(a)(3)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(1) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
GRPC4TK3	EU	63EEEE	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2338(b) The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart EEEE
GRPC4TK4	EU	R5112-063	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(a)(1) § 115.112(a)(3)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.115(a) § 115.115(a)(6) § 115.116(a)(1) [G]§ 115.117	§ 115.118(a)(4) § 115.118(a)(4)(F) § 115.118(a)(5) § 115.118(a)(7)	None
GRPC4TK4	EU	63EEEE	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2338(b) The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63,	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart EEEE

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					Subpart EEEE				
LDGPRSFUG	EU	R5211-024	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(1) § 115.212(a)(1)(A) § 115.212(a)(3)(A) § 115.212(a)(3)(A)(ii) § 115.212(a)(3)(B) [G]§ 115.212(a)(3)(C) § 115.212(a)(3)(E) § 115.214(a)(1)(B) § 115.214(a)(1)(C)	At operations other than gasoline terminals, gasoline bulk plants, and marine terminals, vapors from loading VOC with a true vapor pressure of 0.5 psia or greater must be controlled by one of the methods specified in § 115.212(a)(1)(A)-(C).	§ 115.212(a)(3)(B) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.214(a)(1)(A)(ii) § 115.214(a)(1)(A)(iii) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.216 § 115.216(1) § 115.216(1)(C) § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
LDGPRSFUG	EU	63EEEE	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2338(b) The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart EEEE
LDGTFUG	EU	R5217	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
LTGEN	EU	IIII-NONEMERG4	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a)	Owners and operators of non-emergency stationary CI ICE with a maximum	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	engine power less than 8 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 8.0 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.			
LTGEN	EU	IIII-NONEMERG4	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a displacement of less than 10 liters per cylinder and is not a constant-speed engine and is a 2007 model year and later must comply with the following opacity emission limits: 20% during the acceleration mode, 15% during the lugging mode, and 50% during the peaks in either the acceleration or lugging modes as stated in 40 CFR 60.4201(a)-(c) and 40 CFR 89.113(a)(1)-(3) and 40 CFR 1039.105(b)(1)-(3).	None	None	None
LTGEN	EU	ZZZZ-ENG2	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
N2-D-7	EP	R5121-VCU	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	None
N2-F-15	EU	R5131-006	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(3) § 115.131(a)	VOC water separator compartments must be equipped with a vapor recovery system which satisfies the provisions of §115.131(a) of this title.	[G]§ 115.135(a) § 115.136(a)(2) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(2) § 115.136(a)(3) § 115.136(a)(4)	None
N4-D-10	EP	R5121-VCU	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
N4-D-11	EP	R5121-VCU	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.122(a)(1) § 115.121(a)(1) § 115.122(a)(1)(C)	Vent gas streams affected by §115.121(a)(1) must be controlled properly with a control efficiency of at least 90% or to a volatile organic compound (VOC) concentration of no more than 20 parts per million (ppmv) (on a dry basis corrected to 3.0% oxygen for combustion devices).	[G]§ 115.125 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	§ 115.126 § 115.126(1) § 115.126(1)(A) § 115.126(1)(A)(iii) § 115.126(2)	None
N6-F-144	EU	R5131-006	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(3) § 115.131(a)	VOC water separator compartments must be equipped with a vapor recovery system which satisfies the provisions of §115.131(a) of this title.	[G]§ 115.135(a) § 115.136(a)(2) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(2) § 115.136(a)(3) § 115.136(a)(4)	None
RSWLDFLR	EU	R1111-002	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
RSWLDFLR	CD	60A	Opacity	40 CFR Part 60, Subpart A	§ 60.18(b) § 60.18(c)(1) § 60.18(c)(2) § 60.18(c)(3)(ii) § 60.18(c)(4)(ii) § 60.18(c)(6) § 60.18(e)	Flares shall comply with paragraphs (c)-(f) of § 60.18.	§ 60.18(d) § 60.18(f)(1) § 60.18(f)(2) § 60.18(f)(3) § 60.18(f)(4)	None	None
RW-1	EU	IIII-NONEME RG1	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(a) § 60.4211(c) § 60.4218	than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.			
RW-1	EU	ZZZZ-ENG3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
RW-2	EU	IIII-NONEME RG1	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						a CO emission limit of 3.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.			
RW-2	EU	ZZZZ-ENG3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
SW1-B6	EU	IIII-NONEME RG1	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						1039.101.			
SW1-B6	EU	ZZZZ-ENG3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
SW2-B6	EU	IIII-NONEMERG1	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None
SW2-B6	EU	ZZZZ-ENG3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
SWP-B13	EU	IIII-NONEME RG3	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 19 KW and less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None
SWP-B13	EU	IIII-NONEME RG3	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a displacement of less than 10 liters per cylinder and is not a constant-speed engine and is a 2007 model year and later must comply with the following opacity emission	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4218	limits: 20% during the acceleration mode, 15% during the lugging mode, and 50% during the peaks in either the acceleration or lugging modes as stated in 40 CFR 60.4201(a)-(c) and 40 CFR 89.113(a)(1)-(3) and 40 CFR 1039.105(b)(1)-(3).			
SWP-B13	EU	ZZZZ-ENG1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
SWP-B9	EU	IIII-NONEME RG2	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 37 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.0 g/KW-	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.			
SWP-B9	EU	III- NONEME RG2	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 37 KW but less than 56 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with an NMHC+NO _x emission limit of 4.7 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None
SWP-B9	EU	ZZZZ- ENG1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TO-GEN	EU	IIII-NONEME RG1	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None
TO-GEN	EU	ZZZZ-ENG2	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None

Additional Monitoring Requirements

Periodic Monitoring Summary 60

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 27-TK-219	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2021-01
Pollutant: VOC	Main Standard: § 115.112(a)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: N/A	
Averaging Period: N/A	
Deviation Limit: Failure to keep a record of tank construction specifications	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 27-TK-219	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2021-01
Pollutant: VOC	Main Standard: § 115.112(a)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: N/A	
Deviation Limit: Failure to inspect to determine the structural integrity of the fill pipe and keep records	
<p>Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 27-TK-220	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2021-01
Pollutant: VOC	Main Standard: § 115.112(a)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: N/A	
Averaging Period: N/A	
Deviation Limit: Failure to keep a record of tank construction specifications	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 27-TK-220	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2021-01
Pollutant: VOC	Main Standard: § 115.112(a)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: N/A	
Deviation Limit: Failure to inspect to determine the structural integrity of the fill pipe and keep records	
<p>Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.</p>	

Permit Shield

Permit Shield 65

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
103	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than 1000 gallons.
103	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19,813 gallons).
104	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	Motor vehicle dispensing facilities.
104	N/A	30 TAC Chapter 115, Storage of VOCs	Tank with capacity less than 25,000 gallons located at a motor vehicle fuel dispensing facility.
104	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19,813 gallons).
2	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than 1000 gallons.
2	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19,813 gallons).
27-TK-219	N/A	40 CFR Part 60, Subpart K	Construction or modification of the storage vessel commenced before 6/11/73.
27-TK-220	N/A	40 CFR Part 60, Subpart K	Construction or modification of the storage vessel commenced before 6/11/73.
6-TK-37	N/A	40 CFR Part 60, Subpart Kb	Tank stores VOC (but not petroleum or petroleum liquids), but was constructed before 7/23/84 and has not been modified later than 7/23/84.
6-TK-38	N/A	40 CFR Part 60, Subpart Kb	Tank stores VOC (but not petroleum or petroleum liquids), but was constructed before 7/23/84 and has not been modified later than 7/23/84.
6-TK-48	N/A	40 CFR Part 60, Subpart Kb	Tank stores VOC (but not petroleum or

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
			petroleum liquids), but was constructed before 7/23/84 and has not been modified later than 7/23/84.
6-TK-50	N/A	40 CFR Part 60, Subpart Kb	Tank stores VOC (but not petroleum or petroleum liquids), but was constructed before 7/23/84 and has not been modified later than 7/23/84.
6-TK-55	N/A	40 CFR Part 60, Subpart Kb	Tank is part of an organic liquid distribution facility subject to MACT EEEE (Organic Liquid Distribution) and opts to only to comply with MACT EEEE.
6-TK-56	N/A	40 CFR Part 60, Subpart Kb	Tank is part of an organic liquid distribution facility subject to MACT EEEE (Organic Liquid Distribution) and opts to only to comply with MACT EEEE.
6-TK-98	N/A	40 CFR Part 60, Subpart Kb	Tank stores VOC (but not petroleum or petroleum liquids), but was constructed before 7/23/84 and has not been modified later than 7/23/84.
API SEP	N/A	30 TAC Chapter 115, Water Separation	Separator is fully covered and designed solely to capture stormwater, spills or exterior surface clean up water.
C4BARGE	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	Marine vessels loading operations located at sites in Beaumont/Port Arthur non-attainment areas are exempt.
DIESEL TANK2	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19,813 gallons).
DIESEL TANK3	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
			(19,813 gallons).
DIESEL TANK4	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19,813 gallons).
FDU-8	N/A	30 TAC Chapter 115, Storage of VOCs	Vessel located at motor vehicle fuel dispensing facility and capacity is less than 25,000 gallons
FDU-8	N/A	40 CFR Part 60, Subpart Kb	Storage Capacity is < 19,813 gallons
FRAC TANK1	N/A	40 CFR Part 60, Subpart Kb	Storage vessel has a capacity greater than 75 cubic meters (19,813 gallons) but less than 151 cubic meters (39,900) and stores a liquid with a maximum true vapor pressure less than 15.0 kPa (2.2psia).
FRAC TANK2	N/A	40 CFR Part 60, Subpart Kb	Storage vessel has a capacity greater than 75 cubic meters (19,813 gallons) but less than 151 cubic meters (39,900) and stores a liquid with a maximum true vapor pressure less than 15.0 kPa (2.2psia).
FRAC TANK3	N/A	40 CFR Part 60, Subpart Kb	Storage vessel has a capacity greater than 75 cubic meters (19,813 gallons) but less than 151 cubic meters (39,900) and stores a liquid with a maximum true vapor pressure less than 15.0 kPa (2.2psia).
FRAC TANK4	N/A	40 CFR Part 60, Subpart Kb	Storage vessel has a capacity greater than 75 cubic meters (19,813 gallons) but less than 151 cubic meters (39,900) and stores a liquid with a maximum true vapor pressure less than 15.0 kPa (2.2psia).
GAS TANK1	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19,813 gallons).

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-TANK	6-TK-69, 6-TK-74, 6-TK-83	30 TAC Chapter 115, Storage of VOCs	Tank does not store VOCs.
GRP-TANK	6-TK-69, 6-TK-74, 6-TK-83	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19,813 gallons).
GRPC4FU1	BL-13, BL-4, BL-5, BL-7, BL-8, BL-9, FUGRAFF, NDBEFUG, NMTBE, SMTBE	40 CFR Part 60, Subpart VV	For fugitive components, TPC has elected to comply with the requirements of 40 CFR 63, Subpart UU. TPC is no longer a manufacturer. EEEE is applicable, so UU or TT apply and not the requirements of 40 CFR 60, Subpart VV.
6-TK-117	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than 1,000 gallons.
6TK-117	N/A	40 CFR Part 60, Subpart Kb	Storage Capacity is < 19,813 gallons
GRPC4TK3	27-TK-205, 27-TK-206, 27-TK-207, 27-TK-209, 27-TK-210, 27-TK-211, 27-TK-212, 27-TK-213, 27-TK-215, 27-TK-216	40 CFR Part 60, Subpart Kb	Tank is part of an organic liquid distribution facility subject to MACT EEEE (Organic Liquid Distribution) and opts to only to comply with MACT EEEE.
GRPC4TK4	6-TK-1, 6-TK-10, 6-TK-100, 6-TK-101, 6-TK-103, 6-TK-104, 6-TK-109, 6-TK-11, 6-TK-12, 6-TK-13, 6-TK-14, 6-TK-15, 6-TK-16, 6-TK-17, 6-TK-18, 6-TK-19, 6-TK-2, 6-TK-20, 6-TK-21, 6-TK-22, 6-TK-23, 6-TK-24, 6-TK-25, 6-TK-26, 6-TK-27, 6-TK-28, 6-TK-29, 6-TK-3, 6-TK-30, 6-TK-31, 6-TK-32, 6-TK-35, 6-TK-36, 6-TK-39, 6-TK-4, 6-TK-40, 6-TK-41, 6-TK-42, 6-TK-5, 6-TK-6, 6-TK-84, 6-TK-85, 6-TK-86, 6-TK-87, 6-TK-88, 6-TK-89, 6-TK-9, 6-TK-90, 6-TK-91, 6-TK-92, 6-TK-96, 6-TK-97, 6-TK-99	40 CFR Part 60, Subpart Kb	Tank is part of an organic liquid distribution facility subject to MACT EEEE (Organic Liquid Distribution) and opts to only to comply with MACT EEEE.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
MAINTPAINT	N/A	30 TAC Chapter 115, Surface Coating Operations	Painting operations only include maintenance painting in the field to stationary structures.
N2-D-7	N/A	40 CFR Part 60, Subpart NNN	Unit was constructed prior to 12/30/1983
N4-D-10	N/A	40 CFR Part 60, Subpart NNN	Unit was constructed prior to 12/30/1983
N4-D-11	N/A	40 CFR Part 60, Subpart NNN	Unit was constructed prior to 12/30/1983
RSWLDFLR	N/A	40 CFR Part 63, Subpart A	Flare is not used to comply with applicable subparts of part 63.

New Source Review Authorization References

New Source Review Authorization References 71

New Source Review Authorization References by Emission Unit 72

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 20485	Issuance Date: 09/16/2020
Authorization No.: 160543	Issuance Date: 04/10/2020
Authorization No.: 161021	Issuance Date: 09/10/2021
Authorization No.: 162286	Issuance Date: 09/24/2020
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.261	Version No./Date: 09/04/2000
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 09/04/2000
Number: 106.262	Version No./Date: 11/01/2003
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.412	Version No./Date: 09/04/2000
Number: 106.433	Version No./Date: 09/04/2000
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.476	Version No./Date: 09/04/2000
Number: 106.512	Version No./Date: 06/13/2001
Number: 106.532	Version No./Date: 09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
103	STORAGE TANK	20485
104	STORAGE TANK	20485
2	STORAGE TANK	20485
27-TK-205	MTBE TANK	20485
27-TK-206	MTBE TANK	20485
27-TK-207	MTBE TANK	20485
27-TK-209	MTBE TANK	20485
27-TK-210	MTBE TANK	20485
27-TK-211	MTBE TANK	20485
27-TK-212	MTBE TANK	20485
27-TK-213	MTBE TANK	20485
27-TK-215	MTBE TANK	20485
27-TK-216	MTBE TANK	20485
27-TK-219	STORAGE TANKS/VESSELS	20485
27-TK-220	STORAGE TANKS/VESSELS	20485
6-TK-1	CHANGE SERVICE TO RAFFINATE	20485
6-TK-10	BUTADIENE PRODUCT TANK	20485
6-TK-100	BUTADIENE PRODUCT TANK	20485
6-TK-101	BUTADIENE PRODUCT TANK	20485
6-TK-103	CRUDE BUTADIENE TANK	20485
6-TK-104	BUTADIENE PRODUCT TANK	20485

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
6-TK-109	BUTADIENE PRODUCT TANK	20485
6-TK-11	BUTADIENE PRODUCT TANK	20485
6-TK-117	TBC TANK	20485
6-TK-12	BUTADIENE PRODUCT TANK	20485
6-TK-13	BUTADIENE PRODUCT TANK	20485
6-TK-14	BUTADIENE PRODUCT TANK	20485
6-TK-15	BUTADIENE PRODUCT TANK	20485
6-TK-16	BUTADIENE PRODUCT TANK	20485
6-TK-17	BUTADIENE SLOP TANK	20485, 106.532/09/04/2000
6-TK-18	CRUDE BUTADIENE TANK	20485
6-TK-19	BUTADIENE SLOP TANK	20485
6-TK-2	BB FEED TANK	20485
6-TK-20	CRUDE BUTADIENE TANK	20485
6-TK-21	CRUDE BUTADIENE TANK	20485
6-TK-22	RAFFINAT-1 TANK	20485
6-TK-23	CRUDE BUTADIENE TANK	20485
6-TK-24	CRUDE BUTADIENE TANK	20485
6-TK-25	CRUDE BUTADIENE TANK	20485
6-TK-26	CRUDE BUTADIENE TANK	20485
6-TK-27	RAFFINATE-1 TANK	20485
6-TK-28	CRUDE BUTADIENE TANK	20485

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
6-TK-29	CRUDE BUTADIENE TANK	20485
6-TK-3	CRUDE BUTADIENE TANK	20485
6-TK-30	BUTADIENE SLOP TANK	20485
6-TK-31	BUTADIENE SLOP TANK	20485
6-TK-32	CRUDE BUTADIENE TANK	20485
6-TK-35	C4 RAFFINATTE TANK	20485
6-TK-36	C4 RAFFINATE TANK	20485
6-TK-37	POLYBLEND TANK	20485
6-TK-38	POLYBLEND TANK	20485
6-TK-39	C4 RAFFINATE TANK	20485
6-TK-4	CRUDE BUTADIENE TANK	20485
6-TK-40	C4 RAFFINATE TANK	20485
6-TK-41	C4 RAFFINATE TANK	20485
6-TK-42	C4 RAFFINATE TANK	20485
6-TK-48	NMP TANK	20485
6-TK-5	CRUDE BUTADIENE TANK	20485
6-TK-50	NMP TANK	20485
6-TK-55	METHANOL TANK	20485
6-TK-56	METHANOL TANK	20485
6-TK-6	CRUDE BUTADIENE TANK	20485
6-TK-69	STORAGE TANK	20485

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
6-TK-74	STORAGE TANK	20485
6-TK-83	STORAGE TANK	20485
6-TK-84	CRUDE BUTADIENE TANK	20485
6-TK-85	CRUDE BUTADIENE TANK	20485
6-TK-86	CRUDE BUTADIENE TANK	20485
6-TK-87	CRUDE BUTADIENE TANK	20485
6-TK-88	RAFFINATE-1 TANK	20485
6-TK-89	RAFFINATE-1 TANK	20485
6-TK-9	BUTADIENE PRODUCT TANK	20485
6-TK-90	BUTADIENE INTERMEDIATE TANK	20485
6-TK-91	BUTADIENE INTERMEDIATE TANK	20485
6-TK-92	RAFFINATE STORAGE TANK	20485
6-TK-96	BUTADIENE INTERMEDIATE TANK	20485
6-TK-97	BUTADIENE INTERMEDIATE TANK	20485
6-TK-98	POLYBLEND TANK	20485, 106.473/09/04/2000
6-TK-99	RAFFINATE-1 TANK	20485
API SEP	API SEPARATOR	20485
BL-13	BLOCK 13 FUGITIVES	20485
BL-4	BLOCK 4 FUGITIVES	20485
BL-5	BLOCK 5 FUGITIVES	20485
BL-7	BLOCK 7 FUGITIVES	20485

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
BL-8	BLOCK 8 FUGITIVES	20485
BL-9	BLOCK 9 FUGITIVES	20485
C4BARGE	C4 MARINE BARGE LOADING	20485, 106.261/11/01/2003 [158519]
DIESEL TANK2	STORAGE TANKS/VESSELS	20485, 106.472/09/04/2000
DIESEL TANK3	STORAGE TANKS/VESSELS	20485, 106.472/09/04/2000
DIESEL TANK4	STORAGE TANKS/VESSELS	20485, 106.472/09/04/2000
EMERGEN1	EMERGENCY GENERATOR 1	106.512/06/13/2001 [167367]
EMERGEN2	EMERGENCY GENERATOR 2	106.512/06/13/2001 [167367]
FDU-8	DIESEL FUEL DISPENSING TANK	20485
FRAC TANK1	STORAGE TANKS/VESSELS	106.263/11/01/2001
FRAC TANK2	STORAGE TANKS/VESSELS	106.263/11/01/2001
FRAC TANK3	STORAGE TANKS/VESSELS	106.263/11/01/2001
FRAC TANK4	STORAGE TANKS/VESSELS	106.263/11/01/2001
FUGRAFF	RAFFINATE UNLOADING FUGITIVE EMISSIONS	106.261/11/01/2003, 106.262/11/01/2003, 106.476/09/04/2000
FW-DOCK	FIREWATER ENGINE-DOCK	106.512/06/13/2001 [168414]
FW1-PH	FIREWATER ENGINE 1- PUMP HOUSE	106.512/06/13/2001 [168414]
FW1-WW	FIREWATER ENGINE 1 - JWWTP	106.512/06/13/2001 [168414]
FW2-PH	FIREWATER ENGINE 2- PUMP HOUSE	106.512/06/13/2001 [168414]
FWENG3-PH	FIREWATER ENGINE 3- PUMP HOUSE	106.512/06/13/2001 [167367]
FWJ-PH	FIREWATER JOCKEY - PUMP HOUSE	106.512/06/13/2001 [168414]

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
GAS TANK1	STORAGE TANKS/VESSELS	106.412/09/04/2000, 106.473/09/04/2000
LDGPRSFUG	C4 RAILCAR AND TRUCK LOADING	20485
LDGTKFUG	MISC AND FUEL TANK LOADING/UNLOADING	20485
LTGEN	LIGHT PLANT GENERATOR	106.512/06/13/2001 [168414]
MAINTPAINT	ON SITE STATIONARY SOURCE MAINTENANCE PAINTING	106.433/09/04/2000
N2-D-7	WASTEWATER STEAM STRIPPER	20485
N2-F-15	OIL WATER SEPARATOR	20485
N4-D-10	SPONGE OIL ABSORBER	20485
N4-D-11	SPONGE OIL STRIPPER	20485
N6-F-144	OILY WATER SEPARATOR	20485
NDBEFUG	NORTH PLANT FUGITIVES	20485
NMTBE	NORTH MTBE UNIT FUGITIVES	20485
RSWLDFLR	DOCK FLARE	20485
RW-1	RAW WATER PUMP 1	106.512/06/13/2001 [168414]
RW-2	RAW WATER PUMP 2	106.512/06/13/2001 [168414]
SMTBE	SOUTH MTBE UNIT FUGITIVES	20485
SW1-B6	STORM WATER PUMP 1 - BLOCK 6	106.512/06/13/2001 [168414]
SW2-B6	STORM WATER PUMP 2 - BLOCK 6	106.512/06/13/2001 [168414]
SWP-B13	STORM WATER PUMP - BLOCK 13	106.512/06/13/2001 [168414]
SWP-B9	STORM WATER PUMP - BLOCK 9	106.512/06/13/2001 [168414]
TO-GEN	N-TO GENERATOR	106.512/06/13/2001 [168414]

**This column may include Permit by Rule (PBR) numbers and version dates, PBR Registration numbers in brackets, Standard Permit Registration numbers, Minor NSR permit numbers, and Major NSR permit numbers.

Schedules

Compliance Schedule..... 80

Compliance Schedule

A. Compliance Schedule				
1. Specific Non-Compliance Situation				
Unit/Group/ Process ID. No(s).	SOP Index No.	Pollutant	Applicable Requirement	
			Citation	Text Description
6-TK-55, 6-TK-56, GRPC4TK3, GRPC4TK4, 27-TK-205, 27-TK-206, 27-TK-207, 27-TK-215, 27-TK-219, 27-TK-220, GRPC4FU1 and LDGPRSFUG		HAPS	63.2334(a)	Except as provided for in paragraphs (b) and (c) of this section, you are subject to this subpart if you own or operate an OLD operation that is located at, or is part of, a major source of HAP emissions. An OLD operation may occupy an entire plant site or be collocated with other industrial (e.g., manufacturing) operations at the same plant site.
2. Compliance Status Assessment Method and Records Location				
Compliance Status Assessment Method			Location of Records/Documentation	
Citation	Text Description			
63.2342, 63.2343, 63.2346, 63.2350, 63.2354, 63.2358, 63.2366	Comply with requirements for closed vent systems for (C4 & MTBE) tanks & High throughput Rail Rack, including control, recordkeeping & reporting. Methanol tanks comply with IFR requirements under WW. Fugitives comply with monitoring, recordkeeping & reporting requirements under Subpart UU.		DCS, LeakDAS, File records	
3. Non-compliance Situation Description				
With the discontinuation of Synthetic Organic Chemical Manufacturing, the site is no longer subject to 40 CFR 63 F, G, and H (Hazardous Organic NESHAPS) Requirements, which previously superseded the requirements of 40 CFR 63 Subpart EEEE - Organics Liquids Distribution (OLD). TPC PNO is now subject to OLD and other subpart requirements (WW, SS & UU) incorporated therein.				
4. Corrective Action Plan Description				
Assess applicable requirements, ensure appropriate controls and establish compliance procedures.				
5. List of Activities/Milestones to Implement the Corrective Action Plan				
1	Existing emission controls meet 40 CFR 63 EEEE (and therein incorporated WW, SS & UU) requirements. However, the programs for ensuring compliance with administrative reporting and testing are being developed for implementation by 1/30/2024.			
2	Develop Compliance plan for 40 CFR 63 EEEE (and therein incorporated WW, SS & UU) requirements to identify potential gaps and assign responsibilities.			
3	Develop written programs where required by subparts incorporated by 40 CFR 63 EEEE.			
4	Demonstrate compliance by January 30, 2024.			
6. Previously Submitted	Type of Action			Date

Compliance Schedule

A. Compliance Schedule		
Compliance Plan(s)		Submitted
	N/A	N/A
7. Progress Report Submission Schedule	January 30, 2024, and July 30, 2024	

Compliance Schedule

A. Compliance Schedule				
1. Specific Non-Compliance Situation				
Unit/Group/ Process ID. No(s).	SOP Index No.	Pollutant	Applicable Requirement	
			Citation	Text Description
6-TK-55, 6-TK-56, GRPC4TK3, GRPC4TK4, 27-TK-205, 27-TK-206, 27-TK-207, 27-TK-215, 27-TK-219, 27-TK-220, GRPC4FU1 and LDGPRSFUG		HAPS	63.2334(a), 63.2374 and 63.2378	Demonstrate continuous compliance by monitoring and keep records for all times the source and control device is in OLD operation
2. Compliance Status Assessment Method and Records Location				
Compliance Status Assessment Method			Location of Records/Documentation	
Citation	Text Description			
63.2350, 63 Subpart SS, 63 Subpart UU, 63 Subpart WW	Comply with requirements for closed vent systems for (C4 & MTBE) tanks & High throughput Rail Rack, including control, recordkeeping & reporting. Methanol tanks comply with IFR requirements under WW. Fugitives comply with monitoring, recordkeeping & reporting requirements under Subpart UU.		DCS, LeakDAS, File records	
3. Non-compliance Situation Description				
With the discontinuation of Synthetic Organic Chemical Manufacturing, the site is no longer subject to 40 CFR 63 F, G, and H (Hazardous Organic NESHAPS) Requirements, which previously superseded the requirements of 40 CFR 63 Subpart EEEE -Organics Liquids Distribution (OLD). TPC PNO is now subject to OLD and other subpart requirements (WW, SS & UU) incorporated therein.				
4. Corrective Action Plan Description				
Assess applicable requirements, ensure appropriate methods for demonstrating compliance are in place and establish compliance procedures.				
5. List of Activities/Milestones to Implement the Corrective Action Plan				
1	Existing emission controls meet 40 CFR 63 EEEE (and therein incorporated WW, SS & UU) requirements. However, the programs for ensuring compliance with recordkeeping, administrative reporting and testing are being developed for implementation by 1/30/2024.			
2	Develop Compliance plan for 40 CFR 63 EEEE (and therein incorporated WW, SS & UU) requirements to identify potential gaps and assign responsibilities.			
3	Develop written programs where required by subparts incorporated by 40 CFR 63 EEEE.			
4	Ensure monitoring system and procedures are adequate to comply with the referenced monitoring and recordkeeping requirements in 40 CFR 63 Subpart EEEE.			

Compliance Schedule

A. Compliance Schedule		
5	Demonstrate compliance by January 30, 2024.	
6. Previously Submitted Compliance Plan(s)	Type of Action	
	N/A	Date Submitted
	N/A	N/A
7. Progress Report Submission Schedule	January 30, 2024, and July 30, 2024	

Compliance Schedule

A. Compliance Schedule				
1. Specific Non-Compliance Situation				
Unit/Group/ Process ID. No(s).	SOP Index No.	Pollutant	Applicable Requirement	
			Citation	Text Description
6-TK-55, 6-TK-56, GRPC4TK3, GRPC4TK4, 27-TK-205, 27-TK-206, 27-TK-207, 27-TK-215, 27-TK-219, 27-TK-220, GRPC4FU1 and LDGPRSFUG		HAPS	63.2382(a)	Submit each notification in subpart SS of this part, Table 12 to this subpart, and paragraphs (b) through (d) of this section that applies to you. You must submit these notifications according to the schedule in Table 12 to this subpart and as specified in paragraphs (b) through (d) of this section. You must also comply with the requirements specified in § 63.2346(l).
2. Compliance Status Assessment Method and Records Location				
Compliance Status Assessment Method			Location of Records/Documentation	
Citation	Text Description		DCS, LeakDAS, File records	
63.2350, 63.2386, 63.2390, 63.2394, 63.2398	Comply with requirements for closed vent systems for (C4 & MTBE) tanks & High throughput Rail Rack, including control, recordkeeping & reporting. Methanol tanks comply with IFR requirements under WW. Fugitives comply with monitoring, recordkeeping & reporting requirements under Subpart UU.			
3. Non-compliance Situation Description				
With the discontinuation of Synthetic Organic Chemical Manufacturing, the site is no longer subject to 40 CFR 63 F, G, and H (Hazardous Organic NESHAPS) Requirements which previously superseded the requirements of 40 CFR 63 Subpart EEEE -Organics Liquids Distribution (OLD). TPC PNO is now subject to OLD and other subpart requirements (WW, SS & UU) incorporated therein.				
4. Corrective Action Plan Description				
Assess applicable requirements, ensure appropriate controls and establish compliance procedures.				
5. List of Activities/Milestones to Implement the Corrective Action Plan				
1	Existing emission controls meet 40 CFR 63 EEEE (and therein incorporated WW, SS & UU) requirements; however, the programs for ensuring compliance with administrative reporting and testing are being developed by 1/30/2024.			
2	Develop Compliance plan for 40 CFR 63 EEEE (and therein incorporated WW, SS & UU) to identify potential gaps and assign responsibilities.			
3	Develop written programs where required by the programs for monitoring and recordkeeping.			
4	Demonstrate performance of control equipment by January 30, 2024.			
5	Submit initial notification of compliance status by January 30, 2024, followed by subsequent reports by January 30 and July 30 of each year.			

Compliance Schedule

A. Compliance Schedule		
6. Previously Submitted Compliance Plan(s)	Type of Action	
	N/A	
7. Progress Report Submission Schedule	January 30, 2024, and July 30, 2024	

Appendix A

Acronym List 87

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
SIP	state implementation plan
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound