

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
Pasadena Refining System, Inc.

AUTHORIZING THE OPERATION OF
Pasadena Refinery
Pasadena Refinery System
Petroleum Refineries

LOCATED AT
Harris County, Texas
Latitude 29° 43' 27" Longitude 95° 12' 22"
Regulated Entity Number: RN100716661

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: 03711 Issuance Date: _____

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions:	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements	14
New Source Review Authorization Requirements	16
Compliance Requirements.....	17
Risk Management Plan	18
Protection of Stratospheric Ozone	19
Temporary Fuel Shortages (30 TAC § 112.15)	19
Alternative Requirements.....	20
Permit Location	20
Permit Shield (30 TAC § 122.148).....	20
Attachments	21
Applicable Requirements Summary.....	22
Additional Monitoring Requirements	252
Permit Shield.....	282
New Source Review Authorization References	306
Alternative Requirement.....	320
Appendix A.....	329
Acronym List	330

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
 - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.
 - E. Emission units subject to 40 CFR Part 63, Subparts Y, CC, WW, UUU, EEEE, ZZZZ, DDDDD, or GGGGG as identified in the attached Applicable Requirements Summary

table are subject to 30 TAC Chapter 113, Subchapter C, §§ 113.300, 113.340, 113.540, 113.780, 113.880, 113.1090, 113.1130, or 113.1160, respectively, which incorporate the 40 CFR Part 63 Subparts by reference.

- F. For the purpose of generating emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 1 (Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
- (i) Title 30 TAC § 101.302 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.303 (relating to Emission Reduction Credit Generation Certification)
 - (iii) Title 30 TAC § 101.304 (relating to Mobile Emission Reduction Credit Generation and Certification)
 - (iv) Title 30 TAC § 101.309 (relating to Emission Credit Banking and Trading)
 - (v) The terms and conditions by which the emission limits are established to generate the reduction credit are applicable requirements of this permit
- G. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 3 (Mass Emission Cap and Trade Program) Requirements:
- (i) Title 30 TAC § 101.352 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.353 (relating to Allocation of Allowances)
 - (iii) Title 30 TAC § 101.354 (relating to Allowance Deductions)
 - (iv) Title 30 TAC § 101.356 (relating to Allowance Banking and Trading)
 - (v) Title 30 TAC § 101.359 (relating to Reporting)
 - (vi) Title 30 TAC § 101.360 (relating to Level of Activity Certification)
 - (vii) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit
- H. For the purpose of generating discrete emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 4 (Discrete Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
- (i) Title 30 TAC § 101.372 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.373 (relating to Discrete Emission Reduction Credit Generation and Certification)
 - (iii) Title 30 TAC § 101.374 (relating to Mobile Discrete Emission Reduction Credit Generation and Certification)
 - (iv) Title 30 TAC § 101.378 (relating to Discrete Emission Credit Banking and Trading)

- (v) The terms and conditions by which the emission limits are established to generate the discrete reduction credit are applicable requirements of this permit
- I. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 6 (Highly Reactive Volatile Organic Compound Emissions Cap and Trade Program) requirements:
 - (i) Title 30 TAC § 101.393 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.394 (relating to Allocation of Allowances)
 - (iii) Title 30 TAC § 101.396 (relating to Allowance Deductions)
 - (iv) Title 30 TAC § 101.399 (relating to Allowance Banking and Trading)
 - (v) Title 30 TAC § 101.400 (relating to Reporting)
 - (vi) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit
- 2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
 - A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
- 3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
 - A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit

holder shall comply with the following requirements for stationary vents at the site subject to this standard:

- (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(1)(E)
- (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
- (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the "Applicable Requirements Summary" attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:
 - (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
 - (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
 - (3) Records of all observations shall be maintained.
 - (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet

prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(5) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
 - (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.

(3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A).
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

C. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)
- (iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:

- (1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.
 - (3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
 - (4) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- D. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
- E. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).

- F. Permit holders for sites that have materials handling, construction, roads, streets, alleys, and parking lots shall comply with the following requirements:
 - (i) Title 30 TAC § 111.143 (relating to Materials Handling)
 - (ii) Title 30 TAC § 111.145 (relating to Construction and Demolition)
 - (iii) Title 30 TAC § 111.147 (relating to Roads, Streets, and Alleys)
 - (iv) Title 30 TAC § 111.149 (relating to Parking Lots)

- G. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
 - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)
 - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)

- H. Outdoor burning, as stated in 30 TAC § 111.201, shall not be authorized unless the following requirements are satisfied:
 - (i) Title 30 TAC § 111.205 (relating to Exception for Fire Training)
 - (ii) Title 30 TAC § 111.213 (relating to Exception for Hydrocarbon Burning)
 - (iii) Title 30 TAC § 111.221 (relating to Responsibility for Consequences of Outdoor Burning)

- 4. For storage vessels maintaining working pressure as specified in 30 TAC Chapter 115, Subchapter B, Division 1: Storage of Volatile Organic Compounds, the permit holder shall comply with the requirements of 30 TAC § 115.112(e)(1).

- 5. For industrial wastewater specified in 30 TAC Chapter 115, Subchapter B, the permit holder shall comply with the following requirements for wastewater drains, junction boxes, lift stations and weirs:
 - A. Title 30 TAC § 115.142 (relating to Control Requirements)
 - B. Title 30 TAC § 115.142(1)(A) - (D) (relating to Control Requirements)
 - C. Title 30 TAC § 115.142(1)(E) and (F) (relating to Control Requirements)
 - D. Title 30 TAC § 115.142(1)(G) and (H) (relating to Control Requirements)
 - E. Title 30 TAC § 115.144(1), (5), and (6) (relating to Inspection and Monitoring Requirements)
 - F. Title 30 TAC § 115.145 (relating to Approved Test Methods)

- G. Title 30 TAC § 115.146 (relating to Recordkeeping Requirements)
 - H. Title 30 TAC § 115.147(2) (relating to Exemptions), for streams with an annual VOC loading of 10 megagrams (11.03 tons) or less
 - I. Title 30 TAC § 115.147(7), (7)(A) and (B) (relating to Exemptions)
 - J. Title 30 TAC § 115.148 (relating to Determination of Wastewater Characteristics)
6. Permit holder shall comply with the following 30 TAC Chapter 115, Subchapter C requirements:
- A. When filling stationary gasoline storage vessels (Stage I) for motor vehicle fuel dispensing facilities, constructed prior to November 15, 1992, with transfers to stationary storage tanks located at a facility which has dispensed no more than 10,000 gallons of gasoline in any calendar month after January 1, 1991, the permit holder shall comply with the following requirements specified in 30 TAC Chapter 115, Subchapter C:
 - (i) Title 30 TAC § 115.222(3) (relating to Control Requirements), as it applies to liquid gasoline leaks, visible vapors, or significant odors
 - (ii) Title 30 TAC § 115.222(6) (relating to Control Requirements)
 - (iii) Title 30 TAC § 115.224(1) (relating to Inspection Requirements), as it applies to liquid gasoline leaks, visible vapors, or significant odors
 - (iv) Title 30 TAC § 115.226(2)(B) (relating to Recordkeeping Requirements)
7. Permit holder shall comply with the following 30 TAC Chapter 115, Subchapter D requirements:
- A. Title 30 TAC § 115.312(a)(1) (relating to Control Requirements), for emissions during Process Unit Shutdown or Turnaround
 - B. Title 30 TAC § 115.316(a)(2) (relating to Recordkeeping Requirements), for Process Unit Shutdown or Turnaround
8. The permit holder shall comply with the following requirements of 30 TAC Chapter 115, Subchapter F, Division 3, Degassing of Storage Tanks, Transport Vessels and Marine Vessels:
- A. For degassing of stationary VOC storage tanks, the permit holder shall comply with the following requirements:
 - (i) Title 30 TAC § 115.541(a) - (c) (relating to Emission Specifications)
 - (ii) Title 30 TAC § 115.541(f) (relating to Emission Specifications), for floating roof storage tanks
 - (iii) Title 30 TAC § 115.542(a) and (a)(1), (a)(2), (a)(3) or (a)(4) (relating to Control Requirements). Where the requirements of 30 TAC Chapter 115, Subchapter F contain multiple compliance options, the permit holder shall keep records of when each compliance option was used.
 - (iv) Title 30 TAC § 115.542(b) - (d), (relating to Control Requirements)
 - (v) Title 30 TAC § 115.543 (relating to Alternate Control Requirements)

- (vi) Title 30 TAC § 115.544(a)(1) and (a)(2) (relating to Inspection, Monitoring, and Testing Requirements), for inspections
- (vii) Title 30 TAC § 115.544(b) (relating to Inspection, Monitoring, and Testing Requirements), for monitoring
- (viii) Title 30 TAC § 115.544(b)(1) and (b)(2) (relating to Inspection, Monitoring, and Testing Requirements), for monitoring of control devices
- (ix) Title 30 TAC § 115.544(b)(2)(A) - (J) (relating to Inspection, Monitoring, and Testing Requirements), for monitoring (as appropriate to the control device)
- (x) Title 30 TAC § 115.544(b)(3), (b)(4) and (b)(6) (relating to Inspection, Monitoring, and Testing Requirements), for VOC concentration or lower explosive limit threshold monitoring
- (xi) Title 30 TAC § 115.544(c), and (c)(1) - (c)(3) (relating to Inspection, Monitoring, and Testing Requirements), for testing of control devices used to comply with 30 TAC § 115.542(a)(1)
- (xii) Title 30 TAC § 115.545(1) - (7), (9) - (11) and (13) (relating to Approved Test Methods)
- (xiii) Title 30 TAC § 115.546(a), (a)(1) and (a)(3) (relating to Recordkeeping and Notification Requirements), for recordkeeping
- (xiv) Title 30 TAC § 115.546(a)(2) and (a)(2)(A) - (J) (relating to Recordkeeping and Notification Requirements), for recordkeeping (as appropriate to the control device)
- (xv) Title 30 TAC § 115.546(a)(4) (relating to Recordkeeping and Notification Requirements), for recordkeeping of testing of control devices used to comply with 30 TAC § 115.542(a)(1)
- (xvi) Title 30 TAC § 115.546(b) (relating to Recordkeeping and Notification Requirements), for notification
- (xvii) Title 30 TAC § 115.547(4) (relating to Exemptions)

9. The permit holder shall comply with the following requirements of 30 TAC Chapter 115, Subchapter H, Division 1 for pressure relief devices not controlled by a flare:

- A. Title 30 TAC § 115.725(c)
- B. Title 30 TAC § 115.725(c)(1), (c)(1)(A) - (C)
- C. Title 30 TAC § 115.725(c)(2)
- D. Title 30 TAC § 115.725(c)(3), (c)(3)(A) - (E)
- E. Title 30 TAC § 115.725(c)(4)
- F. Title 30 TAC § 115.725(l)
- G. Title 30 TAC § 115.726(c), (c)(1) - (4)

10. The permit holder shall comply with the requirements of 30 TAC § 115.726(e)(3)(A) for vent streams having no potential to emit HRVOC.
11. The permit holder shall comply with the requirements of 30 TAC § 115.726(e)(3)(A) for vent streams from sources exempt under 30 TAC § 115.727(c)(3).
12. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
 - A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
 - B. Title 40 CFR § 60.8 (relating to Performance Tests)
 - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
 - F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
13. For petroleum refinery facilities subject to 40 CFR Part 60, Subpart QQQ, the permit holder shall comply with the following requirements:
 - A. Title 40 CFR § 60.692-1(a) - (c) (relating to Standards: General)
 - B. Title 40 CFR § 60.692-2(a) - (c), (e) (relating to Standards: Individual Drain Systems)
 - C. Title 40 CFR § 60.692-2(d) (relating to Standards: Individual Drain Systems)
 - D. Title 40 CFR § 60.692-6(a) - (b) (relating to Standards: Delay of Repair)
 - E. Title 40 CFR § 60.692-7(a) - (b) (relating to Standards: Delay of Compliance)
 - F. Title 40 CFR § 60.693-1(a) - (d), (e)(1) - (3) (relating to Alternative Standards for Individual Drain Systems)
 - G. Title 40 CFR § 60.697(a), (b)(1) - (3) (relating to Recordkeeping Requirements), as applicable to Individual Drain Systems
 - H. Title 40 CFR § 60.697(f)(1) - (2), (g) (relating to Recordkeeping Requirements), as applicable to Individual Drain Systems
 - I. Title 40 CFR § 60.697(h) (relating to Recordkeeping Requirements), as applicable to excluded Stormwater Sewer Systems
 - J. Title 40 CFR § 60.697(i) (relating to Recordkeeping Requirements), as applicable to excluded Ancillary Equipment

- K. Title 40 CFR § 60.697(j) (relating to Recordkeeping Requirements), as applicable to excluded Non-contact Cooling Water Systems
 - L. Title 40 CFR § 60.698(a), and (b)(1) (relating to Reporting Requirements), as applicable to Individual Drain Systems
 - M. Title 40 CFR § 60.698(c) (relating to Reporting Requirements), for water seal breaches in Drain Systems
 - N. Title 40 CFR § 60.698(e) (relating to Reporting Requirements), as applicable to Individual Drain Systems
14. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 61, unless otherwise stated in the applicable subpart:
- A. Title 40 CFR § 61.05 (relating to Prohibited Activities)
 - B. Title 40 CFR § 61.07 (relating to Application for Approval of Construction or Modification)
 - C. Title 40 CFR § 61.09 (relating to Notification of Start-up)
 - D. Title 40 CFR § 61.10 (relating to Source Reporting and Request Waiver)
 - E. Title 40 CFR § 61.12 (relating to Compliance with Standards and Maintenance Requirements)
 - F. Title 40 CFR § 61.13 (relating to Emissions Tests and Waiver of Emission Tests)
 - G. Title 40 CFR § 61.14 (relating to Monitoring Requirements)
 - H. Title 40 CFR § 61.15 (relating to Modification)
 - I. Title 40 CFR § 61.19 (relating to Circumvention)
15. For facilities where total annual benzene quantity from waste is greater than or equal to 10 megagrams per year and subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:
- A. Title 40 CFR § 61.342(c)(1)(i) - (iii) (relating to Standards: General)
 - B. Title 40 CFR § 61.342(e)(1) (relating to Standards: General)
 - C. Title 40 CFR § 61.342(e)(2)(i) - (ii) (relating to Standards: General)
 - D. Title 40 CFR § 61.342(f)(1), and (2) (relating to Standards: General)
 - E. Title 40 CFR § 61.342(g) (relating to Standards: General)
 - F. Title 40 CFR § 61.350(a) and (b) (relating to Standards: Delay of Repair)
 - G. Title 40 CFR § 61.355(a)(1)(iii), (a)(2), (a)(6), (b), and (c)(1) - (3) (relating to Test Methods, Procedures, and Compliance Provisions)
 - H. Title 40 CFR § 61.355(k)(1) - (6), and (7)(i) - (iv) (relating to Test Methods, Procedures, and Compliance Provisions), for calculation procedures

- I. Title 40 CFR § 61.356(a) (relating to Recordkeeping Requirements)
 - J. Title 40 CFR § 61.356(b), and (b)(1) (relating to Recordkeeping Requirements)
 - K. Title 40 CFR § 61.356(b)(4) (relating to Recordkeeping Requirements)
 - L. Title 40 CFR § 61.356(b)(5) (relating to Recordkeeping Requirements)
 - M. Title 40 CFR § 61.356(c) (relating to Recordkeeping Requirements)
 - N. Title 40 CFR § 61.357(a), (d)(1), (d)(2) (d)(6) and (d)(8) (relating to Reporting Requirements)
 - O. Title 40 CFR § 61.357(d)(5) (relating to Reporting Requirements)
16. For facilities with containers subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:
- A. Title 40 CFR § 61.345(a)(1) - (3), (b), and (c) (relating to Standards: Containers)
 - B. Title 40 CFR § 61.355(h) (relating to Test Methods, Procedures and Compliance Provisions)
 - C. Title 40 CFR § 61.356(g) (relating to Recordkeeping Requirements)
 - D. Title 40 CFR § 61.356(h) (relating to Recordkeeping Requirements)
17. For facilities with individual drain systems subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:
- A. Title 40 CFR § 61.346(a)(1)(i)(A), (B), (ii), (2), and (3) (relating to Standards: Individual Drain Systems)
 - B. Title 40 CFR § 61.346(b)(1), (2), (2)(i), (3), (4)(i) - (iv), and (5) (relating to Standards: Individual Drain Systems)
 - C. Title 40 CFR § 61.346(b)(2)(ii)(A) (relating to Standards: Individual Drain Systems), for junction boxes
 - D. Title 40 CFR § 61.346(b)(2)(ii)(B) (relating to Standards: Individual Drain Systems), for junction boxes
 - E. Title 40 CFR § 61.355(h) (relating to Test Methods, Procedures and Compliance Provisions)
 - F. Title 40 CFR § 61.356(g) (relating to Recordkeeping Requirements)
 - G. Title 40 CFR § 61.356(h) (relating to Recordkeeping Requirements)
18. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.

19. For sources subject to emission standards in 40 CFR Part 63, Subpart CC, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.340 incorporated by reference):
 - A. Title 40 CFR § 63.640(m) and (m)(1) - (2) (relating to Applicability and Designation of Affected Source), for units and emission points changing from Group 2 to Group 1 status
 - B. Title 40 CFR § 63.642(f) (relating to General Standards), for reporting
 - C. For benzene fenceline monitoring, the permit holder shall comply with the following requirements:
 - (i) Title 40 CFR § 63.658(a) - (k) (relating to Fenceline Monitoring Provisions)
 - (ii) Title 40 CFR § 63.655(h), (h)(8), and (h)(10) (relating to Reporting and Recordkeeping Requirements), for reporting
 - (iii) Title 40 CFR § 63.655(i), (i)(6), and (i)(8) (relating to Reporting and Recordkeeping Requirements), for recordkeeping
20. The permit holder shall comply with the requirement to prepare and implement an Operations and Maintenance plan in accordance with 40 CFR Part 63, Subpart UUU, § 63.1574(f) (Title 30 TAC Chapter 113, Subchapter C, § 113.780 incorporated by reference).
21. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

Additional Monitoring Requirements

22. Unless otherwise specified, the permit holder shall comply with the compliance assurance monitoring requirements as specified in the attached "CAM Summary" upon issuance of the permit. In addition, the permit holder shall comply with the following:
 - A. The permit holder shall comply with the terms and conditions contained in 30 TAC § 122.147 (General Terms and Conditions for Compliance Assurance Monitoring).
 - B. The permit holder shall report, consistent with the averaging time identified in the "CAM Summary," deviations as defined by the deviation limit in the "CAM Summary." Any monitoring data below a minimum limit or above a maximum limit, that is collected in accordance with the requirements specified in 40 CFR § 64.7(c), shall be reported as a deviation. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).
 - C. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "CAM Summary," for purposes of determining whether a deviation has occurred.

However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances in order to avoid reporting deviations. All monitoring data shall be collected in accordance with the requirements specified in 40 CFR § 64.7(c).

- D. The permit holder shall operate the monitoring, identified in the attached “CAM Summary,” in accordance with the provisions of 40 CFR § 64.7.
- E. Except for emission units using a CEMS, COMS or PEMS which meets the requirements of 40 CFR § 64.3(d)(2), the permit holder shall comply with either of the following requirements for any particulate matter capture system associated with the control device subject to CAM. If the results of the following inspections indicate that the capture system is not working properly, the permit holder shall promptly take necessary corrective action:
 - (i) Once per year the permit holder shall inspect any fan for proper operation and inspect the capture system used in compliance of CAM for cracks, holes, tears, and other defects; or
 - (ii) Once per year, the permit holder shall inspect for fugitive emissions escaping from the capture system in compliance of CAM by performing a visible emissions observation for a period of at least six minutes in accordance with 40 CFR Part 60, Appendix A, Test Method 22.
- F. Except for emission units using a CEMS, COMS or PEMS which meets the requirements of 40 CFR § 64.3(d)(2), the permit holder shall comply with either of the following requirements for any capture system associated with the VOC control device subject to CAM. If the results of the following inspections indicate that the capture system is not working properly, the permit holder shall promptly take necessary corrective actions:
 - (i) Once a year the permit holder shall inspect the capture system in compliance of CAM for leaks in accordance with 40 CFR Part 60, Appendix A, Test Method 21. Leaks shall be indicated by an instrument reading greater than or equal to 500 ppm above background or as defined by the underlying applicable requirement; or
 - (ii) Once a month, the permit holder shall conduct a visual, audible, and/or olfactory inspection of the capture system in compliance of CAM to detect leaking components.
- G. Except for emission units using a CEMS, COMS or PEMS which meets the requirements of 40 CFR § 64.3(d)(2), the permit holder shall conduct a once a month visual, audible, and/or olfactory inspection of the capture system to detect leaking components for any capture system associated with the control device subject to CAM. If the results of the following inspections indicate that the capture system is not working properly, the permit holder shall promptly take necessary corrective actions.
- H. Except for emission units using a CEMS, COMS or PEMS which meets the requirements of 40 CFR § 64.3(d)(2), the permit holder shall comply with either of the following requirements for any bypass of the control device subject to CAM. If the results of the following inspections or monitoring indicate bypass of the control device, the permit holder shall promptly take necessary corrective actions and report a deviation:
 - (i) Install a flow indicator that is capable of recording flow, at least once every fifteen minutes, immediately downstream of each valve that if opened would allow a

vent stream to bypass the control device and be emitted, either directly or indirectly, to the atmosphere; or

- (ii) Once a month, the permit holder shall inspect the valves checking the position of the valves and the condition of the car seals. Identify all times when the car seal has been broken and the valve position has been changed to allow a vent stream to bypass the control device and be emitted, either directly or indirectly, to the atmosphere.
- I. The permit holder shall comply with the requirements of 40 CFR § 70.6(a)(3)(ii)(A) and 30 TAC § 122.144(1)(A)-(F) for documentation of all required inspections.
23. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

24. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule (including the terms, conditions, monitoring, recordkeeping, and reporting identified in registered PBRs and permits by rule identified in the PBR Supplemental Tables dated April 12, 2024 in the application for project 32081), standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
- A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
25. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
26. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating

noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).

27. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
- A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
 - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
 - C. Requirements of the non-rule Air Quality Standard Permit for Pollution Control Projects

Compliance Requirements

28. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
29. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:
- A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
 - (i) For sources in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9020:
 - (1) Title 30 TAC § 117.9020(2)(A), (C), and (D)
 - B. The permit holder shall comply with the Initial Control Plan unit listing requirement in 30 TAC § 117.350(c) and (c)(1).
 - C. The permit holder shall comply with the requirements of 30 TAC § 117.354 for Final Control Plan Procedures for Attainment Demonstration Emission Specifications and 30 TAC § 117.356 for Revision of Final Control Plan.
30. Use of Emission Credits to comply with applicable requirements:
- A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) Offsets for Title 30 TAC Chapter 116
 - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)

- (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
- (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)
- (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
- (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)

31. Use of Discrete Emission Credits to comply with the applicable requirements:

- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Risk Management Plan

32. For processes subject to 40 CFR Part 68 and specified in 40 CFR § 68.10, the permit holder shall comply with the requirements of the Accidental Release Prevention Provisions in 40 CFR Part 68. The permit holder shall submit to the appropriate agency either a compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR § 68.10(a), or as part of the compliance certification submitted under this permit, a certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of a risk management plan.

Protection of Stratospheric Ozone

33. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
- A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.
 - B. The permit holder shall comply with the following 40 CFR Part 82, Subpart E requirements for labeling products using ozone-depleting substances:
 - (i) Title 40 CFR § 82.100 (relating to Purpose)
 - (ii) Title 40 CFR § 82.102(a)(1) - (3), (b), (c) (relating to Applicability);
 - (iii) Title 40 CFR § 82.104 (relating to Definitions)
 - (iv) Title 40 CFR § 82.106 - 112 (relating to Warning Statements and Labels)
 - (v) Title 40 CFR § 82.114 (relating to Labeling Containers of Controlled [ozone - depleting] Substances)
 - (vi) Title 40 CFR § 82.116 (relating to Incorporation of Products Manufactured with Controlled [ozone-depleting] Substances)
 - (vii) Title 40 CFR § 82.120 (relating to Petitions)
 - (viii) Title 40 CFR § 82.122 (relating Certification, Recordkeeping, and Notice requirements)
 - (ix) Title 40 CFR § 82.124 (relating to Prohibitions)
 - C. The permit holder shall comply with 40 CFR Part 82, Subpart H related to Halon Emissions Reduction requirements as specified in 40 CFR § 82.250 - § 82.270 and the applicable Part 82 Appendices.

Temporary Fuel Shortages (30 TAC § 112.15)

34. The permit holder shall comply with the following 30 TAC Chapter 112 requirements:
- A. Title 30 TAC § 112.15 (relating to Temporary Fuel Shortage Plan Filing Requirements)
 - B. Title 30 TAC § 112.16(a), (a)(1), and (a)(2)(B) - (C) (relating to Temporary Fuel Shortage Plan Operating Requirements)
 - C. Title 30 TAC § 112.17 (relating to Temporary Fuel Shortage Plan Notification Procedures)
 - D. Title 30 TAC § 112.18 (relating to Temporary Fuel Shortage Plan Reporting Requirements)

Alternative Requirements

35. The permit holder shall comply with the approved alternative means of control (AMOC); alternative monitoring, recordkeeping, or reporting requirements; or requirements determined to be equivalent to an otherwise applicable requirement contained in the Alternative Requirements attachment of this permit. Units complying with an approved alternative requirement have reference to the approval in the Applicable Requirements summary listing for the unit. The permit holder shall maintain the original documentation, from the EPA Administrator and TCEQ Executive Director, demonstrating the method or limitation utilized. Documentation shall be maintained and made available in accordance with 30 TAC § 122.144.

Permit Location

36. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

37. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Alternative Requirement

Applicable Requirements Summary

Unit Summary **23**

Applicable Requirements Summary **46**

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
635G-PV	Emission Points/Stationary Vents/Process Vents	N/A	63-5G-GWREMa	40 CFR Part 63, Subpart GGGGG	Emissions = Vent stream exiting the vent is less than 0.005 cubic meters per minute or is less than 6.0 cubic meters per minute and total HAP concentration is less than 20 parts per million by volume
635G-PV	Emission Points/Stationary Vents/Process Vents	N/A	63-5G-GWREMb	40 CFR Part 63, Subpart GGGGG	Emissions = The average total VOHAP concentration of the material managed by the process vented through the process vent is less than 10 parts per million by weight
BLRHT004	Boilers/Steam Generators/Steam Generating Units	N/A	TX-117B-NG	30 TAC Chapter 117, Subchapter B	Fuel Type #1 = Natural gas.
BLRHT004	Boilers/Steam Generators/Steam Generating Units	N/A	TX-117B-RG	30 TAC Chapter 117, Subchapter B	Fuel Type #1 = Gaseous fuel other than natural gas landfill gas or renewable non-fossil fuel gases.
BLRHT004	Boilers/Steam Generators/Steam Generating Units	N/A	60Db-NG	40 CFR Part 60, Subpart Db	Heat Release Rate = Natural gas oil with a heat release rate greater than 70 MBtu/hr/ft ³ ., D-Series Fuel Type #1 = Natural gas., Subpart J = The affected facility does not meet applicability requirements of 40 CFR Part 60, Subpart J., Subpart E = The affected facility does not meet applicability requirements of 40 CFR Part 60, Subpart E.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
BLRHT004	Boilers/Steam Generators/Steam Generating Units	N/A	60Db-RG	40 CFR Part 60, Subpart Db	Facility Type = The affected facility includes a fuel gas combustion device., Monitoring Device = An instrument is in place for continuous monitoring and recording the concentration (dry basis) of hydrogen sulfide in fuel gasses before being burned in any fuel gas combustion device., Common Fuel Source = The fuel gas combustion device has a common fuel source with other fuel gas combustion devices., D-Series Fuel Type #1 = Gaseous fossil fuel other than natural gas and coal-derived synthetic fuel meeting the definition of natural gas., Subpart J = The affected facility meets applicability requirements of 40 CFR Part 60, Subpart J.
BLRHT004	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-HTR-73to07	40 CFR Part 60, Subpart J	No changing attributes.
BLRHT004	Boilers/Steam Generators/Steam Generating Units	N/A	63DDDDD-BLR	40 CFR Part 63, Subpart DDDDD	No changing attributes.
BLRHT006	Boilers/Steam Generators/Steam Generating Units	N/A	TX-117B-NG-NH3	30 TAC Chapter 117, Subchapter B	Fuel Type #1 = Natural gas.
BLRHT006	Boilers/Steam Generators/Steam Generating Units	N/A	TX-117B-RG-NH3	30 TAC Chapter 117, Subchapter B	Fuel Type #1 = Gaseous fuel other than natural gas landfill gas or renewable non-fossil fuel gases.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
BLRHT006	Boilers/Steam Generators/Steam Generating Units	N/A	60Db-NG	40 CFR Part 60, Subpart Db	Heat Release Rate = Natural gas oil with a heat release rate greater than 70 MBtu/hr/ft ³ ., D-Series Fuel Type #1 = Natural gas., Subpart J = The affected facility does not meet applicability requirements of 40 CFR Part 60, Subpart J., Subpart E = The affected facility does not meet applicability requirements of 40 CFR Part 60, Subpart E.
BLRHT006	Boilers/Steam Generators/Steam Generating Units	N/A	60Db-RG	40 CFR Part 60, Subpart Db	D-Series Fuel Type #1 = Gaseous fossil fuel other than natural gas and coal-derived synthetic fuel meeting the definition of natural gas., Subpart J = The affected facility meets applicability requirements of 40 CFR Part 60, Subpart J.
BLRHT006	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-HTR-73to07	40 CFR Part 60, Subpart J	No changing attributes.
BLRHT006	Boilers/Steam Generators/Steam Generating Units	N/A	63DDDDDD-BLR	40 CFR Part 63, Subpart DDDDDD	No changing attributes.
BLRHT010	Boilers/Steam Generators/Steam Generating Units	N/A	TX-117B-NG	30 TAC Chapter 117, Subchapter B	Fuel Type #1 = Natural gas.
BLRHT010	Boilers/Steam Generators/Steam Generating Units	N/A	TX-117B-RG	30 TAC Chapter 117, Subchapter B	Fuel Type #1 = Gaseous fuel other than natural gas landfill gas or renewable non-fossil fuel gases.
BLRHT010	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	TX-117C-BLR10	30 TAC Chapter 117, Subchapter B	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
C3UL	Loading/Unloading Operations	N/A	TX-115C-LPG	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
CPI	Wastewater Units	N/A	TX-115-WW-C	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.
CPI	Volatile Organic Compound Water Separators	N/A	TX-115-WS-VAP	30 TAC Chapter 115, Water Separation	No changing attributes.
CRUHT001	Process Heaters/Furnaces	N/A	TX117B>200	30 TAC Chapter 117, Subchapter B	No changing attributes.
CRUHT001	Process Heaters/Furnaces	N/A	63DDDDD-HTR	40 CFR Part 63, Subpart DDDDD	No changing attributes.
CRUHT002	Process Heaters/Furnaces	N/A	TX117B-100-200	30 TAC Chapter 117, Subchapter B	No changing attributes.
CRUHT002	Process Heaters/Furnaces	N/A	63DDDDD-HTR	40 CFR Part 63, Subpart DDDDD	No changing attributes.
CRUHT004	Process Heaters/Furnaces	N/A	TX117B-<40	30 TAC Chapter 117, Subchapter B	No changing attributes.
CRUHT004	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60JA-CRUHT	40 CFR Part 60, Subpart Ja	No changing attributes.
CRUHT004	Process Heaters/Furnaces	N/A	63DDDDD-HTR	40 CFR Part 63, Subpart DDDDD	No changing attributes.
CRUVT001	Vacuum Producing Systems	N/A	R5311-1	30 TAC Chapter 115, Unit Turn & Vac System-Pet Ref	No changing attributes.
D-593	Storage Tanks/Vessels	N/A	61FF-5	40 CFR Part 61, Subpart FF	No changing attributes.
D-599	Storage Tanks/Vessels	N/A	63EEEE	40 CFR Part 63, Subpart EEEE	No changing attributes.
DESALTER	Wastewater Units	N/A	TX-115-WW-BSU	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
DOKIN001	Loading/Unloading Operations	N/A	TX-115C-MR>0.5L	30 TAC Chapter 115, Loading and Unloading of VOC	Marine Terminal Exemptions = The marine terminal is not claiming one or more of the loading exemptions in 30 TAC § 115.217(a)(5)(B)., Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline., True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(B), (b)(3)(B), (a)(2)(A), and (b)(3)(A) exemptions do not apply to marine terminals or gasoline terminals., Chapter 115 Control Device Type = Vapor control system with a vapor combustor that is not considered to be a flare, Transfer Type = Only loading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
DOKLO001	Loading/Unloading Operations	N/A	TX-115C- MR>0.5U	30 TAC Chapter 115, Loading and Unloading of VOC	Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline., True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(B), (b)(3)(B), (a)(2)(A), and (b)(3)(A) exemptions do not apply to marine terminals or gasoline terminals., Chapter 115 Control Device Type = Vapor control system with a vapor combustor that is not considered to be a flare, Transfer Type = Only unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
DOKLO001	Loading/Unloading Operations	N/A	TX-115C-MRGasL	30 TAC Chapter 115, Loading and Unloading of VOC	Marine Terminal Exemptions = The marine terminal is not claiming one or more of the loading exemptions in 30 TAC § 115.217(a)(5)(B)., Product Transferred = Gasoline, True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(B), (b)(3)(B), (a)(2)(A), and (b)(3)(A) exemptions do not apply to marine terminals or gasoline terminals., Chapter 115 Control Device Type = Vapor control system with a vapor combustor that is not considered to be a flare, Transfer Type = Only loading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
DOKLO001	Loading/Unloading Operations	N/A	TX-115C- MRGasU	30 TAC Chapter 115, Loading and Unloading of VOC	Product Transferred = Gasoline, True Vapor Pressure = True vapor pressure greater than or equal to 0.5 psia., Daily Throughput = Daily throughput not determined since 30 TAC § 115.217(a)(2)(B), (b)(3)(B), (a)(2)(A), and (b)(3)(A) exemptions do not apply to marine terminals or gasoline terminals., Chapter 115 Control Device Type = Vapor control system with a vapor combustor that is not considered to be a flare, Transfer Type = Only unloading., Control Options = Vapor control system that maintains a control efficiency of at least 90%., Vapor Tight = All liquid and vapor lines are equipped with fittings which make vapor-tight connections that close automatically when disconnected.
DOKIN001	Loading/Unloading Operations	N/A	63Y-UL	40 CFR Part 63, Subpart Y	No changing attributes.
DOKLO001	Loading/Unloading Operations	N/A	TX-115C-MR<0.5L	30 TAC Chapter 115, Loading and Unloading of VOC	Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline., True Vapor Pressure = True vapor pressure less than 0.5 psia., Transfer Type = Only loading.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
DOKLO001	Loading/Unloading Operations	N/A	TX-115C-MR<0.5U	30 TAC Chapter 115, Loading and Unloading of VOC	Product Transferred = Volatile organic compounds other than liquefied petroleum gas and gasoline., True Vapor Pressure = True vapor pressure less than 0.5 psia., Transfer Type = Only unloading.
DOKLO001	Loading/Unloading Operations	N/A	63CC-ML-VCU	40 CFR Part 63, Subpart CC	No changing attributes.
EMGEN001	SRIC Engines	N/A	TX-117B-EM2001+	30 TAC Chapter 117, Subchapter B	No changing attributes.
EMGEN001	SRIC Engines	N/A	63ZZZZ-NOTIFY	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EMGEN002	SRIC Engines	N/A	TX-117B-EM2001+	30 TAC Chapter 117, Subchapter B	No changing attributes.
EMGEN002	SRIC Engines	N/A	60IIII-EMEN-07-	40 CFR Part 60, Subpart IIII	No changing attributes.
EMGEN002	SRIC Engines	N/A	63ZZZZ-NOTIFY2	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EMGEN006	SRIC Engines	N/A	TX-117B-EM2001+	30 TAC Chapter 117, Subchapter B	No changing attributes.
EMGEN006	SRIC Engines	N/A	60IIII-EMEN-10S	40 CFR Part 60, Subpart IIII	No changing attributes.
EMGEN006	SRIC Engines	N/A	63ZZZZ-EXEMPT	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EMGEN007	SRIC Engines	N/A	TX-117B-EM2001+	30 TAC Chapter 117, Subchapter B	No changing attributes.
EMGEN007	SRIC Engines	N/A	60IIII-EMEN-11S	40 CFR Part 60, Subpart IIII	No changing attributes.
EMGEN007	SRIC Engines	N/A	63ZZZZ-EXEMPT	40 CFR Part 63, Subpart ZZZZ	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EMWWEN1	SRIC Engines	N/A	TX-117B-EM2001+	30 TAC Chapter 117, Subchapter B	No changing attributes.
EMWWEN1	SRIC Engines	N/A	60III-EMEN-10M	40 CFR Part 60, Subpart III	No changing attributes.
EMWWEN1	SRIC Engines	N/A	63ZZZZ-EXEMPT	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
FCCHT002	Process Heaters/Furnaces	N/A	TX117B-400ppmCO	30 TAC Chapter 117, Subchapter B	No changing attributes.
FCCHT002	Process Heaters/Furnaces	N/A	63DDDDD-HTR	40 CFR Part 63, Subpart DDDDD	No changing attributes.
FLRFNEAST	Flares	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
FLRFNEAST	Flares	N/A	R5720-01	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
FLRFNEAST	Emission Points/Stationary Vents/Process Vents	N/A	TX-115-H-FLARE	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
FLRFNEAST	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60JA-FLARE	40 CFR Part 60, Subpart Ja	No changing attributes.
FLRFNEAST	Flares	N/A	63CC-01	40 CFR Part 63, Subpart CC	No changing attributes.
FLRFNWEST	Flares	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
FLRFNWEST	Flares	N/A	R5720-01	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
FLRFNWEST	Emission Points/Stationary Vents/Process Vents	N/A	TX-115-H-FLARE	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
FLRFNWEST	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60JA-FLARE	40 CFR Part 60, Subpart Ja	No changing attributes.
FLRFNWEST	Flares	N/A	63CC-01	40 CFR Part 63, Subpart CC	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
FUGCTALK	Industrial Process Cooling Towers	N/A	TX-115H-CT>8000	30 TAC Chapter 115, HRVOC Cooling Towers	No changing attributes.
FUGCTALK	Industrial Process Cooling Towers	N/A	63CC-CT	40 CFR Part 63, Subpart CC	No changing attributes.
FUGCTCPX	Industrial Process Cooling Towers	N/A	TX-115H-CT>8000	30 TAC Chapter 115, HRVOC Cooling Towers	No changing attributes.
FUGCTCPX	Industrial Process Cooling Towers	N/A	63CC-CT	40 CFR Part 63, Subpart CC	No changing attributes.
FUGCTUDX	Industrial Process Cooling Towers	N/A	TX-115H-CT<8000	30 TAC Chapter 115, HRVOC Cooling Towers	No changing attributes.
FUGCTUDX	Industrial Process Cooling Towers	N/A	63CC-CT	40 CFR Part 63, Subpart CC	No changing attributes.
GRP-ALKHT	Process Heaters/Furnaces	ALKHT001, ALKHT002	TX117B-40-100	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRP-ALKHT	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	ALKHT001, ALKHT002	60J-HTR-73to07	40 CFR Part 60, Subpart J	No changing attributes.
GRP-ALKHT	Process Heaters/Furnaces	ALKHT001, ALKHT002	63DDDDD-HTR	40 CFR Part 63, Subpart DDDDD	No changing attributes.
GRP-CC2-1	Storage Tanks/Vessels	TKFTK065, TKFTK335, TKFTK336, TKFTK337	63CC-TK-GRP2	40 CFR Part 63, Subpart CC	No changing attributes.
GRP-CC2-2	Storage Tanks/Vessels	TKFTK205, TKFTK210	TX-115B<1TVP	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRP-CC2-2	Storage Tanks/Vessels	TKFTK205, TKFTK210	63CC-TK-GRP2	40 CFR Part 63, Subpart CC	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRP-CC2-3	Storage Tanks/Vessels	TKFTK307, TKFTK308, TKFTK331, TKFTK820	TX-115B<1TVP	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRP-CC2-3	Storage Tanks/Vessels	TKFTK307, TKFTK308, TKFTK331, TKFTK820	63CC-TK-GRP2	40 CFR Part 63, Subpart CC	No changing attributes.
GRP-CC2-4	Storage Tanks/Vessels	TKFTK051, TKFTK330	TX-115B<1TVP	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRP-CC2-4	Storage Tanks/Vessels	TKFTK051, TKFTK330	63CC-TK-GRP2	40 CFR Part 63, Subpart CC	No changing attributes.
GRP-EMENW	SRIC Engines	EMENW001, EMENW002, EMENW003	TX-117B-EMEN	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRP-EMENW	SRIC Engines	EMENW001, EMENW002, EMENW003	63ZZZZ-EMEN-M	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRP- EMENW2005-	SRIC Engines	EMENW004, EMENW005, EMENW006	TX-117B- EM2001+	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRP- EMENW2005-	SRIC Engines	EMENW004, EMENW005, EMENW006	63ZZZZ-EMEN-M	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRP-NEMENG-L	SRIC Engines	NEMENG001, NEMENG002, NEMENG003	TX-117B-NEM	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRP-NEMENG-L	SRIC Engines	NEMENG001, NEMENG002, NEMENG003	60IIII-NEM-17+L	40 CFR Part 60, Subpart IIII	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRP-NEMENG-L	SRIC Engines	NEMENG001, NEMENG002, NEMENG003	63ZZZZ-NEM	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRP-NEMENG-S	SRIC Engines	NEMENG009, NEMENG010	TX-117B-NEM-HP	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRP-NEMENG-S	SRIC Engines	NEMENG009, NEMENG010	60IIII-NEM-17+S	40 CFR Part 60, Subpart IIII	No changing attributes.
GRP-NEMENG-S	SRIC Engines	NEMENG009, NEMENG010	63ZZZZ-NEM-S	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRP-REFHT	Process Heaters/Furnaces	REFHT001, REFHT002	TX117B-<40	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRP-REFHT	Process Heaters/Furnaces	REFHT001, REFHT002	63DDDDD-HTR	40 CFR Part 63, Subpart DDDDD	No changing attributes.
GRP-TVTKS-1	Storage Tanks/Vessels	TKFTK815, TKFTK816, TKFTK817	TX-115B-EFR	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRP-TVTKS-1	Storage Tanks/Vessels	TKFTK815, TKFTK816, TKFTK817	63CC- TK63WWEFR	40 CFR Part 63, Subpart CC	No changing attributes.
GRP-TVTKS-3	Storage Tanks/Vessels	TKFTK340, TKFTK341, TKFTK353	TX-115B>40K-IFR	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRP-TVTKS-3	Storage Tanks/Vessels	TKFTK340, TKFTK341, TKFTK353	63CC- TK63WWIFR	40 CFR Part 63, Subpart CC	No changing attributes.
GRP-TVTKS-5	Storage Tanks/Vessels	TKFTK824, TKFTK825, TKFTK826	TX-115B>1.5TVP	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRP-TVTKS-5	Storage Tanks/Vessels	TKFTK824, TKFTK825, TKFTK826	63CC-TK824- 63WW	40 CFR Part 63, Subpart CC	No changing attributes.
GRP-TVTKS-8	Storage Tanks/Vessels	TKFTK808, TKFTK810, TKFTK811, TKFTK812, TKFTK813, TKFTK818, TKFTK827	TX-115B>1.5TVP	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRP-TVTKS-8	Storage Tanks/Vessels	TKFTK808, TKFTK810, TKFTK811, TKFTK812, TKFTK813, TKFTK818, TKFTK827	63CC- TK63WWEFR	40 CFR Part 63, Subpart CC	No changing attributes.
GRP-TVTKS-9	Storage Tanks/Vessels	TKFTK830, TKFTK831	TX-115B-EFR	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRP-TVTKS-9	Storage Tanks/Vessels	TKFTK830, TKFTK831	63CC- TK63WWEFR	40 CFR Part 63, Subpart CC	No changing attributes.
GRP-VT-63CC	Emission Points/Stationary Vents/Process Vents	AD-D-2, MD-D-1	63CC-VT-GRP1	40 CFR Part 63, Subpart CC	No changing attributes.
GRP-VT-CRU	Emission Points/Stationary Vents/Process Vents	HTCRU001, HTCRU001-S	TX-111<72-HF	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRP-VT-CRU	Emission Points/Stationary Vents/Process Vents	HTCRU001, HTCRU001-S	TX-115-H-VT	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
GRP-VT-HTR<72	Emission Points/Stationary Vents/Process Vents	HTCRU002, HTCRU004, HTFCC002	TX-111<72-LF	30 TAC Chapter 111, Visible Emissions	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRP-VT-HTR<72	Emission Points/Stationary Vents/Process Vents	HTCRU002, HTCRU004, HTFCC002	TX-115-H-VT	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
GRP-VT-HTR>72	Emission Points/Stationary Vents/Process Vents	HTALK001, HTALK002, HTBLR004, HTBLR006, HTLSG001, HTREF001, HTREF002	TX-111>72-LF	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRP-VT-HTR>72	Emission Points/Stationary Vents/Process Vents	HTALK001, HTALK002, HTBLR004, HTBLR006, HTLSG001, HTREF001, HTREF002	TX-115-H-VT	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
GRP-VT-LOWVOC	Emission Points/Stationary Vents/Process Vents	MSSBZSTR, VTLSG001	TX-111>72-LF	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRP-VT-LOWVOC	Emission Points/Stationary Vents/Process Vents	MSSBZSTR, VTLSG001	TX-115-VT<100#	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
GRP-VT-LSG-REF	Emission Points/Stationary Vents/Process Vents	VTLSG002, VTLSG003, VTREF001	TX-111>72-LF	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRP-VT-VE<72	Emission Points/Stationary Vents/Process Vents	VTFCC001, VTFCC002	TX-111<72-LF	30 TAC Chapter 111, Visible Emissions	No changing attributes.
HTBLR010	Emission Points/Stationary Vents/Process Vents	N/A	TX-111-OPMON	30 TAC Chapter 111, Visible Emissions	No changing attributes.
HTBLR010	Emission Points/Stationary Vents/Process Vents	N/A	TX-115-H-VT	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
HTREF201	Emission Points/Stationary Vents/Process Vents	N/A	TX-111>72-LF	30 TAC Chapter 111, Visible Emissions	No changing attributes.
HTREF201	Emission Points/Stationary Vents/Process Vents	N/A	TX-115-H-VT	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
HTREF2631	Emission Points/Stationary Vents/Process Vents	N/A	TX-111>72-HF	30 TAC Chapter 111, Visible Emissions	No changing attributes.
HTREF2631	Emission Points/Stationary Vents/Process Vents	N/A	TX-115-H-VT	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
INDOK001	Emission Points/Stationary Vents/Process Vents	N/A	TX-111>72-LF	30 TAC Chapter 111, Visible Emissions	No changing attributes.
INSRU001	Emission Points/Stationary Vents/Process Vents	N/A	TX-111<72-LF	30 TAC Chapter 111, Visible Emissions	No changing attributes.
LABWST	Storage Tanks/Vessels	N/A	61FF-LABWST	40 CFR Part 61, Subpart FF	No changing attributes.
LOAD-UNLD	Loading/Unloading Operations	N/A	TX-115C>0.5	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
LODOK001	Loading/Unloading Operations	N/A	TX-115C-MR<0.5L	30 TAC Chapter 115, Loading and Unloading of VOC	Transfer Type = Only loading.
LODOK001	Loading/Unloading Operations	N/A	TX-115C-MR<0.5U	30 TAC Chapter 115, Loading and Unloading of VOC	Transfer Type = Only unloading.
LSGHT001	Process Heaters/Furnaces	N/A	TX117B-310C	30 TAC Chapter 117, Subchapter B	No changing attributes.
LSGHT001	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-HTR-73to07	40 CFR Part 60, Subpart J	No changing attributes.
LSGHT001	Process Heaters/Furnaces	N/A	63DDDDD-HTR	40 CFR Part 63, Subpart DDDDD	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
NEMENG004	SRIC Engines	N/A	TX-117B-NEM	30 TAC Chapter 117, Subchapter B	No changing attributes.
NEMENG004	SRIC Engines	N/A	60III-NEM-2013	40 CFR Part 60, Subpart III	No changing attributes.
NEMENG004	SRIC Engines	N/A	63ZZZZ-NEM	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
NEMENG008	SRIC Engines	N/A	TX-117B-NEM-HP	30 TAC Chapter 117, Subchapter B	No changing attributes.
NEMENG008	SRIC Engines	N/A	60III-NEM-2016	40 CFR Part 60, Subpart III	No changing attributes.
NEMENG008	SRIC Engines	N/A	63ZZZZ-NEM-S	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
OILDSUMP	Storage Tanks/Vessels	N/A	61FF-5	40 CFR Part 61, Subpart FF	No changing attributes.
REFHT201	Process Heaters/Furnaces	N/A	TX117B-40-100	30 TAC Chapter 117, Subchapter B	No changing attributes.
REFHT201	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60JA-REFHT	40 CFR Part 60, Subpart Ja	No changing attributes.
REFHT201	Process Heaters/Furnaces	N/A	63DDDDD-HTR	40 CFR Part 63, Subpart DDDDD	No changing attributes.
REFHT2631	Process Heaters/Furnaces	N/A	TX117B>200FGR	30 TAC Chapter 117, Subchapter B	No changing attributes.
REFHT2631	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-HTR-73to07	40 CFR Part 60, Subpart J	No changing attributes.
REFHT2631	Process Heaters/Furnaces	N/A	63DDDDD-HTR	40 CFR Part 63, Subpart DDDDD	No changing attributes.
REFUNLOAD	Loading/Unloading Operations	N/A	R5211-4	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
REFUNLOAD	Loading/Unloading Operations	N/A	63EEEE-3	40 CFR Part 63, Subpart EEEE	No changing attributes.
SRU-UNLOAD	Loading/Unloading Operations	N/A	TX-115C-U<0.5	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
SRU-UNLOAD	Loading/Unloading Operations	N/A	63EEEE-4	40 CFR Part 63, Subpart EEEE	No changing attributes.
SRU001	Gas Sweetening/Sulfur Recovery Units	N/A	REG2-SRUIN001	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
SRU001	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-SRU	40 CFR Part 60, Subpart J	No changing attributes.
SRUIN001	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-HTR-73to07	40 CFR Part 60, Subpart J	No changing attributes.
TKFTK202	Storage Tanks/Vessels	N/A	61FF-TK-EFR	40 CFR Part 61, Subpart FF	No changing attributes.
TKFTK202	Storage Tanks/Vessels	N/A	63CC-TK63WWEFR	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK250	Storage Tanks/Vessels	N/A	TX-115B<1TVP	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TKFTK250	Volatile Organic Compound Water Separators	N/A	TX-115-WS-ROOF	30 TAC Chapter 115, Water Separation	No changing attributes.
TKFTK250	Storage Tanks/Vessels	N/A	60Kb-VOL-IFR	40 CFR Part 60, Subpart Kb	No changing attributes.
TKFTK250	Volatile Organic Compound Water Separators	N/A	60QQQ-Kb	40 CFR Part 60, Subpart QQQ	No changing attributes.
TKFTK250	Volatile Organic Compound Water Separators	N/A	61FF-Kb	40 CFR Part 61, Subpart FF	No changing attributes.
TKFTK250	Storage Tanks/Vessels	N/A	61FF-TK-IFR2SL	40 CFR Part 61, Subpart FF	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
TKFTK250	Storage Tanks/Vessels	N/A	63CC- TK63WWIFR	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK301	Storage Tanks/Vessels	N/A	TX-115B>40K-IFR	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TKFTK301	Volatile Organic Compound Water Separators	N/A	TX-115-WS- ROOF	30 TAC Chapter 115, Water Separation	No changing attributes.
TKFTK301	Volatile Organic Compound Water Separators	N/A	61FF-Kb	40 CFR Part 61, Subpart FF	No changing attributes.
TKFTK301	Storage Tanks/Vessels	N/A	61FF-TK-IFR2SL	40 CFR Part 61, Subpart FF	No changing attributes.
TKFTK301	Storage Tanks/Vessels	N/A	63CC- TK63WWIFR	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK309	Storage Tanks/Vessels	N/A	TX-115B<1TVP	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TKFTK309	Storage Tanks/Vessels	N/A	61FF-TK-IFR2SL	40 CFR Part 61, Subpart FF	No changing attributes.
TKFTK309	Storage Tanks/Vessels	N/A	63CC-TK-GRP2	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK328	Storage Tanks/Vessels	N/A	TX-115B>40K-IFR	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TKFTK328	Volatile Organic Compound Water Separators	N/A	TX-115-WS- ROOF	30 TAC Chapter 115, Water Separation	No changing attributes.
TKFTK328	Volatile Organic Compound Water Separators	N/A	61FF-Kb	40 CFR Part 61, Subpart FF	No changing attributes.
TKFTK328	Storage Tanks/Vessels	N/A	61FF-TK-EFR	40 CFR Part 61, Subpart FF	No changing attributes.
TKFTK328	Storage Tanks/Vessels	N/A	63CC- TK63WWEFR	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK332	Storage Tanks/Vessels	N/A	TX-115B>40K-IFR	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
TKFTK332	Storage Tanks/Vessels	N/A	63CC- TKG1>11TVP	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK342	Storage Tanks/Vessels	N/A	TK-115B>40K-IFR	30 TAC Chapter 115, Storage of VOCs	Storage Capacity = Capacity is greater than 40,000 gallons, Product Stored = VOC other than crude oil or condensate
TKFTK342	Storage Tanks/Vessels	N/A	TX-115B-TK342	30 TAC Chapter 115, Storage of VOCs	Storage Capacity = Capacity is greater than 40,000 gallons, Product Stored = Crude oil and/or condensate
TKFTK342	Storage Tanks/Vessels	N/A	63CC- TK63WWIFR	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK343	Storage Tanks/Vessels	N/A	TX-115B>40K-IFR	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TKFTK343	Storage Tanks/Vessels	N/A	63CC-TK343- 63WW	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK345	Storage Tanks/Vessels	N/A	61FF-TK-EFR	40 CFR Part 61, Subpart FF	No changing attributes.
TKFTK345	Storage Tanks/Vessels	N/A	63CC-TK-GRP2	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK349	Storage Tanks/Vessels	N/A	TX-115B>40K-IFR	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TKFTK349	Storage Tanks/Vessels	N/A	63CC- TK63WWIFR	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK350	Storage Tanks/Vessels	N/A	TX-115B>40K-IFR	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TKFTK350	Storage Tanks/Vessels	N/A	63CC-TK350- 63WW	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK400	Wastewater Units	N/A	TX-115-WW-FRV	30 TAC Chapter 115, Industrial Wastewater	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
TKFTK400	Storage Tanks/Vessels	N/A	TX-115B>1.5TVP	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TKFTK400	Storage Tanks/Vessels	N/A	60Kb-VOL-EFR	40 CFR Part 60, Subpart Kb	No changing attributes.
TKFTK400	Storage Tanks/Vessels	N/A	61FF-TK-EFR	40 CFR Part 61, Subpart FF	No changing attributes.
TKFTK400	Storage Tanks/Vessels	N/A	63CC- TK63WWEFR	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK807	Storage Tanks/Vessels	N/A	TX-115B-EFR	30 TAC Chapter 115, Storage of VOCs	Storage Capacity = Capacity is greater than 40,000 gallons, Product Stored = Crude oil and/or condensate
TKFTK807	Storage Tanks/Vessels	N/A	TX-115B>1.5TVP	30 TAC Chapter 115, Storage of VOCs	Storage Capacity = Capacity is greater than 40,000 gallons, Product Stored = VOC other than crude oil or condensate
TKFTK807	Storage Tanks/Vessels	N/A	63CC- TK63WWEFR	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK814	Storage Tanks/Vessels	N/A	TX-115B>1.5TVP	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TKFTK814	Storage Tanks/Vessels	N/A	63CC- TKG1>11TVP	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTK822	Storage Tanks/Vessels	N/A	TX-115B-EFR	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TKFTK822	Storage Tanks/Vessels	N/A	63CC- TK63WWEFR	40 CFR Part 63, Subpart CC	No changing attributes.
TKFTKD48	Storage Tanks/Vessels	N/A	63EEEE-5	40 CFR Part 63, Subpart EEEE	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
TRRLOLPG	Loading/Unloading Operations	N/A	TX-115C-L>0.5	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
TVCVSEAST	Fugitive Emission Units	N/A	63CCVV-48210	40 CFR Part 63, Subpart CC	No changing attributes.
TVCVSWEST	Fugitive Emission Units	N/A	63CCVV-48210	40 CFR Part 63, Subpart CC	No changing attributes.
TVFCCPROC	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	63UUU-FCC	40 CFR Part 63, Subpart UUU	No changing attributes.
TVFUG-115VOC	Fugitive Emission Units	N/A	R5352-01	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	No changing attributes.
TVFUG-63CC	Fugitive Emission Units	N/A	63CCVV-648	40 CFR Part 63, Subpart CC	No changing attributes.
TVFUG-63CCJ1	Fugitive Emission Units	N/A	63CCVV-648J1	40 CFR Part 63, Subpart CC	No changing attributes.
TVFUG-63CCJ2	Fugitive Emission Units	N/A	63CCVV-648J2	40 CFR Part 63, Subpart CC	No changing attributes.
TVFUG-63CCJ3	Fugitive Emission Units	N/A	63CCVV-648J3	40 CFR Part 63, Subpart CC	No changing attributes.
TVFUG-63CCJ4	Fugitive Emission Units	N/A	63CCVV-648J4	40 CFR Part 63, Subpart CC	No changing attributes.
TVFUG-63CCJ5	Fugitive Emission Units	N/A	63CCVV-648J5	40 CFR Part 63, Subpart CC	No changing attributes.
TVFUG-63GGGGG	Fugitive Emission Units	N/A	63GGGGG-7915	40 CFR Part 63, Subpart GGGGG	No changing attributes.
TVFUG-GGGA	Fugitive Emission Units	N/A	60GGGa-590a	40 CFR Part 60, Subpart GGGa	No changing attributes.
TVFUG-HRVOC	Fugitive Emission Units	N/A	R5780-01	30 TAC Chapter 115, HRVOC Fugitive Emissions	No changing attributes.
TVREF3PROC	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	63UUU-REF3	40 CFR Part 63, Subpart UUU	No changing attributes.
TVSRUPROC	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	63UUU-SRU	40 CFR Part 63, Subpart UUU	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
VTCCG2	Emission Points/Stationary Vents/Process Vents	N/A	63CC-VT-GRP2	40 CFR Part 63, Subpart CC	No changing attributes.
VTCCMT	Emission Points/Stationary Vents/Process Vents	N/A	63CC-VT-MAINT	40 CFR Part 63, Subpart CC	No changing attributes.
VTFCC003	Emission Points/Stationary Vents/Process Vents	N/A	TX-111-CATREG	30 TAC Chapter 111, Visible Emissions	No changing attributes.
VTFCC003	Emission Points/Stationary Vents/Process Vents	N/A	TX-115-VT<100#	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
WPSLS	Volatile Organic Compound Water Separators	N/A	TX-115-WS-ENCL	30 TAC Chapter 115, Water Separation	No changing attributes.
WPSLS	Volatile Organic Compound Water Separators	N/A	60QQQ-C	40 CFR Part 60, Subpart QQQ	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
635G-PV	EU	63-5G-GWREMa	Exempt	40 CFR Part 63, Subpart GGGGG	§ 63.7885(c) § 63.7885(c)(1) § 63.7885(c)(1)(i) § 63.7885(c)(1)(ii) § 63.7885(c)(2) § 63.7935(b) § 63.7937(a) § 63.7937(b) § 63.7938(a) § 63.7938(b) § 63.7938(b)(2) § 63.7938(b)(4) [G]§ 63.7943(a) [G]§ 63.7943(c)	A process vent that meets the exemption requirements in paragraphs (c)(1) and (2) of this section is exempted from the requirements in paragraph (b) of this section.	[G]§ 63.694(m) § 63.7940(c) § 63.7941(a) § 63.7941(d) [G]§ 63.7943(b) [G]§ 63.7943(c) § 63.7943(d) § 63.7944(a) § 63.7944(b) § 63.7944(b)(1) [G]§ 63.7944(b)(2) § 63.7944(c) § 63.7944(d) § 63.7946(a) § 63.7946(b)	§ 63.7885(c)(2) [G]§ 63.7943(b) [G]§ 63.7943(c) § 63.7944(b)(1) § 63.7944(c) § 63.7946(a) § 63.7952(a) § 63.7952(a)(1) § 63.7952(a)(2) § 63.7952(a)(3) § 63.7952(a)(9) § 63.7952(c) § 63.7953(a) § 63.7953(b) § 63.7953(c) § 63.7953(d)	§ 63.7883(e) § 63.7935(e) § 63.7935(f) [G]§ 63.7937(b)(4) § 63.7941(a) § 63.7941(m) § 63.7950(a) § 63.7950(b) § 63.7950(c) § 63.7950(d) [G]§ 63.7950(e) [G]§ 63.7951(a) § 63.7951(b) § 63.7951(b)(1) § 63.7951(b)(2) § 63.7951(b)(3) § 63.7951(b)(5) [G]§ 63.7951(b)(7) § 63.7951(d) § 63.7951(f) [G]§ 63.7951(g) [G]§ 63.7951(h) § 63.7953(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
635G-PV	EU	63-5G-GWREMB	VHAP	40 CFR Part 63, Subpart GGGGG	§ 63.7885(b)(2) § 63.7935(b) § 63.7937(a) § 63.7937(b) [G]§ 63.7943(a) [G]§ 63.7943(c)	You determine for the remediation material treated or managed by the process vented through the affected process vents that the average total volatile organic hazardous air pollutant (VOHAP) concentration, as defined in §63.7957, of this material is less than 10 parts per million by weight (ppmw). Determination of the VOHAP concentration is made using the procedures specified in §63.7943.	§ 63.7940(c) § 63.7941(a) § 63.7941(d) [G]§ 63.7943(b) [G]§ 63.7943(c) § 63.7943(d) § 63.7944(a) § 63.7944(b) § 63.7944(b)(1) [G]§ 63.7944(b)(2) § 63.7944(c) § 63.7944(d) § 63.7946(a) § 63.7946(b)	[G]§ 63.7943(b) [G]§ 63.7943(c) § 63.7944(b)(1) § 63.7944(c) § 63.7946(a) § 63.7952(a) § 63.7952(a)(1) § 63.7952(a)(2) § 63.7952(a)(3) § 63.7952(a)(9) § 63.7952(c) § 63.7953(a) § 63.7953(b) § 63.7953(c) § 63.7953(d)	§ 63.7883(e) § 63.7935(e) § 63.7935(f) § 63.7937(b)(2) § 63.7941(a) § 63.7941(m) § 63.7950(a) § 63.7950(b) § 63.7950(c) § 63.7950(d) [G]§ 63.7950(e) [G]§ 63.7951(a) § 63.7951(b) § 63.7951(b)(1) § 63.7951(b)(2) § 63.7951(b)(3) § 63.7951(b)(5) [G]§ 63.7951(b)(7) § 63.7951(d) § 63.7951(f) [G]§ 63.7951(g) [G]§ 63.7951(h) § 63.7953(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT004	EU	TX-117B-NG	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT004	EU	TX-117B-NG	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT004	EU	TX-117B-RG	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT004	EU	TX-117B-RG	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT004	EU	60Db-NG	NO _x	40 CFR Part 60, Subpart Db	§ 60.44b(a)(1)(ii) § 60.44b(h) § 60.44b(i) § 60.46b(a)	Except as in §60.44b(k), (l), on/after §60.8 test, no facility combusting natural gas and distillate oil (high heat release rate) shall discharge gases containing NO _x in excess of 86 ng/J heat input.	§ 60.46b(c) § 60.46b(e) § 60.46b(e)(1) § 60.46b(e)(3) [G]§ 60.48b(b) § 60.48b(c) § 60.48b(d) § 60.48b(e) [G]§ 60.48b(e)(2) § 60.48b(e)(3) § 60.48b(f)	[G]§ 60.48b(b) § 60.48b(c) [G]§ 60.49b(d) [G]§ 60.49b(g) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3) § 60.49b(b) § 60.49b(h) § 60.49b(i) § 60.49b(v) § 60.49b(w)
BLRHT004	EU	60Db-NG	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BLRHT004	EU	60Db-NG	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT004	EU	60Db-NG	SO ₂	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BLRHT004	EU	60Db-RG	NO _x	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BLRHT004	EU	60Db-RG	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT004	EU	60Db-RG	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BLRHT004	EU	60Db-RG	SO ₂	40 CFR Part 60, Subpart Db	§ 60.104(a)(1) § 60.104	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from this paragraph.	§ 60.105(a) § 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.105(e) § 60.105(e)(3)(ii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4)	§ 60.105(e) § 60.105(e)(3)(ii) § 60.107(e) § 60.107(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT004	EU	60J-HTR-73to07	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
BLRHT004	EU	63DDDDDD-BLR	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) § 63.7540(a)(1) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT006	EU	TX-117B-NG-NH3	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT006	EU	TX-117B-NG-NH3	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(A)	For boilers that inject urea or ammonia into the exhaust stream for NO _x control, ammonia emissions must not exceed 10 ppmv at 3.0% O ₂ , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3) § 117.340(d) § 117.8000(b) § 117.8000(c) § 117.8000(c)(3) § 117.8000(c)(4) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8130 § 117.8130(1) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(11) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT006	EU	TX-117B-NG-NH3	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT006	EU	TX-117B-RG-NH3	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT006	EU	TX-117B-RG-NH3	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(A)	For boilers that inject urea or ammonia into the exhaust stream for NO _x control, ammonia emissions must not exceed 10 ppmv at 3.0% O ₂ , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3) § 117.340(d) § 117.8000(b) § 117.8000(c) § 117.8000(c)(3) § 117.8000(c)(4) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8130 § 117.8130(1) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(11) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT006	EU	TX-117B-RG-NH3	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT006	EU	60Db-NG	NO _x	40 CFR Part 60, Subpart Db	§ 60.44b(a)(1)(ii) § 60.44b(h) § 60.44b(i) § 60.46b(a)	Except as in §60.44b(k), (l), on/after §60.8 test, no facility combusting natural gas and distillate oil (high heat release rate) shall discharge gases containing NO _x in excess of 86 ng/J heat input.	§ 60.46b(c) § 60.46b(e) § 60.46b(e)(1) § 60.46b(e)(3) [G]§ 60.48b(b) § 60.48b(c) § 60.48b(d) § 60.48b(e) [G]§ 60.48b(e)(2) § 60.48b(e)(3) § 60.48b(f)	[G]§ 60.48b(b) § 60.48b(c) [G]§ 60.49b(d) [G]§ 60.49b(g) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3) § 60.49b(b) § 60.49b(h) § 60.49b(i) § 60.49b(v) § 60.49b(w)
BLRHT006	EU	60Db-NG	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BLRHT006	EU	60Db-NG	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT006	EU	60Db-NG	SO ₂	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BLRHT006	EU	60Db-RG	NO _x	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BLRHT006	EU	60Db-RG	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT006	EU	60Db-RG	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BLRHT006	EU	60Db-RG	SO ₂	40 CFR Part 60, Subpart Db	§ 60.104(a)(1) § 60.104	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from this paragraph.	§ 60.105(a) § 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.105(e) § 60.105(e)(3)(ii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4)	§ 60.105(e) § 60.105(e)(3)(ii) § 60.107(e) § 60.107(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT006	EU	60J-HTR-73to07	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
BLRHT006	EU	63DDDDDD-BLR	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) § 63.7540(a)(1) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT010	EU	TX-117B-NG	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT010	EU	TX-117B-NG	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT010	EU	TX-117B-RG	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT010	EU	TX-117B-RG	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BLRHT010	EU	TX-117C-BLR10	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) [G]§ 117.310(a)(2)(C) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.310(a)(2)(C) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a) § 117.340(c)(1) § 117.340(c)(1)(H) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	[G]§ 117.310(a)(2)(C) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
C3UL	EU	TX-115C-LPG	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(3) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Liquefied petroleum gas. All loading and unloading of liquefied petroleum gas is exempt from the requirements of this division, except for the specified requirements.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i)	§ 115.216 § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	None
CPI	EU	TX-115-WW-C	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) § 115.142(1)(H) § 115.147(7)(A) [G]§ 115.148	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
CPI	EU	TX-115-WS-VAP	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(3) § 115.131(a)	VOC water separator compartments must be equipped with a vapor recovery system which satisfies the provisions of §115.131(a) of this title.	[G]§ 115.135(a) § 115.136(a)(2) § 115.136(a)(2)(C) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(2) § 115.136(a)(2)(C) § 115.136(a)(3) § 115.136(a)(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CRUHT001	EU	TX117B>200	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CRUHT001	EU	TX117B>200	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(A)	For process heaters that inject urea or ammonia into the exhaust stream for NO _x control, ammonia emissions must not exceed 10 ppmv at 3.0% O ₂ , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(d) § 117.8000(b) § 117.8000(c) § 117.8000(c)(3) § 117.8000(c)(4) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8130 § 117.8130(1) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(11) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CRUHT001	EU	TX117B>200	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CRUHT001	EU	63DDDDD-HTR	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CRUHT002	EU	TX117B-100-200	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a) § 117.340(f)(1)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A) ** See Alternative Requirement	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CRUHT002	EU	TX117B-100-200	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(A)	For process heaters that inject urea or ammonia into the exhaust stream for NO _x control, ammonia emissions must not exceed 10 ppmv at 3.0% O ₂ , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(d) § 117.8000(b) § 117.8000(c) § 117.8000(c)(3) § 117.8000(c)(4) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8130 § 117.8130(1) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(11) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CRUHT002	EU	TX117B-100-200	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) ** See Alternative Requirement	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CRUHT002	EU	63DDDDD-HTR	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
CRUHT004	EU	TX117B-<40	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CRUHT004	EU	TX117B-<40	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
CRUHT004	EU	60JA-CRUHT	Hydrogen Sulfide	40 CFR Part 60, Subpart Ja	§ 60.102a(g)(1)(ii) § 60.102a(a) § 60.102a(g) § 60.102a(g)(1) § 60.103a(c) § 60.103a(d) § 60.103a(d)(1) § 60.103a(d)(5) [G]§ 60.103a(e)	For each fuel gas combustion device the owner or operator shall not burn in any fuel gas combustion device any fuel gas that contains H ₂ S in excess of 162 ppmv determined hourly on a 3-hour rolling average basis and H ₂ S in excess of 60 ppmv determined daily on a 365 successive calendar day rolling average basis.	§ 60.104a(a) § 60.104a(c) [G]§ 60.104a(j) § 60.107a(a) § 60.107a(a)(2) § 60.107a(a)(2)(i) § 60.107a(a)(2)(ii) § 60.107a(a)(2)(iii) § 60.107a(a)(2)(iv) § 60.107a(i) § 60.107a(i)(1)(ii)	§ 60.108a(a) § 60.108a(c) [G]§ 60.108a(c)(6) [G]§ 60.108a(d)	§ 60.108a(a) § 60.108a(b) [G]§ 60.108a(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CRUHT004	EU	63DDDDD-HTR	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
CRUVT001	EU	R5311-1	VOC	30 TAC Chapter 115, Unit Turn & Vac System-Pet Ref	§ 115.311(a)(1) § 115.312(a)(2) § 115.312(a)(2)(C)	No emission of VOC from steam ejector or mechanical vacuum pump in a petroleum refinery unless vent stream is burned in accordance with §115.312(a) of this title.	[G]§ 115.315(a) ** See Periodic Monitoring Summary	§ 115.316(a)(3) § 115.316(a)(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
D-593	EU	61FF-5	Benzene	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(ii) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(7)(i) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(7)(i) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(F) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(9)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(D)
D-599	EU	63EEEE	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2338(b) The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart EEEE

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
DESALTER	EU	TX-115-WW-BSU	VOC	30 TAC Chapter 115, Industrial Wastewater	§ 115.142(1) § 115.142 § 115.142(1)(A) § 115.142(1)(B) § 115.142(1)(C) § 115.142(1)(E) § 115.142(1)(G) § 115.142(1)(H) § 115.147(7)(A) [G]§ 115.148	The wastewater component shall meet the specified control requirements.	[G]§ 115.142(1)(H) [G]§ 115.144(1) § 115.144(3) § 115.144(5) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148 ** See CAM Summary	[G]§ 115.142(1)(H) § 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None
DOKIN001	EU	TX-115C-MR>0.5L	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(6)(A) § 115.212(a)(6)(B) [G]§ 115.212(a)(6)(C) § 115.212(a)(6)(D) [G]§ 115.214(a)(3)(A) § 115.214(a)(3)(C) § 115.214(a)(3)(D) § 115.214(a)(3)(E)	At marine terminals, VOC emissions shall not exceed 0.09 pound from the vapor control system vent per 1,000 gallons (10.8kgm/liter) of VOC loaded into the marine vessel, or a vapor control system with 90% efficiency, or a vapor balance system or pressurized loading may be used.	[G]§ 115.214(a)(3)(A) § 115.214(a)(3)(B) § 115.214(a)(3)(B)(i) § 115.214(a)(3)(B)(ii) § 115.214(a)(3)(B)(iii) § 115.214(a)(3)(D) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(7) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(iv)	[G]§ 115.214(a)(3)(A) § 115.214(a)(3)(D) § 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(iv) § 115.216(2) [G]§ 115.216(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
DOKIN001	EU	TX-115C-MR>0.5U	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(5)(B) § 115.214(a)(3)(C) § 115.214(a)(3)(G) § 115.214(a)(3)(G)(i) § 115.217(a)(5)(B)(i)	Unloading of marine vessels is exempt from the requirements of §§115.212(a), 115.214(a), and 115.216 of this title, except as noted.	§ 115.214(a)(3)(B) § 115.214(a)(3)(B)(i)	§ 115.216 § 115.216(2)	None
DOKIN001	EU	TX-115C-MRGasL	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.212(a)(6)(A) § 115.212(a)(6)(B) [G]§ 115.212(a)(6)(C) § 115.212(a)(6)(D) [G]§ 115.214(a)(3)(A) § 115.214(a)(3)(C) § 115.214(a)(3)(D) § 115.214(a)(3)(E)	At marine terminals, VOC emissions shall not exceed 0.09 pound from the vapor control system vent per 1,000 gallons (10.8kg/liter) of VOC loaded into the marine vessel, or a vapor control system with 90% efficiency, or a vapor balance system or pressurized loading may be used.	[G]§ 115.214(a)(3)(A) § 115.214(a)(3)(B) § 115.214(a)(3)(B)(i) § 115.214(a)(3)(B)(ii) § 115.214(a)(3)(B)(iii) § 115.214(a)(3)(D) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(5) § 115.215(7) § 115.215(8) § 115.215(9) § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(iv)	[G]§ 115.214(a)(3)(A) § 115.214(a)(3)(D) § 115.216 § 115.216(1) § 115.216(1)(A) § 115.216(1)(A)(iv) § 115.216(2) [G]§ 115.216(4)	None
DOKIN001	EU	TX-115C-MRGasU	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(5)(B) § 115.214(a)(3)(C) § 115.214(a)(3)(G) § 115.214(a)(3)(G)(i) § 115.217(a)(5)(B)(i)	Unloading of marine vessels is exempt from the requirements of §§115.212(a), 115.214(a), and 115.216 of this title, except as noted.	§ 115.214(a)(3)(B) § 115.214(a)(3)(B)(i)	§ 115.216 § 115.216(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
DOKIN001	EU	63Y-UL	112(B) HAPS	40 CFR Part 63, Subpart Y	§ 63.560(a)(4) § 153.282 § 63.560(a)(2)	Any existing sources with emissions less than 10 tons of any individual HAP and 25 tons of HAP combined must meet the submerged fill standards of 46 CFR 153.282.	§ 63.565(l)	§ 63.567(j)(4)	None
DOKLO001	EU	TX-115C-MR<0.5L	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(5)(B) § 115.212(a)(6)(D) § 115.214(a)(3)(C) § 115.214(a)(3)(G) § 115.214(a)(3)(G)(i) § 115.217(a)(5)(B)(iii)	The marine vessel loading operations specified in §115.217(a)(5)(B)(ii)-(iv) are exempt from the requirements of §§115.212(a), 115.214(a), and 115.216 of this title, except as noted.	§ 115.214(a)(3)(B) § 115.214(a)(3)(B)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2)	None
DOKLO001	EU	TX-115C-MR<0.5U	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(5)(B) § 115.214(a)(3)(C) § 115.214(a)(3)(G) § 115.214(a)(3)(G)(i) § 115.217(a)(5)(B)(i)	Unloading of marine vessels is exempt from the requirements of §§115.212(a), 115.214(a), and 115.216 of this title, except as noted.	§ 115.214(a)(3)(B) § 115.214(a)(3)(B)(i)	§ 115.216 § 115.216(2)	None
DOKLO001	EU	63CC-ML-VCU	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.651(a) § 63.642(b) § 63.642(n)	Except as provided in §63.651(b)-(e), each owner or operator of a marine tank vessel loading operation located at a petroleum refinery shall comply with the requirements of §§63.560 through 63.568.	§ 63.642(d)(1) § 63.642(d)(3) § 63.642(d)(4)	§ 63.642(d)(3) § 63.655(c) § 63.655(i) § 63.655(i)(6)	§ 63.642(d)(2) § 63.642(f) § 63.655(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN001	EU	TX-117B-EM2001+	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
EMGEN001	EU	63ZZZZ-NOTIFY	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(b)(1) § 63.6595(c) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	An affected source which meets either of the criteria in paragraphs §63.6590(b)(1)(i)-(ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(f).	None	None	§ 63.6645(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN002	EU	TX-117B-EM2001+	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
EMGEN002	EU	60IIII-EMEN-07-	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(a)-Table 1 § 60.4206 § 60.4207(b) § 60.4211(b) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and a displacement of less than 10 liters per cylinder and is a pre-2007 model year must comply with a CO emission limit of 11.4 g/KW-hr, as listed in Table 1 to this subpart.	§ 60.4209(a)	§ 60.4211(b)(3) § 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN002	EU	60III-EMEN-07-	Hydrocarbons	40 CFR Part 60, Subpart IIII	§ 60.4205(a)-Table 1 § 60.4206 § 60.4207(b) § 60.4211(b) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and a displacement of less than 10 liters per cylinder and is a pre-2007 model year must comply with an HC emission limit of 1.3 g/KW-hr, as listed in Table 1 to this subpart.	§ 60.4209(a)	§ 60.4211(b)(3) § 60.4214(b)	[G]§ 60.4214(d)
EMGEN002	EU	60III-EMEN-07-	NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(a)-Table 1 § 60.4206 § 60.4207(b) § 60.4211(b) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and a displacement of less than 10 liters per cylinder and is a pre-2007 model year must comply with a NO _x emission limit of 9.2 g/KW-hr, as listed in Table 1 to this subpart.	§ 60.4209(a)	§ 60.4211(b)(3) § 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN002	EU	60IIII-EMEN-07-	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(a)-Table 1 § 60.4206 § 60.4207(b) § 60.4211(b) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and a displacement of less than 10 liters per cylinder and is a pre-2007 model year must comply with a PM emission limit of 0.54 g/KW-hr, as listed in Table 1 to this subpart.	§ 60.4209(a)	§ 60.4211(b)(3) § 60.4214(b)	[G]§ 60.4214(d)
EMGEN002	EU	63ZZZZ-NOTIFY2	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(b)(1) § 63.6595(c) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	An affected source which meets either of the criteria in paragraphs §63.6590(b)(1)(i)-(ii) of this section does not have to meet the requirements of this subpart and of subpart A of this part except for the initial notification requirements of §63.6645(f).	None	None	§ 63.6645(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN006	EU	TX-117B-EM2001+	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN006	EU	60III-EMEN-10S	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
EMGEN006	EU	60III-EMEN-10S	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN006	EU	60IIII-EMEN-10S	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN006	EU	60III-EMEN-10S	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN006	EU	63ZZZZ-EXEMPT	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN007	EU	TX-117B-EM2001+	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN007	EU	60IIII-EMEN-11S	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
EMGEN007	EU	60IIII-EMEN-11S	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN007	EU	60IIII-EMEN-11S	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN007	EU	60III-EMEN-11S	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMGEN007	EU	63ZZZZ-EXEMPT	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMWWEN1	EU	TX-117B-EM2001+	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMWWEN1	EU	60III-EMEN-10M	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
EMWWEN1	EU	60III-EMEN-10M	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMWWEN1	EU	60IIII-EMEN-10M	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMWWEN1	EU	60III-EMEN-10M	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
EMWWEN1	EU	63ZZZZ-EXEMPT	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
FCCHT002	EU	TX117B-400ppmCO	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FCCHT002	EU	TX117B-400ppmCO	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FCCHT002	EU	63DDDDD-HTR	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
FLRFNEAST	CD	R1111-01	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FLRFNEAST	EP	R5720-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(d) § 115.722(d)(1) § 115.722(d)(2) [G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) [G]§ 115.725(l) § 115.725(n) [G]§ 115.726(a)(2)	All flares must continuously meet the requirements of 40 CFR § 60.18(c)(2)-(6) and (d) as amended through October 17, 2000 (65 FR 61744) when vent gas containing HRVOC is being routed to the flare.	[G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) § 115.725(d)(3) § 115.725(d)(4) § 115.725(d)(5) § 115.725(d)(6) § 115.725(d)(7) § 115.725(k)(1)	§ 115.726(a)(1) § 115.726(a)(1)(A) § 115.726(d)(1) § 115.726(d)(10) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n) § 115.726(a)(1)(B) [G]§ 115.726(a)(2)
FLRFNEAST	EP	TX-115-H-FLARE	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(n)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	None	[G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FLRFNEAST	EU	60JA-FLARE	Hydrogen Sulfide	40 CFR Part 60, Subpart Ja	§ 60.103a(h) [G]§ 60.103a(a) [G]§ 60.103a(b) § 60.103a(c) [G]§ 60.103a(c)(1) § 60.103a(d) § 60.103a(d)(1) § 60.103a(d)(2) § 60.103a(d)(3) § 60.103a(d)(5) [G]§ 60.103a(e) § 60.103a(f)	Each owner or operator shall not burn in any affected flare any fuel gas that contains H2S in excess of 162 ppmv determined hourly on a 3-hour rolling average basis. The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from this limit.	[G]§ 60.103a(a) § 60.104a(a) § 60.104a(c) [G]§ 60.104a(j) § 60.107a(a) § 60.107a(a)(2) § 60.107a(a)(2)(i) § 60.107a(a)(2)(ii) § 60.107a(a)(2)(iii) § 60.107a(a)(2)(iv) § 60.107a(a)(2)(vi) [G]§ 60.107a(g) § 60.107a(i) § 60.107a(i)(2)(i) ** See Alternative Requirement	§ 60.108a(c) § 60.108a(c)(1) [G]§ 60.108a(c)(6) [G]§ 60.108a(d)	[G]§ 60.103a(b) [G]§ 60.108a(d)
FLRFNEAST	CD	63CC-01	Opacity	40 CFR Part 63, Subpart CC	§ 63.670(c) § 63.642(b) § 63.642(n) § 63.670 § 63.670(b) § 63.670(d) § 63.670(d)(1) § 63.670(e) § 63.670(o) [G]§ 63.670(o)(1) [G]§ 63.670(o)(2) [G]§ 63.670(o)(3) [G]§ 63.670(o)(4) [G]§ 63.670(o)(5) § 63.670(o)(6) [G]§ 63.670(o)(7) [G]§ 63.671(c)	Visible emissions. The owner or operator shall specify the smokeless design capacity of each flare and operate with no visible emissions, except for periods not to exceed a total of 5 minutes during any 2 consecutive hours, when regulated material is routed to the flare and the flare vent gas flow rate is less than the smokeless design capacity of the flare. The owner or operator shall monitor for visible emissions from the flare as specified in §63.670(h).	§ 63.642(d)(1) § 63.670(b) § 63.670(c) § 63.670(d)(1) § 63.670(e) § 63.670(g) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(j) [G]§ 63.670(k) [G]§ 63.670(m) [G]§ 63.671(a) [G]§ 63.671(b) [G]§ 63.671(c) [G]§ 63.671(d) [G]§ 63.671(e)	§ 63.655(i) § 63.655(i)(6) § 63.655(i)(9) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(j) [G]§ 63.670(o)(1) [G]§ 63.670(o)(5) § 63.670(o)(6) § 63.670(p) [G]§ 63.671(a) [G]§ 63.671(b)	§ 63.642(f) § 63.655(g) § 63.655(g)(11) § 63.655(g)(14) [G]§ 63.670(h) [G]§ 63.670(j) [G]§ 63.670(o)(2) § 63.670(q)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FLRFNWEST	CD	R1111-01	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
FLRFNWEST	EP	R5720-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(d) § 115.722(d)(1) § 115.722(d)(2) [G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) [G]§ 115.725(l) § 115.725(n) [G]§ 115.726(a)(2)	All flares must continuously meet the requirements of 40 CFR § 60.18(c)(2)-(6) and (d) as amended through October 17, 2000 (65 FR 61744) when vent gas containing HRVOC is being routed to the flare.	[G]§ 115.725(d)(1) § 115.725(d)(2) § 115.725(d)(2)(A)(i) [G]§ 115.725(d)(2)(A)(ii) § 115.725(d)(2)(A)(iii) § 115.725(d)(2)(A)(iv) § 115.725(d)(2)(B) § 115.725(d)(2)(B)(i) § 115.725(d)(2)(B)(ii) § 115.725(d)(2)(B)(iii) § 115.725(d)(2)(B)(iv) § 115.725(d)(3) § 115.725(d)(4) § 115.725(d)(5) § 115.725(d)(6) § 115.725(d)(7) § 115.725(k)(1)	§ 115.726(a)(1) § 115.726(a)(1)(A) § 115.726(d)(1) § 115.726(d)(10) § 115.726(d)(2) § 115.726(d)(3) § 115.726(d)(4) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n) § 115.726(a)(1)(B) [G]§ 115.726(a)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FLRFNWEST	EP	TX-115-H-FLARE	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(n)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	None	[G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	§ 115.725(n)
FLRFNWEST	EU	60JA-FLARE	Hydrogen Sulfide	40 CFR Part 60, Subpart Ja	§ 60.103a(h) [G]§ 60.103a(a) [G]§ 60.103a(b) § 60.103a(c) [G]§ 60.103a(c)(1) § 60.103a(d) § 60.103a(d)(1) § 60.103a(d)(2) § 60.103a(d)(3) § 60.103a(d)(5) [G]§ 60.103a(e) § 60.103a(f)	Each owner or operator shall not burn in any affected flare any fuel gas that contains H2S in excess of 162 ppmv determined hourly on a 3-hour rolling average basis. The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from this limit.	[G]§ 60.103a(a) § 60.104a(a) § 60.104a(c) [G]§ 60.104a(j) § 60.107a(a) § 60.107a(a)(2) § 60.107a(a)(2)(i) § 60.107a(a)(2)(ii) § 60.107a(a)(2)(iii) § 60.107a(a)(2)(iv) § 60.107a(a)(2)(vi) [G]§ 60.107a(g) § 60.107a(i) § 60.107a(i)(2)(i) ** See Alternative Requirement	§ 60.108a(c) § 60.108a(c)(1) [G]§ 60.108a(c)(6) [G]§ 60.108a(d)	[G]§ 60.103a(b) [G]§ 60.108a(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FLRFNWEST	CD	63CC-01	Opacity	40 CFR Part 63, Subpart CC	§ 63.670(c) § 63.642(b) § 63.642(n) § 63.670 § 63.670(b) § 63.670(d) § 63.670(d)(1) § 63.670(e) § 63.670(o) [G]§ 63.670(o)(1) [G]§ 63.670(o)(2) [G]§ 63.670(o)(3) [G]§ 63.670(o)(4) [G]§ 63.670(o)(5) § 63.670(o)(6) [G]§ 63.670(o)(7) [G]§ 63.671(c)	Visible emissions. The owner or operator shall specify the smokeless design capacity of each flare and operate with no visible emissions, except for periods not to exceed a total of 5 minutes during any 2 consecutive hours, when regulated material is routed to the flare and the flare vent gas flow rate is less than the smokeless design capacity of the flare. The owner or operator shall monitor for visible emissions from the flare as specified in §63.670(h).	§ 63.642(d)(1) § 63.670(b) § 63.670(c) § 63.670(d)(1) § 63.670(e) § 63.670(g) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(j) [G]§ 63.670(k) [G]§ 63.670(m) [G]§ 63.671(a) [G]§ 63.671(b) [G]§ 63.671(c) [G]§ 63.671(d) [G]§ 63.671(e)	§ 63.655(i) § 63.655(i)(6) § 63.655(i)(9) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(j) [G]§ 63.670(o)(1) [G]§ 63.670(o)(5) § 63.670(o)(6) § 63.670(p) [G]§ 63.671(a) [G]§ 63.671(b)	§ 63.642(f) § 63.655(g) § 63.655(g)(11) § 63.655(g)(14) [G]§ 63.670(h) [G]§ 63.670(j) [G]§ 63.670(o)(2) § 63.670(q)
FUGCTALK	EU	TX-115H-CT>8000	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Cooling Towers	§ 115.761(c)(1) § 115.761(c)(3) § 115.766(i)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 1 of this subchapter must not exceed 1,200 pounds of HRVOCs per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.764(c) § 115.764(f)	§ 115.766(a)(1) § 115.766(a)(2) § 115.766(a)(3) § 115.766(a)(5) § 115.766(a)(6) § 115.766(c) [G]§ 115.766(g) [G]§ 115.766(h) § 115.766(i)(1)	§ 115.766(i)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUGCTALK	EU	63CC-CT	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.654(a) § 63.642(b) § 63.642(n) [G]§ 63.654(d) [G]§ 63.654(f)	Except as specified in §63.654(b), the owner or operator of a heat exchange system that meets the criteria in §63.640(c)(8) must comply with the requirements of §63.654(c)-(g).	§ 63.642(d)(1) § 63.642(d)(3) § 63.642(d)(4) § 63.654(c) [G]§ 63.654(c)(2) § 63.654(c)(3) [G]§ 63.654(c)(4) [G]§ 63.654(c)(6) [G]§ 63.654(d) [G]§ 63.654(f) [G]§ 63.654(g)	§ 63.642(d)(3) [G]§ 63.654(g) § 63.655(i) § 63.655(i)(5) § 63.655(i)(5)(i) § 63.655(i)(5)(ii) [G]§ 63.655(i)(5)(iii) § 63.655(i)(5)(iv) § 63.655(i)(5)(v) § 63.655(i)(6)	§ 63.642(d)(2) § 63.642(f) [G]§ 63.654(c)(4) § 63.655(f) § 63.655(f)(1)(vi) § 63.655(f)(4) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(9) § 63.655(h) § 63.655(h)(7)
FUGTCPX	EU	TX-115H-CT>8000	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Cooling Towers	§ 115.761(c)(1) § 115.761(c)(3) § 115.766(i)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 1 of this subchapter must not exceed 1,200 pounds of HRVOCs per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.764(c) § 115.764(f)	§ 115.766(a)(1) § 115.766(a)(2) § 115.766(a)(3) § 115.766(a)(5) § 115.766(a)(6) § 115.766(c) [G]§ 115.766(g) [G]§ 115.766(h) § 115.766(i)(1)	§ 115.766(i)(2)
FUGTCPX	EU	63CC-CT	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.654(a) § 63.642(b) § 63.642(n) [G]§ 63.654(d) [G]§ 63.654(f)	Except as specified in §63.654(b), the owner or operator of a heat exchange system that meets the criteria in §63.640(c)(8) must comply with the requirements of §63.654(c)-(g).	§ 63.642(d)(1) § 63.642(d)(3) § 63.642(d)(4) § 63.654(c) [G]§ 63.654(c)(2) § 63.654(c)(3) [G]§ 63.654(c)(4) [G]§ 63.654(c)(6) [G]§ 63.654(d) [G]§ 63.654(f) [G]§ 63.654(g)	§ 63.642(d)(3) [G]§ 63.654(g) § 63.655(i) § 63.655(i)(5) § 63.655(i)(5)(i) § 63.655(i)(5)(ii) [G]§ 63.655(i)(5)(iii) § 63.655(i)(5)(iv) § 63.655(i)(5)(v) § 63.655(i)(6)	§ 63.642(d)(2) § 63.642(f) [G]§ 63.654(c)(4) § 63.655(f) § 63.655(f)(1)(vi) § 63.655(f)(4) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(9) § 63.655(h) § 63.655(h)(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUGCTUDX	EU	TX-115H-CT<8000	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Cooling Towers	§ 115.761(c)(1) § 115.761(c)(3) § 115.766(i)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 1 of this subchapter must not exceed 1,200 pounds of HRVOCs per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.764(b)(2) § 115.764(b)(4) § 115.764(b)(5) § 115.764(c) § 115.764(e)(1)	§ 115.766(a)(1) § 115.766(a)(2) § 115.766(a)(3) § 115.766(a)(4) § 115.766(a)(5) § 115.766(a)(6) § 115.766(c) [G]§ 115.766(e) [G]§ 115.766(g) [G]§ 115.766(h) § 115.766(i)(1)	§ 115.766(i)(2)
FUGCTUDX	EU	63CC-CT	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.654(a) § 63.642(b) § 63.642(n) [G]§ 63.654(d) [G]§ 63.654(f)	Except as specified in §63.654(b), the owner or operator of a heat exchange system that meets the criteria in §63.640(c)(8) must comply with the requirements of §63.654(c)-(g).	§ 63.642(d)(1) § 63.642(d)(3) § 63.642(d)(4) § 63.654(c) [G]§ 63.654(c)(2) § 63.654(c)(3) [G]§ 63.654(c)(4) [G]§ 63.654(c)(6) [G]§ 63.654(d) [G]§ 63.654(f) [G]§ 63.654(g)	§ 63.642(d)(3) [G]§ 63.654(g) § 63.655(i) § 63.655(i)(5) § 63.655(i)(5)(i) § 63.655(i)(5)(ii) [G]§ 63.655(i)(5)(iii) § 63.655(i)(5)(iv) § 63.655(i)(5)(v) § 63.655(i)(6)	§ 63.642(d)(2) § 63.642(f) [G]§ 63.654(c)(4) § 63.655(f) § 63.655(f)(1)(vi) § 63.655(f)(4) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(9) § 63.655(h) § 63.655(h)(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-ALKHT	EU	TX117B-40-100	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
GRP-ALKHT	EU	TX117B-40-100	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-ALKHT	EU	60J-HTR-73to07	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
GRP-ALKHT	EU	63DDDDD-HTR	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-CC2-1	EU	63CC-TK-GRP2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
GRP-CC2-2	EU	TX-115B<1TVP	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
GRP-CC2-2	EU	63CC-TK-GRP2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
GRP-CC2-3	EU	TX-115B<1TVP	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-CC2-3	EU	63CC-TK-GRP2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
GRP-CC2-4	EU	TX-115B<1TVP	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
GRP-CC2-4	EU	63CC-TK-GRP2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-EMENW	EU	TX-117B-EMEN	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	§ 117.8140(a) § 117.8140(a)(3)	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
GRP-EMENW	EU	63ZZZZ-EMEN-M	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table 2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-EMENW2005-	EU	TX-117B-EM2001+	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
GRP-EMENW2005-	EU	63ZZZZ-EMEN-M	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table 2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-NEMENG-L	EU	TX-117B-NEM	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B)	CO emissions must not exceed 3.0 g/hp-hr for stationary internal combustion engines.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(C) § 117.340(h) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.801 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-NEMENG-L	EU	TX-117B-NEM	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(9)(E)(vii)(II) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) [G]§ 117.310(f) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(C) § 117.340(h) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.345(f)(3)(B) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-NEMENG-L	EU	60III-NEM-17+L	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039-Appendix I and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None
GRP-NEMENG-L	EU	60III-NEM-17+L	NO _x	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 56 KW but less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2014 model year and later must comply with a NO _x emission limit of 0.40 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-NEMENG-L	EU	60III-NEM-17+L	Nonmethane Hydrocarbons	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 56 KW but less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2014 model year and later must comply with an NMHC emission limit of 0.19 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None
GRP-NEMENG-L	EU	60III-NEM-17+L	PM	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2011 model year and later must comply with a PM emission limit of 0.02 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-NEMENG-L	EU	63ZZZZ-NEM	Formaldehyde	40 CFR Part 63, Subpart ZZZZ	§ 63.6600(b)-Table 2a.3.b § 63.6595(c) § 63.6600(b)-Table 2b.3 § 63.6605(a) § 63.6605(b) § 63.6620(f) § 63.6625(h) § 63.6630(a) § 63.6640(b)	For each new or reconstructed CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, operating at 100% load plus or minus 10%, you must limit the concentration of formaldehyde in the stationary RICE exhaust to 580 ppbvd or less at 15 % O ₂ .	§ 63.6610(a) § 63.6610(b) § 63.6610(c) [G]§ 63.6610(d) § 63.6615 § 63.6620(a) § 63.6620(a)-Table 3.3 § 63.6620(a)-Table 4.3.a.i § 63.6620(a)-Table 4.3.a.ii § 63.6620(a)-Table 4.3.a.iii § 63.6620(a)-Table 4.3.a.iv § 63.6620(b) § 63.6620(b)(4) § 63.6620(d) [G]§ 63.6620(e)(2) § 63.6620(f) [G]§ 63.6625(b) § 63.6630(a)-Table 5.10.a.i § 63.6630(a)-Table 5.10.a.ii § 63.6630(a)-Table 5.10.a.iii § 63.6635(a) § 63.6635(b) § 63.6640(a) § 63.6640(a)-Table 6.8.a.i § 63.6640(a)-Table 6.8.a.ii § 63.6640(a)-Table 6.8.a.iii § 63.6640(a)-Table 6.8.a.iv § 63.6640(b)	§ 63.6620(i) § 63.6630(a)-Table 5.10.a.iii § 63.6635(a) § 63.6635(c) § 63.6655(a) § 63.6655(a)(1) § 63.6655(a)(2) § 63.6655(a)(3) § 63.6655(a)(4) § 63.6655(a)(5) § 63.6655(d) § 63.6660(a) § 63.6660(b) § 63.6660(c)	[G]§ 63.6620(g) § 63.6620(i) § 63.6630(c) § 63.6640(b) § 63.6640(e) § 63.6645(a) § 63.6645(c) § 63.6645(g) § 63.6645(h) § 63.6645(h)(2) § 63.6650(a) § 63.6650(a)-Table 7.1.a.i § 63.6650(a)-Table 7.1.b § 63.6650(a)-Table 7.1.c § 63.6650(b) § 63.6650(b)(1) § 63.6650(b)(2) § 63.6650(b)(3) § 63.6650(b)(4) [G]§ 63.6650(c) [G]§ 63.6650(d) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-NEMENG-S	EU	TX-117B-NEM-HP	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B)	CO emissions must not exceed 3.0 g/hp-hr for stationary internal combustion engines.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(C) § 117.340(h) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.801 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-NEMENG-S	EU	TX-117B-NEM-HP	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(9)(E)(iv)(III) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) [G]§ 117.310(f) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(C) § 117.340(h) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.345(f)(3)(B) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-NEMENG-S	EU	60III-NEM-17+S	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 37 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.0 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039-Appendix I and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None
GRP-NEMENG-S	EU	60III-NEM-17+S	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 37 KW but less than 56 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with an NMHC+NO _x emission limit of 4.7 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039-Appendix I and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-NEMENG-S	EU	60IIII-NEM-17+S	PM	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 19 KW and less than 56 KW and a displacement of less than 10 liters per cylinder and is a 2013 model year and later must comply with a PM emission limit of 0.03 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None
GRP-NEMENG-S	EU	63ZZZZ-NEM-S	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-REFHT	EU	TX117B-<40	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
GRP-REFHT	EU	TX117B-<40	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-REFHT	EU	63DDDDD-HTR	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
GRP-TVTKS-1	EU	TX-115B-EFR	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-TVTKS-1	EU	63CC-TK63WWEFR	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(B) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(2) § 63.1063(c)(2)(i) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1063(c)(2)(iv)(B) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(3)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(2)(ii) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-TVTKS-3	EU	TX-115B>40K-IFR	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-TVTKS-3	EU	63CC-TK63WWIFR	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(1) § 63.1063(a)(1)(i) § 63.1063(a)(1)(i)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(iv) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(1) [G]§ 63.1063(c)(1)(i) [G]§ 63.1063(d)(1) § 63.1063(d)(2) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(2)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-TVTKS-5	EU	TX-115B>1.5TVP	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-TVTKS-5	EU	63CC-TK824-63WW	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(B) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(viii) § 63.1063(a)(2)(viii)(B) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(2) § 63.1063(c)(2)(i) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1063(c)(2)(iv)(B) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(3)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(2)(ii) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-TVTKS-8	EU	TX-115B>1.5TVP	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-TVTKS-8	EU	63CC-TK63WWEFR	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(B) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(2) § 63.1063(c)(2)(i) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1063(c)(2)(iv)(B) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(3)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(2)(ii) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-TVTKS-9	EU	TX-115B-EFR	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-TVTKS-9	EU	63CC-TK63WWEFR	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(B) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(2) § 63.1063(c)(2)(i) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1063(c)(2)(iv)(B) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(3)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(2)(ii) § 63.655(h)(6) § 63.655(h)(6)(ii)
GRP-VT-63CC	EP	63CC-VT-GRP1	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.643(a)(1) § 63.642(b) § 63.642(n) § 63.644(a)(2) § 63.670	For a Group 1 miscellaneous process vent, reduce emissions of organic HAPs using a flare. On and after January 30, 2019, the flare shall meet the requirements of §63.670.	§ 63.644(a) § 63.644(e) § 63.645(a) § 63.645(i)	§ 63.655(i) [G]§ 63.655(i)(3) § 63.655(i)(6)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(ii) [G]§ 63.655(f)(1)(iv) § 63.655(f)(4) § 63.655(g) § 63.655(g)(14) § 63.655(g)(6) § 63.655(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-VT-CRU	EP	TX-111<72-HF	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRP-VT-CRU	EP	TX-115-H-VT	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) [G]§ 115.725(a)(4) [G]§ 115.725(l) § 115.725(n) [G]§ 115.726(a)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(a) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) § 115.725(a)(3)(B) [G]§ 115.725(a)(4) § 115.725(a)(5)	§ 115.726(b)(1) § 115.726(b)(2) § 115.726(b)(3) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	[G]§ 115.725(a)(4) § 115.725(a)(5) § 115.725(n) [G]§ 115.726(a)(2)
GRP-VT-HTR<72	EP	TX-111<72-LF	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-VT-HTR<72	EP	TX-115-H-VT	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) [G]§ 115.725(a)(4) [G]§ 115.725(l) § 115.725(n) [G]§ 115.726(a)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(a) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) § 115.725(a)(3)(B) [G]§ 115.725(a)(4) § 115.725(a)(5)	§ 115.726(b)(1) § 115.726(b)(2) § 115.726(b)(3) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	[G]§ 115.725(a)(4) § 115.725(a)(5) § 115.725(n) [G]§ 115.726(a)(2)
GRP-VT-HTR>72	EP	TX-111>72-LF	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRP-VT-HTR>72	EP	TX-115-H-VT	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) [G]§ 115.725(a)(4) [G]§ 115.725(l) § 115.725(n) [G]§ 115.726(a)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(a) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) § 115.725(a)(3)(B) [G]§ 115.725(a)(4) § 115.725(a)(5)	§ 115.726(b)(1) § 115.726(b)(2) § 115.726(b)(3) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	[G]§ 115.725(a)(4) § 115.725(a)(5) § 115.725(n) [G]§ 115.726(a)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-VT-LOWVOC	EP	TX-111>72-LF	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRP-VT-LOWVOC	EP	TX-115-VT<100#	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(8)	As an alternative to complying with the requirements of this division for a source that is addressed by a Chapter 115 contingency rule, the source may instead choose to comply with the requirements of the contingency rule. Each source choosing this option shall submit written notification to the ED and any local air pollution control program. When the ED and the local program receive such notification, the source will then be considered subject to the contingency rule.	None	None	§ 115.127(a)(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-VT-LSG-REF	EP	TX-111>72-LF	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRP-VT-VE<72	EP	TX-111<72-LF	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
HTBLR010	EP	TX-111-OPMON	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(C) § 111.111(a)(1)(E) § 111.111(a)(2)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	§ 111.111(a)(1)(D) [G]§ 111.111(a)(1)(F) § 111.111(a)(2)	§ 111.111(a)(1)(C) § 111.111(a)(1)(D)	None
HTBLR010	EP	TX-115-H-VT	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) [G]§ 115.725(a)(4) [G]§ 115.725(l) § 115.725(n) [G]§ 115.726(a)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(a) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) § 115.725(a)(3)(B) [G]§ 115.725(a)(4) § 115.725(a)(5)	§ 115.726(b)(1) § 115.726(b)(2) § 115.726(b)(3) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	[G]§ 115.725(a)(4) § 115.725(a)(5) § 115.725(n) [G]§ 115.726(a)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
HTREF201	EP	TX-111>72-LF	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
HTREF201	EP	TX-115-H-VT	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) [G]§ 115.725(a)(4) [G]§ 115.725(l) § 115.725(n) [G]§ 115.726(a)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(a) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) § 115.725(a)(3)(B) [G]§ 115.725(a)(4) § 115.725(a)(5)	§ 115.726(b)(1) § 115.726(b)(2) § 115.726(b)(3) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	[G]§ 115.725(a)(4) § 115.725(a)(5) § 115.725(n) [G]§ 115.726(a)(2)
HTREF2631	EP	TX-111>72-HF	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
HTREF2631	EP	TX-115-H-VT	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.722(c)(1) § 115.722(c)(3) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) [G]§ 115.725(a)(4) [G]§ 115.725(l) § 115.725(n) [G]§ 115.726(a)(2)	HRVOC emissions at each site located in Harris County that is subject to this division or Division 2 of this subchapter must not exceed 1,200 pounds of HRVOC per one-hour block period from any flare, vent, pressure relief valve, cooling tower, or any combination.	§ 115.725(a) § 115.725(a)(1)(A) § 115.725(a)(1)(B) § 115.725(a)(1)(C) § 115.725(a)(3) § 115.725(a)(3)(B) [G]§ 115.725(a)(4) § 115.725(a)(5)	§ 115.726(b)(1) § 115.726(b)(2) § 115.726(b)(3) [G]§ 115.726(h) § 115.726(i) § 115.726(j)(1) § 115.726(j)(2)	[G]§ 115.725(a)(4) § 115.725(a)(5) § 115.725(n) [G]§ 115.726(a)(2)
INDOK001	EP	TX-111>72-LF	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
INSRU001	EP	TX-111<72-LF	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
LABWST	EU	61FF-LABWST	Benzene	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(ii) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(d) [G]§ 61.355(h)	§ 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(G) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(10) § 61.356(j)(2) § 61.356(j)(3)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(l)
LOAD-UNLD	EU	TX-115C>0.5	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(2)(A) § 115.212(a)(2) [G]§ 115.212(a)(7) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Any plant, excluding gasoline bulk plants, which loads less than 20,000 gpd of VOC with a true vapor pressure of 0.5 psia or greater is exempt from the requirements of this division, except for the specified requirements.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B) § 115.216(3)(D)	None
LODOK001	EU	TX-115C-MR<0.5L	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(5)(B) § 115.212(a)(6)(D) § 115.214(a)(3)(C) § 115.214(a)(3)(G) § 115.214(a)(3)(G)(i) § 115.217(a)(5)(B)(iii)	The marine vessel loading operations specified in §115.217(a)(5)(B)(ii)-(iv) are exempt from the requirements of §§115.212(a), 115.214(a), and 115.216 of this title, except as noted.	§ 115.214(a)(3)(B) § 115.214(a)(3)(B)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
LODOK001	EU	TX-115C-MR<0.5U	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(5)(B) § 115.214(a)(3)(C) § 115.214(a)(3)(G) § 115.214(a)(3)(G)(i) § 115.217(a)(5)(B)(i)	Unloading of marine vessels is exempt from the requirements of §§115.212(a), 115.214(a), and 115.216 of this title, except as noted.	§ 115.214(a)(3)(B) § 115.214(a)(3)(B)(i)	§ 115.216 § 115.216(2)	None
LSGHT001	EU	TX117B-310C	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
LSGHT001	EU	TX117B-310C	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
LSGHT001	EU	60J-HTR-73to07	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
LSGHT001	EU	63DDDDD-HTR	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
NEMENG004	EU	TX-117B-NEM	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B)	CO emissions must not exceed 3.0 g/hp-hr for stationary internal combustion engines.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(C) § 117.340(h) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.801 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
NEMENG004	EU	TX-117B-NEM	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(9)(E)(vii)(II) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) [G]§ 117.310(f) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(C) § 117.340(h) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.345(f)(3)(B) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
NEMENG004	EU	60IIII-NEM-2013	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039-Appendix I and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None
NEMENG004	EU	60IIII-NEM-2013	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 75 KW but less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 - 2013 model year must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039-Appendix I and 40 CFR 1039.102.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
NEMENG004	EU	60III-NEM-2013	PM	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.102 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 130 KW and less than 560 KW and a displacement of less than 10 liters per cylinder and is a 2011 model year and later must comply with a PM emission limit of 0.02 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
NEMENG004	EU	63ZZZZ-NEM	Formaldehyde	40 CFR Part 63, Subpart ZZZZ	§ 63.6600(b)-Table 2a.3.b § 63.6595(c) § 63.6600(b)-Table 2b.3 § 63.6605(a) § 63.6605(b) § 63.6620(f) § 63.6625(h) § 63.6630(a) § 63.6640(b)	For each new or reconstructed CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, operating at 100% load plus or minus 10%, you must limit the concentration of formaldehyde in the stationary RICE exhaust to 580 ppbvd or less at 15 % O ₂ .	§ 63.6610(a) § 63.6610(b) § 63.6610(c) [G]§ 63.6610(d) § 63.6615 § 63.6620(a) § 63.6620(a)-Table 3.3 § 63.6620(a)-Table 4.3.a.i § 63.6620(a)-Table 4.3.a.ii § 63.6620(a)-Table 4.3.a.iii § 63.6620(a)-Table 4.3.a.iv § 63.6620(b) § 63.6620(b)(4) § 63.6620(d) [G]§ 63.6620(e)(2) § 63.6620(f) [G]§ 63.6625(b) § 63.6630(a)-Table 5.10.a.i § 63.6630(a)-Table 5.10.a.ii § 63.6630(a)-Table 5.10.a.iii § 63.6635(a) § 63.6635(b) § 63.6640(a) § 63.6640(a)-Table 6.8.a.i § 63.6640(a)-Table 6.8.a.ii § 63.6640(a)-Table 6.8.a.iii § 63.6640(a)-Table 6.8.a.iv § 63.6640(b)	§ 63.6620(i) § 63.6630(a)-Table 5.10.a.iii § 63.6635(a) § 63.6635(c) § 63.6655(a) § 63.6655(a)(1) § 63.6655(a)(2) § 63.6655(a)(3) § 63.6655(a)(4) § 63.6655(a)(5) § 63.6655(d) § 63.6660(a) § 63.6660(b) § 63.6660(c)	[G]§ 63.6620(g) § 63.6620(i) § 63.6630(c) § 63.6640(b) § 63.6640(e) § 63.6645(a) § 63.6645(c) § 63.6645(g) § 63.6645(h) § 63.6645(h)(2) § 63.6650(a) § 63.6650(a)-Table 7.1.a.i § 63.6650(a)-Table 7.1.b § 63.6650(a)-Table 7.1.c § 63.6650(b) § 63.6650(b)(1) § 63.6650(b)(2) § 63.6650(b)(3) § 63.6650(b)(4) [G]§ 63.6650(c) [G]§ 63.6650(d) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
NEMENG008	EU	TX-117B-NEM-HP	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B)	CO emissions must not exceed 3.0 g/hp-hr for stationary internal combustion engines.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(C) § 117.340(h) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.801 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
NEMENG008	EU	TX-117B-NEM-HP	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(9)(E)(iv)(III) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) [G]§ 117.310(f) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)(2)(C) § 117.340(h) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.345(f)(3)(B) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
NEMENG008	EU	60III-NEM-2016	CO	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 37 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.0 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039-Appendix I and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None
NEMENG008	EU	60III-NEM-2016	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 37 KW but less than 56 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with an NMHC+NO _x emission limit of 4.7 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039-Appendix I and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
NEMENG008	EU	60IIII-NEM-2016	PM	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 1039.101 § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 19 KW and less than 56 KW and a displacement of less than 10 liters per cylinder and is a 2013 model year and later must comply with a PM emission limit of 0.03 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None
NEMENG008	EU	63ZZZZ-NEM-S	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
OILDSUMP	EU	61FF-5	Benzene	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(a)(1)(ii)(A) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(ii) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(a)(1)(ii) § 61.349(e) § 61.349(f) § 61.354(c) § 61.354(c)(7)(i) § 61.354(f)(2) [G]§ 61.355(h)	§ 61.349(a)(1)(ii) § 61.354(c) § 61.354(c)(7)(i) § 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(F) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(3)(ii) § 61.356(j)(9)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(D)
REFHT201	EU	TX117B-40-100	CO	30 TAC Chapter 117, Subchapter B	§ 117.325(a)	Where a person can demonstrate that an affected unit cannot attain the carbon monoxide (CO) specifications of § 117.310(c) of this title the executive director may approve emission specifications different from the CO specifications in § 117.310(c) of this title for that unit.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
REFHT201	EU	TX117B-40-100	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
REFHT201	EU	60JA-REFHT	Hydrogen Sulfide	40 CFR Part 60, Subpart Ja	§ 60.102a(g)(1)(ii) § 60.102a(a) § 60.102a(g) § 60.102a(g)(1) § 60.103a(c) § 60.103a(d) § 60.103a(d)(1) § 60.103a(d)(5) [G]§ 60.103a(e)	For each fuel gas combustion device the owner or operator shall not burn in any fuel gas combustion device any fuel gas that contains H ₂ S in excess of 162 ppmv determined hourly on a 3-hour rolling average basis and H ₂ S in excess of 60 ppmv determined daily on a 365 successive calendar day rolling average basis.	§ 60.104a(a) § 60.104a(c) [G]§ 60.104a(j) § 60.107a(a) § 60.107a(a)(2) § 60.107a(a)(2)(i) § 60.107a(a)(2)(ii) § 60.107a(a)(2)(iii) § 60.107a(a)(2)(iv) § 60.107a(i) § 60.107a(i)(1)(ii)	§ 60.108a(a) § 60.108a(c) [G]§ 60.108a(c)(6) [G]§ 60.108a(d)	§ 60.108a(a) § 60.108a(b) [G]§ 60.108a(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
REFHT201	EU	63DDDDD-HTR	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
REFHT2631	EU	TX117B>200FGR	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
REFHT2631	EU	TX117B>200FGR	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
REFHT2631	EU	60J-HTR-73to07	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
REFHT2631	EU	63DDDDD-HTR	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
REFUNLOAD	EU	R5211-4	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(2)(A) § 115.212(a)(2) [G]§ 115.212(a)(7) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Any plant, excluding gasoline bulk plants, which loads less than 20,000 gpd of VOC with a true vapor pressure of 0.5 psia or greater is exempt from the requirements of this division, except for the specified requirements.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B) § 115.216(3)(D)	None
REFUNLOAD	EU	63EEEE-3	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2338(b) The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart EEEE
SRU-UNLOAD	EU	TX-115C-U<0.5	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
SRU-UNLOAD	EU	63EEEE-4	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2338(b) The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart EEEE

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SRU001	EU	REG2-SRUIN001	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.7(a) § 112.7(b)	No person may cause, suffer, allow, or permit emissions of SO ₂ to exceed the emission limits specified for stack effluent flow rates less than or equal to 4,000 scfm as determined by the specified equation in §112.7(a).	§ 112.2(a) ** See CAM Summary	§ 112.2(c)	§ 112.2(b)
SRU001	EU	60J-SRU	SO ₂	40 CFR Part 60, Subpart J	§ 60.104(a)(2)(i)	No owner or operator subject to the provisions of this subpart shall discharge or cause the discharge into the atmosphere from any Claus sulfur recovery plant with a reduction control system followed by incineration any gases containing in excess of 250 ppm by volume of SO ₂ at zero percent excess air.	[G]§ 60.105(a)(5) § 60.106(a) [G]§ 60.106(f)	[G]§ 60.105(a)(5)	§ 60.105(e)(4)(i) § 60.107(d) § 60.107(f) § 60.107(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SRUIN001	EU	60J-HTR-73to07	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1) ** See Alternative Requirement	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
TKFTK202	EU	61FF-TK-EFR	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) [G]§ 60.112b(a)(2) § 61.351(a)(2) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii)	§ 60.115b [G]§ 60.115b(b)(3) § 61.356(k)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4) § 61.357(e) § 61.357(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK202	EU	63CC-TK63WWEFR	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
TKFTK250	EU	TX-115B<1TVP	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
TKFTK250	EU	TX-115-WS-ROOF	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(2)	VOC water separator compartments must have a floating roof or internal-floating cover resting on the surface with closure seals. Gauging and sampling devices shall be vapor-tight except during use.	[G]§ 115.135(a) § 115.136(a)(3) § 115.136(a)(4) ** See Periodic Monitoring Summary	§ 115.136(a)(3) § 115.136(a)(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK250	EU	60Kb-VOL-IFR	VOC	40 CFR Part 60, Subpart Kb	§ 60.110b(e)(5) § 63.1062(a) § 63.1062(a)(1) § 63.1063(a)(1)(i) § 63.1063(a)(1)(i)(B) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(iv) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(e)(1) § 63.1063(e)(2)	Compliance with 40 CFR Part 63, subpart WW, may be chosen to satisfy the requirements of 40 CFR part 60, subpart Kb for IFR storage vessels with a design capacity greater than or equal to 75 m3 but less than 151 m3 containing a VOL with a max true vapor pressure equal to or greater than 27.6 kPa but less than 76.6 kPa.	§ 60.110b(e)(5)(iii) § 60.116b(a) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3) § 63.1063(c)(1) [G]§ 63.1063(c)(1)(i) [G]§ 63.1063(d)(1) § 63.1063(d)(2)	§ 60.110b(e)(5)(iv)(B) § 60.110b(e)(5)(iv)(C) § 60.110b(e)(5)(iv)(D) § 60.110b(e)(5)(iv)(E) § 60.116b(a) § 60.116b(c) § 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(c) § 63.1065(d)	§ 60.110b(e)(5)(iv)(A) § 60.110b(e)(5)(iv)(F)(1) § 60.110b(e)(5)(iv)(F)(2) [G]§ 63.1066(a) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4)
TKFTK250	EU	60QQQ-Kb	VOC	40 CFR Part 60, Subpart QQQ	§ 60.693-2(a) § 60.692-1(a) § 60.692-6(a) § 60.692-6(b) § 60.692-7(b) § 60.693-2(a)(1) § 60.693-2(a)(1)(i) § 60.693-2(a)(1)(i)(B) § 60.693-2(a)(1)(i)(C) [G]§ 60.693-2(a)(1)(ii) § 60.693-2(a)(1)(iii) § 60.693-2(a)(1)(iv) § 60.693-2(a)(2) § 60.693-2(a)(3) § 60.693-2(a)(4) § 60.693-2(a)(5)(ii) § 60.693-2(c)	May elect to install a floating roof on an oil-water separator tank, slop oil tank or other auxiliary equipment subject to this subpart which meets the following specifications:	§ 60.693-2(a)(1)(iii)(A) § 60.693-2(a)(1)(iii)(B) § 60.693-2(a)(5)(i) § 60.696(a) [G]§ 60.696(d)	§ 60.697(a) § 60.697(c) [G]§ 60.697(e) § 60.697(f)(1) [G]§ 60.697(f)(2) [G]§ 60.697(k)	§ 60.693-2(b) § 60.698(a) § 60.698(b)(1) § 60.698(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK250	EU	61FF-Kb	Benzene	40 CFR Part 61, Subpart FF	§ 61.352(a) § 61.352(a)(1) § 61.352(c)	As an alternative to the standards for oil-water separators specified in §61.347, an owner or operator may elect to comply with one of the following: §61.352(a)(1)-(2)	None	[G]§ 61.356(l)	§ 61.357(e) § 61.357(g)
TKFTK250	EU	61FF-TK-IFR2SL	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(B) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) [G]§ 60.113b(a)(3) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(4) § 61.357(e) § 61.357(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK250	EU	63CC-TK63WWIFR	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(1) § 63.1063(a)(1)(i) § 63.1063(a)(1)(i)(B) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(iv) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(1) [G]§ 63.1063(c)(1)(i) [G]§ 63.1063(d)(1) § 63.1063(d)(2) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(2)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK301	EU	TX-115B>40K-IFR	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B)
TKFTK301	EU	TX-115-WS-ROOF	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(2)	VOC water separator compartments must have a floating roof or internal-floating cover resting on the surface with closure seals. Gauging and sampling devices shall be vapor-tight except during use.	[G]§ 115.135(a) § 115.136(a)(3) § 115.136(a)(4) ** See Periodic Monitoring Summary	§ 115.136(a)(3) § 115.136(a)(4)	None
TKFTK301	EU	61FF-Kb	Benzene	40 CFR Part 61, Subpart FF	§ 61.352(a) § 61.352(a)(1) § 61.352(c)	As an alternative to the standards for oil-water separators specified in §61.347, an owner or operator may elect to comply with one of the following: §61.352(a)(1)-(2)	None	[G]§ 61.356(l)	§ 61.357(e) § 61.357(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK301	EU	61FF-TK-IFR2SL	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(B) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) [G]§ 60.113b(a)(3) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(4) § 61.357(e) § 61.357(f)
TKFTK301	EU	63CC-TK63WWIFR	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(1) § 63.1063(a)(1)(i) § 63.1063(a)(1)(i)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(iv) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(1) [G]§ 63.1063(c)(1)(i) [G]§ 63.1063(d)(1) § 63.1063(d)(2) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(2)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK309	EU	TX-115B<1TVP	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
TKFTK309	EU	61FF-TK-IFR2SL	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(B) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) [G]§ 60.113b(a)(3) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(4) § 61.357(e) § 61.357(f)
TKFTK309	EU	63CC-TK-GRP2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK328	EU	TX-115B>40K-IFR	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B)
TKFTK328	EU	TX-115-WS-ROOF	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(2)	VOC water separator compartments must have a floating roof or internal-floating cover resting on the surface with closure seals. Gauging and sampling devices shall be vapor-tight except during use.	[G]§ 115.135(a) § 115.136(a)(3) § 115.136(a)(4) ** See Periodic Monitoring Summary	§ 115.136(a)(3) § 115.136(a)(4)	None
TKFTK328	EU	61FF-Kb	Benzene	40 CFR Part 61, Subpart FF	§ 61.352(a) § 61.352(a)(1) § 61.352(c)	As an alternative to the standards for oil-water separators specified in §61.347, an owner or operator may elect to comply with one of the following: §61.352(a)(1)-(2)	None	[G]§ 61.356(l)	§ 61.357(e) § 61.357(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK328	EU	61FF-TK-EFR	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) [G]§ 60.112b(a)(2) § 61.351(a)(2) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii)	§ 60.115b [G]§ 60.115b(b)(3) § 61.356(k)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4) § 61.357(e) § 61.357(f)
TKFTK328	EU	63CC-TK63WWEFR	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(B) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(2) § 63.1063(c)(2)(i) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1063(c)(2)(iv)(B) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(3)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(2)(ii) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK332	EU	TX-115B>40K-IFR	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK332	EU	63CC-TKG1>11TVP	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.642(b) § 63.642(n) § 63.982(a)(1) § 63.982(c) § 63.982(c)(1) § 63.983(a)(1) § 63.983(a)(2) § 63.983(d)(1) § 63.983(d)(1)(i) [G]§ 63.983(d)(2) § 63.983(d)(3) § 63.985(a) § 63.997(c)(3) [G]§ 63.997(d)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is greater than or equal to 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart SS of this part, according to the requirements in §63.660(a)-(i).	§ 63.642(d)(1) § 63.642(d)(3) § 63.642(d)(4) § 63.660(a)(1) § 63.660(a)(2) § 63.983(b) [G]§ 63.983(b)(1) [G]§ 63.983(b)(2) [G]§ 63.983(b)(3) [G]§ 63.983(c)(1) § 63.983(c)(2) § 63.983(c)(3) § 63.983(d)(1) § 63.983(d)(1)(ii) § 63.985(b) [G]§ 63.985(b)(1) § 63.985(c)(2) § 63.997(c)(3) [G]§ 63.997(d)	§ 63.642(d)(3) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(2) § 63.655(i)(6) § 63.660(a)(1) § 63.983(b) [G]§ 63.983(d)(2) § 63.985(c)(2) [G]§ 63.998(b)(1) [G]§ 63.998(b)(2) [G]§ 63.998(b)(3) [G]§ 63.998(d)(1) [G]§ 63.998(d)(2) § 63.998(d)(3)(i) § 63.998(d)(3)(ii) § 63.998(d)(5)	§ 63.642(d)(2) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) [G]§ 63.655(f)(1)(i)(B) [G]§ 63.655(f)(1)(i)(C) § 63.655(f)(2) § 63.655(f)(3) § 63.655(f)(4) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(5) § 63.655(h) [G]§ 63.655(h)(10) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(C) § 63.655(h)(6) § 63.655(h)(6)(ii) [G]§ 63.655(h)(9) [G]§ 63.985(b)(1) § 63.985(c)(1) § 63.997(c)(3) [G]§ 63.998(b)(3) [G]§ 63.999(a)(1) [G]§ 63.999(a)(2) [G]§ 63.999(b)(2) § 63.999(c)(1) § 63.999(c)(2)(i) [G]§ 63.999(c)(4) [G]§ 63.999(c)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK342	EU	TK-115B>40K-IFR	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B)
TKFTK342	EU	TX-115B-TK342	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK342	EU	63CC-TK63WWIFR	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(1) § 63.1063(a)(1)(i) § 63.1063(a)(1)(i)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(iv) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(1) [G]§ 63.1063(c)(1)(i) [G]§ 63.1063(d)(1) § 63.1063(d)(2) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(2)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK343	EU	TX-115B>40K-IFR	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK343	EU	63CC-TK343-63WW	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(1) § 63.1063(a)(1)(i) § 63.1063(a)(1)(i)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(iv) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(viii) § 63.1063(a)(2)(viii)(B) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(1) [G]§ 63.1063(c)(1)(i) [G]§ 63.1063(d)(1) § 63.1063(d)(2) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(2)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(6) § 63.655(h)(6)(ii)
TKFTK345	EU	61FF-TK-EFR	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) [G]§ 60.112b(a)(2) § 61.351(a)(2) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii)	§ 60.115b [G]§ 60.115b(b)(3) § 61.356(k)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4) § 61.357(e) § 61.357(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK345	EU	63CC-TK-GRP2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
TKFTK349	EU	TX-115B>40K-IFR	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK349	EU	63CC-TK63WWIFR	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(1) § 63.1063(a)(1)(i) § 63.1063(a)(1)(i)(B) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(iv) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(1) [G]§ 63.1063(c)(1)(i) [G]§ 63.1063(d)(1) § 63.1063(d)(2) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(2)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK350	EU	TX-115B>40K-IFR	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(D) § 115.112(e)(2)(F) [G]§ 115.112(e)(2)(I) § 115.114(a)(1)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(1) § 115.114(a)(1)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK350	EU	63CC-TK350-63WW	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(1) § 63.1063(a)(1)(i) § 63.1063(a)(1)(i)(B) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(iv) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(viii) § 63.1063(a)(2)(viii)(B) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(1) [G]§ 63.1063(c)(1)(i) [G]§ 63.1063(d)(1) § 63.1063(d)(2) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(2)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(6) § 63.655(h)(6)(ii)
TKFTK400	EU	TX-115-WW-FRV	VOC	30 TAC Chapter 115, Industrial Wastewater	[G]§ 115.142(2) § 115.142 § 115.147(7)(A) [G]§ 115.148	The wastewater component shall be equipped with a floating roof or internal floating cover which meets the requirements listed in §115.142(2)(A)-(F).	§ 115.144(2) § 115.144(2)(A) § 115.144(2)(C) § 115.145 § 115.145(1) § 115.145(10) [G]§ 115.145(2) [G]§ 115.145(3) § 115.145(4) § 115.145(5) § 115.145(6) § 115.145(7) § 115.145(9) [G]§ 115.148	§ 115.146(1) § 115.146(2) § 115.146(3) § 115.146(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK400	EU	TX-115B>1.5TVP	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK400	EU	60Kb-VOL-EFR	VOC	40 CFR Part 60, Subpart Kb	§ 60.110b(e)(5) § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2)	Compliance with 40 CFR Part 63, subpart WW, may be chosen to satisfy the requirements of 40 CFR part 60, subpart Kb for EFR storage vessels either with a design capacity greater than or equal to 151 m ³ containing a VOL that has a max true vapor pressure equal to or greater than 5.2 kPa but less than 76.6 kPa.	§ 60.110b(e)(5)(iii) § 60.116b(a) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3) § 63.1063(c)(2) § 63.1063(c)(2)(i) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i)	§ 60.110b(e)(5)(iv)(B) § 60.110b(e)(5)(iv)(C) § 60.110b(e)(5)(iv)(D) § 60.110b(e)(5)(iv)(E) § 60.116b(a) § 60.116b(c) § 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d)	§ 60.110b(e)(5)(iv)(A) § 60.110b(e)(5)(iv)(F)(1) § 60.110b(e)(5)(iv)(F)(2) § 63.1063(c)(2)(iv)(B) [G]§ 63.1066(a) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4)
TKFTK400	EU	61FF-TK-EFR	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) [G]§ 60.112b(a)(2) § 61.351(a)(2) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii)	§ 60.115b [G]§ 60.115b(b)(3) § 61.356(k)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4) § 61.357(e) § 61.357(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK400	EU	63CC-TK63WWEFR	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(B) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(2) § 63.1063(c)(2)(i) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1063(c)(2)(iv)(B) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(3)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(2)(ii) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK807	EU	TX-115B-EFR	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)
TKFTK807	EU	TX-115B>1.5TVP	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK807	EU	63CC-TK63WWEFR	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(B) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(2) § 63.1063(c)(2)(i) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1063(c)(2)(iv)(B) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(3)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(2)(ii) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK814	EU	TX-115B>1.5TVP	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(3) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK814	EU	63CC-TKG1>11TVP	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.642(b) § 63.642(n) § 63.982(a)(1) § 63.982(c) § 63.982(c)(1) § 63.983(a)(1) § 63.983(a)(2) § 63.983(d)(1) § 63.983(d)(1)(i) [G]§ 63.983(d)(2) § 63.983(d)(3) § 63.985(a) § 63.997(c)(3) [G]§ 63.997(d)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is greater than or equal to 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart SS of this part, according to the requirements in §63.660(a)-(i).	§ 63.642(d)(1) § 63.642(d)(3) § 63.642(d)(4) § 63.660(a)(1) § 63.660(a)(2) § 63.983(b) [G]§ 63.983(b)(1) [G]§ 63.983(b)(2) [G]§ 63.983(b)(3) [G]§ 63.983(c)(1) § 63.983(c)(2) § 63.983(c)(3) § 63.983(d)(1) § 63.983(d)(1)(ii) § 63.985(b) [G]§ 63.985(b)(1) § 63.985(c)(2) § 63.997(c)(3) [G]§ 63.997(d)	§ 63.642(d)(3) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(2) § 63.655(i)(6) § 63.660(a)(1) § 63.983(b) [G]§ 63.983(d)(2) § 63.985(c)(2) [G]§ 63.998(b)(1) [G]§ 63.998(b)(2) [G]§ 63.998(b)(3) [G]§ 63.998(d)(1) [G]§ 63.998(d)(2) § 63.998(d)(3)(i) § 63.998(d)(3)(ii) § 63.998(d)(5)	§ 63.642(d)(2) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) [G]§ 63.655(f)(1)(i)(B) [G]§ 63.655(f)(1)(i)(C) § 63.655(f)(2) § 63.655(f)(3) § 63.655(f)(4) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(5) § 63.655(h) [G]§ 63.655(h)(10) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(C) § 63.655(h)(6) § 63.655(h)(6)(ii) [G]§ 63.655(h)(9) [G]§ 63.985(b)(1) § 63.985(c)(1) § 63.997(c)(3) [G]§ 63.998(b)(3) [G]§ 63.999(a)(1) [G]§ 63.999(a)(2) [G]§ 63.999(b)(2) § 63.999(c)(1) § 63.999(c)(2)(i) [G]§ 63.999(c)(4) [G]§ 63.999(c)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK822	EU	TX-115B-EFR	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1) § 115.112(e)(2) § 115.112(e)(2)(A) § 115.112(e)(2)(B) § 115.112(e)(2)(C) § 115.112(e)(2)(E) § 115.112(e)(2)(F) § 115.112(e)(2)(G) [G]§ 115.112(e)(2)(H) [G]§ 115.112(e)(2)(I) § 115.114(a)(2)(A) § 115.114(a)(4)(A)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	§ 115.114(a)(2) § 115.114(a)(4) § 115.114(a)(4)(A) [G]§ 115.117	§ 115.118(a)(3) § 115.118(a)(5) § 115.118(a)(6)(C) § 115.118(a)(7)	§ 115.114(a)(2)(B) § 115.114(a)(4)(B) § 115.118(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TKFTK822	EU	63CC-TK63WWEFR	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.660 § 63.1062(a) § 63.1062(a)(2) § 63.1063(a)(1)(ii) § 63.1063(a)(1)(ii)(B) § 63.1063(a)(1)(ii)(C) § 63.1063(a)(2)(i) § 63.1063(a)(2)(ii) § 63.1063(a)(2)(iii) § 63.1063(a)(2)(ix) § 63.1063(a)(2)(v) § 63.1063(a)(2)(vi) § 63.1063(a)(2)(vii) § 63.1063(b)(1) § 63.1063(b)(2) § 63.1063(b)(3) § 63.1063(b)(4) § 63.1063(b)(5) § 63.1063(d)(3)(ii) § 63.1063(d)(3)(iii) § 63.1063(e)(1) § 63.1063(e)(2) § 63.642(b) § 63.642(n) § 63.660(b)	For each Group 1 storage vessel for which the maximum true vapor pressure of stored liquid is less than 76.6 kilopascals (11.1 psia), the owner or operator shall comply with the requirements in Subpart WW of this part, according to the requirements in §63.660(a)-(i).	§ 63.1063(c)(2) § 63.1063(c)(2)(i) § 63.1063(c)(2)(ii) § 63.1063(c)(2)(iii) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) [G]§ 63.1063(d)(1) § 63.1063(d)(3) [G]§ 63.1063(d)(3)(i) § 63.660(a)(1) § 63.660(a)(2)	§ 63.1063(e)(2) § 63.1065 § 63.1065(a) [G]§ 63.1065(b)(1) § 63.1065(b)(2) § 63.1065(c) § 63.1065(d) § 63.655(i) § 63.655(i)(1) § 63.655(i)(1)(v) § 63.655(i)(6) § 63.660(a)(1)	§ 63.1063(c)(2)(iv)(B) § 63.1066(b)(1) § 63.1066(b)(2) § 63.1066(b)(4) § 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(f)(6) § 63.655(g) § 63.655(g)(14) [G]§ 63.655(g)(3)(ii) § 63.655(h) § 63.655(h)(2)(i) § 63.655(h)(2)(i)(A) § 63.655(h)(2)(i)(B) § 63.655(h)(2)(i)(C) § 63.655(h)(2)(ii) § 63.655(h)(6) § 63.655(h)(6)(ii)
TKFTKD48	EU	63EEEE-5	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2338(b) The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart EEEE

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TRRLOLPG	EU	TX-115C-L>0.5	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(2)(A) [G]§ 115.212(a)(7) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Any plant, excluding gasoline bulk plants, which loads less than 20,000 gpd of VOC with a true vapor pressure of 0.5 psia or greater is exempt from the requirements of this division, except for the specified requirements.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B) § 115.216(3)(D)	None
TVCVSEAST	EU	63CCVV-48210	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for open-ended valves or lines complying with §60.482-6.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVCVSEAST	EU	63CCVV-48210	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for flanges or other connectors complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
TVCVSEAST	EU	63CCVV-48210	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-10(f) [G]§ 60.482-10(g) § 60.482-10(h) § 60.482-10(i) [G]§ 60.482-10(j) [G]§ 60.482-10(k) § 60.482-10(m) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for closed vent (or vapor collection) systems complying with §60.482-10.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.482-10(l) [G]§ 60.486(a) [G]§ 60.486(d) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVCVSWEST	EU	63CCVV-48210	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-10(f) [G]§ 60.482-10(g) § 60.482-10(h) § 60.482-10(i) [G]§ 60.482-10(j) [G]§ 60.482-10(k) § 60.482-10(m) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for closed vent (or vapor collection) systems complying with §60.482-10.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.482-10(l) [G]§ 60.486(a) [G]§ 60.486(d) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
TVCVSWEST	EU	63CCVV-48210	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for flanges or other connectors complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVCVSWEST	EU	63CCVV-48210	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for open-ended valves or lines complying with §60.482-6.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFCCPROC	EU	63UUU-FCC	CO	40 CFR Part 63, Subpart UUU	§ 63.1565(a)(1)-Table 8.1 § 63.1565(a)(1) § 63.1565(a)(2) § 63.1565(a)(2)-Table 9.1 § 63.1565(a)(2)-Table 9.3 § 63.1565(a)(3) § 63.1565(a)(4) § 63.1565(a)(5) § 63.1565(b)(4) § 63.1565(b)(4)-Table 12.1 § 63.1565(c)(1) § 63.1565(c)(2) § 63.1569(a)(1) § 63.1569(a)(1)(i)-Table 36.1 § 63.1569(a)(3) § 63.1569(b)(1) § 63.1569(b)(1)-Table 37.1 § 63.1569(b)(2) § 63.1569(b)(2)-Table 38.1.a § 63.1569(c)(1) § 63.1569(c)(2) § 63.1570(a) § 63.1570(c) § 63.1570(d)	For each new and existing CCU subject to the NSPS for CO in 40 CFR §60.103 or §60.102a(b)(4) or electing to comply with the NSPS requirements (Option 1), CO emissions from the catalyst regenerator vent or CO boiler serving the CCU must not exceed 500 parts per million volume (ppmv) (dry basis).	§ 63.1565(b)(1) § 63.1565(b)(1)-Table 10.1 § 63.1565(b)(1)-Table 10.3 § 63.1565(c)(1)-Table 13.1 § 63.1565(c)(1)-Table 14.1 § 63.1565(c)(1)-Table 14.3 § 63.1569(b)(1) § 63.1569(b)(1)-Table 37.1 § 63.1569(c)(1)-Table 39.1 § 63.1571(a) § 63.1571(a)(1) § 63.1571(a)(2) [G]§ 63.1571(a)(6) § 63.1572(a) § 63.1572(a)(1) § 63.1572(a)(1)-Table 40.3 § 63.1572(a)(2) § 63.1572(a)(3) § 63.1572(a)(4) [G]§ 63.1572(d) ** See Alternative Requirement	§ 63.1565(b)(1)-Table 10.1 § 63.1565(c)(1)-Table 14.3 § 63.1569(b)(1)-Table 37.1 § 63.1569(c)(1)-Table 39.1 § 63.1569(c)(1)-Table 39.5 § 63.1570(c) § 63.1570(d) [G]§ 63.1576(a) [G]§ 63.1576(b) § 63.1576(d) § 63.1576(e) § 63.1576(f) § 63.1576(g) § 63.1576(h) § 63.1576(i)	§ 63.1565(b)(5) § 63.1565(b)(6) § 63.1569(b)(3) § 63.1569(b)(4) § 63.1569(c)(1)-Table 39.5 § 63.1570(f) § 63.1571(a) [G]§ 63.1574(a) § 63.1574(d) § 63.1574(d)-Table 42.1 § 63.1574(d)-Table 42.2 § 63.1574(d)-Table 42.3 § 63.1575(a) § 63.1575(a)-Table 43.1 [G]§ 63.1575(b) [G]§ 63.1575(c) [G]§ 63.1575(e) [G]§ 63.1575(f) § 63.1575(g) [G]§ 63.1575(h) [G]§ 63.1575(i) § 63.1575(k) § 63.1575(k)(1) [G]§ 63.1575(k)(2) § 63.1575(l) § 63.1576(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFCCPROC	EU	63UUU-FCC	PM	40 CFR Part 63, Subpart UUU	§ 63.1564(a)(1)-Table 1.1 § 63.1564(a)(1) § 63.1564(a)(2) § 63.1564(a)(2)-Table 2.10 § 63.1564(a)(3) § 63.1564(a)(4) [G]§ 63.1564(a)(5) § 63.1564(b)(3) § 63.1564(b)(5) § 63.1564(b)(5)-Table 5.1 § 63.1564(c)(1) § 63.1564(c)(1)-Table 7.10 [G]§ 63.1564(c)(5) § 63.1569(a)(1) § 63.1569(a)(1)(i)-Table 36.1 § 63.1569(a)(3) § 63.1569(b)(1) § 63.1569(b)(1)-Table 37.1 § 63.1569(b)(2) § 63.1569(b)(2)-Table 38.1.a § 63.1569(c)(1) § 63.1569(c)(2) § 63.1570(a) § 63.1570(c) § 63.1570(d)	For each new or existing CCU subject to NSPS for PM in 40 CFR §60.102, PM emissions must not exceed 1.0 g/kg (1.0 lb/1,000 lbs) of coke burn-off.	§ 63.1564(b)(1) § 63.1564(b)(1)-Table 3.12 § 63.1564(b)(2) [G]§ 63.1564(b)(2)-Table 4.1 § 63.1564(b)(2)-Table 4.2.a § 63.1564(b)(2)-Table 4.2.b [G]§ 63.1564(c)(1)-Table 6.1.a § 63.1569(b)(1) § 63.1569(b)(1)-Table 37.1 § 63.1569(c)(1)-Table 39.1 § 63.1571(a) § 63.1571(a)(1) § 63.1571(a)(5)(ii) [G]§ 63.1571(b) [G]§ 63.1572(d) ** See Alternative Requirement	§ 63.1564(b)(1)-Table 3.12 [G]§ 63.1564(c)(1)-Table 6.1.a § 63.1564(c)(2) § 63.1569(b)(1)-Table 37.1 § 63.1569(c)(1)-Table 39.1 § 63.1569(c)(1)-Table 39.5 § 63.1570(c) § 63.1570(d) [G]§ 63.1576(a) § 63.1576(d) § 63.1576(e) § 63.1576(f) § 63.1576(g) § 63.1576(h) § 63.1576(i)	§ 63.1564(b)(6) § 63.1564(b)(7) § 63.1569(b)(3) § 63.1569(b)(4) § 63.1569(c)(1)-Table 39.5 § 63.1570(f) § 63.1571(a) [G]§ 63.1574(a) § 63.1574(c) § 63.1574(d) § 63.1574(d)-Table 42.1 § 63.1574(d)-Table 42.2 § 63.1574(d)-Table 42.3 § 63.1575(a) § 63.1575(a)-Table 43.1 § 63.1575(a)-Table 43.2 [G]§ 63.1575(b) [G]§ 63.1575(c) [G]§ 63.1575(e) [G]§ 63.1575(f) § 63.1575(g) [G]§ 63.1575(i) § 63.1575(k) [G]§ 63.1575(k)(1) § 63.1575(l)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFCCPROC	EU	63UUU-FCC	PM (Opacity)	40 CFR Part 63, Subpart UUU	§ 63.1564(a)(1)-Table 1.1 § 63.1564(a)(1) § 63.1564(a)(2) § 63.1564(a)(2)-Table 2.1 § 63.1564(a)(2)-Table 2.10 § 63.1564(a)(3) § 63.1564(a)(4) [G]§ 63.1564(a)(5) § 63.1564(b)(3) § 63.1564(b)(5) § 63.1564(b)(5)-Table 5.1 § 63.1564(c)(1) § 63.1564(c)(1)-Table 7.10 [G]§ 63.1564(c)(5) § 63.1569(a)(1) § 63.1569(a)(1)(i)-Table 36.1 § 63.1569(a)(3) § 63.1569(b)(1) § 63.1569(b)(1)-Table 37.1 § 63.1569(b)(2) § 63.1569(b)(2)-Table 38.1.a § 63.1569(c)(1) § 63.1569(c)(2) § 63.1570(b) § 63.1570(c) § 63.1570(d)	For each new or existing CCU subject to NSPS for PM in 40 CFR §60.102, the opacity of emissions must not exceed 30%, except for one 6-minute average opacity reading in any 1-hour period.	§ 63.1564(b)(1) § 63.1564(b)(1)-Table 3.1 § 63.1564(b)(1)-Table 3.12 § 63.1564(b)(2) § 63.1564(b)(2)-Table 4.1 § 63.1564(b)(2)-Table 4.2.c [G]§ 63.1564(c)(1)-Table 6.1.a § 63.1564(c)(1)-Table 7.1 § 63.1569(b)(1) § 63.1569(b)(1)-Table 37.1 § 63.1569(c)(1)-Table 39.1 § 63.1571(a) § 63.1571(a)(1) § 63.1571(a)(5) [G]§ 63.1571(b) § 63.1572(a)(1)-Table 40.1 § 63.1572(a)(4) § 63.1572(b) § 63.1572(b)(1) § 63.1572(b)(2) § 63.1572(b)(3) [G]§ 63.1572(d) ** See Alternative Requirement	§ 63.1564(b)(1)-Table 3.1 § 63.1564(b)(1)-Table 3.12 [G]§ 63.1564(c)(1)-Table 6.1.a § 63.1564(c)(1)-Table 7.1 § 63.1564(c)(2) § 63.1569(b)(1)-Table 37.1 § 63.1569(c)(1)-Table 39.1 § 63.1569(c)(1)-Table 39.5 § 63.1570(c) § 63.1570(d) [G]§ 63.1576(a) § 63.1576(d) § 63.1576(e) § 63.1576(f) § 63.1576(g) § 63.1576(h) § 63.1576(i)	§ 63.1564(b)(6) § 63.1564(b)(7) § 63.1569(b)(3) § 63.1569(b)(4) § 63.1569(c)(1)-Table 39.5 § 63.1570(f) § 63.1571(a) [G]§ 63.1574(a) § 63.1574(c) § 63.1574(d) § 63.1574(d)-Table 42.1 § 63.1574(d)-Table 42.2 § 63.1574(d)-Table 42.3 § 63.1575(a) § 63.1575(a)-Table 43.1 § 63.1575(a)-Table 43.2 [G]§ 63.1575(b) [G]§ 63.1575(c) [G]§ 63.1575(e) [G]§ 63.1575(f) § 63.1575(g) [G]§ 63.1575(i) § 63.1575(k) [G]§ 63.1575(k)(1) [G]§ 63.1575(l) [G]§ 63.1576(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(13)	Components/systems that contact a process fluid containing VOC having a true vapor pressure equal to or less than 0.002 psia at 68 degrees Fahrenheit are exempt from the requirements of this division except §115.356(3)(C) of this title.	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(2) § 115.352(9)	Conservation vents or other devices on atmospheric storage tanks that are actuated either by a vacuum or a pressure of no more than 2.5 psig, pressure relief valves equipped with a rupture disk or venting to a control device, components in continuous vacuum service, and valves that are not externally regulated (such as in-line check valves) are exempt from the requirements of this division, except that each pressure relief valve equipped with a rupture disk must comply with §115.352(9) and §115.	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(3) § 115.352(7) § 115.357(1)	No process drains contacting a fluid with TVP less than or equal to 0.044 psia (heavy liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(3) § 115.352(7)	No process drains contacting a fluid with TVP greater than 0.044 psia (gas/vapor or light liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) § 115.356(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(5) § 115.352(7) § 115.352(9) § 115.357(1) § 115.357(8) § 115.357(9)	No pressure relief valves contacting a fluid with TVP less than or equal to 0.044 psia (heavy liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(4) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(5) § 115.352(7) § 115.352(9) § 115.357(12) § 115.357(8) § 115.357(9)	No pressure relief valves contacting a fluid with TVP greater than 0.044 psia (gas/vapor or light liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(4) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(4) § 115.352(5) § 115.352(6) § 115.352(7) § 115.357(1) § 115.357(8) § 115.357(9)	No open-ended valves or lines contacting a fluid with TVP less than or equal to 0.044 psia (heavy liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(4) § 115.352(5) § 115.352(6) § 115.352(7) § 115.357(12) § 115.357(8) § 115.357(9)	No open-ended valves or lines contacting a fluid with TVP greater than 0.044 psia (gas/vapor or light liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(4) § 115.352(5) § 115.352(6) § 115.352(7) § 115.357(12) § 115.357(8) § 115.357(9)	No valves contacting a fluid with TVP greater than 0.044 psia (gas/vapor or light liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(3) § 115.352(5) § 115.352(7) § 115.352(8) § 115.357(1) § 115.357(12) § 115.357(8)	No flanges or other connectors contacting a fluid with TVP less than or equal to 0.044 psia (heavy liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(11) § 115.354(3) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(3) § 115.352(5) § 115.352(7) § 115.352(8) § 115.357(12) § 115.357(8)	No flanges or other connectors contacting a fluid with TVP greater than 0.044 psia (gas/vapor or light liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(11) § 115.354(3) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(7) § 115.357(1) § 115.357(8)	No agitators contacting a fluid with TVP less than or equal to 0.044 psia (heavy liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	[G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(7) § 115.357(8)	No agitators contacting a fluid with TVP greater than 0.044 psia (gas/vapor or light liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	[G]§ 115.355	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(3) § 115.357(8)	No compressor seals in hydrogen service with and the hydrogen content can be expected to always exceed 50.0% by volume shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	[G]§ 115.355	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(4) § 115.357(8)	No compressor seals that are equipped with a shaft sealing system that prevents or detects emissions of VOCs from the seal shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	[G]§ 115.355	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	None
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(1) § 115.357(8)	No compressor seals contacting a fluid with TVP less than or equal to 0.044 psia (heavy liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(12) § 115.357(8)	No compressor seals contacting a fluid with TVP greater than 0.044 psia (gas/vapor or light liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(4) § 115.357(8)	No pump seals that are equipped with a shaft sealing system that prevents or detects emissions of VOCs from the seal shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	[G]§ 115.355	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(1) § 115.357(8)	No pump seals contacting a fluid with TVP less than or equal to 0.044 psia (heavy liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) [G]§ 115.356(3)(C) § 115.356(5)	None
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(B) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(C) § 115.352(2)(C)(i) § 115.352(2)(C)(ii) § 115.352(2)(C)(iii) § 115.352(3) § 115.352(5) § 115.352(7) § 115.357(12) § 115.357(8)	No pump seals contacting a fluid with TVP greater than 0.044 psia (gas/vapor or light liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery which exceeds a screening concentration greater than 10,000 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) [G]§ 115.355	§ 115.352(7) § 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.352(1)(A) § 115.352(1) § 115.352(2) § 115.352(2)(A) § 115.352(2)(B) § 115.352(3) § 115.352(4) § 115.352(5) § 115.352(6) § 115.352(7) § 115.357(1) § 115.357(8) § 115.357(9)	No valves contacting a fluid with TVP less than or equal to 0.044 psia (heavy liquid service) shall be allowed to have a VOC leak, for more than 15 days after discovery, which exceeds a screening concentration greater than 500 parts per million by volume above background as methane, or the dripping or exuding of process fluid based on sight, smell, or sound.	§ 115.354(1) § 115.354(2) § 115.354(5) § 115.354(6) [G]§ 115.354(7) § 115.354(9) [G]§ 115.355 § 115.357(1)	§ 115.352(7) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) [G]§ 115.356(3)(C) § 115.356(5)	[G]§ 115.354(7)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(10)	Instrumentation systems, as defined in 40 CFR §63.161 (January 17, 1997), that meet 40 CFR §63.169 (June 20, 1996) are exempt from the requirements of this division except §115.356(3)(C) of this title.	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(11)	Sampling connection systems, as defined in 40 CFR §63.161 (January 17, 1997), that meet the requirements of 40 CFR §63.166(a) and (b) (June 20, 1996) are exempt from the requirements of this division except §115.356(3)(C) of this title.	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None
TVFUG-115VOC	EU	R5352-01	VOC	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	§ 115.357(6)	Components at a petroleum refinery or synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process, that contact a process fluid that contains less than 10% VOC by weight are exempt from the requirements of this division except §115.356(3)(C) of this title.	None	§ 115.356 § 115.356(3) [G]§ 115.356(3)(C)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-63CC	EU	63CCVV-648	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-2(b)(1) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(f)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in light liquid service complying with §60.482-2.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) § 60.486(f) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-63CC	EU	63CCVV-648	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(i)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for compressors complying with §60.482-3.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
TVFUG-63CC	EU	63CCVV-648	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-5(a) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for sampling connection systems complying with §60.482-5.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-63CC	EU	63CCVV-648	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for open-ended valves or lines complying with §60.482-6.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
TVFUG-63CC	EU	63CCVV-648	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in gas/vapor service or in light liquid service complying with §60.482-7.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(ii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(d) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-63CC	EU	63CCVV-648	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
TVFUG-63CC	EU	63CCVV-648	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-63CC	EU	63CCVV-648	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for flanges or other connectors complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
TVFUG-63CC	EU	63CCVV-648	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-10(f) [G]§ 60.482-10(g) § 60.482-10(h) § 60.482-10(i) [G]§ 60.482-10(j) [G]§ 60.482-10(k) § 60.482-10(m) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for closed vent (or vapor collection) systems complying with §60.482-10.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.482-10(l) [G]§ 60.486(a) [G]§ 60.486(d) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-63CC	EU	63CCVV-648	112(B) HAPS	40 CFR Part 63, Subpart CC	[G]§ 63.648(g) § 63.642(b) § 63.642(n)	Compressors in hydrogen service are exempt from the requirements of §63.648(a) and (c) if an owner or operator demonstrates that a compressor is in hydrogen service. §63.648(g)(1)-(2).	[G]§ 63.648(g)	§ 63.648(h) § 63.655(d)(3) § 63.655(i)	None
TVFUG-63CC	EU	63CCVV-648	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(d) § 60.486(k) § 63.642(b) § 63.642(n)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for equipment in vacuum service.	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(5) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
TVFUG-63CCJ1	EU	63CCVV-648J1	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(j)(1) § 63.642(b) § 63.642(n) [G]§ 63.648(j)(2) [G]§ 63.648(j)(3)(ii) [G]§ 63.648(j)(3)(v) [G]§ 63.648(j)(6) [G]§ 63.648(j)(7)	Except during a pressure release, operate each pressure relief device in organic HAP gas or vapor service with an instrument reading of less than 500 ppm above background as detected by Method 21 of 40 CFR part 60, appendix A-7.	[G]§ 63.648(j)(2) [G]§ 63.648(j)(3)(i) [G]§ 63.648(j)(3)(ii) § 63.648(j)(3)(iii) § 63.648(j)(3)(iv)	§ 63.648(h) [G]§ 63.648(j)(3)(i) [G]§ 63.648(j)(3)(ii) § 63.655(i) § 63.655(i)(11) § 63.655(i)(11)(i) § 63.655(i)(11)(ii) § 63.655(i)(6)	§ 63.642(f) § 63.648(j)(3)(iii) § 63.655(f) [G]§ 63.655(f)(1)(vii) § 63.655(g) [G]§ 63.655(g)(10) § 63.655(g)(14)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-63CCJ2	EU	63CCVV-648J2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(j)(1) § 63.642(b) § 63.642(n) [G]§ 63.648(j)(2) [G]§ 63.648(j)(3)(ii) [G]§ 63.648(j)(3)(v) [G]§ 63.648(j)(6) [G]§ 63.648(j)(7)	Except during a pressure release, operate each pressure relief device in organic HAP gas or vapor service with an instrument reading of less than 500 ppm above background as detected by Method 21 of 40 CFR part 60, appendix A-7.	[G]§ 63.648(j)(2) [G]§ 63.648(j)(3)(i) [G]§ 63.648(j)(3)(ii) § 63.648(j)(3)(iii) § 63.648(j)(3)(iv)	§ 63.648(h) [G]§ 63.648(j)(3)(i) [G]§ 63.648(j)(3)(ii) § 63.655(i) § 63.655(i)(11) § 63.655(i)(11)(i) § 63.655(i)(11)(ii) § 63.655(i)(6)	§ 63.642(f) § 63.648(j)(3)(iii) § 63.655(f) [G]§ 63.655(f)(1)(vii) § 63.655(g) [G]§ 63.655(g)(10) § 63.655(g)(14)
TVFUG-63CCJ3	EU	63CCVV-648J3	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(j)(1) § 63.642(b) § 63.642(n) [G]§ 63.648(j)(2) [G]§ 63.648(j)(3)(ii) [G]§ 63.648(j)(3)(v) [G]§ 63.648(j)(6) [G]§ 63.648(j)(7)	Except during a pressure release, operate each pressure relief device in organic HAP gas or vapor service with an instrument reading of less than 500 ppm above background as detected by Method 21 of 40 CFR part 60, appendix A-7.	[G]§ 63.648(j)(2) [G]§ 63.648(j)(3)(i) [G]§ 63.648(j)(3)(ii) § 63.648(j)(3)(iii) § 63.648(j)(3)(iv)	§ 63.648(h) [G]§ 63.648(j)(3)(i) [G]§ 63.648(j)(3)(ii) § 63.655(i) § 63.655(i)(11) § 63.655(i)(11)(i) § 63.655(i)(11)(ii) § 63.655(i)(6)	§ 63.642(f) § 63.648(j)(3)(iii) § 63.655(f) [G]§ 63.655(f)(1)(vii) § 63.655(g) [G]§ 63.655(g)(10) § 63.655(g)(14)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-63CCJ4	EU	63CCVV-648J4	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(j)(4)(iv) § 63.642(b) § 63.642(n) § 63.644(a)(2) § 63.670	For each pressure relief device in organic HAP gas or vapor service routed to a control device, both the closed vent system and control device (if applicable) referenced in §63.648(j)(4)(i)-(iii) must meet the requirements of §63.644. When complying with this §63.648(j)(4), all references to 'Group 1 miscellaneous process vent' in §63.644 mean 'pressure relief device.'	§ 63.644(a) § 63.644(e)	§ 63.648(h) § 63.655(i) [G]§ 63.655(i)(3) § 63.655(i)(6)	§ 63.642(f) § 63.655(f) § 63.655(f)(4) § 63.655(g) [G]§ 63.655(g)(10) § 63.655(g)(14) § 63.655(g)(6) § 63.655(h)
TVFUG-63CCJ5	EU	63CCVV-648J5	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(j)(1) § 63.642(b) § 63.642(n) [G]§ 63.648(j)(2)	Except during a pressure release, operate each pressure relief device in organic HAP gas or vapor service with an instrument reading of less than 500 ppm above background as detected by Method 21 of 40 CFR part 60, appendix A-7.	[G]§ 63.648(j)(2)	§ 63.648(h) § 63.655(i) § 63.655(i)(6)	§ 63.642(f) § 63.655(g) [G]§ 63.655(g)(10)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-63GGGGG	EU	63GGGGG-7915	112(B) HAPS	40 CFR Part 63, Subpart GGGGG	§ 63.7887(b)	If the affected equipment leak source is also subject to another subpart in 40 CFR part 61 or 40 CFR Part 63, control emissions of the HAP listed in Table 1 to this subpart from the affected equipment leak source in compliance with the standards specified in the other applicable subpart (i.e. emissions limitations and work practice standards). This provision does not apply to any exemption from the emissions limitations and work practice standards allowed by the other applicable subpart.	None	None	§ 63.7883(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGGA	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) [G]§ 60.482-2a(c)(2) [G]§ 60.482-7a(e) § 60.482-8a(a) § 60.482-8a(a)(2) § 60.482-8a(b) [G]§ 60.482-8a(c) § 60.482-8a(d) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(c) § 60.482-9a(f) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-8a for connectors in heavy liquid service.	§ 60.482-1a(g) § 60.482-8a(a)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGGA	§ 60.593a(g) § 60.482-11a(b)(2) § 60.482-11a(b)(3) § 60.482-11a(d) [G]§ 60.482-11a(e) [G]§ 60.482-11a(f)(1) § 60.482-11a(f)(2) § 60.482-11a(g) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(c) § 60.482-9a(f) § 60.485a(b) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Connectors in gas/vapor or light liquid service are exempt from the requirements in §60.482-11a, provided the owner or operator complies with §60.482-8a for all connectors, not just those in heavy liquid service.	§ 60.482-11a(a) § 60.482-11a(b) § 60.482-11a(b)(1) § 60.482-11a(b)(3) § 60.482-11a(b)(3)(i) § 60.482-11a(b)(3)(ii) [G]§ 60.482-11a(b)(3)(iii) § 60.482-11a(b)(3)(iv) § 60.482-11a(c) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-11a(b)(3)(v) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8) § 60.486a(e)(9) § 60.486a(f) § 60.486a(f)(1)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(5) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(i) § 60.487a(c)(2)(vii) § 60.487a(c)(2)(viii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGGA	§ 60.592a(a) § 60.18 § 60.482-10a(a) § 60.482-10a(d) § 60.482-10a(m) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-10a for flares.	§ 60.482-10a(e) § 60.482-1a(g) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) [G]§ 60.485a(g) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGa	§ 60.592a(a) § 60.482-10a(a) [G]§ 60.482-10a(f) [G]§ 60.482-10a(g) § 60.482-10a(h) § 60.482-10a(i) [G]§ 60.482-10a(j) [G]§ 60.482-10a(k) § 60.482-10a(m) § 60.485a(b) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-10a for closed-vent systems.	§ 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) § 60.593a(d)	[G]§ 60.482-10a(l) § 60.485a(b)(2) [G]§ 60.486a(d) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) [G]§ 60.482-2a(c)(2) [G]§ 60.482-7a(e) § 60.482-8a(a) § 60.482-8a(a)(2) § 60.482-8a(b) [G]§ 60.482-8a(c) § 60.482-8a(d) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(c) § 60.482-9a(e) § 60.482-9a(f) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-8a for valves in heavy liquid service.	§ 60.482-1a(g) § 60.482-8a(a)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGGA	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-7a(a)(1) § 60.482-7a(b) [G]§ 60.482-7a(d) [G]§ 60.482-7a(e) [G]§ 60.482-7a(f) [G]§ 60.482-7a(g) [G]§ 60.482-7a(h) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(c) § 60.482-9a(e) § 60.482-9a(f) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-7a for valves in gas/vapor or light liquid service.	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3) § 60.482-1a(g) § 60.482-7a(a)(1) [G]§ 60.482-7a(a)(2) [G]§ 60.482-7a(c) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) § 60.486a(f)(2)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(2) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(i) § 60.487a(c)(2)(ii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-6a(a)(1) § 60.482-6a(a)(2) § 60.482-6a(b) § 60.482-6a(c) § 60.482-6a(d) § 60.482-6a(e) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-6a for open-ended valves and lines.	§ 60.482-1a(g) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-5a(a) [G]§ 60.482-5a(b) § 60.482-5a(c) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-5a for sampling connection systems.	§ 60.482-1a(g) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGGA	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-3a(a) [G]§ 60.482-3a(b) § 60.482-3a(c) § 60.482-3a(d) § 60.482-3a(e)(2) § 60.482-3a(f) [G]§ 60.482-3a(g) § 60.482-3a(h) [G]§ 60.482-3a(i) § 60.482-3a(j) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-3a for compressors.	§ 60.482-1a(g) § 60.482-3a(e)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) [G]§ 60.486a(h)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(4) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(v) § 60.487a(c)(2)(vi) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGGA	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-3a(a) [G]§ 60.482-3a(b) § 60.482-3a(c) § 60.482-3a(d) § 60.482-3a(e)(2) § 60.482-3a(f) [G]§ 60.482-3a(g) § 60.482-3a(h) [G]§ 60.482-3a(i) § 60.482-3a(j) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e) § 60.593a(c)	Comply with the requirements as stated in §60.482-3a for reciprocating compressors that become subject under §60.14 and §60.15.	§ 60.482-1a(g) § 60.482-3a(e)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) [G]§ 60.486a(h)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(4) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(v) § 60.487a(c)(2)(vi) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGGA	§ 60.593a(b)(1)	Compressors in hydrogen service are exempt from the requirements of §60.592a if an owner or operator demonstrates that a compressor is in hydrogen service.	§ 60.593a(b)(2) [G]§ 60.593a(b)(3)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGGA	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) [G]§ 60.482-2a(c)(2) [G]§ 60.482-7a(e) § 60.482-8a(a) § 60.482-8a(a)(2) § 60.482-8a(b) [G]§ 60.482-8a(c) § 60.482-8a(d) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(d) § 60.482-9a(f) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-8a for pumps in heavy liquid service.	§ 60.482-1a(g) § 60.482-8a(a)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-2a(b)(1) § 60.482-2a(b)(2) § 60.482-2a(b)(2)(ii) § 60.482-2a(c)(1) [G]§ 60.482-2a(c)(2) § 60.482-2a(d) [G]§ 60.482-2a(d)(1) § 60.482-2a(d)(2) § 60.482-2a(d)(3) [G]§ 60.482-2a(d)(6) [G]§ 60.482-2a(e) § 60.482-2a(f) [G]§ 60.482-2a(g) § 60.482-2a(h) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(d) § 60.482-9a(f) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-2a for pumps in light liquid service.	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3) § 60.482-1a(g) § 60.482-2a(a)(1) § 60.482-2a(a)(2) § 60.482-2a(b)(2)(i) [G]§ 60.482-2a(d)(4) [G]§ 60.482-2a(d)(5) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) § 60.486a(e)(7) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) [G]§ 60.486a(h)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(3) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(iii) § 60.487a(c)(2)(iv) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-GGGA	EU	60GGGa-590a	VOC	40 CFR Part 60, Subpart GGGA	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(d) § 60.485a(b) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-1a(d) for equipment in vacuum service.	[G]§ 60.485a(b)(1) § 60.485a(b)(2)	§ 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) § 60.486a(e)(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-HRVOC	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVO C Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(2) § 115.782(c)(2)(A) § 115.782(c)(2)(A)(i) § 115.782(c)(2)(A)(ii) § 115.782(c)(2)(B) § 115.783(5) § 115.787(f) § 115.787(f)(2) § 115.787(f)(3) § 115.787(f)(4) § 115.787(g) § 115.788(a) § 115.788(a)(1) § 115.788(a)(2) § 115.788(a)(2)(A) § 115.788(a)(2)(B) § 115.788(a)(2)(C) § 115.788(a)(2)(C)(i) § 115.788(a)(2)(C)(ii) § 115.788(a)(2)(C)(iii) § 115.788(a)(2)(D) § 115.788(a)(3) § 115.788(a)(3)(A) § 115.788(a)(3)(B) [G]§ 115.788(g)	Open-ended valves or lines within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(3) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(f) § 115.781(f)(1) § 115.781(f)(2) § 115.781(f)(3) § 115.781(f)(4) § 115.781(f)(5) § 115.781(f)(6) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2) § 115.789(1)(B)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) § 115.782(c)(2)(A)(ii) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(2) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g) [G]§ 115.788(g)	§ 115.782(c)(2)(A)(ii) [G]§ 115.786(c) § 115.788(c) [G]§ 115.788(d) § 115.788(e) [G]§ 115.788(g) § 115.789(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-HRVOC	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.787(d) § 115.780(b) [G]§ 115.781(a) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.782(c)(1)(C)(i) § 115.782(c)(1)(C)(i)(I) § 115.782(c)(1)(C)(i)(II) § 115.782(c)(1)(C)(i)(III) § 115.782(c)(1)(C)(ii) § 115.783(3) [G]§ 115.783(3)(A) [G]§ 115.783(3)(B) § 115.787(b) § 115.787(b)(1) § 115.787(g)	All pumps that are equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal are exempt from the monitoring requirement of §115.781(b) and (c). Submerged pumps or sealless pumps may be used to satisfy the requirements of this subsection.	§ 115.782(d)(2)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) § 115.783(3)(C) [G]§ 115.786(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-HRVOC	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Fugitive Emissions	§ 115.787(d) § 115.780(b) [G]§ 115.781(a) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.782(c)(1)(C)(i) § 115.782(c)(1)(C)(i)(I) § 115.782(c)(1)(C)(i)(II) § 115.782(c)(1)(C)(i)(III) § 115.782(c)(1)(C)(ii) § 115.783(3) [G]§ 115.783(3)(A) [G]§ 115.783(3)(B) § 115.787(b) § 115.787(b)(1) § 115.787(g)	All compressors that are equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal are exempt from the monitoring requirement of §115.781(b) and (c). Submerged pumps or sealless pumps may be used to satisfy the requirements of this subsection.	§ 115.782(d)(2)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) § 115.783(3)(C) [G]§ 115.786(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-HRVOC	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVO C Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.782(c)(1)(C)(i) § 115.782(c)(1)(C)(i)(I) § 115.782(c)(1)(C)(i)(II) § 115.782(c)(1)(C)(i)(III) § 115.782(c)(1)(C)(ii) § 115.783(3) [G]§ 115.783(3)(A) [G]§ 115.783(3)(B) § 115.787(b)	Agitators within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(5) § 115.354(6) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(3) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(c)(1) § 115.781(c)(2) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) § 115.783(3)(C) [G]§ 115.786(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-HRVOC	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVO C Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.782(c)(1)(C)(i) § 115.782(c)(1)(C)(i)(I) § 115.782(c)(1)(C)(i)(II) § 115.782(c)(1)(C)(i)(III) § 115.782(c)(1)(C)(ii) § 115.783(3) [G]§ 115.783(3)(A) [G]§ 115.783(3)(B) § 115.787(b) § 115.787(b)(1)	Pump seals within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(c)(1) § 115.781(c)(2) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(2)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) § 115.783(3)(C) [G]§ 115.786(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-HRVOC	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVO C Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.782(c)(1)(C)(i) § 115.782(c)(1)(C)(i)(I) § 115.782(c)(1)(C)(i)(II) § 115.782(c)(1)(C)(i)(III) § 115.782(c)(1)(C)(ii) § 115.783(3) [G]§ 115.783(3)(A) [G]§ 115.783(3)(B) § 115.787(b)	Compressor seals within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(c)(1) § 115.781(c)(2) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) § 115.783(3)(C) [G]§ 115.786(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-HRVOC	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVO C Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv)	Flanges or other connectors within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(11) § 115.354(3) § 115.354(5) § 115.354(6) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(3) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(f) § 115.781(f)(1) § 115.781(f)(2) § 115.781(f)(3) § 115.781(f)(4) § 115.781(f)(5) § 115.781(f)(6) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2) § 115.789(1)(B)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.789(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-HRVOC	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVO C Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(2) § 115.782(c)(2)(A) § 115.782(c)(2)(A)(i) § 115.782(c)(2)(A)(ii) § 115.782(c)(2)(B) § 115.783(5) § 115.787(f) § 115.787(f)(4) § 115.787(g) § 115.788(a) § 115.788(a)(1) § 115.788(a)(2) § 115.788(a)(2)(A) § 115.788(a)(2)(B) § 115.788(a)(2)(C) § 115.788(a)(2)(C)(i) § 115.788(a)(2)(C)(ii) § 115.788(a)(2)(C)(iii) § 115.788(a)(2)(D) § 115.788(a)(3) § 115.788(a)(3)(A) § 115.788(a)(3)(B) [G]§ 115.788(g)	Valves within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(5) § 115.354(6) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) § 115.782(c)(2)(A)(ii) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(2) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g) [G]§ 115.788(g)	§ 115.782(c)(2)(A)(ii) [G]§ 115.786(c) § 115.788(c) [G]§ 115.788(d) § 115.788(e) [G]§ 115.788(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-HRVOC	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVO C Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.787(e) § 115.787(f) § 115.787(g) § 115.788(a) § 115.788(a)(1) § 115.788(a)(2) § 115.788(a)(2)(A) § 115.788(a)(2)(B) § 115.788(a)(2)(C) § 115.788(a)(2)(C)(i) § 115.788(a)(2)(C)(ii) § 115.788(a)(2)(C)(iii) § 115.788(a)(2)(D) § 115.788(a)(3) § 115.788(a)(3)(A) § 115.788(a)(3)(B) [G]§ 115.788(g)	Pressure relief valves (in gaseous service) within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(2) § 115.354(4) § 115.354(5) § 115.354(6) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(b)(8) § 115.781(e) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g) [G]§ 115.788(g)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.788(c) [G]§ 115.788(d) § 115.788(e) [G]§ 115.788(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-HRVOG	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOG Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.783(4)(A)(i) § 115.783(4)(A)(ii) § 115.783(4)(A)(ii)(I) § 115.783(4)(A)(ii)(II) § 115.783(4)(B) § 115.783(4)(B)(i) § 115.783(4)(B)(ii)	Process drains within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.354(1) § 115.354(10) § 115.354(5) § 115.354(6) § 115.354(9) § 115.781(b) § 115.781(b)(10) § 115.781(b)(3) § 115.781(b)(4) § 115.781(b)(5) § 115.781(b)(6) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3)	§ 115.354(10) § 115.356 [G]§ 115.356(1) [G]§ 115.356(2) § 115.356(3) § 115.356(3)(A) § 115.356(3)(B) § 115.356(5) § 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c)
TVFUG-HRVOG	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOG Fugitive Emissions	§ 115.787(a)	Components that contact a process fluid containing less than 5.0% highly-reactive volatile organic compounds by weight on an annual average basis are exempt from the requirements of this division (relating to Fugitive Emissions), except for 115.786(e) and (g) of this title (relating to Record keeping Requirements).	None	§ 115.786(e) § 115.786(g)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-HRVOC	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVO C Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv)	Heat exchanger heads, sight glasses, meters, gauges, sampling connections, bolted manways, hatches, sump covers, junction box vents, and covers and seals on VOC water separators within the process unit or processes listed in §115.780(a) in which a HRVO C is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.781(b) § 115.781(b)(10) § 115.781(b)(3) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) § 115.781(f) § 115.781(f)(1) § 115.781(f)(2) § 115.781(f)(3) § 115.781(f)(4) § 115.781(f)(5) § 115.781(f)(6) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2) § 115.789(1)(B)	§ 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) [G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.789(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-HRVOC	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVO C Fugitive Emissions	§ 115.781(b)(9) § 115.780(b) [G]§ 115.781(a) [G]§ 115.781(d) § 115.781(g)(3) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(2) § 115.782(c)(2)(A) § 115.782(c)(2)(A)(i) § 115.782(c)(2)(A)(ii) § 115.782(c)(2)(B) § 115.783(1) § 115.783(1)(A) § 115.783(1)(B) § 115.783(5) § 115.787(f) § 115.787(f)(4) § 115.787(g) § 115.788(a) § 115.788(a)(1) § 115.788(a)(2) § 115.788(a)(2)(A) § 115.788(a)(2)(B) § 115.788(a)(2)(C) § 115.788(a)(2)(C)(i) § 115.788(a)(2)(C)(ii) § 115.788(a)(2)(C)(iii) § 115.788(a)(2)(D) § 115.788(a)(3) § 115.788(a)(3)(A) § 115.788(a)(3)(B) [G]§ 115.788(g)	Bypass line valves within a petroleum refinery; synthetic organic chemical, polymer, resin, or methyl-tert-butyl ether manufacturing process; or natural gas/gasoline processing operation in which a highly-reactive volatile organic compound is a raw material, intermediate, final product, or in a waste stream is subject to the requirements of this division. A leak is defined as a screening concentration greater than 500 ppmv above background as methane for all components.	§ 115.781(b) § 115.781(b)(10) § 115.781(b)(4) § 115.781(b)(7) § 115.781(b)(7)(A) § 115.781(b)(7)(B) [G]§ 115.781(d) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.782(d)(2) § 115.786(a)(1)	§ 115.781(b)(10) § 115.781(g) § 115.781(g)(1) § 115.781(g)(2) § 115.781(g)(3) § 115.782(c)(2)(A)(ii) § 115.786(a)(1) § 115.786(a)(2) § 115.786(a)(2)(A) § 115.786(a)(2)(B) § 115.786(b)(1) § 115.786(b)(2) § 115.786(b)(2)(A) § 115.786(b)(2)(B) § 115.786(b)(2)(C) [G]§ 115.786(b)(3) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(2) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g) [G]§ 115.788(g)	§ 115.782(c)(2)(A)(ii) [G]§ 115.786(c) § 115.788(c) [G]§ 115.788(d) § 115.788(e) [G]§ 115.788(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVFUG-HRVOG	EU	R5780-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOG Fugitive Emissions	§ 115.787(d) § 115.780(b) [G]§ 115.781(a) § 115.782(a) § 115.782(b)(1) § 115.782(b)(2) § 115.782(c)(1) § 115.782(c)(1)(A) § 115.782(c)(1)(B) [G]§ 115.782(c)(1)(B)(i) § 115.782(c)(1)(B)(ii) [G]§ 115.782(c)(1)(B)(iii) § 115.782(c)(1)(B)(iv) § 115.782(c)(1)(C)(i) § 115.782(c)(1)(C)(i)(I) § 115.782(c)(1)(C)(i)(II) § 115.782(c)(1)(C)(i)(III) § 115.782(c)(1)(C)(ii) § 115.783(3) [G]§ 115.783(3)(A) [G]§ 115.783(3)(B) § 115.787(b) § 115.787(b)(1) § 115.787(g)	All agitators that are equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal are exempt from the monitoring requirement of §115.781(b) and (c). Submerged pumps or sealless pumps may be used to satisfy the requirements of this subsection.	§ 115.782(d)(2)	[G]§ 115.782(c)(1)(B)(i) [G]§ 115.786(c) § 115.786(d) § 115.786(d)(1) § 115.786(d)(2) § 115.786(d)(2)(A) § 115.786(d)(2)(B) § 115.786(d)(2)(C) § 115.786(e) § 115.786(g)	[G]§ 115.782(c)(1)(B)(i) § 115.783(3)(C) [G]§ 115.786(c)
TVREF3PROC	EU	63UUU-REF3	Hydrogen Chloride	40 CFR Part 63, Subpart UUU	§ 63.1567(a)(1)-Table 22.2 § 63.1567(a)(1) § 63.1567(a)(1)(i) § 63.1567(a)(2) § 63.1567(a)(2)-Table 23.1 § 63.1567(a)(3) § 63.1567(b)(3) § 63.1567(b)(4) § 63.1567(b)(4)(ii) § 63.1567(b)(5) § 63.1567(b)(5)-Table	For each existing cyclic or continuous CRU, you must reduce uncontrolled emissions of HCl by 97 percent by weight or to a concentration of 10 ppmv (dry basis), corrected to 3% oxygen.	§ 63.1567(b)(1) § 63.1567(b)(1)-Table 24.1 § 63.1567(b)(2) § 63.1567(b)(2)-Table 25.1.a.(1) § 63.1567(b)(2)-Table 25.1.a.(2) § 63.1567(b)(2)-Table 25.1.b § 63.1567(b)(2)-Table 25.1.c § 63.1567(b)(2)-	§ 63.1567(b)(1)-Table 24.1 § 63.1567(b)(2)-Table 25.1.e.(2) § 63.1567(b)(2)-Table 25.1.e.(3) § 63.1567(b)(2)-Table 25.1.e.(4) § 63.1567(b)(2)-Table 25.2.a.i § 63.1567(b)(2)-Table 25.2.b.i § 63.1567(c)(1)-	§ 63.1567(b)(6) § 63.1567(b)(7) § 63.1569(b)(3) § 63.1569(b)(4) § 63.1569(c)(1)-Table 39.5 § 63.1570(f) § 63.1571(a) § 63.1571(d)(4) [G]§ 63.1574(a) § 63.1574(c) § 63.1574(d) § 63.1574(d)-Table

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					26.2 § 63.1567(c)(1) § 63.1569(a)(1) § 63.1569(a)(1)(iii)- Table 36.3 § 63.1569(a)(3) § 63.1569(b)(2) § 63.1569(b)(2)-Table 38.1.c § 63.1569(c)(1) § 63.1569(c)(2) § 63.1570(a) § 63.1570(c) § 63.1570(d) § 63.1571(d) § 63.1571(d)(4) [G]§ 63.1571(e)		Table 25.1.d § 63.1567(b)(2)- Table 25.1.e.(1) § 63.1567(b)(2)- Table 25.1.e.(2) § 63.1567(b)(2)- Table 25.1.e.(3) § 63.1567(b)(2)- Table 25.1.e.(4) § 63.1567(b)(2)- Table 25.2.a.i § 63.1567(b)(2)- Table 25.2.b.i § 63.1567(c)(1)- Table 27.2 § 63.1567(c)(1)- Table 28.1.a § 63.1567(c)(1)- Table 28.1.b § 63.1569(c)(1)- Table 39.3 § 63.1571(a) § 63.1571(a)(1) [G]§ 63.1571(b) § 63.1572(c) § 63.1572(c)(1) § 63.1572(c)(1)- Table 41.8 § 63.1572(c)(2) § 63.1572(c)(3) § 63.1572(c)(4) [G]§ 63.1572(d)	Table 28.1.a § 63.1567(c)(1)- Table 28.1.b § 63.1567(c)(2) § 63.1569(c)(1)- Table 39.3 § 63.1569(c)(1)- Table 39.5 § 63.1570(c) § 63.1570(d) § 63.1572(c)(4) § 63.1572(c)(5) [G]§ 63.1576(a) § 63.1576(d) § 63.1576(e) § 63.1576(f) § 63.1576(g) § 63.1576(h) § 63.1576(i)	42.1 § 63.1574(d)-Table 42.2 § 63.1574(d)-Table 42.3 § 63.1575(a) § 63.1575(a)-Table 43.1 § 63.1575(a)-Table 43.2 [G]§ 63.1575(b) [G]§ 63.1575(c) [G]§ 63.1575(d) [G]§ 63.1575(f) § 63.1575(g) § 63.1575(k) [G]§ 63.1575(k)(1) [G]§ 63.1575(l)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
TVSRUPROC	EU	63UUU-SRU	SO ₂	40 CFR Part 63, Subpart UUU	§ 63.1568(a)(1)-Table 29.1.a § 63.1568(a)(1) § 63.1568(a)(2) § 63.1568(a)(2)-Table 30.1 § 63.1568(a)(2)-Table 30.6 § 63.1568(a)(3) § 63.1568(a)(4) § 63.1568(a)(4)(i) § 63.1568(a)(4)(iii) § 63.1568(b)(3) § 63.1568(b)(4) § 63.1568(b)(5) § 63.1568(b)(5)-Table 33.1.a § 63.1568(c)(1) § 63.1568(c)(1)-Table 35.1 § 63.1568(c)(2) § 63.1570(a) § 63.1570(c) § 63.1570(d)	For each new or existing Claus SRU part of a sulfur recovery plant with design capacity greater than 20 long tons per day and subject to NSPS for sulfur oxides in 40 CFR §60.104(a)(2) or §60.102a(f)(1), you must meet the emission limit for each process vent of 250 ppmv (dry basis) of sulfur dioxide (SO ₂) at zero percent excess air if you use an oxidation or reduction control system followed by incineration.	§ 63.1568(b)(1) § 63.1568(b)(1)-Table 31.1.a § 63.1568(b)(1)-Table 31.5 § 63.1568(c)(1)-Table 34.1.a § 63.1568(c)(1)-Table 35.5.a § 63.1568(c)(1)-Table 35.5.b § 63.1571(a) § 63.1571(a)(1) [G]§ 63.1571(b) § 63.1572(a) § 63.1572(a)(1)-Table 40.5 § 63.1572(a)(1)-Table 40.9 § 63.1572(a)(2) § 63.1572(a)(3) § 63.1572(a)(4) [G]§ 63.1572(d) ** See Alternative Requirement	§ 63.1568(b)(1)-Table 31.1.a § 63.1568(c)(1)-Table 34.1.a § 63.1570(c) § 63.1570(d) [G]§ 63.1576(a) § 63.1576(d) § 63.1576(e) § 63.1576(f) § 63.1576(g) § 63.1576(h) § 63.1576(i)	§ 63.1568(b)(6) § 63.1568(b)(7) § 63.1570(f) § 63.1571(a) [G]§ 63.1574(a) § 63.1574(c) § 63.1574(d) § 63.1574(d)-Table 42.1 § 63.1574(d)-Table 42.2 § 63.1574(d)-Table 42.3 § 63.1575(a) § 63.1575(a)-Table 43.1 § 63.1575(a)-Table 43.2 [G]§ 63.1575(b) [G]§ 63.1575(c) [G]§ 63.1575(e) [G]§ 63.1575(f) § 63.1575(g) § 63.1575(k) [G]§ 63.1575(k)(1) [G]§ 63.1575(k)(2) [G]§ 63.1575(l) [G]§ 63.1576(b)
VTCCG2	EP	63CC-VT-GRP2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(1) § 63.642(b) § 63.642(n)	All miscellaneous process vents from petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	[G]§ 63.645(g) § 63.645(h) § 63.645(h)(1) § 63.645(h)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(6)	§ 63.642(f) § 63.645(h)(2) § 63.655(f) § 63.655(f)(1)(ii) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
VTCCMT	EP	63CC-VT-MAINT	112(B) HAPS	40 CFR Part 63, Subpart CC	[G]§ 63.643(c) § 63.642(b) § 63.642(n)	An owner or operator may designate a process vent as a maintenance vent if the vent is only used as a result of startup, shutdown, maintenance, or inspection of equipment where equipment is emptied, depressurized, degassed or placed into service. The owner or operator must comply with the applicable requirements in §63.643(c)(1)-(3) for each maintenance vent. §63.643(c)(1)-(3).	[G]§ 63.643(c)	§ 63.643(d) § 63.655(i) [G]§ 63.655(i)(12) § 63.655(i)(6)	§ 63.642(f) § 63.655(g) [G]§ 63.655(g)(13) § 63.655(g)(14)
VTFCC003	EP	TX-111-CATREG	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
VTFCC003	EP	TX-115-VT<100#	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(8)	As an alternative to complying with the requirements of this division for a source that is addressed by a Chapter 115 contingency rule, the source may instead choose to comply with the requirements of the contingency rule. Each source choosing this option shall submit written notification to the ED and any local air pollution control program. When the ED and the local program receive such notification, the source will then be considered subject to the contingency rule.	None	None	§ 115.127(a)(8)
WPSLS	EU	TX-115-WS-ENCL	VOC	30 TAC Chapter 115, Water Separation	§ 115.132(a)(1)	VOC water separators must have each compartment totally enclosed with all openings sealed. Gauging and sampling devices shall be vapor-tight except during use.	[G]§ 115.135(a) § 115.136(a)(3) § 115.136(a)(4) ** See Periodic Monitoring Summary	§ 115.136(a)(3) § 115.136(a)(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
WPSLS	EU	60QQQ-C	VOC	40 CFR Part 60, Subpart QQQ	§ 60.692-3(a) § 60.692-1(a) § 60.692-3(a)(1) § 60.692-3(a)(2) § 60.692-3(a)(3) § 60.692-3(a)(5) § 60.692-3(b) § 60.692-3(e) § 60.692-5(b) § 60.692-5(d) [G]§ 60.692-5(e) § 60.692-6(a) § 60.692-6(b) § 60.692-7(b)	Except as noted, each oil-water separator tank, slop oil tank, storage vessel, or other auxiliary equipment shall be equipped with fixed roof, meeting following specifications:	§ 60.692-3(a)(4) § 60.695(a) § 60.695(a)(3) § 60.695(a)(3)(ii) § 60.696(a) [G]§ 60.696(b)	§ 60.695(a)(3) § 60.697(a) § 60.697(c) § 60.697(d) [G]§ 60.697(e) § 60.697(f)(1) [G]§ 60.697(f)(2) § 60.697(f)(3) § 60.697(f)(3)(i) § 60.697(f)(3)(ii) § 60.697(f)(3)(iii) § 60.697(f)(3)(iv) § 60.697(f)(3)(v) § 60.697(f)(3)(vi) § 60.697(f)(3)(vii) § 60.697(f)(3)(x) § 60.697(f)(3)(x)(B)	§ 60.698(b)(1) § 60.698(d) § 60.698(d)(3) § 60.698(d)(3)(ii) § 60.698(e)

Additional Monitoring Requirements

Compliance Assurance Monitoring Summary 253

Periodic Monitoring Summary 256

CAM Summary

Unit/Group/Process Information	
ID No.: DESALTER	
Control Device ID No.: BZSTRIP	Control Device Type: Other control device type
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Industrial Wastewater	SOP Index No.: TX-115-WW-BSU
Pollutant: VOC	Main Standard: § 115.142(1)
Monitoring Information	
Indicator: Steam flow rate	
Minimum Frequency: Four times per hour	
Averaging Period: One hour	
Deviation Limit: Minimum steam flow rate = 6,000 lb/hr when the benzene stripper is in normal operation.	
<p>CAM Text: The steam flow meter shall be calibrated in accordance with manufacturer's recommendations.</p> <p>The steam flow meter shall be validated in accordance with manufacturer's recommendations.</p> <p>The permit holder shall monitor the steam flow rate to the benzene stripper. Any hourly average below 6,000 lb/hr when the benzene stripper is in normal operation shall be considered and reported as a deviation.</p>	

CAM Summary

Unit/Group/Process Information	
ID No.: SRU001	
Control Device ID No.: INSRU001	Control Device Type: Thermal incinerator (direct flame incinerator/regenerative thermal oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: REG2-SRUIN001
Pollutant: SO ₂	Main Standard: § 112.7(a)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: four times per hour	
Averaging Period: one hour	
Deviation Limit: The minimum combustion temperature is 1250 degrees F. This requirement is applicable during operation of the tail gas incinerator.	
<p>CAM Text: The monitoring device should be installed in the combustion chamber or immediately downstream of the combustion chamber. Each monitoring device shall be calibrated at a frequency in accordance with the manufacturer's specifications, other written procedures that provide an adequate assurance that the device is calibrated accurately, or at least annually, whichever is more frequent, and shall be accurate to within one of the following:</p> <ul style="list-style-type: none"> ± 2% of reading; or ± 2.5 degrees Celsius. 	

CAM Summary

Unit/Group/Process Information	
ID No.: SRU001	
Control Device ID No.: INSRU001	Control Device Type: Thermal incinerator (direct flame incinerator/regenerative thermal oxidizer)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: REG2-SRUIN001
Pollutant: SO ₂	Main Standard: § 112.7(a)
Monitoring Information	
Indicator: SO ₂ Mass Emissions in Pounds per Hour	
Minimum Frequency: four times per hour	
Averaging Period: one hour	
Deviation Limit: Maximum SO ₂ emission limit = 7.29 lb SO ₂ /hr. This requirement is applicable during operation of the tail gas incinerator.	
CAM Text: Use a continuous emission monitoring system (CEMS) to measure and record the mass emissions rate of sulfur dioxide expressed in pounds per hour in the exhaust stream of the control device. The CEMS shall be operated in accordance with the monitoring requirements of 40 CFR § 60.13 and the Performance Specifications of 40 CFR Part 60, Appendix B.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: BLRHT006	
Control Device ID No.: SCR	Control Device Type: Selective catalytic reduction (SCR)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: TX-117B-NG-NH3
Pollutant: NH ₃	Main Standard: § 117.310(c)(2)
Monitoring Information	
Indicator: Ammonia concentration	
Minimum Frequency: Once per hour	
Averaging Period: One hour (excluding authorized MSS periods)	
Deviation Limit: Maximum ammonia concentration = 10 ppmv at 3.0% O ₂ , dry	
<p>Periodic Monitoring Text: Calculate the ammonia emissions using the mass balance equation specified in 30 TAC § 117.8130(1) using the ammonia injection rate and the differential NO_x concentration measured upstream and downstream of the control device that injects ammonia into the exhaust. Any hourly average exceeding the ammonia concentration limit shall be considered and reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: BLRHT006	
Control Device ID No.: SCR	Control Device Type: Selective catalytic reduction (SCR)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: TX-117B-RG-NH3
Pollutant: NH ₃	Main Standard: § 117.310(c)(2)
Monitoring Information	
Indicator: Ammonia concentration	
Minimum Frequency: Once per hour	
Averaging Period: One hour (excluding authorized MSS periods)	
Deviation Limit: Maximum ammonia concentration = 10 ppmv at 3.0% O ₂ , dry	
<p>Periodic Monitoring Text: Calculate the ammonia emissions using the mass balance equation specified in 30 TAC § 117.8130(1) using the ammonia injection rate and the differential NO_x concentration measured upstream and downstream of the control device that injects ammonia into the exhaust. Any hourly average exceeding the ammonia concentration limit shall be considered and reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CRUHT001	
Control Device ID No.: SCR	Control Device Type: Selective catalytic reduction (SCR)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: TX117B>200
Pollutant: NH ₃	Main Standard: § 117.310(c)(2)
Monitoring Information	
Indicator: Ammonia concentration	
Minimum Frequency: Once per hour	
Averaging Period: 24-hour rolling average (excluding authorized MSS periods)	
Deviation Limit: Maximum ammonia concentration = 10 ppmv at 3.0% O ₂ , dry	
<p>Periodic Monitoring Text: Calculate the ammonia emissions using the mass balance equation specified in 30 TAC § 117.8130(1) using the ammonia injection rate and the differential NO_x concentration measured upstream and downstream of the control device that injects ammonia into the exhaust. Any 24-hour rolling average exceeding the ammonia concentration limit shall be considered and reported as a deviation.</p> <p>This requirement is not applicable during authorized MSS periods when the SCR is not operating in accordance with NSR permit 80804.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CRUHT002	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: TX117B-100-200
Pollutant: NH ₃	Main Standard: § 117.310(c)(2)
Monitoring Information	
Indicator: Ammonia concentration	
Minimum Frequency: Once per hour	
Averaging Period: 24-hour rolling average	
Deviation Limit: Maximum ammonia concentration = 10 ppmv at 3.0% O ₂ , dry	
<p>Periodic Monitoring Text: Calculate the ammonia emissions using the mass balance equation specified in 30 TAC § 117.8130(1) using the ammonia injection rate and the differential NO_x concentration measured upstream and downstream of the control device that injects ammonia into the exhaust. Any 24-hour rolling average exceeding the ammonia concentration limit shall be considered and reported as a deviation.</p> <p>This requirement is not applicable during authorized MSS periods when the SCR is not operating in accordance with NSR permit 80804.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CRUHT004	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: TX117B-<40
Pollutant: CO	Main Standard: § 117.325(a)
Monitoring Information	
Indicator: CO Concentration	
Minimum Frequency: Annually	
Averaging Period: One-hour average (excluding authorized MSS periods)	
Deviation Limit: Maximum CO concentration = 400 ppmv	
Periodic Monitoring Text: Conduct a tune-up of the boiler or process heater annually as specified in 40 CFR § 63.7540 and in Item 3 of Table 3 to Subpart DDDDD of 40 CFR Part 63. Any hourly average above the maximum limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CRUVT001	
Control Device ID No.: CRUHT001	Control Device Type: Steam generating unit (boiler)/process heater (design heat input is less than 44 megawatts)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Unit Turn & Vac System-Pet Ref	SOP Index No.: R5311-1
Pollutant: VOC	Main Standard: § 115.311(a)(1)
Monitoring Information	
Indicator: Combustion Temperature / Exhaust Gas Temperature	
Minimum Frequency: Hourly	
Averaging Period: Daily average excluding periods of MSS	
Deviation Limit: Temperature below 1000 degrees F on T1609 and T1610 thermocouples shall be reported as a deviation.	
Periodic Monitoring Text: Measure and record the combustion temperature in the combustion chamber or immediately downstream of the combustion chamber into which the volatile organic compound is introduced. Any daily average (excluding periods of MSS as authorized in NSR 22039, SC 11 and 80804, SC 13.C) below the minimum limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: FCCHT002	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: TX117B-400ppmCO
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: CO Concentration	
Minimum Frequency: Annually	
Averaging Period: One-hour average (excluding authorized MSS periods)	
Deviation Limit: Maximum CO concentration = 400 ppmv	
Periodic Monitoring Text: Conduct a tune-up of the boiler or process heater annually as specified in 40 CFR § 63.7540 and in Item 3 of Table 3 to Subpart DDDDD of 40 CFR Part 63. Any hourly average above the maximum limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-ALKHT	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: TX117B-40-100
Pollutant: CO	Main Standard: § 117.325(a)
Monitoring Information	
Indicator: CO Concentration	
Minimum Frequency: Annually	
Averaging Period: One-hour average (excluding authorized MSS periods)	
Deviation Limit: Maximum CO concentration = 400 ppmv	
Periodic Monitoring Text: Conduct a tune-up of the boiler or process heater annually as specified in 40 CFR § 63.7540 and in Item 3 of Table 3 to Subpart DDDDD of 40 CFR Part 63. Any hourly average above the maximum limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-REFHT	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: TX117B-<40
Pollutant: CO	Main Standard: § 117.325(a)
Monitoring Information	
Indicator: CO Concentration	
Minimum Frequency: Annually	
Averaging Period: One-hour average (excluding authorized MSS periods)	
Deviation Limit: Maximum CO concentration = 400 ppmv	
Periodic Monitoring Text: Conduct a tune-up of the boiler or process heater annually as specified in 40 CFR § 63.7540 and in Item 3 of Table 3 to Subpart DDDDD of 40 CFR Part 63. Any hourly average above the maximum limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-VT-CRU	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: TX-111<72-HF
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Records or Visible Emissions	
Minimum Frequency: once per year	
Averaging Period: block 6-minute average	
Deviation Limit: Burning alternate fuels or Maximum Opacity = 15%	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. A deviation shall be reported if fuels other than pipeline-quality sweet natural gas containing no more than 5 grains of total sulfur; fuel gas containing no more than 10 grains of hydrogen sulfide (H₂S) per 100 dry standard cubic feet (dscf); or fuel gas containing no more than 162 parts per million by volume of H₂S on a 3-hour average basis are burned in the unit.</p> <p>Alternatively, visible emissions observations shall be made and recorded in accordance with EPA Test Method 22. If visible emissions are observed, a deviation shall be reported unless an opacity reading is made in accordance with EPA Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-VT-HTR<72	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: TX-111<72-LF
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Fuel Records or Visible Emissions	
Minimum Frequency: once per year	
Averaging Period: block 6-minute average	
Deviation Limit: Burning alternate fuels or Maximum Opacity = 30%	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. A deviation shall be reported if fuels other than pipeline-quality sweet natural gas containing no more than 5 grains of total sulfur; fuel gas containing no more than 10 grains of hydrogen sulfide (H₂S) per 100 dry standard cubic feet (dscf); or fuel gas containing no more than 162 parts per million by volume of H₂S on a 3-hour average basis are burned in the unit.</p> <p>Alternatively, visible emissions observations shall be made and recorded in accordance with EPA Test Method 22. If visible emissions are observed, a deviation shall be reported unless an opacity reading is made in accordance with EPA Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-VT-HTR>72	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: TX-111>72-LF
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Records or Visible Emissions	
Minimum Frequency: once per year	
Averaging Period: block 6-minute average	
Deviation Limit: Burning alternate fuels or Maximum Opacity = 20%	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. A deviation shall be reported if fuels other than pipeline-quality sweet natural gas containing no more than 5 grains of total sulfur; fuel gas containing no more than 10 grains of hydrogen sulfide (H₂S) per 100 dry standard cubic feet (dscf); or fuel gas containing no more than 162 parts per million by volume of H₂S on a 3-hour average basis are burned in the unit.</p> <p>Alternatively, visible emissions observations shall be made and recorded in accordance with EPA Test Method 22. If visible emissions are observed, a deviation shall be reported unless an opacity reading is made in accordance with EPA Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-VT-LOWVOC	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: TX-111>72-LF
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per year	
Averaging Period: block 6-minute average	
Deviation Limit: Presence of visible emissions or Maximum Opacity = 20%	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded in accordance with EPA Test Method 22. If visible emissions are observed, a deviation shall be reported unless an opacity reading is made in accordance with EPA Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-VT-LSG-REF	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: TX-111>72-LF
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per year	
Averaging Period: block 6-minute average	
Deviation Limit: Presence of visible emissions or Maximum Opacity = 20%	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded in accordance with EPA Test Method 22. If visible emissions are observed, a deviation shall be reported unless an opacity reading is made in accordance with EPA Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-VT-VE<72	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: TX-111<72-LF
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: block 6-minute average	
Deviation Limit: Maximum Opacity = 30%. This monitoring requirement is not applicable during periods when the equipment does not operate for the entire quarter.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: HTREF201	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: TX-111>72-LF
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Records or Visible Emissions	
Minimum Frequency: once per year	
Averaging Period: block 6-minute average	
Deviation Limit: Burning alternate fuels or Maximum Opacity = 20%	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. A deviation shall be reported if fuels other than pipeline-quality sweet natural gas containing no more than 5 grains of total sulfur; fuel gas containing no more than 10 grains of hydrogen sulfide (H₂S) per 100 dry standard cubic feet (dscf); or fuel gas containing no more than 162 parts per million by volume of H₂S on a 3-hour average basis are burned in the unit.</p> <p>Alternatively, visible emissions observations shall be made and recorded in accordance with EPA Test Method 22. If visible emissions are observed, a deviation shall be reported unless an opacity reading is made in accordance with EPA Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: HTREF2631	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: TX-111>72-HF
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Records or Visible Emissions	
Minimum Frequency: once per year	
Averaging Period: block 6-minute average	
Deviation Limit: Burning alternate fuels or Maximum Opacity = 15%	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. A deviation shall be reported if fuels other than pipeline-quality sweet natural gas containing no more than 5 grains of total sulfur; fuel gas containing no more than 10 grains of hydrogen sulfide (H₂S) per 100 dry standard cubic feet (dscf); or fuel gas containing no more than 162 parts per million by volume of H₂S on a 3-hour average basis are burned in the unit.</p> <p>Alternatively, visible emissions observations shall be made and recorded in accordance with EPA Test Method 22. If visible emissions are observed, a deviation shall be reported unless an opacity reading is made in accordance with EPA Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: INDOK001	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: TX-111>72-LF
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per year	
Averaging Period: block 6-minute average	
Deviation Limit: Maximum Opacity = 20%	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: INSRU001	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: TX-111<72-LF
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: block 6-minute average	
Deviation Limit: Maximum Opacity = 30%. This monitoring requirement is not applicable during periods when the equipment does not operate for the entire quarter.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: LSGHT001	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: TX117B-310C
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: CO Concentration	
Minimum Frequency: Annually	
Averaging Period: One-hour average (excluding authorized MSS periods)	
Deviation Limit: Maximum CO concentration = 400 ppmv	
Periodic Monitoring Text: Conduct a tune-up of the boiler or process heater annually as specified in 40 CFR § 63.7540 and in Item 3 of Table 3 to Subpart DDDDD of 40 CFR Part 63. Any hourly average above the maximum limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: REFHT201	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: TX117B-40-100
Pollutant: CO	Main Standard: § 117.325(a)
Monitoring Information	
Indicator: CO Concentration	
Minimum Frequency: Annually	
Averaging Period: One-hour average (excluding authorized MSS periods)	
Deviation Limit: Maximum CO concentration = 400 ppmv	
Periodic Monitoring Text: Conduct a tune-up of the boiler or process heater annually as specified in 40 CFR § 63.7540 and in Item 3 of Table 3 to Subpart DDDDD of 40 CFR Part 63. Any hourly average above the maximum limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: TKFTK250	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Water Separation	SOP Index No.: TX-115-WS-ROOF
Pollutant: VOC	Main Standard: § 115.132(a)(2)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Any defects (as described below) detected in the inspection of the internal floating roof and seals shall be reported as a deviation.	
<p>Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any defects in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: TKFTK301	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Water Separation	SOP Index No.: TX-115-WS-ROOF
Pollutant: VOC	Main Standard: § 115.132(a)(2)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Any defects (as described below) detected in the inspection of the internal floating roof and seals shall be reported as a deviation.	
<p>Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any defects in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: TKFTK328	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Water Separation	SOP Index No.: TX-115-WS-ROOF
Pollutant: VOC	Main Standard: § 115.132(a)(2)
Monitoring Information	
Indicator: External Floating Roof	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Any defects (as described below) detected in the inspection of the external floating roof and seals shall be reported as a deviation.	
<p>Periodic Monitoring Text: Visually inspect and record the inspection of the external floating roof to ensure: the roof is floating on the surface of the VOC and not on the leg supports, liquid has not accumulated on the external floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any defects in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the external floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: VTFCC003	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: TX-111-CATREG
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: block 6-minute average	
Deviation Limit: Maximum Opacity = 30%. This monitoring requirement is not applicable during periods when the equipment does not operate for the entire calendar quarter.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: WPSLS	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Water Separation	SOP Index No.: TX-115-WS-ENCL
Pollutant: VOC	Main Standard: § 115.132(a)(1)
Monitoring Information	
Indicator: VOC Concentration	
Minimum Frequency: Quarterly	
Averaging Period: Specified in Test Method 21	
Deviation Limit: Any monitoring data exceeding 500 ppmv for all leak interfaces other than a seal around a shaft that passes through a cover opening or 10,000 ppm for shaft seal systems shall be considered and reported as a deviation.	
<p>Periodic Monitoring Text: Measure and record the VOC concentration using a portable analyzer to monitor VOC concentration around the immediate area of the compartment in accordance with 40 CFR Part 60, Appendix A, Method 21. Each potential leak interface (i.e., a location where organic vapor leakage could occur) on the cover and associated closure devices shall be checked. Potential leak interfaces that are associated with covers and closure devices include, but are not limited to: the interface of the cover and its foundation mounting; the periphery of any opening on the cover and its associated closure device; and the sealing seat interface on a spring-loaded pressure relief valve. The owner or operator may choose to adjust the detection instrument readings for the background organic concentration level.</p> <p>The monitoring instrumentation shall be maintained and operated in accordance with manufacturer's specifications or other written procedures.</p> <p>Any Method 21 measurement greater than the maximum VOC limit indicated in the Deviation Limit above shall be considered and reported as a deviation as required by § 122.145(2).</p>	

Permit Shield

Permit Shield 283

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
BLRHT004	N/A	30 TAC Chapter 112, Sulfur Compounds	Does not burn solid or liquid fuel
BLRHT004	N/A	40 CFR Part 60, Subpart D	Complying with NSPS Db
BLRHT006	N/A	30 TAC Chapter 112, Sulfur Compounds	Does not burn solid or liquid fuel
BLRHT006	N/A	40 CFR Part 60, Subpart D	Complying with NSPS Db
BLRHT010	N/A	30 TAC Chapter 112, Sulfur Compounds	Does not burn solid or liquid fuel
BLRHT010	N/A	40 CFR Part 60, Subpart D	Constructed prior to August 17, 1971 and has not been modified or reconstructed.
BLRHT010	N/A	40 CFR Part 60, Subpart Db	Constructed prior to June 19, 1984 and has not been modified or reconstructed.
BLRHT010	N/A	40 CFR Part 60, Subpart J	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
BLRHT010	N/A	40 CFR Part 63, Subpart DDDDD	Boiler is subject to 40 CFR Part 63, Subpart UUU.
C3UL	N/A	40 CFR Part 63, Subpart CC	Propane unloading is not part of any petroleum refining process unit
CAUSUNLOAD	N/A	40 CFR Part 63, Subpart EEEE	Transfer rack does not unload organic liquid
CKRSUMP	N/A	40 CFR Part 60, Subpart QQQ	Constructed prior to May 4, 1987 and has not been modified or reconstructed.
CRUHT001	N/A	30 TAC Chapter 112, Sulfur Compounds	Does not burn solid or liquid fuel
CRUHT001	N/A	40 CFR Part 60, Subpart J	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
CRUHT002	N/A	30 TAC Chapter 112, Sulfur Compounds	Does not burn solid or liquid fuel
CRUHT002	N/A	40 CFR Part 60, Subpart J	Constructed prior to June 11, 1973 and has not been modified or reconstructed.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
CRUHT004	N/A	30 TAC Chapter 112, Sulfur Compounds	Does not burn solid or liquid fuel
D-202	N/A	40 CFR Part 61, Subpart FF	Process vessel not used primarily to store or manage waste as described in 40 CFR 61.342(c)(1)(iii).
D-203	N/A	40 CFR Part 61, Subpart FF	Process vessel not used primarily to store or manage waste as described in 40 CFR 61.342(c)(1)(iii).
D-599	N/A	30 TAC Chapter 115, Storage of VOCs	Capacity < 1,000 gallons
D-599	N/A	40 CFR Part 60, Subpart K	Capacity < 40,000 gallons
D-599	N/A	40 CFR Part 60, Subpart Ka	Capacity < 40,000 gallons
D-599	N/A	40 CFR Part 60, Subpart Kb	Capacity < 75 cubic meters
D-599	N/A	40 CFR Part 61, Subpart FF	Tank does not store benzene-containing waste
D-599	N/A	40 CFR Part 63, Subpart CC	Vessel volume is < 10,000 gallons.
DOKLO001	N/A	40 CFR Part 63, Subpart EEEE	Barge loading is not an affected source (barges do not meet the definition of a transport vessel or a container)
DOKLO001	N/A	40 CFR Part 63, Subpart Y	MACT Y does not apply to marine tank vessel loading operations that are contiguous with refinery operations at sources subject to and complying with MACT CC as specified in 40 CFR §63.560(d)(3).
EMGEN006	N/A	40 CFR Part 60, Subpart JJJJ	Compression ignition (CI) engines are not subject to 40 CFR Part 60, Subpart JJJJ
EMGEN007	N/A	40 CFR Part 60, Subpart JJJJ	Compression ignition (CI) engines are not subject to 40 CFR Part 60, Subpart JJJJ

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
EMWWEN1	N/A	40 CFR Part 60, Subpart JJJJ	Compression ignition (CI) engines are not subject to 40 CFR Part 60, Subpart JJJJ
FCCHT002	N/A	30 TAC Chapter 112, Sulfur Compounds	Does not burn solid or liquid fuel
FCCHT002	N/A	40 CFR Part 60, Subpart J	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
FEWWS	N/A	40 CFR Part 60, Subpart QQQ	Constructed prior to May 4, 1987 and has not been modified or reconstructed.
FUGCTALK	N/A	40 CFR Part 63, Subpart Q	No chromium used on or after September 4, 1994.
FUGCTCPX	N/A	40 CFR Part 63, Subpart Q	No chromium used on or after September 4, 1994.
FUGCTUDX	N/A	40 CFR Part 63, Subpart Q	No chromium used on or after September 4, 1994.
GRP-ALKHT	ALKHT001, ALKHT002	30 TAC Chapter 112, Sulfur Compounds	Does not burn solid or liquid fuel.
GRP-ALKHT	ALKHT001, ALKHT002	30 TAC Chapter 115, Vent Gas Controls	Combustion unit not used as a control device for any vent gas stream subject to 30 TAC Chapter 115, Subchapter B, Division 2, Vent Gas Control.
GRP-ALKHT	ALKHT001, ALKHT002	40 CFR Part 63, Subpart CC	Combustion source is not a miscellaneous process vent as defined in §63.641.
GRP-CC2-1	TKFTK065, TKFTK335, TKFTK336, TKFTK337	30 TAC Chapter 115, Storage of VOCs	Tanks do not store volatile organic compounds (VOC).
GRP-CC2-1	TKFTK065, TKFTK335, TKFTK336, TKFTK337	40 CFR Part 60, Subpart K	Constructed prior to June 11, 1973 and has not been modified or reconstructed.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-CC2-1	TKFTK065, TKFTK335, TKFTK336, TKFTK337	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.
GRP-CC2-1	TKFTK065, TKFTK335, TKFTK336, TKFTK337	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
GRP-CC2-1	TKFTK065, TKFTK335, TKFTK336, TKFTK337	40 CFR Part 60, Subpart QQQ	Constructed prior to May 4, 1987 and has not been modified or reconstructed.
GRP-CC2-1	TKFTK065, TKFTK335, TKFTK336, TKFTK337	40 CFR Part 61, Subpart FF	Vessels do not store or manage benzene-containing waste.
GRP-CC2-1	TKFTK065, TKFTK335, TKFTK336, TKFTK337	40 CFR Part 63, Subpart EEEE	Vessels do not store organic liquids as defined in §63.2406.
GRP-CC2-2	TKFTK205, TKFTK210	40 CFR Part 60, Subpart K	Constructed after May 19, 1978.
GRP-CC2-2	TKFTK205, TKFTK210	40 CFR Part 60, Subpart Ka	Constructed after July 23, 1984.
GRP-CC2-2	TKFTK205, TKFTK210	40 CFR Part 60, Subpart Kb	Capacity greater than 151 cubic meters with a TVP less than 3.5 kPa (0.5 psia).
GRP-CC2-2	TKFTK205, TKFTK210	40 CFR Part 60, Subpart QQQ	Tanks are not part of wastewater system that receives, treats, or processes oily wastewater from petroleum refinery process units.
GRP-CC2-2	TKFTK205, TKFTK210	40 CFR Part 61, Subpart FF	Vessels do not store or manage benzene-containing waste.
GRP-CC2-2	TKFTK205, TKFTK210	40 CFR Part 63, Subpart EEEE	Vessels do not store organic liquids as defined in §63.2406.
GRP-CC2-3	TKFTK307, TKFTK308, TKFTK331, TKFTK820	40 CFR Part 60, Subpart K	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
GRP-CC2-3	TKFTK307, TKFTK308, TKFTK331, TKFTK820	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-CC2-3	TKFTK307, TKFTK308, TKFTK331, TKFTK820	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
GRP-CC2-3	TKFTK307, TKFTK308, TKFTK331, TKFTK820	40 CFR Part 60, Subpart QQQ	Constructed prior to May 4, 1987 and has not been modified or reconstructed.
GRP-CC2-3	TKFTK307, TKFTK308, TKFTK331, TKFTK820	40 CFR Part 61, Subpart FF	Vessels do not store or manage benzene-containing waste.
GRP-CC2-3	TKFTK307, TKFTK308, TKFTK331, TKFTK820	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR Part 63, Subpart CC.
GRP-CC2-4	TKFTK051, TKFTK330	40 CFR Part 60, Subpart K	Constructed after May 19, 1978.
GRP-CC2-4	TKFTK051, TKFTK330	40 CFR Part 60, Subpart Ka	Constructed after July 23, 1984.
GRP-CC2-4	TKFTK051, TKFTK330	40 CFR Part 60, Subpart Kb	Capacity greater than 151 cubic meters with a TVP less than 3.5 kPa (0.5 psia).
GRP-CC2-4	TKFTK051, TKFTK330	40 CFR Part 60, Subpart QQQ	Tank is not part of a wastewater system that receives, treats, or processes oily wastewater from petroleum refinery process units.
GRP-CC2-4	TKFTK051, TKFTK330	40 CFR Part 61, Subpart FF	Vessels do not store or manage benzene-containing waste.
GRP-CC2-4	TKFTK051, TKFTK330	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR Part 63, Subpart CC.
GRP-EMENW	EMENW001, EMENW002, EMENW003	40 CFR Part 60, Subpart IIII	Commenced construction before July 11, 2005 and not modified or reconstructed after July 11, 2005.
GRP-EMENW	EMENW001, EMENW002, EMENW003	40 CFR Part 60, Subpart JJJJ	Compression ignition (CI) engines are not subject.
GRP-EMENW2005-	EMENW004, EMENW005, EMENW006	40 CFR Part 60, Subpart JJJJ	Compression ignition (CI) engines are not subject.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-NEMENG-L	NEMENG001, NEMENG002, NEMENG003	40 CFR Part 60, Subpart JJJJ	Stationary SI ICE exempt as it commenced construction before June 12, 2006 and not modified or reconstructed after June 12, 2006.
GRP-PS-TKS	LUBETK1, LUBETK10, LUBETK11, LUBETK12, LUBETK2, LUBETK3, LUBETK4, LUBETK5, LUBETK6, LUBETK7, LUBETK8, LUBETK9, NALCOTK1, NALCOTK2, TKFTK010, TKFTK027B, TKFTK049, TKFTK313, TKFTK318, TKFTK405, TKFTK406, TKFTK535, TKFTK700, TKFTK710, TKFTKD-8, TKFTKD-9, TKFTKF405, TKFTKGDISL, TKGRSOAP, WESTDSLTK1, WESTDSLTK2	30 TAC Chapter 115, Storage of VOCs	Tank does not store volatile organic compounds or the storage capacity of the tank is less than 1,000 gallons.
GRP-PS-TKS	LUBETK1, LUBETK10, LUBETK11, LUBETK12, LUBETK2, LUBETK3, LUBETK4, LUBETK5, LUBETK6, LUBETK7, LUBETK8, LUBETK9, NALCOTK1, NALCOTK2, TKFTK010, TKFTK027B, TKFTK049, TKFTK313, TKFTK318, TKFTK405, TKFTK406, TKFTK535, TKFTK700, TKFTK710, TKFTKD-8, TKFTKD-9, TKFTKF405, TKFTKGDISL, TKGRSOAP, WESTDSLTK1, WESTDSLTK2	40 CFR Part 60, Subpart K	Tank does not store petroleum liquids or the storage capacity of the tank is less than 40,000 gallons or the tank was constructed prior to June 11, 1973.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-PS-TKS	LUBETK1, LUBETK10, LUBETK11, LUBETK12, LUBETK2, LUBETK3, LUBETK4, LUBETK5, LUBETK6, LUBETK7, LUBETK8, LUBETK9, NALCOTK1, NALCOTK2, TKFTK010, TKFTK027B, TKFTK049, TKFTK313, TKFTK318, TKFTK405, TKFTK406, TKFTK535, TKFTK700, TKFTK710, TKFTKD-8, TKFTKD-9, TKFTKF405, TKFTKGDISL, TKGRSOAP, WESTDSLTK1, WESTDSLTK2	40 CFR Part 60, Subpart Ka	Tank does not store petroleum liquids or the storage capacity of the tank is less than 40,000 gallons or the tank was constructed prior to May 18, 1978.
GRP-PS-TKS	LUBETK1, LUBETK10, LUBETK11, LUBETK12, LUBETK2, LUBETK3, LUBETK4, LUBETK5, LUBETK6, LUBETK7, LUBETK8, LUBETK9, NALCOTK1, NALCOTK2, TKFTK010, TKFTK027B, TKFTK049, TKFTK313, TKFTK318, TKFTK405, TKFTK406, TKFTK535, TKFTK700, TKFTK710, TKFTKD-8, TKFTKD-9, TKFTKF405, TKFTKGDISL, TKGRSOAP, WESTDSLTK1, WESTDSLTK2	40 CFR Part 60, Subpart Kb	Tank does not store petroleum liquids or the storage capacity of the tank is less than 75 cubic meters or the tank was constructed prior to July 23, 1984.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-PS-TKS	LUBETK1, LUBETK10, LUBETK11, LUBETK12, LUBETK2, LUBETK3, LUBETK4, LUBETK5, LUBETK6, LUBETK7, LUBETK8, LUBETK9, NALCOTK1, NALCOTK2, TKFTK010, TKFTK027B, TKFTK049, TKFTK313, TKFTK318, TKFTK405, TKFTK406, TKFTK535, TKFTK700, TKFTK710, TKFTKD-8, TKFTKD-9, TKFTKF405, TKFTKGDISL, TKGRSOAP, WESTDSLTK1, WESTDSLTK2	40 CFR Part 60, Subpart QQQ	Tanks are not part of a wastewater system that receives, treats, or processes only wastewater from petroleum refinery process units.
GRP-PS-TKS	LUBETK1, LUBETK10, LUBETK11, LUBETK12, LUBETK2, LUBETK3, LUBETK4, LUBETK5, LUBETK6, LUBETK7, LUBETK8, LUBETK9, NALCOTK1, NALCOTK2, TKFTK010, TKFTK027B, TKFTK049, TKFTK313, TKFTK318, TKFTK405, TKFTK406, TKFTK535, TKFTK700, TKFTK710, TKFTKD-8, TKFTKD-9, TKFTKF405, TKFTKGDISL, TKGRSOAP, WESTDSLTK1, WESTDSLTK2	40 CFR Part 61, Subpart FF	Vessels do not store or manage benzene-containing waste.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-PS-TKS	LUBETK1, LUBETK10, LUBETK11, LUBETK12, LUBETK2, LUBETK3, LUBETK4, LUBETK5, LUBETK6, LUBETK7, LUBETK8, LUBETK9, NALCOTK1, NALCOTK2, TKFTK010, TKFTK027B, TKFTK049, TKFTK313, TKFTK318, TKFTK405, TKFTK406, TKFTK535, TKFTK700, TKFTK710, TKFTKD-8, TKFTKD-9, TKFTKF405, TKFTKGDISL, TKGRSOAP, WESTDSLTK1, WESTDSLTK2	40 CFR Part 63, Subpart CC	These tanks are not a MACT CC storage vessel as defined in §63.641, do not contain hazardous air pollutants, or are used to store diesel and are not part of any petroleum refining process unit.
GRP-PS-TKS	LUBETK1, LUBETK10, LUBETK11, LUBETK12, LUBETK2, LUBETK3, LUBETK4, LUBETK5, LUBETK6, LUBETK7, LUBETK8, LUBETK9, NALCOTK1, NALCOTK2, TKFTK010, TKFTK027B, TKFTK049, TKFTK313, TKFTK318, TKFTK405, TKFTK406, TKFTK535, TKFTK700, TKFTK710, TKFTKD-8, TKFTKD-9, TKFTKF405, TKFTKGDISL, TKGRSOAP, WESTDSLTK1, WESTDSLTK2	40 CFR Part 63, Subpart EEEE	Vessels do not store organic liquids as defined in §63.2406.
GRP-REFHT	REFHT001, REFHT002	30 TAC Chapter 112, Sulfur Compounds	Heaters do not burn solid or liquid fuel.
GRP-REFHT	REFHT001, REFHT002	30 TAC Chapter 115, Vent Gas Controls	Combustion unit not used as a control device for any vent gas stream subject to 30 TAC Chapter 115, Subchapter B, Division 2, Vent Gas Control.
GRP-REFHT	REFHT001, REFHT002	40 CFR Part 60, Subpart J	Constructed prior to June 11, 1973 and has not been modified or reconstructed.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-REFHT	REFHT001, REFHT002	40 CFR Part 63, Subpart CC	Combustion source is not a process vent as defined in §63.641.
GRP-TVTKS-1	TKFTK815, TKFTK816, TKFTK817	40 CFR Part 60, Subpart K	Rule overlap with NSPS K; complying with MACT CC.
GRP-TVTKS-1	TKFTK815, TKFTK816, TKFTK817	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.
GRP-TVTKS-1	TKFTK815, TKFTK816, TKFTK817	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
GRP-TVTKS-1	TKFTK815, TKFTK816, TKFTK817	40 CFR Part 60, Subpart QQQ	Constructed prior to May 4, 1987 and has not been modified or reconstructed.
GRP-TVTKS-1	TKFTK815, TKFTK816, TKFTK817	40 CFR Part 61, Subpart FF	Vessels do not store or manage benzene-containing waste.
GRP-TVTKS-1	TKFTK815, TKFTK816, TKFTK817	40 CFR Part 63, Subpart EEEE	Tanks are subject to 40 CFR Part 63, Subpart CC.
GRP-TVTKS-3	TKFTK340, TKFTK341, TKFTK353	40 CFR Part 60, Subpart K	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
GRP-TVTKS-3	TKFTK340, TKFTK341, TKFTK353	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.
GRP-TVTKS-3	TKFTK340, TKFTK341, TKFTK353	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
GRP-TVTKS-3	TKFTK340, TKFTK341, TKFTK353	40 CFR Part 60, Subpart QQQ	Constructed prior to May 4, 1987 and has not been modified or reconstructed.
GRP-TVTKS-3	TKFTK340, TKFTK341, TKFTK353	40 CFR Part 61, Subpart FF	Vessels do not store or manage benzene-containing waste.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-TVTKS-3	TKFTK340, TKFTK341, TKFTK353	40 CFR Part 63, Subpart EEEE	Tanks are subject to 40 CFR Part 63, Subpart CC.
GRP-TVTKS-5	TKFTK824, TKFTK825, TKFTK826	40 CFR Part 60, Subpart K	Constructed after May 19, 1978.
GRP-TVTKS-5	TKFTK824, TKFTK825, TKFTK826	40 CFR Part 60, Subpart Ka	Rule overlap with NSPS Ka, complying with MACT CC.
GRP-TVTKS-5	TKFTK824, TKFTK825, TKFTK826	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
GRP-TVTKS-5	TKFTK824, TKFTK825, TKFTK826	40 CFR Part 60, Subpart QQQ	Constructed prior to May 4, 1987 and has not been modified or reconstructed.
GRP-TVTKS-5	TKFTK824, TKFTK825, TKFTK826	40 CFR Part 61, Subpart FF	Tank does not store benzene-containing waste.
GRP-TVTKS-5	TKFTK824, TKFTK825, TKFTK826	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR Part 63, Subpart CC.
GRP-TVTKS-8	TKFTK808, TKFTK810, TKFTK811, TKFTK812, TKFTK813, TKFTK818, TKFTK827	40 CFR Part 60, Subpart K	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
GRP-TVTKS-8	TKFTK808, TKFTK810, TKFTK811, TKFTK812, TKFTK813, TKFTK818, TKFTK827	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.
GRP-TVTKS-8	TKFTK808, TKFTK810, TKFTK811, TKFTK812, TKFTK813, TKFTK818, TKFTK827	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
GRP-TVTKS-8	TKFTK808, TKFTK810, TKFTK811, TKFTK812, TKFTK813, TKFTK818, TKFTK827	40 CFR Part 60, Subpart QQQ	Tanks were constructed prior to May 4, 1987 and have not been modified or reconstructed.
GRP-TVTKS-8	TKFTK808, TKFTK810, TKFTK811, TKFTK812, TKFTK813, TKFTK818, TKFTK827	40 CFR Part 61, Subpart FF	Vessels do not store or manage benzene-containing waste.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-TVTKS-8	TKFTK808, TKFTK810, TKFTK811, TKFTK812, TKFTK813, TKFTK818, TKFTK827	40 CFR Part 63, Subpart EEEE	Tanks are subject to 40 CFR Part 63, Subpart CC.
GRP-TVTKS-9	TKFTK830, TKFTK831	40 CFR Part 60, Subpart K	Constructed after May 19, 1978.
GRP-TVTKS-9	TKFTK830, TKFTK831	40 CFR Part 60, Subpart Ka	Rule overlap with NSPS Ka, complying with MACT CC.
GRP-TVTKS-9	TKFTK830, TKFTK831	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
GRP-TVTKS-9	TKFTK830, TKFTK831	40 CFR Part 60, Subpart QQQ	Constructed prior to May 4, 1987 and has not been modified or reconstructed.
GRP-TVTKS-9	TKFTK830, TKFTK831	40 CFR Part 61, Subpart FF	Vessels do not store or manage benzene-containing waste.
GRP-TVTKS-9	TKFTK830, TKFTK831	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR Part 63, Subpart CC.
GRP-TVTKS-MSS	TKFTK902, TKFTK903, TKFTK904, TKFTK905, TKFTK906, TKFTK907, TKFTK908, TKFTK909, TKFTK910, TKFTK911, TKFTK920, TKFTK921, TKFTK922, TKFTK950, TKFTK951, TKFTK952, TKFTK953, TKFTK954, TKFTK955, TKFTK956	30 TAC Chapter 115, Storage of VOCs	Storage tank definition does not include process tanks or vessels.
GRP-TVTKS-MSS	TKFTK902, TKFTK903, TKFTK904, TKFTK905, TKFTK906, TKFTK907, TKFTK908, TKFTK909, TKFTK910, TKFTK911, TKFTK920, TKFTK921, TKFTK922, TKFTK950, TKFTK951, TKFTK952, TKFTK953, TKFTK954, TKFTK955, TKFTK956	40 CFR Part 60, Subpart K	Constructed prior to June 11, 1973 and has not been modified or reconstructed.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-TVTKS-MSS	TKFTK902, TKFTK903, TKFTK904, TKFTK905, TKFTK906, TKFTK907, TKFTK908, TKFTK909, TKFTK910, TKFTK911, TKFTK920, TKFTK921, TKFTK922, TKFTK950, TKFTK951, TKFTK952, TKFTK953, TKFTK954, TKFTK955, TKFTK956	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.
GRP-TVTKS-MSS	TKFTK902, TKFTK903, TKFTK904, TKFTK905, TKFTK906, TKFTK907, TKFTK908, TKFTK909, TKFTK910, TKFTK911, TKFTK920, TKFTK921, TKFTK922, TKFTK950, TKFTK951, TKFTK952, TKFTK953, TKFTK954, TKFTK955, TKFTK956	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
GRP-TVTKS-MSS	TKFTK902, TKFTK903, TKFTK904, TKFTK905, TKFTK906, TKFTK907, TKFTK908, TKFTK909, TKFTK910, TKFTK911, TKFTK920, TKFTK921, TKFTK922, TKFTK950, TKFTK951, TKFTK952, TKFTK953, TKFTK954, TKFTK955, TKFTK956	40 CFR Part 60, Subpart QQQ	Tanks are not part of a wastewater system that receives, treats, or processes oily wastewater from petroleum refinery process units.
GRP-TVTKS-MSS	TKFTK902, TKFTK903, TKFTK904, TKFTK905, TKFTK906, TKFTK907, TKFTK908, TKFTK909, TKFTK910, TKFTK911, TKFTK920, TKFTK921, TKFTK922, TKFTK950, TKFTK951, TKFTK952, TKFTK953, TKFTK954, TKFTK955, TKFTK956	40 CFR Part 61, Subpart FF	Vessels do not store or manage benzene-containing waste.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-TVTKS-MSS	TKFTK902, TKFTK903, TKFTK904, TKFTK905, TKFTK906, TKFTK907, TKFTK908, TKFTK909, TKFTK910, TKFTK911, TKFTK920, TKFTK921, TKFTK922, TKFTK950, TKFTK951, TKFTK952, TKFTK953, TKFTK954, TKFTK955, TKFTK956	40 CFR Part 63, Subpart CC	Not a storage vessel as defined in §63.641 (pressure vessel).
GRP-TVTKS-MSS	TKFTK902, TKFTK903, TKFTK904, TKFTK905, TKFTK906, TKFTK907, TKFTK908, TKFTK909, TKFTK910, TKFTK911, TKFTK920, TKFTK921, TKFTK922, TKFTK950, TKFTK951, TKFTK952, TKFTK953, TKFTK954, TKFTK955, TKFTK956	40 CFR Part 63, Subpart EEEE	Pressure vessels designed to operate in excess of 204.9 kilopascals and without emissions to the atmosphere.
GRP-VT-CRU	HTCRU001, HTCRU001-S	30 TAC Chapter 115, Vent Gas Controls	Combustion unit not used as a control device for any vent gas stream subject to 30 TAC Chapter 115, Subchapter B, Division 2, Vent Gas Control.
GRP-VT-CRU	HTCRU001, HTCRU001-S	40 CFR Part 63, Subpart CC	Combustion source is not a miscellaneous process vent as defined in §63.641.
GRP-VT-HTR<72	HTCRU002, HTCRU004, HTFCC002	30 TAC Chapter 115, Vent Gas Controls	Combustion unit not used as a control device for any vent gas stream subject to 30 TAC Chapter 115, Subchapter B, Division 2, Vent Gas Control.
GRP-VT-HTR<72	HTCRU002, HTCRU004, HTFCC002	40 CFR Part 63, Subpart CC	Combustion source is not a miscellaneous process vent as defined in §63.641.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-VT-HTR>72	HTALK001, HTALK002, HTBLR004, HTBLR006, HTLSG001, HTREF001, HTREF002	30 TAC Chapter 115, Vent Gas Controls	Combustion unit not used as a control device for any vent gas stream subject to 30 TAC Chapter 115, Subchapter B, Division 2, Vent Gas Control.
GRP-VT-HTR>72	HTALK001, HTALK002, HTBLR004, HTBLR006, HTLSG001, HTREF001, HTREF002	40 CFR Part 63, Subpart CC	Combustion source is not a miscellaneous process vent as defined in §63.641.
HSSUMP	N/A	30 TAC Chapter 115, Industrial Wastewater	Wash Pad Sump (WWMSSA) does not manage VOC wastewater as defined in 30 TAC 115.140(6).
HSSUMP	N/A	40 CFR Part 60, Subpart QQQ	Constructed prior to May 4, 1987 and has not been modified or reconstructed.
HTREF201	N/A	30 TAC Chapter 115, Vent Gas Controls	Combustion unit not used as a control device for any vent gas stream subject to 30 TAC Chapter 115, Subchapter B, Division 2, Vent Gas Control.
HTREF201	N/A	40 CFR Part 63, Subpart CC	Combustion source that does not meet the definition of a miscellaneous process vent as defined in §63.641.
HTREF2631	N/A	30 TAC Chapter 115, Vent Gas Controls	Combustion unit not used as a control device for any vent gas stream subject to 30 TAC Chapter 115, Subchapter B, Division 2, Vent Gas Control.
HTREF2631	N/A	40 CFR Part 63, Subpart CC	Combustion source, not a misc. process vent
INSRU001	N/A	30 TAC Chapter 115, Vent Gas Controls	Combustion unit not used as a control device for any vent gas stream subject to 30 TAC Chapter 115, Subchapter B, Division 2, Vent Gas Control.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
INSRU001	N/A	40 CFR Part 63, Subpart CC	Combustion source is not a miscellaneous process vent as defined in §63.641.
LABWST	N/A	30 TAC Chapter 115, Storage of VOCs	Capacity < 1,000 gallons
LABWST	N/A	40 CFR Part 60, Subpart K	Capacity < 40,000 gallons
LABWST	N/A	40 CFR Part 60, Subpart Ka	Capacity < 40,000 gallons
LABWST	N/A	40 CFR Part 60, Subpart Kb	Capacity < 75 cubic meters
LABWST	N/A	40 CFR Part 60, Subpart QQQ	Tank is not part of a wastewater system that receives, treats, or processes oily wastewater from petroleum refinery process units.
LABWST	N/A	40 CFR Part 63, Subpart CC	Not a MACT CC storage vessel as defined in §63.641 (capacity < 40 cubic meters).
LABWST	N/A	40 CFR Part 63, Subpart EEEE	Tank does not store regulated organic liquids
LSGHT001	N/A	30 TAC Chapter 112, Sulfur Compounds	Does not burn solid or liquid fuel
MATRLUNLD	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	The activity does not emit VOC.
REFHT201	N/A	30 TAC Chapter 112, Sulfur Compounds	Does not burn solid or liquid fuel
REFHT201	N/A	40 CFR Part 60, Subpart J	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
REFHT2631	N/A	30 TAC Chapter 112, Sulfur Compounds	Does not burn solid or liquid fuel
REFHT2631	N/A	30 TAC Chapter 112, Sulfur Compounds	Equipment does not combust liquid fuel.
TKFTK202	N/A	40 CFR Part 60, Subpart K	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
TKFTK202	N/A	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
TKFTK202	N/A	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
TKFTK202	N/A	40 CFR Part 60, Subpart QQQ	Vessel subject to 40 CFR Part 60, Subpart Kb is not subject the requirements of 40 CFR Part 60, Subpart QQQ.
TKFTK202	N/A	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR Part 63, Subpart CC.
TKFTK250	N/A	40 CFR Part 60, Subpart K	Constructed after May 19, 1978.
TKFTK250	N/A	40 CFR Part 60, Subpart Ka	Constructed after July 23, 1984.
TKFTK250	N/A	40 CFR Part 60, Subpart Kb	Rule overlap with NSPS Kb, complying with MACT CC.
TKFTK250	N/A	40 CFR Part 60, Subpart QQQ	Rule overlap with NSPS QQQ, complying with MACT CC.
TKFTK250	N/A	40 CFR Part 63, Subpart EEEE	Tank does not store regulated organic liquids
TKFTK301	N/A	40 CFR Part 60, Subpart K	Constructed after May 19, 1978.
TKFTK301	N/A	40 CFR Part 60, Subpart Ka	Constructed after July 23, 1984.
TKFTK301	N/A	40 CFR Part 60, Subpart Kb	Rule overlap with NSPS Kb, complying with MACT CC.
TKFTK301	N/A	40 CFR Part 60, Subpart QQQ	Rule overlap with NSPS QQQ, complying with MACT CC.
TKFTK301	N/A	40 CFR Part 63, Subpart EEEE	Tank does not store regulated organic liquids
TKFTK309	N/A	40 CFR Part 60, Subpart K	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
TKFTK309	N/A	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
TKFTK309	N/A	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
TK FTK309	N/A	40 CFR Part 60, Subpart QQQ	Vessel subject to 40 CFR Part 60, Subpart Kb is not subject the requirements of 40 CFR Part 60, Subpart QQQ.
TKFTK309	N/A	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR 63 Subpart CC
TKFTK328	N/A	40 CFR Part 60, Subpart K	Constructed after May 19, 1978
TKFTK328	N/A	40 CFR Part 60, Subpart Ka	Constructed after July 23, 1984
TKFTK328	N/A	40 CFR Part 60, Subpart Kb	Rule overlap with NSPS Kb, complying with MACT CC.
TKFTK328	N/A	40 CFR Part 60, Subpart QQQ	Rule overlap with NSPS QQQ, complying with MACT CC.
TKFTK328	N/A	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR 63 Subpart CC
TKFTK332	N/A	40 CFR Part 60, Subpart K	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
TKFTK332	N/A	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.
TKFTK332	N/A	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
TKFTK332	N/A	40 CFR Part 60, Subpart QQQ	Constructed prior to May 4, 1987 and has not been modified or reconstructed.
TKFTK332	N/A	40 CFR Part 61, Subpart FF	Tank does not store benzene-containing waste
TKFTK332	N/A	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR 63 Subpart CC

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
TKFTK342	N/A	40 CFR Part 60, Subpart K	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
TKFTK342	N/A	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.
TKFTK342	N/A	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
TKFTK342	N/A	40 CFR Part 60, Subpart QQQ	Constructed prior to May 4, 1987 and has not been modified or reconstructed.
TKFTK342	N/A	40 CFR Part 61, Subpart FF	Tank does not store benzene-containing waste
TKFTK342	N/A	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR 63 Subpart CC
TKFTK343	N/A	40 CFR Part 60, Subpart K	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
TKFTK343	N/A	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.
TKFTK343	N/A	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
TKFTK343	N/A	40 CFR Part 60, Subpart QQQ	Constructed prior to May 4, 1987 and has not been modified or reconstructed.
TKFTK343	N/A	40 CFR Part 61, Subpart FF	Tank does not store benzene-containing waste
TKFTK343	N/A	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR 63 Subpart CC
TKFTK345	N/A	40 CFR Part 60, Subpart K	Capacity < 40,000 gallons
TKFTK345	N/A	40 CFR Part 60, Subpart Ka	Capacity < 40,000 gallons
TKFTK345	N/A	40 CFR Part 60, Subpart Kb	Rule overlap with NSPS Kb, complying with MACT CC.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
TKFTK345	N/A	40 CFR Part 60, Subpart QQQ	Rule overlap with NSPS QQQ, complying with MACT CC.
TKFTK345	N/A	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR Part 63, Subpart CC
TKFTK349	N/A	40 CFR Part 60, Subpart K	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
TKFTK349	N/A	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.
TKFTK349	N/A	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
TKFTK349	N/A	40 CFR Part 61, Subpart FF	Tank does not store benzene-containing waste
TKFTK349	N/A	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR 63 Subpart CC
TKFTK350	N/A	40 CFR Part 60, Subpart K	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
TKFTK350	N/A	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.
TKFTK350	N/A	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
TKFTK350	N/A	40 CFR Part 61, Subpart FF	Tank does not store benzene-containing waste
TKFTK350	N/A	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR 63 Subpart CC
TKFTK400	N/A	40 CFR Part 60, Subpart K	Constructed after May 19, 1978
TKFTK400	N/A	40 CFR Part 60, Subpart Ka	Constructed after July 23, 1984
TKFTK400	N/A	40 CFR Part 60, Subpart QQQ	Vessel subject to 40 CFR Part 60, Subpart Kb is not subject the requirements of 40 CFR Part 60, Subpart QQQ.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
TKFTK400	N/A	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR Part 63 Subpart CC
TKFTK807	N/A	40 CFR Part 60, Subpart K	Constructed prior to June 11, 1973 and has not been modified or reconstructed.
TKFTK807	N/A	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.
TKFTK807	N/A	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
TKFTK807	N/A	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR 63 Subpart CC
TKFTK814	N/A	40 CFR Part 60, Subpart K	Rule overlap with NSPS K, complying with MACT CC
TKFTK814	N/A	40 CFR Part 60, Subpart Ka	Constructed prior to May 18, 1978 and has not been modified or reconstructed.
TKFTK814	N/A	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
TKFTK814	N/A	40 CFR Part 61, Subpart FF	Tank does not store benzene-containing waste
TKFTK814	N/A	40 CFR Part 63, Subpart EEEE	Tank is subject 40 CFR 63 Subpart CC
TKFTK822	N/A	40 CFR Part 60, Subpart K	Constructed after May 19, 1978
TKFTK822	N/A	40 CFR Part 60, Subpart Ka	Rule overlap with NSPS Ka, complying with MACT CC
TKFTK822	N/A	40 CFR Part 60, Subpart Kb	Constructed prior to July 23, 1984 and has not been modified or reconstructed.
TKFTK822	N/A	40 CFR Part 61, Subpart FF	Tank does not store benzene-containing waste
TKFTK822	N/A	40 CFR Part 63, Subpart EEEE	Tank is subject to 40 CFR 63 Subpart CC
TKFTKD48	N/A	30 TAC Chapter 115, Storage of VOCs	Capacity < 1,000 gallons

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
TKFTKD48	N/A	40 CFR Part 60, Subpart K	Capacity < 40,000 gallons
TKFTKD48	N/A	40 CFR Part 60, Subpart Ka	Capacity < 40,000 gallons
TKFTKD48	N/A	40 CFR Part 60, Subpart Kb	Capacity < 75 cubic meters
TKFTKD48	N/A	40 CFR Part 63, Subpart CC	Not a MACT CC storage vessel as defined in §63.641 (capacity < 40 cubic meters).
TVCVSEAST	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	PRV's vent to a closed vent system and control device
TVCVSWEST	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	PRV's vent to a closed vent system and control device
TVFCCPROC	N/A	40 CFR Part 63, Subpart CC	Catalytic reformer catalyst regenerator vents are not included in the affected source.
TVFUG-61J	N/A	40 CFR Part 61, Subpart J	Rule overlap, complies with MACT CC.
TVREF3PROC	N/A	40 CFR Part 63, Subpart CC	Catalytic reformer catalyst regenerator vents are not included in the affected source.
WWSFU001	N/A	30 TAC Chapter 115, Water Separation	Any single or multiple compartment VOC water separator which is designed solely to capture stormwater, spills, or exterior surface cleanup waters and is fully covered.
WWSFU002	N/A	30 TAC Chapter 115, Water Separation	Any single or multiple compartment VOC water separator which is designed solely to capture stormwater, spills, or exterior surface cleanup waters that is fully covered is exempt from 30 TAC Chapter 115, Subchapter B, Division 3: Water Separation.
WWSFU002	N/A	40 CFR Part 60, Subpart QQQ	Construction was completed before May 4, 1987 and has not been modified or reconstructed.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
WWSFU002	N/A	40 CFR Part 61, Subpart FF	Waste that is contained in a segregated stormwater sewer system is not an affected source
WWSFU002	N/A	40 CFR Part 63, Subpart CC	Stormwater from segregated sewers and spills are not affected sources.
WWSFU002	N/A	40 CFR Part 63, Subpart VV	MACT VV not referenced by another regulation
WWSFU003	N/A	30 TAC Chapter 115, Water Separation	Any single or multiple compartment VOC water separator which is designed solely to capture stormwater, spills, or exterior surface cleanup waters that is fully covered is exempt from 30 TAC Chapter 115, Subchapter B, Division 3: Water Separation.
WWSFU003	N/A	40 CFR Part 60, Subpart QQQ	Construction was completed before May 4, 1987 and has not been modified or reconstructed.
WWSFU003	N/A	40 CFR Part 61, Subpart FF	Waste that is contained in a segregated stormwater sewer system is not an affected source
WWSFU003	N/A	40 CFR Part 63, Subpart CC	Stormwater from segregated sewers and spills are not affected sources.
WWSFU003	N/A	40 CFR Part 63, Subpart VV	MACT VV not referenced by another regulation

New Source Review Authorization References

New Source Review Authorization References 307

New Source Review Authorization References by Emission Unit 309

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 20246	Issuance Date: 10/19/2023
Authorization No.: 22039	Issuance Date: 10/10/2023
Authorization No.: 56389	Issuance Date: 10/10/2023
Authorization No.: 80804	Issuance Date: 10/10/2023
Authorization No.: 136490	Issuance Date: 11/24/2015
Authorization No.: 173183	Issuance Date: 07/14/2023
Authorization No.: 174735	Issuance Date: 01/11/2024
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 14	Version No./Date: 06/07/1996
Number: 51	Version No./Date: 11/05/1986
Number: 51	Version No./Date: 06/07/1996
Number: 70	Version No./Date: 06/07/1996
Number: 82	Version No./Date: 06/07/1996
Number: 103	Version No./Date: 06/07/1996
Number: 106.102	Version No./Date: 09/04/2000
Number: 106.122	Version No./Date: 09/04/2000
Number: 106.148	Version No./Date: 09/04/2000
Number: 106.183	Version No./Date: 09/04/2000
Number: 106.227	Version No./Date: 09/04/2000
Number: 106.244	Version No./Date: 09/04/2000
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 11/01/2003
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.265	Version No./Date: 09/04/2000
Number: 106.266	Version No./Date: 09/04/2000
Number: 106.316	Version No./Date: 09/04/2000
Number: 106.317	Version No./Date: 09/04/2000
Number: 106.355	Version No./Date: 11/01/2001
Number: 106.371	Version No./Date: 09/04/2000
Number: 106.372	Version No./Date: 09/04/2000
Number: 106.373	Version No./Date: 09/04/2000

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Number: 106.412	Version No./Date: 03/14/1997
Number: 106.412	Version No./Date: 09/04/2000
Number: 106.419	Version No./Date: 09/04/2000
Number: 106.451	Version No./Date: 09/04/2000
Number: 106.472	Version No./Date: 03/14/1997
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.476	Version No./Date: 03/14/1997
Number: 106.476	Version No./Date: 09/04/2000
Number: 106.478	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 09/04/2000
Number: 106.512	Version No./Date: 06/13/2001
Number: 106.531	Version No./Date: 09/04/2000
Number: 106.532	Version No./Date: 03/14/1997
Number: 106.532	Version No./Date: 09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
635G-PV	Groundwater RMMU Process Vents	56389
AD-D-2	Miscellaneous Process Vent to Flare	56389
ALKHT001	Alky Heater 1	56389
ALKHT002	Alky Heater 2	56389
BLRHT004	Boiler 4	22039
BLRHT006	Boiler 6	22039
BLRHT010	Boiler 10	20246
C3UL	Propane Unloading/Loading	82/06/07/1996
CAUSUNLOAD	Caustic Unloading	51/11/05/1986
CKRSUMP	Coker Unit Sump	106.532/03/14/1997
CMFTHTRS	Comfort Heating	106.102/09/04/2000
CPI	Corrugated Plate Interceptor	56389
CRUHT001	Atmospheric Tower Heater	22039
CRUHT002	Vacuum Tower Heater	22039
CRUHT004	Crude Tower Heater	22039, 56389
CRUVT001	Steam Ejector Vent	56389
D-202	RSU Drum	80804
D-203	RSU Drum	80804
D-593	Ref 3 Aromatic Sump	56389
D-599	EDC Tank	80804
DESALTER	Desalter	56389

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
DOKLO001	Barge Loading	20246
DOKIN001	Vapor Combustor	20246
EMENW001	Fire Water Pump	106.511/09/04/2000
EMENW002	Fire Water Pump	106.511/09/04/2000
EMENW003	Fire Water Pump	106.511/09/04/2000
EMENW004	Fire Water Pump	106.511/09/04/2000
EMENW005	Fire Water Pump	106.511/09/04/2000
EMENW006	Fire Water Pump	106.511/09/04/2000
EMGEN001	Emergency Generator - DCS	106.511/09/04/2000 [152487, 95578]
EMGEN002	Emergency Generator - Main Office	106.511/09/04/2000 [152487, 95578]
EMGEN006	Emergency Generator Diesel Engine 6	106.511/09/04/2000 [152487]
EMGEN007	Emergency Generator	106.511/09/04/2000 [152487]
EMWWEN1	Waste Water Pump Diesel Engine 1	106.511/09/04/2000 [152487]
FCCHT002	FCC Charge Heater	20246
FEWWS	Wastewater System	56389
FLRFNEAST	East Flare	56389
FLRFNWEST	West Flare	56389
FUGCTALK	Alky/Auxiliary Cooling Tower	22039
FUGCTCPX	Complex Cooling Tower	22039
FUGCTUDX	Udex Cooling Tower	22039
HSSUMP	Hydroblast Slab Sump	106.472/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
HTALK001	Alky Heater Stack	22039
HTALK002	Alky Heater Stack	22039
HTBLR004	Boiler 4 Stack	22039
HTBLR006	Boiler 6 Stack	22039
HTBLR010	Boiler 10 Stack	20246
HTCRU001	Crude Tower Heater 1 Stack	22039
HTCRU001-S	Combined Crude Heater Stack	22039
HTCRU002	Crude Tower Heater 2 Stack (MSS Only)	56389
HTCRU004	Crude Tower Heater Stack	22039
HTFCC002	FCC Charge Heater Stack	20246
HTLSG001	Heater H-3701 Stack	22039
HTREF001	Hydrotreater Heater 1 Stack	22039
HTREF002	Hydrotreater Heater 2 Stack	22039
HTREF201	Reformate Splitter Heater Stack	22039
HTREF2631	Reformer Heaters 26-31 Common Stack	22039
INDOK001	Vapor Combustor	20246
INSRU001	SRU Incinerator Stack	56389
LAB	Bench Scale Laboratory Equipment	106.122/09/04/2000
LABWST	Lab Tank	56389
LOAD-UNLD	Site Loading and Unloading	106.473/09/04/2000
LODOK001	Dock Slurry Oil Loading	106.472/09/04/2000 [152488]

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
LSGHT001	Heater H-3701	22039
LUBETK1	FCCU Lube Oil Tank	106.472/09/04/2000 [152488]
LUBETK10	Reformer Lube Oil Tank	106.472/09/04/2000 [152488]
LUBETK11	Alky Lube Oil Tank	106.472/09/04/2000 [152488]
LUBETK12	Lube Oil Drums	106.472/09/04/2000 [152488]
LUBETK2	Szorb Lube Oil Tank	106.472/09/04/2000 [152488]
LUBETK3	Crude Lube Oil Tank	106.472/09/04/2000 [152488]
LUBETK4	Hydrotreater Lube Oil Tank	106.472/09/04/2000 [152488]
LUBETK5	Hydrotreater Lube Oil Tank	106.472/09/04/2000 [152488]
LUBETK6	LPG Lube Oil Tank	106.472/09/04/2000 [152488]
LUBETK7	LPG Lube Oil Tank	106.472/09/04/2000 [152488]
LUBETK8	Reformer Lube Oil Tank	106.472/09/04/2000 [152488]
LUBETK9	Reformer Lube Oil Tank	106.472/09/04/2000 [152488]
MATRLUNLD	Material Unloading	106.148/09/04/2000
MD-D-1	Miscellaneous Process Vent To Flare	56389
MSSBZSTR	MSS Emissions from BSU	80804
NALCOTK1	Nalco Corrosion Inhibitor BH2 Tank	106.472/09/04/2000 [152488]
NALCOTK2	Nalco Corrosion Inhibitor BH3 Tank	106.472/09/04/2000 [152488]
NEMENG001	Air Compressor	106.512/06/13/2001
NEMENG002	Air Compressor	106.512/06/13/2001
NEMENG003	Air Compressor	106.512/06/13/2001

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
NEMENG004	Air Compressor	106.512/06/13/2001
NEMENG008	West Plant Generator	106.512/06/13/2001
NEMENG009	Boiler Water Pump	106.512/06/13/2001
NEMENG010	Reformer Water Pump	106.512/06/13/2001
OILDSUMP	Oil Dock Sump	56389
REFHT001	Hydrotreater Heater 1	22039
REFHT002	Hydrotreater Heater 2	22039
REFHT201	Reformate Splitter Heater	22039
REFHT2631	Reformer 3 Heaters 26-31	22039
REFUNLOAD	Ref. Area Unloading	51/11/05/1986
SRU-UNLOAD	MDEA Unloading	51/11/05/1986
SRU001	Sulfur Recovery Unit	56389
SRUIN001	Tail Gas Incinerator	56389
TKFTK010	Tank 10	106.412/03/14/1997
TKFTK027B	Tank 27B	106.472/03/14/1997
TKFTK049	Tank 49	106.472/03/14/1997
TKFTK051	Tank 51	20246
TKFTK065	Tank 65	20246
TKFTK202	Tank 202	20246
TKFTK205	Tank 205	20246
TKFTK210	Tank 210	20246

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
TKFTK250	Tank 250	20246
TKFTK301	Tank 301	20246
TKFTK307	Tank 307	20246
TKFTK308	Tank 308	20246
TKFTK309	Tank 309	20246
TKFTK313	Tank 313	80804
TKFTK318	Tank 318	80804
TKFTK328	Tank 328	20246
TKFTK330	Tank 330	20246
TKFTK331	Tank 331	20246
TKFTK332	Tank 332	20246
TKFTK335	Tank 335	20246
TKFTK336	Tank 336	20246
TKFTK337	Tank 337	20246
TKFTK340	Tank 340	20246
TKFTK341	Tank 341	20246
TKFTK342	Tank 342	20246
TKFTK343	Tank 343	56389
TKFTK345	Tank 345	20246
TKFTK349	Tank 349	20246
TKFTK350	Tank 350	20246

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
TKFTK353	Tank 353	20246
TKFTK400	Tank 400	20246
TKFTK405	Corrosion Inhibitor Tank	106.261/11/01/2003 [509889], 106.262/11/01/2003 [509889]
TKFTK406	Neutralizer Tank	106.261/11/01/2003 [509889], 106.262/11/01/2003 [509889]
TKFTK535	Tank 535	106.472/03/14/1997
TKFTK700	Tank 700	20246
TKFTK710	Tank 710	20246
TKFTK807	Tank 807	20246
TKFTK808	Tank 808	20246
TKFTK810	Tank 810	20246
TKFTK811	Tank 811	20246
TKFTK812	Tank 812	20246
TKFTK813	Tank 813	20246
TKFTK814	Tank 814	20246
TKFTK815	Tank 815	20246
TKFTK816	Tank 816	20246
TKFTK817	Tank 817	20246
TKFTK818	Tank 818	20246
TKFTK820	Tank 820	20246

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
TKFTK822	Tank 822	20246
TKFTK824	Tank 824	20246
TKFTK825	Tank 825	20246
TKFTK826	Tank 826	20246
TKFTK827	Tank 827	20246
TKFTK830	Tank 830	20246
TKFTK831	Tank 831	20246
TKFTK902	Tank 902	106.476/03/14/1997
TKFTK903	Tank 903	106.476/03/14/1997
TKFTK904	Tank 904	106.476/03/14/1997
TKFTK905	Tank 905	106.476/03/14/1997
TKFTK906	Tank 906	106.476/03/14/1997
TKFTK907	Tank 907	106.476/03/14/1997
TKFTK908	Tank 908	106.476/03/14/1997
TKFTK909	Tank 909	106.476/03/14/1997
TKFTK910	Tank 910	106.476/03/14/1997
TKFTK911	Tank 911	106.476/03/14/1997
TKFTK920	Tank 920	106.476/03/14/1997
TKFTK921	Tank 921	106.476/03/14/1997
TKFTK922	Tank 922	106.476/03/14/1997
TKFTK950	Tank 950	106.476/03/14/1997

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
TKFTK951	Tank 951	106.476/03/14/1997
TKFTK952	Tank 952	106.476/03/14/1997
TKFTK953	Tank 953	106.476/03/14/1997
TKFTK954	Tank 954	106.476/03/14/1997
TKFTK955	Tank 955	106.476/03/14/1997
TKFTK956	Tank 956	106.476/03/14/1997
TKFTKD-8	Spent KOH Tank D-8 > Tank D-8	106.472/03/14/1997
TKFTKD-9	Spent KOH Tank D-9 > Tank D-7	106.472/03/14/1997
TKFTKD48	Tank D-48	20246
TKFTKF405	Corrosion Inhibitor Tank	106.261/11/01/2003 [509889], 106.262/11/01/2003 [509889]
TKFTKGDISL	Diesel Tanks	106.472/03/14/1997
TKGRSOAP	Soap Tanks	106.472/09/04/2000
TRRLOLPG	Truck Loading Rack	56389
TVCVSEAST	East Flare Closed-Vent System	56389
TVCVSWEST	West Flare Closed-Vent System	56389
TVFCCPROC	FCC	20246
TVFUG-115VOC	115 VOC Fugitives	56389, 106.261/11/01/2003, 106.262/11/01/2003
TVFUG-61J	Part 61 Fugitives	56389, 106.261/11/01/2003
TVFUG-63CC	63CC Fugitives	56389, 106.261/11/01/2003, 106.262/11/01/2003
TVFUG-63CCJ1	63CC-61J1 Fugitives	56389, 106.261/11/01/2003, 106.262/11/01/2003

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
TVFUG-63CCJ2	63CC-61J2 Fugitives	56389, 106.261/11/01/2003, 106.262/11/01/2003
TVFUG-63CCJ3	63CC-61J3 Fugitives	56389, 106.261/11/01/2003, 106.262/11/01/2003
TVFUG-63CCJ4	63CC-61J4 Fugitives	56389, 106.261/11/01/2003, 106.262/11/01/2003
TVFUG-63CCJ5	63CC-61J5 Fugitives	56389, 106.261/11/01/2003, 106.262/11/01/2003
TVFUG-63GGGGG	63GGGGG Fugitives	56389, 106.261/11/01/2003, 106.262/11/01/2003
TVFUG-GGGA	60GGGa Fugitives	56389, 106.261/11/01/2003, 106.262/11/01/2003
TVFUG-HRVOG	HRVOG Fugitives	56389, 106.261/11/01/2003, 106.262/11/01/2003
TVREF3PROC	Catalytic Reformer	56389
TVSRUPROC	SRU Recovery Unit	56389
VTCCG2	63CC Group 2 Vents	56389
VTCCMT	63CC Maintenance Vents	80804
VTFCC001	Fresh Catalyst Cyclone Vent	80804
VTFCC002	Spent Catalyst Cyclone Vent	80804
VTFCC003	Seal Pot Vent	80804
VTLSG001	Regenerator Scrubber Vent	56389
VTLSG002	Lockhopper Vent, Sorbent Storage Drum Loading	56389
VTLSG003	Sorbent Fines Drum Unloading	56389
VTREF001	Reformer 3 Catalyst Regeneration Vent	80804
WESTDSLTK1	West Diesel Tank 1	106.478/09/04/2000
WESTDSLTK2	West Diesel Tank 2	106.478/09/04/2000
WPSLS	West Process Sewer Lift Station (Part of FEWWS)	56389

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
WWSFU001	Oil/Water Separator 1	56389
WWSFU002	Oil/Water Separator 2	56389
WWSFU003	Oil/Water Separator 3	56389

**This column may include Permit by Rule (PBR) numbers and version dates, PBR Registration numbers in brackets, Standard Permit Registration numbers, Minor NSR permit numbers, and Major NSR permit numbers.

Alternative Requirement

Alternative Requirement..... 321

Jon Niermann, *Chairman*
Emily Lindley, *Commissioner*
Toby Baker, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

April 4, 2019

MR KEVIN MCGEE
ENVIRONMENTAL MANAGER
PASADENA REFINING SYSTEM INC
111 RED BLUFF RD
PASADENA TX 77506-1530

Re: Alternative Method of Compliance (AMOC) No. 61 Revision 4
NSPS Ja Alternative Monitoring Plan
Regulated Entity Number: RN100716661
Customer Reference Number: CN603137605
Associated Permit Numbers: 56389 and O3711

Dear Mr. McGee:

This correspondence is in response to Pasadena Refining System, Inc's (PRSI's) November 16, 2018 request for an alternative monitoring plan related to total reduced sulfur (TRS) monitoring of the site's two flares (East and West) using an AMOC to comply with 40 CFR Part 60 Subpart Ja Standards of Performance for New Stationary Sources for Petroleum Refineries and for Petroleum Refineries for Which Construction, Reconstruction, or Modification Commenced After May 14, 2007.

We understand that PRSI is requesting an alternative to the TRS calibration verification requirements in §60.107a(e)(1)(iii) in order to minimize the amount of dangerous calibration gases (hydrogen sulfide, carbonyl sulfide, and carbon disulfide - H₂S, COS, and CS₂) needed at the site for worker safety. Based on the monitor design being used on the flares, PRSI has provided data showing that the monitor has an inherently linear relationship in concentration readings throughout its H₂S and TRS range and thus, low-range calibrations can substitute for high-level TRS calibrations in the expected operating range of the facilities.

The Texas Commission on Environmental Quality (TCEQ) Executive Director has made a final decision to approve your AMOC request based on the following monitor calibration parameters using a blend of H₂S, COS, and CS₂:

Description	Level	TRS (ppmv)
Daily CD Check	Zero/Low	< 1000
	High	3,000
Quarterly CGAs, RATA, and Alternative RATA	Low	1,000
	High	3,000

The TCEQ has been delegated authority to enforce the above cited standards and is authorized to approve this AMOC. You are reminded that approval of any AMOC shall not abrogate the Executive Director or Administrator's authority under the Act or in any way prohibit later canceling the AMOC. By copy of this letter we are informing the Environmental Protection Agency, Region 6, of this decision as required by TCEQ's delegation of authority.

P.O. Box 13087 · Austin, Texas 78711-3087 · 512-239-1000 · tceq.texas.gov

How is our customer service? tceq.texas.gov/customersurvey
printed on recycled paper

April 4, 2019
Page 2
Mr. Kevin McGee

Re: Permit Numbers: 56389 and O3711

This AMOC approval may supersede certain requirements or representations in Permit No. 56389. To ensure effective and consistent enforceability, we request that PRSI incorporate this AMOC into the permit through submittal of an alteration no later than 90 days after this approval.

This approval may also change applicable requirements for the site, which are identified in the site operating permit (SOP) O3711. The TCEQ recommends the submittal of a SOP administrative revision if any changes are necessary. Changes meeting the criteria for an administrative revision can be operated before issuance of the revision if a complete application is submitted to the TCEQ and this information is maintained with the SOP records at the site.

If you need further information or have any questions, please contact Ms. Anne Inman, P.E. at (512) 239-1276 or write to the Texas Commission on Environmental Quality, Office of Air, Air Permits Division, MC-163, P.O. Box 13087, Austin, Texas 78711-3087.

This action is taken under authority delegated by the Executive Director of the TCEQ.

Sincerely,



Michael Wilson, P.E., Director
Air Permits Division
Office of Air
Texas Commission on Environmental Quality

cc: Jessica Little, Pasadena Refining System, Inc.
Chief Health Inspector, Health Department, City of Pasadena, Pasadena
Director, Harris County, Pollution Control Services, Pasadena
Air Section Manager, Region 12 - Houston
Jesse E. Chacon, P.E., Manager, Operating Permits Section, Air Permits Division, OA: MC-163
Samuel Short, Manager, Energy New Source Review Permits Section, Air Permits Division, OA:
MC-163
Air Permits Section Chief, New Source Review Section (6PD-R), U.S. Environmental Protection
Agency, Region 6, Dallas

Project Number: 293505

Jon Niermann, *Chairman*
Emily Lindley, *Commissioner*
Bobby Janecka, *Commissioner*
Toby Baker, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

July 23, 2021

MR BRIAN KANE
LEAD ENVIRONMENTAL SPECIALIST
PASADENA REFINING SYSTEM INC
111 RED BLUFF RD
PASADENA TX 77506-1530

Re: Alternative Method of Compliance (AMOC) No. 182
Refinery West Flare
Alternative RATA Period
Regulated Entity Number: RN100716661
Customer Reference Number: CN603137605
Associated Permit Numbers: 56389, PSDTX816, and O3711

Dear Mr. Kane:

This correspondence is in response to Pasadena Refining System, Inc.'s (PRSI's) June 29, 2021 request for the an alternative time frame to complete the Relative Accuracy Test Audit (RATA) requirements of 40 CFR 60, Subpart Ja - Standards of Performance for Petroleum Refineries for Which Construction, Reconstruction, or Modification Commenced After May 14, 2007 (NSPS Ja) for the continuous emission monitor system (CEMS) on the West Flare at the refinery due to the flare being out of service

The West Flare (EPN FLRRNWEST) is equipped with continuous emission monitors for H₂S and TRS requiring annual RATA under NSPS Ja and the company previously performed the annual CEMS/COMS RATA in June 2020. We understand West Flare was removed from service at approximately on June 26, 2021 due to potential mechanical issues with the pilot gas line. The flare was not in operation during the time when the annual RATA would need to be completed. We also understand repairs to the West Flare were completed on June 30, 2021 the RATA was scheduled to be performed on July 7, 2021.

The Texas Commission on Environmental Quality (TCEQ) Executive Director has made a final decision to approve your AMOC request to complete the RATA within 30-days after the flare returns to normal operation as allowed under the federal rules. The TCEQ has been delegated authority to enforce the above cited standards and is authorized to approve this AMOC. You are reminded that approval of any AMOC shall not abrogate the Executive Director or Administrator's authority under the Act or in any way prohibit later canceling the AMOC. By copy of this letter we are informing the Environmental Protection Agency, Region 6, of this decision as required by TCEQ's delegation of authority.

If you need further information or have any questions, please contact Ms. Anne Inman, P.E. at (512) 239-1276 or write to the Texas Commission on Environmental Quality, Office of Air, Air Permits Division, MC-163, P.O. Box 13087, Austin, Texas 78711-3087.

P.O. Box 13087 · Austin, Texas 78711-3087 · 512-239-1000 · tceq.texas.gov

How is our customer service? tceq.texas.gov/customersurvey
printed on recycled paper

July 23, 2021
Page 2
MR BRIAN KANE

Re: Permit Numbers: 56389, PSDTX816, and O3711

Sincerely,

A handwritten signature in black ink, appearing to read 'Samuel Short', followed by a long horizontal line extending to the right.

Samuel Short, Deputy Director
Air Permits Division
Office of Air
Texas Commission on Environmental Quality

cc: Chief Health Inspector, Health Department, City of Pasadena, Pasadena
Director, Harris County, Pollution Control Services, Pasadena
Air Section Manager, Region 12 - Houston
Jesse E. Chacon, P.E., Manager, Operating Permits Section, Air Permits Division, OA: MC-163
Daniel Guthrie, Manager, Energy New Source Review Permits Section, Air Permits Division, OA:
MC-163
Air Permits Section Chief, New Source Review Section (6PD-R), U.S. Environmental Protection
Agency, Region 6, Dallas

Project Number: 330710

Jon Niermann, *Chairman*
 Emily Lindley, *Commissioner*
 Bobby Janecka, *Commissioner*
 Toby Baker, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

October 27, 2021

MR BRIAN KANE
 LEAD ENVIRONMENTAL SPECIALIST
 PASADENA REFINING SYSTEM INC
 111 RED BLUFF RD
 PASADENA TX 77506-1530

Re: Alternative Method of Compliance (AMOC) No. 189
 Pasadena Refinery
 RATA Extensions for Non-Operational Facilities
 Regulated Entity Number: RN100716661
 Customer Reference Number: CN603137605
 Associated Permit Numbers: 6059, 20246, and O3711

Dear Mr. Kane:

This correspondence is in response to Pasadena Refining System, Inc.'s (PRSI's) September 30, 2021 request for an extension to comply with the Relative Accuracy Test Audit (RATA) requirements of several state and federal rules for three units at the refinery due to the units not being in operation.

PRSI has requested to delay annual RATA on the CEMS for three units applicable to the following rules:

Facility	Permit	EPN	CEMS	Regulation	Citation for Alternatives
FCC Regenerator	20246	HTBLR010	CO, CO ₂	MACT UUU & GHG	APPX F
SRU Incinerator	6059	INSRU001	SO ₂ , O ₂	MACT UUU & NSPS J	APPX F
CH-2	6059	HTCRU002	NO _x , CO, O ₂	CHAPTER 117	APPX F

Where: MACT UUU is 40 CFR 63 SUBPART UUU National Emission Standards for Hazardous Air Pollutants for Petroleum Refineries: Catalytic Cracking Units, Catalytic Reforming Units, and Sulfur Recovery Units; GHG is 40 CFR 98 Mandatory Greenhouse Gas Reporting; NSPS J is 40 CFR 60 SUBPART J Standards of Performance for Petroleum Refineries; Chapter 117 is 30 TAC 117 Control Of Air Pollution From Nitrogen Compounds, Subchapter G General Monitoring And Testing Requirements, Division 2 Emission Monitoring; and Appx F is 40 CFR 60 Appendix F Quality Assurance Procedures.

We understand two of the sources (EPNs HTBLR010, INSRU001) listed in the table are not currently operating. The third source (EPN HTCRU002) is only permitted to vent to atmosphere for a limited number of hours per year during MSS activities. During normal operation, it vents through the SCR control device (EPN HTCRU001).

In Appendix F, Section 5.1.4, RATA is required no less than annually, except in the case where the affected facility is not operating. In that case, the RATA shall be performed when the unit recommences operation. The circumstances presented in this request meet that expectation. PRSI has represented the respective RATAs will be completed within 30 days of each applicable EPN achieving stable operation.

P.O. Box 13087 · Austin, Texas 78711-3087 · 512-239-1000 · tceq.texas.gov

How is our customer service? tceq.texas.gov/customersurvey
 printed on recycled paper

October 27, 2021
Page 2
Mr. Brian Kane

Re: Permit Numbers: 6059, 20246, and O3711

The Texas Commission on Environmental Quality (TCEQ) Executive Director has made a final decision to approve your AMOC request. The TCEQ has been delegated authority to enforce the above cited standards and is authorized to approve this AMOC. You are reminded that approval of any AMOC shall not abrogate the Executive Director or Administrator's authority under the Act or in any way prohibit later canceling the AMOC. By copy of this letter, we are informing the Environmental Protection Agency, Region 6, of this decision as required by TCEQ's delegation of authority.

If you need further information or have any questions, please contact Ms. Anne Inman, P.E. at (512) 239-1276 or write to the Texas Commission on Environmental Quality, Office of Air, Air Permits Division, MC-163, P.O. Box 13087, Austin, Texas 78711-3087.

Sincerely,

A handwritten signature in black ink, appearing to read 'Samuel Short', followed by a long horizontal line extending to the right.

Samuel Short, Deputy Director
Air Permits Division
Office of Air
Texas Commission on Environmental Quality

cc: Chief Health Inspector, Health Department, City of Pasadena, Pasadena
Director, Harris County, Pollution Control Services, Pasadena
Air Section Manager, Region 12 - Houston
Jesse E. Chacon, P.E., Manager, Operating Permits Section, Air Permits Division, OA: MC-163
Daniel Guthrie, Manager, Energy New Source Review Permits Section, Air Permits Division, OA:
MC-163
Air Permits Section Chief, New Source Review Section (6PD-R), U.S. Environmental Protection
Agency, Region 6, Dallas

Project Number: 333925

Jon Niermann, *Chairman*
Emily Lindley, *Commissioner*
Bobby Janecka, *Commissioner*
Toby Baker, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

June 10, 2022

MR TIM SUTHERLAND
GENERAL MANAGER
PASADENA REFINING SYSTEM INC
111 RED BLUFF RD
PASADENA TX 77506-1530

Re: Alternative Method of Compliance (AMOC) No. 204
FCCU Regenerator
MACT UUU Test Waiver
Regulated Entity Number: RN100716661
Customer Reference Number: CN603137605
Associated Permit Numbers: 20246, 22039, and O3711

Dear MR TIM SUTHERLAND:

This correspondence is in response to Pasadena Refining System, Inc.'s (PRSI's) April 28, 2022 request for a waiver from the required performance test of the Fluid Catalytic Cracking Unit (FCCU) Regenerator when controlled through Boiler 10's Electrostatic Precipitator Stack (EPN HTBLR010). Performance tests for Nickel (Ni) and Particulate Matter (PM) are required every five years by 40 CFR 63, Subpart UUU National Emission Standards for Hazardous Air Pollutants for Petroleum Refineries: Catalytic Cracking Units, Catalytic Reforming Units, and Sulfur Recovery Units (MACT UUU) (§ 63.1571(a)(5)) and the next deadline is August 1, 2022.

We understand the equipment associated with the FCCU is currently not operating, at this time there is no anticipated date for any return to operation, and that testing is requested to be waived until the system returns to service. PRSI has also represented that within 30 days of resuming operation, a 60-day testing notification will be provided.

The Texas Commission on Environmental Quality (TCEQ) Executive Director has made a final decision to approve your AMOC request to waive performance testing referenced above. PRSI is reminded that once the equipment returns to service that testing must be completed within 150 days. The TCEQ has been delegated authority to enforce the above cited standards and is authorized to approve this AMOC. You are reminded that approval of any AMOC shall not abrogate the Executive Director or Administrator's authority under the Act or in any way prohibit later canceling the AMOC. By copy of this letter we are informing the Environmental Protection Agency, Region 6, of this decision as required by TCEQ's delegation of authority.

This AMOC approval may supersede certain requirements or representations in Permit Nos. 20246 and 22039. To ensure effective and consistent enforceability, we request that PRSI update the representations for pending permit actions (Project Nos. 318180 and 330182) to incorporate this AMOC no later than 60 days after this approval.

This approval may also change applicable requirements for the site, which are identified in the site operating permit (SOP) O3711. The TCEQ recommends the submittal of a SOP administrative revision. Changes meeting the criteria for an administrative revision can be operated before issuance of the revision if a complete application is submitted to the TCEQ and this information is maintained with the SOP records at the site.

P.O. Box 13087 · Austin, Texas 78711-3087 · 512-239-1000 · tceq.texas.gov

How is our customer service? tceq.texas.gov/customersurvey

printed on recycled paper

June 10, 2022
Page 2
MR TIM SUTHERLAND

Re: Permit Numbers: 20246 and O3711

If you need further information or have any questions, please contact Ms. Anne Inman, P.E. at (512) 239-1276 or write to the Texas Commission on Environmental Quality, Office of Air, Air Permits Division, MC-163, P.O. Box 13087, Austin, Texas 78711-3087.

Sincerely,

A handwritten signature in black ink, appearing to read 'Samuel Short', followed by a long horizontal line extending to the right.

Samuel Short, Deputy Director
Air Permits Division
Office of Air
Texas Commission on Environmental Quality

cc: Chief Health Inspector, Health Department, City of Pasadena, Pasadena
Director, Harris County, Pollution Control Services, Pasadena
Air Section Manager, Region 12 - Houston
Jesse E. Chacon, P.E., Manager, Operating Permits Section, Air Permits Division, OA: MC-163
Daniel Guthrie, Manager, Energy New Source Review Permits Section, Air Permits Division, OA:
MC-163
Air Permits Section Chief, New Source Review Section (6PD-R), U.S. Environmental Protection
Agency, Region 6, Dallas

Project Number: 341674

Appendix A

Acronym List 330

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
RO	Responsible Official
SIP	state implementation plan
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound