

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
CITGO Refining and Chemicals Company L.P.

AUTHORIZING THE OPERATION OF
Corpus Christi Refinery East Plant and Terminal
Petroleum Refineries

LOCATED AT
Nueces County, Texas
Latitude 27° 48' 34" Longitude 97° 25' 33"
Regulated Entity Number: RN102555166

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: O1423 Issuance Date: August 9, 2024

A handwritten signature in black ink, appearing to read "K. Keel", is written over a horizontal line.

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions:	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements	14
New Source Review Authorization Requirements	15
Compliance Requirements.....	15
Risk Management Plan	16
Protection of Stratospheric Ozone	16
Permit Location	17
Permit Shield (30 TAC § 122.148)	17
Attachments	18
Applicable Requirements Summary.....	19
Additional Monitoring Requirements	383
Permit Shield	445
New Source Review Authorization References	542
Appendix A	577
Acronym List	578
Appendix B	579

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
 - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.
 - E. Emission units subject to 40 CFR Part 63, Subparts F, G, H, Y, CC, UUU, EEEE, DDDDD, and GGGGG as identified in the attached Applicable Requirements Summary

table are subject to 30 TAC Chapter 113, Subchapter C, §§ 113.110, 113.120, 113.130, 113.300, 113.340, 113.780, 113.880, 113.1130, and 113.1160 respectively, which incorporates the 40 CFR Part 63 Subparts by reference.

- F. For the purpose of generating discrete emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 4 (Discrete Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
 - (i) Title 30 TAC § 101.372 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.373 (relating to Discrete Emission Reduction Credit Generation and Certification)
 - (iii) Title 30 TAC § 101.374 (relating to Mobile Discrete Emission Reduction Credit Generation and Certification)
 - (iv) Title 30 TAC § 101.378 (relating to Discrete Emission Credit Banking and Trading)
 - (v) The terms and conditions by which the emission limits are established to generate the discrete reduction credit are applicable requirements of this permit
- 2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
 - A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
- 3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
 - A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A,

Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:

- (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(1)(E)
- (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
- (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the "Applicable Requirements Summary" attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:
 - (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
 - (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
 - (3) Records of all observations shall be maintained.
 - (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance

from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(5) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
 - (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.

- (2) Records of all observations shall be maintained.
- (3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (4) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

C. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)
- (iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:

- (1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.
 - (3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
 - (4) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- D. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
- E. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).

- F. Permit holders for sites that have materials handling, construction, roads, streets, alleys, and parking lots shall comply with the following requirements:
 - (i) Title 30 TAC § 111.143 (relating to Materials Handling)
 - (ii) Title 30 TAC § 111.145 (relating to Construction and Demolition)
 - (iii) Title 30 TAC § 111.147 (relating to Roads, Streets, and Alleys)
 - (iv) Title 30 TAC § 111.149 (relating to Parking Lots)
- G. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
 - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)
 - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
- H. Outdoor burning, as stated in 30 TAC § 111.201, shall not be authorized unless the following requirements are satisfied:
 - (i) Title 30 TAC § 111.205 (relating to Exception for Fire Training)
 - (ii) Title 30 TAC § 111.207 (relating to Exception for Recreation, Ceremony, Cooking, and Warmth)
 - (iii) Title 30 TAC § 111.219 (relating to General Requirements for Allowable Outdoor Burning)
 - (iv) Title 30 TAC § 111.221 (relating to Responsibility for Consequences of Outdoor Burning)
- 4. For storage vessels maintaining working pressure as specified in 30 TAC Chapter 115, Subchapter B, Division 1: "Storage of Volatile Organic Compounds," the permit holder shall comply with the requirements of 30 TAC § 115.112(b)(1).
- 5. For industrial wastewater specified in 30 TAC Chapter 115, Subchapter B, the permit holder shall comply with the following requirements for wastewater drains, junction boxes, lift stations and weirs:
 - A. Title 30 TAC § 115.142 (relating to Control Requirements)
 - B. Title 30 TAC § 115.142(1)(A) - (D) (relating to Control Requirements)
 - C. Title 30 TAC § 115.142(1)(E) and (F) (relating to Control Requirements)
 - D. Title 30 TAC § 115.142(1)(G) and (H) (relating to Control Requirements)

- E. Title 30 TAC § 115.144(1), (5), and (6) (relating to Inspection and Monitoring Requirements)
 - F. Title 30 TAC § 115.145 (relating to Approved Test Methods)
 - G. Title 30 TAC § 115.146 (relating to Recordkeeping Requirements)
 - H. Title 30 TAC § 115.148 (relating to Determination of Wastewater Characteristics)
6. Permit holder shall comply with the following 30 TAC Chapter 115, Subchapter D requirements:
- A. Title 30 TAC § 115.312(b)(1) (relating to Control Requirements), for emissions during Process Unit Shutdown or Turnaround
7. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
- A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
 - B. Title 40 CFR § 60.8 (relating to Performance Tests)
 - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
 - F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
8. For petroleum refinery facilities subject to 40 CFR Part 60, Subpart QQQ, the permit holder shall comply with the following requirements:
- A. Title 40 CFR § 60.692-1(a) - (c) (relating to Standards: General)
 - B. Title 40 CFR § 60.692-2(a) - (c), (e) (relating to Standards: Individual Drain Systems)
 - C. Title 40 CFR § 60.692-6(a) - (b) (relating to Standards: Delay of Repair)
 - D. Title 40 CFR § 60.692-7(a) - (b) (relating to Standards: Delay of Compliance)
 - E. Title 40 CFR § 60.693-1(a) - (d), (e)(1) - (3) (relating to Alternative Standards for Individual Drain Systems)
 - F. Title 40 CFR § 60.697(a), (b)(1) - (3) (relating to Recordkeeping Requirements), as applicable to Individual Drain Systems
 - G. Title 40 CFR § 60.697(f)(1) - (2), (g) (relating to Recordkeeping Requirements), as applicable to Individual Drain Systems

- H. Title 40 CFR § 60.697(h) (relating to Recordkeeping Requirements), as applicable to excluded Stormwater Sewer Systems
 - I. Title 40 CFR § 60.697(i) (relating to Recordkeeping Requirements), as applicable to excluded Ancillary Equipment
 - J. Title 40 CFR § 60.697(j) (relating to Recordkeeping Requirements), as applicable to excluded Non-contact Cooling Water Systems
 - K. Title 40 CFR § 60.698(a), and (b)(1) (relating to Reporting Requirements), as applicable to Individual Drain Systems
 - L. Title 40 CFR § 60.698(c) (relating to Reporting Requirements), for water seal breaches in Drain Systems
 - M. Title 40 CFR § 60.698(e) (relating to Reporting Requirements), as applicable to Individual Drain Systems
9. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 61, unless otherwise stated in the applicable subpart:
- A. Title 40 CFR § 61.05 (relating to Prohibited Activities)
 - B. Title 40 CFR § 61.07 (relating to Application for Approval of Construction or Modification)
 - C. Title 40 CFR § 61.09 (relating to Notification of Start-up)
 - D. Title 40 CFR § 61.10 (relating to Source Reporting and Request Waiver)
 - E. Title 40 CFR § 61.12 (relating to Compliance with Standards and Maintenance Requirements)
 - F. Title 40 CFR § 61.13 (relating to Emissions Tests and Waiver of Emission Tests)
 - G. Title 40 CFR § 61.14 (relating to Monitoring Requirements)
 - H. Title 40 CFR § 61.15 (relating to Modification)
 - I. Title 40 CFR § 61.19 (relating to Circumvention)
10. For facilities where total annual benzene quantity from waste is greater than or equal to 10 megagrams per year and subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:
- A. Title 40 CFR § 61.342(c)(1)(i) - (iii) (relating to Standards: General)
 - B. Title 40 CFR § 61.342(e)(1) (relating to Standards: General)
 - C. Title 40 CFR § 61.342(e)(2)(i) - (ii) (relating to Standards: General)
 - D. Title 40 CFR § 61.342(f)(1), and (2) (relating to Standards: General)
 - E. Title 40 CFR § 61.342(g) (relating to Standards: General)
 - F. Title 40 CFR § 61.350(a) and (b) (relating to Standards: Delay of Repair)

- G. Title 40 CFR § 61.355(a)(1)(iii), (a)(2), (a)(6), (b), and (c)(1) - (3) (relating to Test Methods, Procedures, and Compliance Provisions)
 - H. Title 40 CFR § 61.355(k)(1) - (6), and (7)(i) - (iv) (relating to Test Methods, Procedures, and Compliance Provisions), for calculation procedures
 - I. Title 40 CFR § 61.356(a) (relating to Recordkeeping Requirements)
 - J. Title 40 CFR § 61.356(b), and (b)(1) (relating to Recordkeeping Requirements)
 - K. Title 40 CFR § 61.356(b)(4) (relating to Recordkeeping Requirements)
 - L. Title 40 CFR § 61.356(b)(5) (relating to Recordkeeping Requirements)
 - M. Title 40 CFR § 61.356(c) (relating to Recordkeeping Requirements)
 - N. Title 40 CFR § 61.357(a), (d)(1), (d)(2) (d)(6) and (d)(8) (relating to Reporting Requirements)
 - O. Title 40 CFR § 61.357(d)(5) (relating to Reporting Requirements)
 - P. Waste generated by remediation activities at these facilities are subject to the requirements identified under 40 CFR § 61.342 for treatment and management of waste
11. For facilities with individual drain systems subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:
- A. Title 40 CFR § 61.346(a)(1)(i)(A), (B), (ii), (2), and (3) (relating to Standards: Individual Drain Systems)
 - B. Title 40 CFR § 61.346(b)(1), (2), (2)(i), (3), (4)(i) - (iv), and (5) (relating to Standards: Individual Drain Systems)
 - C. Title 40 CFR § 61.346(b)(2)(ii)(B) (relating to Standards: Individual Drain Systems), for junction boxes
 - D. Title 40 CFR § 61.355(h) (relating to Test Methods, Procedures and Compliance Provisions)
 - E. Title 40 CFR § 61.356(g) (relating to Recordkeeping Requirements)
 - F. Title 40 CFR § 61.356(h) (relating to Recordkeeping Requirements)
12. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
13. For the chemical manufacturing process specified in 40 CFR Part 63, Subpart F, the permit holder shall comply with 40 CFR § 63.103(a) (relating to General Compliance, Reporting, and Recordkeeping Provisions) (Title 30 TAC Chapter 113, Subchapter C, § 113.110 incorporated by reference).
14. For the chemical manufacturing facilities subject to provisions in 40 CFR Parts 260 - 272, the permit holder shall comply with the following requirements:

- A. Title 40 CFR § 63.110(e)(2)(i) (relating to Applicability), for 40 CFR Part 63, Subpart G applicability to Group 1 or 2 Wastewater Streams
 - B. Title 40 CFR § 63.110(e)(2)(ii)(A) and (B) (relating to Applicability), for 40 CFR Part 63, Subpart G applicability to Group 1 or 2 Wastewater Streams
- 15. For the chemical manufacturing facilities with a 40 CFR Part 63, Subpart G Group 1 or Group 2 wastewater streams that are also subject to 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):
 - A. Title 40 CFR § 63.110(e)(1)(i) and (e)(1)(ii) (relating to Applicability), for 40 CFR Part 63, Subpart G applicability to Group 1 or 2 Wastewater Streams
- 16. For the chemical manufacturing facilities with a 40 CFR Part 63, Subpart G Group 2 wastewater stream, the permit holder shall comply with (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):
 - A. Title 40 CFR § 63.132(a), (a)(1), and (a)(1)(i) (relating to Process Wastewater Provisions - General)
 - B. Title 40 CFR § 63.146(b)(1) (relating to Process Wastewater Provisions - Reporting)
 - C. Title 40 CFR § 63.147(b)(8) (relating to Process Wastewater Provisions - Recordkeeping)
- 17. For the transfer of Group 1 wastewater streams or residuals from Group 1 wastewater streams the permit holder shall comply with the following requirements:
 - A. Title 40 CFR § 63.132(g) (relating to Process Wastewater Provisions - General)
 - B. Title 40 CFR § 63.152(b)(5) and (c)(4)(iv) (relating to General Reporting and Continuous Records)
- 18. For the chemical manufacturing facilities subject to leak detection requirements in 40 CFR Part 63, Subpart G, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):
 - A. General Leak Detection Requirements:
 - (i) Title 40 CFR § 63.148(d)(1) - (3), and (e) (relating to Leak Inspection Provisions)
 - (ii) Title 40 CFR § 63.148(c), (g), (g)(2), (h), and (h)(2) (relating to Leak Inspection Provisions), for monitoring and testing requirements
 - (iii) Title 40 CFR §§ 63.148(g)(2), (h)(2), (i)(1) - (2), (i)(4)(i) - (viii), (i)(5), and 63.152(a)(1) - (5), for recordkeeping requirements
 - (iv) Title 40 CFR §§ 63.148(j), 63.151(a)(6)(i) - (iii), (b)(1) - (2), (j)(1) - (3), 63.152(a)(1) - (5), (b), (b)(1)(i) - (ii), and (b)(4), for reporting requirements
 - B. For closed vent system or vapor collection systems constructed of hard piping:
 - (i) Title 40 CFR § 63.148(b)(1)(ii) (relating to Leak Inspection Provisions), for monitoring and testing requirements

- (ii) Title 40 CFR § 63.148(i)(6) (relating to Leak Inspection Provisions), for recordkeeping requirements
- 19. For the chemical manufacturing facilities subject to transfer operations requirements in 40 CFR Part 63, Subpart G, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):
 - A. Title 40 CFR § 63.126(e)(1) - (2), and (f) (relating to Transfer Operations Provisions Reference Control Technology)
 - B. Title 40 CFR § 63.128(f)(1) - (2) (relating to Transfer Operations Provisions - Test Methods and Procedures)
 - C. Title 40 CFR § 63.130(e) (relating to Transfer Operations Provisions - Periodic Recordkeeping and Reporting)
- 20. For the chemical manufacturing facilities subject to wastewater operations requirements in 40 CFR Part 63, Subpart G, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.120 incorporated by reference):
 - A. Title 40 CFR § 63.135(a) - (f) (relating to Process Wastewater Provisions - Containers)
 - B. Title 40 CFR § 63.136(a) (relating to Process Wastewater Provisions - Individual Drain Systems)
 - C. Title 40 CFR § 63.136(b) - (d) (relating to Process Wastewater Provisions - Individual Drain Systems)
 - D. Title 40 CFR § 63.136(e) - (g) (relating to Process Wastewater Provisions - Individual Drain Systems)
- 21. For the operations pertaining to the loading and unloading of marine tank vessels specified in 40 CFR Part 63, Subpart Y, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.300 incorporated by reference):
 - A. Title 40 CFR § 63.560(c) (relating to Designation of Affected Source), for applicability of the General Provisions of Subpart A
 - B. Title 40 CFR § 63.563(a)(4) (relating to Compliance and Performance Testing), for vapor tightness requirements of the marine vessels
 - C. Title 40 CFR § 63.564(a)(1) and (d) (relating to Monitoring Requirements)
 - D. Title 40 CFR § 63.565(a) (relating to Test Methods and Procedures), for performance testing requirements
 - E. Title 40 CFR § 63.565(c) (relating to Test Methods and Procedures), for vapor tightness requirements of the marine vessels
 - F. Title 40 CFR § 63.566 (relating to Construction and Reconstruction)
 - G. Title 40 CFR § 63.567(a) - (b) and (h) - (i) (relating to Reporting and Recordkeeping Requirements)

22. For sources subject to emission standards in 40 CFR Part 63, Subpart CC, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.340 incorporated by reference):
- A. Title 40 CFR § 63.640(m) and (m)(1) - (2) (relating to Applicability and Designation of Affected Source), for units and emission points changing from Group 2 to Group 1 status
 - B. Title 40 CFR § 63.642(f) (relating to General Standards), for reporting
 - C. For benzene fenceline monitoring, the permit holder shall comply with the following requirements:
 - (i) Title 40 CFR § 63.658(a) - (k) (relating to Fenceline Monitoring Provisions)
 - (ii) Title 40 CFR § 63.655(h), (h)(8), and (h)(10) (relating to Reporting and Recordkeeping Requirements), for reporting
 - (iii) Title 40 CFR § 63.655(i), (i)(6), and (i)(8) (relating to Reporting and Recordkeeping Requirements), for recordkeeping
 - D. Process wastewater streams managed in a wastewater management unit subject to 40 CFR Part 63, Subpart G shall comply with 40 CFR Part 63, Subpart G and 40 CFR Part 61, Subpart FF as specified in 40 CFR § 63.640(o)(2)(i)
23. The permit holder shall comply with the requirement to prepare and implement an Operations and Maintenance plan in accordance with 40 CFR Part 63, Subpart UUU, § 63.1574(f) (Title 30 TAC Chapter 113, Subchapter C, § 113.780 incorporated by reference).
24. For site remediation projects subject to 40 CFR Part 63, Subpart GGGGG that are completed within 30 consecutive calendar days the permit holder shall comply with 40 CFR § 63.7884(b), (b)(1) - (3) (Title 30 TAC, Subchapter C, § 113.1160 incorporated by reference).
25. For the transfer of site remediation materials subject to 40 CFR Part 63, Subpart GGGGG off-site to another facility, the permit holder shall comply with the following requirements (Title 30 TAC, Subchapter C, § 113.1160 incorporated by reference):
- A. Title 40 CFR § 63.7936(a), for the transfer of site remediation materials
 - B. Title 40 CFR § 63.7936(b)(1), for transfer to a landfill or land disposal unit
 - C. Title 40 CFR § 63.7936(b)(2), for transfer to a facility subject to 40 CFR Part 63, Subpart DD
 - D. Title 40 CFR § 63.7936(b)(3), (b)(3)(i) - (iv), for transfer to a facility managing the site remediation material according to the requirements of 40 CFR Part 63, Subpart GGGGG
26. For containers managing remediation materials subject to 40 CFR Part 63, Subpart GGGGG, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.1160 incorporated by reference):
- A. Title 40 CFR § 63.922(b)(1) - (3), (c), (d), (d)(1) - (5), (e), and (f), (f)(1) - (4) (relating to Standards - Container Level 1 Controls)
 - B. Title 40 CFR § 63.923(b)(1) - (3), (c), (d), (d)(1) - (5), (e), and (f), (f)(1) - (4) (relating to Standards - Container Level 2 Controls)

- C. Title 40 CFR § 63.924(b)(1) - (2), (c)(1), and (d) (relating to Standards - Container Level 3 Controls)
 - D. Title 40 CFR § 63.925(a)(1) - (8), and (b)(1) - (3) (relating to Test Methods and Procedures)
 - E. Title 40 CFR § 63.926(a)(1) - (3) (relating to Inspection and Monitoring Requirements)
 - F. Title 40 CFR § 63.7901(b) and (b)(1), for initial demonstration of compliance
 - G. Title 40 CFR § 63.7901(b)(2), for initial demonstration of compliance
 - H. Title 40 CFR § 63.7901(c), (c)(1), and (c)(2), for initial demonstration of compliance
 - I. Title 40 CFR § 63.7901(d), and (d)(1) - (4), for initial demonstration of compliance
 - J. Title 40 CFR § 63.7901(e), (e)(1), and (e)(2), for initial demonstration of compliance
 - K. Title 40 CFR § 63.7902(b), (b)(1), and (b)(2), for inspection and monitoring
 - L. Title 40 CFR § 63.7903(b) and (b)(1), for continuous demonstration of compliance
 - M. Title 40 CFR § 63.7903(b)(2), (b)(2)(i), (b)(2)(ii), for continuous demonstration of compliance
 - N. Title 40 CFR § 63.7903(c)(4), (c)(4)(i), and (c)(4)(ii), for continuous demonstration of compliance
 - O. Title 40 CFR § 63.7903(d)(5), (d)(5)(i), and (d)(5)(ii), for continuous demonstration of compliance
 - P. Title 40 CFR § 63.7903(e)(1) - (3), for continuous demonstration of compliance
 - Q. Title 40 CFR § 63.7952(c), for recordkeeping
27. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

Additional Monitoring Requirements

28. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent

with the averaging time or minimum frequency specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

29. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule (including the terms, conditions, monitoring, recordkeeping, and reporting identified in registered PBRs and permits by rule identified in the PBR Supplemental Tables dated April 12, 2024 in the application for project 35259), standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
 - A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
30. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
31. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
32. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
 - A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
 - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
 - C. Requirements of the non-rule Air Quality Standard Permit for Pollution Control Projects

Compliance Requirements

33. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period

may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.

34. Use of Discrete Emission Credits to comply with the applicable requirements:
- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
 - B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Risk Management Plan

35. For processes subject to 40 CFR Part 68 and specified in 40 CFR § 68.10, the permit holder shall comply with the requirements of the Accidental Release Prevention Provisions in 40 CFR Part 68. The permit holder shall submit to the appropriate agency either a compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR § 68.10(a), or as part of the compliance certification submitted under this permit, a certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of a risk management plan.

Protection of Stratospheric Ozone

36. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
- A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by

properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.

Permit Location

37. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

38. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Alternative Requirement

Applicable Requirements Summary

Unit Summary	20
---------------------------	-----------

Applicable Requirements Summary	52
--	-----------

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
11-H1	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60Ja-1	40 CFR Part 60, Subpart Ja	No changing attributes.
11-H1	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
11-H2	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
14-H1	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
14-H1	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
17-H1	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
17-INC	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
18-E22	Vacuum Producing Systems	N/A	R5115D-01	30 TAC Chapter 115, Unit Turn & Vac System-Pet Ref	No changing attributes.
18-HOTWELL	Vacuum Producing Systems	N/A	R5115D-01	30 TAC Chapter 115, Unit Turn & Vac System-Pet Ref	No changing attributes.
19-H1	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
19-H1	Process Heaters/Furnaces	N/A	63DDDDD-02	40 CFR Part 63, Subpart DDDDD	No changing attributes.
19-H2	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
19-H2	Process Heaters/Furnaces	N/A	63DDDDD-01	40 CFR Part 63, Subpart DDDDD	No changing attributes.
204-U942	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
204-U942	Fugitive Emission Units	N/A	60GGG-ALL	40 CFR Part 60, Subpart GGG	No changing attributes.
207-H-1	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
21-H1A	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
21-H1B	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
23-TK0002A	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
28-H1	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
28-H3	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
29-H1 C&D	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
29-H1A	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
29-H1A	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
29-H1B	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
29-H2B	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
29-H2B	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
29-H3	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
29-TK0105	Storage Tanks/Vessels	N/A	63EEEE	40 CFR Part 63, Subpart EEEE	No changing attributes.
29-V26	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	63UUU-1	40 CFR Part 63, Subpart UUU	No changing attributes.
31-FCCU2	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FCCU	40 CFR Part 60, Subpart J	No changing attributes.
31-FCCU2	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	63UUU-1	40 CFR Part 63, Subpart UUU	No changing attributes.
31-PR-1	Emission Points/Stationary Vents/Process Vents	N/A	111-VENT02	30 TAC Chapter 111, Visible Emissions	No changing attributes.
41-H1	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60Ja-1	40 CFR Part 60, Subpart Ja	§60.107a(b) Exemption = The fuel gas combustion device is not eligible for the exemption in §60.107a(b)
41-H1	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60Ja-2	40 CFR Part 60, Subpart Ja	§60.107a(b) Exemption = The fuel gas combustion device is eligible for the exemption in §60.107a(b)
41-H1	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
41-H2	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60Ja-1	40 CFR Part 60, Subpart Ja	§60.107a(b) Exemption = The fuel gas combustion device is not eligible for the exemption in §60.107a(b)
41-H2	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60Ja-2	40 CFR Part 60, Subpart Ja	§60.107a(b) Exemption = The fuel gas combustion device is eligible for the exemption in §60.107a(b)
41-H2	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
41-U41	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
41-U41	Fugitive Emission Units	N/A	60GGGA-ALL	40 CFR Part 60, Subpart GGGa	No changing attributes.
41-U41	Fugitive Emission Units	N/A	63CCVV-ALL	40 CFR Part 63, Subpart CC	No changing attributes.
44-V10	Emission Points/Stationary Vents/Process Vents	N/A	R5VT-1	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
46-U46	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
47-TK0103	Storage Tanks/Vessels	N/A	115-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
47-TK0103	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
47-U47	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
47-U47	Fugitive Emission Units	N/A	60GGG-ALL	40 CFR Part 60, Subpart GGG	No changing attributes.
51-TK0001	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
52-U52AMNE	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
52-U52AMNE	Fugitive Emission Units	N/A	63CCVV-ALL	40 CFR Part 63, Subpart CC	No changing attributes.
52-U52SRU	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
53-U53	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
54-TK0001	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
54-TK0001	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
54-TK3	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
54-TK3	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
54-TK3	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
56-U56	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
57-D7	Loading/Unloading Operations	N/A	63CC-LOAD	40 CFR Part 63, Subpart CC	No changing attributes.
57-D7	Loading/Unloading Operations	N/A	63Y-LOAD03	40 CFR Part 63, Subpart Y	Material Loaded = Gasoline., Throughput = Source with throughput of 10 M barrels or 200 M barrels.
57-D7	Loading/Unloading Operations	N/A	63Y-LOAD04	40 CFR Part 63, Subpart Y	Material Loaded = Material other than crude oil or gasoline.
57-UD1	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
57-UD1	Fugitive Emission Units	N/A	61J-ALL	40 CFR Part 61, Subpart J	No changing attributes.
57-UD1	Fugitive Emission Units	N/A	61V-ALL	40 CFR Part 61, Subpart V	No changing attributes.
57-UD2	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
57-UDMEC	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
57-UDMEC	Fugitive Emission Units	N/A	60VV-ALL	40 CFR Part 60, Subpart VV	No changing attributes.
57-VC2D7	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
61-B3E	Boilers/Steam Generators/Steam Generating Units	N/A	60DB-BOIL01	40 CFR Part 60, Subpart Db	Alternate Emission Limit (AEL) = The facility combusts byproduct/waste with either natural gas or oil and did not petition the EPA Administrator to establish a NO _x emission limit that applies specifically when the byproduct/waste is combusted., Facility Type = The affected facility includes a fuel gas combustion device., Monitoring Device = An instrument is in place for continuous monitoring and recording the concentration (dry basis) of hydrogen sulfide in fuel gasses before being burned in any fuel gas combustion device., Common Fuel Source = The fuel gas combustion device has a common fuel source with other fuel gas combustion devices., D-Series Fuel Type #1 = Byproduct/waste., Subpart J = The affected facility meets applicability requirements of 40 CFR Part 60, Subpart J.
61-B3E	Boilers/Steam Generators/Steam Generating Units	N/A	60DB-BOIL02	40 CFR Part 60, Subpart Db	D-Series Fuel Type #1 = Natural gas., Subpart J = The affected facility does not meet applicability requirements of 40 CFR Part 60, Subpart J., Subpart E = The affected facility does not meet applicability requirements of 40 CFR Part 60, Subpart E.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
61-B3E	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
61-B3E	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
64-TK0013	Storage Tanks/Vessels	N/A	115TK-03	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
73-FLR442	Flares	N/A	111-FLARE02	30 TAC Chapter 111, Visible Emissions	No changing attributes.
73-FLR442	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60Ja-1	40 CFR Part 60, Subpart Ja	Common Source of Fuel Gas = The flare uses a common source of gas as described in §60.107a(a)(2)(iv), §60.107a(e)(4) Exemption = The flare is not eligible for the exemption in §60.107a(e)(4), §60.107a(a)(3) Exemption = The flare is not eligible for the exemption in §60.107a(a)(3)
73-FLR442	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60Ja-2	40 CFR Part 60, Subpart Ja	§60.107a(e)(4) Exemption = The flare is eligible for the exemption in §60.107a(e)(4), §60.107a(a)(3) Exemption = The flare is eligible for the exemption in §60.107a(a)(3)
73-FLR442	Flares	N/A	63CC-1	40 CFR Part 63, Subpart CC	Flare Tip Velocity = Flare tip velocity is less than 60 feet per second (ft/s)
73-FLR442	Flares	N/A	63CC-2	40 CFR Part 63, Subpart CC	Flare Tip Velocity = Flare tip velocity is greater than or equal to 60 ft/s but less than 400 ft/s
73-FLR446	Flares	N/A	111-FLARE02	30 TAC Chapter 111, Visible Emissions	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
73-FLR446	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60Ja-1	40 CFR Part 60, Subpart Ja	Common Source of Fuel Gas = The flare uses a common source of gas as described in §60.107a(a)(2)(iv), §60.107a(e)(4) Exemption = The flare is not eligible for the exemption in §60.107a(e)(4), §60.107a(a)(3) Exemption = The flare is not eligible for the exemption in §60.107a(a)(3)
73-FLR446	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60Ja-2	40 CFR Part 60, Subpart Ja	§60.107a(e)(4) Exemption = The flare is eligible for the exemption in §60.107a(e)(4), §60.107a(a)(3) Exemption = The flare is eligible for the exemption in §60.107a(a)(3)
73-FLR446	Flares	N/A	63CC-1	40 CFR Part 63, Subpart CC	Flare Tip Velocity = Flare tip velocity is less than 60 feet per second (ft/s)
73-FLR446	Flares	N/A	63CC-2	40 CFR Part 63, Subpart CC	Flare Tip Velocity = Flare tip velocity is greater than or equal to 60 ft/s but less than 400 ft/s
73-U73F	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
73-U73F	Fugitive Emission Units	N/A	63CCVV-ALL	40 CFR Part 63, Subpart CC	No changing attributes.
73-VC447	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
73-VC448	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
73-VC449	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
80-DSW	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
80-DSW	Fugitive Emission Units	N/A	60VV-ALL	40 CFR Part 60, Subpart VV	No changing attributes.
80-DSW	Fugitive Emission Units	N/A	61J-ALL	40 CFR Part 61, Subpart J	No changing attributes.
80-DSW	Fugitive Emission Units	N/A	61V-ALL	40 CFR Part 61, Subpart V	No changing attributes.
82-CPI	Volatile Organic Compound Water Separators	N/A	115-CPI01	30 TAC Chapter 115, Water Separation	No changing attributes.
82-CPI	Volatile Organic Compound Water Separators	N/A	60QQQ-CPI1	40 CFR Part 60, Subpart QQQ	No changing attributes.
82-TK0006	Storage Tanks/Vessels	N/A	61FF-WW	40 CFR Part 61, Subpart FF	No changing attributes.
82-TK0114	Storage Tanks/Vessels	N/A	61FF-WW1	40 CFR Part 61, Subpart FF	Carbon Replacement Interval = The carbon in the carbon adsorption system is replaced at a regular predetermined interval.
82-TK0114	Storage Tanks/Vessels	N/A	61FF-WW2	40 CFR Part 61, Subpart FF	Carbon Replacement Interval = The carbon in the carbon adsorption system is replaced when monitoring indicates breakthrough.
82-TK0115	Storage Tanks/Vessels	N/A	61FF-WW	40 CFR Part 61, Subpart FF	No changing attributes.
82-TK0115	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
82-TK0116	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
82-TK0116	Storage Tanks/Vessels	N/A	61FF-WW	40 CFR Part 61, Subpart FF	No changing attributes.
82-TK0116	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
82-TK0117	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
82-TK0117	Storage Tanks/Vessels	N/A	61FF-WW	40 CFR Part 61, Subpart FF	No changing attributes.
82-TK0117	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
82-TK0605	Storage Tanks/Vessels	N/A	61FF-WWTK1	40 CFR Part 61, Subpart FF	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
82-TK0605	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
82-TK0606	Storage Tanks/Vessels	N/A	61FF-WWTK1	40 CFR Part 61, Subpart FF	No changing attributes.
82-TK0606	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
82-TK0607	Storage Tanks/Vessels	N/A	61FF-WWTK1	40 CFR Part 61, Subpart FF	No changing attributes.
82-TK0607	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
82-TK0608	Storage Tanks/Vessels	N/A	61FF-WWTK1	40 CFR Part 61, Subpart FF	No changing attributes.
82-TK0608	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
83-H1	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
851-TK0925	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
851-TK0925	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
851-TK0925	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
851-TK0926	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
851-TK0926	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
851-TK0926	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
851-TK0927	Storage Tanks/Vessels	N/A	115TK-06	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
851-TK0927	Storage Tanks/Vessels	N/A	60KA-TK23	40 CFR Part 60, Subpart Ka	No changing attributes.
851-TK0927	Storage Tanks/Vessels	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
851-TK0928	Storage Tanks/Vessels	N/A	115TK-06	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
851-TK0928	Storage Tanks/Vessels	N/A	60KA-TK23	40 CFR Part 60, Subpart Ka	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
851-TK0928	Storage Tanks/Vessels	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
851-TK0929	Storage Tanks/Vessels	N/A	63G-03	40 CFR Part 63, Subpart G	No changing attributes.
851-TK0930	Storage Tanks/Vessels	N/A	63G-03	40 CFR Part 63, Subpart G	No changing attributes.
851-TK1029	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
851-TK1029	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
851-TK1029	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
851-TK1030	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
851-TK1030	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
851-TK1030	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
851-TK1031	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
851-TK1031	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
851-TK1031	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
851-TK1032	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
851-TK1032	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0201	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0201	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0201	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0202	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0202	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
852-TK0202	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0211	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0211	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0211	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0212	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0212	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0212	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0221	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0221	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0221	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0222	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0222	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0222	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0223	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0223	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0223	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0224	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0224	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0224	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
852-TK0224	Storage Tanks/Vessels	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
852-TK0225	Storage Tanks/Vessels	N/A	115TK-06	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0225	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0225	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0225	Storage Tanks/Vessels	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
852-TK0226	Storage Tanks/Vessels	N/A	115TK-06	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0226	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0226	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0226	Storage Tanks/Vessels	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
852-TK0301	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0301	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0301	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0302	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0302	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0302	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0401	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0401	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0401	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0402	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
852-TK0402	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0402	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0403	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0403	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0403	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0620	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0621	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK0804	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK0804	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK0804	Storage Tanks/Vessels	N/A	61FF-WWTK1	40 CFR Part 61, Subpart FF	No changing attributes.
852-TK0804	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	Group 1 Storage Vessel = The storage vessel is a Group 2 vessel., Group 2 Applicability = The storage vessel is required to comply with 40 CFR Part 63, Subpart CC and is part of a process unit.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
852-TK0804	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	Group 1 Applicability = The storage vessel is also subject to 40 CFR Part 60, Subpart Kb and is complying with that rule, Group 1 Storage Vessel = The storage vessel is a Group 1 storage vessel (as defined in 40 CFR § 63.641), Product Stored = Crude oil, Storage Capacity = Capacity is greater than or equal to 39,900 gallons (151,416 liters), Maximum TVP = True vapor pressure is greater than or equal to 0.75 psia but less than 11.1 psia, Storage Vessel Description = Fixed roof with an internal floating roof using a mechanical shoe seal, Reid Vapor Pressure = Reid vapor pressure is greater than or equal to 2.0 psia
852-TK0804	Storage Tanks/Vessels	N/A	63G-WWTK11	40 CFR Part 63, Subpart G	No changing attributes.
852-TK1001	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK1002	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK1003	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK1009	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK1009	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK1009	Storage Tanks/Vessels	N/A	61FF-WW	40 CFR Part 61, Subpart FF	No changing attributes.
852-TK1009	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK1010	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
852-TK1015	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK1016	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
852-TK1016	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
852-TK1016	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK1017	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK1018	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK1019	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK1020	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
852-TK1028	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
853-TK2001	Storage Tanks/Vessels	N/A	115-TK21	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
853-TK2001	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
853-TK2002	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	Storage Capacity = Capacity is greater than 40,000 gallons, Product Stored = VOC other than crude oil or condensate
853-TK2002	Storage Tanks/Vessels	N/A	115TK-21	30 TAC Chapter 115, Storage of VOCs	Storage Capacity = Capacity is greater than 40,000 gallons, Product Stored = Crude oil and/or condensate
853-TK2002	Storage Tanks/Vessels	N/A	60KB-1	40 CFR Part 60, Subpart Kb	No changing attributes.
853-TK2002	Storage Tanks/Vessels	N/A	61FF-WWTK1	40 CFR Part 61, Subpart FF	No changing attributes.
853-TK2002	Storage Tanks/Vessels	N/A	63CC-TKKB1	40 CFR Part 63, Subpart CC	Product Stored = Crude oil, Reid Vapor Pressure = Reid vapor pressure is greater than or equal to 2.0 psia

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
853-TK2002	Storage Tanks/Vessels	N/A	63CC-TKKB2	40 CFR Part 63, Subpart CC	Product Stored = Refined petroleum products
853-TK2003	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
853-TK2005	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
853-TK2006	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
853-TK3101	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
853-TK3102	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
854-TK0001	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0001	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
854-TK0001	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
854-TK0001	Storage Tanks/Vessels	N/A	63G-03	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0002	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0002	Storage Tanks/Vessels	N/A	63G-TK12	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0003	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0003	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
854-TK0003	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
854-TK0003	Storage Tanks/Vessels	N/A	63G-03	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0004	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0004	Storage Tanks/Vessels	N/A	63G-TK11	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0005	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
854-TK0005	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
854-TK0005	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
854-TK0005	Storage Tanks/Vessels	N/A	63G-01	40 CFR Part 63, Subpart G	MACT Subpart F/G Applicability = The unit is a Group 1 vessel (as defined in Table 5 for existing sources or Table 6 for new sources of 40 CFR 63, Subpart G)., Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa), Emission Control Type = Internal floating roof, Seal Type = Metallic shoe seal (as defined in 40 CFR § 63.111)
854-TK0005	Storage Tanks/Vessels	N/A	63G-02	40 CFR Part 63, Subpart G	MACT Subpart F/G Applicability = The unit is a Group 2 vessel., NSPS Subpart Kb Applicability = The unit is not subject to 40 CFR Part 60, Subpart Kb.
854-TK0013	Storage Tanks/Vessels	N/A	63G-TK11	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0014	Storage Tanks/Vessels	N/A	63G-01	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0020	Storage Tanks/Vessels	N/A	63G-TK01	40 CFR Part 63, Subpart G	MACT Subpart F/G Applicability = The unit is a Group 2 vessel., NSPS Subpart Kb Applicability = The unit is not subject to 40 CFR Part 60, Subpart Kb.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
854-TK0020	Storage Tanks/Vessels	N/A	63G-TK11	40 CFR Part 63, Subpart G	MACT Subpart F/G Applicability = The unit is a Group 1 vessel (as defined in Table 5 for existing sources or Table 6 for new sources of 40 CFR 63, Subpart G)., Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa), Emission Control Type = Internal floating roof, Seal Type = Metallic shoe seal (as defined in 40 CFR § 63.111)
854-TK0021	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0021	Storage Tanks/Vessels	N/A	61FF-WWTK1	40 CFR Part 61, Subpart FF	No changing attributes.
854-TK0021	Storage Tanks/Vessels	N/A	63G-TK12	40 CFR Part 63, Subpart G	MACT Subpart F/G Applicability = The unit is a Group 1 vessel (as defined in Table 5 for existing sources or Table 6 for new sources of 40 CFR 63, Subpart G)., NESHAP Subpart Y Applicability = The unit is subject to 40 CFR Part 61, Subpart Y., Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa), Emission Control Type = Internal floating roof, Seal Type = Metallic shoe seal (as defined in 40 CFR § 63.111)

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
854-TK0021	Storage Tanks/Vessels	N/A	63G-WWTK11	40 CFR Part 63, Subpart G	Designated Group 1 = The tank receives a wastewater stream designated as Group 1 using the procedures described in §63.132(e), Process Wastewater = The tank receives, manages, or treats process wastewater streams, Meets 40 CFR § 63.139(d) = The tank does not meet the criteria of 40 CFR § 63.149(d) or the criteria in 40 CFR § 63.149(e)(2)., Wastewater Tank Usage = The wastewater tank is not used for heating wastewater, treating by means of an exothermic reaction, nor are the contents of the tank are sparged., Wastewater Tank Properties = Properties do not qualify for exemption, Emission Control Type = Fixed-roof tank equipped with an internal floating roof that meets the requirements specified in 40 CFR § 63.119(b), New Source = The source is an existing source., Alternate Monitoring Parameters = Alternate monitoring parameters for the control device have not been requested or approved.
854-TK0022	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
854-TK0022	Storage Tanks/Vessels	N/A	63G-TK12	40 CFR Part 63, Subpart G	<p>MACT Subpart F/G Applicability = The unit is a Group 1 vessel (as defined in Table 5 for existing sources or Table 6 for new sources of 40 CFR 63, Subpart G).,</p> <p>NESHAP Subpart Y Applicability = The unit is subject to 40 CFR Part 61, Subpart Y., Maximum TVP = Maximum true vapor pressure of the total organic HAP in the liquid is less than 11.11 psi (76.6 kPa), Emission Control Type = Internal floating roof, Seal Type = Metallic shoe seal (as defined in 40 CFR § 63.111)</p>

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
854-TK0022	Storage Tanks/Vessels	N/A	63G-WWTK11	40 CFR Part 63, Subpart G	Designated Group 1 = The tank receives a wastewater stream designated as Group 1 using the procedures described in §63.132(e), Process Wastewater = The tank receives, manages, or treats process wastewater streams, Meets 40 CFR § 63.139(d) = The tank does not meet the criteria of 40 CFR § 63.149(d) or the criteria in 40 CFR § 63.149(e)(2)., Wastewater Tank Usage = The wastewater tank is not used for heating wastewater, treating by means of an exothermic reaction, nor are the contents of the tank are sparged., Wastewater Tank Properties = Properties do not qualify for exemption, Emission Control Type = Fixed-roof tank equipped with an internal floating roof that meets the requirements specified in 40 CFR § 63.119(b), New Source = The source is an existing source., Alternate Monitoring Parameters = Alternate monitoring parameters for the control device have not been requested or approved.
854-TK0033	Storage Tanks/Vessels	N/A	115-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0033	Storage Tanks/Vessels	N/A	63G-TK12	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0034	Storage Tanks/Vessels	N/A	115-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
854-TK0034	Storage Tanks/Vessels	N/A	63G-TK12	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0040	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0040	Storage Tanks/Vessels	N/A	63G-TK01	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0041	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0041	Storage Tanks/Vessels	N/A	63G-TK01	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0042	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0042	Storage Tanks/Vessels	N/A	63G-TK01	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0043	Storage Tanks/Vessels	N/A	63G-03	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0044	Storage Tanks/Vessels	N/A	63G-03	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0045	Storage Tanks/Vessels	N/A	63G-03	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0050	Storage Tanks/Vessels	N/A	63G-TK01	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0055	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0055	Storage Tanks/Vessels	N/A	61FF-WWTK2	40 CFR Part 61, Subpart FF	No changing attributes.
854-TK0055	Storage Tanks/Vessels	N/A	63G-WWTK11	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0056	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0056	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
854-TK0056	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
854-TK0056	Storage Tanks/Vessels	N/A	63G-02	40 CFR Part 63, Subpart G	No changing attributes.
854-TK0057	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
854-TK0057	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
854-TK0057	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
854-TK0060	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
854-TK0061	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
854-TK0062	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
854-TK0081	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
854-TK0082	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0082	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
854-TK0082	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
854-TK0083	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0083	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
854-TK0083	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
854-TK0091	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0091	Storage Tanks/Vessels	N/A	60KA-TK11	40 CFR Part 60, Subpart Ka	No changing attributes.
854-TK0092	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0092	Storage Tanks/Vessels	N/A	60KA-TK11	40 CFR Part 60, Subpart Ka	No changing attributes.
854-TK0093	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
854-TK0093	Storage Tanks/Vessels	N/A	60KA-TK11	40 CFR Part 60, Subpart Ka	No changing attributes.
855-TK1018	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
855-TK1019	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
855-TK1022	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
855-TK1022	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
855-TK1022	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
855-TK1023	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
855-TK1023	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
855-TK1023	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
855-TK1024	Storage Tanks/Vessels	N/A	115TK-05	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
855-TK1024	Storage Tanks/Vessels	N/A	60KB	40 CFR Part 60, Subpart Kb	No changing attributes.
855-TK1024	Storage Tanks/Vessels	N/A	63CC-TKKB	40 CFR Part 63, Subpart CC	No changing attributes.
855-TK1025	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
855-TK1026	Storage Tanks/Vessels	N/A	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
855-TK1027	Storage Tanks/Vessels	N/A	115TK-22	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
855-TK1027	Storage Tanks/Vessels	N/A	60KA-TK22	40 CFR Part 60, Subpart Ka	No changing attributes.
855-TK1027	Storage Tanks/Vessels	N/A	63G-TK22	40 CFR Part 63, Subpart G	No changing attributes.
855-TK1040	Storage Tanks/Vessels	N/A	63G-03	40 CFR Part 63, Subpart G	No changing attributes.
855-TK1041	Storage Tanks/Vessels	N/A	63G-03	40 CFR Part 63, Subpart G	No changing attributes.
855-TK1042	Storage Tanks/Vessels	N/A	115TK-06	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
855-TK1042	Storage Tanks/Vessels	N/A	60KA-TK23	40 CFR Part 60, Subpart Ka	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
855-TK1042	Storage Tanks/Vessels	N/A	63G-1	40 CFR Part 63, Subpart G	No changing attributes.
89-U89	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
911-H	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
911-H	Process Heaters/Furnaces	N/A	63DDDDD-03	40 CFR Part 63, Subpart DDDDD	No changing attributes.
97-D3FUG	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
DEAUNLOAD	Loading/Unloading Operations	N/A	63EEEE	40 CFR Part 63, Subpart EEEE	No changing attributes.
DIESELLOAD	Loading/Unloading Operations	N/A	115-LOAD02	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
ENGVENT01	Emission Points/Stationary Vents/Process Vents	065-P-35 VENT, 065-P-36 VENT, 065-P-37 VENT, 065-P-38 VENT, 085-P-525 VENT, 114-P-001 VENT, 114-P-002 VENT, 114-P-003 VENT, 114-P-004 VENT	111-ENGVENT01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
F066	Emission Points/Stationary Vents/Process Vents	N/A	111-VENT03	30 TAC Chapter 111, Visible Emissions	No changing attributes.
F416	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
F416	Fugitive Emission Units	N/A	60GGG-ALL	40 CFR Part 60, Subpart GGG	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
FUG-FGRS	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
FUG-FGRS	Fugitive Emission Units	N/A	63CCVV-ALL	40 CFR Part 63, Subpart CC	No changing attributes.
FUG-GHT	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
FUG-GHT	Fugitive Emission Units	N/A	60GGG-ALL	40 CFR Part 60, Subpart GGG	No changing attributes.
FUG-GHT	Fugitive Emission Units	N/A	60GGGA-1	40 CFR Part 60, Subpart GGGa	No changing attributes.
FUG-GHT	Fugitive Emission Units	N/A	63CCVV-1	40 CFR Part 63, Subpart CC	No changing attributes.
GRP-HONVT	Emission Points/Stationary Vents/Process Vents	14-E28, 14-V42	63G-VENT01	40 CFR Part 63, Subpart G	No changing attributes.
GRP-NNNVT1	Distillation Operations	14-E43, 14-V15, 14- V28, 14-V31, 18- V65, 18-V66, 18- V92, 18-V96	60NNN-01	40 CFR Part 60, Subpart NNN	No changing attributes.
GRP1DOCK	Loading/Unloading Operations	57-D1, 57-D2	63CC-LOAD	40 CFR Part 63, Subpart CC	No changing attributes.
GRP1DOCK	Loading/Unloading Operations	57-D1, 57-D2	63Y-LOAD03	40 CFR Part 63, Subpart Y	Material Loaded = Gasoline., Throughput = Source with throughput of 10 M barrels or 200 M barrels.
GRP1DOCK	Loading/Unloading Operations	57-D1, 57-D2	63Y-LOAD04	40 CFR Part 63, Subpart Y	Material Loaded = Material other than crude oil or gasoline.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRP1HTR	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	11-H2, 17-H1, 207- H-1, 21-H1A, 21- H1B, 28-H1, 28-H3, 29-H1 C&D, 29- H1B, 29-H3, 31-H1, 83-H1	60J-FUEL01	40 CFR Part 60, Subpart J	No changing attributes.
GRP1PRO	Chemical Manufacturing Process	PROADP, PROBTX, PROCUMENE, PROHYDRAR	63F-PRO01	40 CFR Part 63, Subpart F	No changing attributes.
GRP1STACK	Emission Points/Stationary Vents/Process Vents	73-STK447, 73- STK448, 73-STK449	111-VENT01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRP2FUG	Fugitive Emission Units	10-U10, 21-U21, 23- U23, 24-U24, 28- U28, 29-U29, 31- U31DEC5, 31- U31FCCU, 37- U37MS, 37- U37SHP, 38-U38, 42-U42, 43-U43, 44- U44, 45-U45, 60- U61A,B, 83-U83	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
GRP2FUG	Fugitive Emission Units	10-U10, 21-U21, 23- U23, 24-U24, 28- U28, 29-U29, 31- U31DEC5, 31- U31FCCU, 37- U37MS, 37- U37SHP, 38-U38, 42-U42, 43-U43, 44- U44, 45-U45, 60- U61A,B, 83-U83	63CCVV-ALL	40 CFR Part 63, Subpart CC	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRP2STACK	Emission Points/Stationary Vents/Process Vents	252, 292	111-VENT01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRP3FUG	Fugitive Emission Units	14-U14, 18-U18, 19- U19, 73-U73C, F222	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
GRP3FUG	Fugitive Emission Units	14-U14, 18-U18, 19- U19, 73-U73C, F222	63H-ALL	40 CFR Part 63, Subpart H	No changing attributes.
GRP4FUG	Fugitive Emission Units	57-UD7, 85-U85	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
GRPDEGRSR	Solvent Degreasing Machines	DEGRSR1-MS, DEGRSR2-MS, DEGRSR3-ES, DEGRSR4-IS	115-SOLV11	30 TAC Chapter 115, Degreasing Processes	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRPVENDTKS	Storage Tanks/Vessels	11-TK0106, 11-TK0107, 11-TK0108, 11-TK0109, 11-TK0110, 14-TK0001, 29-TK0101, 30-TK0101, 38-TK0103, 38-TK0104, 38-TK0107, 38-TK0109, 50-TK0101, 60-TK0107, 60-TK0108, 60-TK0109, 81-TK0103, 81-TK0104, 82-TK0101, 82-TK0103, 82-TK0612, 85-TK0006, 85-TK0063, 85-TK0192, 85-TK0205, 97-TK0102, BETZ TK204655, BETZ TK204656, BETZ TK204657, BETZ TK204658, BETZ TK205502, BETZ TK205534, BETZ TK220742, BETZ TK232022, BETZ TK982192	115TK-03	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GRPVENDTKS	Storage Tanks/Vessels	11-TK0106, 11-TK0107, 11-TK0108, 11-TK0109, 11-TK0110, 14-TK0001, 29-TK0101, 30-TK0101, 38-TK0103, 38-TK0104, 38-TK0107, 38-TK0109, 50-TK0101, 60-TK0107, 60-TK0108, 60-TK0109, 81-TK0103, 81-TK0104, 82-TK0101, 82-TK0103, 82-TK0612, 85-TK0006, 85-TK0063, 85-TK0192, 85-TK0205, 97-TK0102, BETZ TK204655, BETZ TK204656, BETZ TK204657, BETZ TK204658, BETZ TK205502, BETZ TK205534, BETZ TK220742, BETZ TK232022, BETZ TK982192	63CC-G2	40 CFR Part 63, Subpart CC	No changing attributes.
PCEUNLOAD	Loading/Unloading Operations	N/A	63EEEE	40 CFR Part 63, Subpart EEEE	No changing attributes.
PROBTXTRTR	Treatment Process	N/A	61FF-TRT01	40 CFR Part 61, Subpart FF	No changing attributes.
PROBTXTRTR	Treatment Process	N/A	63G-TRT01	40 CFR Part 63, Subpart G	No changing attributes.
PRODFDTRTR	Treatment Process	N/A	61FF-TRT02	40 CFR Part 61, Subpart FF	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
PRODFDTRTR	Surface Impoundment	N/A	63GGGGG	40 CFR Part 63, Subpart GGGGG	No changing attributes.
PROEPSRU	Gas Sweetening/Sulfur Recovery Units	N/A	112-SRU01	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
PROEPSRU	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	60J-SRU1	40 CFR Part 60, Subpart J	No changing attributes.
PROEPSRU	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	63UUU-1	40 CFR Part 63, Subpart UUU	SRU Startup/ShutdownEmissions = Startup/shutdown emissions sent to thermal incinerator
PROEPSRU	FCCU Cat Regen/Fuel Gas Combustion/Claus SRU	N/A	63UUU-2	40 CFR Part 63, Subpart UUU	SRU Startup/ShutdownEmissions = Startup/shutdown emissions sent to flare meeting §63.670
SCOTFUG	Fugitive Emission Units	N/A	R5322-ALL	30 TAC Chapter 115, Fugitives Pet Ref B Counties	No changing attributes.
SCOTFUG	Fugitive Emission Units	N/A	60GGG-ALL	40 CFR Part 60, Subpart GGG	No changing attributes.
SLDGLOAD	Loading/Unloading Operations	N/A	115-LOAD02	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
SURFCOAT	Surface Coating Operations	N/A	115-COAT01	30 TAC Chapter 115, Surface Coating Operations	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
11-H1	EU	60Ja-1	Hydrogen Sulfide	40 CFR Part 60, Subpart Ja	§ 60.102a(g)(1)(ii) § 60.102a(a) § 60.102a(g) § 60.102a(g)(1) § 60.103a(c) § 60.103a(d) § 60.103a(d)(1) § 60.103a(d)(5) [G]§ 60.103a(e)	For each fuel gas combustion device the owner or operator shall not burn in any fuel gas combustion device any fuel gas that contains H ₂ S in excess of 162 ppmv determined hourly on a 3-hour rolling average basis and H ₂ S in excess of 60 ppmv determined daily on a 365 successive calendar day rolling average basis.	§ 60.104a(a) § 60.104a(c) [G]§ 60.104a(j) § 60.107a(a) § 60.107a(a)(2) § 60.107a(a)(2)(i) § 60.107a(a)(2)(ii) § 60.107a(a)(2)(iii) § 60.107a(a)(2)(iv) § 60.107a(i) § 60.107a(i)(1)(ii)	§ 60.108a(a) § 60.108a(c) [G]§ 60.108a(c)(6) [G]§ 60.108a(d)	§ 60.108a(a) § 60.108a(b) [G]§ 60.108a(d)
11-H1	EU	60Ja-1	NO _x	40 CFR Part 60, Subpart Ja	§ 60.102a(g)(2)(ii)(A) § 60.102a(a) § 60.102a(g) § 60.102a(g)(2) § 60.102a(g)(2)(ii)	For each forced draft process heater with a rated capacity of greater than 40 MMBtu/hr on a higher heating value basis, the owner or operator shall not discharge to the atmosphere any emissions of NO _x in excess of 60 ppmv (dry basis, corrected to 0-percent excess air) determined daily on a 30-day rolling average basis.	§ 60.104a(a) § 60.104a(c) § 60.104a(i) § 60.104a(i)(1) § 60.104a(i)(2) § 60.104a(i)(3) § 60.104a(i)(5) § 60.104a(i)(8) § 60.107a(c) § 60.107a(c)(1) § 60.107a(c)(2) § 60.107a(c)(3) § 60.107a(c)(4) § 60.107a(c)(5) § 60.107a(i) § 60.107a(i)(3) § 60.107a(i)(3)(ii)	§ 60.108a(a) [G]§ 60.108a(d)	§ 60.108a(a) § 60.108a(b) [G]§ 60.108a(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
11-H1	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
11-H2	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
14-H1	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
14-H1	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
17-H1	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
17-INC	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
18-E22	EU	R5115D-01	VOC	30 TAC Chapter 115, Unit Turn & Vac System-Pet Ref	§ 115.317	In Gregg, Nueces and Victoria Counties, a vacuum-producing system emitting a combined weight of VOCs less than or equal to 100 lbs. in any consecutive 24-hour period is exempt from the requirements of §115.311(b).	None	None	None
18-HOTWELL	EU	R5115D-01	VOC	30 TAC Chapter 115, Unit Turn & Vac System-Pet Ref	§ 115.317	In Gregg, Nueces and Victoria Counties, a vacuum-producing system emitting a combined weight of VOCs less than or equal to 100 lbs. in any consecutive 24-hour period is exempt from the requirements of §115.311(b).	None	None	None
19-H1	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
19-H1	EU	63DDDDD-02	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.2 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7500(e) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(11) § 63.7540(a)(13)	A new or existing boiler or process heater with heat input capacity of less than 10 million Btu per hour, but greater than 5 million Btu per hour, in a unit designed to burn gas 1 must conduct a tune-up of the boiler or process heater biennially as specified in § 63.7540.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
19-H2	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
19-H2	EU	63DDDDD-01	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.1 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7500(e) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(12) § 63.7540(a)(13)	For a new or existing boiler or process heater with a heat input capacity of less than or equal to 5 million Btu per hour designed to burn gas 1, a tune-up of the boiler or process heater must be conducted every 5 years as specified in § 63.7540.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
204-U942	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
204-U942	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for flanges or other connectors.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
204-U942	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-10 for vapor recovery devices.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
204-U942	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for pressure relief devices in light-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
204-U942	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for pumps in heavy-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
204-U942	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for valves in heavy-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
204-U942	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-7 for valves in gas/vapor or light-liquid service.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(ii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
204-U942	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-6 for open-ended valves and lines.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
204-U942	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-5(a) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-5 for sampling connection systems.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
204-U942	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-4(a) § 60.482-4(b)(1) § 60.482-4(c) § 60.482-4(d)(1) § 60.482-4(d)(2) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-4 for pressure relief devices in gas/vapor service.	§ 60.482-4(b)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(3) [G]§ 60.486(e)(4) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
204-U942	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements as stated in §60.482-3 for compressors.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
204-U942	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e) § 60.593(c)	Comply with the requirements as stated in §60.482-3 for reciprocating compressors that become subject under §60.14 and §60.15.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
204-U942	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(d) § 60.486(k)	Comply with the requirements as stated in §60.482-1(d) for equipment in vacuum service.	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(6) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
204-U942	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements as stated in §60.482-2 for pumps in light-liquid service.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
207-H-1	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
21-H1A	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
21-H1B	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
23-TK0002A	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
28-H1	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
28-H3	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
29-H1 C&D	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
29-H1A	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
29-H1A	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
29-H1B	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
29-H2B	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
29-H2B	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
29-H3	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
29-TK0105	EU	63EEEE	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2338(b) The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart EEEE

29-V26	EU	63UUU-1	Hydrogen Chloride	40 CFR Part 63, Subpart UUU	§ 63.1567(a)(1)-Table 22.2 § 63.1567(a)(1) § 63.1567(a)(1)(i) § 63.1567(a)(2) § 63.1567(a)(2)-Table 23.5 § 63.1567(a)(3) § 63.1567(b)(3) § 63.1567(b)(4) § 63.1567(b)(4)(iii) § 63.1567(b)(5) § 63.1567(b)(5)-Table 26.2 § 63.1567(c)(1) § 63.1569(a)(1) § 63.1569(a)(1)(ii)-Table 36.2 § 63.1569(a)(3) § 63.1569(b)(2) § 63.1569(b)(2)-Table 38.1.b § 63.1569(c)(1) § 63.1569(c)(2) § 63.1570(a) § 63.1570(c) § 63.1570(d) § 63.1571(d) § 63.1571(d)(4) [G]§ 63.1571(e)	For each existing cyclic or continuous CRU, you must reduce uncontrolled emissions of HCl by 97 percent by weight or to a concentration of 10 ppmv (dry basis), corrected to 3% oxygen.	§ 63.1567(b)(1) § 63.1567(b)(1)-Table 24.5 § 63.1567(b)(2) § 63.1567(b)(2)-Table 25.1.a.(1) § 63.1567(b)(2)-Table 25.1.a.(2) § 63.1567(b)(2)-Table 25.1.b § 63.1567(b)(2)-Table 25.1.c § 63.1567(b)(2)-Table 25.1.d § 63.1567(b)(2)-Table 25.1.e.(1) § 63.1567(b)(2)-Table 25.1.e.(2) § 63.1567(b)(2)-Table 25.1.e.(3) § 63.1567(b)(2)-Table 25.1.e.(4) § 63.1567(b)(2)-Table 25.6.a § 63.1567(b)(2)-Table 25.6.b § 63.1567(c)(1)-Table 28.5.a § 63.1567(c)(1)-Table 28.5.b § 63.1567(c)(1)-Table 28.5.c § 63.1567(c)(2) § 63.1569(c)(1)-Table 39.2 § 63.1569(c)(1)-Table 39.5 § 63.1570(c) § 63.1570(d) § 63.1572(c)(4) § 63.1572(c)(5) [G]§ 63.1576(a) § 63.1576(d) § 63.1576(e) § 63.1576(f) § 63.1576(g) § 63.1576(h) § 63.1576(i)	§ 63.1567(b)(1)-Table 24.5 § 63.1567(b)(2)-Table 25.1.e.(2) § 63.1567(b)(2)-Table 25.1.e.(3) § 63.1567(b)(2)-Table 25.1.e.(4) § 63.1567(b)(2)-Table 25.6.a § 63.1567(b)(2)-Table 25.6.b § 63.1567(c)(1)-Table 28.5.a § 63.1567(c)(1)-Table 28.5.b § 63.1567(c)(1)-Table 28.5.c § 63.1567(c)(2) § 63.1569(c)(1)-Table 39.2 § 63.1569(c)(1)-Table 39.5 § 63.1570(c) § 63.1570(d) § 63.1572(c)(4) § 63.1572(c)(5) [G]§ 63.1576(a) § 63.1576(d) § 63.1576(e) § 63.1576(f) § 63.1576(g) § 63.1576(h) § 63.1576(i)	§ 63.1567(b)(6) § 63.1567(b)(7) § 63.1569(b)(3) § 63.1569(b)(4) § 63.1569(c)(1)-Table 39.5 § 63.1570(f) § 63.1571(a) § 63.1571(d)(4) [G]§ 63.1574(a) § 63.1574(c) § 63.1574(d) § 63.1574(d)-Table 42.1 § 63.1574(d)-Table 42.2 § 63.1574(d)-Table 42.3 § 63.1575(a) § 63.1575(a)-Table 43.1 § 63.1575(a)-Table 43.2 [G]§ 63.1575(b) [G]§ 63.1575(c) [G]§ 63.1575(d) [G]§ 63.1575(f) § 63.1575(g) § 63.1575(k) [G]§ 63.1575(k)(1) [G]§ 63.1575(l)
29-V26	EU	63UUU-1	TOC	40 CFR Part 63, Subpart UUU	§ 63.1566(a)(1)-Table 15.2 § 63.1566(a)(1) § 63.1566(a)(1)(ii) § 63.1566(a)(2)	For each new or existing catalytic reforming unit, you can elect to reduce uncontrolled emissions of TOC or nonmethane TOC	§ 63.1566(b)(1) § 63.1566(b)(2) § 63.1566(b)(2)-Table 18.2.a § 63.1566(b)(2)-	§ 63.1569(c)(1)-Table 39.2 § 63.1569(c)(1)-Table 39.5 § 63.1570(c)	§ 63.1566(b)(7) § 63.1566(b)(8) § 63.1569(b)(3) § 63.1569(b)(4) § 63.1569(c)(1)-Table

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.1566(a)(2)-Table 16.2.a § 63.1566(a)(3) § 63.1566(a)(4) § 63.1566(a)(5) § 63.1566(b)(1)-Table 17.2 § 63.1566(b)(3) § 63.1566(b)(4) § 63.1566(b)(4)(i) § 63.1566(b)(6) § 63.1566(b)(6)-Table 19.2 § 63.1566(c)(1) § 63.1566(c)(2) § 63.1569(a)(1) § 63.1569(a)(1)(ii)-Table 36.2 § 63.1569(a)(3) § 63.1569(b)(2) § 63.1569(b)(2)-Table 38.1.b § 63.1569(c)(1) § 63.1569(c)(2) § 63.1570(a) § 63.1570(c) § 63.1570(d) § 63.1571(d) § 63.1571(d)(4) [G]§ 63.1571(e)	from your process vent by 98% by weight using a control device or to a concentration of 20 ppmv (dry basis as hexane), corrected to 3% O ₂ , whichever is less stringent (Option 2). If you vent emissions to a boiler/process heater, the vent stream must be introduced into the flame zone or any other location that will achieve the percent reduction or concentration standard.	Table 18.2.b § 63.1566(b)(2)-Table 18.2.c § 63.1566(b)(2)-Table 18.2.d § 63.1566(b)(2)-Table 18.2.f § 63.1566(b)(2)-Table 18.2.h § 63.1566(c)(1)-Table 20.2 § 63.1566(c)(1)-Table 21.2.a § 63.1569(c)(1)-Table 39.2 § 63.1571(a) § 63.1571(a)(1) [G]§ 63.1571(b) § 63.1572(c) § 63.1572(c)(1) § 63.1572(c)(1)-Table 41.9 § 63.1572(c)(2) § 63.1572(c)(3) § 63.1572(c)(4) [G]§ 63.1572(d)	§ 63.1570(d) § 63.1572(c)(4) § 63.1572(c)(5) [G]§ 63.1576(a) § 63.1576(d) § 63.1576(e) § 63.1576(f) § 63.1576(g) § 63.1576(h) § 63.1576(i)	39.5 § 63.1570(f) § 63.1571(a) § 63.1571(d)(4) [G]§ 63.1574(a) § 63.1574(c) § 63.1574(d) § 63.1574(d)-Table 42.1 § 63.1574(d)-Table 42.2 § 63.1574(d)-Table 42.3 § 63.1575(a) § 63.1575(a)-Table 43.1 § 63.1575(a)-Table 43.2 [G]§ 63.1575(b) [G]§ 63.1575(c) [G]§ 63.1575(d) [G]§ 63.1575(f) § 63.1575(g) § 63.1575(k) [G]§ 63.1575(k)(1) § 63.1575(l)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
31-FCCU2	EU	60J-FCCU	CO	40 CFR Part 60, Subpart J	§ 60.103(a) § 60.103	No owner or operator subject to the provisions of this subpart shall discharge or cause the discharge into the atmosphere from any fluid catalytic cracking unit catalyst regenerator any gases that contain carbon monoxide in excess of 500 ppm by volume (dry basis).	§ 60.105(a) [G]§ 60.105(a)(2) § 60.105(c) § 60.105(e) § 60.105(e)(2) § 60.106(a) § 60.106(d)	§ 60.105(a) [G]§ 60.105(a)(2) § 60.105(c)	§ 60.105(e) § 60.105(e)(2) § 60.107(f) § 60.107(g)
31-FCCU2	EU	60J-FCCU	PM	40 CFR Part 60, Subpart J	§ 60.102(a)(1)	No owner or operator subject to the provisions of this subpart shall discharge or cause the discharge into the atmosphere from any fluid catalytic cracking unit catalyst regenerator particulate matter in excess of 1.0 kg/Mg (2.0 lb/ton) of coke burn-off in the catalyst regenerator.	§ 60.105(c) § 60.106(a) [G]§ 60.106(b)	§ 60.105(c)	None
31-FCCU2	EU	60J-FCCU	PM(OPACITY)	40 CFR Part 60, Subpart J	§ 60.102(a)(2)	No owner or operator subject to the provisions of this subpart shall discharge or cause the discharge into the atmosphere from any fluid catalytic cracking unit catalyst regenerator gases exhibiting greater than 30 percent opacity, except for one six-minute average opacity reading in any one hour period.	§ 60.105(a)(1) § 60.105(c) § 60.105(e) § 60.105(e)(1) § 60.106(a) [G]§ 60.106(b)	§ 60.105(a)(1) § 60.105(c)	§ 60.105(e) § 60.105(e)(2) § 60.107(f) § 60.107(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
31-FCCU2	EU	60J-FCCU	SO ₂	40 CFR Part 60, Subpart J	§ 60.104(b)(1) § 60.104(b) § 60.104(c) § 60.104(d)	For each affected fluid catalytic cracking unit catalyst regenerator with an add-on control device, reduce sulfur dioxide emissions to the atmosphere by 90 percent or maintain sulfur dioxide emissions to the atmosphere less than or equal to 50 ppm by volume, whichever is less stringent	§ 60.105(a) § 60.105(a)(10) § 60.105(a)(11) [G]§ 60.105(a)(12) [G]§ 60.105(a)(13) [G]§ 60.105(a)(9) § 60.106(a) § 60.106(g) [G]§ 60.106(h) [G]§ 60.106(k) § 60.108(a) § 60.108(c) § 60.108(d) § 60.108(e)	§ 60.105(a) § 60.105(a)(10) § 60.105(a)(11) [G]§ 60.105(a)(13) [G]§ 60.105(a)(9) § 60.107(b) [G]§ 60.107(b)(1) § 60.107(b)(4)	§ 60.107(a) § 60.107(c) [G]§ 60.107(c)(1) § 60.107(c)(2) [G]§ 60.107(c)(3) [G]§ 60.107(c)(4) § 60.107(d) § 60.107(f) § 60.107(g)
31-FCCU2	EU	63UUU-1	CO	40 CFR Part 63, Subpart UUU	§ 63.1565(a)(1)-Table 8.1 § 63.1565(a)(1) § 63.1565(a)(2) § 63.1565(a)(2)-Table 9.1 § 63.1565(a)(2)-Table 9.3 § 63.1565(a)(3) § 63.1565(a)(4) § 63.1565(a)(5) § 63.1565(b)(4) § 63.1565(b)(4)-Table 12.1 § 63.1565(c)(1) § 63.1565(c)(2) § 63.1570(a) § 63.1570(c) § 63.1570(d)	For each new and existing CCU subject to the NSPS for CO in 40 CFR §60.103 or §60.102a(b)(4) or electing to comply with the NSPS requirements (Option 1), CO emissions from the catalyst regenerator vent or CO boiler serving the CCU must not exceed 500 parts per million volume (ppmv) (dry basis).	§ 63.1565(b)(1) § 63.1565(b)(1)-Table 10.1 § 63.1565(b)(1)-Table 10.3 § 63.1565(c)(1)-Table 13.1 § 63.1565(c)(1)-Table 14.1 § 63.1565(c)(1)-Table 14.3 § 63.1571(a) § 63.1571(a)(1) § 63.1571(a)(2) [G]§ 63.1571(a)(6) § 63.1572(a) § 63.1572(a)(1) § 63.1572(a)(1)-Table 40.3 § 63.1572(a)(2) § 63.1572(a)(3) § 63.1572(a)(4) [G]§ 63.1572(d)	§ 63.1565(b)(1)-Table 10.1 § 63.1565(c)(1)-Table 14.3 § 63.1570(c) § 63.1570(d) [G]§ 63.1576(a) [G]§ 63.1576(b) § 63.1576(d) § 63.1576(e) § 63.1576(f) § 63.1576(g) § 63.1576(h) § 63.1576(i)	§ 63.1565(b)(5) § 63.1565(b)(6) § 63.1570(f) § 63.1571(a) [G]§ 63.1574(a) § 63.1574(d) § 63.1574(d)-Table 42.1 § 63.1574(d)-Table 42.2 § 63.1574(d)-Table 42.3 § 63.1575(a) § 63.1575(a)-Table 43.1 [G]§ 63.1575(b) [G]§ 63.1575(c) [G]§ 63.1575(e) [G]§ 63.1575(f) § 63.1575(g) [G]§ 63.1575(h) [G]§ 63.1575(i) § 63.1575(k) § 63.1575(k)(1) [G]§ 63.1575(k)(2) § 63.1575(l) § 63.1576(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
31-FCCU2	EU	63UUU-1	PM	40 CFR Part 63, Subpart UUU	§ 63.1564(a)(1)-Table 1.2 § 63.1564(a)(1) § 63.1564(a)(2) § 63.1564(a)(2)-Table 2.10 § 63.1564(a)(2)-Table 2.2.b § 63.1564(a)(3) § 63.1564(a)(4) [G]§ 63.1564(a)(5) § 63.1564(b)(3) § 63.1564(b)(5) § 63.1564(b)(5)-Table 5.2 § 63.1564(c)(1) § 63.1564(c)(1)-Table 7.10 [G]§ 63.1564(c)(5) § 63.1570(a) § 63.1570(c) § 63.1570(d)	For each new or existing CCU subject to NSPS for PM in 40 CFR §60.102a(b)(1)(i) or §60.102 and electing §60.100(e), PM emissions must not exceed 1.0 g/kg (1.0 lb/1,000 lbs) of coke burn-off.	§ 63.1564(b)(1) § 63.1564(b)(1)-Table 3.12 § 63.1564(b)(1)-Table 3.2.b § 63.1564(b)(2) [G]§ 63.1564(b)(2)-Table 4.1 § 63.1564(b)(2)-Table 4.3.b § 63.1564(b)(2)-Table 4.3.c § 63.1564(c)(1)-Table 6.2 § 63.1564(c)(1)-Table 7.2.a § 63.1571(a) § 63.1571(a)(1) § 63.1571(a)(5) [G]§ 63.1571(b) § 63.1572(a)(1)-Table 40.1 § 63.1572(a)(4) § 63.1572(b) § 63.1572(b)(1) § 63.1572(b)(3) [G]§ 63.1572(d)	§ 63.1564(b)(1)-Table 3.12 § 63.1564(b)(1)-Table 3.2.b § 63.1564(c)(1)-Table 6.2 § 63.1564(c)(1)-Table 7.2.a § 63.1564(c)(2) § 63.1570(c) § 63.1570(d) [G]§ 63.1576(a) § 63.1576(d) § 63.1576(e) § 63.1576(f) § 63.1576(g) § 63.1576(h) § 63.1576(i)	§ 63.1564(b)(6) § 63.1564(b)(7) § 63.1570(f) § 63.1571(a) [G]§ 63.1574(a) § 63.1574(c) § 63.1574(d) § 63.1574(d)-Table 42.1 § 63.1574(d)-Table 42.2 § 63.1574(d)-Table 42.3 § 63.1575(a) § 63.1575(a)-Table 43.1 § 63.1575(a)-Table 43.2 [G]§ 63.1575(b) [G]§ 63.1575(c) [G]§ 63.1575(e) [G]§ 63.1575(f) § 63.1575(g) [G]§ 63.1575(i) § 63.1575(k) [G]§ 63.1575(k)(1) [G]§ 63.1575(l) [G]§ 63.1576(b)
31-PR-1	EP	111-VENT02	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(C) § 111.111(a)(1)(E) § 111.111(a)(2)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	§ 111.111(a)(1)(D) [G]§ 111.111(a)(1)(F) § 111.111(a)(2)	§ 111.111(a)(1)(C) § 111.111(a)(1)(D)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-H1	EU	60Ja-1	Hydrogen Sulfide	40 CFR Part 60, Subpart Ja	§ 60.102a(g)(1)(ii) § 60.102a(a) § 60.102a(g) § 60.102a(g)(1) § 60.103a(c) § 60.103a(d) § 60.103a(d)(1) § 60.103a(d)(5) [G]§ 60.103a(e)	For each fuel gas combustion device the owner or operator shall not burn in any fuel gas combustion device any fuel gas that contains H ₂ S in excess of 162 ppmv determined hourly on a 3-hour rolling average basis and H ₂ S in excess of 60 ppmv determined daily on a 365 successive calendar day rolling average basis.	§ 60.104a(a) § 60.104a(c) [G]§ 60.104a(j) § 60.107a(a) § 60.107a(a)(2) § 60.107a(a)(2)(i) § 60.107a(a)(2)(ii) § 60.107a(a)(2)(iii) § 60.107a(a)(2)(iv) § 60.107a(i) § 60.107a(i)(1)(ii)	§ 60.108a(a) § 60.108a(c) [G]§ 60.108a(c)(6) [G]§ 60.108a(d)	§ 60.108a(a) § 60.108a(b) [G]§ 60.108a(d)
41-H1	EU	60Ja-2	Hydrogen Sulfide	40 CFR Part 60, Subpart Ja	§ 60.102a(g)(1)(ii) § 60.102a(a) § 60.102a(g) § 60.102a(g)(1) § 60.103a(c) § 60.103a(d) § 60.103a(d)(1) § 60.103a(d)(5) [G]§ 60.103a(e) [G]§ 60.107a(b)	For each fuel gas combustion device the owner or operator shall not burn in any fuel gas combustion device any fuel gas that contains H ₂ S in excess of 162 ppmv determined hourly on a 3-hour rolling average basis and H ₂ S in excess of 60 ppmv determined daily on a 365 successive calendar day rolling average basis.	§ 60.104a(a) § 60.104a(c) [G]§ 60.104a(j) § 60.107a(a)(2)(iv) [G]§ 60.107a(a)(3) § 60.107a(a)(4) § 60.107a(i) § 60.107a(i)(1)(ii) § 60.107a(i)(1)(iii)	§ 60.108a(a) § 60.108a(c) [G]§ 60.108a(c)(6) [G]§ 60.108a(d)	§ 60.108a(a) § 60.108a(b) [G]§ 60.108a(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-H1	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
41-H2	EU	60Ja-1	Hydrogen Sulfide	40 CFR Part 60, Subpart Ja	§ 60.102a(g)(1)(ii) § 60.102a(a) § 60.102a(g) § 60.102a(g)(1) § 60.103a(c) § 60.103a(d) § 60.103a(d)(1) § 60.103a(d)(5) [G]§ 60.103a(e)	For each fuel gas combustion device the owner or operator shall not burn in any fuel gas combustion device any fuel gas that contains H ₂ S in excess of 162 ppmv determined hourly on a 3-hour rolling average basis and H ₂ S in excess of 60 ppmv determined daily on a 365 successive calendar day rolling average basis.	§ 60.104a(a) § 60.104a(c) [G]§ 60.104a(j) § 60.107a(a) § 60.107a(a)(2) § 60.107a(a)(2)(i) § 60.107a(a)(2)(ii) § 60.107a(a)(2)(iii) § 60.107a(a)(2)(iv) § 60.107a(i) § 60.107a(i)(1)(ii)	§ 60.108a(a) § 60.108a(c) [G]§ 60.108a(c)(6) [G]§ 60.108a(d)	§ 60.108a(a) § 60.108a(b) [G]§ 60.108a(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-H2	EU	60Ja-2	Hydrogen Sulfide	40 CFR Part 60, Subpart Ja	§ 60.102a(g)(1)(ii) § 60.102a(a) § 60.102a(g) § 60.102a(g)(1) § 60.103a(c) § 60.103a(d) § 60.103a(d)(1) § 60.103a(d)(5) [G]§ 60.103a(e) [G]§ 60.107a(b)	For each fuel gas combustion device the owner or operator shall not burn in any fuel gas combustion device any fuel gas that contains H ₂ S in excess of 162 ppmv determined hourly on a 3-hour rolling average basis and H ₂ S in excess of 60 ppmv determined daily on a 365 successive calendar day rolling average basis.	§ 60.104a(a) § 60.104a(c) [G]§ 60.104a(j) § 60.107a(a)(2)(iv) [G]§ 60.107a(a)(3) § 60.107a(a)(4) § 60.107a(i) § 60.107a(i)(1)(iii) § 60.107a(i)(1)(iii)	§ 60.108a(a) § 60.108a(c) [G]§ 60.108a(c)(6) [G]§ 60.108a(d)	§ 60.108a(a) § 60.108a(b) [G]§ 60.108a(d)
41-H2	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
41-U41	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(d) § 60.485a(b) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-1a(d) for equipment in vacuum service.	[G]§ 60.485a(b)(1) § 60.485a(b)(2)	§ 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) § 60.486a(e)(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-2a(b)(1) § 60.482-2a(b)(2) § 60.482-2a(b)(2)(ii) § 60.482-2a(c)(1) [G]§ 60.482-2a(c)(2) § 60.482-2a(d) [G]§ 60.482-2a(d)(1) § 60.482-2a(d)(2) § 60.482-2a(d)(3) [G]§ 60.482-2a(d)(6) [G]§ 60.482-2a(e) § 60.482-2a(f) [G]§ 60.482-2a(g) § 60.482-2a(h) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(d) § 60.482-9a(f) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-2a for pumps in light liquid service.	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3) § 60.482-1a(g) § 60.482-2a(a)(1) § 60.482-2a(a)(2) § 60.482-2a(b)(2)(i) [G]§ 60.482-2a(d)(4) [G]§ 60.482-2a(d)(5) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) § 60.486a(e)(7) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) [G]§ 60.486a(h)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(3) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(iii) § 60.487a(c)(2)(iv) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) [G]§ 60.482-2a(c)(2) [G]§ 60.482-7a(e) § 60.482-8a(a) § 60.482-8a(a)(2) § 60.482-8a(b) [G]§ 60.482-8a(c) § 60.482-8a(d) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(d) § 60.482-9a(f) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-8a for pumps in heavy liquid service.	§ 60.482-1a(g) § 60.482-8a(a)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.593a(b)(1)	Compressors in hydrogen service are exempt from the requirements of §60.592a if an owner or operator demonstrates that a compressor is in hydrogen service.	§ 60.593a(b)(2) [G]§ 60.593a(b)(3)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-3a(a) [G]§ 60.482-3a(b) § 60.482-3a(c) § 60.482-3a(d) § 60.482-3a(e)(2) § 60.482-3a(f) [G]§ 60.482-3a(g) § 60.482-3a(h) [G]§ 60.482-3a(i) § 60.482-3a(j) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e) § 60.593a(c)	Comply with the requirements as stated in §60.482-3a for reciprocating compressors that become subject under §60.14 and §60.15.	§ 60.482-1a(g) § 60.482-3a(e)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) [G]§ 60.486a(h)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(4) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(v) § 60.487a(c)(2)(vi) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-3a(a) [G]§ 60.482-3a(b) § 60.482-3a(c) § 60.482-3a(d) § 60.482-3a(e)(2) § 60.482-3a(f) [G]§ 60.482-3a(g) § 60.482-3a(h) [G]§ 60.482-3a(i) § 60.482-3a(j) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-3a for compressors.	§ 60.482-1a(g) § 60.482-3a(e)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) [G]§ 60.486a(h)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(4) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(v) § 60.487a(c)(2)(vi) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-4a(a) § 60.482-4a(b)(1) § 60.482-4a(b)(2) § 60.482-4a(c) § 60.482-4a(d)(1) § 60.482-4a(d)(2) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-4a for pressure relief devices in gas/vapor service.	§ 60.482-1a(g) § 60.482-4a(b)(2) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) § 60.486a(e)(10) § 60.486a(e)(3) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) [G]§ 60.482-2a(c)(2) [G]§ 60.482-7a(e) § 60.482-8a(a) § 60.482-8a(a)(2) § 60.482-8a(b) [G]§ 60.482-8a(c) § 60.482-8a(d) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-8a for pressure relief devices in light liquid service.	§ 60.482-1a(g) § 60.482-8a(a)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-5a(a) [G]§ 60.482-5a(b) § 60.482-5a(c) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-5a for sampling connection systems.	§ 60.482-1a(g) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.593a(f) § 60.482-1a(a) § 60.482-1a(g)	Open-ended valves or lines containing asphalt as defined in (§60.591a are exempt from the requirements of §60.482-6a(a) through (c).	§ 60.482-1a(g) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d)	§ 60.482-1a(g) § 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-6a(a)(1) § 60.482-6a(a)(2) § 60.482-6a(b) § 60.482-6a(c) § 60.482-6a(d) § 60.482-6a(e) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-6a for open-ended valves and lines.	§ 60.482-1a(g) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-7a(a)(1) § 60.482-7a(b) [G]§ 60.482-7a(d) [G]§ 60.482-7a(e) [G]§ 60.482-7a(f) [G]§ 60.482-7a(g) [G]§ 60.482-7a(h) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(c) § 60.482-9a(e) § 60.482-9a(f) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-7a for valves in gas/vapor or light liquid service.	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3) § 60.482-1a(g) § 60.482-7a(a)(1) [G]§ 60.482-7a(a)(2) [G]§ 60.482-7a(c) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) § 60.486a(f)(2)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(2) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(i) § 60.487a(c)(2)(ii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) [G]§ 60.482-2a(c)(2) [G]§ 60.482-7a(e) § 60.482-8a(a) § 60.482-8a(a)(2) § 60.482-8a(b) [G]§ 60.482-8a(c) § 60.482-8a(d) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(c) § 60.482-9a(e) § 60.482-9a(f) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-8a for valves in heavy liquid service.	§ 60.482-1a(g) § 60.482-8a(a)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) [G]§ 60.482-2a(c)(2) [G]§ 60.482-7a(e) § 60.482-8a(a) § 60.482-8a(a)(2) § 60.482-8a(b) [G]§ 60.482-8a(c) § 60.482-8a(d) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(c) § 60.482-9a(f) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-8a for connectors in heavy liquid service.	§ 60.482-1a(g) § 60.482-8a(a)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) [G]§ 60.482-2a(c)(2) [G]§ 60.482-7a(e) § 60.482-8a(a) § 60.482-8a(a)(2) § 60.482-8a(b) [G]§ 60.482-8a(c) § 60.482-8a(d) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-8a for pressure relief devices in heavy liquid service.	§ 60.482-1a(g) § 60.482-8a(a)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-10a(a) [G]§ 60.482-10a(f) [G]§ 60.482-10a(g) § 60.482-10a(h) § 60.482-10a(i) [G]§ 60.482-10a(j) [G]§ 60.482-10a(k) § 60.482-10a(m) § 60.485a(b) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-10a for closed-vent systems.	§ 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) § 60.593a(d)	[G]§ 60.482-10a(l) § 60.485a(b)(2) [G]§ 60.486a(d) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-10a(a) § 60.482-10a(b) § 60.482-10a(m) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-10a for vapor recovery systems.	§ 60.482-10a(e) § 60.482-1a(g) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.18 § 60.482-10a(a) § 60.482-10a(d) § 60.482-10a(m) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-10a for flares.	§ 60.482-10a(e) § 60.482-1a(g) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) [G]§ 60.485a(g) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	60GGGA-ALL	VOC	40 CFR Part 60, Subpart GGGa	§ 60.593a(g) § 60.482-11a(b)(2) § 60.482-11a(b)(3) § 60.482-11a(d) [G]§ 60.482-11a(e) [G]§ 60.482-11a(f)(1) § 60.482-11a(f)(2) § 60.482-11a(g) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(c) § 60.482-9a(f) § 60.485a(b) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Connectors in gas/vapor or light liquid service are exempt from the requirements in §60.482-11a, provided the owner or operator complies with §60.482-8a for all connectors, not just those in heavy liquid service.	§ 60.482-11a(a) § 60.482-11a(b) § 60.482-11a(b)(1) § 60.482-11a(b)(3) § 60.482-11a(b)(3)(i) § 60.482-11a(b)(3)(ii) [G]§ 60.482-11a(b)(3)(iii) § 60.482-11a(b)(3)(iv) § 60.482-11a(c) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-11a(b)(3)(v) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8) § 60.486a(e)(9) § 60.486a(f) § 60.486a(f)(1)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(5) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(i) § 60.487a(c)(2)(vii) § 60.487a(c)(2)(viii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)
41-U41	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-10(f) [G]§ 60.482-10(g) § 60.482-10(h) § 60.482-10(i) [G]§ 60.482-10(j) [G]§ 60.482-10(k) § 60.482-10(m) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for closed vent (or vapor collection) systems complying with §60.482-10.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.482-10(l) [G]§ 60.486(a) [G]§ 60.486(d) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pressure relief devices in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
41-U41	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for flanges or other connectors complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
41-U41	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-10(b) § 60.482-10(m) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for vapor recovery systems complying with §60.482-10.	§ 60.482-10(e) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(d) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
41-U41	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	[G]§ 63.648(g) § 63.642(b) § 63.642(n)	Compressors in hydrogen service are exempt from the requirements of §63.648(a) and (c) if an owner or operator demonstrates that a compressor is in hydrogen service. §63.648(g)(1)-(2).	[G]§ 63.648(g)	§ 63.648(h) § 63.655(d)(3) § 63.655(i)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(d) § 60.486(k) § 63.642(b) § 63.642(n)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for equipment in vacuum service.	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(5) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
41-U41	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-2(b)(1) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(f)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in light liquid service complying with §60.482-2.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) § 60.486(f) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(i)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for compressors complying with §60.482-3.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
41-U41	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-5(a) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for sampling connection systems complying with §60.482-5.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for open-ended valves or lines complying with §60.482-6.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
41-U41	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in gas/vapor service or in light liquid service complying with §60.482-7.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(iii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(d) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
41-U41	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
44-V10	EP	R5VT-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(b)(2)(A) § 115.127(b)(2)	A vent gas stream having a combined weight of the VOC or classes of compounds specified in §115.121(b)(2) and (3) of this title equal to or less than 100 pounds in any continuous 24-hour period is exempt from the requirements of §115.121(b) of this title.	[G]§ 115.125 § 115.126(2) § 115.126(3)(B)	§ 115.126 § 115.126(2) § 115.126(3) § 115.126(3)(B)	None
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
46-U46	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
47-TK0103	EU	115-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(4) § 115.118(b)(5)	None
47-TK0103	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
47-U47	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
47-U47	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for flanges or other connectors.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
47-U47	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-10 for vapor recovery devices.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
47-U47	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for pressure relief devices in light-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
47-U47	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for pumps in heavy-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
47-U47	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for valves in heavy-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
47-U47	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-7 for valves in gas/vapor or light-liquid service.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(ii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
47-U47	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(d) § 60.486(k)	Comply with the requirements as stated in §60.482-1(d) for equipment in vacuum service.	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(6) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
47-U47	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-5(a) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-5 for sampling connection systems.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
47-U47	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-4(a) § 60.482-4(b)(1) § 60.482-4(c) § 60.482-4(d)(1) § 60.482-4(d)(2) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-4 for pressure relief devices in gas/vapor service.	§ 60.482-4(b)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(3) [G]§ 60.486(e)(4) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
47-U47	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements as stated in §60.482-3 for compressors.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
47-U47	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e) § 60.593(c)	Comply with the requirements as stated in §60.482-3 for reciprocating compressors that become subject under §60.14 and §60.15.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
47-U47	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements as stated in §60.482-2 for pumps in light-liquid service.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
47-U47	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-6 for open-ended valves and lines.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
51-TK0001	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52AMNE	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52AMNE	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-2(b)(1) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(f)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in light liquid service complying with §60.482-2.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) § 60.486(f) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
52-U52AMNE	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(d) § 60.486(k) § 63.642(b) § 63.642(n)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for equipment in vacuum service.	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(5) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52AMNE	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	[G]§ 63.648(g) § 63.642(b) § 63.642(n)	Compressors in hydrogen service are exempt from the requirements of §63.648(a) and (c) if an owner or operator demonstrates that a compressor is in hydrogen service. §63.648(g)(1)-(2).	[G]§ 63.648(g)	§ 63.648(h) § 63.655(d)(3) § 63.655(i)	None
52-U52AMNE	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-10(b) § 60.482-10(m) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for vapor recovery systems complying with §60.482-10.	§ 60.482-10(e) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(d) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
52-U52AMNE	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for flanges or other connectors complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52AMNE	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pressure relief devices in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
52-U52AMNE	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-10(f) [G]§ 60.482-10(g) § 60.482-10(h) § 60.482-10(i) [G]§ 60.482-10(j) [G]§ 60.482-10(k) § 60.482-10(m) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for closed vent (or vapor collection) systems complying with §60.482-10.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.482-10(l) [G]§ 60.486(a) [G]§ 60.486(d) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52AMNE	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
52-U52AMNE	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in gas/vapor service or in light liquid service complying with §60.482-7.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(iii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(d) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52AMNE	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for open-ended valves or lines complying with §60.482-6.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
52-U52AMNE	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-5(a) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for sampling connection systems complying with §60.482-5.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52AMNE	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(i)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for compressors complying with §60.482-3.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52AMNE	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
52-U52SRU	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
53-U53	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
54-TK0001	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
54-TK0001	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3) § 60.116b(f)(1) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
54-TK3	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
54-TK3	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
54-TK3	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(iii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) [G]§ 60.116b(e)(3) § 60.116b(f)(1) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
56-U56	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-D7	EU	63CC-LOAD	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.651(a) § 63.642(b) § 63.642(n)	Except as provided in §63.651(b)-(e), each owner or operator of a marine tank vessel loading operation located at a petroleum refinery shall comply with the requirements of §§63.560 through 63.568.	§ 63.642(d)(1) § 63.642(d)(3) § 63.642(d)(4)	§ 63.642(d)(3) § 63.655(c) § 63.655(i) § 63.655(i)(6)	§ 63.642(d)(2) § 63.642(f) § 63.655(c)
57-D7	EU	63Y-LOAD03	112(B) HAPS	40 CFR Part 63, Subpart Y	§ 63.562(b) [G]§ 63.562(b)(1) § 63.562(b)(2) [G]§ 63.562(b)(6) § 63.562(e) § 63.562(e)(1) [G]§ 63.562(e)(2) [G]§ 63.562(e)(3) § 63.562(e)(4) § 63.562(e)(5) § 63.562(e)(6) § 63.562(e)(7) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.563(a)(2) § 63.563(a)(3)	Marine tank vessel loading operations shall apply MACT standards, except for the VMT source.	[G]§ 63.562(b)(6) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.563(b) § 63.563(b)(1) § 63.563(b)(10) § 63.563(b)(3) § 63.563(b)(4) § 63.563(b)(4)(ii) [G]§ 63.563(c) § 63.564(a)(2) § 63.564(a)(3) § 63.564(a)(4) § 63.564(c) § 63.564(e)(2) § 63.564(e)(4) [G]§ 63.565(b) [G]§ 63.565(d) § 63.565(f) § 63.565(f)(1) § 63.565(l) [G]§ 63.565(m)	[G]§ 63.562(b)(6) § 63.562(e)(5) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.564(e)(2) [G]§ 63.565(d) § 63.567(f) [G]§ 63.567(g) § 63.567(j)(1) § 63.567(j)(2) [G]§ 63.567(k)	[G]§ 63.562(b)(6) § 63.562(e)(7)(ii) [G]§ 63.567(b)(2) § 63.567(b)(3) [G]§ 63.567(b)(4) § 63.567(b)(5)(ii) § 63.567(c) § 63.567(e)(1) [G]§ 63.567(e)(2) § 63.567(e)(3) § 63.567(e)(4) § 63.567(e)(5) § 63.567(e)(6) § 63.567(f) § 63.567(j)(3) § 63.567(m) § 63.567(n)(1) § 63.567(n)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-D7	EU	63Y-LOAD03	VOC	40 CFR Part 63, Subpart Y	§ 63.562(c) [G]§ 63.562(c)(2) § 63.562(c)(3) § 63.562(c)(4) [G]§ 63.562(c)(6) § 63.562(e) § 63.562(e)(1) [G]§ 63.562(e)(2) [G]§ 63.562(e)(3) § 63.562(e)(4) § 63.562(e)(5) § 63.562(e)(6) § 63.562(e)(7) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.563(a)(2) § 63.563(a)(3)	Marine tank vessel loading operations shall apply RACT standards, except for the VMT source.	[G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.563(b) § 63.563(b)(1) § 63.563(b)(3) § 63.563(b)(4) § 63.563(b)(4)(iii) [G]§ 63.563(c) § 63.564(a)(2) § 63.564(a)(3) § 63.564(a)(4) § 63.564(c) § 63.564(e)(2) § 63.564(e)(4) [G]§ 63.565(b) [G]§ 63.565(d) § 63.565(f) § 63.565(f)(1) § 63.565(l)	§ 63.562(e)(5) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.564(e)(2) [G]§ 63.565(d) [G]§ 63.565(m) § 63.567(f) [G]§ 63.567(g) [G]§ 63.567(k)	§ 63.562(c)(1) § 63.562(e)(7)(ii) [G]§ 63.567(b)(2) § 63.567(b)(3) [G]§ 63.567(b)(4) § 63.567(c) § 63.567(e)(1) [G]§ 63.567(e)(2) § 63.567(e)(3) § 63.567(e)(4) § 63.567(e)(5) § 63.567(e)(6) § 63.567(f) § 63.567(m) § 63.567(n)(1) § 63.567(n)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-D7	EU	63Y-LOAD04	112(B) HAPS	40 CFR Part 63, Subpart Y	§ 63.562(b) [G]§ 63.562(b)(1) § 63.562(b)(2) [G]§ 63.562(b)(6) § 63.562(e) § 63.562(e)(1) [G]§ 63.562(e)(2) [G]§ 63.562(e)(3) § 63.562(e)(4) § 63.562(e)(5) § 63.562(e)(6) § 63.562(e)(7) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.563(a)(2) § 63.563(a)(3)	Marine tank vessel loading operations shall apply MACT standards, except for the VMT source.	[G]§ 63.562(b)(6) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.563(b) § 63.563(b)(1) § 63.563(b)(10) § 63.563(b)(3) § 63.563(b)(4) § 63.563(b)(4)(ii) [G]§ 63.563(c) § 63.564(a)(2) § 63.564(a)(3) § 63.564(a)(4) § 63.564(c) § 63.564(e)(2) § 63.564(e)(4) [G]§ 63.565(b) [G]§ 63.565(d) § 63.565(f) § 63.565(f)(1) § 63.565(l) [G]§ 63.565(m)	[G]§ 63.562(b)(6) § 63.562(e)(5) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.564(e)(2) [G]§ 63.565(d) § 63.567(f) [G]§ 63.567(g) § 63.567(j)(1) § 63.567(j)(2) [G]§ 63.567(k)	[G]§ 63.562(b)(6) § 63.562(e)(7)(ii) [G]§ 63.567(b)(2) § 63.567(b)(3) [G]§ 63.567(b)(4) § 63.567(b)(5)(ii) § 63.567(c) § 63.567(e)(1) [G]§ 63.567(e)(2) § 63.567(e)(3) § 63.567(e)(4) § 63.567(e)(5) § 63.567(e)(6) § 63.567(f) § 63.567(j)(3) § 63.567(m) § 63.567(n)(1) § 63.567(n)(2)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD1	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
57-UD1	EU	61J-ALL	Benzene	40 CFR Part 61, Subpart J	§ 61.112(a) § 61.112(b)	Each owner or operator subject to this subpart shall comply with the requirements of 40 CFR 61, Subpart V - National Emission Standard for Equipment Leaks (Fugitive Emission Sources).	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UD1	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-6 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for open-ended valves or lines. §61.242-6(a)-(c)	[G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
57-UD1	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-7 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10 [G]§ 61.243-1 [G]§ 61.243-2	Comply with standards for valves. §61.242-7(a)-(h)	[G]§ 61.242-7 [G]§ 61.243-1 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(f) [G]§ 61.246(g) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) § 61.247(d) [G]§ 61.247(e)
57-UD1	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-8 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for pressure relief devices in liquid service. § 61.242-8(a)-(d)	[G]§ 61.242-8 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
57-UD1	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	§ 61.242-9 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d)	Each product accumulator vessel shall be equipped with a closed-vent system to capture and transport any leakage from the vessel to a control device as in §61.242-11, except in §61.242-1(c).	[G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
57-UD1	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	§ 61.242-1(e)	Equipment that is in vacuum service is excluded from the requirements of §61.242-2 to §61.242-11, if it is identified as required in §61.246(e)(5).	None	[G]§ 61.246(e)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UD1	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-4 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for pressure relief devices in gas/vapor service. §61.242-4(a)-(c)	[G]§ 61.242-4 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
57-UD1	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-3 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for compressors. §61.242-3(a)-(i)	[G]§ 61.242-3 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(h) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
57-UD1	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-2 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for pumps. §61.242-2(a)-(g)	[G]§ 61.242-2 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(h) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
57-UD1	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-5 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for sampling connection systems. §61.242-5(a)-(c)	[G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
57-UD1	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-8 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for flanges and other connectors. § 61.242-8(a)-(d)	[G]§ 61.242-8 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UD2	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
57-UDMEC	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
57-UDMEC	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-6(a)(1) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k)	Each open-ended valve or line shall be equipped with a cap, blind flange, plug, or a second valve, except as provided in §60.482-1(c) and paragraphs (d) and (e) of this section.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UDMEC	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	[G]§ 60.482-1(e) § 60.486(k)	Equipment that an owner or operator designates as being in VOC service less than 300 hours (hr)/yr is excluded from the requirements of §§ 60.482-2 through 60.482-10 if it is identified as required in §60.486(e)(6) and it meets any of the conditions specified in paragraphs (e)(1) through (3) of this section. §60.482-1(e)(1)-(3)	None	§ 60.486 [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(6) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
57-UDMEC	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-5(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k)	Each sampling connection system shall be equipped with a closed-purge, closed-loop, or closed-vent system, except as provided in §60.482-1(c) and paragraph (c) of this section.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
57-UDMEC	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-4(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-4(b)(1) § 60.482-4(c) § 60.482-4(d)(1) § 60.482-4(d)(2) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	Except during pressure releases, each pressure relief device in gas/vapor service shall be operated with no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as determined by the methods specified in § 60.485(c).	§ 60.482-4(b)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(3) [G]§ 60.486(e)(4) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
57-UDMEC	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-1(d) § 60.486(k)	Equipment that is in vacuum service is excluded from the requirements of §60.482-2 to §60.482-10, if it is identified as required in §60.486(e)(5).	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(5) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UDMEC	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-2(b)(1) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k)	If an instrument reading of 10,000 ppm or greater is measured for pumps in light liquid service, a leak is detected.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UDMEC	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-3(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	Each compressor shall be equipped with a seal system that includes a barrier fluid system and that prevents leakage of VOC to the atmosphere, except as provided in §60.482-1(c) and paragraphs (h), (i), and (j) of this section.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
57-UDMEC	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-8(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k)	For pumps in heavy liquid service, if an instrument reading of 10,000 ppm or greater is measured, a leak is detected.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UDMEC	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-8(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	For pressure relief devices in light liquid or in heavy liquid service, if an instrument reading of 10,000 ppm or greater is measured, a leak is detected.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
57-UDMEC	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-8(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k)	For valves in heavy liquid service, if an instrument reading of 10,000 ppm or greater is measured, a leak is detected.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-UDMEC	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-7(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k)	If an instrument reading of 10,000 ppm or greater is measured for valves in gas/vapor service and in light liquid service, a leak is detected.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(ii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
57-UDMEC	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-8(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	For flanges and other connectors, if an instrument reading of 10,000 ppm or greater is measured, a leak is detected.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
57-VC2D7	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
61-B3E	EU	60DB-BOIL01	NO _x	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
61-B3E	EU	60DB-BOIL01	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
61-B3E	EU	60DB-BOIL01	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
61-B3E	EU	60DB-BOIL01	SO ₂	40 CFR Part 60, Subpart Db	§ 60.104(a)(1) § 60.104	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from this paragraph.	§ 60.105(a) § 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.105(e) § 60.105(e)(3)(ii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4)	§ 60.105(e) § 60.105(e)(3)(ii) § 60.107(e) § 60.107(f)
61-B3E	EU	60DB-BOIL02	NO _x	40 CFR Part 60, Subpart Db	§ 60.44b(a)(1)(ii) § 60.44b(h) § 60.44b(i) § 60.46b(a)	Except as in §60.44b(k), (l), on/after §60.8 test, no facility combusting natural gas and distillate oil (high heat release rate) shall discharge gases containing NO _x in excess of 86 ng/J heat input.	§ 60.46b(c) § 60.46b(e) § 60.46b(e)(1) § 60.46b(e)(4) [G]§ 60.48b(b) § 60.48b(c) § 60.48b(d) § 60.48b(e) [G]§ 60.48b(e)(2) § 60.48b(e)(3) § 60.48b(f) § 60.48b(g)(1)	[G]§ 60.48b(b) § 60.48b(c) [G]§ 60.49b(d) [G]§ 60.49b(g) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3) § 60.49b(b) § 60.49b(h) § 60.49b(h)(4) § 60.49b(i) § 60.49b(v) § 60.49b(w)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
61-B3E	EU	60DB-BOIL02	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
61-B3E	EU	60DB-BOIL02	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
61-B3E	EU	60DB-BOIL02	SO ₂	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
61-B3E	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
61-B3E	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
64-TK0013	EU	115TK-03	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(4) § 115.118(b)(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-FLR442	EU	111-FLARE02	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
73-FLR442	EU	60Ja-1	Hydrogen Sulfide	40 CFR Part 60, Subpart Ja	§ 60.103a(h) [G]§ 60.103a(a) [G]§ 60.103a(b) § 60.103a(c) [G]§ 60.103a(c)(1) § 60.103a(d) § 60.103a(d)(1) § 60.103a(d)(2) § 60.103a(d)(3) § 60.103a(d)(5) [G]§ 60.103a(e)	Each owner or operator shall not burn in any affected flare any fuel gas that contains H2S in excess of 162 ppmv determined hourly on a 3-hour rolling average basis. The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from this limit.	[G]§ 60.103a(a) § 60.104a(a) § 60.104a(c) [G]§ 60.104a(j) § 60.107a(a) § 60.107a(a)(2) § 60.107a(a)(2)(i) § 60.107a(a)(2)(ii) § 60.107a(a)(2)(iii) § 60.107a(a)(2)(iv) § 60.107a(a)(2)(v) § 60.107a(e) [G]§ 60.107a(e)(1) [G]§ 60.107a(e)(2) § 60.107a(e)(3) [G]§ 60.107a(f) § 60.107a(i) § 60.107a(i)(2)(i)	§ 60.108a(c) § 60.108a(c)(1) [G]§ 60.108a(c)(6) [G]§ 60.108a(d)	[G]§ 60.103a(b) [G]§ 60.108a(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-FLR442	EU	60Ja-2	Hydrogen Sulfide	40 CFR Part 60, Subpart Ja	§ 60.103a(h) [G]§ 60.103a(a) [G]§ 60.103a(b) § 60.103a(c) [G]§ 60.103a(c)(1) § 60.103a(d) § 60.103a(d)(1) § 60.103a(d)(2) § 60.103a(d)(3) § 60.103a(d)(5) [G]§ 60.103a(e) [G]§ 60.107a(b) [G]§ 60.107a(e)(4)	Each owner or operator shall not burn in any affected flare any fuel gas that contains H ₂ S in excess of 162 ppmv determined hourly on a 3-hour rolling average basis. The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from this limit.	[G]§ 60.103a(a) § 60.104a(a) § 60.104a(c) [G]§ 60.104a(j) [G]§ 60.107a(a)(3) § 60.107a(a)(4) § 60.107a(i) § 60.107a(i)(2)(ii)	§ 60.108a(c) § 60.108a(c)(1) § 60.108a(c)(5) [G]§ 60.108a(c)(6) [G]§ 60.108a(d)	[G]§ 60.103a(b) [G]§ 60.108a(d)
73-FLR442	CD	63CC-1	Opacity	40 CFR Part 63, Subpart CC	§ 63.670(c) § 63.642(b) § 63.642(n) § 63.670 § 63.670(b) § 63.670(d) § 63.670(d)(1) § 63.670(e) § 63.670(o) [G]§ 63.670(o)(1) [G]§ 63.670(o)(2) [G]§ 63.670(o)(3) [G]§ 63.670(o)(4) [G]§ 63.670(o)(5) § 63.670(o)(6) [G]§ 63.670(o)(7) [G]§ 63.671(c)	Visible emissions. The owner or operator shall specify the smokeless design capacity of each flare and operate with no visible emissions, except for periods not to exceed a total of 5 minutes during any 2 consecutive hours, when regulated material is routed to the flare and the flare vent gas flow rate is less than the smokeless design capacity of the flare. The owner or operator shall monitor for visible emissions from the flare as specified in §63.670(h).	§ 63.642(d)(1) § 63.670(b) § 63.670(c) § 63.670(d)(1) § 63.670(e) § 63.670(g) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(j) [G]§ 63.670(k) [G]§ 63.670(m) [G]§ 63.671(a) [G]§ 63.671(b) [G]§ 63.671(c) [G]§ 63.671(d) [G]§ 63.671(e)	§ 63.655(i) § 63.655(i)(6) § 63.655(i)(9) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(j) [G]§ 63.670(o)(1) [G]§ 63.670(o)(5) § 63.670(o)(6) § 63.670(p) [G]§ 63.671(a) [G]§ 63.671(b)	§ 63.642(f) § 63.655(g) § 63.655(g)(11) § 63.655(g)(14) [G]§ 63.670(h) [G]§ 63.670(j) [G]§ 63.670(o)(2) § 63.670(q)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-FLR442	CD	63CC-2	Opacity	40 CFR Part 63, Subpart CC	§ 63.670(c) § 63.642(b) § 63.642(n) § 63.670 § 63.670(b) § 63.670(d) § 63.670(d)(2) § 63.670(e) § 63.670(o) [G]§ 63.670(o)(1) [G]§ 63.670(o)(2) [G]§ 63.670(o)(3) [G]§ 63.670(o)(4) [G]§ 63.670(o)(5) § 63.670(o)(6) [G]§ 63.670(o)(7) [G]§ 63.671(c)	Visible emissions. The owner or operator shall specify the smokeless design capacity of each flare and operate with no visible emissions, except for periods not to exceed a total of 5 minutes during any 2 consecutive hours, when regulated material is routed to the flare and the flare vent gas flow rate is less than the smokeless design capacity of the flare. The owner or operator shall monitor for visible emissions from the flare as specified in §63.670(h).	§ 63.642(d)(1) § 63.670(b) § 63.670(c) § 63.670(d)(2) § 63.670(e) § 63.670(g) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(j) [G]§ 63.670(k) [G]§ 63.670(l) [G]§ 63.670(m) [G]§ 63.671(a) [G]§ 63.671(b) [G]§ 63.671(c) [G]§ 63.671(d) [G]§ 63.671(e)	§ 63.655(i) § 63.655(i)(6) § 63.655(i)(9) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(j) [G]§ 63.670(o)(1) [G]§ 63.670(o)(5) § 63.670(o)(6) § 63.670(p) [G]§ 63.671(a) [G]§ 63.671(b)	§ 63.642(f) § 63.655(g) [G]§ 63.655(g)(11) § 63.655(g)(14) [G]§ 63.670(h) [G]§ 63.670(j) [G]§ 63.670(l) [G]§ 63.670(o)(2) § 63.670(q)
73-FLR446	EU	111-FLARE02	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-FLR446	EU	60Ja-1	Hydrogen Sulfide	40 CFR Part 60, Subpart Ja	§ 60.103a(h) [G]§ 60.103a(a) [G]§ 60.103a(b) § 60.103a(c) [G]§ 60.103a(c)(1) § 60.103a(d) § 60.103a(d)(1) § 60.103a(d)(2) § 60.103a(d)(3) § 60.103a(d)(5) [G]§ 60.103a(e)	Each owner or operator shall not burn in any affected flare any fuel gas that contains H ₂ S in excess of 162 ppmv determined hourly on a 3-hour rolling average basis. The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from this limit.	[G]§ 60.103a(a) § 60.104a(a) § 60.104a(c) [G]§ 60.104a(j) § 60.107a(a) § 60.107a(a)(2) § 60.107a(a)(2)(i) § 60.107a(a)(2)(ii) § 60.107a(a)(2)(iii) § 60.107a(a)(2)(iv) § 60.107a(a)(2)(v) § 60.107a(e) [G]§ 60.107a(e)(1) [G]§ 60.107a(e)(2) § 60.107a(e)(3) [G]§ 60.107a(f) § 60.107a(i) § 60.107a(i)(2)(i)	§ 60.108a(c) § 60.108a(c)(1) [G]§ 60.108a(c)(6) [G]§ 60.108a(d)	[G]§ 60.103a(b) [G]§ 60.108a(d)
73-FLR446	EU	60Ja-2	Hydrogen Sulfide	40 CFR Part 60, Subpart Ja	§ 60.103a(h) [G]§ 60.103a(a) [G]§ 60.103a(b) § 60.103a(c) [G]§ 60.103a(c)(1) § 60.103a(d) § 60.103a(d)(1) § 60.103a(d)(2) § 60.103a(d)(3) § 60.103a(d)(5) [G]§ 60.103a(e) [G]§ 60.107a(b) [G]§ 60.107a(e)(4)	Each owner or operator shall not burn in any affected flare any fuel gas that contains H ₂ S in excess of 162 ppmv determined hourly on a 3-hour rolling average basis. The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from this limit.	[G]§ 60.103a(a) § 60.104a(a) § 60.104a(c) [G]§ 60.104a(j) [G]§ 60.107a(a)(3) § 60.107a(a)(4) § 60.107a(i) § 60.107a(i)(2)(ii)	§ 60.108a(c) § 60.108a(c)(1) § 60.108a(c)(5) [G]§ 60.108a(c)(6) [G]§ 60.108a(d)	[G]§ 60.103a(b) [G]§ 60.108a(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-FLR446	CD	63CC-1	Opacity	40 CFR Part 63, Subpart CC	§ 63.670(c) § 63.642(b) § 63.642(n) § 63.670 § 63.670(b) § 63.670(d) § 63.670(d)(1) § 63.670(e) § 63.670(o) [G]§ 63.670(o)(1) [G]§ 63.670(o)(2) [G]§ 63.670(o)(3) [G]§ 63.670(o)(4) [G]§ 63.670(o)(5) § 63.670(o)(6) [G]§ 63.670(o)(7) [G]§ 63.671(c)	Visible emissions. The owner or operator shall specify the smokeless design capacity of each flare and operate with no visible emissions, except for periods not to exceed a total of 5 minutes during any 2 consecutive hours, when regulated material is routed to the flare and the flare vent gas flow rate is less than the smokeless design capacity of the flare. The owner or operator shall monitor for visible emissions from the flare as specified in §63.670(h).	§ 63.642(d)(1) § 63.670(b) § 63.670(c) § 63.670(d)(1) § 63.670(e) § 63.670(g) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(j) [G]§ 63.670(k) [G]§ 63.670(m) [G]§ 63.671(a) [G]§ 63.671(b) [G]§ 63.671(c) [G]§ 63.671(d) [G]§ 63.671(e)	§ 63.655(i) § 63.655(i)(6) § 63.655(i)(9) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(j) [G]§ 63.670(o)(1) [G]§ 63.670(o)(5) § 63.670(o)(6) § 63.670(p) [G]§ 63.671(a) [G]§ 63.671(b)	§ 63.642(f) § 63.655(g) § 63.655(g)(11) § 63.655(g)(14) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(o)(2) § 63.670(q)
73-FLR446	CD	63CC-2	Opacity	40 CFR Part 63, Subpart CC	§ 63.670(c) § 63.642(b) § 63.642(n) § 63.670 § 63.670(b) § 63.670(d) § 63.670(d)(2) § 63.670(e) § 63.670(o) [G]§ 63.670(o)(1) [G]§ 63.670(o)(2) [G]§ 63.670(o)(3) [G]§ 63.670(o)(4) [G]§ 63.670(o)(5) § 63.670(o)(6) [G]§ 63.670(o)(7) [G]§ 63.671(c)	Visible emissions. The owner or operator shall specify the smokeless design capacity of each flare and operate with no visible emissions, except for periods not to exceed a total of 5 minutes during any 2 consecutive hours, when regulated material is routed to the flare and the flare vent gas flow rate is less than the smokeless design capacity of the flare. The owner or operator shall monitor for visible emissions from the flare as specified in §63.670(h).	§ 63.642(d)(1) § 63.670(b) § 63.670(c) § 63.670(d)(2) § 63.670(e) § 63.670(g) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(j) [G]§ 63.670(k) [G]§ 63.670(l) [G]§ 63.670(m) [G]§ 63.671(a) [G]§ 63.671(b) [G]§ 63.671(c) [G]§ 63.671(d) [G]§ 63.671(e)	§ 63.655(i) § 63.655(i)(6) § 63.655(i)(9) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(j) [G]§ 63.670(o)(1) [G]§ 63.670(o)(5) § 63.670(o)(6) § 63.670(p) [G]§ 63.671(a) [G]§ 63.671(b)	§ 63.642(f) § 63.655(g) [G]§ 63.655(g)(11) § 63.655(g)(14) [G]§ 63.670(h) [G]§ 63.670(i) [G]§ 63.670(l) [G]§ 63.670(o)(2) § 63.670(q)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
73-U73F	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-U73F	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-10(f) [G]§ 60.482-10(g) § 60.482-10(h) § 60.482-10(i) [G]§ 60.482-10(j) [G]§ 60.482-10(k) § 60.482-10(m) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for closed vent (or vapor collection) systems complying with §60.482-10.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.482-10(l) [G]§ 60.486(a) [G]§ 60.486(d) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
73-U73F	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for flanges or other connectors complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
73-U73F	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	[G]§ 63.648(g) § 63.642(b) § 63.642(n)	Compressors in hydrogen service are exempt from the requirements of §63.648(a) and (c) if an owner or operator demonstrates that a compressor is in hydrogen service. §63.648(g)(1)-(2).	[G]§ 63.648(g)	§ 63.648(h) § 63.655(d)(3) § 63.655(i)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-U73F	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(d) § 60.486(k) § 63.642(b) § 63.642(n)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for equipment in vacuum service.	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(5) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
73-U73F	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pressure relief devices in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-U73F	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
73-U73F	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-U73F	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in gas/vapor service or in light liquid service complying with §60.482-7.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(ii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(d) § 60.487(e) § 63.642(f) § 63.655(d)(2)
73-U73F	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for open-ended valves or lines complying with §60.482-6.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-U73F	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-5(a) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for sampling connection systems complying with §60.482-5.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
73-U73F	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(i)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for compressors complying with §60.482-3.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-U73F	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-2(b)(1) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(f)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in light liquid service complying with §60.482-2.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) § 60.486(f) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-VC447	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
73-VC448	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
73-VC449	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
80-DSW	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
80-DSW	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-5(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k)	Each sampling connection system shall be equipped with a closed-purge, closed-loop, or closed-vent system, except as provided in §60.482-1(c) and paragraph (c) of this section.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
80-DSW	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-3(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	Each compressor shall be equipped with a seal system that includes a barrier fluid system and that prevents leakage of VOC to the atmosphere, except as provided in §60.482-1(c) and paragraphs (h), (i), and (j) of this section.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
80-DSW	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-6(a)(1) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k)	Each open-ended valve or line shall be equipped with a cap, blind flange, plug, or a second valve, except as provided in §60.482-1(c) and paragraphs (d) and (e) of this section.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
80-DSW	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-7(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k)	If an instrument reading of 10,000 ppm or greater is measured for valves in gas/vapor service and in light liquid service, a leak is detected.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(ii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
80-DSW	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-8(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k)	For valves in heavy liquid service, if an instrument reading of 10,000 ppm or greater is measured, a leak is detected.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
80-DSW	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-1(d) § 60.486(k)	Equipment that is in vacuum service is excluded from the requirements of §60.482-2 to §60.482-10, if it is identified as required in §60.486(e)(5).	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(5) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
80-DSW	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	[G]§ 60.482-1(e) § 60.486(k)	Equipment that an owner or operator designates as being in VOC service less than 300 hours (hr)/yr is excluded from the requirements of §§ 60.482-2 through 60.482-10 if it is identified as required in §60.486(e)(6) and it meets any of the conditions specified in paragraphs (e)(1) through (3) of this section. §60.482-1(e)(1)-(3)	None	§ 60.486 [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(6) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
80-DSW	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-2(b)(1) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k)	If an instrument reading of 10,000 ppm or greater is measured for pumps in light liquid service, a leak is detected.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
80-DSW	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-8(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k)	For pumps in heavy liquid service, if an instrument reading of 10,000 ppm or greater is measured, a leak is detected.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
80-DSW	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-4(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-4(b)(1) § 60.482-4(c) § 60.482-4(d)(1) § 60.482-4(d)(2) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	Except during pressure releases, each pressure relief device in gas/vapor service shall be operated with no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as determined by the methods specified in § 60.485(c).	§ 60.482-4(b)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(3) [G]§ 60.486(e)(4) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
80-DSW	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-8(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	For pressure relief devices in light liquid or in heavy liquid service, if an instrument reading of 10,000 ppm or greater is measured, a leak is detected.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
80-DSW	EU	60VV-ALL	VOC	40 CFR Part 60, Subpart VV	§ 60.482-8(b) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k)	For flanges and other connectors, if an instrument reading of 10,000 ppm or greater is measured, a leak is detected.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
80-DSW	EU	61J-ALL	Benzene	40 CFR Part 61, Subpart J	§ 61.112(a) § 61.112(b)	Each owner or operator subject to this subpart shall comply with the requirements of 40 CFR 61, Subpart V - National Emission Standard for Equipment Leaks (Fugitive Emission Sources).	None	None	None
80-DSW	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	§ 61.242-1(e)	Equipment that is in vacuum service is excluded from the requirements of §61.242-2 to §61.242-11, if it is identified as required in §61.246(e)(5).	None	[G]§ 61.246(e)	None
80-DSW	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-2 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for pumps. §61.242-2(a)-(g)	[G]§ 61.242-2 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(h) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
80-DSW	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-3 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for compressors. §61.242-3(a)-(i)	[G]§ 61.242-3 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(h) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
80-DSW	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-4 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for pressure relief devices in gas/vapor service. §61.242-4(a)-(c)	[G]§ 61.242-4 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
80-DSW	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-5 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for sampling connection systems. §61.242-5(a)-(c)	[G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
80-DSW	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-6 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for open-ended valves or lines. §61.242-6(a)-(c)	[G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
80-DSW	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-7 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10 [G]§ 61.243-1 [G]§ 61.243-2	Comply with standards for valves. §61.242-7(a)-(h)	[G]§ 61.242-7 [G]§ 61.243-1 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(f) [G]§ 61.246(g) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) § 61.247(d) [G]§ 61.247(e)
80-DSW	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-8 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for pressure relief devices in liquid service. § 61.242-8(a)-(d)	[G]§ 61.242-8 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
80-DSW	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	§ 61.242-9 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d)	Each product accumulator vessel shall be equipped with a closed-vent system to capture and transport any leakage from the vessel to a control device as in §61.242-11, except in §61.242-1(c).	[G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
80-DSW	EU	61V-ALL	VHAP	40 CFR Part 61, Subpart V	[G]§ 61.242-8 § 61.242-1(a) § 61.242-1(b) § 61.242-1(d) [G]§ 61.242-10	Comply with standards for flanges and other connectors. § 61.242-8(a)-(d)	[G]§ 61.242-8 [G]§ 61.245(b) [G]§ 61.245(c) [G]§ 61.245(d)	[G]§ 61.246(a) [G]§ 61.246(b) [G]§ 61.246(c) [G]§ 61.246(e) [G]§ 61.246(i) § 61.246(j)	[G]§ 61.247(a) [G]§ 61.247(b) § 61.247(c) [G]§ 61.247(e)
82-CPI	EU	115-CPI01	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(b)(3)	Any separator which separates materials having a true vapor pressure < 1.5 psia (10.3 kPa) obtained from any equipment is exempt from §115.132(b).	[G]§ 115.135(b) § 115.136(b)(1) § 115.136(b)(3) § 115.136(b)(4)	§ 115.136(b)(1) § 115.136(b)(3) § 115.136(b)(4)	None
82-CPI	EU	60QQQ-CPI1	VOC	40 CFR Part 60, Subpart QQQ	§ 60.692-3(a) § 60.692-1(a) § 60.692-3(a)(1) § 60.692-3(a)(2) § 60.692-3(a)(3) § 60.692-3(a)(5) § 60.692-3(b) § 60.692-3(e) § 60.692-5(c) § 60.692-5(d) [G]§ 60.692-5(e) § 60.692-6(a) § 60.692-6(b) § 60.692-7(b)	Except as noted, each oil-water separator tank, slop oil tank, storage vessel, or other auxiliary equipment shall be equipped with fixed roof, meeting following specifications:	§ 60.692-3(a)(4) § 60.695(a)(4) § 60.696(a) § 60.696(c)	§ 60.697(a) § 60.697(c) § 60.697(d) [G]§ 60.697(e) § 60.697(f)(1) [G]§ 60.697(f)(2) § 60.697(f)(3) § 60.697(f)(3)(i) § 60.697(f)(3)(iii) § 60.697(f)(3)(iv) § 60.697(f)(3)(v) § 60.697(f)(3)(vi) § 60.697(f)(3)(vii)	§ 60.698(b)(1) § 60.698(b)(2) § 60.698(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
82-TK0006	EU	61FF-WW	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)
82-TK0114	EU	61FF-WW1	Benzene	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(ii) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(d) [G]§ 61.355(h)	§ 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(G) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(10) § 61.356(j)(2) § 61.356(j)(3)	§ 61.357(d)(7) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(I)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
82-TK0114	EU	61FF-WW2	Benzene	40 CFR Part 61, Subpart FF	§ 61.343(a)(1) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(c) § 61.343(d) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(ii) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall install, operate, and maintain a fixed-roof and closed-vent system that routes all organic vapors vented from the tank to a control device.	§ 61.343(a)(1)(i)(A) § 61.343(c) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(d) [G]§ 61.355(h)	§ 61.356(d) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(G) § 61.356(g) § 61.356(h) § 61.356(j) § 61.356(j)(1) § 61.356(j)(10) § 61.356(j)(2) § 61.356(j)(3)	None
82-TK0115	EU	61FF-WW	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) [G]§ 60.112b(a)(2) § 61.351(a)(2) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii)	§ 60.115b [G]§ 60.115b(b)(3) § 61.356(k)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4) § 61.357(e) § 61.357(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
82-TK0115	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
82-TK0116	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	[G]§ 60.112b(a)(2)	Storage vessels specified in §60.112b(a) and equipped with an external floating roof (pontoon or double-deck type) are to meet the specifications of §60.112b(a)(2)(i)-(iii).	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b [G]§ 60.115b(b)(3) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
82-TK0116	EU	61FF-WW	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) [G]§ 60.112b(a)(2) § 61.351(a)(2) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii)	§ 60.115b [G]§ 60.115b(b)(3) § 61.356(k)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4) § 61.357(e) § 61.357(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
82-TK0116	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) [G]§ 60.112b(a)(2) § 63.640(n)(8)(i) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) § 60.116b(f)(1) [G]§ 60.116b(e)(3) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b [G]§ 60.115b(b)(3) § 60.116b(a) § 60.116b(b) § 63.640(n)(8)(vi)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
82-TK0117	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	[G]§ 60.112b(a)(2)	Storage vessels specified in §60.112b(a) and equipped with an external floating roof (pontoon or double-deck type) are to meet the specifications of §60.112b(a)(2)(i)-(iii).	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b [G]§ 60.115b(b)(3) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4)
82-TK0117	EU	61FF-WW	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) [G]§ 60.112b(a)(2) § 61.351(a)(2) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii)	§ 60.115b [G]§ 60.115b(b)(3) § 61.356(k)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4) § 61.357(e) § 61.357(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
82-TK0117	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) [G]§ 60.112b(a)(2) § 63.640(n)(8)(i) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii) § 60.116b(a) § 60.116b(b) § 60.116b(e) § 60.116b(e)(1) § 60.116b(f)(1) [G]§ 60.116b(e)(3) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b [G]§ 60.115b(b)(3) § 60.116b(a) § 60.116b(b) § 63.640(n)(8)(vi)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
82-TK0605	EU	61FF-WWTK1	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)
82-TK0605	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
82-TK0606	EU	61FF-WWTK1	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
82-TK0606	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
82-TK0607	EU	61FF-WWTK1	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)
82-TK0607	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
82-TK0608	EU	61FF-WWTK1	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)
852-TK0608	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
83-H1	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
851-TK0925	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
851-TK0925	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
851-TK0925	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
851-TK0926	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
851-TK0926	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
851-TK0926	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
851-TK0927	EU	115TK-06	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.112(b)(2)(F) § 115.114(b)(2)(A) § 115.114(b)(4)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(2) § 115.114(b)(3) § 115.114(b)(4) § 115.114(b)(4)(A) [G]§ 115.117	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(2)(B) § 115.114(b)(4)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
851-TK0927	EU	60KA-TK23	VOC	40 CFR Part 60, Subpart Ka	§ 60.112a(a)(1) § 60.112a(a)(1)(i) § 60.112a(a)(1)(i)(A) § 60.112a(a)(1)(i)(C) § 60.112a(a)(1)(i)(D) § 60.112a(a)(1)(ii)(A) § 60.112a(a)(1)(ii)(B) § 60.112a(a)(1)(ii)(C) § 60.112a(a)(1)(ii)(D) § 60.112a(a)(1)(iii) § 60.112a(a)(1)(iv)	Vessels storing petroleum liquids with a TVP > 10.3 kPa (1.5 psia) but < 76.6 kPa (11.1 psia) shall be equipped with an external floating roof and closure device as specified.	§ 60.113a(a)(1) § 60.113a(a)(1)(i) § 60.113a(a)(1)(i)(A) § 60.113a(a)(1)(i)(B) § 60.113a(a)(1)(i)(C) § 60.113a(a)(1)(i)(D) § 60.113a(a)(1)(i)(E) § 60.113a(a)(1)(ii)(A) § 60.113a(a)(1)(ii)(B) § 60.113a(a)(1)(ii)(C) § 60.113a(a)(1)(iii) § 60.113a(a)(1)(iv) § 60.115a(a) § 60.115a(b)	§ 60.113a(a)(1)(i)(D) § 60.115a(a)	§ 60.113a(a)(1)(i)(E) § 60.113a(a)(1)(iv)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
851-TK0927	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(c) § 63.119(a)(1) § 63.119(c)(1) § 63.119(c)(1)(i) § 63.119(c)(1)(ii) § 63.119(c)(1)(iii) § 63.119(c)(2)(i) § 63.119(c)(2)(ii) § 63.119(c)(2)(iii) § 63.119(c)(2)(iv) § 63.119(c)(2)(ix) § 63.119(c)(2)(v) § 63.119(c)(2)(vi) § 63.119(c)(2)(vii) § 63.119(c)(2)(viii) § 63.119(c)(2)(x) § 63.119(c)(2)(xi) § 63.119(c)(2)(xii) [G]§ 63.119(c)(3) § 63.119(c)(4) § 63.120(b)(10)(i) § 63.120(b)(5)(i) § 63.120(b)(5)(ii) § 63.120(b)(6)(i) § 63.120(b)(6)(ii) [G]§ 63.120(b)(7) § 63.120(b)(8)	Tanks using an external floating roof, (defined in § 63.111), to comply with §63.119(a)(1) shall comply with §63.119(c)(1)-(4).	§ 63.120(b)(1)(i) § 63.120(b)(1)(iii) § 63.120(b)(1)(iv) § 63.120(b)(10) § 63.120(b)(2)(i) § 63.120(b)(2)(ii) § 63.120(b)(2)(iii) § 63.120(b)(3) § 63.120(b)(4)	[G]§ 63.120(b)(7) § 63.120(b)(8) § 63.123(a) § 63.123(d) § 63.123(g) [G]§ 63.152(a)	§ 63.120(b)(10)(ii) § 63.120(b)(10)(iii) § 63.120(b)(9) [G]§ 63.122(e)(1) § 63.122(e)(2) § 63.122(e)(3) § 63.122(e)(3)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
851-TK0928	EU	115TK-06	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.112(b)(2)(F) § 115.114(b)(2)(A) § 115.114(b)(4)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(2) § 115.114(b)(3) § 115.114(b)(4) § 115.114(b)(4)(A) [G]§ 115.117	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(2)(B) § 115.114(b)(4)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
851-TK0928	EU	60KA-TK23	VOC	40 CFR Part 60, Subpart Ka	§ 60.112a(a)(1) § 60.112a(a)(1)(i) § 60.112a(a)(1)(i)(A) § 60.112a(a)(1)(i)(C) § 60.112a(a)(1)(i)(D) § 60.112a(a)(1)(ii)(A) § 60.112a(a)(1)(ii)(B) § 60.112a(a)(1)(ii)(C) § 60.112a(a)(1)(ii)(D) § 60.112a(a)(1)(iii) § 60.112a(a)(1)(iv)	Vessels storing petroleum liquids with a TVP > 10.3 kPa (1.5 psia) but < 76.6 kPa (11.1 psia) shall be equipped with an external floating roof and closure device as specified.	§ 60.113a(a)(1) § 60.113a(a)(1)(i) § 60.113a(a)(1)(i)(A) § 60.113a(a)(1)(i)(B) § 60.113a(a)(1)(i)(C) § 60.113a(a)(1)(i)(D) § 60.113a(a)(1)(i)(E) § 60.113a(a)(1)(ii)(A) § 60.113a(a)(1)(ii)(B) § 60.113a(a)(1)(ii)(C) § 60.113a(a)(1)(iii) § 60.113a(a)(1)(iv) § 60.115a(a) § 60.115a(b)	§ 60.113a(a)(1)(i)(D) § 60.115a(a)	§ 60.113a(a)(1)(i)(E) § 60.113a(a)(1)(iv)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
851-TK0928	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(c) § 63.119(a)(1) § 63.119(c)(1) § 63.119(c)(1)(i) § 63.119(c)(1)(ii) § 63.119(c)(1)(iii) § 63.119(c)(2)(i) § 63.119(c)(2)(ii) § 63.119(c)(2)(iii) § 63.119(c)(2)(iv) § 63.119(c)(2)(ix) § 63.119(c)(2)(v) § 63.119(c)(2)(vi) § 63.119(c)(2)(vii) § 63.119(c)(2)(viii) § 63.119(c)(2)(x) § 63.119(c)(2)(xi) § 63.119(c)(2)(xii) [G]§ 63.119(c)(3) § 63.119(c)(4) § 63.120(b)(10)(i) § 63.120(b)(5)(i) § 63.120(b)(5)(ii) § 63.120(b)(6)(i) § 63.120(b)(6)(ii) [G]§ 63.120(b)(7) § 63.120(b)(8)	Tanks using an external floating roof, (defined in § 63.111), to comply with §63.119(a)(1) shall comply with §63.119(c)(1)-(4).	§ 63.120(b)(1)(i) § 63.120(b)(1)(iii) § 63.120(b)(1)(iv) § 63.120(b)(10) § 63.120(b)(2)(i) § 63.120(b)(2)(ii) § 63.120(b)(2)(iii) § 63.120(b)(3) § 63.120(b)(4)	[G]§ 63.120(b)(7) § 63.120(b)(8) § 63.123(a) § 63.123(d) § 63.123(g) [G]§ 63.152(a)	§ 63.120(b)(10)(ii) § 63.120(b)(10)(iii) § 63.120(b)(9) [G]§ 63.122(e)(1) § 63.122(e)(2) § 63.122(e)(3) § 63.122(e)(3)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
851-TK0929	EU	63G-03	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
851-TK0930	EU	63G-03	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
851-TK1029	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
851-TK1029	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
851-TK1029	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
851-TK1030	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
851-TK1030	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
851-TK1030	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
851-TK1031	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
851-TK1031	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
851-TK1031	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
851-TK1032	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
851-TK1032	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0201	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
852-TK0201	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0201	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0202	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
852-TK0202	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0202	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0211	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
852-TK0211	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0211	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0212	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
852-TK0212	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0212	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0221	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
852-TK0221	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0221	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0222	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
852-TK0222	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0222	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0223	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
852-TK0223	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0223	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0224	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
852-TK0224	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0224	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0224	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0225	EU	115TK-06	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.112(b)(2)(F) § 115.114(b)(2)(A) § 115.114(b)(4)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(2) § 115.114(b)(3) § 115.114(b)(4) § 115.114(b)(4)(A) [G]§ 115.117	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(2)(B) § 115.114(b)(4)(B)
852-TK0225	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	[G]§ 60.112b(a)(2)	Storage vessels specified in §60.112b(a) and equipped with an external floating roof (pontoon or double-deck type) are to meet the specifications of §60.112b(a)(2)(i)-(iii).	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b [G]§ 60.115b(b)(3) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0225	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) [G]§ 60.112b(a)(2) § 63.640(n)(8)(i) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b [G]§ 60.115b(b)(3) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 63.640(n)(8)(vi)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0225	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(c) § 63.119(a)(1) § 63.119(c)(1) § 63.119(c)(1)(i) § 63.119(c)(1)(ii) § 63.119(c)(1)(iii) § 63.119(c)(2)(i) § 63.119(c)(2)(ii) § 63.119(c)(2)(iii) § 63.119(c)(2)(iv) § 63.119(c)(2)(ix) § 63.119(c)(2)(v) § 63.119(c)(2)(vi) § 63.119(c)(2)(vii) § 63.119(c)(2)(viii) § 63.119(c)(2)(x) § 63.119(c)(2)(xi) § 63.119(c)(2)(xii) [G]§ 63.119(c)(3) § 63.119(c)(4) § 63.120(b)(10)(i) § 63.120(b)(5)(i) § 63.120(b)(5)(ii) § 63.120(b)(6)(i) § 63.120(b)(6)(ii) [G]§ 63.120(b)(7) § 63.120(b)(8)	Tanks using an external floating roof, (defined in § 63.111), to comply with §63.119(a)(1) shall comply with §63.119(c)(1)-(4).	§ 63.120(b)(1)(i) § 63.120(b)(1)(iii) § 63.120(b)(1)(iv) § 63.120(b)(10) § 63.120(b)(2)(i) § 63.120(b)(2)(ii) § 63.120(b)(2)(iii) § 63.120(b)(3) § 63.120(b)(4)	[G]§ 63.120(b)(7) § 63.120(b)(8) § 63.123(a) § 63.123(d) § 63.123(g) [G]§ 63.152(a)	§ 63.120(b)(10)(ii) § 63.120(b)(10)(iii) § 63.120(b)(9) [G]§ 63.122(e)(1) § 63.122(e)(2) § 63.122(e)(3) § 63.122(e)(3)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
852-TK0226	EU	115TK-06	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.112(b)(2)(F) § 115.114(b)(2)(A) § 115.114(b)(4)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(2) § 115.114(b)(3) § 115.114(b)(4) § 115.114(b)(4)(A) [G]§ 115.117	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(2)(B) § 115.114(b)(4)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0226	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	[G]§ 60.112b(a)(2)	Storage vessels specified in §60.112b(a) and equipped with an external floating roof (pontoon or double-deck type) are to meet the specifications of §60.112b(a)(2)(i)-(iii).	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b [G]§ 60.115b(b)(3) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0226	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) [G]§ 60.112b(a)(2) § 63.640(n)(8)(i) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	[G]§ 60.113b(b)(1) [G]§ 60.113b(b)(2) § 60.113b(b)(3) § 60.113b(b)(4) § 60.113b(b)(4)(i) § 60.113b(b)(4)(i)(A) § 60.113b(b)(4)(i)(B) [G]§ 60.113b(b)(4)(ii) § 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6) § 60.113b(b)(6)(i) § 60.113b(b)(6)(ii) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b [G]§ 60.115b(b)(3) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 63.640(n)(8)(vi)	§ 60.113b(b)(4)(iii) § 60.113b(b)(5) § 60.113b(b)(6)(ii) § 60.115b § 60.115b(b)(1) [G]§ 60.115b(b)(2) § 60.115b(b)(4) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0226	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(c) § 63.119(a)(1) § 63.119(c)(1) § 63.119(c)(1)(i) § 63.119(c)(1)(ii) § 63.119(c)(1)(iii) § 63.119(c)(2)(i) § 63.119(c)(2)(ii) § 63.119(c)(2)(iii) § 63.119(c)(2)(iv) § 63.119(c)(2)(ix) § 63.119(c)(2)(v) § 63.119(c)(2)(vi) § 63.119(c)(2)(vii) § 63.119(c)(2)(viii) § 63.119(c)(2)(x) § 63.119(c)(2)(xi) § 63.119(c)(2)(xii) [G]§ 63.119(c)(3) § 63.119(c)(4) § 63.120(b)(10)(i) § 63.120(b)(5)(i) § 63.120(b)(5)(ii) § 63.120(b)(6)(i) § 63.120(b)(6)(ii) [G]§ 63.120(b)(7) § 63.120(b)(8)	Tanks using an external floating roof, (defined in § 63.111), to comply with §63.119(a)(1) shall comply with §63.119(c)(1)-(4).	§ 63.120(b)(1)(i) § 63.120(b)(1)(iii) § 63.120(b)(1)(iv) § 63.120(b)(10) § 63.120(b)(2)(i) § 63.120(b)(2)(ii) § 63.120(b)(2)(iii) § 63.120(b)(3) § 63.120(b)(4)	[G]§ 63.120(b)(7) § 63.120(b)(8) § 63.123(a) § 63.123(d) § 63.123(g) [G]§ 63.152(a)	§ 63.120(b)(10)(ii) § 63.120(b)(10)(iii) § 63.120(b)(9) [G]§ 63.122(e)(1) § 63.122(e)(2) § 63.122(e)(3) § 63.122(e)(3)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
852-TK0301	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0301	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
852-TK0301	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0302	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0302	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
852-TK0302	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0401	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0401	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
852-TK0401	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0402	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0402	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
852-TK0402	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0403	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0403	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
852-TK0403	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0620	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0621	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
852-TK0804	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
852-TK0804	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0804	EU	61FF-WWTK1	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)
852-TK0804	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK0804	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK0804	EU	63G-WWTK11	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(2)(ii) § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.133(f) § 63.133(h) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a)	A fixed roof and an internal floating roof that meets the requirements specified in Sec. 63.119(b) of this subpart;	§ 63.133(f) § 63.133(g) § 63.133(g)(2) § 63.133(g)(3) § 63.143(a) § 63.143(g)	§ 63.133(h) § 63.147(b) § 63.147(b)(1) § 63.147(b)(6) § 63.147(b)(7) [G]§ 63.152(a)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(c) § 63.146(g) [G]§ 63.151(b) § 63.151(e) [G]§ 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK1001	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
852-TK1002	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
852-TK1003	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
852-TK1009	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK1009	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
852-TK1009	EU	61FF-WW	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK1009	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(iii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
852-TK1010	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
852-TK1015	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK1016	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
852-TK1016	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
852-TK1016	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK1017	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
852-TK1018	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
852-TK1019	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
852-TK1020	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
852-TK1028	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
853-TK2001	EU	115-TK21	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
853-TK2001	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
853-TK2002	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
853-TK2002	EU	115TK-21	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
853-TK2002	EU	60KB-1	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
853-TK2002	EU	61FF-WWTK1	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)
853-TK2002	EU	63CC-TKKB1	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
853-TK2002	EU	63CC-TKKB2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(iii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
853-TK2003	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
853-TK2005	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
853-TK2006	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
853-TK3101	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
853-TK3102	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
854-TK0001	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0001	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
854-TK0001	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
854-TK0001	EU	63G-03	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0002	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
854-TK0002	EU	63G-TK12	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
854-TK0003	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0003	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
854-TK0003	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
854-TK0003	EU	63G-03	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0004	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
854-TK0004	EU	63G-TK11	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
854-TK0005	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0005	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
854-TK0005	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(B) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) [G]§ 60.113b(a)(3) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(4) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0005	EU	63G-01	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
854-TK0005	EU	63G-02	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0013	EU	63G-TK11	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
854-TK0014	EU	63G-01	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0020	EU	63G-TK01	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
854-TK0020	EU	63G-TK11	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
854-TK0021	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0021	EU	61FF-WWTK1	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 61.357(e) § 61.357(f)
854-TK0021	EU	63G-TK12	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0021	EU	63G-WWTK11	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(2)(ii) § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.133(f) § 63.133(h) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a)	A fixed roof and an internal floating roof that meets the requirements specified in Sec. 63.119(b) of this subpart;	§ 63.133(f) § 63.133(g) § 63.133(g)(2) § 63.133(g)(3) § 63.143(a) § 63.143(g)	§ 63.133(h) § 63.147(b) § 63.147(b)(1) § 63.147(b)(6) § 63.147(b)(7) [G]§ 63.152(a)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(c) § 63.146(g) [G]§ 63.151(b) § 63.151(e) [G]§ 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
854-TK0022	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0022	EU	63G-TK12	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
854-TK0022	EU	63G-WWTK11	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(2)(ii) § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.133(f) § 63.133(h) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a)	A fixed roof and an internal floating roof that meets the requirements specified in Sec. 63.119(b) of this subpart;	§ 63.133(f) § 63.133(g) § 63.133(g)(2) § 63.133(g)(3) § 63.143(a) § 63.143(g)	§ 63.133(h) § 63.147(b) § 63.147(b)(1) § 63.147(b)(6) § 63.147(b)(7) [G]§ 63.152(a)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(c) § 63.146(g) [G]§ 63.151(b) § 63.151(e) [G]§ 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0033	EU	115-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
854-TK0033	EU	63G-TK12	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
854-TK0034	EU	115-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0034	EU	63G-TK12	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(b) § 63.119(a)(1) [G]§ 63.119(b)(1) § 63.119(b)(2) § 63.119(b)(3)(ii) § 63.119(b)(4) § 63.119(b)(5)(i) § 63.119(b)(5)(ii) § 63.119(b)(5)(iii) § 63.119(b)(5)(iv) § 63.119(b)(5)(v) § 63.119(b)(5)(vi) § 63.119(b)(5)(vii) [G]§ 63.119(b)(5)(viii) § 63.119(b)(6) § 63.120(a)(4) § 63.120(a)(7)	Tanks using a fixed roof and an internal floating roof (defined in §63.111) to comply with §63.119(a)(1) must comply with: §63.119(b)(1)-(6).	§ 63.120(a)(2)(i) § 63.120(a)(2)(ii)	§ 63.120(a)(4) § 63.123(a) § 63.123(c) § 63.123(g) [G]§ 63.152(a)	§ 63.120(a)(5) § 63.120(a)(6) § 63.122(d) § 63.122(d)(1)(ii) § 63.122(d)(1)(iii) § 63.122(d)(2)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
854-TK0040	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
854-TK0040	EU	63G-TK01	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0041	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
854-TK0041	EU	63G-TK01	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
854-TK0042	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
854-TK0042	EU	63G-TK01	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
854-TK0043	EU	63G-03	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0044	EU	63G-03	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
854-TK0045	EU	63G-03	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
854-TK0050	EU	63G-TK01	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
854-TK0055	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0055	EU	61FF-WWTK2	Benzene	40 CFR Part 61, Subpart FF	§ 61.351(a) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(B) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 61.351(a)(1) § 61.351(b)	As an alternative to the standards for tanks specified in § 61.343, an owner or operator may elect to comply with one of the following §61.351(a)(1)-(3):	§ 60.113b(a)(1) [G]§ 60.113b(a)(3) § 60.113b(a)(4) § 60.113b(a)(5)	§ 60.115b § 60.115b(a)(2) § 61.356(k)	§ 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(4) § 61.357(e) § 61.357(f)
854-TK0055	EU	63G-WWTK11	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.133(a)(2)(ii) § 63.132(a)(2)(i)(A) § 63.132(a)(2)(i)(B) [G]§ 63.132(f) § 63.133(f) § 63.133(h) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a)	A fixed roof and an internal floating roof that meets the requirements specified in Sec. 63.119(b) of this subpart;	§ 63.133(f) § 63.133(g) § 63.133(g)(2) § 63.133(g)(3) § 63.143(a) § 63.143(g)	§ 63.133(h) § 63.147(b) § 63.147(b)(1) § 63.147(b)(6) § 63.147(b)(7) [G]§ 63.152(a)	§ 63.146(b)(2) § 63.146(b)(5) § 63.146(b)(6) § 63.146(c) § 63.146(g) [G]§ 63.151(b) § 63.151(e) [G]§ 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0056	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
854-TK0056	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
854-TK0056	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0056	EU	63G-02	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
854-TK0057	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
854-TK0057	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0057	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(iii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
854-TK0060	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
854-TK0061	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0062	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
854-TK0081	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
854-TK0082	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0082	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
854-TK0082	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(B) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) [G]§ 60.113b(a)(3) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(4) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
854-TK0083	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0083	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
854-TK0083	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(B) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) [G]§ 60.113b(a)(3) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(4) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
854-TK0091	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0091	EU	60KA-TK11	VOC	40 CFR Part 60, Subpart Ka	§ 60.112a(a)(2)	Vessels storing petroleum liquids with a TVP > 10.3 kPa (1.5 psia) but < 76.6 kPa (11.1 psia) shall have a fixed roof and an internal floating cover with the specified closure device and vents.	§ 60.115a(a) § 60.115a(b) ** See Periodic Monitoring Summary	§ 60.115a(a)	None
854-TK0092	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)
854-TK0092	EU	60KA-TK11	VOC	40 CFR Part 60, Subpart Ka	§ 60.112a(a)(2)	Vessels storing petroleum liquids with a TVP > 10.3 kPa (1.5 psia) but < 76.6 kPa (11.1 psia) shall have a fixed roof and an internal floating cover with the specified closure device and vents.	§ 60.115a(a) § 60.115a(b) ** See Periodic Monitoring Summary	§ 60.115a(a)	None
854-TK0093	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
854-TK0093	EU	60KA-TK11	VOC	40 CFR Part 60, Subpart Ka	§ 60.112a(a)(2)	Vessels storing petroleum liquids with a TVP > 10.3 kPa (1.5 psia) but < 76.6 kPa (11.1 psia) shall have a fixed roof and an internal floating cover with the specified closure device and vents.	§ 60.115a(a) § 60.115a(b) ** See Periodic Monitoring Summary	§ 60.115a(a)	None
855-TK1018	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
855-TK1019	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
855-TK1022	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
855-TK1022	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
855-TK1022	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
855-TK1023	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
855-TK1023	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
855-TK1023	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
855-TK1024	EU	115TK-05	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.114(b)(1)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(1)(A) [G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(1)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
855-TK1024	EU	60KB	VOC	40 CFR Part 60, Subpart Kb	§ 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii)	Storage vessels specified in §60.112b(a) and equipped with a fixed roof in combination with an internal floating roof shall meet the specifications listed in §60.112b(a)(1)(i)-(ix).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3)
855-TK1024	EU	63CC-TKKB	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(n)(8) § 60.112b(a)(1) § 60.112b(a)(1)(i) § 60.112b(a)(1)(ii)(C) § 60.112b(a)(1)(iii) § 60.112b(a)(1)(iv) § 60.112b(a)(1)(ix) § 60.112b(a)(1)(v) § 60.112b(a)(1)(vi) § 60.112b(a)(1)(vii) § 60.112b(a)(1)(viii) § 63.640(n)(8)(ii) § 63.640(n)(8)(iii) § 63.640(n)(8)(vii) § 63.642(b) § 63.642(n)	Floating roof storage vessels described by §63.640(n)(2) are to comply with 40 CFR part 60, subpart Kb, except as provided in §63.640(n)(8)(i)-(vii).	§ 60.113b(a)(1) § 60.113b(a)(2) § 60.113b(a)(4) § 60.113b(a)(5) § 60.116b(a) § 60.116b(b) § 60.116b(c) § 60.116b(e) § 60.116b(e)(1) § 60.116b(e)(2) § 60.116b(e)(2)(i) § 63.1063(c)(2)(iv)(A) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(ii)	§ 60.115b § 60.115b(a)(2) § 60.116b(a) § 60.116b(b) § 60.116b(c)	§ 60.113b(a)(2) § 60.113b(a)(5) § 60.115b § 60.115b(a)(1) § 60.115b(a)(3) § 63.1063(c)(2)(iv)(B) § 63.640(n)(8)(iv) § 63.640(n)(8)(v)
855-TK1025	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
855-TK1026	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
855-TK1027	EU	115TK-22	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.112(b)(2)(F) § 115.114(b)(2)(A) § 115.114(b)(4)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(2) § 115.114(b)(3) § 115.114(b)(4) § 115.114(b)(4)(A) [G]§ 115.117	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(2)(B) § 115.114(b)(4)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
855-TK1027	EU	60KA-TK22	VOC	40 CFR Part 60, Subpart Ka	§ 60.112a(a)(1) § 60.112a(a)(1)(i) § 60.112a(a)(1)(i)(A) § 60.112a(a)(1)(i)(C) § 60.112a(a)(1)(i)(D) § 60.112a(a)(1)(ii)(A) § 60.112a(a)(1)(ii)(B) § 60.112a(a)(1)(ii)(C) § 60.112a(a)(1)(ii)(D) § 60.112a(a)(1)(iii) § 60.112a(a)(1)(iv)	Vessels storing petroleum liquids with a TVP > 10.3 kPa (1.5 psia) but < 76.6 kPa (11.1 psia) shall be equipped with an external floating roof and closure device as specified.	§ 60.113a(a)(1) § 60.113a(a)(1)(i) § 60.113a(a)(1)(i)(A) § 60.113a(a)(1)(i)(B) § 60.113a(a)(1)(i)(C) § 60.113a(a)(1)(i)(D) § 60.113a(a)(1)(i)(E) § 60.113a(a)(1)(ii)(A) § 60.113a(a)(1)(ii)(B) § 60.113a(a)(1)(ii)(C) § 60.113a(a)(1)(iii) § 60.113a(a)(1)(iv) § 60.115a(a) § 60.115a(b)	§ 60.113a(a)(1)(i)(D) § 60.115a(a)	§ 60.113a(a)(1)(i)(E) § 60.113a(a)(1)(iv)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
855-TK1027	EU	63G-TK22	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(c) § 63.119(a)(1) § 63.119(c)(1) § 63.119(c)(1)(i) § 63.119(c)(1)(ii) § 63.119(c)(1)(iii) § 63.119(c)(2)(i) § 63.119(c)(2)(ii) § 63.119(c)(2)(iii) § 63.119(c)(2)(iv) § 63.119(c)(2)(ix) § 63.119(c)(2)(v) § 63.119(c)(2)(vi) § 63.119(c)(2)(vii) § 63.119(c)(2)(viii) § 63.119(c)(2)(x) § 63.119(c)(2)(xi) § 63.119(c)(2)(xii) [G]§ 63.119(c)(3) § 63.119(c)(4) § 63.120(b)(10)(i) § 63.120(b)(5)(i) § 63.120(b)(5)(ii) § 63.120(b)(6)(i) § 63.120(b)(6)(ii) [G]§ 63.120(b)(7) § 63.120(b)(8)	Tanks using an external floating roof, (defined in § 63.111), to comply with §63.119(a)(1) shall comply with §63.119(c)(1)-(4).	§ 63.120(b)(1)(i) § 63.120(b)(1)(iii) § 63.120(b)(1)(iv) § 63.120(b)(10) § 63.120(b)(2)(i) § 63.120(b)(2)(ii) § 63.120(b)(2)(iii) § 63.120(b)(3) § 63.120(b)(4)	[G]§ 63.120(b)(7) § 63.120(b)(8) § 63.123(a) § 63.123(d) § 63.123(g) [G]§ 63.152(a)	§ 63.120(b)(10)(ii) § 63.120(b)(10)(iii) § 63.120(b)(9) [G]§ 63.122(e)(1) § 63.122(e)(2) § 63.122(e)(3) § 63.122(e)(3)(ii) § 63.151(a)(7) [G]§ 63.151(b) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(4)(ii)
855-TK1040	EU	63G-03	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
855-TK1041	EU	63G-03	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
855-TK1042	EU	115TK-06	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1) § 115.112(b)(2) § 115.112(b)(2)(A) § 115.112(b)(2)(B) § 115.112(b)(2)(C) § 115.112(b)(2)(D) § 115.112(b)(2)(E) § 115.112(b)(2)(F) § 115.114(b)(2)(A) § 115.114(b)(4)(A)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	§ 115.114(b)(2) § 115.114(b)(3) § 115.114(b)(4) § 115.114(b)(4)(A) [G]§ 115.117	§ 115.118(b)(2) § 115.118(b)(4) § 115.118(b)(5)	§ 115.114(b)(2)(B) § 115.114(b)(4)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
855-TK1042	EU	60KA-TK23	VOC	40 CFR Part 60, Subpart Ka	§ 60.112a(a)(1) § 60.112a(a)(1)(i) § 60.112a(a)(1)(i)(A) § 60.112a(a)(1)(i)(C) § 60.112a(a)(1)(i)(D) § 60.112a(a)(1)(ii)(A) § 60.112a(a)(1)(ii)(B) § 60.112a(a)(1)(ii)(C) § 60.112a(a)(1)(ii)(D) § 60.112a(a)(1)(iii) § 60.112a(a)(1)(iv)	Vessels storing petroleum liquids with a TVP > 10.3 kPa (1.5 psia) but < 76.6 kPa (11.1 psia) shall be equipped with an external floating roof and closure device as specified.	§ 60.113a(a)(1) § 60.113a(a)(1)(i) § 60.113a(a)(1)(i)(A) § 60.113a(a)(1)(i)(B) § 60.113a(a)(1)(i)(C) § 60.113a(a)(1)(i)(D) § 60.113a(a)(1)(i)(E) § 60.113a(a)(1)(ii)(A) § 60.113a(a)(1)(ii)(B) § 60.113a(a)(1)(ii)(C) § 60.113a(a)(1)(iii) § 60.113a(a)(1)(iv) § 60.115a(a) § 60.115a(b)	§ 60.113a(a)(1)(i)(D) § 60.115a(a)	§ 60.113a(a)(1)(i)(E) § 60.113a(a)(1)(iv)
855-TK1042	EU	63G-1	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.119(a)(3)	Group 2 tanks not using emissions averaging as prescribed by §63.150 shall use record keeping methods in §63.123(a). Not required to comply with §63.119 to §63.123.	None	§ 63.123(a)	§ 63.152(c)(4)(iii)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
89-U89	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
911-H	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)
911-H	EU	63DDDDD-03	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
97-D3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
DEAUNLOAD	EU	63EEEE	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2338(b) The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart EEEE
DIESELLOAD	EU	115-LOAD02	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(b)(2) § 115.214(b)(1)(B) § 115.214(b)(1)(D) § 115.214(b)(1)(D)(i)	All land-based loading and unloading of VOC with a true vapor pressure less than 1.5 psia under actual storage conditions is exempt from the requirements of the division (relating to Loading and Unloading of VOCs), except as specified.	§ 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
ENGVENT01	EP	111-ENGVENT01	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
F066	EP	111-VENT03	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	§ 111.111(a)(1)(D) [G]§ 111.111(a)(1)(F)	§ 111.111(a)(1)(C) § 111.111(a)(1)(D)	None
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
F416	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
F416	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(d) § 60.486(k)	Comply with the requirements as stated in §60.482-1(d) for equipment in vacuum service.	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(6) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
F416	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements as stated in §60.482-2 for pumps in light-liquid service.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
F416	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e) § 60.593(c)	Comply with the requirements as stated in §60.482-3 for reciprocating compressors that become subject under §60.14 and §60.15.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
F416	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements as stated in §60.482-3 for compressors.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
F416	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-4(a) § 60.482-4(b)(1) § 60.482-4(c) § 60.482-4(d)(1) § 60.482-4(d)(2) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-4 for pressure relief devices in gas/vapor service.	§ 60.482-4(b)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(3) [G]§ 60.486(e)(4) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
F416	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-5(a) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-5 for sampling connection systems.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
F416	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-6 for open-ended valves and lines.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
F416	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-7 for valves in gas/vapor or light-liquid service.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(ii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
F416	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for valves in heavy-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
F416	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for pumps in heavy-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
F416	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for pressure relief devices in light-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
F416	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-10 for vapor recovery devices.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
F416	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for flanges or other connectors.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-FGRS	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
FUG-FGRS	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	[G]§ 63.648(g) § 63.642(b) § 63.642(n)	Compressors in hydrogen service are exempt from the requirements of §63.648(a) and (c) if an owner or operator demonstrates that a compressor is in hydrogen service. §63.648(g)(1)-(2).	[G]§ 63.648(g)	§ 63.648(h) § 63.655(d)(3) § 63.655(i)	None
FUG-FGRS	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(d) § 60.486(k) § 63.642(b) § 63.642(n)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for equipment in vacuum service.	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(5) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-FGRS	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-2(b)(1) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(f)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in light liquid service complying with §60.482-2.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) § 60.486(f) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-FGRS	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(i)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for compressors complying with §60.482-3.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
FUG-FGRS	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-5(a) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for sampling connection systems complying with §60.482-5.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-FGRS	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for open-ended valves or lines complying with §60.482-6.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
FUG-FGRS	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in gas/vapor service or in light liquid service complying with §60.482-7.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(iii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(d) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-FGRS	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
FUG-FGRS	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-FGRS	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pressure relief devices in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
FUG-FGRS	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for flanges or other connectors complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
FUG-GHT	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-5(a) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-5 for sampling connection systems.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUG-GHT	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-4(a) § 60.482-4(b)(1) § 60.482-4(c) § 60.482-4(d)(1) § 60.482-4(d)(2) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-4 for pressure relief devices in gas/vapor service.	§ 60.482-4(b)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(3) [G]§ 60.486(e)(4) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements as stated in §60.482-3 for compressors.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e) § 60.593(c)	Comply with the requirements as stated in §60.482-3 for reciprocating compressors that become subject under §60.14 and §60.15.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUG-GHT	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-6 for open-ended valves and lines.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements as stated in §60.482-2 for pumps in light-liquid service.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for pumps in heavy-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUG-GHT	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-7 for valves in gas/vapor or light-liquid service.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(ii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for valves in heavy-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUG-GHT	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for flanges or other connectors.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-10 for vapor recovery devices.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUG-GHT	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for pressure relief devices in light-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
FUG-GHT	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(d) § 60.486(k)	Comply with the requirements as stated in §60.482-1(d) for equipment in vacuum service.	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(6) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGGA-1	VOC	40 CFR Part 60, Subpart GGGa	§ 60.593a(g) § 60.482-11a(b)(2) § 60.482-11a(b)(3) § 60.482-11a(d) [G]§ 60.482-11a(e) [G]§ 60.482-11a(f)(1) § 60.482-11a(f)(2) § 60.482-11a(g) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(c) § 60.482-9a(f) § 60.485a(b) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Connectors in gas/vapor or light liquid service are exempt from the requirements in §60.482-11a, provided the owner or operator complies with §60.482-8a for all connectors, not just those in heavy liquid service.	§ 60.482-11a(a) § 60.482-11a(b) § 60.482-11a(b)(1) § 60.482-11a(b)(3) § 60.482-11a(b)(3)(i) § 60.482-11a(b)(3)(ii) [G]§ 60.482-11a(b)(3)(iii) § 60.482-11a(b)(3)(iv) § 60.482-11a(c) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-11a(b)(3)(v) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8) § 60.486a(e)(9) § 60.486a(f) § 60.486a(f)(1)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(5) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(i) § 60.487a(c)(2)(vii) § 60.487a(c)(2)(viii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGGA-1	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) [G]§ 60.482-2a(c)(2) [G]§ 60.482-7a(e) § 60.482-8a(a) § 60.482-8a(a)(2) § 60.482-8a(b) [G]§ 60.482-8a(c) § 60.482-8a(d) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(c) § 60.482-9a(f) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-8a for connectors in heavy liquid service.	§ 60.482-1a(g) § 60.482-8a(a)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGGA-1	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) [G]§ 60.482-2a(c)(2) [G]§ 60.482-7a(e) § 60.482-8a(a) § 60.482-8a(a)(2) § 60.482-8a(b) [G]§ 60.482-8a(c) § 60.482-8a(d) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(c) § 60.482-9a(e) § 60.482-9a(f) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-8a for valves in heavy liquid service.	§ 60.482-1a(g) § 60.482-8a(a)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGGA-1	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-7a(a)(1) § 60.482-7a(b) [G]§ 60.482-7a(d) [G]§ 60.482-7a(e) [G]§ 60.482-7a(f) [G]§ 60.482-7a(g) [G]§ 60.482-7a(h) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(c) § 60.482-9a(e) § 60.482-9a(f) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-7a for valves in gas/vapor or light liquid service.	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3) § 60.482-1a(g) § 60.482-7a(a)(1) [G]§ 60.482-7a(a)(2) [G]§ 60.482-7a(c) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) § 60.486a(f)(2)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(2) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(i) § 60.487a(c)(2)(ii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)
FUG-GHT	EU	60GGGA-1	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-5a(a) [G]§ 60.482-5a(b) § 60.482-5a(c) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-5a for sampling connection systems.	§ 60.482-1a(g) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGGA-1	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-3a(a) [G]§ 60.482-3a(b) § 60.482-3a(c) § 60.482-3a(d) § 60.482-3a(e)(2) § 60.482-3a(f) [G]§ 60.482-3a(g) § 60.482-3a(h) [G]§ 60.482-3a(i) § 60.482-3a(j) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-3a for compressors.	§ 60.482-1a(g) § 60.482-3a(e)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) [G]§ 60.486a(h)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(4) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(v) § 60.487a(c)(2)(vi) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)
FUG-GHT	EU	60GGGA-1	VOC	40 CFR Part 60, Subpart GGGa	§ 60.593a(b)(1)	Compressors in hydrogen service are exempt from the requirements of §60.592a if an owner or operator demonstrates that a compressor is in hydrogen service.	§ 60.593a(b)(2) [G]§ 60.593a(b)(3)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGGA-1	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) [G]§ 60.482-2a(c)(2) [G]§ 60.482-7a(e) § 60.482-8a(a) § 60.482-8a(a)(2) § 60.482-8a(b) [G]§ 60.482-8a(c) § 60.482-8a(d) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(d) § 60.482-9a(f) § 60.485a(b) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-8a for pumps in heavy liquid service.	§ 60.482-1a(g) § 60.482-8a(a)(1) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGGA-1	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(g) § 60.482-2a(b)(1) § 60.482-2a(b)(2) § 60.482-2a(b)(2)(ii) § 60.482-2a(c)(1) [G]§ 60.482-2a(c)(2) § 60.482-2a(d) [G]§ 60.482-2a(d)(1) § 60.482-2a(d)(2) § 60.482-2a(d)(3) [G]§ 60.482-2a(d)(6) [G]§ 60.482-2a(e) § 60.482-2a(f) [G]§ 60.482-2a(g) § 60.482-2a(h) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(d) § 60.482-9a(f) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-2a for pumps in light liquid service.	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3) § 60.482-1a(g) § 60.482-2a(a)(1) § 60.482-2a(a)(2) § 60.482-2a(b)(2)(i) [G]§ 60.482-2a(d)(4) [G]§ 60.482-2a(d)(5) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) [G]§ 60.485a(d) [G]§ 60.485a(e) § 60.593a(d)	§ 60.482-1a(g) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) § 60.486a(e)(7) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) [G]§ 60.486a(h)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(3) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(iii) § 60.487a(c)(2)(iv) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	60GGGA-1	VOC	40 CFR Part 60, Subpart GGGa	§ 60.592a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-1a(d) § 60.485a(b) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.592a(d) § 60.592a(e)	Comply with the requirements as stated in §60.482-1a(d) for equipment in vacuum service.	[G]§ 60.485a(b)(1) § 60.485a(b)(2)	§ 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) § 60.486a(e)(5)	None
FUG-GHT	EU	63CCVV-1	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(d) § 60.486(k) § 63.642(b) § 63.642(n)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for equipment in vacuum service.	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(5) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	63CCVV-1	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-2(b)(1) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(f)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in light liquid service complying with §60.482-2.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) § 60.486(f) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	63CCVV-1	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for flanges or other connectors complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
FUG-GHT	EU	63CCVV-1	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	63CCVV-1	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
FUG-GHT	EU	63CCVV-1	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in gas/vapor service or in light liquid service complying with §60.482-7.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(iii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(d) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	63CCVV-1	112(B) HAPS	40 CFR Part 63, Subpart CC	[G]§ 63.648(g) § 63.642(b) § 63.642(n)	Compressors in hydrogen service are exempt from the requirements of §63.648(a) and (c) if an owner or operator demonstrates that a compressor is in hydrogen service. §63.648(g)(1)-(2).	[G]§ 63.648(g)	§ 63.648(h) § 63.655(d)(3) § 63.655(i)	None
FUG-GHT	EU	63CCVV-1	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(i)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for compressors complying with §60.482-3.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
FUG-GHT	EU	63CCVV-1	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-5(a) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for sampling connection systems complying with §60.482-5.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
GRP-HONVT	EP	63G-VENT01	112(B) HAPS	40 CFR Part 63, Subpart G	[G]§ 63.113(a)(1) § 63.11 § 63.113(h) [G]§ 63.115(f)	Reduce emissions of organic HAP using a flare. §63.113(a)(1)(i)-(ii)	§ 63.114(a) § 63.114(a)(2) [G]§ 63.115(f) [G]§ 63.116(a)	[G]§ 63.117(a)(5) § 63.118(a)(1) § 63.118(a)(2) [G]§ 63.152(a) [G]§ 63.152(f)	[G]§ 63.117(a)(5) § 63.117(f) § 63.118(f)(2) § 63.118(f)(5) [G]§ 63.151(b) § 63.151(e) [G]§ 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-NNNVT1	EP	60NNN-01	VOC/TOC	40 CFR Part 60, Subpart NNN	§ 60.662(b) § 60.18	Each affected facility shall combust the emissions in a flare that meets the requirements of § 60.18.	§ 60.663(b) § 60.663(b)(1) § 60.663(b)(2) § 60.664(a) § 60.664(d) [G]§ 60.664(e)	§ 60.663(b)(2) § 60.665(b) § 60.665(b)(3) § 60.665(d) § 60.665(f)	§ 60.665(a) § 60.665(b) § 60.665(b)(3) § 60.665(k) § 60.665(l) § 60.665(l)(2) § 60.665(l)(4)
GRP1DOCK	EU	63CC-LOAD	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.651(a) § 63.642(b) § 63.642(n)	Except as provided in §63.651(b)-(e), each owner or operator of a marine tank vessel loading operation located at a petroleum refinery shall comply with the requirements of §§63.560 through 63.568.	§ 63.642(d)(1) § 63.642(d)(3) § 63.642(d)(4)	§ 63.642(d)(3) § 63.655(c) § 63.655(i) § 63.655(i)(6)	§ 63.642(d)(2) § 63.642(f) § 63.655(c)
GRP1DOCK	EU	63Y-LOAD03	112(B) HAPS	40 CFR Part 63, Subpart Y	§ 63.562(b) [G]§ 63.562(b)(1) § 63.562(b)(2) [G]§ 63.562(b)(6) § 63.562(e) § 63.562(e)(1) [G]§ 63.562(e)(2) [G]§ 63.562(e)(3) § 63.562(e)(4) § 63.562(e)(5) § 63.562(e)(6) § 63.562(e)(7) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.563(a)(2) § 63.563(a)(3)	Marine tank vessel loading operations shall apply MACT standards, except for the VMT source.	[G]§ 63.562(b)(6) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.563(b) § 63.563(b)(1) § 63.563(b)(10) § 63.563(b)(3) § 63.563(b)(4) § 63.563(b)(4)(ii) [G]§ 63.563(c) § 63.564(a)(2) § 63.564(a)(3) § 63.564(a)(4) § 63.564(c) § 63.564(e)(2) § 63.564(e)(4) [G]§ 63.565(b) [G]§ 63.565(d) § 63.565(f) § 63.565(f)(1) § 63.565(l) [G]§ 63.565(m)	[G]§ 63.562(b)(6) § 63.562(e)(5) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.564(e)(2) [G]§ 63.565(d) § 63.567(f) [G]§ 63.567(g) § 63.567(j)(1) § 63.567(j)(2) [G]§ 63.567(k)	[G]§ 63.562(b)(6) § 63.562(e)(7)(ii) [G]§ 63.567(b)(2) § 63.567(b)(3) [G]§ 63.567(b)(4) § 63.567(b)(5)(ii) § 63.567(c) § 63.567(e)(1) [G]§ 63.567(e)(2) § 63.567(e)(3) § 63.567(e)(4) § 63.567(e)(5) § 63.567(e)(6) § 63.567(f) § 63.567(j)(3) § 63.567(m) § 63.567(n)(1) § 63.567(n)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP1DOCK	EU	63Y-LOAD03	VOC	40 CFR Part 63, Subpart Y	§ 63.562(c) [G]§ 63.562(c)(2) § 63.562(c)(3) § 63.562(c)(4) [G]§ 63.562(c)(6) § 63.562(e) § 63.562(e)(1) [G]§ 63.562(e)(2) [G]§ 63.562(e)(3) § 63.562(e)(4) § 63.562(e)(5) § 63.562(e)(6) § 63.562(e)(7) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.563(a)(2) § 63.563(a)(3)	Marine tank vessel loading operations shall apply RACT standards, except for the VMT source.	[G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.563(b) § 63.563(b)(1) § 63.563(b)(3) § 63.563(b)(4) § 63.563(b)(4)(iii) [G]§ 63.563(c) § 63.564(a)(2) § 63.564(a)(3) § 63.564(a)(4) § 63.564(c) § 63.564(e)(2) § 63.564(e)(4) [G]§ 63.565(b) [G]§ 63.565(d) § 63.565(f) § 63.565(f)(1) § 63.565(l)	§ 63.562(e)(5) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.564(e)(2) [G]§ 63.565(d) [G]§ 63.565(m) § 63.567(f) [G]§ 63.567(g) [G]§ 63.567(k)	§ 63.562(c)(1) § 63.562(e)(7)(ii) [G]§ 63.567(b)(2) § 63.567(b)(3) [G]§ 63.567(b)(4) § 63.567(c) § 63.567(e)(1) [G]§ 63.567(e)(2) § 63.567(e)(3) § 63.567(e)(4) § 63.567(e)(5) § 63.567(e)(6) § 63.567(f) § 63.567(m) § 63.567(n)(1) § 63.567(n)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP1DOCK	EU	63Y-LOAD04	112(B) HAPS	40 CFR Part 63, Subpart Y	§ 63.562(b) [G]§ 63.562(b)(1) § 63.562(b)(2) [G]§ 63.562(b)(6) § 63.562(e) § 63.562(e)(1) [G]§ 63.562(e)(2) [G]§ 63.562(e)(3) § 63.562(e)(4) § 63.562(e)(5) § 63.562(e)(6) § 63.562(e)(7) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.563(a)(2) § 63.563(a)(3)	Marine tank vessel loading operations shall apply MACT standards, except for the VMT source.	[G]§ 63.562(b)(6) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.563(b) § 63.563(b)(1) § 63.563(b)(10) § 63.563(b)(3) § 63.563(b)(4) § 63.563(b)(4)(ii) [G]§ 63.563(c) § 63.564(a)(2) § 63.564(a)(3) § 63.564(a)(4) § 63.564(c) § 63.564(e)(2) § 63.564(e)(4) [G]§ 63.565(b) [G]§ 63.565(d) § 63.565(f) § 63.565(f)(1) § 63.565(l) [G]§ 63.565(m)	[G]§ 63.562(b)(6) § 63.562(e)(5) [G]§ 63.562(e)(7)(i) § 63.562(e)(7)(ii) § 63.564(e)(2) [G]§ 63.565(d) § 63.567(f) [G]§ 63.567(g) § 63.567(j)(1) § 63.567(j)(2) [G]§ 63.567(k)	[G]§ 63.562(b)(6) § 63.562(e)(7)(ii) [G]§ 63.567(b)(2) § 63.567(b)(3) [G]§ 63.567(b)(4) § 63.567(b)(5)(ii) § 63.567(c) § 63.567(e)(1) [G]§ 63.567(e)(2) § 63.567(e)(3) § 63.567(e)(4) § 63.567(e)(5) § 63.567(e)(6) § 63.567(f) § 63.567(j)(3) § 63.567(m) § 63.567(n)(1) § 63.567(n)(2)
GRP1HTR	EU	60J-FUEL01	Hydrogen Sulfide	40 CFR Part 60, Subpart J	§ 60.104(a)(1)	No owner or operator subject to the provisions of this subpart shall burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H ₂ S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from the emission limitation in §60.104(a)(1).	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(ii) § 60.105(a)(4)(iii) § 60.106(a) [G]§ 60.106(e)(1)	§ 60.105(a)(4) § 60.105(a)(4)(i) § 60.105(a)(4)(iii)	§ 60.105(e)(3)(ii) § 60.107(f) § 60.107(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP1PRO	PRO	63F-PRO01	112(B) HAPS	40 CFR Part 63, Subpart F	§ 63.100(b) [G]§ 63.102(a) [G]§ 63.102(c) § 63.105(d)	Except as provided in paragraphs (b)(4) and (c) of this section, the provisions of subparts F, G, and H apply to chemical manufacturing process units that meet the criteria.	§ 63.103(b)(1) § 63.103(b)(3) § 63.103(b)(4) [G]§ 63.103(b)(5) § 63.103(b)(6)	[G]§ 63.103(c) [G]§ 63.105(b) § 63.105(c) § 63.105(e)	§ 63.103(b)(2) [G]§ 63.103(b)(5) [G]§ 63.103(d)
GRP1STAC K	EP	111-VENT01	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP2FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
GRP2FUG	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-10(b) § 60.482-10(m) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for vapor recovery systems complying with §60.482-10.	§ 60.482-10(e) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(d) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
GRP2FUG	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	[G]§ 63.648(g) § 63.642(b) § 63.642(n)	Compressors in hydrogen service are exempt from the requirements of §63.648(a) and (c) if an owner or operator demonstrates that a compressor is in hydrogen service. §63.648(g)(1)-(2).	[G]§ 63.648(g)	§ 63.648(h) § 63.655(d)(3) § 63.655(i)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP2FUG	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(d) § 60.486(k) § 63.642(b) § 63.642(n)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for equipment in vacuum service.	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(5) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
GRP2FUG	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-2(b)(1) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(f)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in light liquid service complying with §60.482-2.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) § 60.486(f) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP2FUG	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2) § 63.648(i)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for compressors complying with §60.482-3.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(d)(6) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
GRP2FUG	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-10(f) [G]§ 60.482-10(g) § 60.482-10(h) § 60.482-10(i) [G]§ 60.482-10(j) [G]§ 60.482-10(k) § 60.482-10(m) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for closed vent (or vapor collection) systems complying with §60.482-10.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.482-10(l) [G]§ 60.486(a) [G]§ 60.486(d) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP2FUG	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-5(a) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for sampling connection systems complying with §60.482-5.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
GRP2FUG	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for flanges or other connectors complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP2FUG	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pressure relief devices in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
GRP2FUG	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP2FUG	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for pumps in heavy liquid service complying with §60.482-8.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
GRP2FUG	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for valves in gas/vapor service or in light liquid service complying with §60.482-7.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(iii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) [G]§ 63.648(b)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(d) § 60.487(e) § 63.642(f) § 63.655(d)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP2FUG	EU	63CCVV-ALL	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.648(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k) § 63.642(b) § 63.642(n) § 63.648(a)(2)	Comply with the specified 40 CFR Part 60, Subpart VV requirements for open-ended valves or lines complying with §60.482-6.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j) § 63.648(h) § 63.655(d)(1)(i) § 63.655(i) § 63.655(i)(6)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 63.642(f) § 63.655(d)(2)
GRP2STAC K	EP	111-VENT01	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
GRP3FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(a) [G]§ 63.172(h) § 63.172(i) § 63.172(j)(1) § 63.172(j)(2) § 63.172(m)	Owners/operators of closed-vent systems and control devices used to comply with provisions of this subpart shall comply with the provisions of this section, except as provided in §63.162(b).	[G]§ 63.172(f)(1) [G]§ 63.172(f)(2) § 63.172(g) [G]§ 63.172(h) § 63.172(j)(1) § 63.172(j)(2) [G]§ 63.172(k) [G]§ 63.172(l) [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.118(a)(3) § 63.172(j)(1) [G]§ 63.172(k) [G]§ 63.172(l) § 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) [G]§ 63.181(g)(2) [G]§ 63.181(g)(3)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.172(d) § 63.11(b) § 63.172(e) [G]§ 63.172(h) § 63.172(m)	Flares used to comply with this subpart shall comply with the requirements of § 63.11(b) of 40 CFR 63, Subpart A.	§ 63.172(e) [G]§ 63.172(h) [G]§ 63.180(b) [G]§ 63.180(d) [G]§ 63.180(e)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(g) § 63.181(g)(1)(i) § 63.181(g)(1)(ii) § 63.181(g)(1)(iii) § 63.181(g)(1)(iv) [G]§ 63.181(g)(2)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.173 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Agitators gas/vapor service and in light liquid service. §63.173(a)-(j).	[G]§ 63.173 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.168 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Valves in gas/vapor service and in light liquid service. §63.168(a)-(j)	[G]§ 63.168 [G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.167 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.175	Standards: Open-ended valves or lines. §63.167(a)-(e).	[G]§ 63.175 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) § 63.181(h) [G]§ 63.181(h)(1) [G]§ 63.181(h)(2) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.163 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171 [G]§ 63.176	Standards: Pumps in light liquid service. §63.163(a)-(j)	[G]§ 63.163 [G]§ 63.176 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) § 63.181(h) [G]§ 63.181(h)(3) § 63.181(h)(4) [G]§ 63.181(h)(5) § 63.181(h)(6) § 63.181(h)(7) § 63.181(h)(8)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.162(e) § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h)	Equipment that is in organic HAP service less than 300 hours per year is excluded from the requirements of §§63.163 - 63.174 and §63.178 if it is identified as required in §63.181(j).	[G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(i) § 63.181(j)	[G]§ 63.182(a) [G]§ 63.182(b)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.164 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Compressors. §63.164(a)-(i)	[G]§ 63.164 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.165 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief device in gas/vapor service. §63.165(a)-(d)	[G]§ 63.165 [G]§ 63.180(b) [G]§ 63.180(c) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(f)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.166 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Sampling connection systems. §63.166(a)-(c)	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pumps in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Valves in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Connectors in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Agitators in heavy liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d) [G]§ 63.181(i)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Instrumentation systems. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.169 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Pressure relief devices in liquid service. §63.169(a)-(d)	[G]§ 63.169 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	§ 63.170 § 63.162(a) § 63.162(c) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Surge control vessels and bottom receivers.	[G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)
GRP3FUG	EU	63H-ALL	112(B) HAPS	40 CFR Part 63, Subpart H	[G]§ 63.174 § 63.162(a) § 63.162(c) [G]§ 63.162(f) [G]§ 63.162(g) § 63.162(h) [G]§ 63.171	Standards: Connectors in gas/vapor service and in light liquid service. §63.174(a)-(j)	[G]§ 63.174 [G]§ 63.180(b) [G]§ 63.180(d)	§ 63.181(a) [G]§ 63.181(b) § 63.181(c) [G]§ 63.181(d)	[G]§ 63.182(a) [G]§ 63.182(b) § 63.182(c) [G]§ 63.182(c)(1) § 63.182(c)(4) [G]§ 63.182(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
GRP4FUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPDEGRSR	EU	115-SOLV11	VOC	30 TAC Chapter 115, Degreasing Processes	§ 115.411(5)	In Gregg, Nueces, and Victoria Counties, degreasing operations located on any property that can emit, when uncontrolled, a combined weight of VOC < 550 pounds in any consecutive 24-hour period are exempt from §115.412 of this title.	None	§ 115.416 § 115.416(3)	None
GRPVENDTKS	EU	115TK-03	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(b)(1)	Tanks shall not store VOC unless the required pressure is maintained, or they are equipped with the appropriate control device specified in Table I(a) or Table II(a).	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(b)(4) § 115.118(b)(5)	None
GRPVENDTKS	EU	63CC-G2	112(B) HAPS	40 CFR Part 63, Subpart CC	§ 63.640(c)(2) § 63.642(b) § 63.642(n)	All storage vessels associated with petroleum refining process units meeting the criteria in §63.640(a) are part of the affected source.	§ 63.660(a)(1) § 63.660(a)(2)	§ 63.655(g)(7)(ii) § 63.655(i) § 63.655(i)(1)(vi) § 63.655(i)(6) § 63.660(a)(1)	§ 63.642(f) § 63.655(f) § 63.655(f)(1)(i)(A) § 63.655(g) § 63.655(g)(14) § 63.655(g)(7) § 63.655(g)(7)(i) § 63.655(h) § 63.655(h)(6) § 63.655(h)(6)(ii)
PCEUNLOAD	EU	63EEEE	112(B) HAPS	40 CFR Part 63, Subpart EEEE	§ 63.2338(b) The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart EEEE	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart EEEE

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
PROBTXTR	PRO	61FF-TRT01	Benzene	40 CFR Part 61, Subpart FF	§ 61.348(a)(1) § 61.348(a)(1)(i) § 61.348(a)(2) § 61.348(a)(3) § 61.348(a)(4) § 61.348(f) § 61.349(a) § 61.349(a)(1)(i) § 61.349(a)(1)(iii) § 61.349(a)(1)(iv) § 61.349(a)(2)(i)(C) § 61.349(b) § 61.349(e) § 61.349(f) § 61.349(g)	The owner or operator shall design, install, operate and maintain a treatment process that removes or destroys benzene as specified.	§ 61.348(f) § 61.349(a)(1)(i) § 61.349(e) § 61.349(f) § 61.354(a)(2) § 61.354(c) § 61.354(c)(1) § 61.355(d) [G]§ 61.355(h)	§ 61.354(a)(2) § 61.354(c) § 61.354(c)(1) § 61.355(d) § 61.356(e) § 61.356(e)(1) [G]§ 61.356(e)(3) § 61.356(f) § 61.356(f)(1) § 61.356(f)(2) § 61.356(f)(2)(i) § 61.356(f)(2)(i)(A) § 61.356(h) [G]§ 61.356(i) § 61.356(j) § 61.356(j)(1) § 61.356(j)(2) § 61.356(j)(3) § 61.356(j)(4)	§ 61.357(d)(7) § 61.357(d)(7)(ii) § 61.357(d)(7)(iv) § 61.357(d)(7)(iv)(A)

PROBTXTR	PRO	63G-TRT01	112(B) HAPS	40 CFR Part 63, Subpart G	§ 63.138(e)(1) [G]§ 63.132(f) [G]§ 63.138(k) § 63.139(b) § 63.139(c)(1) § 63.139(c)(1)(iii) § 63.139(f) § 63.140(a) § 63.140(b) § 63.140(c) § 63.144(a) § 63.145(c)(6) [G]§ 63.148(d) § 63.148(e)	The mass flow rate of Table 9 and/or Table 8 compounds shall be reduced by 99 percent or more and process efficiency shall be as per §63.145(c) or §63.145(d).	§ 63.138(j)(2) § 63.139(d)(2)(i) § 63.139(e) § 63.143(d) § 63.143(e) § 63.143(e)(1) § 63.143(f) § 63.143(g) § 63.145(a)(1) § 63.145(a)(5) [G]§ 63.145(a)(6) § 63.145(c) § 63.145(c)(1) § 63.145(c)(2) § 63.145(c)(3) § 63.145(c)(4) § 63.145(c)(5) § 63.145(c)(6) § 63.148(b)(1)(ii) § 63.148(b)(2)(iii) § 63.148(b)(3) [G]§ 63.148(c) § 63.148(g) § 63.148(g)(2) § 63.148(h) § 63.148(h)(2)	§ 63.143(f) § 63.147(b) § 63.147(b)(2) § 63.147(b)(5) § 63.147(b)(7) § 63.147(d) § 63.147(e) § 63.148(g)(2) § 63.148(h)(2) § 63.148(i)(1) § 63.148(i)(2) [G]§ 63.148(i)(4) § 63.148(i)(5) § 63.148(i)(6) [G]§ 63.152(a) [G]§ 63.152(f)	§ 63.143(d) § 63.146(a) § 63.146(b)(2) § 63.146(b)(4) § 63.146(b)(5) § 63.146(b)(6) [G]§ 63.146(b)(8) § 63.146(b)(9) § 63.146(b)(9)(ii) [G]§ 63.146(d) § 63.146(e) § 63.146(e)(1) § 63.146(f) § 63.148(j) § 63.148(j)(1) [G]§ 63.151(b) § 63.151(e) [G]§ 63.151(e)(1) § 63.151(e)(2) § 63.151(e)(3) § 63.151(e)(5) § 63.151(f) § 63.151(f)(1) § 63.151(f)(2) § 63.151(f)(3) § 63.151(h) [G]§ 63.151(j) [G]§ 63.152(a) § 63.152(b) [G]§ 63.152(b)(1) [G]§ 63.152(b)(2) § 63.152(b)(4) § 63.152(c)(1) § 63.152(c)(2) § 63.152(c)(2)(i) [G]§ 63.152(c)(2)(ii) § 63.152(c)(2)(iii) § 63.152(c)(2)(iv) § 63.152(c)(3) § 63.152(c)(3)(i) § 63.152(c)(3)(ii) § 63.152(c)(4)(ii) [G]§ 63.152(c)(6)
PRODFDTR	PRO	61FF-TRT02	Benzene	40 CFR Part 61, Subpart FF	§ 61.348(a)(1) § 61.348(a)(1)(i) § 61.348(a)(2) § 61.348(a)(3) § 61.348(a)(4) § 61.348(f)	The owner or operator shall design, install, operate and maintain a treatment process that removes or destroys benzene as specified.	§ 61.348(f) § 61.354(a)(2) § 61.355(d)	§ 61.354(a)(2) § 61.355(d) § 61.356(e)(1) [G]§ 61.356(e)(3) [G]§ 61.356(i)	§ 61.357(d)(7) § 61.357(d)(7)(ii)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
PROFDTR TR	EU	63GGGG G	112(B) HAPS	40 CFR Part 63, Subpart GGGGG	§ 63.7886(b)(3) § 63.7938(c)(3)	If the RMMU is also subject to another subpart under 40 CFR part 61 or 40 CFR part 63, control emissions of the HAP listed in Table 1 of this subpart from the affected RMMU in compliance with the standards specified in the applicable subpart (i.e. applicable emissions limitations and work practice standards). This provision does not apply to any exemption of the affected source from the emissions limitations and work practice standards allowed by the other applicable subpart.	None	None	[G]§ 63.7937(c)(3)
PROEPSRU	EU	112-SRU01	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.7(a)	No person may cause, suffer, allow, or permit emissions of SO ₂ to exceed the emission limits specified for stack effluent flow rates less than or equal to 4,000 scfm as determined by the specified equation in §112.7(a).	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
PROEPSRU	PRO	60J-SRU1	SO ₂	40 CFR Part 60, Subpart J	§ 60.104(a)(2)(i)	No owner or operator subject to the provisions of this subpart shall discharge or cause the discharge into the atmosphere from any Claus sulfur recovery plant with an oxidation control system any gases containing in excess of 250 ppm by volume of SO ₂ at zero percent excess air.	[G]§ 60.105(a)(5) § 60.106(a) [G]§ 60.106(f)	[G]§ 60.105(a)(5)	§ 60.105(e)(4)(i) § 60.107(d) § 60.107(f) § 60.107(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
PROEPSRU	EU	63UUU-1	SO ₂	40 CFR Part 63, Subpart UUU	§ 63.1568(a)(1)-Table 29.1.a § 63.1568(a)(1) § 63.1568(a)(2) § 63.1568(a)(2)-Table 30.1 § 63.1568(a)(2)-Table 30.6 § 63.1568(a)(3) § 63.1568(a)(4) § 63.1568(a)(4)(i) § 63.1568(a)(4)(iii) § 63.1568(b)(3) § 63.1568(b)(4) § 63.1568(b)(5) § 63.1568(b)(5)-Table 33.1.a § 63.1568(c)(1) § 63.1568(c)(1)-Table 35.1 § 63.1568(c)(2) § 63.1569(a)(1) § 63.1569(a)(1)(ii)-Table 36.2 § 63.1569(a)(3) § 63.1569(b)(2) § 63.1569(b)(2)-Table 38.1.b § 63.1569(c)(1) § 63.1569(c)(2) § 63.1570(a) § 63.1570(c) § 63.1570(d)	For each new or existing Claus SRU part of a sulfur recovery plant with design capacity greater than 20 long tons per day and subject to NSPS for sulfur oxides in 40 CFR §60.104(a)(2) or §60.102a(f)(1), you must meet the emission limit for each process vent of 250 ppmv (dry basis) of sulfur dioxide (SO ₂) at zero percent excess air if you use an oxidation or reduction control system followed by incineration.	§ 63.1568(b)(1) § 63.1568(b)(1)-Table 31.1.a § 63.1568(b)(1)-Table 31.5 § 63.1568(c)(1)-Table 34.1.a § 63.1568(c)(1)-Table 35.5.a § 63.1568(c)(1)-Table 35.5.b § 63.1569(c)(1)-Table 39.2 § 63.1571(a) § 63.1571(a)(1) [G]§ 63.1571(b) § 63.1572(a) § 63.1572(a)(1) § 63.1572(a)(1)-Table 40.5 § 63.1572(a)(1)-Table 40.9 § 63.1572(a)(2) § 63.1572(a)(3) § 63.1572(a)(4) [G]§ 63.1572(d)	§ 63.1568(b)(1)-Table 31.1.a § 63.1568(c)(1)-Table 34.1.a § 63.1569(c)(1)-Table 39.2 § 63.1569(c)(1)-Table 39.5 § 63.1570(c) § 63.1570(d) [G]§ 63.1576(a) § 63.1576(d) § 63.1576(e) § 63.1576(f) § 63.1576(g) § 63.1576(h) § 63.1576(i)	§ 63.1568(b)(6) § 63.1568(b)(7) § 63.1569(b)(3) § 63.1569(b)(4) § 63.1569(c)(1)-Table 39.5 § 63.1570(f) § 63.1571(a) [G]§ 63.1574(a) § 63.1574(c) § 63.1574(d) § 63.1574(d)-Table 42.1 § 63.1574(d)-Table 42.2 § 63.1574(d)-Table 42.3 § 63.1575(a) § 63.1575(a)-Table 43.1 § 63.1575(a)-Table 43.2 [G]§ 63.1575(b) [G]§ 63.1575(c) [G]§ 63.1575(e) [G]§ 63.1575(f) § 63.1575(g) § 63.1575(k) [G]§ 63.1575(k)(1) [G]§ 63.1575(k)(2) [G]§ 63.1575(l) [G]§ 63.1576(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
PROEPSRU	EU	63UUU-2	SO ₂	40 CFR Part 63, Subpart UUU	§ 63.1568(a)(1)-Table 29.1.a § 63.1568(a)(1) § 63.1568(a)(2) § 63.1568(a)(2)-Table 30.1 § 63.1568(a)(2)-Table 30.5 § 63.1568(a)(3) § 63.1568(a)(4) § 63.1568(a)(4)(i) § 63.1568(a)(4)(ii) § 63.1568(b)(1)-Table 31.4 § 63.1568(b)(3) § 63.1568(b)(4) § 63.1568(b)(5) § 63.1568(b)(5)-Table 33.1.a § 63.1568(c)(1) § 63.1568(c)(1)-Table 35.1 § 63.1568(c)(2) § 63.1569(a)(1) § 63.1569(a)(1)(iii)-Table 36.2 § 63.1569(a)(3) § 63.1569(b)(2) § 63.1569(b)(2)-Table 38.1.b § 63.1569(c)(1) § 63.1569(c)(2) § 63.1570(a) § 63.1570(c) § 63.1570(d) § 63.670(c) § 63.671(a)	For each new or existing Claus SRU part of a sulfur recovery plant with design capacity greater than 20 long tons per day and subject to NSPS for sulfur oxides in 40 CFR §60.104(a)(2) or §60.102a(f)(1), you must meet the emission limit for each process vent of 250 ppmv (dry basis) of sulfur dioxide (SO ₂) at zero percent excess air if you use an oxidation or reduction control system followed by incineration.	§ 63.1568(b)(1) § 63.1568(b)(1)-Table 31.1.a § 63.1568(c)(1)-Table 34.1.a § 63.1568(c)(1)-Table 35.4 § 63.1569(c)(1)-Table 39.2 § 63.1571(a) § 63.1571(a)(1) [G]§ 63.1571(b) § 63.1572(a) § 63.1572(a)(1) § 63.1572(a)(1)-Table 40.5 § 63.1572(a)(1)-Table 40.9 § 63.1572(a)(2) § 63.1572(a)(3) § 63.1572(a)(4) § 63.1572(c) [G]§ 63.1572(d)	§ 63.1568(b)(1)-Table 31.1.a § 63.1568(c)(1)-Table 34.1.a § 63.1569(c)(1)-Table 39.2 § 63.1569(c)(1)-Table 39.5 § 63.1570(c) § 63.1570(d) [G]§ 63.1576(a) § 63.1576(d) § 63.1576(e) § 63.1576(f) § 63.1576(g) § 63.1576(h) § 63.1576(i)	§ 63.1568(b)(6) § 63.1568(b)(7) § 63.1569(b)(3) § 63.1569(b)(4) § 63.1569(c)(1)-Table 39.5 § 63.1570(f) § 63.1571(a) [G]§ 63.1574(a) § 63.1574(c) § 63.1574(d) § 63.1574(d)-Table 42.1 § 63.1574(d)-Table 42.2 § 63.1574(d)-Table 42.3 § 63.1575(a) § 63.1575(a)-Table 43.1 § 63.1575(a)-Table 43.2 [G]§ 63.1575(b) [G]§ 63.1575(c) [G]§ 63.1575(e) [G]§ 63.1575(f) § 63.1575(g) § 63.1575(k) [G]§ 63.1575(k)(1) [G]§ 63.1575(k)(2) [G]§ 63.1575(l) [G]§ 63.1576(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No connector, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(5)	No valve (gaseous service), as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(5)	No pressure relief valve in gaseous service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No elevated valve may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(D) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No elevated valve, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No compressor seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(A) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3) § 115.327(6)	No compressor seal, as described in § 115.327(3), (5) or (6), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No process drain may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(C) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No process drain, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4)	No valve in liquid service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.327(3) § 115.327(5)	No valve in liquid service, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(4) § 115.322(5)	No valve (gaseous service) may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(B) § 115.324(4) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No connector may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.327(1)	Valves of nominal size of 2" (5 cm) or less are exempt, provided allowable emissions from sources affected by this division after controls are applied with exemptions will not exceed by more than 5.0% such allowable emissions with no exemptions.	None	None	§ 115.327(1)(A) § 115.327(1)(B) § 115.327(1)(C)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.327(3)	No pump seal, as described in § 115.327(3) or (5), may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	[G]§ 115.325	[G]§ 115.326(1) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3)	No pump seal may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(1) § 115.324(1)(A) § 115.324(3) § 115.324(4) § 115.324(6) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.326(1) § 115.327(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SCOTFUG	EU	R5322-ALL	VOC	30 TAC Chapter 115, Fugitives Pet Ref B Counties	§ 115.322(1) § 115.322(2) § 115.322(3) § 115.322(5)	No pressure relief valve in gaseous service may be allowed to have a VOC leak as defined in §101.1 for more than 15 calendar days after the leak is found, except as provided in §115.322(2).	§ 115.324 § 115.324(2) § 115.324(2)(C) § 115.324(4) § 115.324(5) § 115.324(6) [G]§ 115.324(7) [G]§ 115.325	[G]§ 115.326(1) [G]§ 115.326(2) [G]§ 115.326(3) § 115.326(5)	[G]§ 115.324(7) [G]§ 115.326(1) § 115.327(4)
SCOTFUG	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for flanges or other connectors.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
SCOTFUG	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-10 for vapor recovery devices.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SCOTFUG	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for pressure relief devices in light-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
SCOTFUG	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for pumps in heavy-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SCOTFUG	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-8(a) § 60.482-8(a)(2) § 60.482-8(b) § 60.482-8(c)(1) § 60.482-8(c)(2) § 60.482-8(d) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-8 for valves in heavy-liquid service.	§ 60.482-8(a)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
SCOTFUG	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-7 for valves in gas/vapor or light-liquid service.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) § 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(iii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SCOTFUG	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-6(a)(1) § 60.482-6(a)(2) § 60.482-6(b) § 60.482-6(c) § 60.482-6(d) § 60.482-6(e) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-6 for open-ended valves and lines.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
SCOTFUG	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-5(a) [G]§ 60.482-5(b) § 60.482-5(c) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-5 for sampling connection systems.	§ 60.485(a) [G]§ 60.485(b) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
SCOTFUG	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-4(a) § 60.482-4(b)(1) § 60.482-4(c) § 60.482-4(d)(1) § 60.482-4(d)(2) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements in as stated in §60.482-4 for pressure relief devices in gas/vapor service.	§ 60.482-4(b)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(3) [G]§ 60.486(e)(4) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SCOTFUG	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements as stated in §60.482-3 for compressors.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SCOTFUG	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) § 60.482-3(a) [G]§ 60.482-3(b) § 60.482-3(c) § 60.482-3(d) § 60.482-3(e)(1) § 60.482-3(e)(2) § 60.482-3(f) § 60.482-3(g)(1) § 60.482-3(g)(2) § 60.482-3(h) [G]§ 60.482-3(i) § 60.482-3(j) § 60.482-9(a) § 60.482-9(b) § 60.486(k) § 60.592(d) § 60.592(e) § 60.593(c)	Comply with the requirements as stated in §60.482-3 for reciprocating compressors that become subject under §60.14 and §60.15.	§ 60.482-3(e)(1) § 60.485(a) [G]§ 60.485(c) [G]§ 60.485(d) § 60.485(f)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
SCOTFUG	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(d) § 60.486(k)	Comply with the requirements as stated in §60.482-1(d) for equipment in vacuum service.	None	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(6) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SCOTFUG	EU	60GGG-ALL	VOC	40 CFR Part 60, Subpart GGG	§ 60.592(a) § 60.482-1(a) § 60.482-1(b) § 60.482-1(g) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4) [G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k) § 60.592(d) § 60.592(e)	Comply with the requirements as stated in §60.482-2 for pumps in light-liquid service.	§ 60.482-1(f)(1) § 60.482-1(f)(2) [G]§ 60.482-1(f)(3) [G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) [G]§ 60.485(d) [G]§ 60.485(e) § 60.485(f) § 60.593(d)	§ 60.482-1(g) [G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e)
SLDGLOAD	EU	115-LOAD02	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(b)(2) § 115.214(b)(1)(B) § 115.214(b)(1)(D) § 115.214(b)(1)(D)(i)	All land-based loading and unloading of VOC with a true vapor pressure less than 1.5 psia under actual storage conditions is exempt from the requirements of the division (relating to Loading and Unloading of VOCs), except as specified.	§ 115.214(b)(1)(A) § 115.214(b)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SURFCOAT	PRO	115-COAT01	VOC	30 TAC Chapter 115, Surface Coating Operations	§ 115.427(7) § 115.426	In Gregg, Nueces, and Victoria Counties, surface coating operations located at any property that, when uncontrolled, will emit a combined weight of VOC less than 550 pounds (249.5 kilograms) in any continuous 24-hour period are exempt from §115.421 of this title. Excluded from this calculation are coatings and solvents used in surface coating activities that are not addressed by the surface coating categories of §115.421(1) - (10) of this title.	§ 115.426(4)	§ 115.426(4)	None

Additional Monitoring Requirements

Periodic Monitoring Summary 384

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 47-TK0103	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115-1
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: N/A	
Averaging Period: N/A	
Deviation Limit: Discharge opening not entirely submerged when pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 47-TK0103	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115-1
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: N/A	
Deviation Limit: Structural integrity of the pipe is in question and not repaired before refilling.	
<p>Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 54-TK3	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 64-TK0013	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-03
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: N/A	
Averaging Period: N/A	
Deviation Limit: Discharge opening not entirely submerged when pipe used to withdraw liquid from the tank; tank can no longer withdraw liquid in normal operation.	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 64-TK0013	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-03
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: emptied and degassed	
Averaging Period: N/A	
Deviation Limit: Structural integrity of the pipe is in question and is not repaired before refilling.	
<p>Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 851-TK0925	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 851-TK0926	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 851-TK1029	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 851-TK1030	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 851-TK1031	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0201	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0202	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0211	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0212	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0221	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0222	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0223	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0224	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0301	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0302	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0401	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0402	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0403	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK0804	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK1009	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 852-TK1016	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 853-TK2001	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115-TK21
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 853-TK2002	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 853-TK2002	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-21
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0001	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0002	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0003	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0004	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0005	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0021	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0022	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0033	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115-1
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0034	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115-1
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0040	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0041	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0042	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0055	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0056	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0057	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0082	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0083	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0091	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0091	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart Ka	SOP Index No.: 60KA-TK11
Pollutant: VOC	Main Standard: § 60.112a(a)(2)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0092	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0092	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart Ka	SOP Index No.: 60KA-TK11
Pollutant: VOC	Main Standard: § 60.112a(a)(2)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0093	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 854-TK0093	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart Ka	SOP Index No.: 60KA-TK11
Pollutant: VOC	Main Standard: § 60.112a(a)(2)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 855-TK1022	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 855-TK1023	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: 855-TK1024	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-05
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Internal Floating Roof	
Minimum Frequency: annually	
Averaging Period: N/A	
Deviation Limit: Roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation	
Periodic Monitoring Text: Visually inspect and record the inspection of the internal floating roof to ensure: the roof is floating on the surface of the VOC and, liquid has not accumulated on the internal floating roof, the seals are not detached, and there are no holes or tears in the seal fabric. Any monitoring data in which the roof is not floating on the surface of the VOC, if liquid has accumulated on the internal floating roof, the seals are detached, or if there are holes or tears in the seal fabric shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: ENGVENT01	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: 111-ENGVENT01
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Once per week	
Averaging Period: N/A	
Deviation Limit: Presence of visible emissions is a deviation, or 20% or greater opacity is a deviation	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If a Test Method 9 is performed, the opacity limit is the corresponding opacity limit associated with the particulate matter standard in the underlying applicable requirement. If there is no corresponding opacity limit in the underlying applicable requirement, the maximum opacity will be established using the most recent performance test. If the result of the Test Method 9 is opacity above the corresponding opacity limit (associated with the particulate matter standard in the underlying applicable requirement or as identified as a result of a previous performance test to establish the maximum opacity limit), the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP1STACK	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: 111-VENT01
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Once per week	
Averaging Period: N/A	
Deviation Limit: Presence of visible emissions is a deviation, or 15% or greater opacity is a deviation	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If a Test Method 9 is performed, the opacity limit is the corresponding opacity limit associated with the particulate matter standard in the underlying applicable requirement. If there is no corresponding opacity limit in the underlying applicable requirement, the maximum opacity will be established using the most recent performance test. If the result of the Test Method 9 is opacity above the corresponding opacity limit (associated with the particulate matter standard in the underlying applicable requirement or as identified as a result of a previous performance test to establish the maximum opacity limit), the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP2STACK	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: 111-VENT01
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Once per week	
Averaging Period: N/A	
Deviation Limit: Presence of visible emissions is a deviation, or 15% or greater opacity is a deviation	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If a Test Method 9 is performed, the opacity limit is the corresponding opacity limit associated with the particulate matter standard in the underlying applicable requirement. If there is no corresponding opacity limit in the underlying applicable requirement, the maximum opacity will be established using the most recent performance test. If the result of the Test Method 9 is opacity above the corresponding opacity limit (associated with the particulate matter standard in the underlying applicable requirement or as identified as a result of a previous performance test to establish the maximum opacity limit), the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPVENDTKS	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-03
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: N/A	
Averaging Period: N/A	
Deviation Limit: Discharge opening not entirely submerged when pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPVENDTKS	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: 115TK-03
Pollutant: VOC	Main Standard: § 115.112(b)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: N/A	
Deviation Limit: Structural integrity of the pipe is in question and not repaired before refilling.	
<p>Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: PROEPSRU	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: 112-SRU01
Pollutant: SO ₂	Main Standard: § 112.7(a)
Monitoring Information	
Indicator: SO ₂ Concentration	
Minimum Frequency: Four times per hour	
Averaging Period: Hourly	
Deviation Limit: Greater than 250 ppm hourly average or greater than 250 ppm on a 12-hour rolling average.	
<p>Periodic Monitoring Text: Measure and record the concentration of SO₂ in the exhaust stream of the control device with a continuous emission monitoring system (CEMS). In addition, measure and record the oxygen or carbon dioxide content of the flue gas with a CEMS. The CEMS shall be operated in accordance with 40 CFR § 60.13 and the Performance Specifications of 40 CFR Part 60, Appendix B. The maximum sulfur dioxide concentration (specified in units of the underlying applicable requirement) is the corresponding sulfur dioxide limit associated with the emission limitation in the underlying applicable requirement. Any monitoring data above the maximum limit shall be considered and reported as a deviation.</p>	

Permit Shield

Permit Shield 446

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
065-P-35	N/A	40 CFR Part 60, Subpart IIII	Not modified or reconstructed after July 11, 2005
065-P-35	N/A	40 CFR Part 63, Subpart ZZZZ	Existing emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
065-P-36	N/A	40 CFR Part 60, Subpart IIII	Not modified or reconstructed after July 11, 2005
065-P-36	N/A	40 CFR Part 63, Subpart ZZZZ	Existing emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
065-P-37	N/A	40 CFR Part 60, Subpart IIII	Not modified or reconstructed after July 11, 2005
065-P-37	N/A	40 CFR Part 63, Subpart ZZZZ	Existing emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
065-P-38	N/A	40 CFR Part 60, Subpart IIII	Not modified or reconstructed after July 11, 2005
065-P-38	N/A	40 CFR Part 63, Subpart ZZZZ	Existing emergency stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
085-P-525	N/A	40 CFR Part 60, Subpart IIII	Not modified or reconstructed after July 11, 2005
085-P-525	N/A	40 CFR Part 63, Subpart ZZZZ	Skid mounted emergency response fire water pump, not a stationary engine
11-H1	N/A	30 TAC Chapter 112, Sulfur Compounds	Process heater does not combust liquid fuel. Refinery fuel gas is the only fuel used.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
11-V-10A	N/A	30 TAC Chapter 115, Unit Turn & Vac System-Pet Ref	Not a vacuum-producing system or hotwell.
114-P-001	N/A	40 CFR Part 60, Subpart IIII	Not modified or reconstructed after July 11, 2005
114-P-001	N/A	40 CFR Part 63, Subpart ZZZZ	Trailer mounted emergency response fire water pump, not a stationary engine
114-P-002	N/A	40 CFR Part 60, Subpart IIII	Not modified or reconstructed after July 11, 2005
114-P-002	N/A	40 CFR Part 63, Subpart ZZZZ	Trailer mounted emergency response fire water pump, not a stationary engine
114-P-003	N/A	40 CFR Part 60, Subpart IIII	Not modified or reconstructed after July 11, 2005
114-P-003	N/A	40 CFR Part 63, Subpart ZZZZ	Trailer mounted emergency response fire water pump, not a stationary engine
114-P-004	N/A	40 CFR Part 60, Subpart IIII	Not modified or reconstructed after July 11, 2005
114-P-004	N/A	40 CFR Part 63, Subpart ZZZZ	Trailer mounted emergency response fire water pump, not a stationary engine
14-H1	N/A	30 TAC Chapter 112, Sulfur Compounds	The unit does not combust liquid or solid fossil fuel.
14-H1	N/A	40 CFR Part 60, Subpart Db	The steam generating unit was constructed prior to 6/19/1984.
14-H1	N/A	40 CFR Part 60, Subpart Dc	The steam generating unit was constructed prior to 6/9/1989.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
14-R101A	N/A	40 CFR Part 60, Subpart RRR	This reactor has no vent streams as defined in 60.701.
14-R101B	N/A	40 CFR Part 60, Subpart RRR	This reactor has no vent streams as defined in 60.701.
14-R101C	N/A	40 CFR Part 60, Subpart RRR	This reactor has no vent streams as defined in 60.701.
17-V30	N/A	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
17-V30	N/A	40 CFR Part 60, Subpart NNN	The facility is not part of a process that produces any chemicals listed in 60.667 as a product, co-product, by-product, or intermediate.
17-V5	N/A	40 CFR Part 60, Subpart RRR	This reactor has no vent streams as defined in 60.701.
17-V6	N/A	40 CFR Part 60, Subpart RRR	This reactor has no vent streams as defined in 60.701.
17-V7	N/A	40 CFR Part 60, Subpart RRR	This reactor has no vent streams as defined in 60.701.
17-V8	N/A	40 CFR Part 60, Subpart RRR	This reactor has no vent streams as defined in 60.701.
18-E22	N/A	40 CFR Part 60, Subpart NNN	The facility is not part of a process that produces any chemicals listed in 60.667 as a product, co-product, by-product, or intermediate.
18-TK0101	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of 30 TAC Chapter 115, Subchapter B, Division 1.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
18-TK0101	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
18-TK0101	N/A	40 CFR Part 63, Subpart CC	The tank is less than 40 cubic meters.
18-TK0101	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
19-H1	N/A	30 TAC Chapter 112, Sulfur Compounds	The unit does not combust liquid or solid fossil fuel.
19-H2	N/A	30 TAC Chapter 112, Sulfur Compounds	The unit does not combust liquid or solid fossil fuel.
19-R1	N/A	40 CFR Part 60, Subpart RRR	This reactor has no vent streams as defined in 60.701.
19-R2	N/A	40 CFR Part 60, Subpart RRR	This reactor has no vent streams as defined in 60.701.
19-R3	N/A	40 CFR Part 60, Subpart RRR	This reactor has no vent streams as defined in 60.701.
19-R4	N/A	40 CFR Part 60, Subpart RRR	This reactor has no vent streams as defined in 60.701.
19-V10	N/A	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
19-V28	N/A	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
19-V28	N/A	40 CFR Part 60, Subpart NNN	Not constructed, modified, or reconstructed after 12/30/1983.
204-TK0001	N/A	30 TAC Chapter 115, Storage of VOCs	The tank is less than 1000 gallons.
204-TK0001	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
204-TK0001	N/A	40 CFR Part 60, Subpart Ka	Tank does not store a petroleum liquid.
204-TK0001	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
204-TK0001	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
204-TK0001	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
204-TK0001	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
204-TK0001	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
204-U942	N/A	40 CFR Part 60, Subpart VV	Equipment is located in a process unit that does not produce as an intermediate or final product any chemical listed in 40 CFR 60.489.
204-U942	N/A	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service.
204-U942	N/A	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate in VHAP service.
204-U942	N/A	40 CFR Part 63, Subpart CC	The equipment is associated with a process unit that does not meet the definition of a petroleum refining process unit because it is not used for the operations listed in 63.641.
204-U942	N/A	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
21-R1A	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
21-R1B	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
21-R2A	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
21-R2B	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
21-R3A	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
21-R3B	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
21-V55RCTR	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
21-V7	N/A	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
21-V7	N/A	40 CFR Part 60, Subpart RRR	The facility is not part of a process that produces any chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
21-V7	N/A	40 CFR Part 63, Subpart CC	Gas streams routed to the fuel gas system are excluded from definition of miscellaneous process vent.
22-V1	N/A	40 CFR Part 60, Subpart III	This reactor is not part of a process unit that produces any of the chemicals listed in 60.617 as a product, co-product, by-product, or intermediate.
22-V1	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
23-TK0002A	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5, and the tank is not equipped with an EFR.
23-TK0002A	N/A	40 CFR Part 60, Subpart K	Th tank has a storage capacity equal to or less than 40,000 gallons.
23-TK0002A	N/A	40 CFR Part 60, Subpart Ka	The tank has a storage capacity equal to or less than 40,000 gallons.
23-TK0002A	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
23-TK0002A	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
23-TK0002A	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
23-TK0002A	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
23-TK0002B	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia, and the tank is not equipped with an EFR.
23-TK0002B	N/A	40 CFR Part 60, Subpart K	The tank has a storage capacity equal to or less than 40,000 gallons.
23-TK0002B	N/A	40 CFR Part 60, Subpart Ka	The tank has a storage capacity equal to or less than 40,000 gallons.
23-TK0002B	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
23-TK0002B	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
23-TK0002B	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
23-TK0002B	N/A	40 CFR Part 63, Subpart CC	The tank does not contain any of the hazardous air pollutants listed in table 1 of this subpart.
23-TK0002B	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
23-V3	N/A	40 CFR Part 60, Subpart III	This reactor is not part of a process unit that produces any of the chemicals listed in 60.617 as a product, co-product, by-product, or intermediate.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
23-V3	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
23-V5	N/A	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
24-V2	N/A	40 CFR Part 60, Subpart III	This reactor is not part of a process unit that produces any of the chemicals listed in 60.617 as a product, co-product, by-product, or intermediate.
24-V2	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
28-V3	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
29-H1A	N/A	30 TAC Chapter 112, Sulfur Compounds	Process heaters do not combust liquid fuel. Refinery fuel gas is the only fuel used.
29-H2B	N/A	30 TAC Chapter 112, Sulfur Compounds	The unit does not combust liquid or solid fossil fuel.
29-TK0103	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of 30 TAC Chapter 115, Subchapter B, Division 1.
29-TK0103	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
29-TK0103	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
29-TK0103	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
29-TK0105	N/A	30 TAC Chapter 115, Storage of VOCs	True vapor pressure less than 1.5 psia
29-TK0105	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
29-TK0105	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
29-TK0105	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
29-TK0105	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
29-TK0105	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
29-TK0105	N/A	40 CFR Part 61, Subpart FF	The tank does not manage, treat, or store a benzene waste stream.
29-TK0105	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
29-TK0105	N/A	40 CFR Part 63, Subpart CC	The tank does not contain any of the hazardous air pollutants listed in Table 1 of this subpart.
29-TK0105	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
29-V1	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
29-V2	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
29-V26	N/A	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
29-V3	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
29-V4	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
31-R1	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
36-TK0100	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of 30 TAC Chapter 115, Subchapter B, Division 1.
36-TK0100	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
36-TK0100	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
36-TK0100	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
37-V202	N/A	40 CFR Part 60, Subpart RRR	This reactor has no vent streams as defined in 60.701.
38-COB	N/A	40 CFR Part 60, Subpart D	Not a steam generating unit
38-COB	N/A	40 CFR Part 60, Subpart J	Not a fluid catalytic cracking unit catalyst regenerator, fuel gas combustion device, or a Claus sulfur recovery plant
38-H2	N/A	30 TAC Chapter 112, Sulfur Compounds	The unit does not combust liquid or solid fossil fuel.
38-H2	N/A	40 CFR Part 60, Subpart J	The combustion device was constructed before 6/11/73 and has not been modified or reconstructed. The combustion device also fires only natural gas, which does not meet the definition of a fuel gas in 60.101(d).
38-TK0106	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
38-TK0106	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
38-V6	N/A	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
38-V6	N/A	40 CFR Part 60, Subpart III	The facility is not part of a process that produces any chemicals listed in 60.617 as a product, co-product, by-product, or intermediate.
38-V7	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
41-H1	N/A	30 TAC Chapter 112, Sulfur Compounds	Process heaters do not combust liquid fuel. Refinery fuel gas is the only fuel used.
41-H2	N/A	30 TAC Chapter 112, Sulfur Compounds	Process heaters do not combust liquid fuel. Refinery fuel gas is the only fuel used.
41-U41	N/A	40 CFR Part 60, Subpart GGG	These equipment leaks are not subject to NSPS GGG because they are subject to the requirements of MACT CC, which supersedes NSPS VV per the overlap provisions of 63.640(p).
41-U41	N/A	40 CFR Part 60, Subpart VV	These equipment leaks are not subject to NSPS VV because they are subject to the requirements of MACT CC, which supersedes NSPS VV per the overlap provisions of 63.640(p).
41-U41	N/A	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service.
41-U41	N/A	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate in VHAP service.
41-U41	N/A	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3)
47-TK0103	N/A	40 CFR Part 60, Subpart K	The tank has a storage capacity equal to or less than 40,000 gallons.
47-TK0103	N/A	40 CFR Part 60, Subpart Ka	The tank has a storage capacity equal to or less than 40,000 gallons.
47-TK0103	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
47-TK0103	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
47-TK0103	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
47-TK0103	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
47-U47	N/A	40 CFR Part 60, Subpart VV	Equipment is located in a process unit that does not produce as an intermediate or final product any chemical listed in 40 CFR 60.489.
47-U47	N/A	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service.
47-U47	N/A	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate in VHAP service.
47-U47	N/A	40 CFR Part 63, Subpart CC	The fugitive sources in this unit do not meet the definition of an "equipment leak" because they neither contain nor contact a fluid that is at least 5% by weight of total organic HAPs.
47-U47	N/A	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).
47-V-105	N/A	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
47-V-105	N/A	40 CFR Part 60, Subpart III	The facility is not part of a process that produces any chemicals listed in 60.617 as a product, co-product, by-product, or intermediate.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
47-V-105	N/A	40 CFR Part 63, Subpart CC	Gas streams routed to the fuel gas system are excluded from definition of miscellaneous process vent.
47-V104	N/A	40 CFR Part 60, Subpart III	This reactor is not part of a process unit that produces any of the chemicals listed in 60.617 as a product, co-product, by-product, or intermediate.
47-V104	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
51-TK0001	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia, and the tank is not equipped with an EFR.
51-TK0001	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
51-TK0001	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
51-TK0001	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
51-TK0001	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
51-TK0001	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
51-TK0001	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
52-R1A	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
52-R1B	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
52-R2A	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
52-R2B	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
52-R3A	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
52-R3B	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
52-U52AMNE	N/A	40 CFR Part 60, Subpart GGG	Construction and any modifications or reconstructions all commenced prior to January 4, 1983.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
52-U52AMNE	N/A	40 CFR Part 60, Subpart VV	Equipment is located in a process unit that does not produce as an intermediate or final product any chemical listed in 40 CFR 60.489.
52-U52AMNE	N/A	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service.
52-U52AMNE	N/A	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate in VHAP service.
52-U52AMNE	N/A	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).
52-U52SRU	N/A	40 CFR Part 60, Subpart GGG	Construction and any modification or reconstruction all commenced prior to January 4, 1983.
52-U52SRU	N/A	40 CFR Part 60, Subpart VV	Equipment is located in a process unit that does not produce as an intermediate or final product any chemical listed in 40 CFR 60.489.
52-U52SRU	N/A	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service.
52-U52SRU	N/A	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate in VHAP service.
52-U52SRU	N/A	40 CFR Part 63, Subpart CC	The fugitive sources in this unit do not meet the definition of an "equipment leak" because they neither contain nor contact a fluid that is at least 5% by weight of total organic HAPs.
52-U52SRU	N/A	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
52-V3A	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
52-V3B	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
53-T001	N/A	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to a fuel gas system do not meet the definition of a vent.
53-T001	N/A	40 CFR Part 60, Subpart III	The facility is not part of a process that produces any chemicals listed in 60.617 as a product, co-product, by-product, or intermediate.
53-TK0001	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia, and the tank is not equipped with an EFR.
53-TK0001	N/A	40 CFR Part 60, Subpart K	The tank has a storage capacity equal to or less than 40,000 gallons.
53-TK0001	N/A	40 CFR Part 60, Subpart Ka	The tank has a storage capacity equal to or less than 40,000 gallons.
53-TK0001	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
53-TK0001	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
53-TK0001	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
53-TK0001	N/A	40 CFR Part 63, Subpart CC	The tank does not contain any of the hazardous air pollutants listed in table 1 of this subpart.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
53-TK0001	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
53-V2	N/A	40 CFR Part 60, Subpart RRR	This reactor is not part of a process unit that produces any of the chemicals listed in 60.707 as a product, co-product, by-product, or intermediate.
54-TK0001	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.
54-TK0001	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
54-TK0001	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
54-TK0001	N/A	40 CFR Part 60, Subpart QQQ	The facility was not constructed or modified after 5/4/87.
54-TK0001	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
54-TK0001	N/A	40 CFR Part 61, Subpart FF	The sour water is not considered a "waste stream" until it exits the sour water stripper.
54-TK0001	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
54-TK0001	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
54-TK0001	N/A	40 CFR Part 63, Subpart G	This unit does not convey, receive, manage, or treat any wastewater from a CMPU.
54-TK3	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
54-TK3	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
54-TK3	N/A	40 CFR Part 60, Subpart QQQ	Sour water storage tank subject to NSPS Kb is not subject to standards for oil-water separators under NSPS QQQ.
54-TK3	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
54-TK3	N/A	40 CFR Part 61, Subpart FF	The sour water is not considered a "waste stream" until it exits the sour water stripper.
54-TK3	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
54-TK3	N/A	40 CFR Part 63, Subpart EEEE	This tank is already subject to another subpart of 40 CFR 63.
54-TK3	N/A	40 CFR Part 63, Subpart G	This unit does not convey, receive, manage, or treat any wastewater from a CMPU.
57-D7	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	Marine loading is exempt from Chapter 115 Subchapter C VOC Transfer Operations.
57-D7	N/A	40 CFR Part 61, Subpart BB	Only exempt materials under 61.300(a) are unloaded.
57-UD1	N/A	40 CFR Part 60, Subpart GGG	Construction and any modification or reconstructions all commenced prior to January 4, 1983.
57-UD1	N/A	40 CFR Part 60, Subpart VV	Construction and any modifications or reconstructions all commenced prior to January 5, 1981.
57-UD1	N/A	40 CFR Part 63, Subpart CC	The equipment is associated with a process unit that does not meet the definition of a petroleum refining process unit because it is not used for the operations listed in 63.641.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
57-UD1	N/A	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).
57-UD2	N/A	40 CFR Part 60, Subpart GGG	Construction and any modifications or reconstructions all commenced prior to January 4, 1983.
57-UD2	N/A	40 CFR Part 60, Subpart VV	Construction and any modifications or reconstructions all commenced prior to January 5, 1981.
57-UD2	N/A	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service.
57-UD2	N/A	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate in VHAP service.
57-UD2	N/A	40 CFR Part 63, Subpart CC	The equipment is associated with a process unit that does not meet the definition of a petroleum refining process unit because it is not used for the operations listed in 63.641.
57-UD2	N/A	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).
57-UDMEC	N/A	40 CFR Part 60, Subpart GGG	This facility is subject to 40 CFR Part 60, Subpart VV.
57-UDMEC	N/A	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service.
57-UDMEC	N/A	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate in VHAP service.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
57-UDMEC	N/A	40 CFR Part 63, Subpart CC	The equipment is associated with a process unit that does not meet the definition of a petroleum refining process unit because it is not used for the operations listed in 63.641.
57-UDMEC	N/A	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).
61-B3E	N/A	30 TAC Chapter 112, Sulfur Compounds	This boiler does not combust liquid or solid fossil fuel.
61-B3E	N/A	40 CFR Part 60, Subpart Dc	This boiler has a heat input of greater than 100 MMBtu/hr.
64-TK0013	N/A	40 CFR Part 60, Subpart K	The tank has a storage capacity equal to or less than 40,000 gallons.
64-TK0013	N/A	40 CFR Part 60, Subpart Ka	The tank has a storage capacity equal to or less than 40,000 gallons.
64-TK0013	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
64-TK0013	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
64-TK0013	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
64-TK0013	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
64-TK0013	N/A	40 CFR Part 63, Subpart EEEE	These tanks store a liquid that does not meet the definition of "organic liquid" (because of HAP content, excluded materials, or low vapor pressure) under MACT EEEE.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
64-TK0013	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
65-TK0107	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of 30 TAC Chapter 115, Subchapter B, Division 1.
65-TK0107	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
65-TK0107	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
65-TK0107	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
65-TK0108	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of 30 TAC Chapter 115, Subchapter B, Division 1.
65-TK0108	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
65-TK0108	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
65-TK0108	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
65-TK0109	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of 30 TAC Chapter 115, Subchapter B, Division 1.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
65-TK0109	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
65-TK0109	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
65-TK0109	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
65-TK0110	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of 30 TAC Chapter 115, Subchapter B, Division 1.
65-TK0110	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
65-TK0110	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
65-TK0110	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
66-TK0100	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of 30 TAC Chapter 115, Subchapter B, Division 1.
66-TK0100	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
66-TK0100	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
66-TK0100	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
73-U73F	N/A	40 CFR Part 60, Subpart GGG	Construction and any modifications or reconstructions all commenced prior to January 4, 1983.
73-U73F	N/A	40 CFR Part 60, Subpart VV	Construction and any modifications or reconstructions all commenced prior to January 5, 1981.
73-U73F	N/A	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service.
73-U73F	N/A	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate in VHAP service.
73-U73F	N/A	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).
73-V11	N/A	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to a fuel gas system do not meet the definition of a vent.
80-DSW	N/A	40 CFR Part 60, Subpart GGG	Equipment in the unit is not an affected facility because the unit does not meet the definition of a process unit in 60.591 since intermediate or final products from petroleum, unfinished petroleum derivatives, or other intermediates are not produced
80-DSW	N/A	40 CFR Part 63, Subpart CC	The equipment is associated with a process unit that does not meet the definition or a petroleum refining process unit because it is not used for the operations listed in 63.641.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
80-DSW	N/A	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).
82-CPI	N/A	40 CFR Part 63, Subpart CC	This oil/water separator does not manage any Group I stream as defined by 63.641.
82-CPI	N/A	40 CFR Part 63, Subpart VV	Subparts of applicable oil-water separator standards found in 40 CFR 60, 61, and 63 do not refer this separator to this subpart.
82-TK0114	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.
82-TK0114	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
82-TK0114	N/A	40 CFR Part 60, Subpart Ka	The tank does not store petroleum liquid.
82-TK0114	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
82-TK0114	N/A	40 CFR Part 60, Subpart QQQ	This tank is already subject to the provisions of 40 CFR 63, Subpart CC.
82-TK0114	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
82-TK0114	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
82-TK0114	N/A	40 CFR Part 63, Subpart CC	Tank capacity is less than 40 cubic meters.
82-TK0114	N/A	40 CFR Part 63, Subpart EEEE	Does not store an organic liquid, as defined by 63.2406.
82-TK0114	N/A	40 CFR Part 63, Subpart G	This unit does not convey, receive, manage, or treat any wastewater from a CMPU.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
82-TK0115	N/A	30 TAC Chapter 115, Storage of VOCs	This tank stores product with a vapor pressure below 1 psia.
82-TK0115	N/A	40 CFR Part 60, Subpart K	Tank does not store a petroleum liquid.
82-TK0115	N/A	40 CFR Part 60, Subpart Ka	The tank does not store petroleum liquid.
82-TK0115	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
82-TK0115	N/A	40 CFR Part 60, Subpart QQQ	This unit is not an oil-water separator or aggregate facility as defined in NSPS Subpart QQQ.
82-TK0115	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
82-TK0115	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
82-TK0115	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
82-TK0115	N/A	40 CFR Part 63, Subpart G	This unit does not convey, receive, manage, or treat any wastewater from a CMPU.
82-TK0116	N/A	30 TAC Chapter 115, Storage of VOCs	This tank stores product with a vapor pressure below 1 psia.
82-TK0116	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
82-TK0116	N/A	40 CFR Part 60, Subpart Ka	The tank does not store petroleum liquid.
82-TK0116	N/A	40 CFR Part 60, Subpart QQQ	This unit is not an oil-water separator or aggregate facility as defined in NSPS Subpart QQQ.
82-TK0116	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
82-TK0116	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
82-TK0116	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
82-TK0116	N/A	40 CFR Part 63, Subpart G	This unit does not convey, receive, manage, or treat any wastewater from a CMPU.
82-TK0117	N/A	30 TAC Chapter 115, Storage of VOCs	This tank stores product with a vapor pressure below 1 psia.
82-TK0117	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
82-TK0117	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
82-TK0117	N/A	40 CFR Part 60, Subpart QQQ	This unit is not an oil-water separator or aggregate facility as defined in this Subpart.
82-TK0117	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
82-TK0117	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
82-TK0117	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
82-TK0117	N/A	40 CFR Part 63, Subpart G	This unit does not convey, receive, manage, or treat any wastewater from a CMPU.
82-TK0605	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is <1.5 psia and the tank is not equipped with an EFR.
82-TK0605	N/A	40 CFR Part 60, Subpart K	Tank does not store a petroleum liquid.
82-TK0605	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
82-TK0605	N/A	40 CFR Part 60, Subpart Kb	Vessel with a capacity greater than or equal to 151 cubic meters stores a liquid with a MTVP less than 3.5 Kpa.
82-TK0605	N/A	40 CFR Part 60, Subpart QQQ	This tank is already subject to the provisions of 40 CFR 63, Subpart CC.
82-TK0605	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
82-TK0605	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
82-TK0605	N/A	40 CFR Part 63, Subpart G	This unit does not convey, receive, manage, or treat any wastewater from a CMPU.
82-TK0606	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
82-TK0606	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
82-TK0606	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
82-TK0606	N/A	40 CFR Part 60, Subpart Kb	Vessel with a capacity greater than or equal to 151 cubic meters stores a liquid with a MTVP less than 3.5 Kpa.
82-TK0606	N/A	40 CFR Part 60, Subpart QQQ	This tank is already subject to the provisions of 40 CFR 63, Subpart CC.
82-TK0606	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
82-TK0606	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
82-TK0606	N/A	40 CFR Part 63, Subpart G	This unit does not convey, receive, manage, or treat any wastewater from a CMPU.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
82-TK0607	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
82-TK0607	N/A	40 CFR Part 60, Subpart K	Tank does not store a petroleum liquid.
82-TK0607	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
82-TK0607	N/A	40 CFR Part 60, Subpart Kb	Vessel with a capacity greater than or equal to 151 cubic meters stores a liquid with a MTVP less than 3.5 Kpa.
82-TK0607	N/A	40 CFR Part 60, Subpart QQQ	This tank is already subject to the provisions of 40 CFR 63, Subpart CC.
82-TK0607	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
82-TK0607	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
82-TK0607	N/A	40 CFR Part 63, Subpart G	This unit does not convey, receive, manage, or treat any wastewater from a CMPU.
82-TK0608	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
82-TK0608	N/A	40 CFR Part 60, Subpart K	Tank does not store a petroleum liquid.
82-TK0608	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
82-TK0608	N/A	40 CFR Part 60, Subpart Kb	Vessel with a capacity greater than or equal to 151 cubic meters stores a liquid with a MTVP less than 3.5 Kpa.
82-TK0608	N/A	40 CFR Part 60, Subpart QQQ	This tank is already subject to the provisions of 40 CFR 63, subpart CC.
82-TK0608	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
82-TK0608	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
82-TK0608	N/A	40 CFR Part 63, Subpart G	This unit does not convey, receive, manage, or treat any wastewater from a CMPU.
82-TK0616	N/A	30 TAC Chapter 115, Storage of VOCs	The maximum true vapor pressure is less than 1.5 psia and the tank is not equipped with an external floating roof.
82-TK0616	N/A	40 CFR Part 60, Subpart K	Tank does not store a petroleum liquid.
82-TK0616	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
82-TK0616	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
82-TK0616	N/A	40 CFR Part 60, Subpart QQQ	This unit is not an oil-water separator or aggregate facility as defined in NSPS Subpart QQQ.
82-TK0616	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
82-TK0616	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
82-TK0616	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
82-TK0616	N/A	40 CFR Part 63, Subpart EEEE	Does not store an organic liquid, as defined by 63.2406.
82-TK0616	N/A	40 CFR Part 63, Subpart G	This unit does not convey, receive, manage, or treat any wastewater from a CMPU.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
82-TK0617	N/A	30 TAC Chapter 115, Storage of VOCs	The maximum true vapor pressure is less than 1.5 psia and the tank is not equipped with an external floating roof.
82-TK0617	N/A	40 CFR Part 60, Subpart K	Tank does not store a petroleum liquid.
82-TK0617	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
82-TK0617	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
82-TK0617	N/A	40 CFR Part 60, Subpart QQQ	This unit is not an oil-water separator or aggregate facility as defined in NSPS Subpart QQQ.
82-TK0617	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
82-TK0617	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
82-TK0617	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
82-TK0617	N/A	40 CFR Part 63, Subpart EEEE	Does not store an organic liquid, as defined by 63.2406.
82-TK0617	N/A	40 CFR Part 63, Subpart G	This unit does not convey, receive, manage, or treat any wastewater from a CMPU.
82-TK0618	N/A	30 TAC Chapter 115, Storage of VOCs	The maximum true vapor pressure is less than 1.5 psia and the tank is not equipped with an external floating roof.
82-TK0618	N/A	40 CFR Part 60, Subpart K	Tank does not store a petroleum liquid.
82-TK0618	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
82-TK0618	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
82-TK0618	N/A	40 CFR Part 60, Subpart QQQ	This unit is not an oil-water separator or aggregate facility as defined in NSPS Subpart QQQ.
82-TK0618	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
82-TK0618	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
82-TK0618	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
82-TK0618	N/A	40 CFR Part 63, Subpart EEEE	Does not store an organic liquid, as defined by 63.2406.
82-TK0618	N/A	40 CFR Part 63, Subpart G	This unit does not convey, receive, manage, or treat any wastewater from a CMPU.
83-R1	N/A	40 CFR Part 60, Subpart RRR	This reactor was constructed prior to 6/29/1990 and has not been modified or reconstructed.
83-R2	N/A	40 CFR Part 60, Subpart RRR	This reactor was constructed prior to 6/29/1990 and has not been modified or reconstructed.
83-V105	N/A	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
83-V105	N/A	40 CFR Part 60, Subpart NNN	Not constructed, modified, or re-constructed after 12/30/1983.
83-V105	N/A	40 CFR Part 63, Subpart CC	Gas streams routed to the fuel gas system are excluded from definition of miscellaneous process vent.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
85-TK0190	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of 30 TAC Chapter 115, Subchapter B, Division 1.
85-TK0190	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
85-TK0190	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
85-TK0190	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
85-TK0191	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with storage capacity less than or equal to 1,000 gallons is exempt from the requirements of 30 TAC Chapter 115, Subchapter B, Division 1.
85-TK0191	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters.
85-TK0191	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
85-TK0191	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
851-TK0925	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
851-TK0925	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
851-TK0925	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
851-TK0925	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
851-TK0925	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
851-TK0925	N/A	40 CFR Part 63, Subpart G	The tank does not use as a reactant, or manufacture as a product or co-product, one or more of the organic hazardous air pollutants listed in Table 2 of this subpart.
851-TK0926	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility
851-TK0926	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
851-TK0926	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
851-TK0926	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
851-TK0926	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
851-TK0926	N/A	40 CFR Part 63, Subpart G	The tank does not use as a reactant, or manufacture as a product or co-product, one or more of the organic hazardous air pollutants listed in Table 2 of this subpart.
851-TK0927	N/A	40 CFR Part 60, Subpart K	The tank was built on or after 5/16/78.
851-TK0927	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
851-TK0927	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
851-TK0927	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
851-TK0927	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
851-TK0927	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
851-TK0927	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
851-TK0927	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
851-TK0928	N/A	40 CFR Part 60, Subpart K	The tank was built on or after 5/19/78.
851-TK0928	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
851-TK0928	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
851-TK0928	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
851-TK0928	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
851-TK0928	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
851-TK0928	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
851-TK0928	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
851-TK0929	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
851-TK0929	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
851-TK0929	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
851-TK0929	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
851-TK0929	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
851-TK0929	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
851-TK0929	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
851-TK0929	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
851-TK0929	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
851-TK0929	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
851-TK0930	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
851-TK0930	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
851-TK0930	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
851-TK0930	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
851-TK0930	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
851-TK0930	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
851-TK0930	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
851-TK0930	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
851-TK0930	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
851-TK0930	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
851-TK1029	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
851-TK1029	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
851-TK1029	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
851-TK1029	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
851-TK1030	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
851-TK1030	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
851-TK1030	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
851-TK1030	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
851-TK1031	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
851-TK1031	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
851-TK1031	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
851-TK1031	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
851-TK1031	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
851-TK1031	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
851-TK1031	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
851-TK1032	N/A	30 TAC Chapter 115, Storage of VOCs	The maximum true vapor pressure is less than 1.5 psia and the tank is not equipped with an external floating roof.
851-TK1032	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
851-TK1032	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
851-TK1032	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK0201	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK0201	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0201	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0201	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK0202	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK0202	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0202	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0202	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK0211	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK0211	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
852-TK0211	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0211	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
852-TK0211	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0211	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
852-TK0211	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK0212	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK0212	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
852-TK0212	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0212	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK0212	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0212	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
852-TK0212	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK0221	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK0221	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
852-TK0221	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0221	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
852-TK0221	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0221	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
852-TK0221	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK0222	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK0222	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
852-TK0222	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0222	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK0222	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0222	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
852-TK0222	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK0223	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK0223	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
852-TK0223	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0223	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
852-TK0223	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0223	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
852-TK0223	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK0224	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK0224	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0224	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0225	N/A	40 CFR Part 60, Subpart K	The tank was built on or after 5/19/78.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK0225	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0225	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0226	N/A	40 CFR Part 60, Subpart K	The tank was built on or after 5/19/78.
852-TK0226	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0226	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0301	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK0301	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0301	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0301	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
852-TK0301	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK0302	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK0302	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0302	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0302	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK0401	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK0401	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0401	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0401	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK0402	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK0402	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
852-TK0402	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0402	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
852-TK0402	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0402	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
852-TK0402	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK0403	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK0403	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
852-TK0403	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0403	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK0403	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0403	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
852-TK0403	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK0620	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.
852-TK0620	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
852-TK0620	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
852-TK0620	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
852-TK0620	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0620	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0620	N/A	40 CFR Part 63, Subpart G	The tank does not use as a reactant, or manufacture as a product or co-product, one or more of the organic hazardous air pollutants listed in Table 2 of this subpart.
852-TK0621	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.
852-TK0621	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK0621	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
852-TK0621	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
852-TK0621	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0621	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0621	N/A	40 CFR Part 63, Subpart G	The tank does not use as a reactant, or manufacture as a product or co-product, one or more of the organic hazardous air pollutants listed in Table 2 of this subpart.
852-TK0804	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
852-TK0804	N/A	40 CFR Part 60, Subpart QQQ	Tanks subject to NSPS K, Ka, or Kb are not subject to NSPS QQQ.
852-TK0804	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0804	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0804	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
852-TK0901	N/A	30 TAC Chapter 115, Storage of VOCs	This tank is part of a motor vehicle fuel dispensing facility and has a nominal capacity less than 25,000 gallons.
852-TK0901	N/A	40 CFR Part 60, Subpart K	The tank has a storage capacity equal to or less than 40,000 gallons.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK0901	N/A	40 CFR Part 60, Subpart Ka	The tank has a storage capacity equal to or less than 40,000 gallons.
852-TK0901	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
852-TK0901	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK0901	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK0901	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
852-TK0901	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK1001	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
852-TK1001	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK1001	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
852-TK1001	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
852-TK1001	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK1001	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK1001	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK1001	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK1002	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
852-TK1002	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK1002	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
852-TK1002	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
852-TK1002	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK1002	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK1002	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK1003	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.
852-TK1003	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK1003	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
852-TK1003	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
852-TK1003	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK1003	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK1003	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK1009	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK1009	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK1009	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK1009	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
852-TK1009	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK1010	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
852-TK1010	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK1010	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
852-TK1010	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
852-TK1010	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK1010	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK1010	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
852-TK1010	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK1015	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.
852-TK1015	N/A	40 CFR Part 60, Subpart K	The tank was built on or after 5/19/78.
852-TK1015	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
852-TK1015	N/A	40 CFR Part 60, Subpart Kb	This tank has a storage capacity greater or equal to 151 cubic meters and stores a liquid with maximum true vapor pressure less than 3.5 kPa.
852-TK1015	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK1015	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK1015	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK1016	N/A	40 CFR Part 60, Subpart K	The tank was built on or after 5/19/78.
852-TK1016	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK1016	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK1016	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK1017	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
852-TK1017	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK1017	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
852-TK1017	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
852-TK1017	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK1017	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK1017	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
852-TK1017	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK1018	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
852-TK1018	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK1018	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
852-TK1018	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK1018	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK1018	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK1018	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK1019	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
852-TK1019	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK1019	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
852-TK1019	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
852-TK1019	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK1019	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK1019	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK1020	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
852-TK1020	N/A	40 CFR Part 60, Subpart K	The tank was built on or after 5/19/78.
852-TK1020	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
852-TK1020	N/A	40 CFR Part 60, Subpart Kb	This tank has a storage capacity greater or equal to 151 cubic meters and stores a liquid with maximum true vapor pressure less than 3.5 kPa.
852-TK1020	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK1020	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK1020	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
852-TK1028	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
852-TK1028	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
852-TK1028	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
852-TK1028	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
852-TK1028	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
852-TK1028	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
852-TK1028	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
853-TK2001	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
853-TK2001	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
853-TK2001	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
853-TK2001	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
853-TK2001	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
853-TK2001	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
853-TK2001	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
853-TK2002	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
853-TK2002	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
853-TK2002	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
853-TK2002	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
853-TK2002	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
853-TK2003	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.
853-TK2003	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
853-TK2003	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
853-TK2003	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
853-TK2003	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
853-TK2003	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
853-TK2003	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
853-TK2005	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.
853-TK2005	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
853-TK2005	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
853-TK2005	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
853-TK2005	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
853-TK2005	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
853-TK2005	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
853-TK2006	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
853-TK2006	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
853-TK2006	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
853-TK2006	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
853-TK2006	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
853-TK2006	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
853-TK2006	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
853-TK3101	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.
853-TK3101	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
853-TK3101	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
853-TK3101	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
853-TK3101	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
853-TK3101	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
853-TK3101	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
853-TK3102	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.
853-TK3102	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
853-TK3102	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
853-TK3102	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
853-TK3102	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
853-TK3102	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
853-TK3102	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
854-TK0001	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0001	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0001	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0002	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0002	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0002	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0002	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0002	N/A	40 CFR Part 61, Subpart Y	The tank is already subject to 40 CFR 63, Subpart G.
854-TK0002	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
854-TK0003	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0003	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0003	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0004	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0004	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0004	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0004	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0004	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0004	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
854-TK0004	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
854-TK0005	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0005	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0005	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0011	N/A	30 TAC Chapter 115, Storage of VOCs	Storage tank storing a VOC with a true vapor pressure less than 1.0 psia.
854-TK0011	N/A	40 CFR Part 60, Subpart Kb	Tank does not store a VOL with a vapor pressure greater than 3.5 kPa.
854-TK0011	N/A	40 CFR Part 63, Subpart CC	Tank does not store a Table 1 HAP.
854-TK0012	N/A	30 TAC Chapter 115, Storage of VOCs	Storage tank storing a VOC with a true vapor pressure less than 1.0 psia.
854-TK0012	N/A	40 CFR Part 60, Subpart Kb	Tank does not store a VOL with a vapor pressure greater than 3.5 kPa.
854-TK0012	N/A	40 CFR Part 63, Subpart CC	Tank does not store a Table 1 HAP.
854-TK0013	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
854-TK0013	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0013	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/1978 and 7/22/1984.
854-TK0013	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0013	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0013	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0013	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
854-TK0013	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0014	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia, and the tank is not equipped with an EFR.
854-TK0014	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0014	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0014	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0014	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0014	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0014	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
854-TK0020	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
854-TK0020	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0020	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0020	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0020	N/A	40 CFR Part 60, Subpart QQQ	Not a wastewater source.
854-TK0020	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0020	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0020	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0020	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
854-TK0020	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
854-TK0021	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0021	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0021	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0021	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0021	N/A	40 CFR Part 61, Subpart Y	The tank is already subject to 40 CFR 63, Subpart G.
854-TK0021	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
854-TK0021	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
854-TK0022	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0022	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0022	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0022	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0022	N/A	40 CFR Part 61, Subpart FF	Does not store benzene waste.
854-TK0022	N/A	40 CFR Part 61, Subpart Y	The tank is already subject to 40 CFR 63, Subpart G.
854-TK0022	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
854-TK0022	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
854-TK0033	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0033	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0033	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0033	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0033	N/A	40 CFR Part 61, Subpart Y	The tank is already subject to 40 CFR 63, Subpart G.
854-TK0033	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
854-TK0034	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0034	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0034	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0034	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0034	N/A	40 CFR Part 61, Subpart Y	The tank is already subject to 40 CFR 63, Subpart G.
854-TK0034	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
854-TK0040	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0040	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0040	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0040	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0040	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0040	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I
854-TK0040	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
854-TK0041	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0041	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0041	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0041	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0041	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0041	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I
854-TK0041	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
854-TK0042	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0042	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0042	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0042	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0042	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0042	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I
854-TK0042	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
854-TK0043	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia, and the tank is not equipped with an EFR.
854-TK0043	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0043	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0043	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0043	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0043	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0043	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
854-TK0043	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0043	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
854-TK0043	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
854-TK0044	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia, and the tank is not equipped with an EFR.
854-TK0044	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0044	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0044	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0044	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
854-TK0044	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0044	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
854-TK0044	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0044	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0044	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
854-TK0045	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia, and the tank is not equipped with an EFR.
854-TK0045	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0045	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0045	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0045	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
854-TK0045	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0045	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
854-TK0045	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0045	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
854-TK0045	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
854-TK0050	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.
854-TK0050	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0050	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0050	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0050	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
854-TK0050	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0050	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
854-TK0050	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0050	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
854-TK0050	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
854-TK0055	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
854-TK0055	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0055	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0055	N/A	40 CFR Part 60, Subpart QQQ	The facility was not constructed or modified after 5/4/87.
854-TK0055	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0055	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0055	N/A	40 CFR Part 63, Subpart CC	The unit is already subject to wastewater under Subparts F, G, H, or, I.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0055	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
854-TK0056	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0056	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0056	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0057	N/A	40 CFR Part 60, Subpart K	The tank stores less than 65,000 gallons and was not built between 3/8/74 & 5/18/78.
854-TK0057	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0057	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0057	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
854-TK0057	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
854-TK0060	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia, and the tank is not equipped with an EFR.
854-TK0060	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
854-TK0060	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
854-TK0060	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0060	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0060	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0060	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
854-TK0061	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia, and the tank is not equipped with an EFR.
854-TK0061	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
854-TK0061	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
854-TK0061	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0061	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0061	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0061	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
854-TK0062	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia, and the tank is not equipped with an EFR.
854-TK0062	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
854-TK0062	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
854-TK0062	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0062	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0062	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0062	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
854-TK0063	N/A	30 TAC Chapter 115, Storage of VOCs	The tank holds less than 1000 gallons.
854-TK0063	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
854-TK0063	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
854-TK0063	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
854-TK0063	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0063	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0063	N/A	40 CFR Part 63, Subpart CC	The tank does not feed a petroleum refining unit or receive product from a petroleum refining unit.
854-TK0081	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia, and the tank is not equipped with an EFR.
854-TK0081	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0081	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
854-TK0081	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0081	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0081	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0081	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
854-TK0082	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0082	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0082	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0082	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
854-TK0083	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
854-TK0083	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0083	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0083	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
854-TK0091	N/A	40 CFR Part 60, Subpart K	The tank was built after 5/18/78.
854-TK0091	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0091	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0091	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0091	N/A	40 CFR Part 63, Subpart CC	The tank does not contain any of the hazardous air pollutants listed in table 1 of this subpart.
854-TK0091	N/A	40 CFR Part 63, Subpart EEEE	These tanks store a liquid that does not meet the definition of "organic liquid" (because of HAP content, excluded materials, or low vapor pressure) under MACT EEEE.
854-TK0091	N/A	40 CFR Part 63, Subpart G	The tank does not contain any Table 2 OHAPs in a form other than impurities.
854-TK0092	N/A	40 CFR Part 60, Subpart K	The tank was built after 5/18/78.
854-TK0092	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
854-TK0092	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0092	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0092	N/A	40 CFR Part 63, Subpart CC	The tank does not contain any of the hazardous air pollutants listed in table 1 of this subpart.
854-TK0092	N/A	40 CFR Part 63, Subpart EEEE	These tanks store a liquid that does not meet the definition of "organic liquid" (because of HAP content, excluded materials, or low vapor pressure) under MACT EEEE.
854-TK0092	N/A	40 CFR Part 63, Subpart G	The tank does not contain any Table 2 organic HAPs in a form other than impurities.
854-TK0093	N/A	40 CFR Part 60, Subpart K	The tank was built after 5/18/78 (per applicability to Kb).
854-TK0093	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
854-TK0093	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
854-TK0093	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
854-TK0093	N/A	40 CFR Part 63, Subpart CC	The tank does not contain any Refinery MACT Table 1 OHAPS.
854-TK0093	N/A	40 CFR Part 63, Subpart EEEE	These tanks store a liquid that does not meet the definition of "organic liquid" (because of HAP content, excluded materials, or low vapor pressure) under MACT EEEE.
854-TK0093	N/A	40 CFR Part 63, Subpart G	The tank does not contain any Table 2 OHAPs in a form other than impurities.
855-TK1018	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
855-TK1018	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
855-TK1018	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
855-TK1018	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
855-TK1018	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
855-TK1018	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
855-TK1018	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
855-TK1019	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an EFR.
855-TK1019	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
855-TK1019	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
855-TK1019	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
855-TK1019	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
855-TK1019	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
855-TK1019	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
855-TK1022	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
855-TK1022	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
855-TK1022	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
855-TK1022	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
855-TK1023	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
855-TK1023	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
855-TK1023	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
855-TK1023	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
855-TK1023	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
855-TK1024	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
855-TK1024	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
855-TK1024	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
855-TK1024	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
855-TK1025	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.
855-TK1025	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
855-TK1025	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
855-TK1025	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
855-TK1025	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
855-TK1025	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
855-TK1025	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
855-TK1026	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.
855-TK1026	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
855-TK1026	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
855-TK1026	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
855-TK1026	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
855-TK1026	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
855-TK1026	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
855-TK1027	N/A	40 CFR Part 60, Subpart K	The tank was built on or before 6/11/73.
855-TK1027	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
855-TK1027	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
855-TK1027	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
855-TK1027	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I
855-TK1027	N/A	40 CFR Part 63, Subpart EEEE	The tank is already subject to another subpart of 40 CFR 63.
855-TK1040	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia and the tank is not equipped with an external floating roof.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
855-TK1040	N/A	40 CFR Part 60, Subpart K	The tank was built on or after 5/19/78.
855-TK1040	N/A	40 CFR Part 60, Subpart Ka	The tank was not constructed, reconstructed, or modified between 5/19/78 & 7/22/84.
855-TK1040	N/A	40 CFR Part 60, Subpart Kb	The tank with a storage capacity of greater than or equal to 151 cubic meters stores product with a vapor pressure less than 3.5 kPa.
855-TK1040	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
855-TK1040	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
855-TK1040	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
855-TK1041	N/A	30 TAC Chapter 115, Storage of VOCs	This tank stores product with a vapor pressure below 1 psia.
855-TK1041	N/A	40 CFR Part 60, Subpart K	The tank was built on or after 5/19/78.
855-TK1041	N/A	40 CFR Part 60, Subpart Ka	Maximum vapor pressure of petroleum liquid stored does not exceed 1.0 psia.
855-TK1041	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
855-TK1041	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
855-TK1041	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
855-TK1041	N/A	40 CFR Part 63, Subpart CC	The tank is already subject to Subparts F, G, H, or I.
855-TK1042	N/A	40 CFR Part 60, Subpart K	The tank was built on or after 5/19/78.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
855-TK1042	N/A	40 CFR Part 60, Subpart Kb	The tank was not constructed, reconstructed, or modified after 7/23/1984.
855-TK1042	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
855-TK1042	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
855-TK1042	N/A	40 CFR Part 63, Subpart CC	The tank does not contain any of the hazardous air pollutants listed in table 1 of this subpart.
89-TK0180	N/A	30 TAC Chapter 115, Storage of VOCs	The tank holds less than 1000 gallons.
89-TK0180	N/A	40 CFR Part 60, Subpart K	The tank has a storage capacity equal to or less than 40,000 gallons.
89-TK0180	N/A	40 CFR Part 60, Subpart Ka	The tank has a storage capacity equal to or less than 40,000 gallons.
89-TK0180	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
89-TK0180	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
89-TK0180	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
89-TK0180	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
89-TK0180	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
89-TK0180	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
89-TK0180	N/A	40 CFR Part 63, Subpart EEEE	These tanks store a liquid that does not meet the definition of "organic liquid" (because of HAP content, excluded materials, or low vapor pressure) under MACT EEEE.
89-TK0180	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
89-U89	N/A	40 CFR Part 60, Subpart GGG	Equipment in this unit is not an affected facility because it does not meet the definition of a process unit in 60.591 since intermediate or final products from petroleum, unfinished petroleum derivatives, or other intermediates are not produced
89-U89	N/A	40 CFR Part 60, Subpart VV	Equipment is located in a process unit that does not produce as an intermediate or final product any chemical listed in 40 CFR 60.489.
89-U89	N/A	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service.
89-U89	N/A	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate in VHAP service.
89-U89	N/A	40 CFR Part 63, Subpart CC	The equipment is associated with a process unit that does not meet the definition of a petroleum refining process unit because it is not used for the operations listed in 63.641.
89-U89	N/A	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).
90-TK0103	N/A	30 TAC Chapter 115, Storage of VOCs	The tank holds less than 1000 gallons.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
90-TK0103	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
90-TK0103	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
90-TK0103	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
90-TK0103	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
90-TK0103	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
90-TK0103	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
90-TK0103	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
90-TK0103	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
90-TK0103	N/A	40 CFR Part 63, Subpart EEEE	The tank does not store an organic liquid, as defined in 63.2406.
90-TK0104	N/A	30 TAC Chapter 115, Storage of VOCs	The tank holds less than 1000 gallons.
90-TK0104	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
90-TK0104	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid
90-TK0104	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
90-TK0104	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
90-TK0104	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
90-TK0104	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
90-TK0104	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
90-TK0104	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
90-TK0104	N/A	40 CFR Part 63, Subpart EEEE	The tank does not store an organic liquid, as defined in 63.2406.
90-TK0104	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
90-TK0105	N/A	30 TAC Chapter 115, Storage of VOCs	The tank holds less than 1000 gallons.
90-TK0105	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
90-TK0105	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
90-TK0105	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
90-TK0105	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
90-TK0105	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
90-TK0105	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
90-TK0105	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
90-TK0105	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
90-TK0105	N/A	40 CFR Part 63, Subpart EEEE	The tank does not store an organic liquid, as defined in 63.2406.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
90-TK0105	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
90-UD3	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	Marine unloading is exempted from 30 TAC Chapter 115, Subchapter C, Division 1, Loading and Unloading of VOC.
90-UD3	N/A	40 CFR Part 61, Subpart BB	Only unloading is conducted at this dock.
90-UD3	N/A	40 CFR Part 63, Subpart CC	Only unloading is conducted at this dock.
90-UD3	N/A	40 CFR Part 63, Subpart Y	Only unloading is conducted at this dock.
91-TK0103	N/A	30 TAC Chapter 115, Storage of VOCs	The tank holds less than 1000 gallons.
91-TK0103	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
91-TK0103	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
91-TK0103	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
91-TK0103	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
91-TK0103	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
91-TK0103	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
91-TK0103	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
91-TK0103	N/A	40 CFR Part 63, Subpart EEEE	The tank does not store an organic liquid, as defined in 63.2406.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
91-TK0103	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
91-TK0104	N/A	30 TAC Chapter 115, Storage of VOCs	The tank holds less than 1000 gallons.
91-TK0104	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
91-TK0104	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
91-TK0104	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
91-TK0104	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
91-TK0104	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
91-TK0104	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.
91-TK0104	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
91-TK0104	N/A	40 CFR Part 63, Subpart EEEE	The tank does not store an organic liquid, as defined in 63.2406.
91-TK0104	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
911-H	N/A	30 TAC Chapter 112, Sulfur Compounds	The unit does not combust liquid or solid fossil fuel.
911-H	N/A	40 CFR Part 60, Subpart Db	The steam generating unit was constructed prior to 6/19/1984.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
911-H	N/A	40 CFR Part 60, Subpart Dc	The steam generating unit was constructed prior to 6/9/1989.
97-D3FUG	N/A	40 CFR Part 60, Subpart GGG	This unit is not an affected facility because it does not meet the definition of a process unit in 60.591 since intermediate or final products from petroleum, unfinished petroleum derivatives, or other intermediates are not produced
97-D3FUG	N/A	40 CFR Part 60, Subpart VV	Equipment is located in a process unit that does not produce as an intermediate or final product any chemical listed in 40 CFR 60.489.
97-D3FUG	N/A	40 CFR Part 61, Subpart J	Equipment associated with unit is not intended to operate in benzene service.
97-D3FUG	N/A	40 CFR Part 61, Subpart V	Equipment associated with the unit is not intended to operate in VHAP service.
97-D3FUG	N/A	40 CFR Part 63, Subpart CC	The equipment is associated with a process unit that does not meet the definition of a petroleum refining process unit because it is not used for the operations listed in 63.641.
97-D3FUG	N/A	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).
97-TK0103	N/A	30 TAC Chapter 115, Storage of VOCs	The tank holds less than 1000 gallons.
97-TK0103	N/A	40 CFR Part 60, Subpart K	The tank does not store a petroleum liquid.
97-TK0103	N/A	40 CFR Part 60, Subpart Ka	The tank does not store a petroleum liquid.
97-TK0103	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
97-TK0103	N/A	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
97-TK0103	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
97-TK0103	N/A	40 CFR Part 61, Subpart FF	This tank does not manage, treat, or store a benzene waste stream.
97-TK0103	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
97-TK0103	N/A	40 CFR Part 63, Subpart EEEE	The tank does not store an organic liquid, as defined in 63.2406.
97-TK0103	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
CAUSTLOAD	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	This loading operation is not a VOC transfer operation because inorganic materials are loaded.
GASUNLOAD	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	Motor vehicle fuel dispensing facilities, as defined in 30 TAC 101.1, are exempt from the requirements of 30 TAC 115, Subchapter C, Division 1.
GRP-CCVT1	18-V13, 18-V62, 28-V16, 29-V106, 73-V6, 73-V7	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
GRP-CCVT1	18-V13, 18-V62, 28-V16, 29-V106, 73-V6, 73-V7	40 CFR Part 63, Subpart CC	Gas streams routed to the fuel gas system are excluded from definition of miscellaneous process vent.
GRP-CCVT2	21-V2, 21-V20, 21-V27, 21-V39, 21-V51, 37-V33, 73-V15, 73-V17	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-CCVT2	21-V2, 21-V20, 21-V27, 21-V39, 21-V51, 37-V33, 73-V15, 73-V17	40 CFR Part 63, Subpart CC	Gas streams routed to the fuel gas system are excluded from definition of miscellaneous process vent.
GRP-CCVT3	18-V71, 29-V13	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
GRP-CCVT3	18-V71, 29-V13	40 CFR Part 60, Subpart NNN	The facility is not part of a process that produces any chemicals listed in 60.667 as a product, co-product, by-product, or intermediate.
GRP-CCVT3	18-V71, 29-V13	40 CFR Part 63, Subpart CC	Gas streams routed to the fuel gas system are excluded from definition of miscellaneous process vent.
GRP-CCVT4	29-V53, 29-V54	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to a fuel gas system do not meet the definition of a vent.
GRP-CCVT4	29-V53, 29-V54	40 CFR Part 63, Subpart CC	Gas streams routed to the fuel gas system are excluded from definition of miscellaneous process vent.
GRP-HONVT	14-E28, 14-V42	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
GRP-HONVT	14-E28, 14-V42	40 CFR Part 60, Subpart NNN	A 40 CFR 63, Subpart G Group 1 process vent that is also subject to NSPS Subpart NNN is required to comply only with 40 CFR 63, Subpart G.
GRP-NNNVT1	14-E43, 14-V15, 14-V28, 14-V31, 18-V65, 18-V66, 18-V92, 18-V96	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
GRP-R5VT1	14-ME1, 14-V18, 14-V19, 14-V26, 14-V46, 19-V11, 19-V16, 46-V8, 46-V9	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-R5VT2	19-V12, 19-V9	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
GRP-R5VT2	19-V12, 19-V9	40 CFR Part 60, Subpart NNN	Not constructed, modified, or reconstructed after 12/30/1983.
GRP-R5VT3	51-V4, 54-V3, 54-V4	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
GRP-R5VT3	51-V4, 54-V3, 54-V4	40 CFR Part 60, Subpart NNN	The facility is not part of a process that produces any chemicals listed in 60.667 as a product, co-product, by-product, or intermediate.
GRP-R5VT4	52-V9A, 52-V9B	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
GRP-R5VT5	21-P18SUMP, 23-P6SUMP, 31-V21, 31-V22, 31-V8, 85-SUMP14	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
GRP-R5VT6	31-IN1, 42-P1SUMP, 43-P2SUMP, 46-V15, 51-F7, 53-P5SUMP, 54-P8SUMP, 54-P9SUMP, 54-V5, 54-V6	30 TAC Chapter 115, Vent Gas Controls	Gas streams routed to the fuel gas system do not meet the definition of a vent.
GRP1CT	17-CT10, 19-CT11, 207-CT001, 29-CT9, 37-CT12, 38-CT-5, 48-CT7, 50-CT208, 81-CT81, 83-CT83, CTW002A, CTW002B	40 CFR Part 63, Subpart Q	Cooling Towers have not been operated with chromium-based water treatment chemicals on or after 9/8/94.
GRP1DOCK	57-D1, 57-D2	30 TAC Chapter 115, Loading and Unloading of VOC	Marine loading is exempt from Subchapter C VOC Transfer Operations.
GRP1DOCK	57-D1, 57-D2	40 CFR Part 61, Subpart BB	Only exempt materials under 61.300(a) are loaded.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP1ENG	17-C1, 17-C2, 17-C5, 29-C3, 29-C4, 29-C5, 29-C6, 39-C1, 39-C1A, 39-C1B	40 CFR Part 60, Subpart J	These combustion devices fire only natural gas, which does not meet the definition of a fuel gas in 60.101(d).
GRP1FUG	01-U01A, 61-U61, 70-WW-70	30 TAC Chapter 115, Fugitives Pet Ref B Counties	Fugitive components only contact fluid that contains less than 10% VOC by weight.
GRP1FUG	01-U01A, 61-U61, 70-WW-70	40 CFR Part 60, Subpart GGG	Unit does not contain equipment in VOC service.
GRP1FUG	01-U01A, 61-U61, 70-WW-70	40 CFR Part 60, Subpart VV	Equipment is located in a process unit that does not produce as an intermediate or final product any chemical listed in 40 CFR 60.489.
GRP1FUG	01-U01A, 61-U61, 70-WW-70	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service.
GRP1FUG	01-U01A, 61-U61, 70-WW-70	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate in VHAP service.
GRP1FUG	01-U01A, 61-U61, 70-WW-70	40 CFR Part 63, Subpart CC	The equipment is associated with a process unit that does not meet the definition of a petroleum refining process unit because it is not used for the operations listed in 63.641.
GRP1FUG	01-U01A, 61-U61, 70-WW-70	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).
GRP1HTR	11-H2, 17-H1, 207-H-1, 21-H1A, 21-H1B, 28-H1, 28-H3, 29-H1 C&D, 29-H1B, 29-H3, 31-H1, 83-H1	30 TAC Chapter 112, Sulfur Compounds	Process heaters do not combust liquid fuel. Refinery fuel gas is the only fuel used.
GRP2DOCK	97-D3, 97-D4, 97-D7	30 TAC Chapter 115, Loading and Unloading of VOC	Marine loading is exempt from 30 TAC Chapter 115, Subchapter C, Division 1, Loading and Unloading of VOCs.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP2DOCK	97-D3, 97-D4, 97-D7	40 CFR Part 61, Subpart BB	Only exempt materials under 61.300(a) are loaded.
GRP2DOCK	97-D3, 97-D4, 97-D7	40 CFR Part 63, Subpart CC	MACT CC does not apply because unit is not a gasoline loading rack.
GRP2DOCK	97-D3, 97-D4, 97-D7	40 CFR Part 63, Subpart Y	This dock does not load commodities with vapor pressure above 1.5 psia.
GRP2FUG	10-U10, 21-U21, 23-U23, 24-U24, 28-U28, 29-U29, 31-U31DEC5, 31-U31FCCU, 37-U37MS, 37-U37SHP, 38-U38, 42-U42, 43-U43, 44-U44, 45-U45, 60-U61A,B, 83-U83	40 CFR Part 60, Subpart GGG	These equipment leaks are subject to the requirements of MACT CC, which supersedes NSPS GGG per the overlap provisions of 63.640(p).
GRP2FUG	10-U10, 21-U21, 23-U23, 24-U24, 28-U28, 29-U29, 31-U31DEC5, 31-U31FCCU, 37-U37MS, 37-U37SHP, 38-U38, 42-U42, 43-U43, 44-U44, 45-U45, 60-U61A,B, 83-U83	40 CFR Part 60, Subpart VV	These equipment leaks are not subject to NSPS VV because they are subject to the requirements of MACT CC, which supersedes NSPS VV per the overlap provisions of 63.640(p).
GRP2FUG	10-U10, 21-U21, 23-U23, 24-U24, 28-U28, 29-U29, 31-U31DEC5, 31-U31FCCU, 37-U37MS, 37-U37SHP, 38-U38, 42-U42, 43-U43, 44-U44, 45-U45, 60-U61A,B, 83-U83	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service.
GRP2FUG	10-U10, 21-U21, 23-U23, 24-U24, 28-U28, 29-U29, 31-U31DEC5, 31-U31FCCU, 37-U37MS, 37-U37SHP, 38-U38, 42-U42, 43-U43, 44-U44, 45-U45, 60-U61A,B, 83-U83	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate in VHAP service.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP2FUG	10-U10, 21-U21, 23-U23, 24-U24, 28-U28, 29-U29, 31-U31DEC5, 31-U31FCCU, 37-U37MS, 37-U37SHP, 38-U38, 42-U42, 43-U43, 44-U44, 45-U45, 60-U61A,B, 83-U83	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3)
GRP3FUG	14-U14, 18-U18, 19-U19, 73-U73C, F222	40 CFR Part 60, Subpart GGG	These equipment leaks are subject to the requirements of MACT H, which supersedes NSPS GGG per the overlap provisions of 63.160(b)(1).
GRP3FUG	14-U14, 18-U18, 19-U19, 73-U73C, F222	40 CFR Part 60, Subpart VV	These equipment leaks are not subject to NSPS VV because they are subject to the requirements of MACT H, which supersedes NSPS VV per the overlap provisions of 63.160(b)(1).
GRP3FUG	14-U14, 18-U18, 19-U19, 73-U73C, F222	40 CFR Part 61, Subpart J	These equipment leaks are subject to the requirements of 40 CFR Part 63, Subpart H, which supersedes 40 CFR Part 61, Subpart J per the overlap provisions of 63.160(b)(1).
GRP3FUG	14-U14, 18-U18, 19-U19, 73-U73C, F222	40 CFR Part 61, Subpart V	These equipment leaks are subject to the requirements of MACT H, which supersedes NESHAP V per the overlap provisions of 63.160(b)(1).
GRP3FUG	14-U14, 18-U18, 19-U19, 73-U73C, F222	40 CFR Part 63, Subpart CC	Unit is subject to 40 CFR 63, Subparts F, G, H, and/or I.
GRP4FUG	57-UD7, 85-U85	40 CFR Part 60, Subpart GGG	Construction and any modifications or reconstructions all commenced prior to January 4, 1983.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP4FUG	57-UD7, 85-U85	40 CFR Part 60, Subpart VV	Construction and any modifications or reconstructions all commenced prior to January 5, 1981.
GRP4FUG	57-UD7, 85-U85	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service.
GRP4FUG	57-UD7, 85-U85	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate VHAP service.
GRP4FUG	57-UD7, 85-U85	40 CFR Part 63, Subpart CC	The equipment is associated with a process unit that does not meet the definition of a petroleum refining process unit because it is not used for the operations listed in 63.641.
GRP4FUG	57-UD7, 85-U85	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).
GRP5FUG	90-UD3FUG	40 CFR Part 60, Subpart GGG	Construction and any modifications or reconstructions all commenced prior to January 4, 1983.
GRP5FUG	90-UD3FUG	40 CFR Part 60, Subpart VV	Equipment is located in a process unit that does not produce as an intermediate or final product any chemical listed in 40 CFR 60.489.
GRP5FUG	90-UD3FUG	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service.
GRP5FUG	90-UD3FUG	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate in VHAP service.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP5FUG	90-UD3FUG	40 CFR Part 63, Subpart CC	The equipment is associated with a process unit that does not meet the definition of a petroleum refining process unit because it is not used for the operations listed in 63.641.
GRP5FUG	90-UD3FUG	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).
GRPDEGRSR	DEGRSR1-MS, DEGRSR2-MS, DEGRSR3-ES, DEGRSR4-IS	40 CFR Part 63, Subpart T	The solvent degreasers do not use solvents containing methylene chloride, trichlorethylene, perchloroethylene, 1,1, 1-trichloroethane, carbon tetrachloride, or chloroform.
GRPVENDTKS	11-TK0106, 11-TK0107, 11-TK0108, 11-TK0109, 11-TK0110, 14-TK0001, 29-TK0101, 30-TK0101, 38-TK0103, 38-TK0104, 38-TK0107, 38-TK0109, 50-TK0101, 60-TK0107, 60-TK0108, 60-TK0109, 81-TK0103, 81-TK0104, 82-TK0101, 82-TK0103, 82-TK0612, 85-TK0006, 85-TK0063, 85-TK0192, 85-TK0205, 97-TK0102, BETZ TK204655, BETZ TK204656, BETZ TK204657, BETZ TK204658, BETZ TK205502, BETZ TK205534, BETZ TK220742, BETZ TK232022, BETZ TK982192	40 CFR Part 60, Subpart K	The tanks were constructed or modified after May 19, 1978.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRPVENDTKS	11-TK0106, 11-TK0107, 11-TK0108, 11-TK0109, 11-TK0110, 14-TK0001, 29-TK0101, 30-TK0101, 38-TK0103, 38-TK0104, 38-TK0107, 38-TK0109, 50-TK0101, 60-TK0107, 60-TK0108, 60-TK0109, 81-TK0103, 81-TK0104, 82-TK0101, 82-TK0103, 82-TK0612, 85-TK0006, 85-TK0063, 85-TK0192, 85-TK0205, 97-TK0102, BETZ TK204655, BETZ TK204656, BETZ TK204657, BETZ TK204658, BETZ TK205502, BETZ TK205534, BETZ TK220742, BETZ TK232022, BETZ TK982192	40 CFR Part 60, Subpart Ka	The tanks were constructed or modified after July 23, 1984.
GRPVENDTKS	11-TK0106, 11-TK0107, 11-TK0108, 11-TK0109, 11-TK0110, 14-TK0001, 29-TK0101, 30-TK0101, 38-TK0103, 38-TK0104, 38-TK0107, 38-TK0109, 50-TK0101, 60-TK0107, 60-TK0108, 60-TK0109, 81-TK0103, 81-TK0104, 82-TK0101, 82-TK0103, 82-TK0612, 85-TK0006, 85-TK0063, 85-TK0192, 85-TK0205, 97-TK0102, BETZ TK204655, BETZ TK204656, BETZ TK204657, BETZ TK204658, BETZ TK205502, BETZ TK205534, BETZ TK220742, BETZ TK232022, BETZ TK982192	40 CFR Part 60, Subpart Kb	Storage vessel with capacity less than 75 cubic meters and not an EFR

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRPVENDTKS	11-TK0106, 11-TK0107, 11-TK0108, 11-TK0109, 11-TK0110, 14-TK0001, 29-TK0101, 30-TK0101, 38-TK0103, 38-TK0104, 38-TK0107, 38-TK0109, 50-TK0101, 60-TK0107, 60-TK0108, 60-TK0109, 81-TK0103, 81-TK0104, 82-TK0101, 82-TK0103, 82-TK0612, 85-TK0006, 85-TK0063, 85-TK0192, 85-TK0205, 97-TK0102, BETZ TK204655, BETZ TK204656, BETZ TK204657, BETZ TK204658, BETZ TK205502, BETZ TK205534, BETZ TK220742, BETZ TK232022, BETZ TK982192	40 CFR Part 60, Subpart QQQ	This is not an affected facility.
GRPVENDTKS	11-TK0106, 11-TK0107, 11-TK0108, 11-TK0109, 11-TK0110, 14-TK0001, 29-TK0101, 30-TK0101, 38-TK0103, 38-TK0104, 38-TK0107, 38-TK0109, 50-TK0101, 60-TK0107, 60-TK0108, 60-TK0109, 81-TK0103, 81-TK0104, 82-TK0101, 82-TK0103, 82-TK0612, 85-TK0006, 85-TK0063, 85-TK0192, 85-TK0205, 97-TK0102, BETZ TK204655, BETZ TK204656, BETZ TK204657, BETZ TK204658, BETZ TK205502, BETZ TK205534, BETZ TK220742, BETZ TK232022, BETZ TK982192	40 CFR Part 60, Subpart UU	The tanks do not store asphalt.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRPVENDTKS	11-TK0106, 11-TK0107, 11-TK0108, 11-TK0109, 11-TK0110, 14-TK0001, 29-TK0101, 30-TK0101, 38-TK0103, 38-TK0104, 38-TK0107, 38-TK0109, 50-TK0101, 60-TK0107, 60-TK0108, 60-TK0109, 81-TK0103, 81-TK0104, 82-TK0101, 82-TK0103, 82-TK0612, 85-TK0006, 85-TK0063, 85-TK0192, 85-TK0205, 97-TK0102, BETZ TK204655, BETZ TK204656, BETZ TK204657, BETZ TK204658, BETZ TK205502, BETZ TK205534, BETZ TK220742, BETZ TK232022, BETZ TK982192	40 CFR Part 61, Subpart Y	These tanks do not store industrial or refined grade benzene.
NBB-TKDSL	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
NBB-TKDSL	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
NCCR-TKDSL	N/A	30 TAC Chapter 115, Storage of VOCs	The max TVP is less than 1.5 psia, and the tank is not equipped with an EFR.
NCCR-TKDSL	N/A	40 CFR Part 60, Subpart K	The tank does not store petroleum liquids.
NCCR-TKDSL	N/A	40 CFR Part 60, Subpart Ka	The tank does not store petroleum liquids.
NCCR-TKDSL	N/A	40 CFR Part 60, Subpart Kb	The tank has a storage capacity less than 75 cubic meters.
NCCR-TKDSL	N/A	40 CFR Part 60, Subpart UU	The tank does not store asphalt.
NCCR-TKDSL	N/A	40 CFR Part 61, Subpart Y	The tank does not store industrial or refined grade benzene.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
NCCR-TKDSL	N/A	40 CFR Part 63, Subpart CC	The tank has a storage capacity less than 40 cubic meters.
NCCR-TKDSL	N/A	40 CFR Part 63, Subpart G	The tank is not associated with a chemical manufacturing process unit that is subject to this subpart.
SCOTFUG	N/A	40 CFR Part 60, Subpart VV	Equipment is located in a process unit that does not produce as an intermediate or final product any chemical listed in 40 CFR 60.489.
SCOTFUG	N/A	40 CFR Part 61, Subpart J	Equipment associated with this unit is not intended to operate in benzene service
SCOTFUG	N/A	40 CFR Part 61, Subpart V	Equipment associated with this unit is not intended to operate in VHAP service.
SCOTFUG	N/A	40 CFR Part 63, Subpart CC	The equipment does not contact HAPs as listed in table 1 of MACT CC.
SCOTFUG	N/A	40 CFR Part 63, Subpart H	The equipment is associated with a process unit that does not meet the criteria for a chemical manufacturing unit specified in 63.100(b)(1)-(3).
SLDGLOAD	N/A	40 CFR Part 61, Subpart BB	Only exempt materials under 61.300(a) are loaded.

New Source Review Authorization References

New Source Review Authorization References	543
New Source Review Authorization References by Emission Unit	545

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Prevention of Significant Deterioration (PSD) Permits	
PSD Permit No.: PSDTX36	Issuance Date: 07/21/2023
PSD Permit No.: PSDTX653M1	Issuance Date: 07/21/2023
PSD Permit No.: PSDTX831	Issuance Date: 07/21/2023
PSD Permit No.: PSDTX96	Issuance Date: 07/21/2023
Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 2699A	Issuance Date: 07/21/2023
Authorization No.: 3857A	Issuance Date: 07/18/2023
Authorization No.: 9604A	Issuance Date: 06/18/2020
Authorization No.: 17677A	Issuance Date: 07/06/2023
Authorization No.: 80521	Issuance Date: 08/04/2016
Authorization No.: 80801	Issuance Date: 07/30/2021
Authorization No.: 141429	Issuance Date: 10/13/2022
Authorization No.: 163223	Issuance Date: 12/02/2020
Authorization No.: 170413	Issuance Date: 07/06/2023
Authorization No.: 170581	Issuance Date: 11/02/2022
Authorization No.: 173037	Issuance Date: 06/30/2023
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 14	Version No./Date: 06/07/1996
Number: 53	Version No./Date: 09/12/1989
Number: 57	Version No./Date: 04/04/1975
Number: 86	Version No./Date: 08/30/1988
Number: 86	Version No./Date: 09/13/1993
Number: 88	Version No./Date: 07/20/1992
Number: 106	Version No./Date: 08/30/1988
Number: 106	Version No./Date: 04/05/1995
Number: 111	Version No./Date: 07/20/1992
Number: 118	Version No./Date: 01/08/1980
Number: 106.183	Version No./Date: 09/04/2000
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 09/04/2000
Number: 106.262	Version No./Date: 11/01/2003

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Number: 106.263	Version No./Date: 11/01/2001
Number: 106.371	Version No./Date: 09/04/2000
Number: 106.433	Version No./Date: 09/04/2000
Number: 106.454	Version No./Date: 11/01/2001
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.478	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 09/04/2000
Number: 106.512	Version No./Date: 09/04/2000
Number: 106.532	Version No./Date: 09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
01-U01A	PC Boiler 7 & 8 Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
065-P-35	Emergency Fire Pump Engine	106.511/09/04/2000
065-P-35 VENT	Emergency Fire Pump Engine Vent	106.511/09/04/2000
065-P-36	Emergency Fire Pump Engine	106.511/09/04/2000
065-P-36 VENT	Emergency Fire Pump Engine Vent	106.511/09/04/2000
065-P-37	Emergency Fire Pump Engine	106.511/09/04/2000
065-P-37 VENT	Emergency Fire Pump Engine Vent	106.511/09/04/2000
065-P-38	Emergency Fire Pump Engine	106.511/09/04/2000
065-P-38 VENT	Emergency Fire Pump Engine Vent	106.511/09/04/2000
085-P-525	Maintenance Hydrotest Pump Engine	106.511/09/04/2000
085-P-525 VENT	Maintenance Hydrotest Pump Engine Vent	106.511/09/04/2000
10-U10	Crude and Vacuum Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [151502, 160982, 164588, 168537, 172374], 106.262/11/01/2003 [168537, 172374]
11-H1	No. 11 Crude Unit Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [136760]
11-H2	No. 11 Vacuum Unit Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [136760]
11-TK0106	Vendor Tank	106.472/09/04/2000
11-TK0107	Vendor Tank	106.472/09/04/2000
11-TK0108	Vendor Tank	106.472/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
11-TK0109	Vendor Tank	106.472/09/04/2000
11-TK0110	Vendor Tank	106.472/09/04/2000
11-V-10A	Vacuum Tower Ejector System	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
114-P-001	Emergency Fire Pump Engine	106.511/09/04/2000
114-P-001 VENT	Emergency Fire Pump Engine Vent	106.511/09/04/2000
114-P-002	Emergency Fire Pump Engine	106.511/09/04/2000
114-P-002 VENT	Emergency Fire Pump Engine Vent	106.511/09/04/2000
114-P-003	Emergency Fire Pump Engine	106.511/09/04/2000
114-P-003 VENT	Emergency Fire Pump Engine Vent	106.511/09/04/2000
114-P-004	Emergency Fire Pump Engine	106.511/09/04/2000
114-P-004 VENT	Emergency Fire Pump Engine Vent	106.511/09/04/2000
14-E28	Recycle Column Ovhd Receiver Vent Condenser	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
14-E43	HP Cumene Column Vent Condenser	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
14-H1	Cumene Unit Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
14-ME1	Propylene Sulfur Guard Bed Filter	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
14-R101A	Alkylation Reactor A	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
14-R101B	Alkylation Reactor B	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
14-R101C	Transalkylation Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
14-TK0001	Vendor Tank	106.472/09/04/2000
14-U14	Cumene Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [146219, 149580, 156156, 168537], 106.262/11/01/2003 [146219, 149580, 168537]
14-V15	HP Cumene Column Overhead Receiver	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
14-V18	Hot Oil Expansion Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
14-V19	Hot Oil Sump Tank	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
14-V26	Fuel Gas KO Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
14-V28	No. 2 Effluent Rectifier Ovhd Receiver	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
14-V31	LP Cumene Column Ovhd Receiver	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
14-V42	DIPB Column Ovhd Receiver	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
14-V46	Propane Degassing Pot	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
17-C1	ADP No. 1 Compressor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
17-C2	ADP No. 2 Compressor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
17-C5	ADP No. 5 Compressor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
17-CT10	BTX No. 10 Cooling Tower	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
17-H1	ADP Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
17-INC	BTX Wastewater Incinerator	88/07/20/1992
17-V30	Waste Water Stripper Overhead Receiver	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
17-V5	ADP Reactor No. 1	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
17-V6	ADP Reactor No. 2	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
17-V7	ADP Reactor No. 3	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
17-V8	ADP Reactor No. 4	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
18-E22	Solvent Fractionator 3-Stage Jet Ejectors	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
18-HOTWELL	Solvent Fractionator Hotwell	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
18-TK0101	Storage Tank 18 TK 101	106.472/09/04/2000
18-U18	Udex Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [148586, 160982, 161396, 172374], 106.262/11/01/2003 [148586, 161396, 171445, 172374]
18-V13	Extractor Column	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
18-V62	Extractor Column No. 2	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
18-V65	Benzene Column Overhead Receiver	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
18-V66	Toluene Column Receiver	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
18-V71	SRC Overhead Receiver	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
18-V92	Aromatics Fractionator Receiver	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
18-V96	Xylene Column Receiver	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
19-CT11	Hydrar No. 11 Cooling Tower	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
19-H1	Hydrar Stabilizer Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
19-H2	Hydrar Stripper Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
19-R1	Hydrar Reactor No. 1	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
19-R2	Hydrar Reactor No. 2	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
19-R3	Hydrar Reactor No. 3	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
19-R4	Hydrar Reactor No. 4	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
19-U19	Hydrar Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [168357], 106.262/11/01/2003 [151026, 168537]
19-V10	Waste Water Degassing Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
19-V11	Absorber Oil Stripper Feed Vent	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
19-V12	Absorber Oil Stripper Receiver	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
19-V16	Make-Up H2 Suction Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
19-V28	Stripper Off Gas KO Pot	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
19-V9	Stabilizer Receiver	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
204-TK0001	Tank for Diesel Engine (Flood Water Engine)	106.261/11/01/2003 [139767], 106.472/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
204-U942	Mixed C3 Terminal Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [151002, 168537], 106.262/11/01/2003 [168537]
207-CT001	GHT Cooling Tower	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
207-H-1	GHT Charge Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [151502, 159107]
21-H1A	Unibon Reactor "A" Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
21-H1B	Unibon Reactor "B" Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
21-P18SUMP	DEA Sump	106.472/09/04/2000
21-R1A	Gas Oil Unibon Reactor 1A	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
21-R1B	Gas Oil Unibon Reactor 1B	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
21-R2A	Gas Oil Unibon Reactor 2A	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
21-R2B	Gas Oil Unibon Reactor 2B	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
21-R3A	Gas Oil Unibon Reactor 3A	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
21-R3B	Gas Oil Unibon Reactor 3B	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
21-U21	Unibon Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [168537, 172374], 106.262/11/01/2003 [168537, 172374], 118/01/08/1980
21-V2	Gas Oil Unibon Unit Feed Surge Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
21-V20	Filter Backwash Surge Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
21-V27	Fuel Gas K.O. Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
21-V39	Injection Water Surge Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
21-V51	Drain Pot	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
21-V55RCTR	NAHS Skid Unibon Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
21-V7	Recycle Gas Scrubber	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
22-V1	LSR Gasoline Merox Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
23-P6SUMP	Caustic Sump	106.472/09/04/2000
23-TK0002A	50 Block DEA Storage Tank	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.472/09/04/2000
23-TK0002B	50 Block DEA Storage Tank	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.472/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
23-U23	Jet/Kerosene Merox Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
23-V3	Jet/Kerosene Merox Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
23-V5	Caustic Degassing Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
24-U24	FCC Gasoline Merox Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
24-V2	FCC Merox Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106/04/05/1995
252	PC Boilers No. 7 & 8 Stack	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106/04/05/1995
28-H1	No. 4 Unifiner Reactor Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
28-H3	No. 4 Unifiner Stripper Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
28-U28	No. 4 Unifiner Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
28-V16	Unifiner Booster Compressor Suction Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
28-V3	Unifiner Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-C3	No. 4 Platformer Compressor No. 3	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
29-C4	No. 4 Platformer Compressor No. 4	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-C5	No. 4 Platformer Compressor No. 5	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-C6	No. 4 Platformer Compressor No. 6	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-CT9	No. 4 Platformer No. 9 Cooling Tower	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-H1 C&D	No. 4 Platformer Reactor Heater 1 C & D	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-H1A	No. 4 Platformer Reactor Heater 1A	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-H1B	No. 4 Platformer Reactor Heater 1B	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-H2B	No. 4 Platformer Stabilizer Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-H3	No. 4 Platformer Aro. Spl. Reb. Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-TK0101	Vendor Tank	106.472/09/04/2000
29-TK0103	Storage Tank 29 TK 103	106.472/09/04/2000
29-TK0105	Storage Tank 29 TK 105	106.478/09/04/2000
29-U29	No.4 Platformer Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [168537], 106.262/11/01/2003 [168537]

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
29-V1	Plat Reactor No. 1	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-V106	Atmos Knock Out Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-V13	Splitter Overhead Receiver	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-V2	Plat Reactor No. 2	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-V26	Platform Regenerator Vent	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-V3	Plat Reactor No. 3	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-V4	Plat Reactor No. 4	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-V53	Vent Pot	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
29-V54	Vent Pot	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
292	Combined Crude and Vacuum Heater Stack	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
30-TK0101	Vendor Tank	106.472/09/04/2000
31-FCCU2	No. 2 FCCU	9604A, PSDTX653M1, 106.261/11/01/2003 [146219], 106.262/11/01/2003 [146219]
31-H1	No. 2 FCCU Heater	9604A, PSDTX653M1
31-IN1	Regenerator-Hopper	9604A, PSDTX653M1

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
31-PR-1	No. 2 FCCU Regen ESP Stack	9604A, PSDTX653M1
31-R1	No. 2 FCCU Reactor-Stripper	9604A, PSDTX653M1
31-U31DEC5	Depropanizer Tower Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
31-U31FCCU	No. 2 FCCU Unit Fugitives	9604A, PSDTX653M1, 106.261/11/01/2003 [129920, 139767, 172374], 106.262/11/01/2003 [172374]
31-V21	Intercat Additive Pot	9604A, PSDTX653M1
31-V22	Nosox Additive Pot	9604A, PSDTX653M1
31-V8	Equilibrium Catalyst Storage Hopper (Vent to Atm)	9604A, PSDTX653M1
36-TK0100	Storage Tank 36 TK 100	106.472/09/04/2000
37-CT12	No. 12 Cooling Tower	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
37-U37MS	Mole Sieve Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
37-U37SHP	C4 Shp Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
37-V202	C4 Shp Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
37-V33	Water Degassing Pot	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
38-COB	Flue Gas Cooler	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
38-CT-5	No. 1 FCCU No. 5 Cooling Tower	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
38-H2	No. 1 FCCU Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
38-TK0103	Vendor Tank	106.472/09/04/2000
38-TK0104	Vendor Tank	106.472/09/04/2000
38-TK0106	Storage Tank 38 TK 106	106.472/09/04/2000
38-TK0107	Vendor Tank	106.472/09/04/2000
38-TK0109	Vendor Tank	106.472/09/04/2000
38-U38	No. 1 FCCU and Gas Con Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [168537], 106.262/11/01/2003 [168537]
38-V6	No. 1 FCCU Regenerator (Flue Gas to CO Boiler)	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
38-V7	No. 1 FCCU Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
39-C1	No. 1 FCCU North Compressor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [75340]
39-C1A	No. 1 FCCU Middle Compressor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [75340]
39-C1B	No. 1 FCCU South Compressor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [75340]
41-H1	No. 41 Absorber Reboiler Heater 1	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [151502]

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
41-H2	No. 41 Debutanizer Reboiler Heater 2	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [151502]
41-U41	Saturates Gas Plant Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [146219, 168537], 106.262/11/01/2003 [146219, 168537]
42-P1SUMP	DEA Sump	106.472/09/04/2000
42-U42	No. 42 Fuel Gas Treatment Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [164588]
43-P2SUMP	Caustic Sump	106.472/09/04/2000
43-U43	LPG Merox Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
44-U44	Mercaptan Extractor Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [146219], 106.262/11/01/2003 [146219]
44-V10	Disulfide Knock Out Vent Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
45-U45	C3/C4 Splitter Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [146219, 160982], 106.262/11/01/2003 [146219]
46-U46	Alky Washwater Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [168537, 172374], 106.262/11/01/2003 [168537, 172374]
46-V15	Wash Water Break Tank	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
46-V8	Degassing Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
46-V9	Degassing Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
47-TK0103	Storage Tank 47 TK 103	106.478/09/04/2000
47-U47	C5 Merox Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [172374], 106.262/11/01/2003 [172374]
47-V-105	C5 Merox Vent	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
47-V104	C5 Merox Unit Oxidizer	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
48-CT7	No. 7 Cooling Tower	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
50-CT208	TGTU # 2 Cooling Tower	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
50-TK0101	Vendor Tank	106.472/09/04/2000
51-F7	Amine Filter And Sump	106.472/09/04/2000
51-TK0001	Scot DEA Storage Tank	106.472/09/04/2000
51-V4	Auxiliary Flash Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
52-R1A	Sulfur Unit Catalytic Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
52-R1B	Sulfur Unit Catalytic Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
52-R2A	Sulfur Unit Catalytic Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
52-R2B	Sulfur Unit Catalytic Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
52-R3A	Sulfur Unit Catalytic Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
52-R3B	Sulfur Unit Catalytic Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
52-U52AMNE	Amine Regeneration Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [170743], 106.262/11/01/2003 [170743]
52-U52SRU	SRU Fugitives	2699A, 170581, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [111443, 146219], 106.262/11/01/2003 [111443, 146219]
52-V3A	Sulfur Unit Thermal Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
52-V3B	Sulfur Unit Thermal Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
52-V9A	Sulfur Drain Header	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
52-V9B	Sulfur Drain Header	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
53-P5SUMP	Scot Solution Pit	106.472/09/04/2000
53-T001	Scot Absorber	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
53-TK0001	Scot Ucarsol MDEA Storage Tank	106.472/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
53-U53	Scot Incinerator #1	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
53-V2	Scot Reactor	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
54-P8SUMP	Amine Sump	170581, 106.472/09/04/2000
54-P9SUMP	Amine Sump	170581, 106.472/09/04/2000
54-TK0001	Storage Tank 54 TK 001 (W/ Vapor Scrubber)	106.472/09/04/2000
54-TK3	Sour Water Storage Tank	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [139905], 106.262/11/01/2003 [139905]
54-V3	SW Flash Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
54-V4	Sour Water Gas Scrubber	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
54-V5	Amine Scrubber	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
54-V6	Amine Scrubber	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
56-U56	Scot Incinerator # 2	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [156156]
57-D1	Ship Dock No. 1 Loading	3857A, 106.261/11/01/2003 [141703], 106.262/11/01/2003 [141703]
57-D2	Barge Dock No. 2 Loading	3857A, 106.261/11/01/2003 [141703, 164588], 106.262/11/01/2003 [141703]

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
57-D7	Dock No. 7 Loading	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
57-UD1	Dock 1 Piping Fugitives	3857A, 106.261/11/01/2003 [141703, 146219], 106.262/11/01/2003 [141703, 146219]
57-UD2	Dock 2 Piping Fugitives	3857A, 106.261/11/01/2003 [141703], 106.262/11/01/2003 [141703]
57-UD7	Dock No. 7 Piping Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.262/11/01/2003 [169854]
57-UDMEC	Marine Emission Control Piping Fugitives	3857A, 106.261/11/01/2003 [141703, 146219], 106.262/11/01/2003 [141703, 146219]
57-VC2D7	Dock 7 MEC	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
60-TK0107	Vendor Tank	106.472/09/04/2000
60-TK0108	Vendor Tank	106.472/09/04/2000
60-TK0109	Vendor Tank	106.472/09/04/2000
60-U61A,B	No.2 Oil Salt Drier Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [160982]
61-B3E	Utility Boiler E	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
61-U61	Utility Boiler Area Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
64-TK0013	Storage Tank 64 TK 13	106.478/09/04/2000
65-TK0107	Storage Tank 65 TK 107	106.472/09/04/2000
65-TK0108	Storage Tank 65 TK 108	106.472/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
65-TK0109	Storage Tank 65 TK 109	106.472/09/04/2000
65-TK0110	Storage Tank 65 TK 110	106.472/09/04/2000
66-TK0100	Storage Tank 66 TK 100	106.472/09/04/2000
70-WW-70	Wastewater Treater Fugitives	106.532/09/04/2000
73-FLR442	Fluor Flare	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
73-FLR446	Cumene Flare	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [56720]
73-STK447	Marine Combustor No. 1 Stack	2699A, 3857A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
73-STK448	Marine Combustor No. 2 Stack	2699A, 3857A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
73-STK449	Marine Combustor No. 3 Stack	2699A, 3857A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
73-U73C	Cumene Flare Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [149580, 156156], 106.262/11/01/2003 [149580]
73-U73F	No. 73 Fluor Flare Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [156156]
73-V11	Enclosed Flare Liquid Seal	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
73-V15	Fluor Flare KO Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
73-V17	Fluor Flare Gas Seal Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
73-V6	Cumene HP Flare KO Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
73-V7	Cumene LP Flare KO Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
73-VC447	Marine Combustor No. 1	2699A, 3857A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [141703], 106.262/11/01/2003 [141703]
73-VC448	Marine Combustor No. 2	2699A, 3857A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [141703], 106.262/11/01/2003 [141703]
73-VC449	Marine Combustor No. 3	2699A, 3857A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [141703], 106.262/11/01/2003 [141703]
80-DSW	FHR Dock 2 Fugitives	106.261/09/04/2000 [53921], 106.262/09/04/2000 [53921]
81-CT81	No. 81 Cooling Tower	2699A, 9604A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
81-TK0103	Vendor Tank	106.472/09/04/2000
81-TK0104	Vendor Tank	106.472/09/04/2000
82-CPI	East Plant CPI Separator	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
82-TK0006	Tank 6	106.478/09/04/2000 [83882]
82-TK0101	Vendor Tank	106.472/09/04/2000
82-TK0103	Vendor Tank	106.472/09/04/2000
82-TK0114	CPI Storage Tank 114	53/09/12/1989

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
82-TK0115	Wastewater Tank 115	106.472/09/04/2000
82-TK0116	Equalization Tank 116	106.472/09/04/2000
82-TK0117	Equalization Tank 117	106.472/09/04/2000
82-TK0605	Storage Tank 605	57/04/04/1975
82-TK0606	Storage Tank 606	57/04/04/1975
82-TK0607	Storage Tank 607	57/04/04/1975
82-TK0608	Storage Tank 608	57/04/04/1975
82-TK0612	Vendor Tank	106.472/09/04/2000
82-TK0616	Storage Tank 616	106.472/09/04/2000
82-TK0617	Storage Tank 617	106.472/09/04/2000
82-TK0618	Storage Tank 618	106.472/09/04/2000
83-CT83	No. 83 Cooling Tower	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
83-H1	No. 83 Hf Alky Heater	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
83-R1	Alkylation Reactor No. 1	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
83-R2	Alkylation Reactor No. 2	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
83-U83	Alky Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [139767, 146219, 167712, 168537], 106.262/11/01/2003 [146219, 167712, 168537], 106.263/11/01/2001 [167713]

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
83-V105	Relief Gas Scrubber	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
85-SUMP14	Glycol Sump	106.472/09/04/2000
85-TK0006	Vendor Tank	106.472/09/04/2000
85-TK0063	Vendor Tank	106.472/09/04/2000
85-TK0190	Storage Tank 85 TK 190	106.472/09/04/2000
85-TK0191	Storage Tank 85 TK 191	106.472/09/04/2000
85-TK0192	Vendor Tank	106.472/09/04/2000
85-TK0205	Vendor Tank	106.472/09/04/2000
85-U85	Tank Farm and Pump House Area Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [139767, 146219, 160982, 164588, 168537, 172374], 106.262/11/01/2003 [139385, 146219, 168537, 169854, 172374], 106.472/09/04/2000
851-TK0925	Storage Tank 925	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
851-TK0926	Storage Tank 926	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
851-TK0927	Storage Tank 927	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [78195]
851-TK0928	Storage Tank 928	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [78195]
851-TK0929	Storage Tank 929	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
851-TK0930	Storage Tank 930	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
851-TK1029	Storage Tank 1029	9604A, PSDTX653M1, 106.478/09/04/2000 [77094]
851-TK1030	Storage Tank 1030	9604A, PSDTX653M1
851-TK1031	Storage Tank 1031	9604A, PSDTX653M1
851-TK1032	Storage Tank 1032	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.478/09/04/2000 [76742]
852-TK0201	Storage Tank 201	9604A, PSDTX653M1, 106.261/11/01/2003 [56720]
852-TK0202	Storage Tank 202	9604A, PSDTX653M1, 106.261/11/01/2003 [56720]
852-TK0211	Storage Tank 211	9604A, PSDTX653M1
852-TK0212	Storage Tank 212	9604A, PSDTX653M1
852-TK0221	Storage Tank 221	9604A, PSDTX653M1
852-TK0222	Storage Tank 222	9604A, PSDTX653M1
852-TK0223	Storage Tank 223	9604A, PSDTX653M1
852-TK0224	Storage Tank 224	9604A, PSDTX653M1
852-TK0225	Storage Tank 225	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.478/09/04/2000 [78195]
852-TK0226	Storage Tank 226	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.478/09/04/2000 [78195]
852-TK0301	Storage Tank 301	9604A, PSDTX653M1

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
852-TK0302	Storage Tank 302	9604A, PSDTX653M1
852-TK0401	Storage Tank 401	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
852-TK0402	Storage Tank 402	9604A, PSDTX653M1
852-TK0403	Storage Tank 403	9604A, PSDTX653M1
852-TK0620	Storage Tank 620	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
852-TK0621	Storage Tank 621	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
852-TK0804	Storage Tank 804	106.478/09/04/2000
852-TK0901	Motor Vehicle Fuel Station Tank - Gasoline	14/06/07/1996
852-TK1001	Storage Tank 1001	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
852-TK1002	Storage Tank 1002	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
852-TK1003	Storage Tank 1003	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
852-TK1009	Storage Tank 1009	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
852-TK1010	Storage Tank 1010	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
852-TK1015	Storage Tank 1015	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
852-TK1016	Storage Tank 1016	9604A, PSDTX653M1

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
852-TK1017	Storage Tank 1017	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
852-TK1018	Storage Tank 1018	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
852-TK1019	Storage Tank 1019	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.263/11/01/2001 [111955]
852-TK1020	Storage Tank 1020	86/09/13/1993
852-TK1028	Storage Tank 1028	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
853-TK2001	Storage Tank 2001	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [151502]
853-TK2002	Storage Tank 2002	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [154927]
853-TK2003	Storage Tank 2003	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
853-TK2005	Storage Tank 2005	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.472/09/04/2000 [77066]
853-TK2006	Storage Tank 2006	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.472/09/04/2000 [77066]
853-TK3101	Storage Tank 3101	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
853-TK3102	Storage Tank 3102	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0001	Storage Tank 1	86/08/30/1988

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
854-TK0002	Storage Tank 2	2699A, 141429, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0003	Storage Tank 3	86/08/30/1988, 106.478/09/04/2000
854-TK0004	Storage Tank 4	2699A, 141429, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0005	Storage Tank 5	86/08/30/1988, 106.478/09/04/2000
854-TK0011	Storage Tank 11	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0012	Storage Tank 12	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0013	Storage Tank 13	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0014	Storage Tank 14	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0020	Storage Tank 20	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0021	Storage Tank 21	2699A, 141429, 170413, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0022	Storage Tank 22	2699A, 141429, 170413, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0033	Storage Tank 33	2699A, 141429, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0034	Storage Tank 34	2699A, 141429, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
854-TK0040	Storage Tank 40	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0041	Storage Tank 41	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0042	Storage Tank 42	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0043	Storage Tank 43	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0044	Storage Tank 44	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0045	Storage Tank 45	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0050	Storage Tank 50	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0055	Storage Tank 55	141429, 106.472/09/04/2000, 106.478/09/04/2000
854-TK0056	Storage Tank 56	9604A, PSDTX653M1
854-TK0057	Storage Tank 57	9604A, PSDTX653M1, 106.261/11/01/2003 [56720]
854-TK0060	Storage Tank 60	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0061	Storage Tank 61	2699A, 170413, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0062	Storage Tank 62	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
854-TK0063	Storage Tank 63	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0081	Storage Tank 81	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
854-TK0082	Storage Tank 82	9604A, PSDTX653M1
854-TK0083	Storage Tank 83	9604A, PSDTX653M1
854-TK0091	Storage Tank 91	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [76883], 106.262/11/01/2003 [76883]
854-TK0092	Storage Tank 92	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [76883], 106.262/11/01/2003 [76883]
854-TK0093	Storage Tank 93	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [76883], 106.262/11/01/2003 [76883]
855-TK1018	Storage Tank 1018	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
855-TK1019	Storage Tank 1019	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
855-TK1022	Storage Tank 1022	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
855-TK1023	Storage Tank 1023	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
855-TK1024	Storage Tank 1024	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
855-TK1025	Storage Tank 1025	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
855-TK1026	Storage Tank 1026	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
855-TK1027	Storage Tank 1027	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
855-TK1040	Storage Tank 1040	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
855-TK1041	Storage Tank 1041	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
855-TK1042	Storage Tank 1042	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [76883], 106.262/11/01/2003 [76883]
89-TK0180	Storage Tank 89 TK 180	106.478/09/04/2000
89-U89	Butane Storage Area #89 Fugitives	106.261/11/01/2003 [168537], 106.262/11/01/2003 [168537], 111/07/20/1992
90-TK0103	Storage Tank 90 TK 103	106.472/09/04/2000
90-TK0104	Storage Tank 90 TK 104	106.472/09/04/2000
90-TK0105	Storage Tank 90 TK 105	106.472/09/04/2000
90-UD3	Crude Unloading Dock No. 3	106/08/30/1988
90-UD3FUG	Crude Dock No. 3 Fugitives	106/08/30/1988
91-TK0103	Storage Tank 91 TK 103	106.472/09/04/2000
91-TK0104	Storage Tank 91 TK 104	106.472/09/04/2000
911-H	Coker Feed Heater	106.183/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
97-D3	Public Dock #3 Loading	17677A, 106.473/09/04/2000
97-D3FUG	Public Dock #3 Fugitives	17677A
97-D4	Public Dock #4 Loading	106.472/09/04/2000, 106.473/09/04/2000
97-D7	Public Dock #7 Loading	106.472/09/04/2000, 106.473/09/04/2000
97-TK0102	Vendor Tank	106.472/09/04/2000
97-TK0103	Storage Tank 97 TK 103	106.472/09/04/2000
BETZ TK204655	Vendor Tank	106.472/09/04/2000
BETZ TK204656	Vendor Tank	106.472/09/04/2000
BETZ TK204657	Vendor Tank	106.472/09/04/2000
BETZ TK204658	Vendor Tank	106.472/09/04/2000
BETZ TK205502	Vendor Tank	106.472/09/04/2000
BETZ TK205534	Vendor Tank	106.472/09/04/2000
BETZ TK220742	Vendor Tank	106.472/09/04/2000
BETZ TK232022	Vendor Tank	106.472/09/04/2000
BETZ TK982192	Vendor Tank	106.472/09/04/2000
CAUSTLOAD	Spent Caustic Loading	106.472/09/04/2000
CTW002A	Cooling Tower A for Lab Facility	106.371/09/04/2000
CTW002B	Cooling Tower B for Lab Facility	106.371/09/04/2000
DEAUNLOAD	DEA Unloading	106.472/09/04/2000
DEGRSR1-MS	Mechanical Shop Cold Solvent Degreaser #1	106.454/11/01/2001 [155845]
DEGRSR2-MS	Mechanical Shop Cold Solvent Degreaser #2	106.454/11/01/2001 [155845]

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
DEGRSR3-ES	Electrical Shop Remote Solvent Degreaser	106.454/11/01/2001
DEGRSR4-IS	Instrument Shop Remote Solvent Degreaser	106.454/11/01/2001
DIESELLOAD	Raw Diesel Loading	106.472/09/04/2000
F066	No. 1 FCCU CO Boiler Stack	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
F222	VC450 Fugitives	141429
F416	Scot Unit # 2 Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
FUG-FGRS	Flare Gas Recovery Fugitives	80521, 170581, 106.261/11/01/2003 [146219, 156156], 106.262/11/01/2003 [146219]
FUG-GHT	GHT Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96, 106.261/11/01/2003 [138157, 168537, 172374], 106.262/11/01/2003 [168537, 172374]
GASUNLOAD	Gasoline Unloading	14/06/07/1996
NBB-TKDSL	NBB Tank	106.472/09/04/2000
NCCR-TKDSL	Diesel Tank Near NCCR Building	106.472/09/04/2000
PCEUNLOAD	Perchloroethylene Unloading	106.478/09/04/2000
PROADP	ADP Process Unit	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
PROBTX	BTX Process Unit	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
PROBTXTRTR	BTX Wastewater Stripper	88/07/20/1992
PROCUMENE	Cumene Process Unit	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
PRODFDTRTR	Desalter Water Flash Drum	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
PROEPSRU	Gas Sweetening/Sulfur Recovery Unit Process	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
PROHYDRAR	Hydrar Process Unit	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
SCOTFUG	Scot Unit Fugitives	2699A, PSDTX36, PSDTX653M1, PSDTX831, PSDTX96
SLDGLOAD	EP/Unit 82 Sludge Load	106.472/09/04/2000
SURFCOAT	East Plant Surface Coating Operations	106.263/11/01/2001, 106.433/09/04/2000

**This column may include Permit by Rule (PBR) numbers and version dates, PBR Registration numbers in brackets, Standard Permit Registration numbers, Minor NSR permit numbers, and Major NSR permit numbers.

Appendix A

Acronym List 578

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
SIP	state implementation plan
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound

Appendix B

Major NSR Summary Table 580

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
742	Tank No. 1	VOC	2.42	4.75	4, 6, 15	4, 6, 15, 74, 79	4, 6
743	Tank 2	VOC	0.54	0.88	4, 6, 15	4, 6, 15, 74, 79	4, 6
744	Tank No. 3	VOC	2.36	4.62	4, 6, 15	4, 6, 15, 74, 79	4, 6
745	Tank No. 4	VOC	1.32	2.43	4, 6, 15	4, 6, 15, 74, 79	4, 6
746	Tank No. 5	VOC	3.44	11.79	4, 6, 15	4, 6, 15, 68, 74, 79	4, 6
749	Tank No. 13	VOC	0.94	0.51	4, 6, 15	4, 6, 15, 74, 79	4, 6
750	Tank No. 14	VOC	1.15	1.25	4, 6, 15	4, 6, 15, 74, 79	4, 6
751	Tank No. 20*	VOC	0.93	0.67	4, 6, 15	4, 6, 15, 74, 79	4, 6
751	Tank No. 20**	VOC	0.06	0.06	4, 6, 15	4, 6, 15, 74, 79	4, 6
752	Tank 21	VOC	0.64	0.85	4, 6, 15	4, 6, 15, 74, 79	4, 6
753	Tank 22*	VOC	0.64	0.85	4, 6, 15	4, 6, 15, 74, 79	4, 6
753	Tank 22**	VOC	0.0	0.0	4, 6, 15	4, 6, 15, 74, 79	4, 6
757	Tank 33	VOC	0.59	0.63	4, 6, 15	4, 6, 15, 74, 79	4, 6
758	Tank 34	VOC	0.59	0.63	4, 6, 15	4, 6, 15, 74, 79	4, 6
759	Tank No. 40	VOC	0.68	0.90	4, 6, 15	4, 6, 15, 74, 79	4, 6
760	Tank No. 41	VOC	0.78	1.11	4, 6, 15	4, 6, 15, 74, 79	4, 6

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
761	Tank No. 42	VOC	0.78	1.11	4, 6, 15	4, 6, 15, 74, 79	4, 6
762	Tank 43	VOC	0.54	0.58	4, 6, 15	4, 6, 15, 74, 79	4, 6
763	Tank 44	VOC	0.54	0.58	4, 6, 15	4, 6, 15, 74, 79	4, 6
764	Tank 45	VOC	0.47	0.52	4, 6, 15	4, 6, 15, 74, 79	4, 6
765	Tank No. 50	VOC	0.84	0.32	4, 6, 15	4, 6, 15, 74, 79	4, 6
769	Storage Tank 60	VOC	0.11	0.01	4, 6, 15	4, 6, 15, 74, 79	4, 6
770	Storage Tank 61	VOC	0.11	0.01	4, 6, 15	4, 6, 15, 74, 79	4, 6
771	Storage Tank 62	VOC	0.85	0.01	4, 6, 15	4, 6, 15, 74, 79	4, 6
772	Storage Tank 63	VOC	0.96	0.01	4, 6, 15	4, 6, 15, 74, 79	4, 6
773	Storage Tank 81	VOC	19.50	5.50	4, 6, 15	4, 6, 15, 74, 79	4, 6
776	Tank 91	VOC	0.63	0.86	4, 6, 15	4, 6, 15, 74, 79	4, 6
777	Tank 92	VOC	0.63	0.86	4, 6, 15	4, 6, 15, 74, 79	4, 6
778	Tank 93	VOC	0.63	0.86	4, 6, 15	4, 6, 15, 74, 79	4, 6
712	Tank 225 (8)	VOC	2.42	3.06	4, 6, 15	4, 6, 15, 74, 79	4, 6
713	Tank 226 (8)	VOC	2.42	3.06	4, 6, 15	4, 6, 15, 74, 79	4, 6

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
657	Storage Tank 620	VOC	18.42	0.18	4, 6, 15	4, 6, 15, 74, 79	4, 6
658	Storage Tank 621	VOC	18.42	0.18	4, 6, 15	4, 6, 15, 74, 79	4, 6
714	Storage Tank 804	VOC	3.91	2.77	4, 6, 15	4, 6, 15, 74, 79	4, 6
638	Tank 925	VOC	1.99	4.66	4, 6, 15	4, 6, 15, 74, 79	4, 6
639	Tank 926	VOC	1.99	4.66	4, 6, 15	4, 6, 15, 74, 79	4, 6
629	Tank 927 (9)	Xylene	0.62	0.47	4, 6, 15	4, 6, 15, 74, 79	4, 6
630	Tank 928 (9)	Xylene	0.62	0.48	4, 6, 15	4, 6, 15, 74, 79	4, 6
640	Tank No. 929	VOC	1.27	0.40	4, 6, 15	4, 6, 15, 74, 79	4, 6
641	Tank No. 930	VOC	0.97	0.41	4, 6, 15	4, 6, 15, 74, 79	4, 6
662	Storage Tank 1001	VOC	7.98	0.09	4, 6, 15	4, 6, 15, 74, 79	4, 6
664	Storage Tank 1003	VOC	19.50	3.69	4, 6, 15	4, 6, 15, 74, 79	4, 6
670	Storage Tank 1009	VOC	1.11	1.47	4, 6, 15	4, 6, 15, 74, 79	4, 6
666	Storage Tank 1015	VOC	28.45	1.67	4, 6, 15	4, 6, 15, 74, 79	4, 6
676	Storage Tank 1017	VOC	4.79	0.04	4, 6, 15	4, 6, 15, 74, 79	4, 6
722	Storage Tank	VOC	0.71	0.55	4, 6, 15	4, 6, 15, 74, 79	4, 6

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
	1018						
723	Storage Tank 1019	VOC	0.71	0.55	4, 6, 15	4, 6, 15, 67, 74, 79	4, 6
665A	Storage Tank 1020	VOC	28.45	1.67	4, 6, 15	4, 6, 15, 74, 79	4, 6
724	Tank 1022	VOC	4.66	14.68	4, 6, 15	4, 6, 15, 74, 79	4, 6
725	Tank No. 1023	VOC	5.99	20.95	4, 6, 15	4, 6, 15, 74, 79	4, 6
726	Tank 1024	VOC	3.76	9.70	4, 6, 15	4, 6, 15, 74, 79	4, 6
727	Storage Tank 1025	VOC	31.93	8.12	4, 6, 15	4, 6, 15, 74, 79	4, 6
728	Storage Tank 1026	VOC	31.93	7.37	4, 6, 15	4, 6, 15, 74, 79	4, 6
729	Tank No. 1027	VOC	1.06	1.71	4, 6, 15	4, 6, 15, 68, 74, 79	4, 6
677	Storage Tank 1028	VOC	9.12	7.24	4, 6, 15	4, 6, 15, 67, 74, 79	4, 6
718	Tank 1040	VOC	0.77	0.43	4, 6, 15	4, 6, 15, 74, 79	4, 6
719	Tank 1041	VOC	0.70	0.34	4, 6, 15	4, 6, 15, 74, 79	4, 6
720	Tank 1042	VOC	1.08	1.51	4, 6, 15	4, 6, 15, 74, 79	4, 6
732	Tank 2001	VOC	5.09	1.67	4, 6, 15	4, 6, 15, 74, 79	4, 6
733	Tank 2002	VOC	2.89	6.41	4, 6, 15	4, 6, 15, 66, 74, 79	4, 6

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
734	Tank 2003	VOC	8.80	0.93	4, 6, 15	4, 6, 15, 66, 74, 79	4, 6
736	Tank 2005	VOC	8.80	2.21	4, 6, 15	4, 6, 15, 66, 74, 79	4, 6
737	Tank 2006	VOC	8.80	2.21	4, 6, 15	4, 6, 15, 66, 74, 79	4, 6
739	Storage Tank 3101	VOC	10.65	0.66	4, 6, 15	4, 6, 15, 74, 79	4, 6
740	Storage Tank 3102	VOC	10.65	0.66	4, 6, 15	4, 6, 15, 74, 79	4, 6
433	Sour Water Tank	H ₂ S	0.12	0.38	4, 6, 15	4, 6, 15, 74, 79	4, 6
		NH ₃	0.01	0.01			
		VOC	0.46	1.51			
087	Catalyst Regenerator Vent	CO	0.22	0.97	4, 6, 53	4, 6, 9, 79	4, 6, 53
		HCl	0.024	0.11			
		Cl ₂	0.17	0.72			
CPICAS	CPI Carbon Canister	VOC	0.01	0.05	4, 6, 22	4, 6, 22, 74, 79	4, 6
6100	Utility Boiler E	NO _x	25.60	112.13	4, 6, 53, 61, 75	4, 6, 13, 61, 75, 76, 79	4, 6, 53, 61, 75, 76
		CO	23.84	104.43			
		VOC	1.76	7.71			
		SO ₂	9.08	39.77			

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
		PM ₁₀	2.43	10.65			
292 (6)	Combined Stack for the Crude Heater (11-H-1) and the Vacuum Heater (11-H-2)	CO	21.77	82.63	4, 6, 53, 55, 58,60	4, 6, 24, 55, 60, 79	4, 6, 53
		NO _x	52.87	200.67			
		PM	4.63	17.59			
		PM ₁₀	4.63	17.59			
		PM _{2.5}	4.63	17.59			
		SO ₂	19.44	35.44			
		VOC	3.35	12.73			
312	Unibon Heater 21-H-1A	CO	4.44	17.66	4, 6, 53, 55, 58	4, 6, 24, 55, 78, 79	4, 6, 53
		NO _x	3.17	12.61			
		PM	0.40	1.60			
		PM ₁₀	0.40	1.60			
		PM _{2.5}	0.40	1.60			
		SO ₂	1.42	5.65			
		VOC	0.29	1.16			
313	Unibon	CO	4.44	17.66	4, 6, 53, 55, 58	4, 6, 24, 55, 78, 79	4, 6, 53

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
	Heater 21-H-1B	NO _x	3.17	12.61			
		PM	0.40	1.60			
		PM ₁₀	0.40	1.60			
		PM _{2.5}	0.40	1.60			
		SO ₂	1.42	5.65			
		VOC	0.29	1.16			
362	Absorber Reboiler Heater 41-H1 (7)	CO	0.35	0.80	4, 6, 53, 55, 58, 59	4, 6, 11, 55, 79	4, 6, 53
		NO _x	2.25	9.86			
		PM	0.42	1.84			
		PM ₁₀	0.42	1.84			
		PM _{2.5}	0.42	1.84			
		SO ₂	2.03	4.35			
		VOC	0.30	1.33			
362	Debutanizer Reboiler Heater 41-H2 (7)	CO	0.22	0.47	4, 6, 53, 55, 58, 59	4, 6, 11, 55, 79	4, 6, 53
		NO _x	1.42	6.22			
		PM	0.26	1.16			

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
		PM ₁₀	0.26	1.16			
		PM _{2.5}	0.26	1.16			
		SO ₂	1.05	1.73			
		VOC	0.19	0.84			
262	Alky Heater 83-H-1	VOC	0.74	2.93	4, 6, 55, 58	4, 6, 24, 55, 78, 79	4, 6
		NO _x	25.43	101.26			
		SO ₂	3.60	14.33			
		PM	1.02	4.05			
		PM ₁₀	1.02	4.05			
		PM _{2.5}	1.02	4.05			
		CO	11.24	44.77			

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
86	Aromatic Splitter Heater 29H5	VOC	0.28	1.13	4, 6, 55, 58	4, 6, 23, 24, 55, 79	4, 6
		CO	4.35	17.31			
		NO _x	5.18	20.61			
		PM	0.39	1.57			
		PM ₁₀	0.39	1.57			
		PM _{2.5}	0.39	1.57			
		SO ₂	1.61	3.20			
202	ADP Heater 17H1	VOC	0.18	0.81	4, 6, 55, 58	4, 6, 23, 24, 55, 79	4, 6
		CO	1.03	4.51			
		NO _x	3.09	13.52			
		PM	0.26	1.12			
		PM ₁₀	0.26	1.12			
		PM _{2.5}	0.26	1.12			
		SO ₂	1.04	2.29			
356	Process Heater 14-H-1	VOC	0.85	3.73	4, 6, 53, 55, 57, 58, 60	4, 6, 24, 55, 57, 60, 72, 79	4, 6, 53
		NO _x	15.76	69.05			

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
		CO	13.01	57.00			
		PM	1.18	5.16			
		PM ₁₀	1.18	5.16			
		PM _{2.5}	1.18	5.16			
		SO ₂	4.16	18.22			
222	Heater 19-H-1	CO	0.86	3.75	4, 6, 55, 58, 60	4, 6, 24, 55, 60, 78, 79	4, 6
		NO _x	1.02	4.46			
		PM	0.08	0.34			
		PM ₁₀	0.08	0.34			
		PM _{2.5}	0.08	0.34			
		SO ₂	0.28	0.45			
		VOC	0.06	0.25			
223	Heater 19-H-2	CO	0.33	1.46	4, 6, 55, 58, 60	4, 6, 24, 55, 60, 78, 79	4, 6
		NO _x	0.40	1.74			
		PM	0.03	0.13			
		PM ₁₀	0.03	0.13			

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
102	Unifier Reactor Heater	PM _{2.5}	0.03	0.13	4, 6, 12, 55, 58	4, 6, 12, 55, 79	4, 6
		SO ₂	0.11	0.18			
		VOC	0.02	0.10			
		VOC	0.21	0.91			
		NO _x	3.78	16.60			
103	Unifier Stripper Heater	SO ₂	1.04	4.56	4, 6, 12, 55, 58	4, 6, 12, 55, 79	4, 6
		PM ₁₀	0.29	1.26			
		CO	3.17	13.90			
		VOC	0.08	0.35			
		NO _x	1.46	6.41			
		SO ₂	0.40	1.76			
		PM ₁₀	0.11	0.49			
		CO	1.23	5.39			

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
82, 83, 84	Platformer Reactor Heaters 1A, 1B, 1C, 1D	VOC	1.39	6.10	4, 6, 12, 53, 55, 56, 58	4, 6, 12, 55, 56, 79	4, 6, 53, 56
		NO _x	11.36	49.76			
		SO ₂	6.98	30.41			
		PM ₁₀	1.91	8.41			
		CO	21.23	92.93			
85	Platformer Stabilizer Heater	VOC	0.12	0.51	4, 6, 12, 55, 58	4, 6, 12, 55, 79	4, 6
		NO _x	2.10	9.20			
		SO ₂	0.58	2.53			
		PM ₁₀	0.16	0.70			
		CO	1.76	7.72			
207-H-1	GHT Charge Heater	NO _x	1.93	8.44	4, 6, 53, 55, 58	4, 6, 53, 55, 78, 79	4, 53,6
		SO ₂	1.24	5.44			
		VOC	0.29	1.25			
		CO	3.93	17.22			
		PM	0.41	1.80			
		PM ₁₀	0.41	1.80			

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
		PM _{2.5}	0.41	1.80			
412	SRU Incinerator Stack	CO	0.20	0.85	4, 6, 53, 63	4, 6, 27, 55, 63, 79	4, 6, 53
		NO _x	1.37	6.00			
		PM ₁₀	0.11	0.50			
		VOC	0.03	0.15			
		COS	0.50	-			
		CS ₂	0.63	-			
		H ₂ S	0.56	-			
		SO ₂	26.44	-			

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
412A	SRU Incinerator Stack	CO	1.26	2.14	4, 6, 53, 63	4, 6, 27, 55, 63, 79	4, 6, 53
		NO _x	1.20	2.03			
		PM ₁₀	0.11	0.19			
		VOC	0.08	0.14			
		COS	0.50	-			
		CS ₂	0.63	-			
		H ₂ S	0.56	-			
		SO ₂	26.44	-			
412/412A	Annual SRU Incinerator Cap	COS		2.19	4, 6, 53, 63	4, 6, 27, 55, 63, 79	4, 6, 53
		CS ₂		2.76			
		H ₂ S		2.46			
		SO ₂		115.81			
417	Cooling Tower (5)	PM ₁₀	1.54	6.76	4, 6, 29	4, 6, 29, 79	4, 6
		VOC	0.18	0.77			
CT	Cooling Tower	PM	0.32	1.38	4, 6, 29, 30	4, 6, 29, 30, 79	4, 6
		PM ₁₀	0.32	1.38			

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
		PM _{2.5}	0.32	1.38			
		VOC	0.59	2.58			
F069	No. 5 Cooling Tower (5)	PM	2.80	12.26	4, 6, 29	4, 6, 29, 79	4, 6
		PM ₁₀	2.80	12.26			
		PM _{2.5}	2.80	12.26			
		VOC	0.32	1.38			
F110	Cooling Tower 7	VOC	0.71	3.10	4, 6	4, 6, 79	4, 6
F089	Cooling Tower 9 (5)	VOC	0.15	0.67	4, 6, 29	4, 6, 79	4, 6
F208	Cooling Tower 10	VOC	0.34	1.47	4, 6, 29, 30	4, 6, 29, 30, 79	4, 6
		PM	2.88	12.62			
		PM ₁₀	1.22	5.37			
		PM _{2.5}	0.01	0.03			
F3700	Cooling Tower 12	VOC	0.63	2.76	4, 6, 29	4, 6, 29, 79	4, 6
		PM	5.51	24.13			
		PM ₁₀	5.51	24.13			
		PM _{2.5}	5.51	24.13			

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
F297	Cooling Tower 81	VOC	1.26	5.52	4, 6, 29	4, 6, 29, 79	4, 6
		PM	0.68	2.96			
		PM ₁₀	0.68	2.96			
		PM _{2.5}	< 0.01	< 0.01			
F264	Alky Cooling Tower	VOC (5)	1.01	4.42	4, 6, 29	4, 6, 29, 79	4, 6
		PM	0.54	2.37			
		PM ₁₀	0.54	2.37			
		PM _{2.5}	0.54	2.37			
207-CT001	GHT Cooling Tower	VOC	0.12	0.50	4, 6, 29	4, 6, 29, 79	4, 6
		PM	0.05	0.20			
		PM ₁₀	0.05	0.20			
		PM _{2.5}	0.05	0.20			
F442	Fluor Flare	CO	0.10	0.46	4, 6, 32	4, 6, 32, 79	4, 6
		NO _x	0.01	0.06			
		SO ₂	0.01	0.01			
		VOC	0.01	0.01			

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
MEC7	Dock 7 MEC	VOC (10)	55.18	11.98	4, 5, 6, 33, 34, 53, 64	4, 5, 6, 34, 64, 79	4, 5, 6, 53, 64
		Benzene	3.41	0.34			
		NO _x	15.69	22.61			
		CO	11.77	16.96			
		SO ₂	0.01	0.06			
		PM	0.55	0.79			
		PM ₁₀	0.55	0.79			
		PM _{2.5}	0.55	0.79			
591	Dock 7 Loading Fugitives	VOC (10)	159.78	29.35	4, 5, 6, 46	4, 5, 6, 46, 47, 79, 81	4, 5, 6, 46
		Benzene	0.87	0.13			
SULFURLOAD	Molten Sulfur Truck/Railcar Loading (5)	H ₂ S (10)	0.18	0.26	4, 6	4, 6, 38, 79, 80	4, 6
415	Sulfur Pit	H ₂ S	0.44	1.93	4, 6	4, 6, 79	4, 6
F290	Fugitives (5)	VOC	34.80	152.42	4, 6, 44, 46	4, 6, 44, 46, 47, 79	4, 6, 44, 46
F311	Unibon Process Fugitives (5)	VOC	21.17	92.73	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46
F321	Jet/Kerosene	VOC	0.08	0.33	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
	Fugitives (5)	H ₂ S	< 0.01	< 0.01			
		NaOH	< 0.01	< 0.01			
F331	FCC Gasoline Merox Unit Fugitives (5)	VOC	0.28	1.23	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46
F361	Saturates Gas Plant Process Fugitives (5)	VOC	9.10	39.85	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46
		H ₂ S	< 0.01	0.02			
F371	No. 42 Fuel Gas Treatment Fugitives (5)	VOC	1.05	4.59	4, 6, 48	4, 6, 48, 79	4, 6
		Ammonia	< 0.01	0.02			
		H ₂ S	0.02	0.09			
F381	Saturated LPG Merox Fugitives (5)	VOC	1.49	6.54	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46
		H ₂ S	0.01	0.04			
		NaOH	< 0.01	< 0.01			
F391	Unsaturates LPG Merox Fugitives (5)	VOC	1.35	5.92	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46
		H ₂ S	< 0.01	0.01			
		NaOH	< 0.01	< 0.01			
F244	Mole Sieve Unit Process	VOC	0.40	1.74	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
	Fugitives (5)						
F261	Alky Fugitives (5)	VOC	11.93	52.58	4, 6, 46, 51	4, 6, 46, 47, 51, 52, 79	4, 6, 46
		HF	0.08	0.34			
F411	SRU Process Fugitives (5)	H ₂ S	2.63	11.53	4, 6, 44	4, 6, 44, 79	4, 6, 44
		NH ₃	0.41	1.82			
		VOC	5.99	26.24			
F416	SRU Process Fugitives (5)	H ₂ S	0.20	0.85	4, 6, 45, 46	4, 6, 46, 47, 79	4, 6, 46
		NH ₃	0.01	0.01			
		VOC	0.12	0.50			
F211	Process Fugitives (5)	VOC	4.39	19.21	4, 6, 41	4, 6, 41, 43, 79	4, 6, 41
		H ₂ S	< 0.01	< 0.01			
F355	Fugitives (5)	VOC	3.06	13.68	4, 5, 6, 41	4, 5, 6, 41, 43, 71, 79	4, 5, 6, 41
		Benzene	0.84	3.68			
F942	Mixed C3 Terminal Fugitives (5)	VOC	7.93	34.73	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46
F441	Fluor Flare Fugitives (5)	VOC	0.26	1.14	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
F221	Hydrar Fugitives (5)	VOC	1.30	5.68	4, 6, 41, 49	4, 6, 41, 43, 79	4, 6, 41
		H ₂ S	0.01	0.01			
F3720	C4SHP Fugitives (5)	VOC	2.34	10.25	4, 6, 44	4, 6, 44, 79	4, 6, 44
F3200	DeC5 Process Fugitives (5)	VOC	1.70	7.45	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46
F4600	MTBE Process Fugitives (5)	VOC	1.14	5.01	4, 6, 44, 46, 49	4, 6, 44, 46, 47, 79	4, 6, 44, 46
F4710	C5 Merox Unit Fugitives (5)	VOC	0.91	3.96	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46
		NaOH	< 0.01	< 0.01			
F271	Utility Boiler E Fugitives (5)	VOC	0.38	1.66	4, 6, 44	4, 6, 44, 79	4, 6, 44
F1002	Dock 7 Piping Fugitives (5)	VOC	0.37	1.61	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46
F281 (5)	No.2 Oil and Salt Drier Area Fugitives	VOC	0.04	0.16	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46
F821 (5)	Tank Farm & Pump House Area Fugitives (5)	VOC	15.58	68.25	4, 5, 6, 41, 49	4, 5, 6, 41, 43, 79	4, 5, 6, 41
		Benzene	0.49	2.13			
F890	Butane	VOC	0.26	1.13	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46

Major NSR Summary Table

Permit Numbers: 2699A, PSDTX36, PSDTX653M1, PSDTX831, and PSDTX96					Issuance Date: July 21, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
	Storage Fugitives (5)						
F081	Platformer 4 Fugitives (5)	VOC	22.52	98.62	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46
FUG-GHT	GHT Fugitives (5)	VOC	1.50	6.56	4, 6, 46	4, 6, 46, 47, 79	4, 6, 46
		H ₂ S	< 0.01	0.04			
		NH ₃	0.01	0.01			
F061	FCCU 1 Process Fugitives (5)	VOC	23.09	101.40	4, 6, 44, 46	4, 6, 44, 46, 47, 79	4, 6, 44, 46

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name. For fugitive sources, use area name or fugitive source name.

(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1

NO_x - total oxides of nitrogen

SO₂ - sulfur dioxide

PM - total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented

PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented

PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter

CO - carbon monoxide

NH₃ - ammonia

CS₂ - carbon disulfide

COS - carbonyl disulfide

H₂S - hydrogen sulfide

HCl - hydrogen chloride

Cl₂ - chlorine

NaOH - sodium hydroxide

HF - hydrogen fluoride

H₂SO₄ - sulfuric acid PM collected in balk-half of PM test collection device

HAP - hazardous air pollutant as listed in § 112(b) of the Federal Clean Air Act or Title 40 Code of Federal Regulations Part 63, Subpart C

- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
- (5) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission rate. Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.
- (6) These emission rate limits become effective upon completion of the project identified in the Company's March 2013 permit amendment application.
- (7) Each heater vents through a common stack.
- (8) Permit by Rule (PBR) Number 78195 authorizes the change in service to the tanks in this permit and a tank in another permit. PBR 78195 cannot be voided, retains authorization, and is fully incorporated by reference into this table.
- (9) PBR Number 90292 superseded the authorizations for EPNs 629 and 630 contained in PBR 78195 and is fully incorporated into this permit and voided.
- (10) VOC emission rates are total VOC emission rates and include the benzene emission rates.

*These emission rates shall be suspended while EPN 753 is out of service and shall be reinstated when EPN 753 returns to service.

**These emission rates are temporary while EPN 753 is out of service and shall be suspended when EPN 753 returns to service.

Major NSR Summary Table

Permit Numbers: 9604A and PSDTX653M1					Issuance Date: June 18, 2020		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
31-PR-1	No.2 FCCU Regenerator/ESP Stack	VOC	9.0	41.4	9, 10, 11, 12, 13, 14, 17, 19, 20	3, 9, 10, 11, 12,13, 14, 17	10, 12, 21
		NOx (PSD)	169.8	81.2			
		CO	287.2	247.3			
		SO2 (PSD)	262.8	141.4			
		PM	94.9	408.6			
		PM10	94.9	408.6			
		H2SO4 (PSD)	47.5	204.3			
642	Tank 1029	VOC	3.20	9.00	8	8	
643	Tank 1030	VOC	4.63	12.88	8	8	
644	Tank 1031	VOC	5.00	14.11	8	8	
645	Tank 1032	VOC	0.19	0.65	8	8	
667A	Tank 1016	VOC	3.69	8.47	8	8	
692	Tank 201	VOC	1.87	4.04	8	8	
693	Tank 202	VOC	1.87	4.04	8	8	
694	Tank 211	VOC	1.59	3.27	8	8	
695	Tank 212	VOC	1.59	3.27	8	8	
696	Tank 221	VOC	1.65	3.72	8	8	
697	Tank 222	VOC	1.56	3.47	8	8	
698	Tank 223	VOC	1.62	3.53	8	8	
699	Tank 224	VOC	1.59	2.72	8	8	
704	Tank 301	VOC	3.68	10.25	8	8	
705	Tank 302	VOC	3.77	10.25	8	8	
706	Tank 401	VOC	3.69	10.50	8	8	
707	Tank 402	VOC	2.05	5.39	8	8	

Major NSR Summary Table

Permit Numbers: 9604A and PSDTX653M1					Issuance Date: June 18, 2020		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lbs/hour	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
708	Tank 403	VOC	2.05	5.39	8	8	
767	Tank 56	VOC	2.14	4.11	8	8	
768	Tank 57	VOC	2.03	5.11	8	8	
774	Tank 82	VOC	5.67	15.89	8	8	
775	Tank 83	VOC	5.67	15.89	8	8	
3103	Tank 3103	VOC	3.80	0.28	8	8	
F341	Number 2 FCCU Fugitives (5)	VOC	34.73	152.12	15	15	15
F343	Number 2 FCCU Spent Catalyst Truck Loading	PM	0.12	0.01			
		PM ₁₀	0.12	0.01			

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
- NO_x - total oxides of nitrogen
- SO₂ - sulfur dioxide
- PM - total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented
- PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented
- PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter
- CO - carbon monoxide
- H₂SO₄ - sulfuric acid PM collected in back-half of PM test collection device
- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
- (5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.



Texas Commission on Environmental Quality Air Quality Permit

A Permit Is Hereby Issued To
CITGO Refining and Chemicals Company L.P.
Authorizing the Construction and Operation of
Citgo Corpus Christi Refinery East Plant
Located at Corpus Christi, Nueces County, Texas
Latitude 27.810555 Longitude -97.426944

Permits: 2699A, PSDTX36, PSDTX653M1, PSDTX831
and PSDTX96

Issuance Date: July 21, 2023

Expiration Date: March 31, 2026

A handwritten signature in black ink, appearing to read "K. Keel".

For the Commission

1. **Facilities** covered by this permit shall be constructed and operated as specified in the application for the permit. All representations regarding construction plans and operation procedures contained in the permit application shall be conditions upon which the permit is issued. Variations from these representations shall be unlawful unless the permit holder first makes application to the Texas Commission on Environmental Quality (commission) Executive Director to amend this permit in that regard and such amendment is approved. [Title 30 Texas Administrative Code (TAC) Section 116.116 (30 TAC § 116.116)] ¹
2. **Voiding of Permit.** A permit or permit amendment is automatically void if the holder fails to begin construction within 18 months of the date of issuance, discontinues construction for more than 18 months prior to completion, or fails to complete construction within a reasonable time. Upon request, the executive director may grant an 18-month extension. Before the extension is granted the permit may be subject to revision based on best available control technology, lowest achievable emission rate, and netting or offsets as applicable. One additional extension of up to 18 months may be granted if the permit holder demonstrates that emissions from the facility will comply with all rules and regulations of the commission, the intent of the Texas Clean Air Act (TCAA), including protection of the public's health and physical property; and (b)(1) the permit holder is a party to litigation not of the permit holder's initiation regarding the issuance of the permit; or (b)(2) the permit holder has spent, or committed to spend, at least 10 percent of the estimated total cost of the project up to a maximum of \$5 million. A permit holder granted an extension under subsection (b)(1) of this section may receive one subsequent extension if the permit holder meets the conditions of subsection (b)(2) of this section. [30 TAC § 116.120]
3. **Construction Progress.** Start of construction, construction interruptions exceeding 45 days, and completion of construction shall be reported to the appropriate regional office of the commission not later than 15 working days after occurrence of the event. [30 TAC § 116.115(b)(2)(A)]
4. **Start-up Notification.** The appropriate air program regional office shall be notified prior to the commencement of operations of the facilities authorized by the permit in such a manner that a representative of the commission may be present. The permit holder shall provide a separate notification for the commencement of operations for each unit of phased construction, which may involve a series of units commencing operations at different times. Prior to operation of the facilities authorized by the permit, the permit holder shall identify the source or sources of allowances to be utilized for compliance with Chapter 101, Subchapter H, Division 3 of this title (relating to Mass Emissions Cap and Trade Program). [30 TAC § 116.115(b)(2)(B)]
5. **Sampling Requirements.** If sampling is required, the permit holder shall contact the commission's Office of Compliance and Enforcement prior to sampling to obtain the proper data forms and procedures. All sampling and testing procedures must be approved by the executive director and coordinated with the regional representatives of the commission. The permit holder is also responsible for providing sampling facilities and conducting the sampling operations or contracting with an independent sampling consultant. [30 TAC § 116.115(b)(2)(C)]
6. **Equivalency of Methods.** The permit holder must demonstrate or otherwise justify the equivalency of emission control methods, sampling or other emission testing methods, and monitoring methods proposed as alternatives to methods indicated in the conditions of the permit. Alternative methods shall be applied for in writing and must be reviewed and approved by the executive director prior to their use in fulfilling any requirements of the permit. [30 TAC § 116.115(b)(2)(D)]
7. **Recordkeeping.** The permit holder shall maintain a copy of the permit along with records containing the information and data sufficient to demonstrate compliance with the permit, including production records and

operating hours; keep all required records in a file at the plant site. If, however, the facility normally operates unattended, records shall be maintained at the nearest staffed location within Texas specified in the application; make the records available at the request of personnel from the commission or any air pollution control program having jurisdiction in a timely manner; comply with any additional recordkeeping requirements specified in special conditions in the permit; and retain information in the file for at least two years following the date that the information or data is obtained. [30 TAC § 116.115(b)(2)(E)]

8. **Maximum Allowable Emission Rates.** The total emissions of air contaminants from any of the sources of emissions must not exceed the values stated on the table attached to the permit entitled "Emission Sources-- Maximum Allowable Emission Rates." [30 TAC § 116.115(b)(2)(F)] ¹
9. **Maintenance of Emission Control.** The permitted facilities shall not be operated unless all air pollution emission capture and abatement equipment is maintained in good working order and operating properly during normal facility operations. The permit holder shall provide notification in accordance with 30 TAC §101.201, 101.211, and 101.221 of this title (relating to Emissions Event Reporting and Recordkeeping Requirements; Scheduled Maintenance, Startup, and Shutdown Reporting and Recordkeeping Requirements; and Operational Requirements). [30 TAC§ 116.115(b)(2)(G)]
10. **Compliance with Rules.** Acceptance of a permit by an applicant constitutes an acknowledgment and agreement that the permit holder will comply with all rules and orders of the commission issued in conformity with the TCAA and the conditions precedent to the granting of the permit. If more than one state or federal rule or regulation or permit condition is applicable, the most stringent limit or condition shall govern and be the standard by which compliance shall be demonstrated. Acceptance includes consent to the entrance of commission employees and agents into the permitted premises at reasonable times to investigate conditions relating to the emission or concentration of air contaminants, including compliance with the permit. [30 TAC § 116.115(b)(2)(H)]
11. **This** permit may not be transferred, assigned, or conveyed by the holder except as provided by rule. [30 TAC § 116.110(e)]
12. **There** may be additional special conditions attached to a permit upon issuance or modification of the permit. Such conditions in a permit may be more restrictive than the requirements of Title 30 of the Texas Administrative Code. [30 TAC § 116.115(c)]
13. **Emissions** from this facility must not cause or contribute to "air pollution" as defined in Texas Health and Safety Code (THSC) §382.003(3) or violate THSC § 382.085. If the executive director determines that such a condition or violation occurs, the holder shall implement additional abatement measures as necessary to control or prevent the condition or violation.
14. **The** permit holder shall comply with all the requirements of this permit. Emissions that exceed the limits of this permit are not authorized and are violations of this permit. ¹

¹ Please be advised that the requirements of this provision of the general conditions may not be applicable to greenhouse gas emissions.

Common Acronyms in Air Permits

°C = Temperature in degrees Celsius	GLCmax = maximum (predicted) ground-level concentration
°F = Temperature in degrees Fahrenheit	gpm = gallon per minute
°K = Temperature in degrees Kelvin	gr/1000scf = grain per 1000 standard cubic feet
µg = microgram	gr/dscf = grain per dry standard cubic feet
µg/m ³ = microgram per cubic meter	H ₂ CO = formaldehyde
acfm = actual cubic feet per minute	H ₂ S = hydrogen sulfide
AMOC = alternate means of control	H ₂ SO ₄ = sulfuric acid
AOS = alternative operating scenario	HAP = hazardous air pollutant as listed in § 112(b) of the Federal Clean Air Act or Title 40 Code of Federal Regulations Part 63, Subpart C
AP-42 = Air Pollutant Emission Factors, 5th edition	HC = hydrocarbons
APD = Air Permits Division	HCl = hydrochloric acid, hydrogen chloride
API = American Petroleum Institute	Hg = mercury
APWL = air pollutant watch list	HGB = Houston/Galveston/Brazoria
BPA = Beaumont/ Port Arthur	hp = horsepower
BACT = best available control technology	hr = hour
BAE = baseline actual emissions	IFR = internal floating roof tank
bbl = barrel	in H ₂ O = inches of water
bbl/day = barrel per day	in Hg = inches of mercury
bhp = brake horsepower	IR = infrared
BMP = best management practices	ISC3 = Industrial Source Complex, a dispersion model
Btu = British thermal unit	ISCST3 = Industrial Source Complex Short-Term, a dispersion model
Btu/scf = British thermal unit per standard cubic foot or feet	K = Kelvin; extension of the degree Celsius scaled-down to absolute zero
CAA = Clean Air Act	LACT = lease automatic custody transfer
CAM = compliance-assurance monitoring	LAER = lowest achievable emission rate
CEMS = continuous emissions monitoring systems	lb = pound
cfm = cubic feet (per) minute	lb/day = pound per day
CFR = Code of Federal Regulations	lb/hr = pound per hour
CN = customer ID number	lb/MMBtu = pound per million British thermal units
CNG = compressed natural gas	LDAR = Leak Detection and Repair (Requirements)
CO = carbon monoxide	LNG = liquefied natural gas
COMS = continuous opacity monitoring system	LPG = liquefied petroleum gas
CPMS = continuous parametric monitoring system	LT/D = long ton per day
DFW = Dallas/ Fort Worth (Metroplex)	m = meter
DE = destruction efficiency	m ³ = cubic meter
DRE = destruction and removal efficiency	m/sec = meters per second
dscf = dry standard cubic foot or feet	MACT = maximum achievable control technology
dscfm = dry standard cubic foot or feet per minute	MAERT = Maximum Allowable Emission Rate Table
ED = (TCEQ) Executive Director	MERA = Modeling and Effects Review Applicability
EF = emissions factor	mg = milligram
EFR = external floating roof tank	mg/g = milligram per gram
EGU = electric generating unit	mL = milliliter
EI = Emissions Inventory	MMBtu = million British thermal units
ELP = El Paso	MMBtu/hr = million British thermal units per hour
EPA = (United States) Environmental Protection Agency	MSDS = material safety data sheet
EPN = emission point number	MSS = maintenance, startup, and shutdown
ESL = effects screening level	MW = megawatt
ESP = electrostatic precipitator	NAAQS = National Ambient Air Quality Standards
FCAA = Federal Clean Air Act	NESHAP = National Emission Standards for Hazardous Air Pollutants
FCCU = fluid catalytic cracking unit	NGL = natural gas liquids
FID = flame ionization detector	NNSR = nonattainment new source review
FIN = facility identification number	NO _x = total oxides of nitrogen
ft = foot or feet	NSPS = New Source Performance Standards
ft/sec = foot or feet per second	
g = gram	
gal/wk = gallon per week	
gal/yr = gallon per year	
GLC = ground level concentration	

PAL = plant-wide applicability limit
PBR = Permit(s) by Rule
PCP = pollution control project
PEMS = predictive emission monitoring system
PID = photo ionization detector
PM = periodic monitoring
PM = total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented
PM_{2.5} = particulate matter equal to or less than 2.5 microns in diameter
PM₁₀ = total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented
POC = products of combustion
ppb = parts per billion
ppm = parts per million
ppmv = parts per million (by) volume
psia = pounds (per) square inch, absolute
psig = pounds (per) square inch, gage
PTE = potential to emit
RA = relative accuracy
RATA = relative accuracy test audit
RM = reference method
RVP = Reid vapor pressure
scf = standard cubic foot or feet
scfm = standard cubic foot or feet (per) minute
SCR = selective catalytic reduction
SIL = significant impact levels
SNCR = selective non-catalytic reduction
SO₂ = sulfur dioxide
SOCMI = synthetic organic chemical manufacturing industry
SRU = sulfur recovery unit
TAC = Texas Administrative Code
TCAA = Texas Clean Air Act
TCEQ = Texas Commission on Environmental Quality
TD = Toxicology Division
TLV = threshold limit value
TMDL = total maximum daily load
tpd = tons per day
tpy = tons per year
TVP = true vapor pressure
VOC = volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
VRU = vapor recovery unit or system

Special Conditions

Permit Number 2699A, PSDTX36, PSDTX96, PSDTX653M1, PSDTX831

1. This permit authorizes emissions from those points listed in the attached table entitled "Emission Sources - Maximum Allowable Emission Rates" (MAERT) and the facilities covered by this permit are authorized to emit subject to the emission rate limits on the MAERT and other requirements specified in the special conditions.
2. Non-fugitive emissions from relief valves, safety valves, or rupture discs of gases containing volatile organic compounds (VOC) at a concentration of greater than 1 percent are not authorized by this permit unless authorized on the MAERT. Any releases directly to atmosphere from relief valves, safety valves, or rupture discs of gases containing VOC at a concentration greater than 1 weight percent are not consistent with good practice for minimizing emissions. All existing process safety valves in VOC service that discharge to the atmosphere only as a result of fire or failure of utilities are exempt from these requirements.
3. A copy of this permit shall be kept at the plant site and made available at the request of personnel from the Texas Commission on Environmental Quality (TCEQ) or any duly authorized air pollution control agency. In addition, the holder of this permit shall identify all equipment covered by this permit at the property that has the potential of emitting air contaminants. Permitted emission points shall be identified corresponding to the Emission Point Numbers (EPN) on the MAERT.

Federal Applicability

4. These facilities shall comply with all applicable requirements of the U.S. Environmental Protection Agency (EPA) regulations on Standards of Performance for New Stationary Sources (NSPS) promulgated in Title 40 Code of Federal Regulations Part 60 (40 CFR Part 60):
 - A. Subpart A, General Provisions.
 - B. Subpart Db, Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units.
 - C. Subpart J, Standards of Performance for Petroleum Refineries.
 - D. Subpart Ja, Standards of Performance for Petroleum Refineries for Which Construction, Reconstruction, or Modification Commenced After May 14, 2007.
 - E. Subpart K, Standards of Performance for Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After June 11, 1973, and Prior to May 19, 1978.
 - F. Subpart Ka, Standards of Performance for Storage Vessels for Petroleum Liquids for Which Construction, Reconstruction, or Modification Commenced After May 18, 1978, and Prior to July 23, 1984.
 - G. Subpart Kb, Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced after July 23, 1984.
 - H. Subpart VV, Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry for which Construction, Reconstruction, or Modification Commenced After January 5, 1981, and on or Before November 7, 2006.
 - I. Subpart GGG, Standards of Performance for Equipment Leaks of VOC in Petroleum Refineries for which Construction, Reconstruction, or Modification Commenced after January 4, 1983, and on or Before November 7, 2006.

Special Conditions

Permit Numbers 2699A, PSDTX36, PSDTX96, PSDTX653M1, PSDTX831

Page 2

- J. Subpart GGGa, Standards of Performance for Equipment Leaks of VOC in Petroleum Refineries for which Construction, Reconstruction, or Modification Commenced After November 7, 2006.
 - K. Subpart NNN, Standards of Performance for VOC Emissions from Synthetic Organic Chemical Manufacturing Industry (SOCMI) Distillation Operations.
 - L. Subpart QQQ, Standards of Performance for VOC Emissions from Petroleum Refinery Wastewater Systems.
5. These facilities shall comply with all applicable requirements of the EPA regulations of National Emissions Standards for Hazardous Air Pollutants (NESHAPS) in 40 CFR Part 61:
- M. Subpart A, General Provisions.
 - N. Subpart J, National Emission Standards for Equipment Leaks (Fugitive Emission Sources) of Benzene.
 - O. Subpart V, National Emission Standards for Equipment Leaks (Fugitive Emission Sources).
 - P. Subpart Y, National Emission Standards for Benzene Emissions from Benzene Storage Vessels.
 - Q. Subpart FF, National Emission Standard for Benzene Waste Operations.
6. These facilities shall comply with all applicable requirements of the EPA regulations on NESHAPS for Source Categories in 40 CFR Part 63:
- R. Subpart A, General Provisions.
 - S. Subpart F, National Emission Standards for Organic Hazardous Air Pollutants from the SOCMI.
 - T. Subpart G, National Emission Standards for Organic Hazardous Air Pollutants from the Synthetic Organic Chemical Manufacturing Industry Process Vents, Storage Vessels, Transfer Operations, and Wastewater.
 - U. Subpart H, National Emission Standards for Organic Hazardous Air Pollutants for Equipment Leaks.
 - V. Subpart R, National Emission Standards for Gasoline Distribution Facilities (Bulk Gasoline Terminals and Pipeline Breakout Stations).
 - W. Subpart Y, National Emission Standards for Marine Tank Vessel Loading Operations.
 - X. Subpart CC, National Emission Standards for Hazardous Air Pollutants from Petroleum Refineries.
 - Y. Subpart VV, National Emission Standards for Oil-Water Separators and Organic-Water Separators.
 - Z. Subpart UUU, NESHAPS for Petroleum Refineries: Catalytic Cracking Units, Catalytic Reforming Units, and Sulfur Recovery Units.

Special Conditions

Permit Numbers 2699A, PSDTX36, PSDTX96, PSDTX653M1, PSDTX831

Page 3

Emissions Standards

7. The facilities in this permit are authorized to operate up to 8,760 hours per year.
8. Daily and annual production shall be limited to the following:

Unit	Short Term Production	Annual Production
No. 4 Crude & Vacuum Unit	165, 000 Barrel Per Calendar Day (BPCD) (Crude Oil)	---
Aromatic Feed to ADP	18,230 Barrel Per Stream Day (BPSD)	---
Unibon Unit	75,000 Barrel Per Calendar Day (BPCD) (Gas Oil)	26 Million Barrels Per Year (MMBPY) (Gas Oil)
Molten Sulfur Loading	24 Long Ton Per Hour (LTPH)	67,525 Long Ton Per Year (LTPY)
Jet Kerosene Merox	30,000 Barrel Per Day (BPD) (Kerosene/ Jet fuel)	---
FCC Gasoline Merox	55,000 BPD (Gasoline Feedstock)	16,790,000 BPY (Gasoline Feedstock)
Hydrar Unit	---	1.533 Million Barrels Per Year (MMBPY) (Cyclohexane)
C4 Selective Hydrogenation Process Unit	258,839 Pounds Per Hour (lb/hr) (feed rate)	---
C5 Merox	9,800 BPD (Raffinate)	---
Cumene	--	5,638,835 BPY (Cumene)

9. The calculated coke burn rate from the Catalyst Regenerator Vent (EPN 087) shall not exceed that identified in the confidential portion of the permit application.

Fuel

10. No combustion unit at this facility shall burn fuel oil. Fuel oil shall mean any liquid fossil fuel with a sulfur content of greater than 500 ppmw.
11. Refinery fuel gas sulfur content shall not exceed 160 parts per million by volume, dry (ppmvd) of hydrogen sulfide (H₂S) on an hourly basis. The maximum H₂S concentration in the fuel gas feed to Absorber Reboiler Heater 41-H1 and Debutanizer Reboiler Heater 41-H2 (common stack

identified as EPN 362) shall not exceed 162 ppmv on a rolling 3-hour average basis (updated hourly), and shall not exceed 60 ppmv on a 365 successive calendar day rolling average basis.

12. Fuel gas usage shall be monitored and recorded. Hourly firing rates shall be calculated immediately upon request by the TCEQ. Fuel gas to each heater (EPNs 82, 83, 84, 85, 102, and 103) shall be continuously monitored.
13. Fuel used in the Utility Boiler E (EPN 6100) shall be limited to pipeline-quality, sweet natural gas containing no more than 1.0 grain of H₂S and 5 grains of total sulfur per 100 dry standard cubic feet (dscf) and/or refinery fuel gas containing no more than 10 grains of H₂S per 100 dscf. Use of any other fuel will require an amendment to the permit.

Storage Tanks

14. The true vapor pressure (TVP) of any liquid stored at this facility in an atmospheric tank shall not exceed 11.0 pounds per square inch absolute (psia).
15. Storage tanks are subject to the following requirements: The control requirements specified in parts B-D of this condition shall not apply (1) where the VOC has an aggregate partial pressure of less than 0.50 psia at the maximum feed temperature or 95 degrees Fahrenheit (°F), whichever is greater, or (2) to storage tanks smaller than 25,000 gallons.
 - A. The tank emissions must be controlled as specified in one of the paragraphs below:
 - (1) An internal floating deck or "roof" shall be installed. A domed external floating roof tank is equivalent to an internal floating roof tank. The floating roof shall be equipped with one of the following closure devices between the wall of the storage vessel and the edge of the floating roof: (1) a liquid-mounted seal, (2) two continuous seals mounted one above the other, or (3) a mechanical shoe seal. This does not apply to Tank No. 1023.
 - (2) An open-top tank shall contain a floating roof (external floating roof tank) which uses double seal or secondary seal technology provided the primary seal consists of either a mechanical shoe seal or a liquid-mounted seal and the secondary seal is rim-mounted. A weathershield is not approved as a secondary seal unless specifically reviewed and determined to be vapor-tight.
 - B. For any tank equipped with a floating roof, the permit holder shall perform the visual inspections and any seal gap measurements specified in 40 CFR §60.113b Testing and Procedures (as amended at 54 FR 32973, August 11, 1989) to verify fitting and seal integrity. Records shall be maintained of the dates inspection was performed, any measurements made, results of inspections and measurements made (including raw data), and actions taken to correct any deficiencies noted.
 - C. The floating roof design shall incorporate sufficient flotation to conform to the requirements of American Petroleum Institute (API) Code 650 dated November 1, 1998 except that an internal floating cover need not be designed to meet rainfall support requirements and the materials of construction may be steel or other materials.

- D. Except for labels, logos, etc. not to exceed 15 percent of the tank total surface area, uninsulated tank exterior surfaces exposed to the sun shall be white or unpainted aluminum. Storage tanks must be equipped with permanent submerged fill pipes.
- E. The permit holder shall maintain an emissions record which includes calculated emissions of VOC from all storage tanks during the previous calendar month and the past consecutive 12-month period. The record shall include tank identification number, control method used, tank capacity in gallons, name of the material stored, VOC molecular weight, VOC monthly average temperature in °F, VOC vapor pressure at the monthly average material temperature in psia, VOC throughput for the previous month and year-to-date. Records of monthly average temperature are not required to be kept for unheated tanks which receive liquids that are at or below ambient temperatures.

Emissions from tanks shall be calculated using the methods that were used to determine the MAERT limits in the permit application. Sample calculations from the application shall be attached to a copy of this permit at the plant site.

The permit holder shall maintain a record of tank throughput for the previous month and the past consecutive 12-month period for each tank.

- 16. [RESERVED] (03/22)
- 17. Tank 47-T103 shall be limited to a maximum fill rate of 25 gallons per minute.
- 18. Storage tank throughput and service shall be limited to the table in Attachment A.
- 19. The following requirements apply to Tank Nos. 929, 930, 1023, 1027, 1, 3, 4, 5, 13, 14, 20, and 50 (EPNs: 640, 641, 725, 729, 742, 744, 745, 746, 749, 750, 751, and 765).
 - A. The tanks shall be designed to completely drain its entire contents to a sump in a manner that leaves no more than 9 gallons of free-standing liquid in the tank or the sump.
 - B. Tanks shall be constructed or equipped with a connection to a vapor recovery system that routes vapors from the vapor space under the landed roof to a control device.
- 20. Operation without visible liquid leaks or spills shall be maintained at all loading/unloading facilities, regardless of vapor pressure. This does not apply to momentary dripping associated with the initial connection or disconnection of fittings. Sustained dripping from fittings during loading/unloading operations is not permitted. Any liquid spill that occurs during loading/unloading activities shall be reported pursuant to 30 Texas Administrative Code §§101.201, 101.211, and 101.221 and shall be cleaned up immediately to minimize air emissions.

Catalyst Regenerator Vent

- 21. The Catalyst Regenerator Vent (EPN 087) shall be controlled by the UOP Regeneration Vent Gas Chlorosorb System.

Corrugated Plate Interceptor (CPI) Separator

22. The CPI separator shall be covered and the exhaust vent sent to a carbon absorption system (CAS), emission point number (EPN CPICAS) consisting of at least two activated carbon canisters that are connected in series.
- A. The CAS shall be sampled every 48 hours to determine breakthrough of volatile organic compounds (VOC). The sampling point shall be at the outlet of the initial canister but before the inlet to the second or final polishing canister.
- B. The VOC sampling and analysis shall be performed using an instrument with a flame ionization detector (FID), photoionization detector (PID), or a TCEQ-approved alternative detector. The instrument/FID must meet all requirements specified in Section 8.1 of EPA Method 21 (40 CFR 60, Appendix A). Sampling and analysis for VOC breakthrough shall be performed as follows: **(03/22)**
- (1) Immediately prior to performing sampling, the instrument shall be calibrated with zero and span calibration gas mixtures. Zero gas shall be certified to contain less than 0.1 ppmv total hydrocarbons. Span calibration gas shall be at a concentration within ± 10 percent of 50 ppmv, and certified by the manufacturer to be ± 2 percent accurate. Calibration error for the zero and span calibration gas checks must be less than ± 5 percent of the span calibration gas value before sampling may be conducted. **(03/22)**
 - (2) The sampling point shall be at the outlet of the initial canister but before the inlet to the second or final polishing canister. Sample ports or connections must be designed such that air leakage into the sample port does not occur during sampling.
 - (3) During sampling, data recording shall not begin until after two times the instrument response time. The VOC concentration shall be monitored for at least 5 minutes, recording 1-minute averages
- C. Breakthrough shall be defined as the highest 1-minute average measured VOC concentration at or exceeding 50 ppmv. When the condition of breakthrough of VOC from the initial saturation canister occurs, the waste gas flow shall be switched to the second canister and a fresh canister shall be placed as the new final polishing canister within 48 hours. Sufficient new activated carbon canisters shall be maintained at the site to replace spent carbon canisters such that replacements can be done in the above specified time frame.
- D. Records of the CAS monitoring maintained at the plant site, shall include (but are not limited to) the following:
- (1) Sample time and date.
 - (2) Monitoring results (ppmv).
 - (3) Corrective action taken including the time and date of that action.
 - (4) Process operations occurring at the time of sampling.

Special Conditions

Permit Numbers 2699A, PSDTX36, PSDTX96, PSDTX653M1, PSDTX831

Page 7

- E. Alternate monitoring or sampling requirements that are equivalent or better may be approved by the TCEQ Regional Manager. Alternate requirements must be approved in writing before they can be used for compliance purposes.

Heaters and Boilers

23. Refinery fuel gas fired in heaters shall not exceed 0.1 grain of H₂S per dscf on an hourly basis. Refinery fuel gas fired in ADP Heater 17-H-1 and Aromatic Splitter Heater 29-H-5 shall not exceed 0.05 grains of H₂S per dscf on an annual basis. The rate of fuel gas burned must be measured and recorded daily. These measurements shall be summarized monthly and the record of any such measurements and summary shall be retained for at least two years following the date of such measurements and summaries.
24. The firing rates of the heaters are listed in the table below. Records of the hourly and annual firing rates shall be maintained and be made available upon request by the Executive Director of the TCEQ or a designated representative.

EPN	Source Name	Firing Rate (MMBtu/hr) Hourly Average	Firing Rate (MMBtu/hr) Annual Average
292	Crude Heater 11-H-1	475	
292	Vacuum Heater 11-H-2	147	
312	Unibon Heater 21-H-1A	52.8	48.0
313	Unibon Heater 21-H-1B	52.8	48.0
262	Alkylation Heater 83-H-1	133.8	121.7
356	Process Heater 14-H-1	132	
222	Process Heater 19-H-1	9.0	
223	Process Heater 19-H-2	3.5	
202	ADP Heater 17-H-1	34.3	
86	Aromatic Splitter Heater 29-H-5	52.8	

25. Emissions of NO_x and CO for the heaters are listed in the table below.

EPN	Source Name	Maximum Allowable Emissions Oxides of Nitrogen (NO _x) – Hourly Average	Maximum Allowable Emissions Carbon Monoxide (CO) – Hourly Average
292	Crude Heater 11-H-1 & Vacuum Heater 11-H-2	0.085 lb/MMBtu	---
356	Process Heater 14-H-1	0.12 lb/MMBtu	134 ppmvd
312	Unibon Heater 21-H-1A	0.06 lb/MMBtu	---
313	Unibon Heater 21-H-1B	0.06 lb/MMBtu	---
362	Absorber and Debutanizer Reboiler Heaters 41-H-1 and 41-H-2	0.04 lb/MMBtu	50 ppmvd
82	Platformer Reactor Heater	0.045 lb/MMBtu	0.084 lb/MMBtu
83	Platformer Reactor Heater	0.045 lb/MMBtu	0.084 lb/MMBtu
84	Platformer Reactor Heater	0.045 lb/MMBtu	0.084 lb/MMBtu
207-H-1	Charge Heater ¹	0.035 lb/MMBtu	---
6100	Utility Boiler E	0.06 lb/MMBtu (natural gas) 0.08 lb/MMBtu (refinery fuel gas)	100 ppmvd
86	Aromatic Splitter Heater 29-H-5 ⁴	86.57 lb/MMscf ²	72.72 lb/MMscf ³
202	ADP Heater 17-H-1 ⁴	0.09 lb/MMBtu ⁵	0.03 lb/MMBtu ³

1. 1-hr average

2. lb/MMscf = pounds per million standard cubic feet [higher heating value (HHV), 1-hr or annual rolling average]

3. corrected to 3% O₂

4. Except during periods of planned maintenance, startup, and shutdown (MSS)

5. lb/MMBtu = pounds per million British thermal unit (HHV, 1-hr or annual rolling average)

26. For any future expansion or modification using the excess steam capacity afforded to this facility by the installation of the Utility Boiler E, the permit holder or the operator of this facility shall add any emissions increase from the future expansion to the actual emissions increase from the excess steam generation using the Utility Boiler E to determine if prevention of significant deterioration and/or nonattainment review is applicable for any regulated pollutant.

SRU

27. The in-stack concentration of SO₂ from each Shell Claus Off-Gas Treating Unit (SCOT) tail gas incinerator (TGI) shall not exceed 250 ppmv at dry conditions, 0 percent excess air, calculated as an hourly average.

The sulfur pit vessel that receives molten sulfur from each sulfur recovery unit (SRU) shall vent to the inlet of the tail gas incinerator(s).

28. The minimum sulfur recovery efficiency for these permitted units (taken as a whole) shall be 99.8 percent. The sulfur recovery efficiency shall be determined by calculation as follows:

$$\text{Efficiency} = \frac{(\text{S recovered}) * (100)}{(\text{S recovered}) + (\text{S in both TGI stacks})}$$

Where: Efficiency = sulfur recovery efficiency, percent

$$\text{S recovered, lbs/hr} = \frac{\text{monthly S production}}{\text{Number hrs/month}}$$

$$\text{S in both incinerator} = (\text{Total Hourly CEM SO}_2 \text{ readings over a 24-hour period converted to lbs of SO}_2) / 2$$

Cooling Towers

29. The cooling towers (except F110) shall be operated and monitored in accordance with the following:
- A. The cooling tower water shall be monitored monthly for VOC leakage from heat exchangers in accordance with the requirements of the TCEQ Sampling Procedures Manual, Appendix P (dated January 2003 or a later edition) or another equivalent air stripping method described in the following paragraphs.
 - B. For all sampling required by this condition, the sample port for the water returning from the heat exchangers to the cooling tower shall be located on the top of the horizontal section of the water line returning to the cooling tower. The minimum detection level of the overall testing system shall be no greater than 0.15 ppmw VOC (concentration VOC in water entering the cooling tower). The minimum detection limit for the air stripped VOC shall be no greater than 2.50 ppmv (concentration VOC in the stripping air). Calibration standards shall include at least zero ppmv and 10 ppmv VOC in air (as methane).
 - C. Cooling water VOC concentrations above 0.08 ppmv indicate faulty equipment for all other cooling towers. Equipment shall be maintained so as to minimize VOC emissions into the cooling water. Faulty equipment shall be repaired at the earliest opportunity but no later than the next scheduled shutdown of the process unit in which the leak occurs.
 - D. Except as indicated in (E), emissions from cooling towers are not authorized if the VOC concentration of the water returning to the cooling tower exceeds 0.80 ppmv. The VOC concentrations above 0.80 ppmv in all cooling towers are not subject to extensions for delay of repair under this permit condition. The results of the monitoring and maintenance efforts shall be recorded and such records shall be maintained for a period of five (5) years. The records shall be made available to the TCEQ Executive Director or personnel of any air pollution program with jurisdiction upon request.
 - E. Emissions from Cooling Tower 12, No. 5 Cooling Tower, and Cooling Tower 417 (EPNs F3700, F069, and 417) are not authorized if the VOC concentration of the water returning to the cooling tower exceeds 5 parts per million by weight (ppmw). The VOC

concentrations above 5 ppmw are not subject to extensions for delay of repair under this permit condition. The results of the monitoring and maintenance efforts shall be recorded, and such records shall be maintained for a period of two years. The records shall be made available at the request of TCEQ personnel.

- F. Cooling water sampling shall be representative of the cooling tower feed water and shall be conducted using approved methods. The cooling water shall be sampled once a week for total dissolved solids (TDS).
- (1) The analysis method for TDS shall be EPA Method 160.1, American Society for Testing and Materials (ASTM) D5907, and SM 2540 C [Standard Method (SM) - 19th edition of Standard Methods for Examination of Water]. Water samples should be capped upon collection, and transferred to a laboratory area for analysis.
 - (2) Alternate sampling and analysis methods may be used to comply with D(1) with written approval from the TCEQ Regional Director.
 - (3) Records of all instrument calibrations and test results and process measurements used for the emission calculations shall be retained.
 - (4) After 8 weeks of sampling, for EPNs F297 and 207-CT001, the permit holder shall compare these results with those used to determine cycles of concentration to establish the maximum cycles that would indicate compliance with the Particulate Matter (PM) 10 and PM2.5 allowable emission rates. That measure, cycles of concentration, may be used to demonstrate compliance after the demonstration is complete.
- G. The Alky Cooling Tower (EPN F264) shall be analyzed for particulate emissions. Cooling water shall be sampled at least once per day for TDS. TDS monitoring may be reduced to weekly if conductivity is monitored daily and TDS is calculated using a ratio of TDS-to-conductivity. The ratio of TDS-to-conductivity shall be determined by concurrently monitoring TDS and conductivity on a weekly basis. Particulate emission rates shall be calculated using the measured TDS and the ratio or correlation of TDS to conductivity measurements, the design drift factor and the cooling water circulation rate.
- H. The appropriate equipment shall be maintained so as to minimize fugitive VOC emissions from all cooling towers. Faulty equipment shall be repaired at the earliest opportunity but no later than the next scheduled shutdown of the process unit in which the leak occurs.
30. Cooling Tower EPNs F208 and CT shall be operated and monitored in accordance with the following:
- A. Each cooling tower shall be equipped with drift eliminators having manufacturer's design assurance of 0.02% and 0.001% drift or less for EPNs F208 and CT, respectively. Drifts eliminators shall be maintained and inspected at least annually. The permit holder shall maintain records of all inspections and repairs.
 - B. TDS shall not exceed 3600 and 4500 ppmw for EPNs F208 and CT respectively. Dissolved solids in the cooling water drift are considered to be emitted as PM, PM10, and PM2.5 as represented in the permit application calculations.
 - C. Emission rates of PM, PM10 and PM2.5 shall be calculated using the measured TDS, the design drift rate and the daily maximum and average actual cooling water circulation rate for the short term and annual average rates. Alternately, the design maximum circulation rate may be used for all calculations. Emission records shall be updated monthly.

31. Cooling water Total Organic Carbon (TOC) concentrations above 54 ppmw in EPN F110 indicate faulty equipment. Emissions from the cooling tower are not authorized if the TOC concentration of the water returning to the cooling tower exceeds 540 ppmw. The TOC concentrations above 540 ppmw are not subject to extensions for delay of repair under this permit condition.

Flares

32. Flare (EPN F442) shall be designed and operated in accordance with the following requirements:
- A. The flare systems shall be designed such that the combined assist natural gas and waste stream to each flare meets the 40 CFR §60.18 specifications of minimum heating value and maximum tip velocity at all times when emissions may be vented to them.

The heating value and velocity requirements shall be satisfied during operations authorized by this permit. Flare testing per 40 CFR §60.18(f) may be requested by the appropriate regional office to demonstrate compliance with these requirements.
 - B. The flare shall be operated with a flame present at all times and/or have a constant pilot flame. The pilot flame shall be continuously monitored by a thermocouple, infrared monitor, or ultraviolet monitor. The time, date, and duration of any loss of pilot flame shall be recorded. Each monitoring device shall be accurate to, and shall be calibrated at a frequency in accordance with, the manufacturer's specifications.
 - C. The flare shall be operated with no visible emissions except periods not to exceed a total of five minutes during any two consecutive hours.

Vapor Combustor (EPN MEC7)

33. A permissive interlock system must be operational prior to loading that prevents loading to begin until the MEC vapor combustor reaches the operating temperature required by Special Condition No. 33. If the operating temperature drops below the required minimum temperature, an alarm shall immediately alert the operator and immediate adjustments will be made to increase the temperature and stabilize the unit within 20 minutes. If the proper operating temperature cannot be achieved within 30 minutes shutdown of loading operations shall begin immediately and shall not restart until operating temperature is restored. The entire process must be within the hourly emission limits and at no time should the hourly emission rate be exceeded.
34. The MEC vapor combustor (FIN 57-VC2D7) shall be designed and operated in accordance with the following requirements:
- A. The MEC vapor combustor unit (VCU) shall achieve a 99.89 percent capture and collection capacity for UDEX Feed, a 98 percent control of the waste loading emissions from the loading of gasoline, alkylate, C5/PLAT, and reformate and shall be operated with no visible emissions. This shall be ensured by maintaining the temperature in, or immediately downstream of, the combustion chamber above 1500°F, when waste gases are being sent to the vapor combustor, prior to the initial stack test performed in accordance with Special Condition No. 53. Following the completion of that stack test, the six-minute average temperature shall be maintained above the minimum one-hour average temperature maintained during the last satisfactory stack test.
 - B. The temperature measurement device shall reduce the temperature readings to an averaging period of six minutes or less and record it at that frequency. The temperature monitor shall be installed, calibrated at least annually, and maintained according to the

manufacturer's specifications. The device shall have an accuracy of the greater of 2 percent of the temperature being measured expressed in degrees Celsius (°C) or 2.5°C.

- C. Quality-assured (or valid) data must be generated when the vapor combustion unit (VCU) is operating except during the performance of a daily zero and span check. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted provided it does not exceed 5 percent of the time (in minutes) that the VCU operated over the previous rolling 12-month period. The measurements missed shall be estimated using engineering judgment and the methods used recorded.
35. Pilot and assist gas combusted at this facility shall be pipeline quality natural gas containing no more than 5 grains of total sulfur per 100 dscf.

Railcar Loading

36. Molten sulfur shall be delivered to the loading rack via an enclosed piping system.
37. Venting or draining of the KO Pot Vessels shall not occur simultaneously with truck or railcar loading.

Marine Loading

38. Before loading a marine vessel with a VOC which has a vapor pressure equal to or greater than 0.5 pound per square inch absolute (psia) under actual storage conditions, the owner or operator of the marine terminal shall verify that the marine vessel has passed an annual vapor-tightness test as specified in 40 CFR 63.565(c) (September 19, 1995) or 40 CFR 61.304(f) (October 17, 2000).
39. All Dock 7 loading shall be submerged and limited to the loading of gasoline, alkylate, UDEX Feed, C5/PLAT, reformat and petroleum products having an initial boiling point of 300°F or greater.
40. Dock 7 loading emissions from loading of gasoline, alkylate, C5/PLAT, UDEX Feed, and reformat shall be vented to the MEC vapor combustor (FIN 57-VC2D7).

Fugitives

Piping, Valves, Connectors, Pumps, Agitators and Compressors, in VOC Service - Intensive Directed Maintenance - 28MID

41. Except as may be provided for in the Special Conditions of this permit, the following requirements apply to EPNs F211, F355, F221, and F821:
- A. The requirements of paragraphs F and G shall not apply (1) for components not in benzene service or (2) where the VOC has an aggregate partial pressure or vapor pressure of less than 0.044 psia at 68°F or (3) operating pressure is at least 5 kilopascals (0.725 psi) below ambient pressure. Equipment excluded from this condition shall be identified in a list or by one of the methods described below to be made available upon request.

The exempted components may be identified by one or more of the following methods:

- piping and instrumentation diagram (PID);
 - a written or electronic database or electronic file;
 - color coding;
 - a form of weatherproof identification; or
 - designation of exempted process unit boundaries.
- B. Construction of new and reworked piping, valves, pump systems, agitators, and compressor systems shall conform to applicable American National Standards Institute (ANSI), API, American Society of Mechanical Engineers (ASME), or equivalent codes.
- C. New and reworked underground process pipelines shall contain no buried valves such that fugitive emission monitoring is rendered impractical. New and reworked buried connectors shall be welded.
- D. To the extent that good engineering practice will permit, new and reworked valves and piping connections shall be so located to be reasonably accessible for leak checking during plant operation. Difficult-to-monitor and unsafe-to-monitor valves, as defined by 30 TAC Chapter 115, shall be identified in a list to be made available upon request. The difficult-to-monitor and unsafe-to-monitor valves may be identified by one or more of the methods described in subparagraph A above.
- E. New and reworked piping connections shall be welded or flanged. Screwed connections are permissible only on piping smaller than two-inch diameter. Gas or hydraulic testing of the new and reworked piping connections at no less than operating pressure shall be performed prior to returning the components to service or they shall be monitored for leaks using an approved gas analyzer within 15 days of the components being returned to service. Adjustments shall be made as necessary to obtain leak-free performance. Connectors shall be inspected by visual, audible, and/or olfactory means at least weekly by operating personnel walk-through.

No later than the next scheduled quarterly monitoring after initial installation or replacement, all new or reworked connections shall be gas-tested or hydraulically- tested at no less than normal operating pressure and adjustments made as necessary to obtain leak-free performance. Connectors shall be inspected by visual, audible, and/or olfactory means at least weekly by operating personnel walk-through.

Each open-ended valve or line shall be equipped with an appropriately sized cap, blind flange, plug, or a second valve to seal the line. Except during sampling, both valves shall be closed. If the isolation of equipment for hot work or the removal of a component for repair or replacement results in an open-ended line or valve, it is exempt from the requirement to install a cap, blind flange, plug, or second valve for 72 hours. If the repair or replacement is not completed within 72 hours, the permit holder must complete either of the following actions within that time period;

- (1) a cap, blind flange, plug, or second valve must be installed on the line or valve;
or
- (2) the open-ended valve or line shall be monitored once for leaks above background for a plant or unit turnaround lasting up to 45 days with an approved gas analyzer and the results recorded. For all other situations, the open-ended valve or line shall be monitored once by the end of the 72 hours period following the creation of the open-ended line and monthly thereafter with an approved gas analyzer and the results recorded. For turnarounds and all other situations, leaks are indicated by readings of 500 ppmv and must be repaired within 24 hours or a cap, blind flange, plug, or second valve must be installed on the line or valve.

- F. Accessible valves shall be monitored by leak checking for fugitive emissions at least quarterly using an approved gas analyzer with a directed maintenance program. Sealless/leakless valves (including, but not limited to, welded bonnet bellows and diaphragm valves) and relief valves equipped with a rupture disc upstream or venting to a control device are not required to be monitored. For valves equipped with rupture discs, a pressure-sensing device shall be installed between the relief valve and rupture disc to monitor disc integrity. All leaking discs shall be replaced at the earliest opportunity but no later than the next process shutdown.

A check of the reading of the pressure-sensing device to verify disc integrity shall be performed at least quarterly and recorded in the unit log or equivalent. Pressure-sensing devices that are continuously monitored with alarms are exempt from recordkeeping requirements specified in this paragraph.

An approved gas analyzer shall conform to requirements listed in Method 21 of 40 CFR part 60, appendix A. The gas analyzer shall be calibrated with methane. In addition, the response factor of the instrument for a specific VOC of interest shall be determined and meet the requirements of Section 8 of Method 21. If a mixture of VOCs is being monitored, the response factor shall be calculated for the average composition of the process fluid. A calculated average is not required when all of the compounds in the mixture have a response factor less than 10 using methane. If a response factor less than 10 cannot be achieved using methane, then the instrument may be calibrated with one of the VOC to be measured or any other VOC so long as the instrument has a response factor of less than 10 for each of the VOC to be measured.

A directed maintenance program shall consist of the repair and maintenance of components assisted simultaneously by the use of an approved gas analyzer such that a minimum concentration of leaking VOC is obtained for each component being maintained. A first attempt to repair the leak must be made within 5 days. Records of the first attempt to repair shall be maintained. Replaced components shall be re-monitored within 15 days of being placed back into VOC service.

- G. All new and replacement pumps, compressors, and agitators shall be equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal. These seal systems need not be monitored and may include (but are not limited to) dual pump seals with barrier fluid at higher pressure than process pressure, seals degassing to vent control systems kept in good working order, or seals equipped with an automatic seal failure detection and alarm system. Submerged pumps or sealless pumps (including, but

not limited to, diaphragm, canned, or magnetic-driven pumps) may be used to satisfy the requirements of this condition and need not be monitored.

All other pump, compressor, and agitator seals shall be monitored with an approved gas analyzer at least quarterly.

- H. Damaged or leaking valves, connectors, compressor seals, pump seals, and agitator seals found to be emitting VOC in excess of 500 ppmv or found by visual inspection to be leaking (e.g., dripping process fluids) shall be tagged and replaced or repaired. A leaking component shall be repaired as soon as practicable, but no later than 15 days after the leak is found. If the repair of a component would require a unit shutdown that would create more emissions than the repair would eliminate, the repair may be delayed until the next scheduled shutdown. All leaking components which cannot be repaired until a scheduled shutdown shall be identified for such repair by tagging. A listing of all components that qualify for delay of repair shall be maintained on a delay of repair list. The cumulative daily emissions from all components on the delay of repair list shall be estimated by multiplying by 24 the mass emission rate for each component calculated in accordance with the instructions in 30 TAC 115.782 (c)(1)(B)(i)(II). The calculations of the cumulative daily emissions from all components on the delay of repair list shall be updated within ten days of when the latest leaking component is added to the delay of repair list. When the cumulative daily emission rate of all components on the delay of repair list times the number of days until the next scheduled unit shutdown is equal to or exceeds the total emissions from a unit shutdown as calculated in accordance with 30 TAC 115.782 (c)(1)(B)(i)(I), the TCEQ Regional Manager and any local programs shall be notified and may require early unit shutdown or other appropriate action based on the number and severity of tagged leaks awaiting shutdown. This notification shall be made within 15 days of making this determination.
- I. If the repair of a component would require a unit shutdown, the repair may be delayed until the next scheduled shutdown. All leaking components which cannot be repaired until a scheduled shutdown shall be identified for such repair by tagging. At the discretion of the TCEQ Executive Director or designated representative, early unit shutdown or other appropriate action may be required based on the number and severity of tagged leaks awaiting shutdown.
- J. In lieu of the monitoring frequency specified in paragraph F, valves in gas and light liquid service may be monitored on a semiannual basis if the percent of valves leaking for two consecutive quarterly monitoring periods is less than 0.5 percent.
- K. Valves in gas and light liquid service may be monitored on an annual basis if the percent of valves leaking for two consecutive semiannual monitoring periods is less than 0.5 percent.
- L. If the percent of valves leaking for any semiannual or annual monitoring period is 0.5 percent or greater, the facility shall revert to quarterly monitoring until the facility again qualifies for the alternative monitoring schedules previously outlined in this paragraph.
- M. The percent of valves leaking used in paragraph I shall be determined using the following formula:

$$(V_I + V_S) \times 100 / V_T = V_P$$

Where:

V_I = the number of valves found leaking by the end of the monitoring period, either by Method 21 or sight, sound, and smell.

V_S = the number of valves for which repair has been delayed and are listed on the facility shutdown log.

V_T = the total number of valves in the facility subject to the monitoring requirements, as of the last day of the monitoring period, not including non-accessible and unsafe-to-monitor valves.

V_P = the percentage of leaking valves for the monitoring period.

- N. Records of repairs shall include date of repairs, repair results, justification for delay of repairs, and corrective actions taken for all components. Records of instrument monitoring shall indicate dates and times, test methods, and instrument readings. The instrument monitoring record shall include the time that monitoring took place for no less than 95% of the instrument readings recorded. Records of physical inspections shall be noted in the operator's log or equivalent.
42. Compliance with the requirements of this condition does not assure compliance with requirements of 30 TAC Chapter 115, an applicable New Source Performance Standard, or an applicable NESHAPS and does not constitute approval of alternative standards for these regulations.
43. A list of non-accessible valves as defined or required by the EPA shall fulfill the requirements of Special Condition No. 41.D.

Process Piping, Valves, Connectors, Flanges, Pumps, and Compressors in VOC Service – 28M

44. Except as may be provided for in the special conditions of this permit, the following requirements apply to EPNs F290 (except preheat train and pump suction areas), F411, F3720, F3200, F4600, F271, and F061: **(07/21)**
- A. These conditions shall not apply (1) where the VOC has an aggregate partial pressure or vapor pressure of less than 0.5 psia at 100°F or at maximum process operating temperature if less than 100°F or (2) to piping and valves two inches nominal size and smaller or (3) where the operating pressure is at least 5 kilopascals (0.725 psi) below ambient pressure. Equipment excluded from this condition shall be identified in a list to be made available upon request.
- B. Construction of new and reworked piping, valves, pump systems, and compressor systems shall conform to applicable American National Standards Institute (ANSI), American Petroleum Institute (API), American Society of Mechanical Engineers (ASME), or equivalent codes.

- C. New and reworked underground process pipelines shall contain no buried valves such that fugitive emission monitoring is rendered impractical.
- D. To the extent that good engineering practice will permit, new and reworked valves and piping connections shall be so located to be reasonably accessible for leak-checking during plant operation. Non-accessible valves, as defined in 30 TAC Chapter 115, shall be identified in a list to be made available upon request.
- E. New and reworked piping connections shall be welded or flanged. Screwed connections are permissible only on piping smaller than two-inch diameter. No later than the next scheduled quarterly monitoring period after initial installation or replacement, all new or reworked connections shall be gas-tested or hydraulically-tested at no less than normal operating pressure and adjustments made as necessary to obtain leak-free performance. Flanges shall be inspected by visual, audible, and/or olfactory means at least weekly by operating personnel walk-through.
- F. Each open-ended valve or line shall be equipped with a cap, blind flange, plug, or a second valve. Except during sampling, the second valve shall be closed.
- G. Accessible valves shall be monitored by leak-checking for fugitive emissions at least quarterly using an approved gas analyzer. Sealless/leakless valves (including, but not limited to, welded bonnet bellows and diaphragm valves) and relief valves equipped with a rupture disc upstream or venting to a control device are not required to be monitored. For valves equipped with rupture discs, a pressure sensing device shall be installed between the relief valve and rupture disc to monitor disc integrity. All leaking discs shall be replaced at the earliest opportunity but no later than the next process shutdown.

An approved gas analyzer shall conform to requirements listed in Title 40 CFR §60.485(a) - (b).

- H. Except as may be provided for in the special conditions of this permit, all pump and compressor seals shall be monitored with an approved gas analyzer at least quarterly or be equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal. Seal systems designed and operated to prevent emissions or seals equipped with an automatic seal failure detection and alarm system need not be monitored. Seal systems that prevent emissions may include (but are not limited to) dual pump seals with barrier fluid at higher pressure than process pressure or seals degassing to vent control systems kept in good working order.

Submerged pumps or sealless pumps (including, but not limited to, diaphragm, canned, or magnetic driven pumps) may be used to satisfy the requirements of this condition and need not be monitored.

- I. Damaged or leaking valves, flanges, compressor seals, and pump seals found to be emitting VOC in excess of 10,000 ppmv or found by visual inspection to be leaking (e.g., dripping process fluids) shall be tagged and replaced or repaired. Every reasonable effort shall be made to repair a leaking component as specified in this paragraph within 15 days after the leak is found. If the repair of a component would require a unit shutdown, the repair may be delayed until the next scheduled shutdown. All leaking components which cannot be repaired until a scheduled shutdown shall be identified for

such repair by tagging. The TCEQ Executive Director, at his discretion, may require early unit shutdown or other appropriate action based on the number and severity of tagged leaks awaiting shutdown.

If the repair of a component would require a unit shutdown, the repair may be delayed until the next scheduled shutdown. All leaking components which cannot be repaired until a scheduled shutdown shall be identified for such repair by tagging. At the discretion of the TCEQ Executive Director or designated representative, early unit shutdown or other appropriate action may be required based on the number and severity of tagged leaks awaiting shutdown.

- J. The results of the required fugitive instrument monitoring and maintenance program shall be made available to the TCEQ Executive Director or designated representative upon request. Records shall indicate appropriate dates, test methods, instrument readings, repair results, justification for delay of repairs, and corrective actions taken for all components. Records of physical inspections are not required unless a leak is detected.
 - K. Fugitive emission monitoring required by an applicable 30 TAC Chapter 115, NSPS, 40 CFR Part 60, or an applicable NESHAPS, 40 CFR Part 61, may be used in lieu of Items F through I of this condition.
 - L. Compliance with the requirements of this condition does not assure compliance with requirements of NSPS or NESHAPS and does not constitute approval of alternate standards for these regulations.
 - M. A list of non-accessible valves as defined or required by the EPA shall fulfill the requirements of paragraph D of this special condition.
45. Process fugitive equipment in ammonia and hydrogen sulfide service under EPN F416 shall implement a weekly walkthrough inspection following the requirements of paragraphs E and I through K of Special Condition 44.

Process Piping, Valves, Pumps, and Compressors in VOC Service – 28VHP

46. Except as may be provided for in the special conditions of this permit, the following requirements apply to EPNs F391, F244, F361, F373, F381, F261, F290 (preheat train and pump suction areas), F311, F321, F331, F416, F492, F441, F4710, F1002, 591, F281, F890, F081, F3200, F4600, F061 and FUG-GHT: **(07/21)**
- A. The requirements of paragraphs F and G shall not apply (1) where the VOC has an aggregate partial pressure or vapor pressure of less than 0.044 pounds per square inch, absolute (psia) at 68°F or (2) operating pressure is at least 5 kilopascals (0.725 psi) below ambient pressure. Equipment excluded from this condition shall be identified in a list or by one of the methods described below to be made readily available upon request.

The exempted components may be identified by one or more of the following methods:

- piping and instrumentation diagram (PID);
- a written or electronic database or electronic file;

- color coding;
 - a form of weatherproof identification; or
 - designation of exempted process unit boundaries.
- B. Construction of new and reworked piping, valves, pump systems, and compressor systems shall conform to applicable ANSI, API, ASME, or equivalent codes.
- C. New and reworked underground process pipelines shall contain no buried valves such that fugitive emission monitoring is rendered impractical. New and reworked buried connectors shall be welded.
- D. To the extent that good engineering practice will permit, new and reworked valves and piping connections shall be so located to be reasonably accessible for leak-checking during plant operation. Difficult-to-monitor and unsafe-to-monitor valves, as defined by 30 TAC Chapter 115, shall be identified in a list to be made readily available upon request. The difficult-to-monitor and unsafe-to-monitor valves may be identified by one or more of the methods described in subparagraph A above. If an unsafe to monitor component is not considered safe to monitor within a calendar year, then it shall be monitored as soon as possible during safe to monitor times. A difficult to monitor component for which quarterly monitoring is specified may instead be monitored annually.
- E. New and reworked piping connections shall be welded or flanged. Screwed connections are permissible only on piping smaller than two-inch diameter. Gas or hydraulic testing of the new and reworked piping connections at no less than operating pressure shall be performed prior to returning the components to service or they shall be monitored for leaks using an approved gas analyzer within 15 days of the components being returned to service. Adjustments shall be made as necessary to obtain leak-free performance. Connectors shall be inspected by visual, audible, and/or olfactory means at least weekly by operating personnel walk-through.

Each open-ended valve or line shall be equipped with an appropriately sized cap, blind flange, plug, or a second valve to seal the line. Except during sampling, both valves shall be closed. If the isolation of equipment for hot work or the removal of a component for repair or replacement results in an open-ended line or valve, it is exempt from the requirement to install a cap, blind flange, plug, or second valve for 72 hours. If the repair or replacement is not completed within 72 hours, the permit holder must complete either of the following actions within that time period;

- (1) a cap, blind flange, plug, or second valve must be installed on the line or valve;
or
- (2) the open-ended valve or line shall be monitored once for leaks above background for a plant or unit turnaround lasting up to 45 days with an approved gas analyzer and the results recorded. For all other situations, the open-ended valve or line shall be monitored once within the 72-hour period following the creation of the open-ended line and monthly thereafter with an approved gas analyzer and the results recorded. For turnarounds and all other situations, leaks

are indicated by readings of 500 ppmv and must be repaired within 24 hours or a cap, blind flange, plug, or second valve must be installed on the line or valve.

- F. Accessible valves shall be monitored by leak checking for fugitive emissions at least quarterly using an approved gas analyzer. Sealless/leakless valves (including, but not limited to, welded bonnet bellows and diaphragm valves) and relief valves equipped with a rupture disc upstream or venting to a control device are not required to be monitored. If a relief valve is equipped with rupture disc, a pressure-sensing device shall be installed between the relief valve and rupture disc to monitor disc integrity.

A check of the reading of the pressure-sensing device to verify disc integrity shall be performed at least quarterly and recorded in the unit log or equivalent. Pressure-sensing devices that are continuously monitored with alarms are exempt from recordkeeping requirements specified in this paragraph. All leaking discs shall be replaced at the earliest opportunity but no later than the next process shutdown.

An approved gas analyzer shall conform to requirements listed in 40 CFR §60.485(a)-(b).

The gas analyzer shall conform to requirements listed in Method 21 of 40 CFR part 60, appendix A. The gas analyzer shall be calibrated with methane. In addition, the response factor of the instrument for a specific VOC of interest shall be determined and meet the requirements of Section 8 of Method 21. If a mixture of VOCs is being monitored, the response factor shall be calculated for the average composition of the process fluid. A calculated average is not required when all of the compounds in the mixture have a response factor less than 10 using methane. If a response factor less than 10 cannot be achieved using methane, then the instrument may be calibrated with one of the VOC to be measured or any other VOC so long as the instrument has a response factor of less than 10 for each of the VOC to be measured.

Replacements for leaking components shall be re-monitored within 15 days of being placed back into VOC service.

- G. Except as may be provided for in the special conditions of this permit, all pump, compressor, and agitator seals shall be monitored with an approved gas analyzer at least quarterly or be equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal. Seal systems designed and operated to prevent emissions or seals equipped with an automatic seal failure detection and alarm system need not be monitored. These seal systems may include (but are not limited to) dual pump seals with barrier fluid at higher pressure than process pressure, seals degassing to vent control systems kept in good working order, or seals equipped with an automatic seal failure detection and alarm system. Submerged pumps or sealless pumps (including, but not limited to, diaphragm, canned, or magnetic-driven pumps) may be used to satisfy the requirements of this condition and need not be monitored.
- H. Damaged or leaking valves or connectors found to be emitting VOC in excess of 500 ppmv or found by visual inspection to be leaking (e.g., dripping process fluids) shall be tagged and replaced or repaired. Damaged or leaking pump, compressor, and agitator seals found to be emitting VOC in excess of 2,000 ppmv or found by visual inspection to be leaking (e.g., dripping process fluids) shall be tagged and replaced or repaired. A first

attempt to repair the leak must be made within 5 days and a record of the attempt shall be maintained.

- I. Every reasonable effort shall be made to repair a leaking component, as specified in this paragraph, within 15 days after the leak is found. If the repair of a component would require a unit shutdown that would create more emissions than the repair would eliminate, the repair may be delayed until the next scheduled shutdown. All leaking components which cannot be repaired until a scheduled shutdown shall be identified for such repair by tagging within 15 days of the detection of the leak. A listing of all components that qualify for delay of repair shall be maintained on a delay of repair list. The cumulative daily emissions from all components on the delay of repair list shall be estimated by multiplying by 24 the mass emission rate for each component calculated in accordance with the instructions in 30 TAC 115.782 (c)(1)(B)(i)(II). The calculations of the cumulative daily emissions from all components on the delay of repair list shall be updated within ten days of when the latest leaking component is added to the delay of repair list. When the cumulative daily emission rate of all components on the delay of repair list times the number of days until the next scheduled unit shutdown is equal to or exceeds the total emissions from a unit shutdown as calculated in accordance with 30 TAC 115.782 (c)(1)(B)(I)(I), the TCEQ Regional Manager and any local programs shall be notified and may require early unit shutdown or other appropriate action based on the number and severity of tagged leaks awaiting shutdown. This notification shall be made within 15 days of making this determination.
 - J. The results of the required fugitive instrument monitoring and maintenance program shall be made available to the TCEQ Executive Director or his designated representative upon request. Records shall indicate appropriate dates, test methods, instrument readings, repair results, justification for delay of repairs, and corrective actions taken for all components. Records of physical inspections are not required unless a leak is detected.
 - K. Records of repairs shall include date of repairs, repair results, justification for delay of repairs, and corrective actions taken for all components. Records of instrument monitoring shall indicate dates and times, test methods, and instrument readings. The instrument monitoring record shall include the time that monitoring took place for no less than 95% of the instrument readings recorded. Records of physical inspections shall be noted in the operator's log or equivalent.
 - L. Alternative monitoring frequency schedules of 30 TAC §115.352-115.359 or National Emission Standards for Organic Hazardous Air Pollutants, 40 CFR Part 63, Subpart H, may be used in lieu of items F through G of this condition.
 - M. Compliance with the requirements of this condition does not assure compliance with requirements of 30 TAC Chapter 115, an applicable NSPS, or an applicable NESHAPS and does not constitute approval of alternative standards for these regulations.
47. A list of non-accessible valves as defined or required by the EPA shall fulfill the requirements of Special Condition No.46.D.

Process Piping, Valves, Pumps, and Compressors in H₂S or Ammonia (NH₃) – 28AVO

48. Except as may be provided for in the special conditions of this permit, the following requirements apply to EPN F373:

- A. Audio, olfactory, and visual checks for leaks within the operating area shall be made every four hours.
- B. Immediately, but no later than one hour upon detection of a leak, plant personnel shall take at least one of the following actions:
 - (1) Isolate the leak.
 - (2) Commence repair or replacement of the leaking component.
 - (3) Use a leak collection/containment system to prevent the leak until repair or replacement can be made if immediate repair is not possible.

Date and time of each inspection shall be noted in the operator's log or equivalent. Records shall be maintained at the plant site of all repairs and replacements made due to leaks. These records shall be made available to representatives of the TCEQ upon request.

Connector Monitoring with an Instrument Annually - 28CNTA

49. In addition to the weekly physical inspection, for EPNs F221, F4600, and F821 [subject to Hazardous Organic NESHAP (HON)], required by Item E of Special Condition No. 411, any connectors in gas/vapor and light liquid service shall be monitored annually with an approved gas analyzer in accordance with items F thru J of Special Condition No. 411. Alternative monitoring frequency schedules ("skip options") of Title 40 CFR Part 63, Subpart H, National Emission Standards for Organic Hazardous Air Pollutants for Equipment Leaks, may be used in lieu of the monitoring frequency required by this permit condition. Compliance with this condition does not assure compliance with requirements of applicable state or federal regulation and does not constitute approval of alternative standards for these regulations.

Piping, Valves, Pumps, and Compressors in Heavy Oil Service (EPN F311)

50. For the purposes of demonstrating compliance with Special Condition No. 15, the vapor pressure of heavy oils shall be estimated using the distillation values of Unibon feed or No. 2 FCCU feed, the API Technical Data Book, 9/77 version, Figures 5A1.14b and 5A1.14c, and the procedure outlined in the letter dated August 21, 2000 in the permit file.

Piping, Valves, Pumps, and Compressors in Hydrogen Fluoride (HF) Service (EPN F261)

51. Visual inspection for piping, valves, pumps, and compressors in HF service:
- A. There shall be no visible emissions of HF from the fugitive components in HF service, as represented in the facility's renewal application. To ensure compliance with this condition, plant personnel shall take the following actions:

- (1) Paint each component in HF service with a HF reactive paint that changes color upon exposure to HF.
 - (2) Perform visual checks for HF leaks within the operating area once per shift. Visual checks will include looking for changes in the HF reactive paint.
 - (3) Use video surveillance cameras located within the HF operating area to check for leaks.
 - B. Immediately, but no later than one hour upon detection of a leak, plant personnel shall initiate the following actions:
 - (1) Isolate the leak.
 - (2) Commence repair or replacement of the leaking component.
 - (3) Use a leak collection/containment system to prevent the leak until repair or replacement can be made if immediate repair is not possible.
52. Date and time of each inspection shall be noted in the operator's log or equivalent. Records shall be maintained at the plant site of all repairs and replacements made due to leaks. These records shall be made available to representatives of the TCEQ upon request.

Initial Determination of Compliance

53. The permit holder shall perform stack sampling and other testing as required to establish the actual pattern and quantities of air contaminants being emitted into the atmosphere from the EPNs listed in the table below to demonstrate compliance with the MAERT. The permit holder is responsible for providing sampling and testing facilities and conducting the sampling and testing operations at his expense. Sampling shall be conducted in accordance with the appropriate procedures of the Texas Commission on Environmental Quality (TCEQ) Sampling Procedures Manual and the U.S. Environmental Protection Agency (EPA) Reference Methods.

EPN	Description	Air Contaminants to be Tested For
292	Crude Heater 11-H-1 and Vacuum Heater 11-H-2 (when firing refinery gas)	NOx, CO, VOC
312	Unibon Heater 21-H-1A	NOx, CO
313	Unibon Heater 21-H-1B	NOx, CO
362	Heater 41-H1 and 41-H2	NOx, CO
412, 412A	SCOT Incinerator Stack	SO ₂
356	Process Heater 14-H-1	NOx, CO
6100	Utility Boiler E	NOx, CO, SO ₂ , O ₂ , opacity
MEC	MEC Vapor Combustor 57-VC2D7	VOC, benzene
82, 83, 84	Platformer Reactor Heaters	NOx, CO
087	Catalyst Regenerator Vent	PM, CO, HCl, Cl ₂
207-H-1	Charge Heater	NOx, CO

Requests to waive testing for any pollutant specified in this condition shall be submitted to the TCEQ Office of Air, Air Permits Division in Austin. Test waivers and alternate/equivalent procedure proposals for Title 40 Code of Federal Regulation Part 60 (40 CFR Part 60) testing which must have EPA approval shall be submitted to the TCEQ Regional Director.

A. The appropriate TCEQ Regional Office (TCEQ Corpus Christi Regional Office) shall be notified not less than 45 days prior to sampling. The notice shall include:

- (1) Proposed date for pretest meeting.
- (2) Date sampling will occur.
- (3) Name of firm conducting sampling.
- (4) Type of sampling equipment to be used.
- (5) Method or procedure to be used in sampling.
- (6) Description of any proposed deviation from the sampling procedures specified in this permit or TCEQ/EPA sampling procedures.
- (7) Procedure/parameters to be used to determine worst case emissions at maximum firing rate and normal operations load during the sampling period.

The purpose of the pretest meeting is to review the necessary sampling and testing procedures, to provide the proper data forms for recording pertinent data, and to review the format procedures for submitting the test reports. A written proposed description of any deviation from sampling procedures specified in permit conditions, TCEQ, or EPA sampling procedures shall be made available to the TCEQ prior to the pretest meeting. The TCEQ Regional Director must approve any deviation from specified sampling procedures.

- B. Air contaminants emitted from the sources listed in the table above to be tested for include VOC, NO_x, CO, SO₂, O₂, PM, HCl, Cl₂, opacity, and benzene. The above table specifies the pollutants to be tested for each facility.
- C. Sampling shall occur within 60 days after achieving the maximum operating rate, but no later than 180 days after initial start-up of the facilities and at such other times as may be required by the Executive Director of the TCEQ. Requests for additional time to perform sampling shall be submitted to the TCEQ Regional Office. Additional time to comply with the applicable requirements of 40 CFR 60 and 40 CFR 61 requires EPA approval, and requests shall be submitted to the TCEQ Regional Director.
- D. The plant shall operate at maximum production rates during stack emission testing. Primary operating parameters that enable determination of production rate shall be monitored and recorded during the stack test. These parameters are to be determined at the pretest meeting. If the plant is unable to operate at maximum rates during testing, then future production rates may be limited to the rates established during testing. Additional stack testing, for the Platformer Reactor Heaters (EPNs 82, 83, and 84), may be required if the firing rate exceeds the tested firing rate by more than 10 percent. Permit conditions and parameter limits may be waived during stack testing performed under this condition if the proposed condition/parameter range is identified in the test notice specified in paragraph A and accepted by the TCEQ Regional Office. Permit allowable emissions and emission control requirements are not waived and still apply during stack testing periods.

During subsequent operations for the Absorber Reboiler Heater 41-H1, Debutanizer Reboiler Heater 41-H2, Process Heater 14-H-1, and GHT Charge Heater (EPNs 362, 356, and 207-H-1), if the hourly firing rate is greater than that recorded during the test period, stack sampling shall be performed at the new operating conditions within 120 days. This sampling may be waived by the TCEQ Air Section Director for the region.

- E. Copies of the final sampling report shall be forwarded to the offices below within 60 days after sampling is completed. Sampling reports shall comply with the attached provisions entitled "Chapter 14, Contents of Sampling Reports" of the TCEQ Sampling Procedures Manual. The reports shall be distributed as follows:

One copy to the TCEQ Corpus Christi Regional Office.

- F. Sampling ports and platform(s) shall be incorporated into the design of Heaters 41-H1, 41-H2, Utility Boiler E, and the MEC vapor combustor according to the specifications set forth in the attachment entitled "Chapter 2, Stack Sampling Facilities" of the TCEQ Sampling Procedures Manual. Alternate sampling facility designs must be submitted for approval to the TCEQ Regional Director.
- G. If the normal production rate of sulfur from the SCOT Incinerator Stacks exceeds by more than 10 percent, the production rate in long tons per day maintained during sampling, the company must notify in writing, the Executive Director of the TCEQ and the source may be subject to additional sampling to demonstrate continued compliance with all applicable state and federal regulations.
- H. The plant shall operate at the scenario producing maximum waste vapors using the MEC during stack emission testing. Primary operating parameters that enable determination of loading rate shall be monitored and recorded during the stack test and the data shall be included in the sampling report. These parameters shall include but are not limited to those discussed prior to or during testing. Additional stack testing may be required.
- I. The holder of this permit shall conduct the performance test, as required under 40 CFR § 60.8, using the NOx Continuous Emission Monitoring Systems (CEMS). Emissions of NOx shall be monitored to demonstrate compliance with the NOx limits of Special Condition No. 0.
- J. If the sample results from the Platformer Reactor Heaters (EPNs 82, 83, and 84) show that the NOx emission rate is less than 0.045 lb/MMBtu, the permit holder shall submit a permit alteration request to the TCEQ Office of Air, Air Permits Division to lower the allowable emission rate for the heaters. The request shall be made within 180 days of sampling the heaters.
- K. If the sample results from the catalyst regenerator (EPN 87) show that the CO emission rate is less than 50 percent of the allowable emission rate, the permit holder shall submit a permit alteration request to the TCEQ Office of Air, Air Permits Division to lower the allowable emission rate. The request shall be made within 180 days of sampling the catalyst regenerator heater.

Continuous Demonstration of Compliance

54. Upon request by the TCEQ Executive Director or the TCEQ Regional Director having jurisdiction, the holder of this permit shall perform stack sampling and/or other testing as required to establish the actual pattern and quantities of air contaminants being emitted into the atmosphere to demonstrate compliance with the MAERT and with emission performance levels as specified in the

special conditions and/or otherwise prove satisfactory equipment performance. Sampling must be conducted in accordance with the TCEQ Guidelines for Stack Sampling Facilities and in accordance with the applicable EPA 40 CFR procedures. Any deviations from those procedures must be approved by the TCEQ Executive Director or the appropriate TCEQ Regional Director prior to conducting sampling.

Heaters

55. The fuel gas shall be sampled to determine the hydrogen sulfide and net heating value. The hourly average results shall be maintained in the plant information system for two (2) years. The test results from the fuel supplier may be used to satisfy this requirement.
56. The permit holder shall install, calibrate, and maintain a CEMS to measure and record the in-stack concentration of NO_x from Platformer Reactor Heaters (EPNs 82, 83, and 84).
 - A. The CEMS shall meet the design and performance specifications, pass the field tests, and meet the installation requirements and the data analysis and reporting requirements specified in the applicable Performance Specification Nos. 1 through 9, Title 40 CFR Part 60 (40 CFR Part 60), Appendix B. If there are no applicable performance specifications in 40 CFR Part 60, Appendix B, contact the TCEQ Office of Air, Air Permits Division for requirements to be met.
 - B. Section 1 below applies to sources subject to the quality-assurance requirements of 40 CFR Part 60, Appendix F; section 2 applies to all other sources:
 - (1) The permit holder shall assure that the CEMS meets the applicable quality-assurance requirements specified in 40 CFR Part 60, Appendix F, Procedure 1. Relative accuracy exceedances, as specified in 40 CFR Part 60, Appendix F, Section 5.2.3 and any CEMS downtime shall be reported to the appropriate TCEQ Regional Manager, and necessary corrective action shall be taken. Supplemental stack concentration measurements may be required at the discretion of the appropriate TCEQ Regional Manager.
 - (2) The system shall be zeroed and spanned daily, and corrective action taken when the 24-hour span drift exceeds two times the amounts specified in the applicable Performance Specification Nos. 1 through 9, 40 CFR Part 60, Appendix B, or as specified by the TCEQ if not specified in Appendix B. Zero and span is not required on weekends and plant holidays if instrument technicians are not normally scheduled on those days.

Each monitor shall be quality-assured at least quarterly using Cylinder Gas Audits (CGA) in accordance with 40 CFR Part 60, Appendix F, Procedure 1, Section 5.1.2, with the following exception: a relative accuracy test audit (RATA) is not required once every four quarters (i.e., four successive quarterly CGA may be conducted). An equivalent quality-assurance method approved by the TCEQ may also be used. Successive quarterly audits shall occur no closer than two months.

All CGA exceedances of +15 percent accuracy indicate that the CEMS is out of control.
 - C. The monitoring data shall be reduced to hourly average concentrations at least once every day, using a minimum of four equally-spaced data points from each one-hour period. The individual average concentrations shall be reduced to units of lbs/hr at least once every week as follows:

The measured hourly average concentration from the CEMS shall be multiplied by the heater duty to determine the hourly emission rate.

- D. All monitoring data and quality-assurance data shall be maintained by the source. The data from the CEMS may, at the discretion of the TCEQ, be used to determine compliance with the conditions of this permit.
 - E. The appropriate TCEQ Regional Office shall be notified at least 30 days prior to any required RATA in order to provide them the opportunity to observe the testing.
 - F. Quality-assured (or valid) data must be generated when the Platformer Reactor Heaters (EPNs 82, 83, and 84) are operating except during the performance of a daily zero and span check. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration shall be estimated using engineering judgment and the methods used recorded. Options to increase system reliability to an acceptable value, including a redundant CEMS, may be required by the TCEQ Regional Manager for loss of valid data exceeding 5 percent of the time in minutes that the Platformer Reactor Heaters (EPNs 82, 83, and 84) operated over the previous rolling 12-month period.
57. Quality assured (or valid) data must be generated, for Process Heater 14-H-1 (EPN 356), when the heater is operating. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted provided it does not exceed 5 percent of the time (in minutes) that the heater operated over the previous rolling 12-month period. The measurements missed shall be estimated using engineering judgment and the methods used recorded.
58. The holder of this permit shall comply with the H₂S monitoring requirements of 40 CFR §60.105(a)(4) for heaters if 40 CFR §60.105(a)(3) monitoring for sulfur dioxide (SO₂) is not utilized.
59. The holder of this permit shall install and maintain a continuous H₂S monitoring system in a location in the fuel gas system for the Absorber Reboiler Heater 41-H11 and Debutanizer Reboiler Heater 41-H2 (Common stack identified as EPN 362) in accordance with the fuel sulfur monitoring requirements of 40 CFR §60.107a.

Fuel Flow Monitoring

60. The permit holder shall install and operate a totalizing fuel flow meter to measure the gas fuel usage for the Crude Heater 11-H-1, Vacuum Heater 11-H-2, Heater 19-H-1, Heater 19-H-2, and Process Heater 14-H-1 (EPNs 292, 222, 223, and 356) and fuel usage for each shall be recorded monthly. Each monitoring device shall be calibrated at a frequency in accordance with the manufacturer's specifications and shall be accurate to within 5 percent.

Boiler (EPN: 6100)

61. In order to demonstrate continuous compliance with the NO_x limit of Special Condition No. 0 and the MAERT for Utility Boiler E, the holder of this permit shall comply with the monitoring provisions of 40 CFR §60.48b.

The CEMS used to measure and record the in-stack concentration of NO_x and Oxygen (O₂) from Utility Boiler E (EPN 6100) shall be installed, calibrated, and maintained in accordance with the

requirements of 40 CFR §§60.13 and 60.48b. In addition, the holder of this permit shall comply with the following:

- A. The CEMS shall meet the design and performance specifications, pass the field tests, and meet the installation requirements and data analysis and reporting requirements specified in the applicable Performance Specifications in 40 CFR Part 60, Appendix B.

The performance specification tests shall be conducted prior to or during the sampling required by Special Condition No. 533, and written copies of the results shall be submitted within 60 days of completion of the tests to the TCEQ Corpus Christi Regional Office and the TCEQ Air Permits Division in Austin.
- B. The system shall be zeroed and spanned daily and corrective action taken when the 24-hour span drift exceeds two times the amounts specified in 40 CFR Part 60, Appendix B. Each gaseous monitor shall be quality-assured at least quarterly using cylinder gas audits (CGAs). The CGA method to be used is contained in 40 CFR Part 60, Appendix F, Procedure 1.
- C. The gaseous monitoring data shall be reduced to hourly average concentrations at least once every day, using a minimum of four equally-spaced data points from each one-hour period. At least 23 hourly averages shall be generated per day.
- D. All CGA exceedances greater than ± 15 percent accuracy and any unscheduled CEMS downtime shall be reported to the TCEQ Corpus Christi Regional Office within 24-hours of detection, and necessary corrective action shall be taken. Supplemental stack concentration measurements may be required at the discretion of the TCEQ Regional Director.
- E. The CEMS shall demonstrate a system reliability of at least 90 percent based on an annual rolling period (downtime does not include daily zero and span measurement time or unit downtime), or options to increase system reliability to an acceptable value, including a redundant CEMS, may be required by the TCEQ Corpus Christi Regional Director.
- F. Compliance with the SO₂ limit of this permit on a continuous basis shall be demonstrated by monitoring the H₂S in the refinery fuel fired in the boiler with a CEMS to ensure that H₂S limits of Special Condition No. 133 are not exceeded. The permit holder or the operator of the facility covered by this permit shall also provide documents to show that the natural gas fired in the boiler does not contain H₂S in excess of the limits imposed by Special Condition No. 133.

Visible Emissions

- 62. The opacity from any heater or Utility Boiler E, EPN 6100, shall not exceed 5 percent averaged over a six-minute period, except for those periods described in Title 30 TAC §111.111(a)(1)(E).

SRU (EPN: 412 and 412A)

- 63. The holder of this permit shall install, calibrate, maintain and operate a CEMS to monitor and record emissions of SO₂ from each SCOT Incinerator Stack, EPN 412 and 412A. Each CEMS shall meet the performance specifications, pass the field tests, meet the installation requirements and the data analysis and reporting requirements specified in Performance Specifications Nos. 1, 2 and 3, 40 CFR Part 60, Appendix B. Each monitor shall be zeroed and spanned daily and corrective action taken when the instrument drift exceeds the amount specified in 40 CFR Part 60, Appendix B. The monitoring data shall be collected and analyzed every day, shall be reduced to units of the permit allowable emission rate every day, shall be maintained by the source for a period of two years and shall be made available to the TCEQ Executive Director or his designated representative upon

request. The data from the CEMS may be used to determine compliance with the conditions of this permit. The CEMS required by this permit shall be subject to all future quality assurance requirements as they are published in the TCEQ Sampling Procedures Manual.

Compliance Assurance Monitoring (CAM)

64. The following requirements apply to capture systems for the MEC vapor combustor (FIN 57-VC2D7):
- A. Once a year, verify the capture system is leak-free by inspecting in accordance with 40 CFR Part 60, Appendix A, Test Method 21. Leaks shall be indicated by an instrument reading greater than or equal to 500 ppmv above background.
 - B. The control device shall not have a bypass.
 - C. If any of the above inspections is not satisfactory, a deviation shall be reported if the monitoring or inspections indicate bypass of the control device and the permit holder shall promptly take necessary corrective action.

Maintenance, Startup, and Shutdown

65. Maintenance, startup, and shutdown emissions are authorized in Permit No. 80801.

Recordkeeping Requirements

66. Records shall be kept on a daily average for the daily throughput and a 12-month rolling average for the annual throughput for Tanks 2002, 2003, 2005, 2006 (EPNs 733, 734, 736, and 737). Records shall be updated monthly.
67. Records of daily output production rates of kerosene/jet fuel shall be kept on-site and maintained for a minimum of five years. Production records shall be made available to the Executive Director or his representative upon request.
68. The holder of this permit shall keep records of daily (24-hour) cyclohexane production in BPD. The company shall also keep a 365 day yearly cumulative production total, starting on January first of each calendar year.
69. The holder of this permit shall maintain records of actual feed rates to the C4 Selective Hydrogenation Process Unit.
70. Monthly production records shall be maintained, for the C5 MEROX Unit for a period of two years and shall be made available to the TCEQ personnel upon request.
71. The holder of this permit shall keep records of all fugitive monitoring, repairs, and replacements conducted on the Cumene Unit electronically or in hard copy format for two years.
72. The holder of this permit shall keep records of the firing rate for the Process Heater (EPN 356) in MMBtu/hr on a monthly basis electronically or in hard copy format for two years.

Special Conditions

Permit Numbers 2699A, PSDTX36, PSDTX96, PSDTX653M1, PSDTX831

Page 30

73. The holder of this permit shall keep records of cumene production in BPD and cumulative barrels per year electronically or in hard copy format for two years to show continuous compliance with this permit.
74. The holder of this permit shall keep records of each storage tank throughput in barrels per month and cumulative barrels per year electronically or in hard copy format for two years to demonstrate compliance with tank throughput restrictions.
75. The following monitoring data shall be maintained, for Utility Boiler E (EPN 6100), by the source for a period of five years and shall be made available to the TCEQ Executive Director or his designated representative upon request:
 - A. Average hourly NO_x concentration in ppmvd, average hourly emissions in lb/hr, and one-hour rolling average NO_x emissions in lb/MMBtu of heat input.
 - B. Records of initial performance test. After the initial determination of compliance, the holder of this permit shall maintain a raw data file of all CEMS measurements, including CEMS performance testing measurements, all CEMS calibration checks, and adjustments and maintenance performed on these systems; or measurements of operating conditions monitored, including steam generating unit load, identified in the monitoring plan. This data shall be maintained in a permanent form, either hard copy or electronically, so long as it is suitable for inspection.
 - C. Records of flue gas recirculation (FGR) rates determined pursuant to Special Condition No. 53
 - D. Records specified in Special Condition No. 53.D.
 - E. Copies of natural gas contract specifications for total sulfur and H₂S contents shall be kept in an on-site file. Records of fuel purchased, including date delivered, amount delivered, and any sulfur and H₂S analyses shall be kept in an on-site file. In addition to the records of fuel supplier contract specifications, the holder of this permit shall submit a quarterly report which will include a certification statement signed by the permit holder that the records of fuel supplier certification submitted represent all of the fuel supplied or combusted during the quarter.
 - F. Records of refinery fuel H₂S monitoring specified in Special Condition No. 6161.F.
76. All occurrences of noncomplying emissions/conditions associated with Utility Boiler E (EPN 6100) must be logged and copies sent to the TCEQ Corpus Christi Regional Office on a semiannual basis. For purposes of quarterly reporting, noncomplying emissions will be:
 - A. Each rolling 30-day period, as recorded by the CEMS, during which the average NO_x emissions exceed the lb/MMBtu limit specified in Special Condition No. 0.
 - B. Each one-hour period during which the average NO_x emissions, as recorded by the CEMS, exceed the ppmvd concentration limit stated in Special Condition No. 0 and each hour during which the calculated hourly emissions (lb/hr) exceed the permit allowable stated in the MAERT.

Special Conditions

Permit Numbers 2699A, PSDTX36, PSDTX96, PSDTX653M1, PSDTX831

Page 31

- C. Any FGR value, recorded pursuant to Special Condition No. 755.C during periods of CEMS downtime, that falls outside the rate predetermined during the initial compliance test pursuant to Special Condition No. 53.
- D. Failure to keep any record specified in any condition of this permit will constitute a violation of this permit.
- E. Any fuel certification mandated by Special Condition No. 755.E with fuel sulfur content exceeding the sulfur and/or the H₂S limits specified in Special Condition No. 13.
- F. Failure to conduct and keep records of either the NO_x reduction in lieu of post construction monitoring or postconstruction monitoring in lieu of NO_x reduction, whichever is applicable.

As long as noncomplying emissions/conditions have not occurred, reporting shall consist only of an annual letter to the TCEQ Corpus Christi Regional Office stating that no such conditions have occurred.

- 77. The permit holder shall attach the confidential coke burn rate identified in Special Condition No. 9 to their copy of this permit at their plant site.
- 78. The holder of this permit shall maintain records of the hourly and annual firing rate of the fuel for the Charge Heater, Unibon Heaters 21-H-1A and 21-H-1B, Alkylation Heater 83-H-1, and the Process Heaters (EPNs 207-H-1, 312, 313, 262, 222, and 223).
- 79. For purposes of assuring compliance with the emissions limitations of this permit, the holder of this permit shall calculate emissions monthly showing the monthly and cumulative emissions for the preceding 12-month period from each emission point listed on the attached table entitled "Emission Sources - Maximum Allowable Emission Rates."
- 80. Records of hourly and annual throughputs in long tons of molten sulfur loaded shall be maintained at this facility site and made available at the request of personnel from the TCEQ or any other air pollution control program having jurisdiction to demonstrate compliance with permit limitations. These records shall be totaled for each calendar month and retained for a rolling 60-month period.
- 81. The permit holder shall maintain and update monthly an emissions record which includes calculated emissions of VOC from all Dock 7 loading operations over the previous rolling 12-month period. The record shall include the loading spot, control method used, quantity loaded in gallons, name of the liquid loaded, vapor molecular weight liquid temperature in °F, liquid vapor pressure at the liquid temperature in psia, liquid throughput for the previous month and rolling 12 months to date. Records of VOC temperature are not required to be kept for liquids loaded from unheated tanks which receive liquids that are at or below ambient temperatures. Emissions shall be calculated using the TCEQ publication titled Technical Guidance Package for Chemical Sources - Loading Operations.
- 82. Keep records required under Special Condition 123 for fuel gas usage.
- 83. Keep records required under Special Condition 15 for storage tanks.

Special Conditions

Permit Numbers 2699A, PSDTX36, PSDTX96, PSDTX653M1, PSDTX831

Page 32

84. Keep records required under Special Condition 33 for the vapor combustor.
85. Keep records required under Special Conditions 23, 24, 57, and 60 for heaters.
86. Keep records required under Special Condition 61 for boilers.
87. Keep records required under Special Condition 63 for incinerators.
88. Keep records required under Special Conditions 29 and 30 for cooling towers.
89. Keep records required under Special Condition 32 for flares.
90. Keep records required under Special Condition 38 for marine loading.
91. Keep records required under Special Condition 41 for fugitives under 28MID.
92. Keep records required under Special Condition 44 for fugitives under 28M.
93. Keep records required under Special Condition 46 for fugitives under 28VHP.
94. Keep records required under Special Condition 51 for fugitives under HF service.

Referenced Permit by Rule Authorizations

95. The following sources and/or activities are authorized under a Permit by Rule (PBR) by Title 30 Texas Administrative Code Chapter 106 (30 TAC Chapter 106). These lists are not intended to be all inclusive and can be altered without modifications to this permit.

Authorization	Source or Activity
PBR Reg. No. 77066	Increased FCC feed at Storage Tanks 2006 and 2007
PBR 139767	Changes made to piping to install fugitive components such as valves and flanges
PBR No. 56720	Tank Truck Gasoline Loading
SP No. 80521	Flare Gas Recovery System
1975 Standard Exemption	Butane Loading and Unloading Rack

Date: July 21, 2023

Attachment A (07/23)

Storage Tank Approved Products List

EPN	Tank	Service	Maximum Filling Rate (bbls/hr)	Throughput (bbls/yr)
629	927	Xylene	---	---
630	928	Xylene	---	---
640	929	Xylene	8,000	3,700,000
641	930	Xylene	6,000	3,700,000
657	620	FCCU Feed (Gas Oil)	168,000	---
658	621	FCCU Feed (Gas Oil)	168,000	---
662	1001	Slurry Oil	210,000	---
664	1003	Light Cycle Oil	252,000	---
665A	1020	Coker Feed (No. 6 Oil, Reside)	630,000	---
666	1015	Coker Feed (No. 6 Oil, Reside)	630,000	---
670	1009	Reclaimed Gasoline/Oil	3,000	---
676	1017	Slurry Oil	126,000	---
677	1028	Kerosene/Diesel/Diesel Blend	84,000	---
712	225	Alkylate	---	---
713	226	Alkylate	---	---
714	804	Slop Oil	---	12,000
718	1040	Cumene	294,000	209,000,000
719	1041	Cumene	294,000	209,000,000
720	1042	Cyclohexane	6,000	64,386,000 (gal/yr)
722	1018	MDH Feed (No. 2 Oil, Light Cycle Oil)	5,000	---
723	1019	MDH Feed/LCO/Kerosene	5,000	---
725	1023	Pent/Plat	5,000	2,500,000
		C9+ Aromatics	5,000	3,000,000
		C10+ Aromatics	5,000	550,000
		4UnifPLAT FD	5,000	9,286,917
727	1025	Diesel (LS)	9,225,237	---
728	1026	Diesel (LS)	5,000,000	---
729	1027	Cyclohexane	4,000	1,500,000

EPN	Tank	Service	Maximum Filling Rate (bbls/hr)	Throughput (bbls/yr)
		Toluene	4,000	1,100,000
		Xylene	4,000	3,700,000
739	3101	Diesel (No. 2 Oil)	2,000,000	---
740	3102	Diesel (No. 2 Oil)	2,000,000	---
742	1	Raffinate	3,000	4,197,500
		Cumene BTM	460	121,667
743	2	Benzene	84,000	173,000,000
744	3	Raffinate	3,000	4,197,500
		BTM	460	121,667
745	4	UDEX (Carom) Feed	4,000	7,400,000
746	5	CAT GAS0 from FCCUs	9,000	8,000,000
		UDEX (Carom) Feed	4,000	4,197,500
		Raffinate	4,000	4,197,500
		Cumene BTM	2,000	121,667
		Toluene	4,000	1,711,850
		Cyclohexane	6,000	985,500
749	13	Toluene	4,000	1,711,850
		Light Platformate	4,000	389,455
750	14	UDEX (Carom) Feed	4,000	1,711,850
		Toluene	4,000	1,711,850
751	20	Toluene	4,000	1,711,850
		Cumene BTM	4,000	1,711,850
		C9+ Aromatics	4,000	1,711,850
		C10+ Aromatics	4,000	5,500,000
		Benzene ¹	4,000	144,285,960
752	21	Benzene	84,000	144,000,000
753	22	Benzene	84,000	144,000,000
757	33	Benzene	2,000	51,110,220 (gal/yr)
758	34	Benzene	2,000	51,110,220 (gal/yr)
759	40	VOC	1,000	2,000,000
760	41	VOC	1,000	2,000,000
761	42	VOC	1,000	2,000,000
762	43	Cumene	105,000	209,000,000
763	44	Cumene	105,000	209,000,000

EPN	Tank	Service	Maximum Filling Rate (bbls/hr)	Throughput (bbls/yr)
764	45	Cumene	105,000	209,000,000
765	50	C9+ Aromatics	4,000	3,000,000
		Xylene	4,000	700,000
		C10+ Aromatics	4,000	550,000
769	60	Tetraethylene Glycol dissolved in water	30,000	---
770	61	Tetraethylene Glycol dissolved in water	30,000	---
771	62	Reclaimed Tetraethylene Glycol	30,000	---
772	63	Tetraethylene Glycol	30,000	---
773	81	Light Cycle Oil	5,302,407	---
776	91	Cyclohexane	1,500	41,391,000 (gal/yr)
777	92	Cyclohexane	1,500	41,391,000 (gal/yr)
778	93	Cyclohexane	1,500	41,391,000 (gal/yr)

¹ This product is authorized to be temporarily stored in Tank 20 while Tank 22 is out of service.
When Tank 22 comes back into service this product is no longer authorized to be stored in Tank 20.

Date: July 21, 2023

Emission Sources - Maximum Allowable Emission Rates

Permit Number 2699A, PSDTX36, PSDTX96, PSDTX653M1, PSDTX831

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
742	Tank No. 1	VOC	2.42	4.75
743	Tank 2	VOC	0.54	0.88
744	Tank No. 3	VOC	2.36	4.62
745	Tank No. 4	VOC	1.32	2.43
746	Tank No. 5	VOC	3.44	11.79
749	Tank No. 13	VOC	0.94	0.51
750	Tank No. 14	VOC	1.15	1.25
751	Tank No. 20*	VOC	0.93	0.67
751	Tank No. 20**	VOC	0.06	0.06
752	Tank 21	VOC	0.64	0.85
753	Tank 22*	VOC	0.64	0.85
753	Tank 22**	VOC	0.0	0.0
757	Tank 33	VOC	0.59	0.63
758	Tank 34	VOC	0.59	0.63
759	Tank No. 40	VOC	0.68	0.90
760	Tank No. 41	VOC	0.78	1.11
761	Tank No. 42	VOC	0.78	1.11
762	Tank 43	VOC	0.54	0.58
763	Tank 44	VOC	0.54	0.58
764	Tank 45	VOC	0.47	0.52
765	Tank No. 50	VOC	0.84	0.32
769	Storage Tank 60	VOC	0.11	0.01
770	Storage Tank 61	VOC	0.11	0.01

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
771	Storage Tank 62	VOC	0.85	0.01
772	Storage Tank 63	VOC	0.96	0.01
773	Storage Tank 81	VOC	19.50	5.50
776	Tank 91	VOC	0.63	0.86
777	Tank 92	VOC	0.63	0.86
778	Tank 93	VOC	0.63	0.86
712	Tank 225 (8)	VOC	2.42	3.06
713	Tank 226 (8)	VOC	2.42	3.06
657	Storage Tank 620	VOC	18.42	0.18
658	Storage Tank 621	VOC	18.42	0.18
714	Storage Tank 804	VOC	3.91	2.77
638	Tank 925	VOC	1.99	4.66
639	Tank 926	VOC	1.99	4.66
629	Tank 927 (9)	Xylene	0.62	0.47
630	Tank 928 (9)	Xylene	0.62	0.48
640	Tank No. 929	VOC	1.27	0.40
641	Tank No. 930	VOC	0.97	0.41
662	Storage Tank 1001	VOC	7.98	0.09
664	Storage Tank 1003	VOC	19.50	3.69
670	Storage Tank 1009	VOC	1.11	1.47
666	Storage Tank 1015	VOC	28.45	1.67
676	Storage Tank 1017	VOC	4.79	0.04

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
722	Storage Tank 1018	VOC	0.71	0.55
723	Storage Tank 1019	VOC	0.71	0.55
665A	Storage Tank 1020	VOC	28.45	1.67
724	Tank 1022	VOC	4.66	14.68
725	Tank No. 1023	VOC	5.99	20.95
726	Tank 1024	VOC	3.76	9.70
727	Storage Tank 1025	VOC	31.93	8.12
728	Storage Tank 1026	VOC	31.93	7.37
729	Tank No. 1027	VOC	1.06	1.71
677	Storage Tank 1028	VOC	9.12	7.24
718	Tank 1040	VOC	0.77	0.43
719	Tank 1041	VOC	0.70	0.34
720	Tank 1042	VOC	1.08	1.51
732	Tank 2001	VOC	5.09	1.67
733	Tank 2002	VOC	2.89	6.41
734	Tank 2003	VOC	8.80	0.93
736	Tank 2005	VOC	8.80	2.21
737	Tank 2006	VOC	8.80	2.21
739	Storage Tank 3101	VOC	10.65	0.66
740	Storage Tank 3102	VOC	10.65	0.66
433	Sour Water Tank	H ₂ S	0.12	0.38
		NH ₃	0.01	0.01
		VOC	0.46	1.51
087		CO	0.22	0.97

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
	Catalyst Regenerator Vent	HCl	0.024	0.11
		Cl ₂	0.17	0.72
CPICAS	CPI Carbon Canister	VOC	0.01	0.05
6100	Utility Boiler E	NO _x	25.60	112.13
		CO	23.84	104.43
		VOC	1.76	7.71
		SO ₂	9.08	39.77
		PM ₁₀	2.43	10.65
292 (6)	Combined Stack for the Crude Heater (11-H-1) and the Vacuum Heater (11-H-2)	CO	21.77	82.63
		NO _x	52.87	200.67
		PM	4.63	17.59
		PM ₁₀	4.63	17.59
		PM _{2.5}	4.63	17.59
		SO ₂	19.44	35.44
		VOC	3.35	12.73
312	Unibon Heater 21-H-1A	CO	4.44	17.66
		NO _x	3.17	12.61
		PM	0.40	1.60
		PM ₁₀	0.40	1.60
		PM _{2.5}	0.40	1.60
		SO ₂	1.42	5.65
		VOC	0.29	1.16
313	Unibon Heater 21-H-1B	CO	4.44	17.66
		NO _x	3.17	12.61
		PM	0.40	1.60
		PM ₁₀	0.40	1.60
		PM _{2.5}	0.40	1.60

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
		SO ₂	1.42	5.65
		VOC	0.29	1.16
362	Absorber Reboiler Heater 41-H1 (7)	CO	0.35	0.80
		NO _x	2.25	9.86
		PM	0.42	1.84
		PM ₁₀	0.42	1.84
		PM _{2.5}	0.42	1.84
		SO ₂	2.03	4.35
		VOC	0.30	1.33
362	Debutanizer Reboiler Heater 41-H2 (7)	CO	0.22	0.47
		NO _x	1.42	6.22
		PM	0.26	1.16
		PM ₁₀	0.26	1.16
		PM _{2.5}	0.26	1.16
		SO ₂	1.05	1.73
		VOC	0.19	0.84
262	Alky Heater 83-H-1	VOC	0.74	2.93
		NO _x	25.43	101.26
		SO ₂	3.60	14.33
		PM	1.02	4.05
		PM ₁₀	1.02	4.05
		PM _{2.5}	1.02	4.05
		CO	11.24	44.77

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
86	Aromatic Splitter Heater 29H5	VOC	0.28	1.13
		CO	4.35	17.31
		NO _x	5.18	20.61
		PM	0.39	1.57
		PM ₁₀	0.39	1.57
		PM _{2.5}	0.39	1.57
		SO ₂	1.61	3.20
202	ADP Heater 17H1	VOC	0.18	0.81
		CO	1.03	4.51
		NO _x	3.09	13.52
		PM	0.26	1.12
		PM ₁₀	0.26	1.12
		PM _{2.5}	0.26	1.12
		SO ₂	1.04	2.29
356	Process Heater 14-H-1	VOC	0.85	3.73
		NO _x	15.76	69.05
		CO	13.01	57.00
		PM	1.18	5.16
		PM ₁₀	1.18	5.16
		PM _{2.5}	1.18	5.16
		SO ₂	4.16	18.22

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
222	Heater 19-H-1	CO	0.86	3.75
		NO _x	1.02	4.46
		PM	0.08	0.34
		PM ₁₀	0.08	0.34
		PM _{2.5}	0.08	0.34
		SO ₂	0.28	0.45
		VOC	0.06	0.25
223	Heater 19-H-2	CO	0.33	1.46
		NO _x	0.40	1.74
		PM	0.03	0.13
		PM ₁₀	0.03	0.13
		PM _{2.5}	0.03	0.13
		SO ₂	0.11	0.18
		VOC	0.02	0.10
102	Unifier Reactor Heater	VOC	0.21	0.91
		NO _x	3.78	16.60
		SO ₂	1.04	4.56
		PM ₁₀	0.29	1.26
		CO	3.17	13.90
103	Unifier Stripper Heater	VOC	0.08	0.35
		NO _x	1.46	6.41
		SO ₂	0.40	1.76
		PM ₁₀	0.11	0.49
		CO	1.23	5.39

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
82, 83, 84	Platformer Reactor Heaters 1A, 1B, 1C, 1D	VOC	1.39	6.10
		NO _x	11.36	49.76
		SO ₂	6.98	30.41
		PM ₁₀	1.91	8.41
		CO	21.23	92.93
85	Platformer Stabilizer Heater	VOC	0.12	0.51
		NO _x	2.10	9.20
		SO ₂	0.58	2.53
		PM ₁₀	0.16	0.70
		CO	1.76	7.72
207-H-1	GHT Charge Heater	NO _x	1.93	8.44
		SO ₂	1.24	5.44
		VOC	0.29	1.25
		CO	3.93	17.22
		PM	0.41	1.80
		PM ₁₀	0.41	1.80
		PM _{2.5}	0.41	1.80
412	SRU Incinerator Stack	CO	0.20	0.85
		NO _x	1.37	6.00
		PM ₁₀	0.11	0.50
		VOC	0.03	0.15
		COS	0.50	-
		CS ₂	0.63	-
		H ₂ S	0.56	-
		SO ₂	26.44	-

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
412A	SRU Incinerator Stack	CO	1.26	2.14
		NO _x	1.20	2.03
		PM ₁₀	0.11	0.19
		VOC	0.08	0.14
		COS	0.50	-
		CS ₂	0.63	-
		H ₂ S	0.56	-
		SO ₂	26.44	-
412/412A	Annual SRU Incinerator Cap	COS		2.19
		CS ₂		2.76
		H ₂ S		2.46
		SO ₂		115.81
417	Cooling Tower (5)	PM ₁₀	1.54	6.76
		VOC	0.18	0.77
CT	Cooling Tower	PM	0.32	1.38
		PM ₁₀	0.32	1.38
		PM _{2.5}	0.32	1.38
		VOC	0.59	2.58
F069	No. 5 Cooling Tower (5)	PM	2.80	12.26
		PM ₁₀	2.80	12.26
		PM _{2.5}	2.80	12.26
		VOC	0.32	1.38
F110	Cooling Tower 7	VOC	0.71	3.10
F089	Cooling Tower 9 (5)	VOC	0.15	0.67

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
F208	Cooling Tower 10	VOC	0.34	1.47
		PM	2.88	12.62
		PM ₁₀	1.22	5.37
		PM _{2.5}	0.01	0.03
F3700	Cooling Tower 12	VOC	0.63	2.76
		PM	5.51	24.13
		PM ₁₀	5.51	24.13
		PM _{2.5}	5.51	24.13
F297	Cooling Tower 81	VOC	1.26	5.52
		PM	0.68	2.96
		PM ₁₀	0.68	2.96
		PM _{2.5}	< 0.01	< 0.01
F264	Alky Cooling Tower	VOC (5)	1.01	4.42
		PM	0.54	2.37
		PM ₁₀	0.54	2.37
		PM _{2.5}	0.54	2.37
207-CT001	GHT Cooling Tower	VOC	0.12	0.50
		PM	0.05	0.20
		PM ₁₀	0.05	0.20
		PM _{2.5}	0.05	0.20
F442	Fluor Flare	CO	0.10	0.46
		NO _x	0.01	0.06
		SO ₂	0.01	0.01
		VOC	0.01	0.01

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
MEC7	Dock 7 MEC	VOC (10)	55.18	11.98
		Benzene	3.41	0.34
		NO _x	15.69	22.61
		CO	11.77	16.96
		SO ₂	0.01	0.06
		PM	0.55	0.79
		PM ₁₀	0.55	0.79
		PM _{2.5}	0.55	0.79
591	Dock 7 Loading Fugitives	VOC (10)	159.78	29.35
		Benzene	0.87	0.13
SULFURLOAD	Molten Sulfur Truck/Railcar Loading (5)	H ₂ S (10)	0.18	0.26
415	Sulfur Pit	H ₂ S	0.44	1.93
F290	Fugitives (5)	VOC	34.80	152.42
F311	Unibon Process Fugitives (5)	VOC	21.17	92.73
F321	Jet/Kerosene Fugitives (5)	VOC	0.08	0.33
		H ₂ S	< 0.01	< 0.01
		NaOH	< 0.01	< 0.01
F331	FCC Gasoline Merox Unit Fugitives (5)	VOC	0.28	1.23
F361	Saturates Gas Plant Process Fugitives (5)	VOC	9.10	39.85
		H ₂ S	< 0.01	0.02
F371	No. 42 Fuel Gas Treatment Fugitives (5)	VOC	1.05	4.59
		Ammonia	< 0.01	0.02
		H ₂ S	0.02	0.09

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
F381	Saturated LPG Merox Fugitives (5)	VOC	1.49	6.54
		H ₂ S	0.01	0.04
		NaOH	< 0.01	< 0.01
F391	Unsaturates LPG Merox Fugitives (5)	VOC	1.35	5.92
		H ₂ S	< 0.01	0.01
		NaOH	< 0.01	< 0.01
F244	Mole Sieve Unit Process Fugitives (5)	VOC	0.40	1.74
F261	Alky Fugitives (5)	VOC	11.93	52.58
		HF	0.08	0.34
F411	SRU Process Fugitives (5)	H ₂ S	2.63	11.53
		NH ₃	0.41	1.82
		VOC	5.99	26.24
F416	SRU Process Fugitives (5)	H ₂ S	0.20	0.85
		NH ₃	0.01	0.01
		VOC	0.12	0.50
F211	Process Fugitives (5)	VOC	4.39	19.21
		H ₂ S	< 0.01	< 0.01
F355	Fugitives (5)	VOC	3.06	13.68
		Benzene	0.84	3.68
F942	Mixed C3 Terminal Fugitives (5)	VOC	7.93	34.73
F441	Fluor Flare Fugitives (5)	VOC	0.26	1.14
F221	Hydrar Fugitives (5)	VOC	1.30	5.68
		H ₂ S	0.01	0.01
F3720	C4SHP Fugitives (5)	VOC	2.34	10.25

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
F3200	DeC5 Process Fugitives (5)	VOC	1.70	7.45
F4600	MTBE Process Fugitives (5)	VOC	1.14	5.01
F4710	C5 Merox Unit Fugitives (5)	VOC	0.91	3.96
		NaOH	< 0.01	< 0.01
F271	Utility Boiler E Fugitives (5)	VOC	0.38	1.66
F1002	Dock 7 Piping Fugitives (5)	VOC	0.37	1.61
F281 (5)	No.2 Oil and Salt Drier Area Fugitives	VOC	0.04	0.16
F821 (5)	Tank Farm & Pump House Area Fugitives (5)	VOC	15.58	68.25
		Benzene	0.49	2.13
F890	Butane Storage Fugitives (5)	VOC	0.26	1.13
F081	Platformer 4 Fugitives (5)	VOC	22.52	98.62
FUG-GHT	GHT Fugitives (5)	VOC	1.50	6.56
		H ₂ S	< 0.01	0.04
		NH ₃	0.01	0.01
F061	FCCU 1 Process Fugitives (5)	VOC	23.09	101.40

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name. For fugitive sources, use area name or fugitive source name.

(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1

NO_x - total oxides of nitrogen

SO₂ - sulfur dioxide

PM - total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented

PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented

PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter

Emission Sources - Maximum Allowable Emission Rates

CO	- carbon monoxide
NH ₃	- ammonia
CS ₂	- carbon disulfide
COS	- carbonyl disulfide
H ₂ S	- hydrogen sulfide
HCl	- hydrogen chloride
Cl ₂	- chlorine
NaOH	- sodium hydroxide
HF	- hydrogen fluoride
H ₂ SO ₄	- sulfuric acid PM collected in balk-half of PM test collection device
HAP	- hazardous air pollutant as listed in § 112(b) of the Federal Clean Air Act or Title 40 Code of Federal Regulations Part 63, Subpart C

- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
- (5) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission rate. Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.
- (6) These emission rate limits become effective upon completion of the project identified in the Company's March 2013 permit amendment application.
- (7) Each heater vents through a common stack.
- (8) Permit by Rule (PBR) Number 78195 authorizes the change in service to the tanks in this permit and a tank in another permit. PBR 78195 cannot be voided, retains authorization, and is fully incorporated by reference into this table.
- (9) PBR Number 90292 superseded the authorizations for EPNs 629 and 630 contained in PBR 78195 and is fully incorporated into this permit and voided.
- (10) VOC emission rates are total VOC emission rates and include the benzene emission rates.

*These emission rates shall be suspended while EPN 753 is out of service and shall be reinstated when EPN 753 returns to service.

**These emission rates are temporary while EPN 753 is out of service and shall be suspended when EPN 753 returns to service.

Date: July 21, 2023



Texas Commission on Environmental Quality Air Quality Permit

A Permit Is Hereby Issued To
CITGO Refining and Chemicals Company L.P.
Authorizing the Construction and Operation of
CITGO Corpus Christi Refinery East Plant
Located at Corpus Christi, Nueces County, Texas
Latitude 27° 48' 34" Longitude -97° 25' 33"

Permits: 9604A and PSDTX653M1

Revision Date: June 18, 2020

Expiration Date: August 23, 2029



For the Commission

1. **Facilities** covered by this permit shall be constructed and operated as specified in the application for the permit. All representations regarding construction plans and operation procedures contained in the permit application shall be conditions upon which the permit is issued. Variations from these representations shall be unlawful unless the permit holder first makes application to the Texas Commission on Environmental Quality (commission) Executive Director to amend this permit in that regard and such amendment is approved. [Title 30 Texas Administrative Code (TAC) Section 116.116 (30 TAC § 116.116)] ¹
2. **Voiding of Permit.** A permit or permit amendment is automatically void if the holder fails to begin construction within 18 months of the date of issuance, discontinues construction for more than 18 months prior to completion, or fails to complete construction within a reasonable time. Upon request, the executive director may grant an 18-month extension. Before the extension is granted the permit may be subject to revision based on best available control technology, lowest achievable emission rate, and netting or offsets as applicable. One additional extension of up to 18 months may be granted if the permit holder demonstrates that emissions from the facility will comply with all rules and regulations of the commission, the intent of the Texas Clean Air Act (TCAA), including protection of the public's health and physical property; and (b)(1) the permit holder is a party to litigation not of the permit holder's initiation regarding the issuance of the permit; or (b)(2) the permit holder has spent, or committed to spend, at least 10 percent of the estimated total cost of the project up to a maximum of \$5 million. A permit holder granted an extension under subsection (b)(1) of this section may receive one subsequent extension if the permit holder meets the conditions of subsection (b)(2) of this section. [30 TAC § 116.120]
3. **Construction Progress.** Start of construction, construction interruptions exceeding 45 days, and completion of construction shall be reported to the appropriate regional office of the commission not later than 15 working days after occurrence of the event. [30 TAC § 116.115(b)(2)(A)]
4. **Start-up Notification.** The appropriate air program regional office shall be notified prior to the commencement of operations of the facilities authorized by the permit in such a manner that a representative of the commission may be present. The permit holder shall provide a separate notification for the commencement of operations for each unit of phased construction, which may involve a series of units commencing operations at different times. Prior to operation of the facilities authorized by the permit, the permit holder shall identify the source or sources of allowances to be utilized for compliance with Chapter 101, Subchapter H, Division 3 of this title (relating to Mass Emissions Cap and Trade Program). [30 TAC § 116.115(b)(2)(B)]
5. **Sampling Requirements.** If sampling is required, the permit holder shall contact the commission's Office of Compliance and Enforcement prior to sampling to obtain the proper data forms and procedures. All sampling and testing procedures must be approved by the executive director and coordinated with the regional representatives of the commission. The permit holder is also responsible for providing sampling facilities and conducting the sampling operations or contracting with an independent sampling consultant. [30 TAC § 116.115(b)(2)(C)]
6. **Equivalency of Methods.** The permit holder must demonstrate or otherwise justify the equivalency of emission control methods, sampling or other emission testing methods, and monitoring methods proposed as alternatives to methods indicated in the conditions of the permit. Alternative methods shall be applied for in writing and must be reviewed and approved by the executive director prior to their use in fulfilling any requirements of the permit. [30 TAC § 116.115(b)(2)(D)]
7. **Recordkeeping.** The permit holder shall maintain a copy of the permit along with records containing the information and data sufficient to demonstrate compliance with the permit, including production records and

operating hours; keep all required records in a file at the plant site. If, however, the facility normally operates unattended, records shall be maintained at the nearest staffed location within Texas specified in the application; make the records available at the request of personnel from the commission or any air pollution control program having jurisdiction in a timely manner; comply with any additional recordkeeping requirements specified in special conditions in the permit; and retain information in the file for at least two years following the date that the information or data is obtained. [30 TAC § 116.115(b)(2)(E)]

8. **Maximum Allowable Emission Rates.** The total emissions of air contaminants from any of the sources of emissions must not exceed the values stated on the table attached to the permit entitled "Emission Sources-- Maximum Allowable Emission Rates." [30 TAC § 116.115(b)(2)(F)] ¹
9. **Maintenance of Emission Control.** The permitted facilities shall not be operated unless all air pollution emission capture and abatement equipment is maintained in good working order and operating properly during normal facility operations. The permit holder shall provide notification in accordance with 30 TAC §101.201, 101.211, and 101.221 of this title (relating to Emissions Event Reporting and Recordkeeping Requirements; Scheduled Maintenance, Startup, and Shutdown Reporting and Recordkeeping Requirements; and Operational Requirements). [30 TAC§ 116.115(b)(2)(G)]
10. **Compliance with Rules.** Acceptance of a permit by an applicant constitutes an acknowledgment and agreement that the permit holder will comply with all rules and orders of the commission issued in conformity with the TCAA and the conditions precedent to the granting of the permit. If more than one state or federal rule or regulation or permit condition is applicable, the most stringent limit or condition shall govern and be the standard by which compliance shall be demonstrated. Acceptance includes consent to the entrance of commission employees and agents into the permitted premises at reasonable times to investigate conditions relating to the emission or concentration of air contaminants, including compliance with the permit. [30 TAC § 116.115(b)(2)(H)]
11. **This** permit may not be transferred, assigned, or conveyed by the holder except as provided by rule. [30 TAC § 116.110(e)]
12. **There** may be additional special conditions attached to a permit upon issuance or modification of the permit. Such conditions in a permit may be more restrictive than the requirements of Title 30 of the Texas Administrative Code. [30 TAC § 116.115(c)]
13. **Emissions** from this facility must not cause or contribute to "air pollution" as defined in Texas Health and Safety Code (THSC) §382.003(3) or violate THSC § 382.085. If the executive director determines that such a condition or violation occurs, the holder shall implement additional abatement measures as necessary to control or prevent the condition or violation.
14. **The** permit holder shall comply with all the requirements of this permit. Emissions that exceed the limits of this permit are not authorized and are violations of this permit. ¹

¹ Please be advised that the requirements of this provision of the general conditions may not be applicable to greenhouse gas emissions.

Common Acronyms in Air Permits

°C = Temperature in degrees Celsius	GLCmax = maximum (predicted) ground-level concentration
°F = Temperature in degrees Fahrenheit	gpm = gallon per minute
°K = Temperature in degrees Kelvin	gr/1000scf = grain per 1000 standard cubic feet
µg = microgram	gr/dscf = grain per dry standard cubic feet
µg/m ³ = microgram per cubic meter	H ₂ CO = formaldehyde
acfm = actual cubic feet per minute	H ₂ S = hydrogen sulfide
AMOC = alternate means of control	H ₂ SO ₄ = sulfuric acid
AOS = alternative operating scenario	HAP = hazardous air pollutant as listed in § 112(b) of the Federal Clean Air Act or Title 40 Code of Federal Regulations Part 63, Subpart C
AP-42 = Air Pollutant Emission Factors, 5th edition	HC = hydrocarbons
APD = Air Permits Division	HCl = hydrochloric acid, hydrogen chloride
API = American Petroleum Institute	Hg = mercury
APWL = air pollutant watch list	HGB = Houston/Galveston/Brazoria
BPA = Beaumont/ Port Arthur	hp = horsepower
BACT = best available control technology	hr = hour
BAE = baseline actual emissions	IFR = internal floating roof tank
bbl = barrel	in H ₂ O = inches of water
bbl/day = barrel per day	in Hg = inches of mercury
bhp = brake horsepower	IR = infrared
BMP = best management practices	ISC3 = Industrial Source Complex, a dispersion model
Btu = British thermal unit	ISCST3 = Industrial Source Complex Short-Term, a dispersion model
Btu/scf = British thermal unit per standard cubic foot or feet	K = Kelvin; extension of the degree Celsius scaled-down to absolute zero
CAA = Clean Air Act	LACT = lease automatic custody transfer
CAM = compliance-assurance monitoring	LAER = lowest achievable emission rate
CEMS = continuous emissions monitoring systems	lb = pound
cfm = cubic feet (per) minute	hp = horsepower
CFR = Code of Federal Regulations	hr = hour lb/day = pound per day
CN = customer ID number	lb/hr = pound per hour
CNG = compressed natural gas	lb/MMBtu = pound per million British thermal units
CO = carbon monoxide	LDAR = Leak Detection and Repair (Requirements)
COMS = continuous opacity monitoring system	LNG = liquefied natural gas
CPMS = continuous parametric monitoring system	LPG = liquefied petroleum gas
DFW = Dallas/ Fort Worth (Metroplex)	LT/D = long ton per day
DE = destruction efficiency	m = meter
DRE = destruction and removal efficiency	m ³ = cubic meter
dscf = dry standard cubic foot or feet	m/sec = meters per second
dscfm = dry standard cubic foot or feet per minute	MACT = maximum achievable control technology
ED = (TCEQ) Executive Director	MAERT = Maximum Allowable Emission Rate Table
EF = emissions factor	MERA = Modeling and Effects Review Applicability
EFR = external floating roof tank	mg = milligram
EGU = electric generating unit	mg/g = milligram per gram
EI = Emissions Inventory	mL = milliliter
ELP = El Paso	MMBtu = million British thermal units
EPA = (United States) Environmental Protection Agency	MMBtu/hr = million British thermal units per hour
EPN = emission point number	MSDS = material safety data sheet
ESL = effects screening level	MSS = maintenance, startup, and shutdown
ESP = electrostatic precipitator	MW = megawatt
FCAA = Federal Clean Air Act	NAAQS = National Ambient Air Quality Standards
FCCU = fluid catalytic cracking unit	NESHAP = National Emission Standards for Hazardous Air Pollutants
FID = flame ionization detector	NGL = natural gas liquids
FIN = facility identification number	NNSR = nonattainment new source review
ft = foot or feet	NO _x = total oxides of nitrogen
ft/sec = foot or feet per second	
g = gram	
gal/wk = gallon per week	
gal/yr = gallon per year	
GLC = ground level concentration	

NSPS = New Source Performance Standards
 PAL = plant-wide applicability limit
 PBR = Permit(s) by Rule
 PCP = pollution control project
 PEMS = predictive emission monitoring system
 PID = photo ionization detector
 PM = periodic monitoring
 PM = total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented
 PM_{2.5} = particulate matter equal to or less than 2.5 microns in diameter
 PM₁₀ = total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented
 POC = products of combustion
 ppb = parts per billion
 ppm = parts per million
 ppmv = parts per million (by) volume
 psia = pounds (per) square inch, absolute
 psig = pounds (per) square inch, gage
 PTE = potential to emit
 RA = relative accuracy
 RATA = relative accuracy test audit
 RM = reference method
 RVP = Reid vapor pressure
 scf = standard cubic foot or feet
 scfm = standard cubic foot or feet (per) minute
 SCR = selective catalytic reduction
 SIL = significant impact levels
 SNCR = selective non-catalytic reduction
 SO₂ = sulfur dioxide
 SOCMF = synthetic organic chemical manufacturing industry
 SRU = sulfur recovery unit
 TAC = Texas Administrative Code
 TCAA = Texas Clean Air Act
 TCEQ = Texas Commission on Environmental Quality
 TD = Toxicology Division
 TLV = threshold limit value
 TMDL = total maximum daily load
 tpd = tons per day
 tpy = tons per year
 TVP = true vapor pressure
 VOC = volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
 VRU = vapor recovery unit or system

Special Conditions
Permit Numbers 9604A and PSDTX653M1

Emission Standards

1. This permit authorizes emissions only from those points listed in the attached table entitled "Emission Sources - Maximum Allowable Emission Rates," (MAERT) and the facilities covered by this permit are authorized to emit subject to the emission rate limits on that table and other operating conditions specified in this permit.
2. Non-fugitive emissions from relief valves, safety valves, or rupture discs of gases containing volatile organic compounds (VOC) at a concentration of greater than 1 percent are not authorized by this permit unless authorized on the maximum allowable emission rates table. Any releases directly to atmosphere from relief valves, safety valves, or rupture discs of gases containing VOC at a concentration greater than 1 weight percent are not consistent with good practice for minimizing emissions.

Operational Limitations, Work Practices, and Plant Design

3. The fresh feed charge rate to the No. 2 Fluid Catalytic Cracking Unit (FCCU) shall not exceed the values listed below.

Daily maximum of 81,600 barrels per day.

Annual average of 75,000 barrels per day, calculated as a 12-month rolling average at the end of each calendar month

Records of daily charge rate and 12-month rolling average calculations shall be maintained. **(PSD)**

4. The No. 2 FCCU Regenerator sulfur dioxide (SO₂) emissions shall be limited as follows:

SO₂ emissions from the No.2 FCCU Regenerator/ESP stack shall not exceed 25 ppmvd at 0% excess oxygen on a 365-day rolling average basis, 50 ppmvd at 0% excess oxygen on a 7-day rolling average, and 200 ppmvd at 0 % excess oxygen on a one-hour average basis.
(PSD)

5. Carbon monoxide (CO) emissions from the No. 2 FCCU Regenerator/ESP stack shall not exceed 100 ppmvd at 0% excess O₂ on a 365-day rolling average basis, and 500 ppmvd at 0% excess O₂ on a one-hour average basis.
6. Emissions of nitrogen oxides (NO_x) from the No. 2 FCCU Regenerator/ESP stack shall not exceed 20 ppmvd at 0% excess O₂ on a 365-day rolling average basis, 40 ppmvd at 0% excess O₂ on a seven-day rolling average basis, and 180 ppmvd at 0% excess oxygen on a one -hour average basis. **(PSD)**
7. Emissions of particulate matter and sulfuric acid mist from the No.2 FCCU Regenerator/ESP Stack (Emission Point No. [EPN] 31-PR-1) shall not exceed one pound per 1,000 pounds of coke burn-off and 0.50 pound per 1,000 pounds of coke burn-off respectively.

Storage Tanks

8. Storage tanks are subject to the following requirements. These conditions shall not apply: (1) where the VOC has an aggregate partial pressure of less than 0.5 pound per square inch, absolute (psia) at the maximum feed temperature or 95°F, whichever is greater, or (2) to storage tanks smaller than 25,000 gallons.
- A. An internal floating roof or equivalent control shall be installed on all tanks. The floating roof shall be equipped with one of the following closure devices between the wall of the storage vessel and the edge of the internal floating roof: (1) a liquid-mounted seal, (2) two continuous seals mounted one above the other, or (3) a mechanical shoe seal.
 - B. An open-top tank containing an floating roof (external floating roof tank) which uses double seal or secondary seal technology shall be an approved control alternative to an internal floating roof tank provided the primary seal consists of either a mechanical shoe seal or a liquid-mounted seal, and the secondary seal is rim-mounted. A weather shield is not approvable as a secondary seal unless specifically reviewed and determined to be vapor-tight.
 - C. For any tank equipped with a floating roof, the permit holder shall perform the visual inspections and seal gap measurements as specified in Title 40 Code of Federal Regulations § 60.113b (40 CFR § 60.113b) Testing and Procedures (as amended at 54 FR 32973, August 11, 1989) to verify fitting and seal integrity. Records shall be maintained of the dates seals were inspected and seal gap measurements made, results of inspections and measurements made (including raw data), and actions taken to correct any deficiencies noted.
 - D. The floating roof design shall incorporate sufficient floatation to conform to the requirements of American Petroleum Institute (API) Code 650, dated November 1, 1998, except that an internal floating cover need not be designed to meet rainfall support requirements and the materials of construction may be steel or other materials.
 - E. Except for labels, logos, etc. not to exceed 15 percent of the tank total surface area, uninsulated tank exterior surfaces exposed to the sun shall be white or unpainted aluminum. Storage tanks must be equipped with permanent submerged fill pipes.
 - F. The permit holder shall maintain an emissions record which includes calculated emissions of VOC from all storage tanks during the previous calendar month and the past 12-month rolling period. The records shall include tank identification number, control method used, tank capacity in gallons, name of the material stored, VOC molecular weight, VOC monthly average temperature in degrees Fahrenheit, VOC vapor pressure at the monthly average material temperature in psia, VOC throughput for the previous month and year-to-date. Records of VOC monthly average temperature are not required to be kept for unheated tanks which receive liquids that are at or below ambient temperatures.
- Emissions from tanks shall be calculated using the methods that were used to determine the MAERT limits in the permit application. Sample calculations from the application shall be attached to a copy of this permit at the plant site.

Spent Catalyst and Electrostatic Precipitator Dust Removal

9. Spent catalyst and electrostatic precipitator dust shall be collect by a vacuum truck equipped with a filter on the exhaust blower rated to achieve 0.005 grains per standard cubic foot or better. The date, start and stop time of the vacuuming and blower rate shall be recorded.

Initial Demonstration of Compliance

10. The holder of this permit shall perform stack sampling and other testing as required to establish the actual pattern and quantities of air contaminants being emitted into the atmosphere from the No. 2 FCCU Regenerator/ESP Stack, Source 31-PR-1. The holder of this permit is responsible for providing sampling and testing facilities and conducting the sampling and the testing operation at his expense.
 - A. The TCEQ Corpus Christi Regional Office shall be contacted as soon as testing is scheduled but not less than 45 days prior to sampling to schedule a pretest meeting.

The notice shall include:

 - (1) Date for pretest meeting.
 - (2) Date sampling will occur.
 - (3) Name of firm conducting sampling.
 - (4) Type of sampling equipment to be used.
 - (5) Method or procedure to be used in sampling.

The purpose of the pretest meeting is to review the necessary sampling and testing procedures, to provide the proper data forms for recording pertinent data, and to review the format procedures for submitting the test reports. Testing shall be performed per U.S. Environmental Protection Agency (EPA) Test Method (TM) 6 for SO₂, TM 7 for NO_x, and TM 8 for H₂SO₄.

A written description of any deviation from sampling procedures specified in permit conditions or TCEQ or EPA sampling procedures shall be made available to the TCEQ at or prior to the pretest meeting. The TCEQ Corpus Christi Regional Director shall approve or disapprove of any deviation from specified sampling procedures. Requests to waive testing for any pollutant specified in B of this condition shall be submitted to the TCEQ Air Permits Division. Test waivers and alternate or equivalent procedure proposals for New Source Performance Standards (NSPS) testing which must have the EPA approval shall be submitted to the TCEQ Corpus Christi Regional Director.
 - B. Air contaminants to be emitted from the No. 2 FCCU Regenerator/ESP stack to be tested for include (but are not limited to) H₂SO₄.
 - C. Sampling shall occur within 60 days after the facilities achieve maximum production, but not later than 180 days after initial start-up of the facilities and at such other times as may be required by the Executive Director of the TCEQ. Requests for additional time to perform sampling shall be submitted to the TCEQ Corpus Christi Regional Office. Additional time to comply with the requirements of 40 CFR Part 60 and 40 CFR Part 61 cannot be granted.

- D. One copy of the final sampling report shall be forwarded to the TCEQ within 30 days after sampling is completed. Sampling reports shall comply with the provisions of Chapter 14 of the TCEQ Sampling Procedures Manual. The reports shall be distributed as follows:

One copy to the TCEQ Corpus Christi Regional Office.

This condition has been rolled in from the original Prevention of Signification Deterioration (PSD) permit. The above testing was performed on December 10, 1985, and does not need to be redone due to the consolidation of permits.

On-Going Demonstration of Compliance

11. The concentrations of SO₂ and O₂ in the No. 2 FCCU Regenerator/ESP stack shall be continuously monitored and recorded. The SO₂ and O₂ continuous emission monitoring system (CEMS) shall be subjected to quality-assurance procedures which shall, as a minimum, include daily zero and span of the analyzer. This monitoring data shall be maintained in accordance with conditions of 40 CFR Part 60, Appendix A, and 30 TAC Chapter 101. In addition, the SO₂ concentration on a dry, air-free basis shall be reduced to hourly averages every month. Quality assured (or valid) data must be generated when the No. 2 FCCU Regenerator is operating except during the performance of a daily zero and span check. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted. If the total measurements missed due to monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration exceeds five percent of the time (in minutes) that the No. 2 FCCU Regenerator operated over the previous rolling 12-month period, the measurements missed shall be estimated using engineering judgment and the methods used recorded. Additionally, if the total measurements missed due to monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration exceeds 5 percent of the time (in minutes) that the No. 2 FCCU Regenerator operated over the previous rolling 12-month period, options to increase system reliability to an acceptable value, including a redundant CEMS, may be required by the TCEQ Regional Director. **(PSD)**
12. The concentration of CO in the No. 2 FCCU Regenerator/ESP stack shall be continuously monitored and recorded. The CO CEMS shall be subjected to quality-assurance procedures which shall, as a minimum, included daily zero and span of the analyzer. This monitoring data shall be maintained in accordance with the recordkeeping requirements of 40 CFR Part 60, Appendix A, and 30 TAC Chapter 101. In addition, CO concentrations shall be reduced to hourly averages every month. Quality-assured (or valid) data must be generated when the No. 2 FCCU Regenerator is operating except during the performance of a daily zero and span check. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted. If the total measurements missed due to monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration exceeds 5 percent of the time (in minutes) that the No. 2 FCCU Regenerator operated over the previous rolling 12-month period, the measurements missed shall be estimated using engineering judgment and the methods used recorded. Additionally, if the total measurements missed due to monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration exceeds five percent of the time (in minutes) that the FCCU regenerator operated over the previous rolling 12-month period, options to increase system reliability to an acceptable value, including a redundant CEMS, may be required by the TCEQ Regional Director.
13. The NO_x continuous emission monitor shall be operated in the No. 2 FCCU Regenerator/ESP stack. A daily zero and span calibration shall be included on the monitor. The monitoring data shall

be maintained in accordance with provisions of 40 CFR Part 60, Appendix A, and 30 TAC Chapter 101. For purposes of recordkeeping, the NO_x concentration on a dry, air-free basis shall be reduced to an hourly average every month. Quality-assured (or valid) data must be generated when the No.2 FCCU Regenerator is operating except during the performance of a daily zero and span check. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted. If the total measurements missed due to monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration exceeds 5 percent of the time (in minutes) that the No.2 FCCU Regenerator operated over the previous rolling 12-month period, the measurements missed shall be estimated using engineering judgment and the methods used recorded. Additionally, if the total measurements missed due to monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration exceeds five percent of the time (in minutes) that the No.2 FCCU regenerator operated over the previous rolling 12-month period, options to increase system reliability to an acceptable value, including a redundant CEMS, may be required by the TCEQ Regional Director. **(PSD)**

14. Hourly average coke burn shall be determined per the equation in 40 CFR 60.106 (b)(3) using CEMS for CO, CO₂ and O₂ to determine the FCCU regenerator % concentrations on a dry basis and flow monitors that measure volumetric flow rate of air to the FCCU regenerator and the volumetric exhaust gas rate from the FCCU regenerator in dry standard cubic feet per minute (dscf/min).
 - A. The CEMS shall meet the design and performance specifications, pass the field tests, and meet the installation requirements and the data analysis and reporting requirements specified in the applicable Performance Specification Nos. 2 through 4B, Title 40 Code of Federal Regulation Part 60 (40 CFR Part 60), Appendix B.
 - B. The systems shall be zeroed and spanned daily, and corrective action taken when the 24-hour span drift exceeds two times the amounts specified in the applicable Performance Specification Nos. 2 through 4B, 40 CFR Part 60, Appendix B. Zero and span is not required on weekends and plant holidays if instrument technicians are not normally scheduled on those days.

Each monitor shall be quality-assured at least quarterly using Cylinder Gas Audits (CGA) in accordance with 40 CFR Part 60, Appendix F, Procedure 1, Section 5.1.2, with the following exception: a relative accuracy test audit (RATA) is not required once every four quarters (i.e., four successive quarterly CGA may be conducted). An equivalent quality-assurance method approved by the TCEQ may also be used. Successive quarterly audits shall occur no closer than two months.

All CGA exceedances of +15 percent accuracy indicate that the CEMS is out of control.
 - C. The flow monitors shall be calibrated or have a calibration check performed on an annual basis to meet the following accuracy specifications: the flow monitor shall be $\pm 5.0\%$, temperature monitor shall be $\pm 2.0\%$ at absolute temperature, and pressure monitor shall be ± 5.0 mm Hg.
 - D. All monitoring data and quality-assurance data shall be maintained by the source. Quality-assured (or valid) data must be generated when the FCCU is operating except during the performance of a daily zero and span check. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted. If the total measurements missed due to monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration

exceeds 5 percent of the time (in minutes) that the FCCU Regenerator operated over the previous rolling 12-month period, the measurements missed shall be estimated using engineering judgment and the methods used recorded. Additionally, if the total measurements missed due to monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration exceeds five percent of the time (in minutes) that the FCCU regenerator operated over the previous rolling 12-month period, options to increase system reliability to an acceptable value, including a redundant CEMS, may be required by the TCEQ Regional Director.

15. Piping, Valves, Connectors, Pumps, and Compressors in VOC Service - Intensive Directed Maintenance - 28MID

Except as may be provided for in the special conditions of this permit, the following requirements apply to the above-referenced equipment:

- A. These requirements of paragraphs F and G shall not apply (1) where the VOC has an aggregate partial pressure or vapor pressure of less than 0.044 psia at 68°F or (2) to piping and valves two inches nominal size and smaller or (3) operating pressure is at least 5 kilopascals (0.725 pound per square inch) below ambient pressure. Equipment excluded from this condition shall be identified in a list to be made available upon request.

The exempted components may be identified by one or more of the following methods:

- (1) piping and instrumentation diagram (PID);
 - (2) a written or electronic database or electronic file;
 - (3) color coding;
 - (4) a form of weatherproof identification; or
 - (5) designation of exempted process unit boundaries.
- B. Construction of new and reworked piping, valves, pump systems, agitators, and compressor systems shall conform to applicable American National Standards Institute (ANSI), American Petroleum Institute (API), American Society of Mechanical Engineers (ASME), or equivalent codes.
- C. New and reworked underground process pipelines shall contain no buried valves such that fugitive emission monitoring is rendered impractical. New and reworked buried connectors shall be welded.
- D. To the extent that good engineering practice will permit, new and reworked valves and piping connections shall be so located to be reasonably accessible for leak-checking during plant operation. Difficult-to-monitor and unsafe-to-monitor valves, as defined by 30 TAC Chapter 115, shall be identified-in a list to be made available upon request. The difficult-to-monitor and unsafe-to-monitor valves may be identified by one or more of the methods described in subparagraph A above.
- E. New and reworked piping connections shall be welded or flanged. Screwed connections are permissible only on piping smaller than two-inch diameter. Gas or hydraulic testing of the new and reworked piping connections at no less than operating pressure shall be performed prior to returning the components to service or they shall be monitored for leaks using an approved gas analyzer within 15 days of the components being returned to service. Adjustments shall be made as necessary to obtain leak-free performance. Connectors shall

be inspected by visual, audible, and/or olfactory means at least weekly by operating personnel walk-through.

No later than the next scheduled quarterly monitoring after initial installation or replacement, all new or reworked connections shall be gas-tested or hydraulically-tested at no less than normal operating pressure and adjustments made as necessary to obtain leak-free performance. Connectors shall be inspected by visual, audible, and/or olfactory means at least weekly by operating personnel walk-through.

Each open-ended valve or line shall be equipped with an appropriately sized cap, blind flange, plug, or a second valve to seal the line. Except during sampling, both valves shall be closed. If the removal of a component for repair or replacement results in an open ended line or valve, it is exempt from the requirement to install a cap, blind flange, plug, or second valve for 72 hours. If the repair or replacement is not completed within 72 hours, the permit holder must complete either of the following actions within that time period: the line or valve must have a cap, blind flange, plug, or second valve installed; or the permit holder shall verify that there is no leakage from the open-ended line or valve. The open-ended line or valve shall be monitored on a weekly basis in accordance with the applicable NSR permit condition for fugitive emission monitoring except that a leak is defined as any VOC reading greater than background. Leaks must be repaired within 24 hours or a cap, blind flange, plug, or second valve must be installed on the line or valve. The results of this weekly check and any corrective actions taken shall be recorded.

- F. Accessible valves shall be monitored by leak-checking for fugitive emissions at least quarterly using an approved gas analyzer with a directed maintenance program. Sealless/leakless valves (including, but not limited to, welded bonnet bellows and diaphragm valves) and relief valves equipped with a rupture disc upstream or venting to a control device are not required to be monitored. For valves equipped with rupture discs, a pressure-sensing device shall be installed between the relief valve and rupture disc to monitor disc integrity. All leaking discs shall be replaced at the earliest opportunity but no later than the next process shutdown.

A check of the reading of the pressure-sensing device to verify disc integrity shall be performed weekly and recorded in the unit log or equivalent. Pressure-sensing devices that are continuously monitored with alarms are exempt from recordkeeping requirements specified in this paragraph.

An approved gas analyzer shall conform to requirements listed in Method 21 of 40 CFR Part 60, Appendix A. The gas analyzer shall be calibrated with methane. In addition, the response factor of the instrument for a specific VOC of interest shall be determined and meet the requirements of Section 8 of Method 21. If a mixture of VOCs are being monitored, the response factor shall be calculated for the average composition of the process fluid. A calculated average is not required when all of the compounds in the mixture have a response factor less than 10 using methane, then the instrument may be calibrated with one of the VOC to be measured or any other VOC so long as the instrument has a response factor of less than 10 for each of the VOC to be measured.

A directed maintenance program shall consist of the repair and maintenance of components assisted simultaneously by the use of an approved gas analyzer such that a minimum concentration of leaking VOC is obtained for each component being maintained. A first attempt to repair the leak must be made within 5 days. Records of the first attempt to repair shall be maintained. Replaced components shall be re-monitored within 15 days of being placed back into VOC service. Replaced components shall be re-monitored within 15 days of being placed back into VOC service.

- G. All new and replacement pumps, compressors and agitators shall be equipped with a shaft sealing system that prevents or detects emissions of VOC from the seal. These seal systems need not be monitored and may include (but are not limited to) dual pump seals with barrier fluid at higher pressure than process pressure, seals degassing to vent control systems kept in good working order, or seals equipped with an automatic seal failure detection and alarm system. Submerged pumps or sealless pumps (including, but not limited to, diaphragm, canned, or magnetic-driven pumps) may be used to satisfy the requirements of this condition and need not be monitored.

All other pump, compressor and agitator seals emitting VOC shall be monitored with an approved gas analyzer at least quarterly.

- H. Damaged or leaking valves, connectors, compressor seals, pump seals, and agitator seals found to be emitting VOC in excess of 500 ppmv or found by visual inspection to be leaking (e.g., dripping process fluids) shall be tagged and replaced or repaired. Every reasonable effort shall be made to repair a leaking component, as specified in this paragraph, within 15 days after the leak is found. If the repair of a component would require a unit shutdown that would create more emissions than the repair would eliminate, the repair may be delayed until the next scheduled shutdown. All leaking components which cannot be repaired until a scheduled shutdown shall be identified for such repair by tagging. A listing of all components that qualify for delay of repair shall be maintained on a delay of repair list. The cumulative daily emissions from all components on the delay of repair list shall be estimated by multiplying by 24 the mass emission rate for each component calculated in accordance with the instructions in 30 TAC § 115.782 (c)(1)(B)(i)(II). The calculations of the cumulative daily emissions from all components on the delay of repair list shall be updated within ten days of when the latest leaking component is added to the delay of repair list. When the cumulative daily emission rate of all components on the delay of repair list times the number of days until the next scheduled unit shutdown is equal to or exceeds the total emissions from a unit shutdown as calculated in accordance with 30 TAC § 115.782(c)(1)(B)(i)(I), the TCEQ Regional Manager and any local programs shall be notified and may require early unit shutdown or other appropriate action based on the number and severity of tagged leaks awaiting shutdown. This notification shall be made within 15 days of making this determination.

- I. In lieu of the monitoring frequency specified in paragraph F, valves in gas and light liquid service may be monitored on a semiannual basis if the percent of valves leaking for two consecutive quarterly monitoring periods is less than 0.5 percent.

Valves in gas and light liquid service may be monitored on an annual basis if the percent of valves leaking for two consecutive semiannual monitoring periods is less than 0.5 percent.

If the percent of valves leaking for any semiannual or annual monitoring period is 0.5 percent or greater, the facility shall revert to quarterly monitoring until the facility again qualifies for the alternative monitoring schedules previously outlined in this paragraph.

- J. The percent of valves leaking used in paragraph I shall be determined using the following formula:

$$(V_l + V_s) \times 100/V_t = V_p$$

Where:

V_l = the number of valves found leaking by the end of the monitoring period, either by Method 21 or sight, sound, and smell.

Vs = the number of valves for which repair has been delayed and are listed on the facility shutdown log.

Vt = the total number of valves in the facility subject to the monitoring requirements, as of the last day of the monitoring period, not including nonaccessible and unsafe-to-monitor valves.

Vp = the percentage of leaking valves for the monitoring period.

- K. Records of repairs shall include date of repairs, repair results, justification for delay of repairs, and corrective actions taken for all components. Records of instrument monitoring shall indicate dates and times, test methods and instrument readings. The instrument monitoring record shall include the time that monitoring took place for no less than 95% of the instrument readings recorded. Records of physical inspections shall be noted in the operator's log or equivalent.
 - L. Compliance with the requirements of this condition does not assure compliance with requirements of 30 TAC Chapter 115, an applicable New Source performance Standard, or an applicable National Emission Standards for Hazardous Air Pollutants and does not constitute approval of alternative standards for these regulations.
16. No combustion unit at this facility shall burn fuel oil. Fuel oil shall mean any liquid fossil fuel with a sulfur content of greater than 500 ppm by weight. This condition shall not be construed to prohibit the use of torch oil during FCCU startups.

Incorporated Consent Decree (Special Conditions 17-21) (06/20)

17. The SO₂, O₂, CO, and NO_x CEMS used to demonstrate compliance with the NO_x, SO_x, CO, and O₂ limits in Special Conditions 4, 5 and 6 shall be installed, calibrated and certified in accordance with 40 C.F.R. § 60.13 and Part 60, Appendices A and F and the applicable performance specification test of 40 C.F.R. Part 60, Appendix B. However, in lieu of the requirements of 40 C.F.R. Part 60, Appendix F §§ 5.1.1, 5.1.3, and 5.1.4, the holder of this permit may perform (1) either a Relative Accuracy Audit ("RAA") or a Relative Accuracy Test Audit ("RATA") once every three years for compliance with the limits in Special Conditions 4, 5 and 6; and (2) a Cylinder Gas Audit ("CGA") each calendar quarter in which a RAA or RATA is not performed.
18. The SO₂ 1-hour average and 365-day rolling average emission limits shall apply at all times (including during startup and shutdown) that the FCCU is operating. The SO₂ 7-day rolling average limit of 50 ppmvd at 0% excess oxygen shall not apply during periods of hydrotreater outages including periods of startup and shutdown of the hydrotreater, provided that during any hydrotreater outage CITGO operates the FCCU in a manner consistent with good air pollution control practices and follows its hydrotreater outage plan during such periods. Hydrotreater outage shall mean the period of time during which the FCCU operation is affected as a result of catalyst change-out operations or shutdowns required by ASME pressure vessel requirements or state boiler codes, that prevents the hydrotreater from effectively producing the quantity and quality of feed necessary to achieve established FCCU emission performance.
19. Emissions of particulate matter (front half) from the No.2 FCCU Regenerator/ESP Stack (Emission Point No. [EPN] 31-PR-1) shall not exceed one pound per 1,000 pounds of coke burn on a three-hour average basis per the stack test protocol specified in 40 C.F.R. 60.106(b)(2) using EPA Reference Method 5B or 5F to measure PM emissions.

20. Sampling emissions from the No. 2 FCCU Regenerator Stack shall occur once every five years to measure PM emissions.
21. FCCU Hydrotreater Outage Plan (February 11, 2005, Revision 1), referenced in special condition 18 is as follows;

The current short-term MAERT SO₂ emission limits and the established long-term SO₂ emission limit of 25 ppmvd at 0% excess oxygen on a 365-day rolling average basis will be complied with during hydrotreater outages by taking the following steps:

- A. Purchased gas oil feeds and refinery internal gas oil transfers will be managed such that the combined feed sulfur level and SO₂ reducing catalyst additive rates will always keep the flue gas SO₂ in compliance.
- B. The SO₂ reducing catalyst additive hopper will always be inventoried with SO₂ reducing catalyst additive. An adequate supply of SO₂ reducing catalyst additive tote bins will be maintained in the refinery to replenish the SO₂ reducing catalyst additive hopper as required. NOTE: If future technology developments permit, CITGO may choose to add the SO₂ reducing catalyst additive as a component in the fresh FCC catalyst additions.
- C. If necessary, feedrate will be reduced.
- D. Planned Hydrotreater outages will be conducted concurrently with planned FCCU outages, to the extent practicable. EPA is aware that this element does not apply to unplanned Hydrotreater outages.
- E. During any Hydrotreater outage, CITGO will add SO₂-reducing catalyst additive to both FCC#1 and FCC#2 at 10.0% of the total daily catalyst addition rate.
- F. CITGO will begin adding catalyst additive at the maximum additive rate 2 weeks (14 days) prior to a known or planned Hydrotreater outage when possible. In the event of an unplanned outage, CITGO will reach the maximum additive rate within 24 hours of the start of the Hydrotreater outage. In any event, if the refinery is able to meet the short-term limit for NO_x or SO₂, CITGO does not need to comply with any of the pollutant specific terms of the Hydrotreater outage plan.
- G. Upon conclusion of each Hydrotreater outage, CITGO will submit a report to EPA identifying the periods of time that the Hydrotreater outage plan was applicable rather than the short-term limit. This report will describe, in detail, the steps taken to comply with this Hydrotreater outage plan for these periods. The report will contain all data (compiled on a daily average basis) including the concentrations of NO_x and SO₂ necessary to document that each requirement of the plans were fully implemented.

Compliance with this Hydrotreater plan does not alleviate CITGO from compliance with the requirements of the Consent Decree outside of those specifically identified.

Date: June 18, 2020

Emission Sources - Maximum Allowable Emission Rates

Permit Number 9604A & PSDTX653M1

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
31-PR-1	No.2 FCCU Regenerator/ESP Stack	VOC	9.0	41.4
		NO _x (PSD)	169.8	81.2
		CO	287.2	247.3
		SO ₂ (PSD)	262.8	141.4
		PM	94.9	408.6
		PM ₁₀	94.9	408.6
		H ₂ SO ₄ (PSD)	47.5	204.3
642	Tank 1029	VOC	3.20	9.00
643	Tank 1030	VOC	4.63	12.88
644	Tank 1031	VOC	5.00	14.11
645	Tank 1032	VOC	0.19	0.65
667A	Tank 1016	VOC	3.69	8.47
692	Tank 201	VOC	1.87	4.04
693	Tank 202	VOC	1.87	4.04
694	Tank 211	VOC	1.59	3.27
695	Tank 212	VOC	1.59	3.27
696	Tank 221	VOC	1.65	3.72
697	Tank 222	VOC	1.56	3.47
698	Tank 223	VOC	1.62	3.53
699	Tank 224	VOC	1.59	2.72
704	Tank 301	VOC	3.68	10.25
705	Tank 302	VOC	3.77	10.25
706	Tank 401	VOC	3.69	10.50
707	Tank 402	VOC	2.05	5.39
708	Tank 403	VOC	2.05	5.39
767	Tank 56	VOC	2.14	4.11
768	Tank 57	VOC	2.03	5.11

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
774	Tank 82	VOC	5.67	15.89
775	Tank 83	VOC	5.67	15.89
3103	Tank 3103	VOC	3.80	0.28
F341	Number 2 FCCU Fugitives (5)	VOC	34.73	152.12
F343	Number 2 FCCU Spent Catalyst Truck Loading	PM	0.12	0.01
		PM ₁₀	0.12	0.01

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name. For fugitive sources, use area name or fugitive source name.

(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1

NO_x - total oxides of nitrogen

SO₂ - sulfur dioxide

PM - total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented

PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented

PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter

CO - carbon monoxide

H₂SO₄ - sulfuric acid PM collected in back-half of PM test collection device

(4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.

(5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.

Date: July 3, 2014