

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
NRG Texas Power LLC

AUTHORIZING THE OPERATION OF
Cedar Bayou Electric Generating Station
Fossil Fuel Electric Power Generation

LOCATED AT
Chambers County, Texas
Latitude 29° 44' 54" Longitude 94° 55' 38"
Regulated Entity Number: RN100825371

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site, emission units and affected source listed in this permit. Operations of the site, emission units and affected source listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site, emission units and affected source authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site, emission units and affected source.

Permit No: 072 Issuance Date: November 24, 2021

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions:	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements	9
New Source Review Authorization Requirements	10
Compliance Requirements.....	11
Risk Management Plan	12
Protection of Stratospheric Ozone	12
Temporary Fuel Shortages (30 TAC § 112.15)	12
Permit Location	13
Permit Shield (30 TAC § 122.148)	13
Acid Rain Permit Requirements	13
Acid Rain Unit Exemptions	17
Cross-State Air Pollution Rule (CSAPR) Trading Program Requirements	17
Cross-State Air Pollution Rule (CSAPR) Trading Program Unit Exemptions	23
Attachments	24
Applicable Requirements Summary.....	25
Additional Monitoring Requirements	47
Permit Shield.....	61
New Source Review Authorization References	66
Appendix A.....	70
Acronym List	71

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
 - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.

- E. Emission units subject to 40 CFR Part 63, Subpart ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.
- F. For the purpose of generating emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 1 (Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
 - (i) Title 30 TAC § 101.302 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.303 (relating to Emission Reduction Credit Generation Certification)
 - (iii) Title 30 TAC § 101.304 (relating to Mobile Emission Reduction Credit Generation and Certification)
 - (iv) Title 30 TAC § 101.309 (relating to Emission Credit Banking and Trading)
 - (v) The terms and conditions by which the emission limits are established to generate the reduction credit are applicable requirements of this permit
- G. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 2 (Emissions Banking and Trading of Allowances) Requirements for an electric generating facility authorized under 30 TAC Chapter 116, Subchapter I:
 - (i) Title 30 TAC § 101.332 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.333 (relating to Allocation of Allowances)
 - (iii) Title 30 TAC § 101.334 (relating to Allowance Deductions)
 - (iv) Title 30 TAC § 101.335 (relating to Allowance Banking and Trading)
 - (v) Title 30 TAC § 101.336 (relating to Emission Monitoring and Compliance Demonstration and Reporting)
 - (vi) The terms and conditions by which the emission limits are established to meet the quantity of allowances for the electric generating facility are applicable requirements of this permit
- H. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 3 (Mass Emission Cap and Trade Program) Requirements:
 - (i) Title 30 TAC § 101.352 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.353 (relating to Allocation of Allowances)
 - (iii) Title 30 TAC § 101.354 (relating to Allowance Deductions)
 - (iv) Title 30 TAC § 101.356 (relating to Allowance Banking and Trading)
 - (v) Title 30 TAC § 101.359 (relating to Reporting)
 - (vi) Title 30 TAC § 101.360 (relating to Level of Activity Certification)

- (vii) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit
- I. For the purpose of generating discrete emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 4 (Discrete Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
 - (i) Title 30 TAC § 101.372 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.373 (relating to Discrete Emission Reduction Credit Generation and Certification)
 - (iii) Title 30 TAC § 101.374 (relating to Mobile Discrete Emission Reduction Credit Generation and Certification)
 - (iv) Title 30 TAC § 101.378 (relating to Discrete Emission Credit Banking and Trading)
 - (v) The terms and conditions by which the emission limits are established to generate the discrete reduction credit are applicable requirements of this permit
- 2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
 - A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
- 3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
 - A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity

averaged over a six minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:

- (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(1)(E)
- (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
- (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the "Applicable Requirements Summary" attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:
 - (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
 - (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
 - (3) Records of all observations shall be maintained.
 - (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet

prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(5) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
 - (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.

(3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A).
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

C. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)
- (iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:

- (1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.
 - (3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
 - (4) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- D. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
- E. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).

- F. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
 - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)
 - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
- G. Outdoor burning, as stated in 30 TAC § 111.201, shall not be authorized unless the following requirements are satisfied:
 - (i) Title 30 TAC § 111.205 (relating to Exception for Fire Training)
 - (ii) Title 30 TAC § 111.207 (relating to Exception for Recreation, Ceremony, Cooking, and Warmth)
 - (iii) Title 30 TAC § 111.219 (relating to General Requirements for Allowable Outdoor Burning)
 - (iv) Title 30 TAC § 111.221 (relating to Responsibility for Consequences of Outdoor Burning)
- 4. For storage vessels maintaining working pressure as specified in 30 TAC Chapter 115, Subchapter B, Division 1: Storage of Volatile Organic Compounds, the permit holder shall comply with the requirements of 30 TAC § 115.112(e)(1).
- 5. Permit holder shall comply with the following 30 TAC Chapter 115, Subchapter C requirements:
 - A. When filling stationary gasoline storage vessels (Stage I) for motor vehicle fuel dispensing facilities, constructed prior to November 15, 1992, with transfers to stationary storage tanks located at a facility which has dispensed no more than 10,000 gallons of gasoline in any calendar month after January 1, 1991, the permit holder shall comply with the following requirements specified in 30 TAC Chapter 115, Subchapter C:
 - (i) Title 30 TAC § 115.222(3) (relating to Control Requirements), as it applies to liquid gasoline leaks, visible vapors, or significant odors
 - (ii) Title 30 TAC § 115.222(6) (relating to Control Requirements)
 - (iii) Title 30 TAC § 115.224(1) (relating to Inspection Requirements), as it applies to liquid gasoline leaks, visible vapors, or significant odors
 - (iv) Title 30 TAC § 115.226(2)(B) (relating to Recordkeeping Requirements)
- 6. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
 - A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
 - B. Title 40 CFR § 60.8 (relating to Performance Tests)

- C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
 - F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
7. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
8. For each gasoline dispensing facility, with a throughput of less than 10,000 gallons per month as specified in 40 CFR Part 63, Subpart CCCCCC, the permit holder shall comply with the following requirements (Title 30 TAC, Subchapter C, § 113.1380 incorporated by reference):
- A. Title 40 CFR § 63.11111(e), for records of monthly throughput
 - B. Title 40 CFR § 63.11111(i), for compliance due to increase of throughput
 - C. Title 40 CFR § 63.11113(c), for compliance due to increase of throughput
 - D. Title 40 CFR § 63.11115(a), for operation of the source
 - E. Title 40 CFR § 63.11116(a) and (a)(1) - (4), for work practices
 - F. Title 40 CFR § 63.11116(b), for records availability
 - G. Title 40 CFR § 63.11116(d), for portable gasoline containers
9. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

Additional Monitoring Requirements

10. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent

with the averaging time or minimum frequency specified in the “Periodic Monitoring Summary,” for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

11. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule (including the terms, conditions, monitoring, recordkeeping, and reporting identified in registered PBRs and permits by rule identified in the PBR Supplemental Tables dated October 3, 2023 in the application for project 35676), standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
 - A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
12. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
13. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit’s compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
14. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
 - A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
 - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
 - C. Applicable requirements of 30 TAC § 116.617 for Pollution Control Projects based on the information contained in the registration application.
 - D. Applicable requirements of 30 TAC § 117.550 for Pollution Control Projects based on the information contained in the registration application.
 - E. Requirements of the non-rule Air Quality Standard Permit for Pollution Control Projects

Compliance Requirements

15. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
16. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:
 - A. The permit holder shall comply with the compliance schedules and submit written notification to the Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
 - (i) For electric utilities in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9120
17. Use of Emission Credits to comply with applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) Offsets for Title 30 TAC Chapter 116
 - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)
 - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
 - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)
18. Use of Discrete Emission Credits to comply with the applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115

- (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
- (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Risk Management Plan

19. For processes subject to 40 CFR Part 68 and specified in 40 CFR § 68.10, the permit holder shall comply with the requirements of the Accidental Release Prevention Provisions in 40 CFR Part 68. The permit holder shall submit to the appropriate agency either a compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR § 68.10(a), or as part of the compliance certification submitted under this permit, a certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of a risk management plan.

Protection of Stratospheric Ozone

20. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
- A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.
 - B. The permit holder shall comply with 40 CFR Part 82, Subpart H related to Halon Emissions Reduction requirements as specified in 40 CFR § 82.250 - § 82.270 and the applicable Part 82 Appendices.

Temporary Fuel Shortages (30 TAC § 112.15)

21. The permit holder shall comply with the following 30 TAC Chapter 112 requirements:

- A. Title 30 TAC § 112.15 (relating to Temporary Fuel Shortage Plan Filing Requirements)
- B. Title 30 TAC § 112.16(a), (a)(1), and (a)(2)(B) - (C) (relating to Temporary Fuel Shortage Plan Operating Requirements)
- C. Title 30 TAC § 112.17 (relating to Temporary Fuel Shortage Plan Notification Procedures)
- D. Title 30 TAC § 112.18 (relating to Temporary Fuel Shortage Plan Reporting Requirements)

Permit Location

- 22. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

- 23. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Acid Rain Permit Requirements

- 24. For units 1 and 2 (identified in the Certificate of Representation as units CBY1 and CBY2), located at the affected source identified by ORIS/Facility code 3460, the designated representative and the owner or operator, as applicable, shall comply with the following Acid Rain Permit requirements.
 - A. General Requirements
 - (i) Under 30 TAC § 122.12(1) and 40 CFR Part 72, the Acid Rain Permit requirements contained here are a separable portion of the Federal Operating Permit (FOP) and have an independent public comment process which may be separate from, or combined with the FOP.
 - (ii) The owner and operator shall comply with the requirements of 40 CFR Part 72 and 40 CFR Part 76. Any noncompliance with the Acid Rain Permit will be considered noncompliance with the FOP and may be subject to enforcement action.
 - (iii) The owners and operators of the affected source shall operate the source and the unit in compliance with the requirements of this Acid Rain Permit and all other applicable State and federal requirements.
 - (iv) The owners and operators of the affected source shall comply with the General Terms and Conditions of the FOP that incorporates this Acid Rain Permit.

- (v) The term for the Acid Rain permit shall commence with the issuance of the FOP that incorporates the Acid Rain permit and shall be run concurrent with the remainder of the term of the FOP. Renewal of the Acid Rain permit shall coincide with the renewal of the FOP that incorporates the Acid Rain permit and subsequent terms shall be no more than five years from the date of renewal of the FOP and run concurrent with the permit term of the FOP.

B. Monitoring Requirements

- (i) The owners and operators, and the designated representative, of the affected source and each affected unit at the source shall comply with the monitoring requirements contained in 40 CFR Part 75.
- (ii) The emissions measurements recorded and reported in accordance with 40 CFR Part 75 and any other credible evidence shall be used to determine compliance by the affected source with the acid rain emissions limitations and emissions reduction requirements for SO₂ and NO_x under the ARP.
- (iii) The requirements of 40 CFR Part 75 shall not affect the responsibility of the owners and operators to monitor emission of other pollutants or other emissions characteristics at the unit under other applicable requirements of the FCAA Amendments (42 U.S.C. 7401, as amended November 15, 1990) and other terms and conditions of the operating permit for the source.

C. SO₂ emissions requirements

- (i) The owners and operators of each source and each affected unit at the source shall comply with the applicable acid rain emissions limitations for SO₂.
- (ii) As of the allowance transfer deadline the owners and operators of the affected source and each affected unit at the source shall hold, in the unit's compliance subaccount, allowances in an amount not less than the total annual emissions of SO₂ for the previous calendar year.
- (iii) Each ton of SO₂ emitted in excess of the acid rain emissions limitations for SO₂ shall constitute a separate violation of the FCAA amendments.
- (iv) An affected unit shall be subject to the requirements under (i) and (ii) of the SO₂ emissions requirements as follows:
 - (1) Starting January 1, 2000, an affected unit under 40 CFR § 72.6(a)(2); or
 - (2) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR Part 75, an affected unit under 40 CFR § 72.6(a)(3).
- (v) Allowances shall be held in, deducted from, or transferred into or among Allowance Tracking System accounts in accordance with the requirements of the ARP.
- (vi) An allowance shall not be deducted, for compliance with the requirements of this permit, in a calendar year before the year for which the allowance was allocated.
- (vii) An allowance allocated by the EPA Administrator or under the ARP is a limited authorization to emit SO₂ in accordance with the ARP. No provision of the ARP,

Acid Rain permit application, this Acid Rain Permit, or an exemption under 40 CFR §§ 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.

- (viii) An allowance allocated by the EPA Administrator under the ARP does not constitute a property right.

D. NO_x Emission Requirements

- (i) The owners and operators of the source and each affected unit at the source shall comply with the applicable acid rain emissions limitations for NO_x under 40 CFR Part 76.

E. Excess emissions requirements for SO₂ and NO_x.

- (i) The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77.

- (ii) If an affected source has excess emissions in any calendar year shall, as required by 40 CFR Part 77:

- (1) Pay, without demand, the penalty required and pay, upon demand, the interest on that penalty.
- (2) Comply with the terms of an approved offset plan.

F. Recordkeeping and Reporting Requirements

- (i) Unless otherwise provided, the owners and operators of the affected source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the permitting authority or the EPA Administrator.

- (1) The certificate of representation for the designated representative for the source and each affected unit and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR § 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative.
- (2) All emissions monitoring information, in accordance with 40 CFR Part 75, provided that to the extent that 40 CFR Part 75 provides for a 3-year period for recordkeeping (rather than a five-year period cited in 30 TAC § 122.144), the 3-year period shall apply.
- (3) Copies of all reports, compliance certifications, and other submissions and all records made or required under the ARP or relied upon for compliance certification.
- (4) Copies of all documents used to complete an acid rain permit application and any other submission under the ARP or to demonstrate compliance with the requirements of the ARP.

- (ii) The designated representative of an affected source and each affected unit at the source shall submit the reports required under the ARP including those under 40 CFR Part 72, Subpart I and 40 CFR Part 75.

G. Liability

- (i) Any person who knowingly violates any requirement or prohibition of the ARP, a complete acid rain permit application, an acid rain permit, or a written exemption under 40 CFR §§ 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to FCAA § 113(c).
- (ii) Any person who knowingly makes a false, material statement in any record, submission, or report under the ARP shall be subject to criminal enforcement pursuant to FCAA § 113(c) and 18 U.S.C. 1001.
- (iii) No permit revision shall excuse any violation of the requirements of the ARP that occurs prior to the date that the revision takes effect.
- (iv) The affected source and each affected unit shall meet the requirements of the ARP contained in 40 CFR Parts 72 through 78.
- (v) Any provision of the ARP that applies to an affected source or the designated representative of an affected source shall also apply to the owners and operators of such source and of the affected units at the source.
- (vi) Any provision of the ARP that applies to an affected unit (including a provision applicable to the DR of an affected unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR § 72.44 (Phase II repowering extension plans) and 40 CFR § 76.11 (NO_x averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR §§ 75.16, 75.17, and 75.18), the owners and operators and the DR of one affected unit shall not be liable for any violation by any other affected unit of which they are not owners or operators or the DR and that is located at a source of which they are not owners or operators or the DR.
- (vii) Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or DR of such source or unit, shall be a separate violation of the FCAA Amendments.

H. Effect on other authorities. No provision of the ARP, an acid rain permit application, an acid rain permit, or an exemption under 40 CFR §§ 72.7 or 72.8 shall be construed as:

- (i) Except as expressly provided in Title IV of the FCAA Amendments, exempting or excluding the owners and operators and, to the extent applicable, the DR of an affected source or affected unit from compliance with any other provision of the FCAA Amendments, including the provisions of Title I of the FCAA Amendments relating to applicable National Ambient Air Quality Standards or State Implementation Plans.
- (ii) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the FCAA Amendments.

- (iii) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law.
 - (iv) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
 - (v) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established.
- I. The number of SO₂ allowances allocated by the EPA in 40 CFR Part 73 is enforceable only by the EPA Administrator.

Acid Rain Unit Exemptions

25. As reference only information, CBY3 has received an acid rain unit exemption and is not incorporated into an Acid Rain Permit.

Cross-State Air Pollution Rule (CSAPR) Trading Program Requirements

26. For units 1 and 2 (identified in the Certificate of Representation as units CBY1 and CBY2), located at the site identified by Plant code/ORIS/Facility code 3460 the designated representative and the owner or operator, as applicable, shall comply with the following CSAPR requirements.

A. General Requirements

- (i) The owners and operators of the CSAPR NO_x Ozone Season Group 2 source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall operate the source and the unit in compliance with the requirements of the CSAPR NO_x Ozone Season Group 2 Trading Program and all other applicable State and federal requirements.
- (ii) The owners and operators of the CSAPR NO_x Ozone Season Group 2 source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall comply with the requirements of 40 CFR Part 97, Subpart EEEEE for CSAPR NO_x Ozone Season Group 2 Trading Program, and with the General Terms and Conditions of the Federal Operating Permit (FOP) that incorporates the CSAPR requirements.

B. Description of CSAPR Monitoring Provisions

- (i) The CSAPR subject unit(s), and the unit-specific monitoring provisions at this source, are identified in the following paragraph(s). These unit(s) are subject to the requirements for the CSAPR NO_x Ozone Season Group 2 Trading Program.
 - (1) For units 1 and 2, the owners and operators shall comply with the continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart H for NO_x, and with the excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D for heat input.
- (ii) The above description of the monitoring used by a unit does not change, create an exemption from, or otherwise affect the monitoring, recordkeeping, and reporting requirements applicable to the unit under 40 CFR §§ 97.830 through

97.835 (CSAPR NO_x Ozone Season Group 2 Trading Program). The monitoring, recordkeeping and reporting requirements applicable to each unit are included below in the standard conditions for the applicable CSAPR trading program.

- (iii) Owners and operators must submit to the Administrator a monitoring plan for each unit in accordance with 40 CFR §§ 75.53, 75.62 and 75.73, as applicable. The monitoring plan for each unit is available at the EPA's website at <https://www.epa.gov/airmarkets/clean-air-markets-monitoring-plans-part-75-sources>.
- (iv) Owners and operators that want to use an alternative monitoring system must submit to the Administrator a petition requesting approval of the alternative monitoring system in accordance with 40 CFR Part 75, Subpart E and 40 CFR § 75.66 and § 97.835 (CSAPR NO_x Ozone Season Group 2 Trading Program). The Administrator's response approving or disapproving any petition for an alternative monitoring system is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
- (v) Owners and operators that want to use an alternative to any monitoring, recordkeeping, or reporting requirement under 40 CFR §§ 97.830 through 97.834 (CSAPR NO_x Ozone Season Group 2 Trading Program) must submit to the Administrator a petition requesting approval of the alternative in accordance with 40 CFR § 75.66 and § 97.835 (CSAPR NO_x Ozone Season Group 2 Trading Program). The Administrator's response approving or disapproving any petition for an alternative to a monitoring, recordkeeping, or reporting requirement is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
- (vi) The descriptions of monitoring applicable to the unit(s) included above meet the requirement of 40 CFR §§ 97.830 through 97.834 (CSAPR NO_x Ozone Season Group 2 Trading Program), and therefore procedures for minor permit revisions, in accordance with 30 TAC § 122.217, may be used to add or change this unit's monitoring system description.

27. CSAPR NO_x Ozone Season Group 2 Trading Program Requirements (40 CFR § 97.806)

A. Designated representative requirements

- (i) The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR §§ 97.813 through 97.818.

B. Emissions monitoring, reporting, and recordkeeping requirements

- (i) The owners and operators, and the designated representative, of each CSAPR NO_x Ozone Season Group 2 source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR § 97.830 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), § 97.831 (initial monitoring system certification and recertification procedures), § 97.832 (monitoring system out-of-control periods), § 97.833 (notifications concerning monitoring), § 97.834 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and §

97.835 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).

- (ii) The emissions data determined in accordance with 40 CFR § 97.830 through § 97.835 and any other credible evidence shall be used to calculate allocations of CSAPR NO_x Ozone Season Group 2 allowances under 40 CFR §§ 97.811(a)(2) and (b) and § 97.812 and to determine compliance with the CSAPR NO_x Ozone Season Group 2 emissions limitation and assurance provisions under paragraph C. below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR §§ 97.830 through 97.835 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

C. NO_x emissions requirements

(i) CSAPR NO_x Ozone Season Group 2 emissions limitation

- (1) As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NO_x Ozone Season Group 2 source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall hold, in the source's compliance account, CSAPR NO_x Ozone Season Group 2 allowances available for deduction for such control period under 40 CFR § 97.824(a) in an amount not less than the tons of total NO_x emissions for such control period from all CSAPR NO_x Ozone Season Group 2 units at the source.
- (2) If total NO_x emissions during a control period in a given year from the CSAPR NO_x Ozone Season Group 2 units at a CSAPR NO_x Ozone Season Group 2 source are in excess of the CSAPR NO_x Ozone Season Group 2 emissions limitation set forth in paragraph C.(i)(1) above, then:
 - (a) The owners and operators of the source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall hold the CSAPR NO_x Ozone Season Group 2 allowances required for deduction under 40 CFR § 97.824(d); and
 - (b) The owners and operators of the source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart EEEEE and the Clean Air Act.

(ii) CSAPR NO_x Ozone Season Group 2 assurance provisions

- (1) If total NO_x emissions during a control period in a given year from all CSAPR NO_x Ozone Season Group 2 units at CSAPR NO_x Ozone Season Group 2 sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO_x emissions during such control period

exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) CSAPR NO_x Ozone Season Group 2 allowances available for deduction for such control period under 40 CFR § 97.825(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR § 97.825(b), of multiplying -

- (a) The quotient of the amount by which the common designated representative's share of such NO_x emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such NO_x emissions exceeds the respective common designated representative's assurance level; and
 - (b) The amount by which total NO_x emissions from all CSAPR NO_x Ozone Season Group 2 units at CSAPR NO_x Ozone Season Group 2 sources in the state for such control period exceed the state assurance level.
- (2) The owners and operators shall hold the CSAPR NO_x Ozone Season Group 2 allowances required under paragraph C.(ii)(1) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
- (3) Total NO_x emissions from all CSAPR NO_x Ozone Season Group 2 units at CSAPR NO_x Ozone Season Group 2 sources in the state during a control period in a given year exceed the state assurance level if such total NO_x emissions exceed the sum, for such control period, of the state NO_x Ozone Season Group 2 trading budget under 40 CFR § 97.810(a) and the state's variability limit under 40 CFR § 97.810(b).
- (4) It shall not be a violation of 40 CFR Part 97, Subpart EEEEE or of the Clean Air Act if total NO_x emissions from all CSAPR NO_x Ozone Season Group 2 units at CSAPR NO_x Ozone Season Group 2 sources in the state during a control period exceed the state assurance level or if a common designated representative's share of total NO_x emissions from the CSAPR NO_x Ozone Season Group 2 units at CSAPR NO_x Ozone Season Group 2 sources in the state during a control period exceeds the common designated representative's assurance level.
- (5) To the extent the owners and operators fail to hold CSAPR NO_x Ozone Season Group 2 allowances for a control period in a given year in accordance with paragraphs C.(ii)(1) through (3) above,
 - (a) The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
 - (b) Each CSAPR NO_x Ozone Season Group 2 allowance that the owners and operators fail to hold for such control period in

accordance with paragraphs C.(ii)(1) through (3) above and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart EEEEE and the Clean Air Act.

- (iii) Compliance periods
 - (1) A CSAPR NO_x Ozone Season Group 2 unit shall be subject to the requirements under paragraph C.(i) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR § 97.830(b) and for each control period thereafter.
 - (2) A CSAPR NO_x Ozone Season Group 2 unit shall be subject to the requirements under paragraph C.(ii) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR § 97.830(b) and for each control period thereafter.
- (iv) Vintage of allowances held for compliance
 - (1) A CSAPR NO_x Ozone Season Group 2 allowance held for compliance with the requirements under paragraph C.(i)(1) above for a control period in a given year must be a CSAPR NO_x Ozone Season Group 2 allowance that was allocated for such control period or a control period in a prior year.
 - (2) A CSAPR NO_x Ozone Season Group 2 allowance held for compliance with the requirements under paragraphs C.(i)(2)(a) and (ii)(1) through (3) above for a control period in a given year must be a CSAPR NO_x Ozone Season Group 2 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
- (v) Allowance Management System requirements. Each CSAPR NO_x Ozone Season Group 2 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart EEEEE.
- (vi) Limited authorization. A CSAPR NO_x Ozone Season Group 2 allowance is a limited authorization to emit one ton of NO_x during the control period in one year. Such authorization is limited in its use and duration as follows:
 - (1) Such authorization shall only be used in accordance with the CSAPR NO_x Ozone Season Group 2 Trading Program; and
 - (2) Notwithstanding any other provision of 40 CFR Part 97, Subpart EEEEE, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (vii) Property right. A CSAPR NO_x Ozone Season Group 2 allowance does not constitute a property right.

D. FOP revision requirements

- (i) No FOP revision shall be required for any allocation, holding, deduction, or transfer of CSAPR NO_x Ozone Season Group 2 allowances in accordance with 40 CFR Part 97, Subpart EEEEE.
- (ii) This FOP incorporates the CSAPR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR §§ 97.830 through 97.835, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, subpart H), an excepted monitoring system (pursuant to 40 CFR Part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR § 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, subpart E). Therefore the Description of CSAPR Monitoring Provisions for CSAPR subject unit(s) may be added to, or changed, in this FOP using procedures for minor permit revisions in accordance with 30 TAC § 122.217.

E. Additional recordkeeping and reporting requirements

- (i) Unless otherwise provided, the owners and operators of each CSAPR NO_x Ozone Season Group 2 source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
 - (1) The certificate of representation under 40 CFR § 97.816 for the designated representative for the source and each CSAPR NO_x Ozone Season Group 2 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR § 97.816 changing the designated representative.
 - (2) All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart EEEEE.
 - (3) Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the CSAPR NO_x Ozone Season Group 2 Trading Program.
- (ii) The designated representative of a CSAPR NO_x Ozone Season Group 2 source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall make all submissions required under the CSAPR NO_x Ozone Season Group 2 Trading Program, except as provided in 40 CFR § 97.818. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under 30 TAC § 122.165.

F. Liability

- (i) Any provision of the CSAPR NO_x Ozone Season Group 2 Trading Program that applies to a CSAPR NO_x Ozone Season Group 2 source or the designated representative of a CSAPR NO_x Ozone Season Group 2 source shall also apply

to the owners and operators of such source and of the CSAPR NO_x Ozone Season Group 2 units at the source.

- (ii) Any provision of the CSAPR NO_x Ozone Season Group 2 Trading Program that applies to a CSAPR NO_x Ozone Season Group 2 unit or the designated representative of a CSAPR NO_x Ozone Season Group 2 unit shall also apply to the owners and operators of such unit.

G. Effect on other authorities

- (i) No provision of the CSAPR NO_x Ozone Season Group 2 Trading Program or exemption under 40 CFR § 97.805 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a CSAPR NO_x Ozone Season Group 2 source or CSAPR NO_x Ozone Season Group 2 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

Cross-State Air Pollution Rule (CSAPR) Trading Program Unit Exemptions

- 28. As reference-only information, CBY3 has received a CSAPR retired unit exemption under 40 CFR Part 97 (CSAPR NO_x and SO₂ Trading Programs) and is not subject to CSAPR Requirements.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Applicable Requirements Summary

Unit Summary 26

Applicable Requirements Summary 29

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (§ 122.144), Reporting Terms and Conditions (§ 122.145), and Compliance Certification Terms and Conditions (§ 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
A-120-1	STORAGE TANKS/VESSELS	N/A	R5112-2	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
AB1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R7UT-1	30 TAC Chapter 117, Utility Electric Generation	Annual Heat Input = Annual heat input is greater than 2.2(10 ¹¹) Btu/yr.
AB1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R7UT-2	30 TAC Chapter 117, Utility Electric Generation	Annual Heat Input = Annual heat input is less than or equal to 2.2(10 ¹¹) Btu/yr.
ACT1	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
ACT2	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
CBAB	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
CBY1EDG	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-3	30 TAC Chapter 111, Visible Emissions	No changing attributes.
CBY1EDG	SRIC ENGINES	N/A	63ZZZZ-01	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
CBY2EDG	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-3	30 TAC Chapter 111, Visible Emissions	No changing attributes.
CBY2EDG	SRIC ENGINES	N/A	63ZZZZ-01	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
CBYUNLOAD	LOADING/UNLOADING OPERATIONS	N/A	R5212-1	30 TAC Chapter 115, Loading and Unloading of	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				VOC	
GRP-AUXB	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	CBAB2N, CBAB3N	R7UT-1	30 TAC Chapter 117, Utility Electric Generation	Annual Heat Input = Annual heat input is greater than 2.2(10 ¹¹) Btu/yr., NOx Monitoring System = Continuous emission monitoring system.
GRP-AUXB	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	CBAB2N, CBAB3N	R7UT-2	30 TAC Chapter 117, Utility Electric Generation	Annual Heat Input = Annual heat input is less than or equal to 2.2(10 ¹¹) Btu/yr., NOx Monitoring System = Not using a CEMS, PEMS, monitoring in accordance with 40 CFR Part 75, Appendix E, or the maximum block one hour emission rate.
GRP-AUXB	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	CBAB2N, CBAB3N	60Db-1	40 CFR Part 60, Subpart Db	No changing attributes.
GRP-B1-2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	1, 2	R1153-1	30 TAC Chapter 111, Nonagricultural Processes	No changing attributes.
GRP-B1-2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	1, 2	REG2-1	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
GRP-B1-2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	1, 2	R7UT-01	30 TAC Chapter 117, Utility Electric Generation	Fuel Type #1 = Natural gas.
GRP-B1-2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	1, 2	R7UT-02	30 TAC Chapter 117, Utility Electric Generation	Fuel Type #1 = Natural gas., Fuel Type #2 = Fuel oil.
GRP-B1-2	BOILERS/STEAM GENERATORS/STEAM	1, 2	R7UT-03	30 TAC Chapter 117, Utility Electric Generation	Fuel Type #1 = Fuel oil.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	GENERATING UNITS				
GRP-B1-2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	1, 2	60D-1	40 CFR Part 60, Subpart D	D-Series Fuel Type #1 = Natural gas.
GRP-B1-2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	1, 2	60D-2	40 CFR Part 60, Subpart D	D-Series Fuel Type #2 = Liquid fossil fuel., D-Series Fuel Type #1 = Natural gas.
GRP-B1-2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	1, 2	60D-3	40 CFR Part 60, Subpart D	D-Series Fuel Type #1 = Liquid fossil fuel.
GRP-B1-2S	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	CB1, CB2	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRP-CB-LOV	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	CB1-LOV, CB2-LOV	R1111-3	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRPTANK1	STORAGE TANKS/VESSELS	A-103-1, A-103-2, A-103-5, A-103-6, A-105-1	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPTANK2	STORAGE TANKS/VESSELS	A-103-7, A-105-2	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPTANK3	STORAGE TANKS/VESSELS	A-114-1, A-115-1	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
S1	VOLATILE ORGANIC COMPOUND WATER SEPARATORS	N/A	R5131-1	30 TAC Chapter 115, Water Separation	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
A-120-1	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None
AB1	EU	R7UT-1	CO	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(1) § 117.1210(b) § 117.1210(b)(1)(A)	No person shall allow the discharge into the atmosphere from any unit subject to the NO _x emission specifications specified in subsection (a) of this section, carbon monoxide (CO) emissions in excess of 400 parts per million by volume (ppmv) at 3.0% oxygen (O ₂), dry, or alternatively, 0.30 lb/MMBtu heat input for gas-fired auxiliary steam boilers.	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(b) § 117.1240(f) § 117.1240(f)(2) § 117.1240(i) § 117.8120	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
AB1	EU	R7UT-1	NO _x	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(a)(2) § 117.1210(c)(4) § 117.1240(l) § 117.1240(l)(2) § 117.1240(o) § 117.1240(o)(3)	Emission specifications for the Mass Emission Cap and Trade Program. The owner or operator of each auxiliary steam boiler shall ensure that emissions of nitrogen	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(a) § 117.1240(f) § 117.1240(f)(2)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) [G]§ 117.1240(o)(2) § 117.1245(b) § 117.1245(b)(1) § 117.1256 § 117.8010

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						oxides (NO _x) do not exceed 0.030, in pounds per million British thermal units (lb/MMBtu) heat input, on the basis of daily and 30-day averaging periods as specified in §117.1220 of this title, and as specified in the mass emissions cap and trade program of Chapter 101, Subchapter H, Division 3 of this title.	§ 117.1240(i) § 117.1240(n) § 117.1240(o)(1) [G]§ 117.1240(o)(2)		[G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
AB1	EU	R7UT-2	CO	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(1) § 117.1210(b) § 117.1210(b)(1)(A)	No person shall allow the discharge into the atmosphere from any unit subject to the NO _x emission specifications specified in subsection (a) of this section, carbon monoxide (CO) emissions in excess of 400 parts per million by volume (ppmv) at 3.0% oxygen (O ₂), dry, or alternatively, 0.30 lb/MMBtu heat input for gas-fired auxiliary steam boilers.	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(b) § 117.1240(f) § 117.1240(f)(2) § 117.1240(i) § 117.8120	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
AB1	EU	R7UT-2	NO _x	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(a)(2) § 117.1210(c)(4) § 117.1240(l) § 117.1240(l)(2) § 117.1240(o) § 117.1240(o)(3)	Emission specifications for the Mass Emission Cap and Trade Program. The owner or operator of each auxiliary steam boiler shall ensure that emissions of nitrogen oxides (NO _x) do not exceed 0.030, in pounds per million British thermal units (lb/MMBtu) heat input, on the basis of daily and 30-	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(a) § 117.1240(f) § 117.1240(f)(2) § 117.1240(i) § 117.1240(n) § 117.1240(o)(1) [G]§ 117.1240(o)(2)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) [G]§ 117.1240(o)(2) § 117.1245(b) § 117.1245(b)(1) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						day averaging periods as specified in §117.1220 of this title, and as specified in the mass emissions cap and trade program of Chapter 101, Subchapter H, Division 3 of this title.			§ 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
ACT1	EP	R1111-1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
ACT2	EP	R1111-1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
CBAB	EP	R1111-1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
CBY1EDG	EP	R1111-3	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						begun after January 31, 1972.			
CBY1EDG	EU	63ZZZZ-01	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
CBY2EDG	EP	R1111-3	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
CBY2EDG	EU	63ZZZZ-01	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CBYUNLOAD	EU	R5212-1	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
GRP-AUXB	EU	R7UT-1	CO	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(1) § 117.1210(b) § 117.1210(b)(1)(A)	No person shall allow the discharge into the atmosphere from any unit subject to the NO _x emission specifications specified in subsection (a) of this section, carbon monoxide (CO) emissions in excess of 400 parts per million by volume (ppmv) at 3.0% oxygen (O ₂), dry, or alternatively, 0.30 lb/MMBtu heat input for gas-fired auxiliary steam boilers.	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(b) § 117.1240(f) § 117.1240(f)(2) § 117.1240(i) § 117.8120	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRP-AUXB	EU	R7UT-1	NO _x	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(a)(2) § 117.1210(c)(4) § 117.1240(l) § 117.1240(l)(2) § 117.1240(o) § 117.1240(o)(3)	Emission specifications for the Mass Emission Cap and Trade Program. The owner or operator of each auxiliary steam boiler shall ensure that emissions of nitrogen oxides (NO _x) do not exceed 0.030, in pounds per million British thermal units (lb/MMBtu) heat input, on the basis of daily and 30-day averaging periods as specified in §117.1220 of this title, and as specified in	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1235(d) § 117.1235(d)(1) § 117.1235(d)(2) § 117.1240(a) § 117.1240(d) [G]§ 117.1240(d)(2) § 117.1240(f) § 117.1240(f)(1) § 117.1240(i) § 117.1240(n)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1245(b)(2) [G]§ 117.1245(c) § 117.1245(d) § 117.1245(d)(2) § 117.1245(d)(3) § 117.1245(d)(4) § 117.1245(d)(5) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						the mass emissions cap and trade program of Chapter 101, Subchapter H, Division 3 of this title.	§ 117.1240(o)(1) § 117.8110(a) § 117.8110(a)(1) [G]§ 117.8110(a)(2)		§ 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRP-AUXB	EU	R7UT-2	CO	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(1) § 117.1210(b) § 117.1210(b)(1)(A)	No person shall allow the discharge into the atmosphere from any unit subject to the NO _x emission specifications specified in subsection (a) of this section, carbon monoxide (CO) emissions in excess of 400 parts per million by volume (ppmv) at 3.0% oxygen (O ₂), dry, or alternatively, 0.30 lb/MMBtu heat input for gas-fired auxiliary steam boilers.	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(b) § 117.1240(f) § 117.1240(f)(2) § 117.1240(i) § 117.8120	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRP-AUXB	EU	R7UT-2	NO _x	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(a)(2) § 117.1210(c)(4) § 117.1240(l) § 117.1240(l)(2) § 117.1240(o) § 117.1240(o)(3)	Emission specifications for the Mass Emission Cap and Trade Program. The owner or operator of each auxiliary steam boiler shall ensure that emissions of nitrogen oxides (NO _x) do not exceed 0.030, in pounds per million British thermal units (lb/MMBtu) heat input, on the basis of daily and 30-day averaging periods as specified in §117.1220 of	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(a) § 117.1240(f) § 117.1240(f)(2) § 117.1240(i) § 117.1240(n) § 117.1240(o)(1) [G]§ 117.1240(o)(2)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) [G]§ 117.1240(o)(2) § 117.1245(b) § 117.1245(b)(1) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						this title, and as specified in the mass emissions cap and trade program of Chapter 101, Subchapter H, Division 3 of this title.			§ 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRP-AUXB	EU	60Db-1	NO _x	40 CFR Part 60, Subpart Db	§ 60.44b(l)(1) § 60.44b(h) § 60.44b(i) § 60.46b(a)	Affected facilities combusting coal, oil, or natural gas, or a mixture of these fuels, or any other fuels: a limit of 86 ng/JI (0.20 lb/million Btu) heat input unless the affected facility meets the specified requirements.	§ 60.46b(c) § 60.46b(e) § 60.46b(e)(1) § 60.46b(e)(3) [G]§ 60.48b(b) § 60.48b(c) § 60.48b(d) § 60.48b(e) [G]§ 60.48b(e)(2) § 60.48b(e)(3) § 60.48b(f)	[G]§ 60.48b(b) § 60.48b(c) [G]§ 60.49b(d) [G]§ 60.49b(g) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3) § 60.49b(b) § 60.49b(h) § 60.49b(i) § 60.49b(v) § 60.49b(w)
GRP-AUXB	EU	60Db-1	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
GRP-AUXB	EU	60Db-1	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
GRP-AUXB	EU	60Db-1	SO ₂	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).			
GRP-B1-2	EU	R1153-1	PM	30 TAC Chapter 111, Nonagricultural Processes	§ 111.153(c)	No person may cause, suffer, allow, or permit emissions of particulate matter from any oil or gas fuel-fired steam generator with a heat input greater than 2,500 million Btu per hour to exceed 0.1 pound of total suspended particulate per million Btu input averaged over a two-hour period.	** See Periodic Monitoring Summary	None	None
GRP-B1-2	EU	REG2-1	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(a)	No person may cause, suffer, allow, or permit emissions of SO ₂ from any liquid fuel-fired steam generator, furnace, or heater to exceed 440 ppmv at actual stack conditions and averaged over 3-hours.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)
GRP-B1-2	EU	R7UT-01	CO	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(1) § 117.1210(b) § 117.1210(b)(1)(B)	No person shall allow the discharge into the atmosphere from any unit subject to the NO _x emission specifications specified in subsection (a) of this section, carbon monoxide (CO) emissions in excess of 400 parts per million by volume (ppmv) at 3.0% oxygen (O ₂), dry, or alternatively, 0.30 lb/MMBtu heat input for gas-fired utility boilers.	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1235(c) § 117.1235(d) § 117.1235(d)(5) § 117.1240(b) § 117.1240(d) [G]§ 117.1240(d)(2) § 117.1240(i) § 117.8110(a) § 117.8110(a)(1) [G]§ 117.8110(a)(2) § 117.8120 § 117.8120(1)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1245(b)(2) [G]§ 117.1245(c) § 117.1245(d) § 117.1245(d)(1) § 117.1245(d)(2) § 117.1245(d)(3) § 117.1245(d)(4) § 117.1245(d)(5) [G]§ 117.1254(a) § 117.1254(c) § 117.1256 § 117.8010

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8120(1)(A)		[G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRP-B1-2	EU	R7UT-01	NH ₃	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(2) § 117.1210(b) § 117.1210(b)(2)(B)	No person shall allow the discharge into the atmosphere from any unit subject to the NO _x emission specifications specified in subsection (a) of this section, ammonia emissions in excess of 10 ppmv, at 3.0% O ₂ , dry, for boilers that inject urea or ammonia into the exhaust stream for NO _x control.	§ 117.1235(a) § 117.1235(a)(2) § 117.1235(a)(3) § 117.1235(c) § 117.1240(c) § 117.1240(d) [G]§ 117.1240(d)(2) § 117.1240(i)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1245(b)(2) [G]§ 117.1245(c) § 117.1245(d) § 117.1245(d)(1) § 117.1245(d)(2) § 117.1245(d)(3) § 117.1245(d)(4) § 117.1245(d)(5) [G]§ 117.1254(a) § 117.1254(c) § 117.1256
GRP-B1-2	EU	R7UT-01	NO _x	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(a)(1)(A) [G]§ 117.1203(c) § 117.1210(a)(1) § 117.1210(c)(3) § 117.1220(a) § 117.1220(b) [G]§ 117.1220(c) § 117.1220(d) § 117.1220(e) § 117.1220(i) § 117.1220(j) § 117.1220(k) § 117.1220(l) § 117.1220(m)	The owner or operator of each gas fired utility boiler shall ensure that emissions of nitrogen oxides (NO _x) do not exceed 0.030, in pounds per million British thermal units (lb/MMBtu) heat input, on the basis of daily and 30-day averaging periods as specified in §117.1220 of this title, and as specified in the mass emissions cap and trade program of Chapter 101, Subchapter H,	§ 117.1220(d) [G]§ 117.1220(e)(1) § 117.1220(h) § 117.1220(k) § 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1235(c) § 117.1235(d) § 117.1235(d)(1) § 117.1235(d)(2) § 117.1235(d)(3) § 117.1240(a) § 117.1240(d)	§ 117.1220(f) § 117.1245(a) [G]§ 117.1245(e)	[G]§ 117.1203(c) § 117.1220(g) § 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1245(b)(2) [G]§ 117.1245(c) § 117.1245(d) § 117.1245(d)(1) § 117.1245(d)(1)(B) § 117.1245(d)(2) § 117.1245(d)(3) § 117.1245(d)(4) § 117.1245(d)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.1240(l) § 117.1240(l)(2) § 117.1240(o) § 117.1240(o)(3)	Division 3 of this title.	[G]§ 117.1240(d)(2) § 117.1240(i) § 117.1240(n) § 117.1240(o)(1) § 117.8110(a) § 117.8110(a)(1) [G]§ 117.8110(a)(2)		[G]§ 117.1254(a) [G]§ 117.1254(b) § 117.1254(c) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRP-B1-2	EU	R7UT-02	CO	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(1) § 117.1210(b) § 117.1210(b)(1)(B)	No person shall allow the discharge into the atmosphere from any unit subject to the NO _x emission specifications specified in subsection (a) of this section, carbon monoxide (CO) emissions in excess of 400 parts per million by volume (ppmv) at 3.0% oxygen (O ₂), dry, or alternatively, 0.30 lb/MMBtu heat input for gas-fired utility boilers.	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1235(c) § 117.1235(d) § 117.1235(d)(5) § 117.1240(b) § 117.1240(d) [G]§ 117.1240(d)(2) § 117.1240(i) § 117.8110(a) § 117.8110(a)(1) [G]§ 117.8110(a)(2) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1245(b)(2) [G]§ 117.1245(c) § 117.1245(d) § 117.1245(d)(1) § 117.1245(d)(2) § 117.1245(d)(3) § 117.1245(d)(4) § 117.1245(d)(5) [G]§ 117.1254(a) § 117.1254(c) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRP-B1-2	EU	R7UT-02	NH ₃	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(2) § 117.1210(b) § 117.1210(b)(2)(B)	No person shall allow the discharge into the atmosphere from any unit subject to the NO _x emission specifications specified in subsection (a) of this section, ammonia emissions in excess of 10 ppmv, at 3.0% O ₂ , dry, for boilers that inject urea or ammonia into the exhaust stream for NO _x control.	§ 117.1235(a) § 117.1235(a)(2) § 117.1235(a)(3) § 117.1235(c) § 117.1240(c) § 117.1240(d) [G]§ 117.1240(d)(2) § 117.1240(i)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1245(b)(2) [G]§ 117.1245(c) § 117.1245(d) § 117.1245(d)(1) § 117.1245(d)(2) § 117.1245(d)(3) § 117.1245(d)(4) § 117.1245(d)(5) [G]§ 117.1254(a) § 117.1254(c) § 117.1256
GRP-B1-2	EU	R7UT-02	NO _x	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(a)(1)(A) [G]§ 117.1203(c) § 117.1210(a)(1) § 117.1210(c)(3) § 117.1220(a) § 117.1220(b) [G]§ 117.1220(c) § 117.1220(d) § 117.1220(e) § 117.1220(i) § 117.1220(j) § 117.1220(k) § 117.1220(l) § 117.1220(m) § 117.1240(l) § 117.1240(l)(2) § 117.1240(o) § 117.1240(o)(3)	The owner or operator of each gas fired utility boiler shall ensure that emissions of nitrogen oxides (NO _x) do not exceed 0.030, in pounds per million British thermal units (lb/MMBtu) heat input, on the basis of daily and 30-day averaging periods as specified in §117.1220 of this title, and as specified in the mass emissions cap and trade program of Chapter 101, Subchapter H, Division 3 of this title.	§ 117.1220(d) [G]§ 117.1220(e)(1) § 117.1220(h) § 117.1220(k) § 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1235(c) § 117.1235(d) § 117.1235(d)(1) § 117.1235(d)(2) § 117.1235(d)(3) § 117.1240(a) § 117.1240(d) [G]§ 117.1240(d)(2) § 117.1240(i) § 117.1240(n) § 117.1240(o)(1) § 117.8110(a) § 117.8110(a)(1) [G]§ 117.8110(a)(2)	§ 117.1220(f) § 117.1245(a) [G]§ 117.1245(e)	[G]§ 117.1203(c) § 117.1220(g) § 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1245(b)(2) [G]§ 117.1245(c) § 117.1245(d) § 117.1245(d)(1) § 117.1245(d)(1)(B) § 117.1245(d)(2) § 117.1245(d)(3) § 117.1245(d)(4) § 117.1245(d)(5) [G]§ 117.1254(a) [G]§ 117.1254(b) § 117.1254(c) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRP-B1-2	EU	R7UT-03	CO	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(1) § 117.1210(b) § 117.1210(b)(1)(B)	No person shall allow the discharge into the atmosphere from any unit subject to the NO _x emission specifications specified in subsection (a) of this section, carbon monoxide (CO) emissions in excess of 400 parts per million by volume (ppmv) at 3.0% oxygen (O ₂), dry, or alternatively, 0.31 lb/MMBtu heat input for oil-fired utility boilers.	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1235(c) § 117.1235(d) § 117.1235(d)(5) § 117.1240(b) § 117.1240(d) [G]§ 117.1240(d)(2) § 117.1240(i) § 117.8110(a) § 117.8110(a)(1) [G]§ 117.8110(a)(2) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1245(b)(2) [G]§ 117.1245(c) § 117.1245(d) § 117.1245(d)(1) § 117.1245(d)(2) § 117.1245(d)(3) § 117.1245(d)(4) § 117.1245(d)(5) [G]§ 117.1254(a) § 117.1254(c) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRP-B1-2	EU	R7UT-03	NH ₃	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(2) § 117.1210(b) § 117.1210(b)(2)(B)	No person shall allow the discharge into the atmosphere from any unit	§ 117.1235(a) § 117.1235(a)(2) § 117.1235(a)(3)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						subject to the NO _x emission specifications specified in subsection (a) of this section, ammonia emissions in excess of 10 ppmv, at 3.0% O ₂ , dry, for boilers that inject urea or ammonia into the exhaust stream for NO _x control.	§ 117.1235(c) § 117.1240(c) § 117.1240(d) [G]§ 117.1240(d)(2) § 117.1240(i)		§ 117.1245(b)(2) [G]§ 117.1245(c) § 117.1245(d) § 117.1245(d)(1) § 117.1245(d)(2) § 117.1245(d)(3) § 117.1245(d)(4) § 117.1245(d)(5) [G]§ 117.1254(a) § 117.1254(c) § 117.1256
GRP-B1-2	EU	R7UT-03	NO _x	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(a)(1)(B)(i) [G]§ 117.1203(c) § 117.1210(a)(1) § 117.1210(a)(1)(B) § 117.1210(c)(3) § 117.1220(a) § 117.1220(b) [G]§ 117.1220(c) § 117.1220(d) § 117.1220(e) § 117.1220(i) § 117.1220(j) § 117.1220(k) § 117.1220(l) § 117.1220(m) § 117.1240(l) § 117.1240(l)(2) § 117.1240(o) § 117.1240(o)(3)	The owner or operator of each oil-fired wall-fired utility boiler shall ensure that emissions of nitrogen oxides (NO _x) do not exceed 0.050, in pounds per million British thermal units (lb/MMBtu) heat input, on the basis of daily and 30-day averaging periods as specified in §117.1220 of this title, and as specified in the mass emissions cap and trade program of Chapter 101, Subchapter H, Division 3 of this title.	§ 117.1220(d) [G]§ 117.1220(e)(1) § 117.1220(h) § 117.1220(k) § 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1235(c) § 117.1235(d) § 117.1235(d)(1) § 117.1235(d)(2) § 117.1235(d)(3) § 117.1240(a) § 117.1240(d) [G]§ 117.1240(d)(2) § 117.1240(i) § 117.1240(n) § 117.1240(o)(1) § 117.8110(a) § 117.8110(a)(1) [G]§ 117.8110(a)(2)	§ 117.1220(f) § 117.1245(a) [G]§ 117.1245(e)	[G]§ 117.1203(c) § 117.1220(g) § 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1245(b)(2) [G]§ 117.1245(c) § 117.1245(d) § 117.1245(d)(1) § 117.1245(d)(1)(B) § 117.1245(d)(2) § 117.1245(d)(3) § 117.1245(d)(4) § 117.1245(d)(5) [G]§ 117.1254(a) [G]§ 117.1254(b) § 117.1254(c) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
									§ 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRP-B1-2	EU	60D-1	NO _x	40 CFR Part 60, Subpart D	§ 60.44(a)(1)	On/after the §60.8 test, no affected facility shall emit gases containing NO _x , expressed as NO ₂ in excess of 86 ng/J heat input (0.20 lb/MMBtu) derived from gaseous fossil fuel.	§ 60.45(a) § 60.45(b)(3) § 60.45(c) § 60.45(c)(1) § 60.45(c)(2) § 60.45(c)(3) § 60.45(c)(3)(i) § 60.45(c)(3)(ii) [G]§ 60.45(e) [G]§ 60.45(f) § 60.45(g) § 60.45(g)(3) § 60.45(g)(3)(i) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(5) [G]§ 60.46(d)(1) § 60.46(d)(5) § 60.46(d)(6) § 60.46(d)(7)	None	§ 60.45(g)
GRP-B1-2	EU	60D-1	SO ₂	40 CFR Part 60, Subpart D	§ 60.40(a)	The affected facility burns fuel (such as only gaseous fuels) that has no specific SO ₂ emission requirements.	§ 60.45(b)(1) § 60.45(b)(4)	None	None
GRP-B1-2	EU	60D-2	NO _x	40 CFR Part 60, Subpart D	§ 60.44(b)	Except as stated in §60.44(c), (d), and (e), when different fossil fuels are burned simultaneously in any combination, the applicable standard is determined by proration using the specified formula.	§ 60.45(a) § 60.45(b)(3) § 60.45(c) § 60.45(c)(1) § 60.45(c)(2) § 60.45(c)(3) § 60.45(c)(3)(i) § 60.45(c)(3)(ii) § 60.45(c)(4) [G]§ 60.45(e) [G]§ 60.45(f)	None	§ 60.45(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 60.45(g) § 60.45(g)(3) § 60.45(g)(3)(i) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(5) [G]§ 60.46(c) [G]§ 60.46(d)(1) § 60.46(d)(5) § 60.46(d)(6) § 60.46(d)(7)		
GRP-B1-2	EU	60D-2	PM (Opacity)	40 CFR Part 60, Subpart D	§ 60.42(a)(2)	On/after the §60.8 test, no affected facility shall emit gases exhibiting greater than 20% opacity except for one six minute period per hour of not more than 27% opacity.	§ 60.45(b)(1) § 60.45(b)(7) [G]§ 60.45(b)(7)(i) [G]§ 60.45(b)(7)(ii) § 60.45(b)(7)(iii) § 60.45(h) [G]§ 60.45(h)(1) [G]§ 60.45(h)(2) § 60.45(h)(3) § 60.46(a) § 60.46(b)(3)	§ 60.45(h) [G]§ 60.45(h)(1) [G]§ 60.45(h)(2) § 60.45(h)(3)	§ 60.45(h)(3)
GRP-B1-2	EU	60D-2	SO ₂	40 CFR Part 60, Subpart D	§ 60.43(b) § 60.43(c)	When different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) shall be determined by proration using the specified formula.	§ 60.45(b)(1) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(4) [G]§ 60.46(c) [G]§ 60.46(d)(1) [G]§ 60.46(d)(3) § 60.46(d)(4) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
GRP-B1-2	EU	60D-3	NO _x	40 CFR Part 60, Subpart D	§ 60.44(a)(2)	On/after the §60.8 test, no affected facility shall emit	§ 60.45(a) § 60.45(b)(3)	None	§ 60.45(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						gases containing NO _x , expressed as NO ₂ in excess of 129 ng/J heat input (0.30 lb/MMBtu) derived from liquid fossil fuel, liquid fossil fuel and wood residue, or gaseous fossil fuel and wood residue.	§ 60.45(c) § 60.45(c)(1) § 60.45(c)(2) § 60.45(c)(3) § 60.45(c)(3)(i) § 60.45(c)(3)(ii) [G]§ 60.45(e) [G]§ 60.45(f) § 60.45(g) § 60.45(g)(3) § 60.45(g)(3)(i) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(5) [G]§ 60.46(d)(1) § 60.46(d)(5) § 60.46(d)(6) § 60.46(d)(7)		
GRP-B1-2	EU	60D-3	PM (Opacity)	40 CFR Part 60, Subpart D	§ 60.42(a)(2)	On/after the §60.8 test, no affected facility shall emit gases exhibiting greater than 20% opacity except for one six minute period per hour of not more than 27% opacity.	§ 60.45(b)(1) § 60.45(b)(7) [G]§ 60.45(b)(7)(i) [G]§ 60.45(b)(7)(ii) § 60.45(b)(7)(iii) § 60.45(h) [G]§ 60.45(h)(1) [G]§ 60.45(h)(2) § 60.45(h)(3) § 60.46(a) § 60.46(b)(3)	§ 60.45(h) [G]§ 60.45(h)(1) [G]§ 60.45(h)(2) § 60.45(h)(3)	§ 60.45(h)(3)
GRP-B1-2	EU	60D-3	SO ₂	40 CFR Part 60, Subpart D	§ 60.43(a)(1)	On/after the §60.8 test, no affected facility shall emit gases containing SO ₂ in excess of 340 ng/J heat input (0.80 lb/MMBtu) derived from liquid fossil fuel or liquid fossil fuel and wood residue.	§ 60.45(b)(1) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(4) [G]§ 60.46(d)(1) [G]§ 60.46(d)(3) § 60.46(d)(4) § 60.46(d)(6)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 60.46(d)(7) ** See Periodic Monitoring Summary		
GRP-B1-2S	EP	R1111-1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRP-CB-LOV	EP	R1111-3	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRPTANK1	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPTANK2	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPTANK3	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				VOCs		storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.		§ 115.118(a)(7)	
S1	EU	R5131-1	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None

Additional Monitoring Requirements

Periodic Monitoring Summary 48

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: A-120-1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Record of Tank Construction Specifications	
Minimum Frequency: N/A	
Averaging Period: N/A	
Deviation Limit: Any deviation from tank construction specifications.	
Periodic Monitoring Text: Keep a record of tank construction specifications (e.g. engineering drawings) that show a fill pipe that extends from the top of a tank to have a maximum clearance of six inches (15.2 centimeters) from the bottom or, when the tank is loaded from the side, a discharge opening entirely submerged when the pipe used to withdraw liquid from the tank can no longer withdraw liquid in normal operation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: A-120-1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: N/A	
Deviation Limit: It is a deviation if required repairs are not completed prior to refilling the storage vessel.	
<p>Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed to ensure that it continues to meet the specifications in the above requirement. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: ACT1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Visible emissions	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Opacity greater than 15% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. The source must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observation cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. Documentation of all observations shall be maintained. If visible emissions are observed, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: ACT2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Visible emissions	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Opacity greater than 15% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. The source must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observation cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. Documentation of all observations shall be maintained. If visible emissions are observed, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CBAB	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: N/A	
Deviation Limit: Any opacity readings that are above 15% averaged over a six-minute period shall be considered and reported as a deviation.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CBY1EDG	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-3
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: N/A	
Deviation Limit: 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: CBY2EDG	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-3
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: N/A	
Deviation Limit: 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-B1-2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Nonagricultural Processes	SOP Index No.: R1153-1
Pollutant: PM	Main Standard: § 111.153(c)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: Once per month	
Averaging Period: Six-minutes	
Deviation Limit: Observed opacity greater than 20%.	
Periodic Monitoring Text: Opacity shall be monitored, by a certified observer, for at least one, six-minute period in accordance with Title 40 Code of Federal Regulations Part 60 (40 CFR Part 60), Appendix A, Test Method 9. Any opacity readings above the deviation limit shall be reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-B1-2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: REG2-1
Pollutant: SO ₂	Main Standard: § 112.9(a)
Monitoring Information	
Indicator: Sulfur Content of Fuel	
Minimum Frequency: Quarterly and within 24 hours of any fuel change	
Averaging Period: N/A	
Deviation Limit: Any monitoring data showing sulfur dioxide emissions above 440 ppmv, averaged over a three-hour period, shall be considered and reported as a deviation.	
Periodic Monitoring Text: Measure and record the sulfur content of the fuel. Any monitoring data above the deviation limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-B1-2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60D-2
Pollutant: SO ₂	Main Standard: § 60.43(b)
Monitoring Information	
Indicator: Sulfur Content of Fuel	
Minimum Frequency: Quarterly	
Averaging Period: N/A	
Deviation Limit: Maximum Sulfur Content of Fuel Oil = 0.06 wt. %	
Periodic Monitoring Text: When firing fuel oil and gas simultaneously, measure and record the sulfur content of the fuel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-B1-2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60D-3
Pollutant: SO ₂	Main Standard: § 60.43(a)(1)
Monitoring Information	
Indicator: Sulfur Content of Fuel	
Minimum Frequency: Quarterly	
Averaging Period: N/A	
Deviation Limit: Maximum Sulfur Content of Fuel Oil = 0.06 wt. %	
Periodic Monitoring Text: When firing fuel oil, measure and record the sulfur content of the fuel.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-B1-2S	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: Once per month	
Averaging Period: Six-minutes	
Deviation Limit: Maximum opacity = 15% averaged over a six-minute period.	
Periodic Monitoring Text: Opacity shall be monitored, by a certified observer, for at least one, six-minute period in accordance with Title 40 Code of Federal Regulations Part 60 (40 CFR Part 60), Appendix A, Test Method 9. Any opacity readings above the deviation limit shall be reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRP-CB-LOV	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-3
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible emissions	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Opacity greater than 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. The source must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observation cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. Documentation of all observations shall be maintained. If visible emissions are observed, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

Permit Shield

Permit Shield 62

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
A-113-1	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than 1,000 gallons.
A-113-1	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.
AB1	N/A	30 TAC Chapter 112, Sulfur Compounds	The Auxiliary Boiler No. 1 does not fire solid or liquid fuel.
AB1	N/A	40 CFR Part 60, Subpart D	Construction or modification commenced prior to August 17, 1971.
AB1	N/A	40 CFR Part 60, Subpart Da	Construction, modification, or reconstruction commenced prior to September 18, 1978.
AB1	N/A	40 CFR Part 60, Subpart Db	Construction, modification, or reconstruction commenced prior to June 19, 1984.
AB1	N/A	40 CFR Part 60, Subpart Dc	Construction, modification, or reconstruction commenced prior to June 9, 1989.
AB1	N/A	40 CFR Part 63, Subpart DDDDD	The site is an area source of HAPs.
ACT1	N/A	40 CFR Part 63, Subpart Q	This source does not operate with chromium-based water treatment chemicals.
ACT2	N/A	40 CFR Part 63, Subpart Q	This source does not operate with chromium-based water treatment chemicals.
CBAB	N/A	30 TAC Chapter 115, Vent Gas Controls	The vent is a combustion unit exhaust stream that is not being used as a control device for any vent gas stream which is subject to this division and which originates from a non-combustion source.
CBGST1	N/A	30 TAC Chapter 115, Vent Gas Controls	All VOCs in this vent gas stream originate from a source for which another division within Chapter 115 has established a control requirement, emission specification or exemption.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
CBY FUG	N/A	40 CFR Part 61, Subpart J	Fugitive piping components do not operate in benzene service as defined in 40 CFR §61.111.
CBY FUG	N/A	40 CFR Part 61, Subpart V	These sources do not operate in volatile hazardous air pollutant (VHAP) service.
CBY FUG	N/A	40 CFR Part 63, Subpart H	Fugitive piping components do not operate in organic hazardous air pollutant service 300 hours or more during a calendar year within a source subject to the provisions of a specific subpart in 40 CFR Part 63 that references 40 CFR Part 63, Subpart H.
CBY1EDG	N/A	30 TAC Chapter 117, Subchapter B	Engines are located at an electric generating facility subject to Subchapter C.
CBY1EDG	N/A	40 CFR Part 60, Subpart IIII	The source commenced construction prior to July 11, 2005.
CBY1EDG	N/A	40 CFR Part 60, Subpart JJJJ	Engine is not a spark ignition internal combustion engine.
CBY2EDG	N/A	30 TAC Chapter 117, Subchapter B	Engines are located at an electric generating facility subject to Subchapter C.
CBY2EDG	N/A	40 CFR Part 60, Subpart IIII	The source commenced construction prior to July 11, 2005.
CBY2EDG	N/A	40 CFR Part 60, Subpart JJJJ	Engine is not a spark ignition internal combustion engine.
CBYGAS	N/A	30 TAC Chapter 115, Loading and Unloading of VOC	Unloading operation is a motor vehicle fuel dispensing facility.
DG-1	N/A	30 TAC Chapter 115, Degreasing Processes	Solvent used has a vapor pressure less than 0.6 psia at 100 degrees Fahrenheit with a drain area

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
			less than 16 square inches, and the waste solvent is disposed of properly in enclosed containers.
GRP-AUXB	CBAB2N, CBAB3N	30 TAC Chapter 112, Sulfur Compounds	Auxiliary Boilers Nos. 2 & 3 do not fire solid or liquid fuel.
GRP-AUXB	CBAB2N, CBAB3N	40 CFR Part 60, Subpart D	These units commenced construction, modification, or reconstruction after June 19, 1986 and are not subject to subpart D.
GRP-AUXB	CBAB2N, CBAB3N	40 CFR Part 60, Subpart Da	These auxiliary boilers do not meet the definition of electric utility steam generating units, per 60.41Da, because they do not serve a generator that produces electricity for sale.
GRP-AUXB	CBAB2N, CBAB3N	40 CFR Part 60, Subpart Dc	Auxiliary boiler heat input capacity is greater than 100 million Btu/hr.
GRP-AUXB	CBAB2N, CBAB3N	40 CFR Part 63, Subpart DDDDD	The site is an area source of HAPs.
GRP-B1-2	1, 2	40 CFR Part 60, Subpart Da	Construction, modification, or reconstruction commenced prior to September 18, 1978.
GRP-B1-2	1, 2	40 CFR Part 60, Subpart Db	Construction, modification, or reconstruction commenced prior to June 19, 1984.
GRP-B1-2	1, 2	40 CFR Part 60, Subpart Dc	Construction, modification, or reconstruction commenced prior to June 9, 1989.
GRP-B1-2	1, 2	40 CFR Part 60, Subpart TTTT	Construction commenced before January 8, 2014 and has not been reconstructed or modified.
GRP-B1-2	1, 2	40 CFR Part 63, Subpart DDDDD	The units are natural gas fired electric utility steam generating units.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
GRP-B1-2	1, 2	40 CFR Part 63, Subpart UUUUU	GRP-B1-2 are electric utility steam generating units that meet the exemption criteria under 40 CFR 63.9983(c)
GRP-B1-2S	CB1, CB2	30 TAC Chapter 115, Vent Gas Controls	The vent is a combustion unit exhaust stream that is not being used as a control device for any vent gas stream which is subject to this division and which originates from a non-combustion source.
GRP-CB-LOV	CB1-LOV, CB2-LOV	30 TAC Chapter 115, Vent Gas Controls	Does not emit VOC.
NGFUG	N/A	40 CFR Part 61, Subpart J	Fugitive piping components do not operate in benzene service as defined in 40 CFR §61.111.
NGFUG	N/A	40 CFR Part 61, Subpart V	These sources do not operate in volatile hazardous air pollutant (VHAP) service.
NGFUG	N/A	40 CFR Part 63, Subpart H	Fugitive piping components do not operate in organic hazardous air pollutant service 300 hours or more during a calendar year within a source subject to the provisions of a specific subpart in 40 CFR Part 63 that references 40 CFR Part 63, Subpart H.
TG1	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than 25,000 gallons and located at a motor vehicle fuel dispensing facility.

New Source Review Authorization References

New Source Review Authorization References 67

New Source Review Authorization References by Emission Unit 68

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 1532	Issuance Date: 02/17/2015
Authorization No.: 26833	Issuance Date: 12/01/1994
Authorization No.: 26834	Issuance Date: 12/01/1994
Authorization No.: 45998	Issuance Date: 03/11/2020
Authorization No.: 46591	Issuance Date: 06/23/2020
Authorization No.: 49590	Issuance Date: 03/31/2022
Authorization No.: 53235	Issuance Date: 03/10/2014
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 5	Version No./Date: 06/07/1996
Number: 8	Version No./Date: 06/07/1996
Number: 14	Version No./Date: 06/07/1996
Number: 34	Version No./Date: 06/07/1996
Number: 40	Version No./Date: 06/07/1996
Number: 51	Version No./Date: 06/07/1996
Number: 53	Version No./Date: 06/07/1996
Number: 61	Version No./Date: 11/05/1986
Number: 68	Version No./Date: 06/07/1996
Number: 103	Version No./Date: 06/07/1996
Number: 106.227	Version No./Date: 09/04/2000
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.352	Version No./Date: 09/04/2000
Number: 106.532	Version No./Date: 09/04/2000
Number: 106.533	Version No./Date: 03/14/1997
Number: 107	Version No./Date: 06/07/1996

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
1	UNIT 1 BOILER	1532, 26833, 46591
2	UNIT 2 BOILER	1532, 26834, 45998
A-103-1	LUBE OIL TANK	51/06/07/1996
A-103-2	LUBE OIL TANK	51/06/07/1996
A-103-5	TURBINE LUBE OIL TANK	51/06/07/1996
A-103-6	TURBINE LUBE OIL TANK	51/06/07/1996
A-103-7	TURBINE LUBE OIL TANK	51/06/07/1996
A-105-1	DIESEL TANK	51/06/07/1996
A-105-2	DIESEL TANK	51/06/07/1996
A-113-1	USED OIL TANK	51/06/07/1996
A-114-1	USED OIL TANK	51/06/07/1996
A-115-1	DIESEL TANK	51/06/07/1996
A-120-1	CONDENSATE TANK	106.352/09/04/2000
AB1	AUXILIARY BOILER 1	53235
ACT1	COOLING TOWER 1	8/06/07/1996
ACT2	COOLING TOWER 2	8/06/07/1996
CB1	UNIT 1 BOILER STACK	1532, 26833, 45998, 46591
CB1-LOV	UNIT 1 LUBE OIL VENT	1532
CB2	UNIT 2 BOILER STACK	1532, 26834, 45998, 46591
CB2-LOV	UNIT 2 LUBE OIL VENT	1532
CBAB	AUXILIARY BOILER STACK	49590, 53235

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
CBAB2N	AUXILIARY BOILER 2	49590
CBAB3N	AUXILIARY BOILER 3	49590
CBGST1	GASOLINE TANK VENT	14/06/07/1996
CBY FUG	CBY AMMONIA FUGITIVES	1532
CBY1EDG	#1 EMERGENCY DIESEL GENERATOR	5/06/07/1996
CBY2EDG	#2 EMERGENCY DIESEL GENERATOR	5/06/07/1996
CBYGAS	CBY GAS UNLOADING	53/06/07/1996
CBYUNLOAD	CBY UNLOADING OPERATIONS	51/06/07/1996
DG-1	CBY DEGREASER	107/06/07/1996
NGFUG	NATURAL GAS PIPING FUGITIVES	1532
S1	OILY WASTE TREATMENT SYSTEM SEPARATOR	61/11/05/1986
TG1	GASOLINE TANK	14/06/07/1996

**This column may include Permit by Rule (PBR) numbers and version dates, PBR Registration numbers in brackets, Standard Permit Registration numbers, Minor NSR permit numbers, and Major NSR permit numbers.

Appendix A

Acronym List 71

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
SIP	state implementation plan
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound