

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
Targa Pipeline Mid-Continent WestTex LLC

AUTHORIZING THE OPERATION OF
Benedum Gas Plant
Crude Petroleum and Natural Gas Extraction

LOCATED AT
Upton County, Texas
Latitude 31° 20' 33" Longitude 101° 47' 47"
Regulated Entity Number: RN100223890

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: O3111 Issuance Date: _____

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions:	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements	6
New Source Review Authorization Requirements	6
Compliance Requirements.....	7
Permit Location	8
Permit Shield (30 TAC § 122.148)	8
Attachments	9
Applicable Requirements Summary.....	10
Additional Monitoring Requirements	52
Permit Shield.....	56
New Source Review Authorization References	61
Appendix A.....	68
Acronym List	69

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
 - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.
 - E. Emission units subject to 40 CFR Part 63, Subparts HH or ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113,

Subchapter C, §§ 113.390 or 113.1090, respectively, which incorporate the 40 CFR Part 63 Subparts by reference.

2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
 - A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
 - A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
 - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
 - (ii) Title 30 TAC § 111.111(a)(1)(E)
 - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
 - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the "Applicable

Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:

- (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
- (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer’s eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (5) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the

source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)

- (ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)

- (iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:

- (1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.

- (2) Records of all observations shall be maintained.

- (3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

- (4) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the

applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)

- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
 - C. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
 - D. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
 - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)
 - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
 - E. Outdoor burning, as stated in 30 TAC § 111.201, shall not be authorized unless the following requirements are satisfied:
 - (i) Title 30 TAC § 111.205 (relating to Exception for Fire Training)
 - (ii) Title 30 TAC § 111.207 (relating to Exception for Recreation, Ceremony, Cooking, and Warmth)
 - (iii) Title 30 TAC § 111.219 (relating to General Requirements for Allowable Outdoor Burning)
 - (iv) Title 30 TAC § 111.221 (relating to Responsibility for Consequences of Outdoor Burning)
4. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
- A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)

- B. Title 40 CFR § 60.8 (relating to Performance Tests)
 - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
 - F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
5. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
 6. For oil and natural gas production facilities as specified in 40 CFR Part 63, Subpart HH, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.390 incorporated by reference):
 - A. Title 40 CFR § 63.760(c) (relating to Applicability and Designation of Affected Source)
 7. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

Additional Monitoring Requirements

8. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

9. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule (including

the terms, conditions, monitoring, recordkeeping, and reporting identified in registered PBRs and permits by rule identified in the PBR Supplemental Tables dated March 21, 2025 in the application for project 36324), standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:

- A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
10. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
11. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
12. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
- A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
 - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
 - C. Requirements of the Air Quality Standard Permit for Oil and Gas Handling and Production Facilities

Compliance Requirements

13. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
14. Use of Discrete Emission Credits to comply with the applicable requirements:
- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:

- (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
- (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Permit Location

15. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

16. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Applicable Requirements Summary

Unit Summary 11

Applicable Requirements Summary 15

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
C-101	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-102	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-201	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-202	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-203	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-204	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-205	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-206	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-207	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-208	FUGITIVE EMISSION UNITS	N/A	600000a-03	40 CFR Part 60, Subpart 0000a	No changing attributes.
C-301	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-302	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-303	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-304	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
C-305	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-306	FUGITIVE EMISSION UNITS	N/A	600000-03	40 CFR Part 60, Subpart 0000	No changing attributes.
C-307	FUGITIVE EMISSION UNITS	N/A	600000a-03	40 CFR Part 60, Subpart 0000a	No changing attributes.
C-404	FUGITIVE EMISSION UNITS	N/A	600000b-CMP	40 CFR Part 60, Subpart 0000b	No changing attributes.
C-B8	SRIC ENGINES	N/A	63ZZZZ-01	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
E-AMINE	GAS SWEETENING/SULFUR RECOVERY UNITS	N/A	600000-02	40 CFR Part 60, Subpart 0000	No changing attributes.
E-GEN1	SRIC ENGINES	N/A	60IIII-01	40 CFR Part 60, Subpart IIII	No changing attributes.
E-GEN1	SRIC ENGINES	N/A	63ZZZZ-02	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
E-GEN2	SRIC ENGINES	N/A	60IIII-02	40 CFR Part 60, Subpart IIII	No changing attributes.
E-GEN2	SRIC ENGINES	N/A	63ZZZZ-02	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EE-1	SRIC ENGINES	N/A	60IIII-0003	40 CFR Part 60, Subpart IIII	No changing attributes.
EE-1	SRIC ENGINES	N/A	63ZZZZ-0006	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EH-1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R200-0001	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
FLR-B	FLARES	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
FLR-E	FLARES	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
FLR-J	FLARES	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
FUG-1B	FUGITIVE EMISSION UNITS	N/A	60KKK-1	40 CFR Part 60, Subpart KKK	No changing attributes.
FUG-1B	FUGITIVE EMISSION UNITS	N/A	600000-1	40 CFR Part 60, Subpart 0000	No changing attributes.
FUG-1B	FUGITIVE EMISSION UNITS	N/A	600000a-1	40 CFR Part 60, Subpart 0000a	No changing attributes.
FUG-1E	FUGITIVE EMISSION UNITS	N/A	600000-1	40 CFR Part 60, Subpart 0000	No changing attributes.
FUG-1E	FUGITIVE EMISSION UNITS	N/A	600000a-1	40 CFR Part 60, Subpart 0000a	No changing attributes.
FUG-1J	FUGITIVE EMISSION UNITS	N/A	600000a-1	40 CFR Part 60, Subpart 0000a	No changing attributes.
FUG-1J	FUGITIVE EMISSION UNITS	N/A	600000b-FUG	40 CFR Part 60, Subpart 0000b	No changing attributes.
FUG-GPX	FUGITIVE EMISSION UNITS	N/A	600000a-1	40 CFR Part 60, Subpart 0000a	No changing attributes.
GRP-COMPRESSOR	FUGITIVE EMISSION UNITS	C-105, C-106, C-401, C-402, C-403, C-405, C-406, C-407, C-408, C-409, C-410, C-411, C-701, C-702, C-703, C-704, C-705, C-706	600000a-03	40 CFR Part 60, Subpart 0000a	No changing attributes.
H-700-3	BOILERS/STEAM GENERATORS/STEAM	N/A	60Dc-03	40 CFR Part 60, Subpart Dc	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	GENERATING UNITS				
H-781	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60Dc-03	40 CFR Part 60, Subpart Dc	No changing attributes.
HTR-3	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60Dc-03	40 CFR Part 60, Subpart Dc	No changing attributes.
J-AMINE	GAS SWEETENING/SULFUR RECOVERY UNITS	N/A	600000a-02	40 CFR Part 60, Subpart 0000a	No changing attributes.
JE-1	SRIC ENGINES	N/A	60IIII-0003	40 CFR Part 60, Subpart IIII	No changing attributes.
JE-1	SRIC ENGINES	N/A	63ZZZZ-0006	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
JH-1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R200-0001	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
PORTENG	SRIC ENGINES	N/A	60IIII-0003	40 CFR Part 60, Subpart IIII	No changing attributes.
PORTENG	SRIC ENGINES	N/A	63ZZZZ-0006	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
PORTHTR	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R200-0001	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
TEG-1	GLYCOL DEHYDRATION	N/A	63HH-01	40 CFR Part 63, Subpart HH	No changing attributes.
V-1	GLYCOL DEHYDRATION	N/A	63HH-01	40 CFR Part 63, Subpart HH	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
C-101	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)
C-102	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)
C-201	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor rod packing replacement,	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						whichever is later.			
C-202	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)
C-203	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)
C-204	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						rod packing replacement, whichever is later.			
C-205	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)
C-206	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)
C-207	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						reciprocating compressor rod packing replacement, whichever is later.			
C-208	EU	600000a-03	VOC	40 CFR Part 60, Subpart OOOOa	§ 60.5385a(a)(1) § 60.5370a(a) § 60.5370a(b) § 60.5385a § 60.5385a(a) § 60.5385a(b) § 60.5385a(c) § 60.5385a(d) § 60.5410a § 60.5415a(c) § 60.5415a(c)(2) § 60.5415a(c)(3)	For each reciprocating compressor, the owner or operator must replace the rod packing on or before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, August 2, 2016, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.	§ 60.5410a(c)(1) § 60.5415a(c)(1)	§ 60.5410a(c)(4) § 60.5420a(c) [G]§ 60.5420a(c)(3)	§ 60.5410a(c)(3) § 60.5420a(a) § 60.5420a(a)(1) § 60.5420a(b) [G]§ 60.5420a(b)(1) § 60.5420a(b)(11) [G]§ 60.5420a(b)(13) [G]§ 60.5420a(b)(14) [G]§ 60.5420a(b)(4)
C-301	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)
C-302	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.			
C-303	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)
C-304	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)
C-305	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.5420(a)(1)	continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.			[G]§ 60.5420(b)(4)
C-306	EU	600000-03	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5385(a)(1) § 60.5370(b) § 60.5385(a) § 60.5415(c)(3) § 60.5420(a)(1)	Before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, or October 15, 2012, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.	§ 60.5410(c)(1) § 60.5415(c)(1)	§ 60.5420(c) [G]§ 60.5420(c)(3)	§ 60.5420(a) § 60.5420(a)(1) § 60.5420(b) [G]§ 60.5420(b)(1) [G]§ 60.5420(b)(4)
C-307	EU	600000a-03	VOC	40 CFR Part 60, Subpart OOOOa	§ 60.5385a(a)(1) § 60.5370a(a) § 60.5370a(b) § 60.5385a § 60.5385a(a) § 60.5385a(b) § 60.5385a(c) § 60.5385a(d) § 60.5410a § 60.5415a(c) § 60.5415a(c)(2) § 60.5415a(c)(3)	For each reciprocating compressor, the owner or operator must replace the rod packing on or before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, August 2, 2016, or the date of the most recent reciprocating compressor rod packing replacement,	§ 60.5410a(c)(1) § 60.5415a(c)(1)	§ 60.5410a(c)(4) § 60.5420a(c) [G]§ 60.5420a(c)(3)	§ 60.5410a(c)(3) § 60.5420a(a) § 60.5420a(a)(1) § 60.5420a(b) [G]§ 60.5420a(b)(1) § 60.5420a(b)(11) [G]§ 60.5420a(b)(13) [G]§ 60.5420a(b)(14) [G]§ 60.5420a(b)(4)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						whichever is later.			
C-404	EU	600000b-CMP	METHANE & VOC	40 CFR Part 60, Subpart OOOOb	§ 60.5385b(a) [G]§ 60.5370b(a) § 60.5370b(b) § 60.5385b § 60.5385b(a)(1) § 60.5385b(a)(2) [G]§ 60.5385b(a)(3) § 60.5410(b)(e) [G]§ 60.5412b(a)(3) § 60.5415b(g)	For each reciprocating compressor, measure the volumetric flow rate of each cylinder, and flow rate must not exceed 2 scfm per individual cylinder. Follow the measurement schedule specified in §60.5385(a)(1)-(2). Repair or replace rod packing according to § 60.5385(a)(3).	§ 60.5386b(a)(1)(i) § 60.5410b(e)(1) [G]§ 60.5412b(a)(3) § 60.5413b(a)(1) § 60.5415b(g)(3) § 60.5415b(g)(4) [G]§ 60.5416b(a)(1) § 60.5417b(a) § 60.5417b(d)(8)(i) [G]§ 60.5417b(d)(8)(iii) § 60.5417b(d)(8)(iv) § 60.5417b(d)(8)(v)	§ 60.5410b(e)(7) § 60.5415b(g)(6) § 60.5416b(b)(9) § 60.5417b(a) § 60.5417b(j) [G]§ 60.5420b(c)(11) [G]§ 60.5420b(c)(12) [G]§ 60.5420b(c)(5) [G]§ 60.5420b(c)(8)	§ 60.5410b(e)(6) § 60.5413b(d)(12) § 60.5415b(g)(5) § 60.5416b(b)(9) § 60.5417b(a) § 60.5417b(j) § 60.5420b(a) § 60.5420b(a)(1) § 60.5420b(b) [G]§ 60.5420b(b)(1) § 60.5420b(b)(15) [G]§ 60.5420b(b)(6) § 60.5420b(d)
C-B8	EU	63ZZZZ-01	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.8 § 63.6595(a)(1) § 63.6603(f) § 63.6605(a) § 63.6605(b) § 63.6625(h) § 63.6625(j)	For each existing non-emergency, non-black start 4SLB remote stationary RICE with a site rating greater than 500 HP, located at an area source, you must comply with the requirements as specified in Table 2d.8.a-c.	§ 63.6625(j) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6603(f) § 63.6625(j) § 63.6655(e) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
E-AMINE	EU	600000-02	SO ₂	40 CFR Part 60, Subpart OOOO	§ 60.5365(g)(3)	Facilities that have a design capacity less than 2 long tons per day (LT/D) of hydrogen sulfide (H ₂ S) in the acid gas (expressed as sulfur) are required to comply with recordkeeping and reporting requirements specified in §60.5423(c) but are not required to comply with §§60.5405 through 60.5407 and §§60.5410(g) and 60.5415(g) of this subpart.	None	§ 60.5423(c)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
E-GEN1	EU	60III-01	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
E-GEN1	EU	60III-01	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
E-GEN1	EU	60III-01	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW	None	None	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(f)	and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
E-GEN1	EU	60III-01	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).	None	None	[G]§ 60.4214(d)
E-GEN1	EU	63ZZZZ-02	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
E-GEN2	EU	60III-02	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 8 KW and less than 19 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 6.6 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
E-GEN2	EU	60III-02	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 7.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
E-GEN2	EU	60III-02	PM	40 CFR Part 60,	§ 60.4205(b)	Owners and operators of	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Subpart IIII	§ 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 19 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.40 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.			
E-GEN2	EU	63ZZZZ-02	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
EE-1	EU	60IIII-0003	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 8 KW and less than 19 KW and a displacement of less than	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(f)	10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 6.6 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.			
EE-1	EU	60III-0003	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 7.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
EE-1	EU	60III-0003	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 19 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.40 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.	None	None	None
EE-1	EU	63ZZZ-	112(B)	40 CFR Part 63,	§ 63.6590(c)	Stationary RICE subject to	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		0006	HAPS	Subpart ZZZZ		Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
EH-1	EU	R200-0001	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(a)	No person may cause, suffer, allow, or permit emissions of SO ₂ from any liquid fuel-fired steam generator, furnace, or heater to exceed 440 ppmv at actual stack conditions and averaged over 3-hours.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)
FLR-B	CD	R1111-01	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
FLR-E	CD	R1111-01	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						the provisions under §101.222(b).			
FLR-J	CD	R1111-01	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to the provisions under §101.222(b).	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None
FUG-1B	EU	60KKK-1	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f) § 60.486(k)	Comply with the requirements for valves in gas/vapor service as stated in §60.482-7 and §60.482-1(a), (b) and (d), except as provided in §60.633.	§ 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(ii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) § 60.485(d)(2) § 60.485(d)(3) § 60.485(f) § 60.632(d)	[G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 60.636(b) [G]§ 60.636(c)
FUG-1B	EU	60KKK-1	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-2(b)(1) [G]§ 60.482-2(b)(2) § 60.482-2(c)(1) [G]§ 60.482-2(c)(2) § 60.482-2(d) [G]§ 60.482-2(d)(1) § 60.482-2(d)(2) § 60.482-2(d)(3) [G]§ 60.482-2(d)(4)	Comply with the requirements for pumps in light liquid service as stated in §60.482-2 and §60.482-1(a), (b) and (d), except as provided in §60.633.	[G]§ 60.482-2(a) [G]§ 60.482-2(b)(2) [G]§ 60.482-2(d)(4) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) § 60.485(d)(2) § 60.485(d)(3) [G]§ 60.485(e) § 60.485(f) § 60.632(d) [G]§ 60.633(h)	[G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) [G]§ 60.486(h) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 60.636(b) [G]§ 60.636(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.482-2(d)(5) [G]§ 60.482-2(d)(6) [G]§ 60.482-2(e) § 60.482-2(f) [G]§ 60.482-2(g) § 60.482-2(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(d) § 60.482-9(f) § 60.486(k)				
FUG-1B	EU	60KKK-1	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-4(a) § 60.482-4(b)(1) § 60.482-4(c) § 60.482-4(d)(1) § 60.482-4(d)(2) § 60.482-9(a) § 60.482-9(b) § 60.486(k) [G]§ 60.633(b)(3)	Comply with the requirements for pressure relief devices in gas/vapor service as stated in §60.482-4 and 60.482-1(a), (b) and (d), except as provided in §60.633.	§ 60.482-4(b)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) § 60.485(d)(2) § 60.485(d)(3) § 60.485(f) § 60.632(d) § 60.633(b)(1) § 60.633(b)(2) [G]§ 60.633(b)(3) [G]§ 60.633(b)(4)	[G]§ 60.486(a) § 60.486(e) § 60.486(e)(1) § 60.486(e)(3) [G]§ 60.486(e)(4) § 60.486(j) § 60.633(b)(1) [G]§ 60.633(b)(4) [G]§ 60.635(b)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 60.636(b) [G]§ 60.636(c)
FUG-1B	EU	60KKK-1	VOC	40 CFR Part 60, Subpart KKK	§ 60.632(a) § 60.482-1(a) § 60.482-1(b) § 60.482-7(b) § 60.482-7(d)(1) § 60.482-7(d)(2) [G]§ 60.482-7(e) [G]§ 60.482-7(f) [G]§ 60.482-7(g) [G]§ 60.482-7(h) § 60.482-9(a) § 60.482-9(b) [G]§ 60.482-9(c) § 60.482-9(e) § 60.482-9(f)	Comply with the requirements for valves in light liquid service as stated in §60.482-7 and §60.482-1(a), (b) and (d), except as provided in §60.633.	§ 60.482-7(a)(1) [G]§ 60.482-7(a)(2) § 60.482-7(c)(1)(i) § 60.482-7(c)(1)(ii) § 60.482-7(c)(2) § 60.485(a) [G]§ 60.485(b) [G]§ 60.485(c) § 60.485(d)(2) § 60.485(d)(3) [G]§ 60.485(e) § 60.485(f) § 60.632(d) [G]§ 60.633(h)	[G]§ 60.486(a) [G]§ 60.486(b) [G]§ 60.486(c) § 60.486(e) § 60.486(e)(1) [G]§ 60.486(e)(2) [G]§ 60.486(e)(4) [G]§ 60.486(f) § 60.486(j)	§ 60.487(a) [G]§ 60.487(b) [G]§ 60.487(c) § 60.487(e) § 60.636(b) [G]§ 60.636(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.486(k)				
FUG-1B	EU	600000-1	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5400(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-4a(a) § 60.482-4a(b)(1) § 60.482-4a(b)(2) § 60.482-4a(c) § 60.482-4a(d)(1) § 60.482-4a(d)(2) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.5370(b) § 60.5400(d) § 60.5400(e) § 60.5400(f) § 60.5401(b)(1) § 60.5401(b)(2) § 60.5401(b)(3)(i) § 60.5401(b)(3)(ii) § 60.5401(b)(4)(i) § 60.5401(b)(4)(ii) § 60.5410(f) § 60.5420(a)(1) § 60.5422(b)	Except as provided in §60.5401 pressure relief device in gas/vapor service must comply with the requirements of §60.482-4a. Except during pressure releases, each pressure relief device in gas/vapor service shall be operated with no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as determined by the methods specified in §60.485a(c).	§ 60.482-4a(b)(2) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) § 60.5401(b)(1) § 60.5401(g)	§ 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(10) § 60.486a(e)(3) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) § 60.5420(c) [G]§ 60.5421(b)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420(a) § 60.5420(a)(1) § 60.5422(b) [G]§ 60.5422(c)
FUG-1B	EU	600000-1	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5400(a) § 60.482-11a(b)(2) § 60.482-11a(b)(3) § 60.482-11a(b)(3)(i) § 60.482-11a(d)	Except as provided in §60.5401 connectors in gas and vapor and light liquid service must comply with the requirements of §60.482-11a(b)(2). If an	§ 60.482-11a(a) § 60.482-11a(b) § 60.482-11a(b)(1) § 60.482-11a(b)(3) § 60.482-11a(b)(3)(ii)	§ 60.482-11a(b)(3)(v) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(5) § 60.487a(c) § 60.487a(c)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.482-11a(e) [G]§ 60.482-11a(f)(1) § 60.482-11a(f)(2) § 60.482-11a(g) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.5370(b) § 60.5400(d) § 60.5400(e) § 60.5400(f) § 60.5410(f) § 60.5420(a)(1)	instrument reading greater than or equal to 500 ppm is measured in connectors in gas and vapor and light liquid service, a leak is detected.	[G]§ 60.482-11a(b)(3)(iii) § 60.482-11a(b)(3)(iv) § 60.482-11a(c) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) [G]§ 60.485a(e) [G]§ 60.5401(f) § 60.5401(g)	§ 60.486a(e)(1) [G]§ 60.486a(e)(8) § 60.486a(e)(9) § 60.486a(f) § 60.486a(f)(1) § 60.5420(c)	§ 60.487a(c)(2) § 60.487a(c)(2)(vii) § 60.487a(c)(2)(viii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420(a) § 60.5420(a)(1)
FUG-1B	EU	600000-1	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5400(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-7a(a)(1) [G]§ 60.482-7a(a)(2) § 60.482-7a(b) [G]§ 60.482-7a(c) [G]§ 60.482-7a(d) [G]§ 60.482-7a(e) [G]§ 60.482-7a(f) [G]§ 60.482-7a(g) [G]§ 60.482-7a(h) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.5370(b) § 60.5400(d)	Except as provided in §60.5401 valves in gas/vapor service must comply with the requirements of §60.482-7a(b). At a valve in gas vapor service if an instrument reading of 500 ppm or greater is measured, a leak is detected.	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) [G]§ 60.485a(e) [G]§ 60.5401(f) § 60.5401(g)	§ 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) § 60.486a(f)(2) § 60.5420(c)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(2) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(i) § 60.487a(c)(2)(ii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420(a) § 60.5420(a)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.5400(e) § 60.5400(f) § 60.5410(f) § 60.5420(a)(1)				
FUG-1B	EU	600000-1	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5400(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-2a(a)(1) § 60.482-2a(a)(2) § 60.482-2a(b)(1) § 60.482-2a(b)(1)(i) § 60.482-2a(b)(1)(ii) § 60.482-2a(b)(2) § 60.482-2a(b)(2)(ii) § 60.482-2a(c)(1) [G]§ 60.482-2a(c)(2) § 60.482-2a(d) [G]§ 60.482-2a(d)(1) § 60.482-2a(d)(2) § 60.482-2a(d)(3) [G]§ 60.482-2a(d)(6) [G]§ 60.482-2a(e) § 60.482-2a(f) [G]§ 60.482-2a(g) § 60.482-2a(h) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(d) § 60.482-9a(f) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1)	Except as provided in §60.5401 pumps in light liquid service must comply with the requirements of §60.482-2a. The instrument reading that defines a leak in a pump in light liquid service is 5,000 parts per million (ppm) or greater for pumps handling polymerizing monomers or 2,000 ppm or greater for all other pumps, as specified in paragraphs 60.482-2a(b)(1)(i) and 60.482-2a(b)(1)(ii).	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3) § 60.482-2a(b)(2)(i) [G]§ 60.482-2a(d)(4) [G]§ 60.482-2a(d)(5) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) [G]§ 60.485a(e) [G]§ 60.5401(f) § 60.5401(g)	§ 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) § 60.486a(e)(7) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) [G]§ 60.486a(h) § 60.5420(c)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(3) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(iii) § 60.487a(c)(2)(iv) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420(a) § 60.5420(a)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.486a(a)(2) § 60.486a(k) § 60.5370(b) § 60.5400(d) § 60.5400(e) § 60.5400(f) § 60.5410(f) § 60.5420(a)(1)				
FUG-1B	EU	600000a-1	VOC	40 CFR Part 60, Subpart OOOOa	§ 60.5400a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-7a(a)(1) [G]§ 60.482-7a(a)(2) § 60.482-7a(b) [G]§ 60.482-7a(c) [G]§ 60.482-7a(d) [G]§ 60.482-7a(e) [G]§ 60.482-7a(f) [G]§ 60.482-7a(g) [G]§ 60.482-7a(h) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.5370a(a) § 60.5370a(b) § 60.5400a(d) § 60.5400a(e) § 60.5400a(f) § 60.5410a § 60.5410a(f) § 60.5415a(f)	Except as provided in §60.5401 valves in gas/vapor service or light liquid service must comply with the requirements of §60.482-7a. At a valve in gas/vapor service or light liquid service, if an instrument reading of 500 ppm or greater is measured, a leak is detected.	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) [G]§ 60.485a(e) [G]§ 60.5401a(f) § 60.5401a(g)	§ 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) § 60.486a(f)(2)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(2) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(ii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420a(a) § 60.5420a(a)(1) § 60.5422a(a)
FUG-1B	EU	600000a-1	VOC	40 CFR Part 60, Subpart OOOOa	§ 60.5400a(a) § 60.482-1a(a)	Except as provided in §60.5401 pressure relief	§ 60.482-4a(b)(2) § 60.482-9a(a)	§ 60.485a(b)(2) § 60.486a(e)	§ 60.487a(a) § 60.487a(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.482-1a(b) § 60.482-4a(a) § 60.482-4a(b)(1) § 60.482-4a(b)(2) § 60.482-4a(c) § 60.482-4a(d)(1) § 60.482-4a(d)(2) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.5370a(a) § 60.5370a(b) § 60.5400a(d) § 60.5400a(e) § 60.5400a(f) § 60.5401a(b)(2) § 60.5401a(b)(3)(i) § 60.5401a(b)(3)(ii) § 60.5401a(b)(4)(i) § 60.5401a(b)(4)(ii) § 60.5410a § 60.5410a(f) § 60.5415a(f)	device in gas/vapor service must comply with the requirements of §60.482-4a. Except during pressure releases, each pressure relief device in gas/vapor service shall be operated with no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as determined by the methods specified in §60.485a(c).	§ 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) § 60.5401a(b)(1) § 60.5401a(g)	§ 60.486a(e)(1) [G]§ 60.486a(e)(10) § 60.486a(e)(3) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) [G]§ 60.5421a(b)	§ 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420a(a) § 60.5420a(a)(1) § 60.5422a(a) § 60.5422a(b) [G]§ 60.5422a(c)
FUG-1E	EU	600000-1	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5400(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-2a(a)(1) § 60.482-2a(a)(2) § 60.482-2a(b)(1) § 60.482-2a(b)(1)(i) § 60.482-2a(b)(1)(ii) § 60.482-2a(b)(2)	Except as provided in §60.5401 pumps in light liquid service must comply with the requirements of §60.482-2a. The instrument reading that defines a leak in a pump in light liquid service is 5,000 parts per million (ppm) or greater for pumps handling	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3) § 60.482-2a(b)(2)(i) [G]§ 60.482-2a(d)(4) [G]§ 60.482-2a(d)(5) § 60.482-9a(a) § 60.485a(a)	§ 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) § 60.486a(e)(7) [G]§ 60.486a(e)(8)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(3) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(iii) § 60.487a(c)(2)(iv) § 60.487a(c)(2)(xi)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.482-2a(b)(2)(ii) § 60.482-2a(c)(1) [G]§ 60.482-2a(c)(2) § 60.482-2a(d) [G]§ 60.482-2a(d)(1) § 60.482-2a(d)(2) § 60.482-2a(d)(3) [G]§ 60.482-2a(d)(6) [G]§ 60.482-2a(e) § 60.482-2a(f) [G]§ 60.482-2a(g) § 60.482-2a(h) § 60.482-9a(a) § 60.482-9a(b) [G]§ 60.482-9a(d) § 60.482-9a(f) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.5370(b) § 60.5400(d) § 60.5400(e) § 60.5400(f) § 60.5410(f) § 60.5420(a)(1)	polymerizing monomers or 2,000 ppm or greater for all other pumps, as specified in paragraphs 60.482-2a(b)(1)(i) and 60.482-2a(b)(1)(ii).	[G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) [G]§ 60.485a(e) [G]§ 60.5401(f) § 60.5401(g)	§ 60.486a(f) § 60.486a(f)(1) [G]§ 60.486a(h) § 60.5420(c)	§ 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420(a) § 60.5420(a)(1)
FUG-1E	EU	600000-1	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5400(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-4a(a) § 60.482-4a(b)(1) § 60.482-4a(b)(2)	Except as provided in §60.5401 pressure relief device in gas/vapor service must comply with the requirements of §60.482-4a. Except during pressure	§ 60.482-4a(b)(2) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2)	§ 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(10) § 60.486a(e)(3) [G]§ 60.486a(e)(4)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.482-4a(c) § 60.482-4a(d)(1) § 60.482-4a(d)(2) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.5370(b) § 60.5400(d) § 60.5400(e) § 60.5400(f) § 60.5401(b)(1) § 60.5401(b)(2) § 60.5401(b)(3)(i) § 60.5401(b)(3)(ii) § 60.5401(b)(4)(i) § 60.5401(b)(4)(ii) § 60.5410(f) § 60.5420(a)(1) § 60.5422(b)	releases, each pressure relief device in gas/vapor service shall be operated with no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as determined by the methods specified in §60.485a(c).	§ 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) § 60.5401(b)(1) § 60.5401(g)	[G]§ 60.486a(e)(8) § 60.5420(c) [G]§ 60.5421(b)	§ 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420(a) § 60.5420(a)(1) § 60.5422(b) [G]§ 60.5422(c)
FUG-1E	EU	600000-1	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5400(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-7a(a)(1) [G]§ 60.482-7a(a)(2) § 60.482-7a(b) [G]§ 60.482-7a(c) [G]§ 60.482-7a(d) [G]§ 60.482-7a(e) [G]§ 60.482-7a(f) [G]§ 60.482-7a(g) [G]§ 60.482-7a(h) § 60.485a(b)	Except as provided in §60.5401 valves in gas/vapor service must comply with the requirements of §60.482-7a(b). At a valve in gas vapor service if an instrument reading of 500 ppm or greater is measured, a leak is detected.	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) [G]§ 60.485a(e) [G]§ 60.5401(f) § 60.5401(g)	§ 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) § 60.486a(f)(2) § 60.5420(c)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(2) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(i) § 60.487a(c)(2)(ii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.5370(b) § 60.5400(d) § 60.5400(e) § 60.5400(f) § 60.5410(f) § 60.5420(a)(1)				§ 60.5420(a)(1)
FUG-1E	EU	600000-1	VOC	40 CFR Part 60, Subpart OOOO	§ 60.5400(a) § 60.482-11a(b)(2) § 60.482-11a(b)(3) § 60.482-11a(b)(3)(i) § 60.482-11a(d) [G]§ 60.482-11a(e) [G]§ 60.482-11a(f)(1) § 60.482-11a(f)(2) § 60.482-11a(g) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.5370(b) § 60.5400(d) § 60.5400(e) § 60.5400(f) § 60.5410(f) § 60.5420(a)(1)	Except as provided in §60.5401 connectors in gas and vapor and light liquid service must comply with the requirements of §60.482-11a(b)(2). If an instrument reading greater than or equal to 500 ppm is measured in connectors in gas and vapor and light liquid service, a leak is detected.	§ 60.482-11a(a) § 60.482-11a(b) § 60.482-11a(b)(1) § 60.482-11a(b)(3) § 60.482-11a(b)(3)(ii) [G]§ 60.482-11a(b)(3)(iii) § 60.482-11a(b)(3)(iv) § 60.482-11a(c) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) [G]§ 60.485a(e) [G]§ 60.5401(f) § 60.5401(g)	§ 60.482-11a(b)(3)(v) § 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(8) § 60.486a(e)(9) § 60.486a(f) § 60.486a(f)(1) § 60.5420(c)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(5) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(vii) § 60.487a(c)(2)(viii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420(a) § 60.5420(a)(1)
FUG-1E	EU	600000a-1	VOC	40 CFR Part 60, Subpart OOOOa	§ 60.5400a(a) § 60.482-1a(a) § 60.482-1a(b)	Except as provided in §60.5401 valves in gas/vapor service or light	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3)	§ 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.482-7a(a)(1) [G]§ 60.482-7a(a)(2) § 60.482-7a(b) [G]§ 60.482-7a(c) [G]§ 60.482-7a(d) [G]§ 60.482-7a(e) [G]§ 60.482-7a(f) [G]§ 60.482-7a(g) [G]§ 60.482-7a(h) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.5370a(a) § 60.5370a(b) § 60.5400a(d) § 60.5400a(e) § 60.5400a(f) § 60.5410a § 60.5410a(f) § 60.5415a(f)	liquid service must comply with the requirements of §60.482-7a. At a valve in gas/vapor service or light liquid service, if an instrument reading of 500 ppm or greater is measured, a leak is detected.	§ 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) [G]§ 60.485a(e) [G]§ 60.5401a(f) § 60.5401a(g)	[G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) § 60.486a(f)(2)	§ 60.487a(b)(2) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(ii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420a(a) § 60.5420a(a)(1) § 60.5422a(a)
FUG-1E	EU	600000a-1	VOC	40 CFR Part 60, Subpart OOOOa	§ 60.5400a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-4a(a) § 60.482-4a(b)(1) § 60.482-4a(b)(2) § 60.482-4a(c) § 60.482-4a(d)(1) § 60.482-4a(d)(2) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1)	Except as provided in §60.5401 pressure relief device in gas/vapor service must comply with the requirements of §60.482-4a. Except during pressure releases, each pressure relief device in gas/vapor service shall be operated with no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as determined	§ 60.482-4a(b)(2) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) § 60.5401a(b)(1) § 60.5401a(g)	§ 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(10) § 60.486a(e)(3) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) [G]§ 60.5421a(b)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420a(a) § 60.5420a(a)(1) § 60.5422a(a) § 60.5422a(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.5370a(a) § 60.5370a(b) § 60.5400a(d) § 60.5400a(e) § 60.5400a(f) § 60.5401a(b)(2) § 60.5401a(b)(3)(i) § 60.5401a(b)(3)(ii) § 60.5401a(b)(4)(i) § 60.5401a(b)(4)(ii) § 60.5410a § 60.5410a(f) § 60.5415a(f)	by the methods specified in §60.485a(c).			[G]§ 60.5422a(c)
FUG-1J	EU	600000a-1	VOC	40 CFR Part 60, Subpart OOOOa	§ 60.5400a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-7a(a)(1) [G]§ 60.482-7a(a)(2) § 60.482-7a(b) [G]§ 60.482-7a(c) [G]§ 60.482-7a(d) [G]§ 60.482-7a(e) [G]§ 60.482-7a(f) [G]§ 60.482-7a(g) [G]§ 60.482-7a(h) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.5370a(a) § 60.5370a(b)	Except as provided in §60.5401 valves in gas/vapor service or light liquid service must comply with the requirements of §60.482-7a. At a valve in gas/vapor service or light liquid service, if an instrument reading of 500 ppm or greater is measured, a leak is detected.	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) [G]§ 60.485a(e) [G]§ 60.5401a(f) § 60.5401a(g)	§ 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) § 60.486a(f)(2)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(2) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(ii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420a(a) § 60.5420a(a)(1) § 60.5422a(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.5400a(d) § 60.5400a(e) § 60.5400a(f) § 60.5410a § 60.5410a(f) § 60.5415a(f)				
FUG-1J	EU	600000a-1	VOC	40 CFR Part 60, Subpart OOOOa	§ 60.5400a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-4a(a) § 60.482-4a(b)(1) § 60.482-4a(b)(2) § 60.482-4a(c) § 60.482-4a(d)(1) § 60.482-4a(d)(2) § 60.482-9a(a) § 60.482-9a(b) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2) § 60.486a(k) § 60.5370a(a) § 60.5370a(b) § 60.5400a(d) § 60.5400a(e) § 60.5400a(f) § 60.5401a(b)(2) § 60.5401a(b)(3)(i) § 60.5401a(b)(3)(ii) § 60.5401a(b)(4)(i) § 60.5401a(b)(4)(ii) § 60.5410a § 60.5410a(f) § 60.5415a(f)	Except as provided in §60.5401 pressure relief device in gas/vapor service must comply with the requirements of §60.482-4a. Except during pressure releases, each pressure relief device in gas/vapor service shall be operated with no detectable emissions, as indicated by an instrument reading of less than 500 ppm above background, as determined by the methods specified in §60.485a(c).	§ 60.482-4a(b)(2) § 60.482-9a(a) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) § 60.5401a(b)(1) § 60.5401a(g)	§ 60.485a(b)(2) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(10) § 60.486a(e)(3) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) [G]§ 60.5421a(b)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420a(a) § 60.5420a(a)(1) § 60.5422a(a) § 60.5422a(b) [G]§ 60.5422a(c)
FUG-1J	EU	600000b	METHANE	40 CFR Part 60,	§ 60.5401(a)	As an alternative to §	§ 60.5401b(a)	§ 60.5401b(a)	§ 60.5401b(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		-FUG	& VOC	Subpart OOOOb	[G]§ 60.5370b(a) § 60.5370b(b) § 60.5401b(a) § 60.5401b(a)(1) § 60.5401b(a)(2) [G]§ 60.5401b(c) [G]§ 60.5401b(f) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(k) § 60.5410b(h) § 60.5415b(j)	60.5400b, the owner or operator of connectors in heavy liquid service may comply with the requirements in paragraph (g) of this section. If evidence of a potential leak is found at any time by AVO, or any other detection method, the owner or operator must comply with either paragraph (g)(1) or (2) of this section.	[G]§ 60.5401b(c) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(m) § 60.5410b(h)(10) § 60.5410b(h)(6) § 60.5410b(h)(8) § 60.5410b(h)(9) § 60.5415b(j)(10) § 60.5415b(j)(6) § 60.5415b(j)(8) § 60.5415b(j)(9)	§ 60.5401b(m) § 60.5415b(j)(15) § 60.5420b(c) § 60.5421b(a) [G]§ 60.5421b(b)	§ 60.5401b(l) [G]§ 60.5401b(l) § 60.5415b(j)(14) § 60.5420b(a) § 60.5420b(a)(1) § 60.5420b(b) [G]§ 60.5420b(b)(1) § 60.5420b(b)(15) § 60.5420b(d) § 60.5422b(a) [G]§ 60.5422b(b)
FUG-1J	EU	60000Ob -FUG	METHANE & VOC	40 CFR Part 60, Subpart OOOOb	[G]§ 60.5401b(f) [G]§ 60.5370b(a) § 60.5370b(b) § 60.5401b(a) § 60.5401b(a)(1) § 60.5401b(a)(2) [G]§ 60.5401b(c) [G]§ 60.5401b(f) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(k) § 60.5410b(h) § 60.5415b(j)	As an alternative to § 60.5400b, the owner or operator of valves in gas/vapor or light liquid service may comply with the requirements in paragraph (e) of this section. An instrument reading of 500 ppmv or greater is a leak.	§ 60.5401b(a) [G]§ 60.5401b(c) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(m) § 60.5410b(h)(10) § 60.5410b(h)(6) § 60.5410b(h)(8) § 60.5410b(h)(9) § 60.5415b(j)(10) § 60.5415b(j)(6) § 60.5415b(j)(8) § 60.5415b(j)(9)	§ 60.5401b(a) § 60.5401b(m) § 60.5415b(j)(15) § 60.5420b(c) § 60.5421b(a) [G]§ 60.5421b(b)	§ 60.5401b(a) § 60.5401b(l) [G]§ 60.5401b(l) § 60.5415b(j)(14) § 60.5420b(a) § 60.5420b(a)(1) § 60.5420b(b) [G]§ 60.5420b(b)(1) § 60.5420b(b)(15) § 60.5420b(d) § 60.5422b(a) [G]§ 60.5422b(b)
FUG-1J	EU	60000Ob -FUG	METHANE & VOC	40 CFR Part 60, Subpart OOOOb	§ 60.5401(a) [G]§ 60.5370b(a) § 60.5370b(b) § 60.5401b(a) § 60.5401b(a)(1) § 60.5401b(a)(2) [G]§ 60.5401b(c) [G]§ 60.5401b(f) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(k) § 60.5410b(h)	As an alternative to § 60.5400b, the owner or operator of valves in heavy liquid service may comply with the requirements in paragraph (g) of this section. If evidence of a potential leak is found at any time by AVO, or any other detection method, the owner or operator must comply with either	§ 60.5401b(a) [G]§ 60.5401b(c) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(m) § 60.5410b(h)(10) § 60.5410b(h)(6) § 60.5410b(h)(8) § 60.5410b(h)(9) § 60.5415b(j)(10) § 60.5415b(j)(6) § 60.5415b(j)(8)	§ 60.5401b(a) § 60.5401b(m) § 60.5415b(j)(15) § 60.5420b(c) § 60.5421b(a) [G]§ 60.5421b(b)	§ 60.5401b(a) § 60.5401b(l) [G]§ 60.5401b(l) § 60.5415b(j)(14) § 60.5420b(a) § 60.5420b(a)(1) § 60.5420b(b) [G]§ 60.5420b(b)(1) § 60.5420b(b)(15) § 60.5420b(d) § 60.5422b(a) [G]§ 60.5422b(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.5415b(j)	paragraph (g)(1) or (2) of this section.	§ 60.5415b(j)(9)		
FUG-1J	EU	600000b-FUG	METHANE & VOC	40 CFR Part 60, Subpart OOOOb	§ 60.5401(a) [G]§ 60.5370b(a) § 60.5370b(b) § 60.5401b(a) § 60.5401b(a)(1) § 60.5401b(a)(2) [G]§ 60.5401b(c) [G]§ 60.5401b(f) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(k) § 60.5410b(h) § 60.5415b(j)	As an alternative to § 60.5400b, the owner or operator of pumps in heavy liquid service may comply with the requirements in paragraph (g) of this section. If evidence of a potential leak is found at any time by AVO, or any other detection method, the owner or operator must comply with either paragraph (g)(1) or (2) of this section.	§ 60.5401b(a) [G]§ 60.5401b(c) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(m) § 60.5410b(h)(10) § 60.5410b(h)(6) § 60.5410b(h)(8) § 60.5410b(h)(9) § 60.5415b(j)(10) § 60.5415b(j)(6) § 60.5415b(j)(8) § 60.5415b(j)(9)	§ 60.5401b(a) § 60.5401b(m) § 60.5415b(j)(15) § 60.5420b(c) § 60.5421b(a) [G]§ 60.5421b(b)	§ 60.5401b(a) § 60.5401b(l) [G]§ 60.5401b(l) § 60.5415b(j)(14) § 60.5420b(a) § 60.5420b(a)(1) § 60.5420b(b) [G]§ 60.5420b(b)(1) § 60.5420b(b)(15) § 60.5420b(d) § 60.5422b(a) [G]§ 60.5422b(b)
FUG-1J	EU	600000b-FUG	METHANE & VOC	40 CFR Part 60, Subpart OOOOb	§ 60.5401b(a) [G]§ 60.5370b(a) § 60.5370b(b) § 60.5401b(a) § 60.5401b(a)(1) § 60.5401b(a)(2) [G]§ 60.5401b(c) [G]§ 60.5401b(f) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(k) § 60.5410b(h) § 60.5415b(j)	As an alternative to § 60.5400b, the owner or operator of connectors in gas/vapor or light liquid service may comply with the requirements in paragraph (h) of this section. If an instrument reading greater than or equal to 500 ppmv is measured, a leak is detected.	§ 60.5401b(a) [G]§ 60.5401b(c) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(m) § 60.5410b(h)(10) § 60.5410b(h)(6) § 60.5410b(h)(8) § 60.5410b(h)(9) § 60.5415b(j)(10) § 60.5415b(j)(6) § 60.5415b(j)(8) § 60.5415b(j)(9)	§ 60.5401b(a) § 60.5401b(m) § 60.5415b(j)(15) § 60.5420b(c) § 60.5421b(a) [G]§ 60.5421b(b)	§ 60.5401b(a) § 60.5401b(l) [G]§ 60.5401b(l) § 60.5415b(j)(14) § 60.5420b(a) § 60.5420b(a)(1) § 60.5420b(b) [G]§ 60.5420b(b)(1) § 60.5420b(b)(15) § 60.5420b(d) § 60.5422b(a) [G]§ 60.5422b(b)
FUG-1J	EU	600000b-FUG	METHANE & VOC	40 CFR Part 60, Subpart OOOOb	§ 60.5401b(a) [G]§ 60.5370b(a) § 60.5370b(b) § 60.5401b(a) § 60.5401b(a)(1) § 60.5401b(a)(2) [G]§ 60.5401b(c) [G]§ 60.5401b(f) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(k) § 60.5410b(h) § 60.5415b(j)	As an alternative to § 60.5400b, the owner or operator of pressure relief devices in gas/vapor service may comply with the requirements in paragraph (c) of this section. A leak is defined as an instrument reading of 500 ppmv or	§ 60.5401b(a) [G]§ 60.5401b(c) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(m) § 60.5410b(h)(10) § 60.5410b(h)(6) § 60.5410b(h)(8) § 60.5410b(h)(9)	§ 60.5401b(a) § 60.5401b(m) § 60.5415b(j)(15) § 60.5420b(c) § 60.5421b(a) [G]§ 60.5421b(b)	§ 60.5401b(a) § 60.5401b(l) [G]§ 60.5401b(l) § 60.5415b(j)(14) § 60.5420b(a) § 60.5420b(a)(1) § 60.5420b(b) [G]§ 60.5420b(b)(1) § 60.5420b(b)(15)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.5401b(h) § 60.5401b(k) § 60.5410b(h) § 60.5415b(j)	greater.	§ 60.5415b(j)(10) § 60.5415b(j)(6) § 60.5415b(j)(8) § 60.5415b(j)(9)		§ 60.5420b(d) § 60.5422b(a) [G]§ 60.5422b(b)
FUG-1J	EU	600000b-FUG	METHANE & VOC	40 CFR Part 60, Subpart OOOOb	§ 60.5401(a) [G]§ 60.5370b(a) § 60.5370b(b) § 60.5401b(a) § 60.5401b(a)(1) § 60.5401b(a)(2) [G]§ 60.5401b(c) [G]§ 60.5401b(f) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(k) § 60.5410b(h) § 60.5415b(j)	As an alternative to § 60.5400b, the owner or operator of pressure relief devices in light liquid or heavy liquid service may comply with the requirements in paragraph (g) of this section. If evidence of a potential leak is found at any time by AVO, or any other detection method, the owner or operator must comply with either paragraph (g)(1) or (2) of this section.	§ 60.5401b(a) [G]§ 60.5401b(c) [G]§ 60.5401b(g) [G]§ 60.5401b(h) § 60.5401b(m) § 60.5410b(h)(10) § 60.5410b(h)(6) § 60.5410b(h)(8) § 60.5410b(h)(9) § 60.5415b(j)(10) § 60.5415b(j)(6) § 60.5415b(j)(8) § 60.5415b(j)(9)	§ 60.5401b(a) § 60.5401b(m) § 60.5415b(j)(15) § 60.5420b(c) § 60.5421b(a) [G]§ 60.5421b(b)	§ 60.5401b(a) § 60.5401b(l) [G]§ 60.5401b(l) § 60.5415b(j)(14) § 60.5420b(a) § 60.5420b(a)(1) § 60.5420b(b) [G]§ 60.5420b(b)(1) § 60.5420b(b)(15) § 60.5420b(d) § 60.5422b(a) [G]§ 60.5422b(b)
FUG-GPX	EU	600000a-1	VOC	40 CFR Part 60, Subpart OOOOa	§ 60.5400a(a) § 60.482-1a(a) § 60.482-1a(b) § 60.482-7a(a)(1) [G]§ 60.482-7a(a)(2) § 60.482-7a(b) [G]§ 60.482-7a(c) [G]§ 60.482-7a(d) [G]§ 60.482-7a(e) [G]§ 60.482-7a(f) [G]§ 60.482-7a(g) [G]§ 60.482-7a(h) § 60.485a(b) § 60.485a(c) § 60.485a(c)(1) § 60.485a(f) § 60.486a(a)(1) § 60.486a(a)(2)	Except as provided in §60.5401 valves in gas/vapor service or light liquid service must comply with the requirements of §60.482-7a. At a valve in gas/vapor service or light liquid service, if an instrument reading of 500 ppm or greater is measured, a leak is detected.	§ 60.482-1a(f)(1) § 60.482-1a(f)(2) [G]§ 60.482-1a(f)(3) § 60.485a(a) [G]§ 60.485a(b)(1) § 60.485a(b)(2) § 60.485a(c)(2) § 60.485a(d) § 60.485a(d)(2) § 60.485a(d)(3) [G]§ 60.485a(e) [G]§ 60.5401a(f) § 60.5401a(g)	§ 60.485a(b)(2) [G]§ 60.486a(a)(3) [G]§ 60.486a(b) [G]§ 60.486a(c) § 60.486a(e) § 60.486a(e)(1) [G]§ 60.486a(e)(2) [G]§ 60.486a(e)(4) [G]§ 60.486a(e)(8) § 60.486a(f) § 60.486a(f)(1) § 60.486a(f)(2)	§ 60.487a(a) § 60.487a(b) § 60.487a(b)(1) § 60.487a(b)(2) § 60.487a(c) § 60.487a(c)(1) § 60.487a(c)(2) § 60.487a(c)(2)(ii) § 60.487a(c)(2)(xi) § 60.487a(c)(3) § 60.487a(c)(4) § 60.487a(e) § 60.5420a(a) § 60.5420a(a)(1) § 60.5422a(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.486a(k) § 60.5370a(a) § 60.5370a(b) § 60.5400a(d) § 60.5400a(e) § 60.5400a(f) § 60.5410a § 60.5410a(f) § 60.5415a(f)				
GRP-COMPRESSOR	EU	600000a-03	VOC	40 CFR Part 60, Subpart OOOOa	§ 60.5385a(a)(1) § 60.5370a(a) § 60.5370a(b) § 60.5385a § 60.5385a(a) § 60.5385a(b) § 60.5385a(c) § 60.5385a(d) § 60.5410a § 60.5415a(c) § 60.5415a(c)(2) § 60.5415a(c)(3)	For each reciprocating compressor, the owner or operator must replace the rod packing on or before the compressor has operated for 26,000 hours. The number of hours of operation must be continuously monitored beginning upon initial startup of your reciprocating compressor affected facility, August 2, 2016, or the date of the most recent reciprocating compressor rod packing replacement, whichever is later.	§ 60.5410a(c)(1) § 60.5415a(c)(1)	§ 60.5410a(c)(4) § 60.5420a(c) [G]§ 60.5420a(c)(3)	§ 60.5410a(c)(3) § 60.5420a(a) § 60.5420a(a)(1) § 60.5420a(b) [G]§ 60.5420a(b)(1) § 60.5420a(b)(11) [G]§ 60.5420a(b)(13) [G]§ 60.5420a(b)(14) [G]§ 60.5420a(b)(4)
H-700-3	EU	60Dc-03	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a)
H-700-3	EU	60Dc-03	PM (Opacity)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						heat input capacity of 2.9-29 megawatts (MW).			
H-700-3	EU	60Dc-03	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a)
H-781	EU	60Dc-03	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a)
H-781	EU	60Dc-03	PM (Opacity)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a)
H-781	EU	60Dc-03	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a)
HTR-3	EU	60Dc-03	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						megawatts (MW).			
HTR-3	EU	60Dc-03	PM (Opacity)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a)
HTR-3	EU	60Dc-03	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a)
J-AMINE	EU	600000a-02	SO ₂	40 CFR Part 60, Subpart OOOOa	§ 60.5365a(g)(3) § 60.5370a(b)	Owners or operators of facilities that have a design capacity less than 2 long tons per day (LT/D) of hydrogen sulfide (H ₂ S) in the acid gas (expressed as sulfur) are required to comply with recordkeeping and reporting requirements specified in §60.5423a(c), but are not required to comply with §§60.5405a through 60.5407a and §§60.5410a(g) and 60.5415a(g).	None	§ 60.5423a(c)	§ 60.5420a(a) § 60.5420a(a)(1) § 60.5420a(b) [G]§ 60.5420a(b)(1) § 60.5420a(b)(11) [G]§ 60.5420a(b)(13) [G]§ 60.5420a(b)(14)
JE-1	EU	60III-0003	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 8 KW and less than 19 KW and a	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4211(c) [G]§ 60.4211(f)	displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 6.6 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.			
JE-1	EU	60III-0003	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 7.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
JE-1	EU	60III-0003	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 19 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.40 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
JE-1	EU	63ZZZZ-0006	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
JH-1	EU	R200-0001	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(a)	No person may cause, suffer, allow, or permit emissions of SO ₂ from any liquid fuel-fired steam generator, furnace, or heater to exceed 440 ppmv at actual stack conditions and averaged over 3-hours.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)
PORTENG	EU	60IIII-0003	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 8 KW and less than 19 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 6.6 g/KW-hr, as stated in 40 CFR	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.			
PORTENG	EU	60IIII-0003	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 37 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 7.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(i)-(ii), 40 CFR 1039-Appendix I, and Table 2 to this subpart.	None	None	None
PORTENG	EU	60IIII-0003	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 60.4202(a)(1)(ii) § 60.4202(a)(1)(ii)-Table 2 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power less than 19 KW and a displacement of less than 10 liters per cylinder and is a 2008 model year and later must comply with a PM emission limit of 0.40 g/KW-hr, as stated in 40 CFR 60.4202(a)(1)(ii) and Table 2 to this subpart.	None	None	None
PORTENG	EU	63ZZZZ-0006	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
PORTHTR	EU	R200-0001	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(a)	No person may cause, suffer, allow, or permit emissions of SO ₂ from any liquid fuel-fired steam generator, furnace, or heater to exceed 440 ppmv at actual stack conditions and averaged over 3-hours.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)
TEG-1	EU	63HH-01	112(B) HAPS	40 CFR Part 63, Subpart HH	§ 63.764(e)(1)(ii) § 63.764(a) § 63.764(e)(1) § 63.764(j) § 63.775(c)(8)	The owner or operator of an area source is exempt from the requirements of §63.764(d) when the actual average emissions of benzene from the glycol dehydration unit process vent to the atmosphere < 0.90 megagram/yr, as determined by the procedures specified in §63.772(b)(2) of this subpart.	[G]§ 63.772(b)(2)	§ 63.774(d)(1) § 63.774(d)(1)(ii)	None
V-1	EU	63HH-01	112(B) HAPS	40 CFR Part 63, Subpart HH	§ 63.764(e)(1)(ii) § 63.764(a) § 63.764(e)(1) § 63.764(j) § 63.775(c)(8)	The owner or operator of an area source is exempt from the requirements of §63.764(d) when the actual average emissions of benzene from the glycol	[G]§ 63.772(b)(2)	§ 63.774(d)(1) § 63.774(d)(1)(ii)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						dehydration unit process vent to the atmosphere < 0.90 megagram/yr, as determined by the procedures specified in §63.772(b)(2) of this subpart.			

Additional Monitoring Requirements

Periodic Monitoring Summary 53

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: EH-1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: R200-0001
Pollutant: SO ₂	Main Standard: § 112.9(a)
Monitoring Information	
Indicator: Sulfur Content of Fuel	
Minimum Frequency: Quarterly and within 24 hours of any fuel change	
Averaging Period: N/A	
Deviation Limit: Less than 15 ppm Sulfur Content in Fuel.	
Periodic Monitoring Text: Measure and record the sulfur content of the fuel. Any monitoring data above the deviation limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: JH-1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: R200-0001
Pollutant: SO ₂	Main Standard: § 112.9(a)
Monitoring Information	
Indicator: Sulfur Content of Fuel	
Minimum Frequency: Quarterly and within 24 hours of any fuel change	
Averaging Period: N/A	
Deviation Limit: Less than 15 ppm Sulfur Content in Fuel.	
Periodic Monitoring Text: Measure and record the sulfur content of the fuel. Any monitoring data above the deviation limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: PORTHTR	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: R200-0001
Pollutant: SO ₂	Main Standard: § 112.9(a)
Monitoring Information	
Indicator: Sulfur Content of Fuel	
Minimum Frequency: Quarterly and within 24 hours of any fuel change	
Averaging Period: N/A	
Deviation Limit: Less than 15 ppm Sulfur Content in Fuel.	
Periodic Monitoring Text: Measure and record the sulfur content of the fuel. Any monitoring data above the deviation limit shall be considered and reported as a deviation.	

Permit Shield

Permit Shield 57

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
C-B8	N/A	30 TAC Chapter 112, Sulfur Compounds	Engine does not combust liquid fuel.
C-B8	N/A	30 TAC Chapter 117, Subchapter B	Engine is not located in one of the listed counties.
C-B8	N/A	40 CFR Part 60, Subpart JJJJ	This regulation has no requirements for this existing 1340 HP four stroke lean burn engine, that was originally manufactured before 01/01/2008, until it is modified or reconstructed after 06/12/2006.
EC-101-B	N/A	40 CFR Part 60, Subpart OOOOa	The centrifugal compressor does not use wet seals.
EC-101-E	N/A	40 CFR Part 60, Subpart OOOOa	The centrifugal compressor does not use wet seals.
EC-101-J	N/A	40 CFR Part 60, Subpart OOOOa	The centrifugal compressor does not use wet seals.
FLR-B	N/A	40 CFR Part 60, Subpart A	This flare is not used to comply with applicable subparts of 40 CFR Part 60 or Part 61.
FLR-B	N/A	40 CFR Part 63, Subpart A	This flare is not used to comply with applicable subparts of 40 CFR Part 63.
FLR-E	N/A	40 CFR Part 60, Subpart A	This flare is not used to comply with applicable subparts of 40 CFR Part 60 or Part 61
FLR-E	N/A	40 CFR Part 63, Subpart A	This flare is not used to comply with applicable subparts of 40 CFR Part 63
FLR-J	N/A	40 CFR Part 60, Subpart A	This flare is not used to comply with applicable subparts of 40 CFR Part 63.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
FLR-J	N/A	40 CFR Part 63, Subpart A	This flare is not used to comply with applicable subparts of 40 CFR Part 60 or Part 61.
H-700-3	N/A	40 CFR Part 63, Subpart DDDDD	Heater is not located at a major source of HAPs.
H-701	N/A	40 CFR Part 60, Subpart Dc	Reboiler has a maximum design capacity of less than 10 MMBtu/hr.
H-701	N/A	40 CFR Part 63, Subpart DDDDD	Reboiler is not located at a major source of HAPs.
H-741	N/A	40 CFR Part 60, Subpart Dc	Reboiler is not located at a major source of HAPs.
H-741	N/A	40 CFR Part 63, Subpart DDDDD	Reboiler has a maximum design capacity of less than 10 MMBtu/hr.
H-781	N/A	40 CFR Part 63, Subpart DDDDD	Reboiler is not located at a major source of HAPs.
H-800	N/A	40 CFR Part 60, Subpart Dc	Reboiler has a maximum design capacity of less than 10 MMBtu/hr.
H-800	N/A	40 CFR Part 63, Subpart DDDDD	Reboiler is not located at a major source of HAPs.
HMHTR-1A	N/A	40 CFR Part 60, Subpart Db	Heater commenced construction prior to June 19, 1984 and has a maximum design capacity of less than 100 MMBtu/hr
HMHTR-1A	N/A	40 CFR Part 60, Subpart Dc	Heater commenced construction prior to June 19, 1989 and has a maximum design capacity of less than 10 MMBtu/hr
HMHTR-1A	N/A	40 CFR Part 63, Subpart DDDDD	Heater is not located at a major source of HAPs

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
HTR-1	N/A	40 CFR Part 60, Subpart Dc	Reboiler has a maximum design capacity of less than 10 MMBtu/hr.
HTR-1	N/A	40 CFR Part 63, Subpart DDDDD	Reboiler is not located at a major source of HAPs.
HTR-2	N/A	40 CFR Part 60, Subpart Dc	Reboiler has a maximum design capacity of less than 10 MMBtu/hr.
HTR-2	N/A	40 CFR Part 63, Subpart DDDDD	Reboiler is not located at a major source of HAPs.
HTR-3	N/A	40 CFR Part 63, Subpart DDDDD	Reboiler is not located at a major source of HAPs.
PW-B-TK1	N/A	40 CFR Part 60, Subpart OOOOa	The tank was modified after December 6, 2022.
PW-B-TK1	N/A	40 CFR Part 60, Subpart OOOOb	The tank has a potential to emit less than 6 tpy of VOC and 20 tpy of methane pre-control.
R-141-E	N/A	40 CFR Part 60, Subpart OOOOa	The centrifugal compressor does not use wet seals.
R-141-J	N/A	40 CFR Part 60, Subpart OOOOa	The centrifugal compressor does not use wet seals.
TK-1	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.
TK-2	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.
TK-22	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.
TK-3	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.
TK-4	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.
TK-5	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.
TK-6	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
TK-901	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.
TK-902A	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.
TK-903	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.
TK-904A	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.
TK-904B	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.
TK-905	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 19,800 gallons.

New Source Review Authorization References

New Source Review Authorization References 62

New Source Review Authorization References by Emission Unit 63

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 143035	Issuance Date: 03/26/2025
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 11/01/2003
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.359	Version No./Date: 09/10/2013

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
C-101	RECIPROCATING COMPRESSOR	143035
C-102	RECIPROCATING COMPRESSOR	143035
C-105	LP INLET COMPRESSOR	143035
C-106	LP INLET COMPRESSOR	143035
C-201	RECIPROCATING COMPRESSOR	143035
C-202	RECIPROCATING COMPRESSOR	143035
C-203	RECIPROCATING COMPRESSOR	143035
C-204	RECIPROCATING COMPRESSOR	143035
C-205	RECIPROCATING COMPRESSOR	143035
C-206	RECIPROCATING COMPRESSOR	143035
C-207	RECIPROCATING COMPRESSOR	143035
C-208	RECIPROCATING COMPRESSOR	143035
C-301	RECIPROCATING COMPRESSOR	143035
C-302	RECIPROCATING COMPRESSOR	143035
C-303	RECIPROCATING COMPRESSOR	143035
C-304	RECIPROCATING COMPRESSOR	143035
C-305	RECIPROCATING COMPRESSOR	143035
C-306	RECIPROCATING COMPRESSOR	143035
C-307	RECIPROCATING COMPRESSOR	143035
C-401	LP INLET COMPRESSOR	143035
C-402	LP INLET COMPRESSOR	143035

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
C-403	LP INLET COMPRESSOR	143035
C-404	LP INLET COMPRESSOR	143035
C-405	INLET COMPRESSOR	143035
C-406	INLET COMPRESSOR	143035
C-407	INLET COMPRESSOR	143035
C-408	INLET COMPRESSOR	143035
C-409	INLET COMPRESSOR	143035
C-410	INLET COMPRESSOR	143035
C-411	INLET COMPRESSOR	143035
C-701	RESIDUE COMPRESSOR	143035
C-702	RESIDUE COMPRESSOR	143035
C-703	RESIDUE COMPRESSOR	143035
C-704	RESIDUE COMPRESSOR	143035
C-705	RESIDUE COMPRESSOR	143035
C-706	RESIDUE COMPRESSOR	143035
C-B8	1340 HP CATERPILLAR G3516TALE ENGINE	143035
E-AMINE	E-AMINE	143035
E-GEN1	CUMMINS QSL9-G7	143035
E-GEN2	PERKINS SD400 EMERGENCY GENERATOR ENGINE	143035
EC-101-B	CENTRIFUGAL DRY SEAL COMPRESSOR	143035
EC-101-E	CENTRIFUGAL DRY SEAL COMPRESSOR	143035

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
EC-101-J	CENTRIFUGAL DRY SEAL COMPRESSOR	143035
EE-1	EMERGENCY ENGINE	106.263/11/01/2001 [166242]
EH-1	EMERGENCY HEATER	106.263/11/01/2001 [166242]
FLR-B	BENEDUM GP FLARE	143035
FLR-E	EDWARD GP FLARE	143035
FLR-J	JOYCE GP FLARE	143035
FUG-1B	FUGITIVES - BENEDUM	143035
FUG-1E	FUGITIVES - EDWARD	143035
FUG-1J	FUGITIVES-JOYCE	143035
FUG-GPX	FUGITIVES - GRAND PRIX	106.261/11/01/2003 [172499], 106.262/11/01/2003 [172499]
H-700-3	TRIM REBOILER	143035
H-701	HOT OIL HEATER	143035
H-741	REGEN GAS HEATER	143035
H-781	TRIM REBOILER	143035
H-800	CRYO HEATER	143035
HMHTR-1A	HEAT MEDIUM HEATER	143035
HTR-1	TEG REBOILER	143035
HTR-2	REGEN GAS HEATER	143035
HTR-3	HOH/TRIM REBOILER	143035
J-AMINE	AMINE UNIT	143035

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
JE-1	EMERGENCY ENGINE	106.263/11/01/2001 [166242]
JH-1	EMERGENCY HEATER	106.263/11/01/2001 [166242]
PORTENG	EMERGENCY ENGINE	106.263/11/01/2001 [169851]
PORTHTR	EMERGENCY HEATER	106.263/11/01/2001 [169851]
PW-B-TK1	PRODUCED WATER TANK	143035
R-141-E	CENTRIFUGAL DRY SEAL COMPRESSOR	143035
R-141-J	CENTRIFUGAL DRY SEAL COMPRESSOR	143035
TEG-1	GLYCOL DEHYDRATOR	143035
TK-1	NEW OIL TANK	143035
TK-2	USED OIL TANK	143035
TK-22	UNLEADED GASOLINE TANK	143035
TK-3	SLOP OIL TANK	143035
TK-4	LEAN AMINE TANK	143035
TK-5	RICH AMINE TANK	143035
TK-6	TEG TANK	143035
TK-901	NEW LUBE OIL TANK	143035
TK-902A	NEW AMINE TANK	143035
TK-903	TEG TANK	143035
TK-904A	CONTACT WATER TANK	143035
TK-904B	CONTACT WATER TANK	143035
TK-905	USED LUBE OIL TANK	143035

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
V-1	GLYCOL DEHYDRATOR	143035

**This column may include Permit by Rule (PBR) numbers and version dates, PBR Registration numbers in brackets, Standard Permit Registration numbers, Minor NSR permit numbers, and Major NSR permit numbers.

Appendix A

Acronym List 69

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
RO	Responsible Official
SIP	state implementation plan
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound