

# FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO  
Air Liquide Large Industries U.S. LP

AUTHORIZING THE OPERATION OF  
Air Liquide Bayou Cogeneration Plant  
Industrial Gas Manufacturing

LOCATED AT  
Harris County, Texas  
Latitude 29° 37' 23" Longitude 95° 2' 46"  
Regulated Entity Number: RN100233998

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No:     O1735     Issuance Date: \_\_\_\_\_

\_\_\_\_\_  
For the Commission

## Table of Contents

Section	Page
General Terms and Conditions .....	1
Special Terms and Conditions: .....	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements .....	6
New Source Review Authorization Requirements .....	6
Compliance Requirements.....	7
Risk Management Plan .....	8
Permit Location .....	9
Permit Shield (30 TAC § 122.148) .....	9
Cross-State Air Pollution Rule (CSAPR) Trading Program Requirements .....	9
Attachments .....	16
Applicable Requirements Summary.....	17
Additional Monitoring Requirements .....	71
Permit Shield .....	76
New Source Review Authorization References .....	79
Appendix A .....	84
Acronym List .....	85
Appendix B .....	86

## **General Terms and Conditions**

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

## **Special Terms and Conditions:**

### **Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting**

1. Permit holder shall comply with the following requirements:
  - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
  - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
  - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
  - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.

- E. Emission units subject to 40 CFR Part 63, Subpart ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.
- F. For the purpose of generating emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 1 (Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
  - (i) Title 30 TAC § 101.302 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.303 (relating to Emission Reduction Credit Generation Certification)
  - (iii) Title 30 TAC § 101.304 (relating to Mobile Emission Reduction Credit Generation and Certification)
  - (iv) Title 30 TAC § 101.309 (relating to Emission Credit Banking and Trading)
  - (v) The terms and conditions by which the emission limits are established to generate the reduction credit are applicable requirements of this permit
- G. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 3 (Mass Emission Cap and Trade Program) Requirements:
  - (i) Title 30 TAC § 101.352 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.353 (relating to Allocation of Allowances)
  - (iii) Title 30 TAC § 101.354 (relating to Allowance Deductions)
  - (iv) Title 30 TAC § 101.356 (relating to Allowance Banking and Trading)
  - (v) Title 30 TAC § 101.359 (relating to Reporting)
  - (vi) Title 30 TAC § 101.360 (relating to Level of Activity Certification)
  - (vii) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit
- H. For the purpose of generating discrete emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 4 (Discrete Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
  - (i) Title 30 TAC § 101.372 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.373 (relating to Discrete Emission Reduction Credit Generation and Certification)
  - (iii) Title 30 TAC § 101.374 (relating to Mobile Discrete Emission Reduction Credit Generation and Certification)
  - (iv) Title 30 TAC § 101.378 (relating to Discrete Emission Credit Banking and Trading)

- (v) The terms and conditions by which the emission limits are established to generate the discrete reduction credit are applicable requirements of this permit
- 2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
  - A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
  - B. Title 30 TAC § 101.3 (relating to Circumvention)
  - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
  - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
  - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
  - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
  - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
  - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
  - I. Title 30 TAC § 101.222 (relating to Demonstrations)
  - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
- 3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
  - A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
    - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
    - (ii) Title 30 TAC § 111.111(a)(1)(E)
    - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
    - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that

does not obstruct the transmission of light. Vents, as specified in the “Applicable Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:

- (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
- (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (5) Compliance Certification:
  - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
  - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is

determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.
- B. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).
- C. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
  - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
  - (ii) Sources with an effective stack height ( $h_e$ ) less than the standard effective stack height ( $H_e$ ), must reduce the allowable emission level by multiplying it by  $[h_e/H_e]^2$  as required in 30 TAC § 111.151(b)
  - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
- D. Permit holder shall comply with the following requirements for steam generators:
  - (i) Emissions from any oil or gas fuel-fired steam generator with a heat input capacity greater than 2,500 MMBtu per hour may not exceed 0.1 pound of TSP per MMBtu of heat input, averaged over a two-hour period, as required in 30 TAC § 111.153(c) (relating to Emissions Limits for Steam Generators).
- 4. The permit holder shall comply with the requirements of 30 TAC § 115.722(b) (relating to Site-wide Cap and Control Requirements) and the requirements of 30 TAC § 115.726(g) (relating to Recordkeeping and Reporting Requirements).
- 5. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
  - A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
  - B. Title 40 CFR § 60.8 (relating to Performance Tests)
  - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
  - D. Title 40 CFR § 60.12 (relating to Circumvention)
  - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)

- F. Title 40 CFR § 60.14 (relating to Modification)
  - G. Title 40 CFR § 60.15 (relating to Reconstruction)
  - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
6. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.

#### **Additional Monitoring Requirements**

7. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

#### **New Source Review Authorization Requirements**

8. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule (including the terms, conditions, monitoring, recordkeeping, and reporting identified in registered PBRs and permits by rule identified in the PBR Supplemental Tables dated September 13, 2024 in the application for project 37161), standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
- A. Are incorporated by reference into this permit as applicable requirements
  - B. Shall be located with this operating permit
  - C. Are not eligible for a permit shield
9. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
10. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and



available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).

### **Compliance Requirements**

11. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
12. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:
  - A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
    - (i) For sources in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9020:
      - (1) Title 30 TAC § 117.9020(2)(A), (C), and (D)
    - (ii) For electric generating facilities in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9020(2)(B)
  - B. The permit holder shall comply with the Initial Control Plan unit listing requirement in 30 TAC § 117.350(c) and (c)(1).
  - C. The permit holder shall comply with the requirements of 30 TAC § 117.354 for Final Control Plan Procedures for Attainment Demonstration Emission Specifications and 30 TAC § 117.356 for Revision of Final Control Plan.
13. Use of Emission Credits to comply with applicable requirements:
  - A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
    - (i) Title 30 TAC Chapter 115
    - (ii) Title 30 TAC Chapter 117
    - (iii) Offsets for Title 30 TAC Chapter 116
  - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
    - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)
    - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1

- (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)
- (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
- (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)

14. Use of Discrete Emission Credits to comply with the applicable requirements:

- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
  - (i) Title 30 TAC Chapter 115
  - (ii) Title 30 TAC Chapter 117
  - (iii) If applicable, offsets for Title 30 TAC Chapter 116
  - (iv) Temporarily exceed state NSR permit allowables
- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
  - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
  - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
  - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
  - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
  - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

**Risk Management Plan**

- 15. For processes subject to 40 CFR Part 68 and specified in 40 CFR § 68.10, the permit holder shall comply with the requirements of the Accidental Release Prevention Provisions in 40 CFR Part 68. The permit holder shall submit to the appropriate agency either a compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR § 68.10(a), or as part of the compliance certification submitted under this permit, a certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of a risk management plan.

## **Permit Location**

16. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

## **Permit Shield (30 TAC § 122.148)**

17. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

## **Cross-State Air Pollution Rule (CSAPR) Trading Program Requirements**

18. For units CG801, CG802, CG803, CG804, located at the site identified by Plant code/ORIS/Facility code 10298, the designated representative and the owner or operator, as applicable, shall comply with the following CSAPR requirements.

### **A. General Requirements**

- (i) The owners and operators of the CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall operate the source and the unit in compliance with the requirements of the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program and all other applicable State and federal requirements.
- (ii) The owners and operators of the CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall comply with the requirements of 40 CFR Part 97, Subpart EEEEE for CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program, and with the General Terms and Conditions of the Federal Operating Permit (FOP) that incorporates the CSAPR requirements.

### **B. Description of CSAPR Monitoring Provisions**

- (i) The CSAPR subject unit(s), and the unit-specific monitoring provisions at this source, are identified in the following paragraph(s). These unit(s) are subject to the requirements for the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program.
  - (1) For units CG801, CG802, CG803, CG804, the owners and operators shall comply with the continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart H for NO<sub>x</sub>, and with the excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D for heat input.
- (ii) The above description of the monitoring used by a unit does not change, create an exemption from, or otherwise affect the monitoring, recordkeeping, and reporting requirements applicable to the unit under 40 CFR §§ 97.830 through 97.835 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program). The monitoring,

recordkeeping and reporting requirements applicable to each unit are included below in the standard conditions for the applicable CSAPR trading program.

- (iii) Owners and operators must submit to the Administrator a monitoring plan for each unit in accordance with 40 CFR §§ 75.53, 75.62 and 75.73, as applicable. The monitoring plan for each unit is available at the EPA's website at <https://www.epa.gov/airmarkets/clean-air-markets-monitoring-plans-part-75-sources>.
- (iv) Owners and operators that want to use an alternative monitoring system must submit to the Administrator a petition requesting approval of the alternative monitoring system in accordance with 40 CFR Part 75, Subpart E and 40 CFR § 75.66 and § 97.835 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program). The Administrator's response approving or disapproving any petition for an alternative monitoring system is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
- (v) Owners and operators that want to use an alternative to any monitoring, recordkeeping, or reporting requirement under 40 CFR §§ 97.830 through 97.834 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program) must submit to the Administrator a petition requesting approval of the alternative in accordance with 40 CFR § 75.66 and § 97.835 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program). The Administrator's response approving or disapproving any petition for an alternative to a monitoring, recordkeeping, or reporting requirement is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
- (vi) The descriptions of monitoring applicable to the unit(s) included above meet the requirement of 40 CFR §§ 97.830 through 97.834 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program), and therefore procedures for minor permit revisions, in accordance with 30 TAC § 122.217, may be used to add or change this unit's monitoring system description.

19. CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program Requirements (40 CFR § 97.806)

A. Designated representative requirements

- (i) The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR §§ 97.813 through 97.818.

B. Emissions monitoring, reporting, and recordkeeping requirements

- (i) The owners and operators, and the designated representative, of each CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR § 97.830 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), § 97.831 (initial monitoring system certification and recertification procedures), § 97.832 (monitoring system out-of-control periods), § 97.833 (notifications concerning monitoring), § 97.834 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and § 97.835 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).

- (ii) The emissions data determined in accordance with 40 CFR § 97.830 through § 97.835 and any other credible evidence shall be used to calculate allocations of CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances under 40 CFR §§ 97.811(a)(2) and (b) and § 97.812 and to determine compliance with the CSAPR NO<sub>x</sub> Ozone Season Group 2 emissions limitation and assurance provisions under paragraph C. below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR §§ 97.830 through 97.835 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

C. NO<sub>x</sub> emissions requirements

(i) CSAPR NO<sub>x</sub> Ozone Season Group 2 emissions limitation

- (1) As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall hold, in the source's compliance account, CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances available for deduction for such control period under 40 CFR § 97.824(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for such control period from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at the source.
- (2) If total NO<sub>x</sub> emissions during a control period in a given year from the CSAPR NO<sub>x</sub> Ozone Season Group 2 units at a CSAPR NO<sub>x</sub> Ozone Season Group 2 source are in excess of the CSAPR NO<sub>x</sub> Ozone Season Group 2 emissions limitation set forth in paragraph C.(i)(1) above, then:
  - (a) The owners and operators of the source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall hold the CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances required for deduction under 40 CFR § 97.824(d); and
  - (b) The owners and operators of the source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart EEEEE and the Clean Air Act.

(ii) CSAPR NO<sub>x</sub> Ozone Season Group 2 assurance provisions

- (1) If total NO<sub>x</sub> emissions during a control period in a given year from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO<sub>x</sub> emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances available for deduction for such

control period under 40 CFR § 97.825(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR § 97.825(b), of multiplying -

- (a) The quotient of the amount by which the common designated representative's share of such NO<sub>x</sub> emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such NO<sub>x</sub> emissions exceeds the respective common designated representative's assurance level; and
  - (b) The amount by which total NO<sub>x</sub> emissions from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state for such control period exceed the state assurance level.
- (2) The owners and operators shall hold the CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances required under paragraph C.(ii)(1) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
- (3) Total NO<sub>x</sub> emissions from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state during a control period in a given year exceed the state assurance level if such total NO<sub>x</sub> emissions exceed the sum, for such control period, of the state NO<sub>x</sub> Ozone Season Group 2 trading budget under 40 CFR § 97.810(a) and the state's variability limit under 40 CFR § 97.810(b).
- (4) It shall not be a violation of 40 CFR Part 97, Subpart EEEEE or of the Clean Air Act if total NO<sub>x</sub> emissions from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state during a control period exceed the state assurance level or if a common designated representative's share of total NO<sub>x</sub> emissions from the CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state during a control period exceeds the common designated representative's assurance level.
- (5) To the extent the owners and operators fail to hold CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances for a control period in a given year in accordance with paragraphs C.(ii)(1) through (3) above,
  - (a) The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
  - (b) Each CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance that the owners and operators fail to hold for such control period in accordance with paragraphs C.(ii)(1) through (3) above and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart EEEEE and the Clean Air Act.

(iii) Compliance periods

- (1) A CSAPR NO<sub>x</sub> Ozone Season Group 2 unit shall be subject to the requirements under paragraph C.(i) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR § 97.830(b) and for each control period thereafter.
- (2) A CSAPR NO<sub>x</sub> Ozone Season Group 2 unit shall be subject to the requirements under paragraph C.(ii) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR § 97.830(b) and for each control period thereafter.

(iv) Vintage of allowances held for compliance

- (1) A CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance held for compliance with the requirements under paragraph C.(i)(1) above for a control period in a given year must be a CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance that was allocated for such control period or a control period in a prior year.
- (2) A CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance held for compliance with the requirements under paragraphs C.(i)(2)(a) and (ii)(1) through (3) above for a control period in a given year must be a CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.

(v) Allowance Management System requirements. Each CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart EEEEE.

(vi) Limited authorization. A CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance is a limited authorization to emit one ton of NO<sub>x</sub> during the control period in one year. Such authorization is limited in its use and duration as follows:

- (1) Such authorization shall only be used in accordance with the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program; and
- (2) Notwithstanding any other provision of 40 CFR Part 97, Subpart EEEEE, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.

(vii) Property right. A CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance does not constitute a property right.

D. FOP revision requirements

- (i) No FOP revision shall be required for any allocation, holding, deduction, or transfer of CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances in accordance with 40 CFR Part 97, Subpart EEEEE.

- (ii) This FOP incorporates the CSAPR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR §§ 97.830 through 97.835, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, subpart H), an excepted monitoring system (pursuant to 40 CFR Part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR § 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, subpart E). Therefore the Description of CSAPR Monitoring Provisions for CSAPR subject unit(s) may be added to, or changed, in this FOP using procedures for minor permit revisions in accordance with 30 TAC § 122.217.

E. Additional recordkeeping and reporting requirements

- (i) Unless otherwise provided, the owners and operators of each CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
  - (1) The certificate of representation under 40 CFR § 97.816 for the designated representative for the source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR § 97.816 changing the designated representative.
  - (2) All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart EEEEE.
  - (3) Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program.
- (ii) The designated representative of a CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall make all submissions required under the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program, except as provided in 40 CFR § 97.818. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under 30 TAC § 122.165.

F. Liability

- (i) Any provision of the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program that applies to a CSAPR NO<sub>x</sub> Ozone Season Group 2 source or the designated representative of a CSAPR NO<sub>x</sub> Ozone Season Group 2 source shall also apply to the owners and operators of such source and of the CSAPR NO<sub>x</sub> Ozone Season Group 2 units at the source.
- (ii) Any provision of the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program that applies to a CSAPR NO<sub>x</sub> Ozone Season Group 2 unit or the designated



representative of a CSAPR NO<sub>x</sub> Ozone Season Group 2 unit shall also apply to the owners and operators of such unit.

G. Effect on other authorities

- (i) No provision of the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program or exemption under 40 CFR § 97.805 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a CSAPR NO<sub>x</sub> Ozone Season Group 2 source or CSAPR NO<sub>x</sub> Ozone Season Group 2 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

## **Attachments**

**Applicable Requirements Summary**

**Additional Monitoring Requirements**

**Permit Shield**

**New Source Review Authorization References**

### **Applicable Requirements Summary**

<b>Unit Summary .....</b>	<b>18</b>
---------------------------	-----------

<b>Applicable Requirements Summary .....</b>	<b>22</b>
--	-----------

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
BO1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	117B-BOILER	30 TAC Chapter 117, Subchapter B	No changing attributes.
BO1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DB-BOILER	40 CFR Part 60, Subpart Db	No changing attributes.
BO2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	117B-BOILER	30 TAC Chapter 117, Subchapter B	No changing attributes.
BO2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DB-BOILER	40 CFR Part 60, Subpart Db	No changing attributes.
BO3	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	117B-BOILER	30 TAC Chapter 117, Subchapter B	No changing attributes.
BO3	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DB-BOILER	40 CFR Part 60, Subpart Db	No changing attributes.
BO4	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	117B-BOILER	30 TAC Chapter 117, Subchapter B	No changing attributes.
BO4	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DB-BOILER	40 CFR Part 60, Subpart Db	No changing attributes.
CG801R	STATIONARY TURBINES	N/A	117B-TURB	30 TAC Chapter 117, Subchapter B	No changing attributes.
CG801R	STATIONARY TURBINES	N/A	60KKKK-TURB	40 CFR Part 60, Subpart KKKK	No changing attributes.
CG802R	STATIONARY TURBINES	N/A	117B-TURB	30 TAC Chapter 117,	No changing attributes.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				Subchapter B	
CG802R	STATIONARY TURBINES	N/A	60KKKK-TURB	40 CFR Part 60, Subpart KKKK	No changing attributes.
CG803R	STATIONARY TURBINES	N/A	117B-TURB	30 TAC Chapter 117, Subchapter B	No changing attributes.
CG803R	STATIONARY TURBINES	N/A	60KKKK-TURB	40 CFR Part 60, Subpart KKKK	No changing attributes.
CG804R	STATIONARY TURBINES	N/A	117B-TURB	30 TAC Chapter 117, Subchapter B	No changing attributes.
CG804R	STATIONARY TURBINES	N/A	60KKKK-TURB	40 CFR Part 60, Subpart KKKK	No changing attributes.
DLUNLOAD	LOADING/UNLOADING OPERATIONS	N/A	115-UNLOAD	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
EG100	SRIC ENGINES	N/A	117ENG	30 TAC Chapter 117, Subchapter B	No changing attributes.
EG100	SRIC ENGINES	N/A	MACTZZZZ1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EG1100	SRIC ENGINES	N/A	117ENG1	30 TAC Chapter 117, Subchapter B	No changing attributes.
EG1100	SRIC ENGINES	N/A	MACTZZZZ1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EG200	SRIC ENGINES	N/A	117ENG	30 TAC Chapter 117, Subchapter B	No changing attributes.
EG200	SRIC ENGINES	N/A	MACTZZZZ2	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EG300	SRIC ENGINES	N/A	117ENG	30 TAC Chapter 117, Subchapter B	No changing attributes.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
EG300	SRIC ENGINES	N/A	60III1	40 CFR Part 60, Subpart IIII	No changing attributes.
EG300	SRIC ENGINES	N/A	MACTZZZZ3	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EG310	SRIC ENGINES	N/A	117ENG	30 TAC Chapter 117, Subchapter B	No changing attributes.
EG310	SRIC ENGINES	N/A	60III2	40 CFR Part 60, Subpart IIII	No changing attributes.
EG310	SRIC ENGINES	N/A	MACTZZZZ3	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
EG902	SRIC ENGINES	N/A	117ENG	30 TAC Chapter 117, Subchapter B	No changing attributes.
EG902	SRIC ENGINES	N/A	MACTZZZZ4	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
FIREPUMP	SRIC ENGINES	N/A	117ENGP	30 TAC Chapter 117, Subchapter B	No changing attributes.
FIREPUMP	SRIC ENGINES	N/A	60III3	40 CFR Part 60, Subpart IIII	No changing attributes.
FIREPUMP	SRIC ENGINES	N/A	MACTZZZZ6	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
FW100	SRIC ENGINES	N/A	117ENGP	30 TAC Chapter 117, Subchapter B	No changing attributes.
FW100	SRIC ENGINES	N/A	MACTZZZZ5	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
NH-FUG1	PROCESS HEATERS/FURNACES	N/A	117HEAT1	30 TAC Chapter 117, Subchapter B	No changing attributes.
NH-FUG2	PROCESS HEATERS/FURNACES	N/A	117HEAT1	30 TAC Chapter 117, Subchapter B	No changing attributes.
P3AH-FUG1	PROCESS HEATERS/FURNACES	N/A	117HEAT1	30 TAC Chapter 117, Subchapter B	No changing attributes.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
P606D2	SRIC ENGINES	N/A	117ENGP	30 TAC Chapter 117, Subchapter B	No changing attributes.
P606D2	SRIC ENGINES	N/A	60IIII4	40 CFR Part 60, Subpart IIII	No changing attributes.
P606D2	SRIC ENGINES	N/A	MACTZZZZ6	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
P606E	SRIC ENGINES	N/A	117ENGP	30 TAC Chapter 117, Subchapter B	No changing attributes.
P606E	SRIC ENGINES	N/A	MACTZZZZ1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
RAH-VENT	PROCESS HEATERS/FURNACES	N/A	117HEAT1	30 TAC Chapter 117, Subchapter B	No changing attributes.
SMRBDVENT	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5121-1	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
SMRFLARE1	FLARES	N/A	R1111-F1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
SMRSTACK	PROCESS HEATERS/FURNACES	N/A	117HEAT2	30 TAC Chapter 117, Subchapter B	No changing attributes.
TK-3	STORAGE TANKS/VESSELS	N/A	R5115	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TK-DIESEL	STORAGE TANKS/VESSELS	N/A	115TK-00002	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TK1	STORAGE TANKS/VESSELS	N/A	R5115	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
TK2	STORAGE TANKS/VESSELS	N/A	R5115	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BO1	EU	117B-BOILER	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(B)(iii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
BO1	EU	117B-	NH <sub>3</sub>	30 TAC Chapter	§ 117.310(c)(2)	For boilers that inject urea	§ 117.335(a)(2)	§ 117.345(a)	§ 117.335(b)



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		BOILER		117, Subchapter B	§ 117.310(c)(2)(B) § 117.340(f)(1)	or ammonia into the exhaust stream for NO <sub>x</sub> control, ammonia emissions must not exceed 10 ppmv at 3.0% O <sub>2</sub> , dry.	§ 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3) § 117.340(d) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8130 § 117.8130(4)	§ 117.345(f) § 117.345(f)(11) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
BO1	EU	117B-BOILER	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101,	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(1) § 117.335(g) § 117.340(a)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		§ 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
BO1	EU	60DB-BOILER	NO <sub>x</sub>	40 CFR Part 60, Subpart Db	§ 60.44b(a)(1)(ii) § 60.44b(h) § 60.44b(i) § 60.46b(a)	Except as provided in §60.44b(k) and (l), on and after the §60.8 performance test is completed, no facility that combusts high heat release rate natural gas and distillate oil (except §60.44b(a)(4)) shall discharge NO <sub>x</sub> in excess of 86 ng/J heat input (0.20	§ 60.46b(c) § 60.46b(e) § 60.46b(e)(1) § 60.46b(e)(3) [G]§ 60.48b(b) § 60.48b(c) § 60.48b(d) § 60.48b(e) [G]§ 60.48b(e)(2) § 60.48b(e)(3)	[G]§ 60.48b(b) § 60.48b(c) [G]§ 60.49b(d) [G]§ 60.49b(g) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3) § 60.49b(b) § 60.49b(h) § 60.49b(i) § 60.49b(v) § 60.49b(w)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						lb/MMBtu).	§ 60.48b(f)		
BO1	EU	60DB-BOILER	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	The affected facility to which this subpart applies is each steam generating unit that commences construction, modification, or reconstruction after June 19, 1984, and that has a heat input capacity from fuels combusted in the steam generating unit of greater than 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/hr)).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BO1	EU	60DB-BOILER	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	The affected facility to which this subpart applies is each steam generating unit that commences construction, modification, or reconstruction after June 19, 1984, and that has a heat input capacity from fuels combusted in the steam generating unit of greater than 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/hr)).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BO1	EU	60DB-BOILER	SO <sub>2</sub>	40 CFR Part 60, Subpart Db	§ 60.42b(k)(2)	On and after the §60.8 performance test is completed, units constructed, reconstructed, or modified after February 28, 2005, firing only very low sulfur oil, gaseous fuel, a mixture of these fuels, or a mixture of these fuels with	§ 60.47b(f)	§ 60.45b(k) § 60.49b(o) § 60.49b(r) [G]§ 60.49b(r)(2)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(r) [G]§ 60.49b(r)(2)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						any other fuels with a potential SO <sub>2</sub> emission rate of 140 ng/J (0.32 lb/MMBtu) heat input or less are exempt from the SO <sub>2</sub> emissions limit in §60.42b(k)(1).			
BO2	EU	117B-BOILER	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(B)(iii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)		
BO2	EU	117B-BOILER	NH <sub>3</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(B) § 117.340(f)(1)	For boilers that inject urea or ammonia into the exhaust stream for NO <sub>x</sub> control, ammonia emissions must not exceed 10 ppmv at 3.0% O <sub>2</sub> , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3) § 117.340(d) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8130 § 117.8130(4)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
BO2	EU	117B-	NO <sub>x</sub>	30 TAC Chapter	§ 117.310(d)(3)	An owner or operator may	[G]§ 117.335(a)(1)	§ 117.345(a)	§ 117.335(b)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		BOILER		117, Subchapter B	§ 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(1) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
BO2	EU	60DB-BOILER	NO <sub>x</sub>	40 CFR Part 60, Subpart Db	§ 60.44b(a)(1)(iii) § 60.44b(h)	Except as provided in §60.44b(k) and (l), on and	§ 60.46b(c) § 60.46b(e)	[G]§ 60.48b(b) § 60.48b(c)	§ 60.49b(a) § 60.49b(a)(1)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.44b(i) § 60.46b(a)	after the §60.8 performance test is completed, no facility that combusts high heat release rate natural gas and distillate oil (except §60.44b(a)(4)) shall discharge NOx in excess of 86 ng/J heat input (0.20 lb/MMBtu).	§ 60.46b(e)(1) § 60.46b(e)(3) [G]§ 60.48b(b) § 60.48b(c) § 60.48b(d) § 60.48b(e) [G]§ 60.48b(e)(2) § 60.48b(e)(3) § 60.48b(f)	[G]§ 60.49b(d) [G]§ 60.49b(g) § 60.49b(o)	§ 60.49b(a)(3) § 60.49b(b) § 60.49b(h) § 60.49b(i) § 60.49b(v) § 60.49b(w)
BO2	EU	60DB-BOILER	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	The affected facility to which this subpart applies is each steam generating unit that commences construction, modification, or reconstruction after June 19, 1984, and that has a heat input capacity from fuels combusted in the steam generating unit of greater than 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/hr)).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BO2	EU	60DB-BOILER	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	The affected facility to which this subpart applies is each steam generating unit that commences construction, modification, or reconstruction after June 19, 1984, and that has a heat input capacity from fuels combusted in the steam generating unit of greater than 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/hr)).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BO2	EU	60DB-	SO <sub>2</sub>	40 CFR Part 60,	§ 60.42b(k)(2)	On and after the §60.8	§ 60.47b(f)	§ 60.45b(k)	§ 60.49b(a)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		BOILER		Subpart Db		performance test is completed, units constructed, reconstructed, or modified after February 28, 2005, firing only very low sulfur oil, gaseous fuel, a mixture of these fuels, or a mixture of these fuels with any other fuels with a potential SO <sub>2</sub> emission rate of 140 ng/J (0.32 lb/MMBtu) heat input or less are exempt from the SO <sub>2</sub> emissions limit in §60.42b(k)(1).		§ 60.49b(o) § 60.49b(r) [G]§ 60.49b(r)(2)	§ 60.49b(a)(1) § 60.49b(r) [G]§ 60.49b(r)(2)
BO3	EU	117B-BOILER	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(B)(iii) ) § 117.8100(a)(1)(C)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)		
BO3	EU	117B-BOILER	NH <sub>3</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(B) § 117.340(f)(1)	For boilers that inject urea or ammonia into the exhaust stream for NO <sub>x</sub> control, ammonia emissions must not exceed 10 ppmv at 3.0% O <sub>2</sub> , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3) § 117.340(d) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§	§ 117.345(a) § 117.345(f) § 117.345(f)(11) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8130 § 117.8130(4)		
BO3	EU	117B-BOILER	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(1) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		
BO3	EU	60DB-BOILER	NO <sub>x</sub>	40 CFR Part 60, Subpart Db	§ 60.44b(a)(1)(ii) § 60.44b(h) § 60.44b(i) § 60.46b(a)	Except as provided in §60.44b(k) and (l), on and after the §60.8 performance test is completed, no facility that combusts high heat release rate natural gas and distillate oil (except §60.44b(a)(4)) shall discharge NO <sub>x</sub> in excess of 86 ng/J heat input (0.20 lb/MMBtu).	§ 60.46b(c) § 60.46b(e) § 60.46b(e)(1) § 60.46b(e)(3) [G]§ 60.48b(b) § 60.48b(c) § 60.48b(d) § 60.48b(e) [G]§ 60.48b(e)(2) § 60.48b(e)(3) § 60.48b(f)	[G]§ 60.48b(b) § 60.48b(c) [G]§ 60.49b(d) [G]§ 60.49b(g) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3) § 60.49b(b) § 60.49b(h) § 60.49b(i) § 60.49b(v) § 60.49b(w)
BO3	EU	60DB-BOILER	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	The affected facility to which this subpart applies is each steam generating unit that commences construction, modification, or reconstruction after June 19, 1984, and that has a heat input capacity from fuels combusted in the steam generating unit of greater than 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/hr)).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BO3	EU	60DB-BOILER	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	The affected facility to which this subpart applies is each steam generating unit that commences construction, modification, or reconstruction after June 19, 1984, and that has a heat input capacity from	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						fuels combusted in the steam generating unit of greater than 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/hr)).			
BO3	EU	60DB-BOILER	SO <sub>2</sub>	40 CFR Part 60, Subpart Db	§ 60.42b(k)(2)	On and after the §60.8 performance test is completed, units constructed, reconstructed, or modified after February 28, 2005, firing only very low sulfur oil, gaseous fuel, a mixture of these fuels, or a mixture of these fuels with any other fuels with a potential SO <sub>2</sub> emission rate of 140 ng/J (0.32 lb/MMBtu) heat input or less are exempt from the SO <sub>2</sub> emissions limit in §60.42b(k)(1).	§ 60.47b(f)	§ 60.45b(k) § 60.49b(o) § 60.49b(r) [G]§ 60.49b(r)(2)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(r) [G]§ 60.49b(r)(2)
BO4	EU	117B-BOILER	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(B)(iii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)		[G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
BO4	EU	117B-BOILER	NH <sub>3</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(B) § 117.340(f)(1)	For boilers that inject urea or ammonia into the exhaust stream for NO <sub>x</sub> control, ammonia emissions must not exceed 10 ppmv at 3.0% O <sub>2</sub> , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3) § 117.340(d) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) )	§ 117.345(a) § 117.345(f) § 117.345(f)(11) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8130 § 117.8130(4)		§ 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
BO4	EU	117B-BOILER	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		
BO4	EU	60DB-BOILER	NO <sub>x</sub>	40 CFR Part 60, Subpart Db	§ 60.44b(a)(1)(ii) § 60.44b(h) § 60.44b(i) § 60.46b(a)	Except as provided in §60.44b(k) and (l), on and after the §60.8 performance test is completed, no facility that combusts high heat release rate natural gas and distillate oil (except §60.44b(a)(4)) shall discharge NO <sub>x</sub> in excess of 86 ng/J heat input (0.20 lb/MMBtu).	§ 60.46b(c) § 60.46b(e) § 60.46b(e)(1) § 60.46b(e)(3) [G]§ 60.48b(b) § 60.48b(c) § 60.48b(d) § 60.48b(e) [G]§ 60.48b(e)(2) § 60.48b(e)(3) § 60.48b(f)	[G]§ 60.48b(b) § 60.48b(c) [G]§ 60.49b(d) [G]§ 60.49b(g) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3) § 60.49b(b) § 60.49b(h) § 60.49b(i) § 60.49b(v) § 60.49b(w)
BO4	EU	60DB-BOILER	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	The affected facility to which this subpart applies is each steam generating unit that commences construction, modification, or reconstruction after June 19, 1984, and that has a heat input capacity from fuels combusted in the steam generating unit of greater than 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/hr)).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
BO4	EU	60DB-BOILER	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	The affected facility to which this subpart applies is each steam generating unit that commences construction, modification, or reconstruction after June 19, 1984, and that has a heat input capacity from fuels combusted in the steam generating unit of greater than 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/hr)).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
BO4	EU	60DB-BOILER	SO <sub>2</sub>	40 CFR Part 60, Subpart Db	§ 60.42b(k)(2)	On and after the §60.8 performance test is completed, units constructed, reconstructed, or modified after February 28, 2005, firing only very low sulfur oil, gaseous fuel, a mixture of these fuels, or a mixture of these fuels with any other fuels with a potential SO <sub>2</sub> emission rate of 140 ng/J (0.32 lb/MMBtu) heat input or less are exempt from the SO <sub>2</sub> emissions limit in §60.42b(k)(1).	§ 60.47b(f)	§ 60.45b(k) § 60.49b(o) § 60.49b(r) [G]§ 60.49b(r)(2)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(r) [G]§ 60.49b(r)(2)
CG801R	EU	117B-TURB	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4)



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.340(a) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(B)(iii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		§ 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG801R	EU	117B-TURB	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(10)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(g) § 117.340(a) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2)	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	§ 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		§ 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG801R	EU	60KKKK-TURB	NO <sub>x</sub>	40 CFR Part 60, Subpart KKKK	§ 60.4320(a)-Table 1 § 60.4320(a) § 60.4333(a) § 60.4335(b)(1) [G]§ 60.4345	Heat recovery units operating independent of the combustion turbine must meet the nitrogen oxides emission standard of 54 ppm at 15 percent O <sub>2</sub> .	§ 60.4335(b)(1) [G]§ 60.4345 § 60.4350(a) § 60.4350(b) § 60.4350(e) § 60.4350(f) § 60.4350(h) [G]§ 60.4400(a) § 60.4400(b) § 60.4400(b)(1) § 60.4400(b)(4) § 60.4400(b)(5) § 60.4400(b)(6) [G]§ 60.4405	[G]§ 60.4345 § 60.4350(b)	[G]§ 60.4345 § 60.4375(a) § 60.4380 [G]§ 60.4380(b) § 60.4395
CG801R	EU	60KKKK-	SO <sub>2</sub>	40 CFR Part 60,	§ 60.4330(a)(2)	You must not burn in the	§ 60.4365	§ 60.4365(b)	§ 60.4375(a)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		TURB		Subpart KKKK	§ 60.4333(a)	subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO <sub>2</sub> /J (0.060 lb SO <sub>2</sub> /MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.	§ 60.4365(b) § 60.4415(a) § 60.4415(a)(2) § 60.4415(a)(2)(ii)		
CG802R	EU	117B-TURB	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(B)(iii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							[G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		
CG802R	EU	117B-TURB	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(10)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(g) § 117.340(a) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							117.8100(a)(5)(E) § 117.8100(a)(6)		
CG802R	EU	60KKKK-TURB	NO <sub>x</sub>	40 CFR Part 60, Subpart KKKK	§ 60.4320(a)-Table 1 § 60.4320(a) § 60.4333(a) § 60.4335(b)(1) [G]§ 60.4345	Heat recovery units operating independent of the combustion turbine must meet the nitrogen oxides emission standard of 54 ppm at 15 percent O <sub>2</sub> .	§ 60.4335(b)(1) [G]§ 60.4345 § 60.4350(a) § 60.4350(b) § 60.4350(e) § 60.4350(f) § 60.4350(h) [G]§ 60.4400(a) § 60.4400(b) § 60.4400(b)(1) § 60.4400(b)(4) § 60.4400(b)(5) § 60.4400(b)(6) [G]§ 60.4405	[G]§ 60.4345 § 60.4350(b)	[G]§ 60.4345 § 60.4375(a) § 60.4380 [G]§ 60.4380(b) § 60.4395
CG802R	EU	60KKKK-TURB	SO <sub>2</sub>	40 CFR Part 60, Subpart KKKK	§ 60.4330(a)(2) § 60.4333(a)	You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO <sub>2</sub> /J (0.060 lb SO <sub>2</sub> /MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.	§ 60.4365 § 60.4365(b) § 60.4415(a) § 60.4415(a)(2) § 60.4415(a)(2)(ii)	§ 60.4365(b)	§ 60.4375(a)
CG803R	EU	117B-TURB	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) [G]§ 117.340(f)(2) § 117.8100(a)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(B)(iii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		§ 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG803R	EU	117B-TURB	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(10)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(g) § 117.340(a) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a)	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						specified in § 117.9800 to comply with § 117.320.	§ 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		[G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG803R	EU	60KKKK-TURB	NO <sub>x</sub>	40 CFR Part 60, Subpart KKKK	§ 60.4320(a)-Table 1 § 60.4320(a) § 60.4333(a) § 60.4335(b)(1) [G]§ 60.4345	Heat recovery units operating independent of the combustion turbine must meet the nitrogen oxides emission standard of 54 ppm at 15 percent O <sub>2</sub> .	§ 60.4335(b)(1) [G]§ 60.4345 § 60.4350(a) § 60.4350(b) § 60.4350(e) § 60.4350(f) § 60.4350(h) [G]§ 60.4400(a) § 60.4400(b) § 60.4400(b)(1) § 60.4400(b)(4) § 60.4400(b)(5) § 60.4400(b)(6) [G]§ 60.4405	[G]§ 60.4345 § 60.4350(b)	[G]§ 60.4345 § 60.4375(a) § 60.4380 [G]§ 60.4380(b) § 60.4395
CG803R	EU	60KKKK-TURB	SO <sub>2</sub>	40 CFR Part 60, Subpart KKKK	§ 60.4330(a)(2) § 60.4333(a)	You must not burn in the subject stationary combustion turbine any fuel which contains total	§ 60.4365 § 60.4365(b) § 60.4415(a) § 60.4415(a)(2)	§ 60.4365(b)	§ 60.4375(a)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						potential sulfur emissions in excess of 26 ng SO <sub>2</sub> /J (0.060 lb SO <sub>2</sub> /MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.	§ 60.4415(a)(2)(ii)		
CG804R	EU	117B-TURB	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CG804R	EU	117B-TURB	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(10)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(g) § 117.340(a) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
CG804R	EU	60KKKK-	NO <sub>x</sub>	40 CFR Part 60,	§ 60.4320(a)-Table	Heat recovery units	§ 60.4335(b)(1)	[G]§ 60.4345	[G]§ 60.4345

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
		TURB		Subpart KKKK	1 § 60.4320(a) § 60.4333(a) § 60.4335(b)(1) [G]§ 60.4345	operating independent of the combustion turbine must meet the nitrogen oxides emission standard of 54 ppm at 15 percent O <sub>2</sub> .	[G]§ 60.4345 § 60.4350(a) § 60.4350(b) § 60.4350(e) § 60.4350(f) § 60.4350(h) [G]§ 60.4400(a) § 60.4400(b) § 60.4400(b)(1) § 60.4400(b)(4) § 60.4400(b)(5) § 60.4400(b)(6) [G]§ 60.4405	§ 60.4350(b)	§ 60.4375(a) § 60.4380 [G]§ 60.4380(b) § 60.4395
CG804R	EU	60KKKK-TURB	SO <sub>2</sub>	40 CFR Part 60, Subpart KKKK	§ 60.4330(a)(2) § 60.4333(a)	You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO <sub>2</sub> /J (0.060 lb SO <sub>2</sub> /MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.	§ 60.4365 § 60.4365(b) § 60.4415(a) § 60.4415(a)(2) § 60.4415(a)(2)(ii)	§ 60.4365(b)	§ 60.4375(a)
DLUNLOAD	EU	115-UNLOAD	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
EG100	EU	117ENG	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10),	§ 117.8140(a) § 117.8140(a)(3)	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
EG100	EU	MACTZZZ Z1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
EG1100	EU	117ENG1	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001,	None	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)			
EG1100	EU	MACTZZZ Z1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
EG200	EU	117ENG	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based	§ 117.8140(a) § 117.8140(a)(3)	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						on a rolling 12-month average.			
EG200	EU	MACTZZZ Z2	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.5 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(j) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary SI RICE; black start stationary SI RICE; non-emergency, non-black start 4SLB stationary RICE with a site rating greater than 500 HP that operates 24 hours or less per calendar year; non-emergency, non-black start 4SRB stationary RICE with a site rating greater than 500 HP that operates 24 hours or less per calendar year, located at an area source, you must comply with the requirements as specified in Table 2d.5.a-c.	§ 63.6625(j) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(j) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
EG300	EU	117ENG	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified.	None	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						§117.303(a)(11)(A)-(B)			
EG300	EU	60IIII1	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
EG300	EU	60IIII1	NMHC and NO <sub>x</sub>	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO <sub>x</sub> emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
EG300	EU	60IIII1	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 60.4211(f)	and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
EG300	EU	MACTZZZ Z3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
EG310	EU	117ENG	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a	None	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)			
EG310	EU	60IIII2	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
EG310	EU	60IIII2	NMHC and NO <sub>x</sub>	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO <sub>x</sub> emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
EG310	EU	60IIII2	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I	Owners and operators of emergency stationary CI	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4202(a)(2) § 60.4206 [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
EG310	EU	MACTZZZ Z3	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
EG902	EU	117ENG	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and	§ 117.8140(a) § 117.8140(a)(3)	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
EG902	EU	MACTZZZ Z4	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
FIREPUMP	EU	117ENGP	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in	None	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)			
FIREPUMP	EU	60III3	NMHC and NO <sub>x</sub>	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 75 KW and less than 130 KW and a displacement of less than 30 liters per cylinder and is a 2010 model year and later must comply with an NMHC+NO <sub>x</sub> emission limit of 4.0 g/KW-hr, as listed in Table 4 to this subpart.	None	None	[G]§ 60.4214(d)
FIREPUMP	EU	60III3	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(c)-Table 4 § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary fire pump CI ICE with a maximum engine power greater than or equal to 75 KW and less than 130 KW and a displacement of less than 30 liters per cylinder and is a 2010 model year and later must comply with a PM emission limit of 0.30 g/KW-hr, as listed in Table 4 to this subpart.	None	None	[G]§ 60.4214(d)
FIREPUMP	EU	MACTZZZ Z6	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section	None	None	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
FW100	EU	117ENGP	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	§ 117.8140(a) § 117.8140(a)(3)	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
FW100	EU	MACTZZZ Z5	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)				
NH-FUG1	EU	117HEAT1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
NH-FUG1	EU	117HEAT1	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)		[G]§ 117.8010(7)
NH-FUG2	EU	117HEAT1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
NH-FUG2	EU	117HEAT1	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)		
P3AH-FUG1	EU	117HEAT1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
P3AH-FUG1	EU	117HEAT1	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						specified in § 117.9800 to comply with § 117.320.	§ 117.8000(c)(6) [G]§ 117.8000(d)		
P606D2	EU	117ENGP	Exempt	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
P606D2	EU	60IIII4	CO	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
P606D2	EU	60IIII4	NMHC and NO <sub>x</sub>	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I	Owners and operators of emergency stationary CI	None	None	[G]§ 60.4214(d)



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4202(a)(2) § 60.4206 [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.			
P606D2	EU	60IIII4	PM	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039-Appendix I § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 1039-Appendix I.	None	None	[G]§ 60.4214(d)
P606D2	EU	60IIII4	PM (Opacity)	40 CFR Part 60, Subpart IIII	§ 60.4205(b) § 1039.105(b)(1) § 1039.105(b)(2) § 1039.105(b)(3) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f)	Emergency stationary CI ICE, that are not fire pump engines, with displacement < 10 lpc and not constant-speed engines, with max engine power < 2237 KW and a 2007 model year and later or max engine power > 2237 KW and a 2011 model year and later, must comply	None	None	[G]§ 60.4214(d)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						with following opacity emission limits: 20% during acceleration, 15% during lugging, 50% during peaks in either acceleration or lugging modes as stated in §60.4202(a)(1)-(2), (b)(2), and 40 CFR 1039.105(b)(1)-(3).			
P606D2	EU	MACTZZZ Z6	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
P606E	EU	117ENGP	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations,	§ 117.8140(a) § 117.8140(a)(3)	§ 117.340(j) § 117.345(f) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
P606E	EU	MACTZZZ Z1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.4 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(4) § 63.6640(f)(4)(i)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at an area source, you must comply with the requirements as specified in Table 2d.4.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
RAH-VENT	EU	117HEAT1	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3)	CO emissions must not exceed 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) ** See Periodic Monitoring Summary	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
RAH-VENT	EU	117HEAT1	NO <sub>x</sub>	30 TAC Chapter	§ 117.310(d)(3)	An owner or operator may	[G]§ 117.335(a)(1)	§ 117.345(a)	§ 117.335(b)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				117, Subchapter B	§ 117.310(a) § 117.310(a)(8)(A)(ii) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
SMRBDVENT	EP	R5121-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	[G]§ 115.125 § 115.126(2) § 115.126(3)(B)	§ 115.126 § 115.126(2) § 115.126(3) § 115.126(3)(B)	None
SMRBDVENT	EP	R5121-1	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(B) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream specified in § 115.121(a)(1) of this title with a concentration of VOC < 612 ppmv is exempt from § 115.121(a)(1).	[G]§ 115.125 § 115.126(2) § 115.126(3)(C)	§ 115.126 § 115.126(2) § 115.126(3) § 115.126(3)(C)	None
SMRFLARE 1	EU	R1111-F1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(4)(A)	Visible emissions from a process gas flare shall not be permitted for more than five minutes in any two-hour period. Non-excessive upset events are subject to	§ 111.111(a)(4)(A)(i) § 111.111(a)(4)(A)(ii)	§ 111.111(a)(4)(A)(ii)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						the provisions under §101.222(b).			
SMRSTACK	EU	117HEAT2	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a)(2)(A) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(B)(iii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
SMRSTACK	EU	117HEAT2	NH <sub>3</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(B) § 117.340(f)(1)	For process heaters that inject urea or ammonia into the exhaust stream for NO <sub>x</sub> control, ammonia emissions must not exceed 10 ppmv at 3.0% O <sub>2</sub> , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(g) § 117.340(d) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8130 § 117.8130(4)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) § 117.8010(8) § 117.8100(c)
SMRSTACK	EU	117HEAT2	NO <sub>x</sub>	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(8)(A)(i) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO <sub>x</sub> emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3,	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(2) § 117.335(g) § 117.340(a)(2)(A) § 117.340(c)(1)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) ) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		§ 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
TK-3	EU	R5115	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
TK-DIESEL	EU	115TK-00002	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						requirements of this division.			
TK1	EU	R5115	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
TK2	EU	R5115	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None



## **Additional Monitoring Requirements**

<b>Periodic Monitoring Summary .....</b>	<b>72</b>
--	-----------

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: NH-FUG1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: 117HEAT1
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: CO concentration	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Maximum CO concentration = 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	
<p>Periodic Monitoring Text: The permit holder shall comply with the process heater tune-up requirements as specified in 40 CFR §63.7540(a)(10)(i)-(v). The CO and oxygen concentration in the effluent stream shall be measured and recorded. Any monitoring data where the measured CO concentration exceeds 400 ppm by volume measured at 3.0% O<sub>2</sub> on a dry basis shall be considered and reported as a deviation.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: NH-FUG2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: 117HEAT1
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: CO concentration	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Maximum CO concentration = 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	
Periodic Monitoring Text: The permit holder shall comply with the process heater tune-up requirements as specified in 40 CFR §63.7540(a)(10)(i)-(v). The CO and oxygen concentration in the effluent stream shall be measured and recorded. Any monitoring data where the measured CO concentration exceeds 400 ppm by volume measured at 3.0% O <sub>2</sub> on a dry basis shall be considered and reported as a deviation.	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: P3AH-FUG1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: 117HEAT1
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: CO concentration	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Maximum CO concentration = 400 ppm by volume at 3.0% O <sub>2</sub> , dry basis.	
<p>Periodic Monitoring Text: The permit holder shall comply with the process heater tune-up requirements as specified in 40 CFR §63.7540(a)(10)(i)-(v). The CO and oxygen concentration in the effluent stream shall be measured and recorded. Any monitoring data where the measured CO concentration exceeds 400 ppm by volume measured at 3.0% O<sub>2</sub> on a dry basis shall be considered and reported as a deviation.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: RAH-VENT	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 117, Subchapter B	SOP Index No.: 117HEAT1
Pollutant: CO	Main Standard: § 117.310(c)(1)
Monitoring Information	
Indicator: CO concentration	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Maximum CO concentration = 400 ppmv at 3.0% O <sub>2</sub> , dry basis.	
<p>Periodic Monitoring Text: The permit holder shall comply with the process heater tune-up requirements as specified in 40 CFR §63.7540(a)(10)(i)-(v). The CO and oxygen concentration in the effluent stream shall be measured and recorded. Any monitoring data where the measured CO concentration exceeds 400 ppm by volume measured at 3.0% O<sub>2</sub> on a dry basis shall be considered and reported as a deviation.</p>	

**Permit Shield**

**Permit Shield ..... 77**

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
CG801R	N/A	40 CFR Part 60, Subpart GG	The unit is exempt because it is regulated under NSPS KKKK.
CG802R	N/A	40 CFR Part 60, Subpart GG	The unit is exempt because it is regulated under NSPS KKKK.
CG803R	N/A	40 CFR Part 60, Subpart GG	The unit is exempt because it is regulated under NSPS KKKK.
CG804R	N/A	40 CFR Part 60, Subpart GG	The unit is exempt because it is regulated under NSPS KKKK.
GRP-DUCTBURN	DUCTBURN-1, DUCTBURN-2, DUCTBURN-3, DUCTBURN-4	40 CFR Part 60, Subpart Db	Constructed prior to 6/19/1984.
NH3VENT	N/A	30 TAC Chapter 115, Vent Gas Controls	Vent gas stream does not contain VOC
PRO-SMR	N/A	40 CFR Part 63, Subpart F	The Steam Methane Reformer (SMR) plant does not manufacture or use compounds listed in Table 1 and 2 of HON.
SMRCT	N/A	40 CFR Part 63, Subpart Q	Chromium-based water treatment chemicals are not utilized.
SMRFLARE1	N/A	40 CFR Part 60, Subpart A	Flare does not control an NSPS source
SMRFUG	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	SMR unit is not a refinery, SOCMI plant, polymer plant, resin plant, MTBE plant or gas processing plant.
SMRFUG	N/A	40 CFR Part 60, Subpart VV	This is not a SOCMI facility.
SMRGLYCOL	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity < 1000 gallons.
SMRGLYCOL	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 73 cubic meters.
SMRH2VENT	N/A	30 TAC Chapter 115, Vent Gas Controls	Vent gas stream does not contain VOC

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
SMR行为3TNK	N/A	30 TAC Chapter 115, Storage of VOCs	Tank does not store VOC.
SMR行为3TNK	N/A	40 CFR Part 60, Subpart Kb	Tank does not store VOL.
SMRSTACK	N/A	30 TAC Chapter 115, Vent Gas Controls	Heater is a combustion unit not controlling VOC vents
SSM&PIPELINE	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	SMR unit is not a refinery, SOCMI plant, polymer plant, resin plant, MTBE plant or gas processing plant
SSM&PIPELINE	N/A	40 CFR Part 60, Subpart VV	This is not a SOCMI facility
TK-3	N/A	40 CFR Part 60, Subpart K	Capacity less than 40,000 gallons.
TK-ACID	N/A	30 TAC Chapter 115, Storage of VOCs	Storage tank does not store a VOC.
TK-DIESEL	N/A	40 CFR Part 60, Subpart Kb	Storage tank has a design capacity less than 75 cubic meters.
TK-NAOH	N/A	30 TAC Chapter 115, Storage of VOCs	Storage tank does not store a VOC.
TK1	N/A	40 CFR Part 60, Subpart Ka	Capacity less than 40,000 gallons.
TK2	N/A	40 CFR Part 60, Subpart K	Capacity less than 40,000 gallons.



**New Source Review Authorization References**

<b>New Source Review Authorization References .....</b>	<b>80</b>
<b>New Source Review Authorization References by Emission Unit .....</b>	<b>81</b>

### New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

<b>Prevention of Significant Deterioration (PSD) Permits</b>	
PSD Permit No.: GHGPSDTX23*	Issuance Date: 11/21/2013
PSD Permit No.: PSDTX612M2	Issuance Date: 03/02/2023
<b>Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.</b>	
Authorization No.: 9346	Issuance Date: 03/02/2023
Authorization No.: 73110	Issuance Date: 02/05/2021
<b>Permits By Rule (30 TAC Chapter 106) for the Application Area</b>	
Number: 5	Version No./Date: 05/05/1976
Number: 5	Version No./Date: 01/08/1980
Number: 5	Version No./Date: 08/30/1988
Number: 67	Version No./Date: 05/12/1981
Number: 106.183	Version No./Date: 06/18/1997
Number: 106.183	Version No./Date: 09/04/2000
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 11/01/2003
Number: 106.371	Version No./Date: 09/04/2000
Number: 106.372	Version No./Date: 09/04/2000
Number: 106.373	Version No./Date: 09/04/2000
Number: 106.454	Version No./Date: 11/01/2001
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 03/14/1997
Number: 106.511	Version No./Date: 09/04/2000
Number: 106.532	Version No./Date: 09/04/2000

\*For reference EPA issued permit PSD-TX-612-GHG has been assigned TCEQ permit number GHGPSDTX23

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
BO1	NEW BOILER 1	9346, GHGPSDTX23, PSDTX612M2
BO2	NEW BOILER 2	9346, GHGPSDTX23, PSDTX612M2
BO3	NEW BOILER 3	9346, GHGPSDTX23, PSDTX612M2
BO4	RENTECH BOILER 4	9346, PSDTX612M2
CG801R	REPLACEMENT GAS TURBINE	9346, GHGPSDTX23, PSDTX612M2, 106.261/11/01/2003 [99546], 106.262/11/01/2003 [99546]
CG802R	REPLACEMENT GAS TURBINE	9346, GHGPSDTX23, PSDTX612M2, 106.261/11/01/2003 [99546], 106.262/11/01/2003 [99546]
CG803R	REPLACEMENT GAS TURBINE	9346, GHGPSDTX23, PSDTX612M2, 106.261/11/01/2003 [99546], 106.262/11/01/2003 [99546]
CG804R	REPLACEMENT GAS TURBINE	9346, GHGPSDTX23, PSDTX612M2, 106.261/11/01/2003 [99546], 106.262/11/01/2003 [99546]
CHILL-NH3	AMMONIA CHILLER SYSTEM	106.373/09/04/2000 [148323]
DEGREASER	DEGREASER UNIT	106.454/11/01/2001 [87052]
DLUNLOAD	DIESEL UNLOADING	106.473/09/04/2000 [87052]
DUCTBURN-1	HEAT RECOVERY STEAM GENERATOR 1	9346, PSDTX612M2, 106.261/11/01/2003 [99546], 106.262/11/01/2003 [99546]
DUCTBURN-2	HEAT RECOVERY STEAM GENERATOR 2	9346, PSDTX612M2, 106.261/11/01/2003 [99546], 106.262/11/01/2003 [99546]
DUCTBURN-3	HEAT RECOVERY STEAM GENERATOR 3	9346, PSDTX612M2, 106.261/11/01/2003 [99546], 106.262/11/01/2003 [99546]

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
DUCTBURN-4	HEAT RECOVERY STEAM GENERATOR 4	9346, PSDTX612M2, 106.261/11/01/2003 [99546], 106.262/11/01/2003 [99546]
EG100	ASU EMERGENCY GENERATOR 1100 HP B	106.511/03/14/1997
EG1100	UTILITIES EMERGENCY GENERATOR 1485HP	106.511/03/14/1997
EG200	ASU EMERGENCY GENERATOR 150 HP	5/05/05/1976
EG300	ASU EMERGENCY GENERATOR 1100 HP A	5/05/05/1976
EG310	EMERGENCY ENGINE	106.511/09/04/2000
EG902	IWTC EMERGENCY GENERATOR 220HP	5/01/08/1980
FIREPUMP	FIRE PUMP 173 HP	106.511/09/04/2000
FUG-NH3	ASU CHILLER UNIT FUGITIVES	106.373/09/04/2000 [148323]
FUG-NH3S	SUPPLEMENTAL NH3 CHILLER FUGITIVES	106.373/09/04/2000 [148323]
FW100	FW100	106.511/03/14/1997
NH-FUG1	NITROGEN VAPORIZER HEATER # 1	106.183/09/04/2000 [70423]
NH-FUG2	NITROGEN VAPORIZER HEATER # 2	106.183/09/04/2000 [70423]
NH3VENT	NH3 STORAGE GAS VENT	73110
P3AH-FUG1	PLANT 3A ASU HEATER	106.183/06/18/1997 [37485]
P606D2	IWTC EMERGENCY WATER PUMP 950 HP	106.511/09/04/2000
P606E	IWTC EMERGENCY WATER PUMP 985 HP	5/08/30/1988, 106.511/03/14/1997
PRO-SMR	SMR PROCESS UNIT	73110
RAH-VENT	OXYGEN VAPORIZER HEATER	106.183/09/04/2000 [53106]
SMRBDVENT	SMR BLOWDOWN VENT	73110

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
SMRCT	COOLING TOWERS	73110
SMRFLARE1	SMR FLARE	73110
SMRFUG	PROCESS FUGITIVES	73110
SMRGLYCOL	GLYCOL STORAGE TANK	73110
SMRH2VENT	HYDROGEN COMPRESSOR VENT	73110
SMRANH3TNK	AMMONIA TANK UNLOADING	73110
SMRSTACK	SMR FURNACE STACK	73110
SSM&PIPELINE	SSM & PIPELINE CONSTRAINTS	73110
TK-3	STORAGE TANK 3	106.472/09/04/2000
TK-ACID	SULFURIC ACID TANK	106.472/09/04/2000
TK-DIESEL	DIESEL TANK	106.473/09/04/2000 [87052]
TK-NAOH	SODIUM HYDROXIDE TANK	106.472/09/04/2000
TK1	STORAGE TANK 1	67/05/12/1981
TK2	STORGE TANK 2	106.472/09/04/2000

\*\*This column may include Permit by Rule (PBR) numbers and version dates, PBR Registration numbers in brackets, Standard Permit Registration numbers, Minor NSR permit numbers, and Major NSR permit numbers.

**Appendix A**

**Acronym List ..... 85**

## Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H <sub>2</sub> S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO <sub>x</sub>	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
SIP	state implementation plan
SO <sub>2</sub>	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound

**Appendix B**

**Major NSR Summary Table ..... 87**



**Major NSR Summary Table**

Permit Numbers 9346 and PSDTX612M2					Issuance Date: March 2, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
CG801	Gas Turbine Only	NO <sub>x</sub>	17.46	76.48	2, 4, 7, 14, 15, 16, 18	2, 7, 12, 14, 15, 16, 18, 19, 20	2, 15, 16, 21
		NO <sub>x</sub> (7)	170.00				
		CO	31.89	139.67			
		CO (7)	450.00				
		VOC	1.89	8.26			
		VOC (7)	15.5				
		SO <sub>2</sub>	0.66	2.91			
		PM	4.50	19.71			
		PM <sub>10</sub>	4.50	19.71			
		PM <sub>2.5</sub>	3.90	17.08			
		H <sub>2</sub> SO <sub>4</sub>	0.07	0.29			
		HAPs	0.60	(8)			
CG802	Gas Turbine Only	NO <sub>x</sub>	17.46	76.48	2, 4, 7, 14, 15, 16, 18	2, 7, 12, 14, 15, 16, 18, 19, 20	2, 15, 16, 21
		NO <sub>x</sub> (7)	170.00				
		CO	31.89	139.67			

**Major NSR Summary Table**

Permit Numbers 9346 and PSDTX612M2					Issuance Date: March 2, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
		CO (7)	450.00				
		VOC	1.89	8.26			
		VOC (7)	15.5				
		SO <sub>2</sub>	0.66	2.91			
		PM	4.50	19.71			
		PM <sub>10</sub>	4.50	19.71			
		PM <sub>2.5</sub>	3.90	17.08			
		H <sub>2</sub> SO <sub>4</sub>	0.07	0.29			
		HAPs	0.60	(8)			
CG803	Gas Turbine Only	NO <sub>x</sub>	17.46	76.48	2, 4, 7, 14, 15, 16, 18	2, 7, 12, 14, 15, 16, 18, 19, 20	2, 15, 16, 21
		NO <sub>x</sub> (7)	170.00				
		CO	31.89	139.67			
		CO (7)	450.00				
		VOC	1.89	8.26			
		VOC (7)	15.5				

**Major NSR Summary Table**

Permit Numbers 9346 and PSDTX612M2					Issuance Date: March 2, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
		SO <sub>2</sub>	0.66	2.91			
		PM	4.50	19.71			
		PM <sub>10</sub>	4.50	19.71			
		PM <sub>2.5</sub>	3.90	17.08			
		H <sub>2</sub> SO <sub>4</sub>	0.07	0.29			
		HAPs	0.60	(8)			
CG804	Gas Turbine Only	NO <sub>x</sub>	17.46	76.48	2, 4, 7, 14, 15, 16, 18	2, 7, 12, 14, 15, 16, 18, 19, 20	2, 15, 16, 21
		NO <sub>x</sub> (7)	170.00				
		CO	31.89	139.67			
		CO (7)	450.00				
		VOC	1.89	8.26			
		VOC (7)	15.5				
		SO <sub>2</sub>	0.66	2.91			
		PM	4.50	19.71			
		PM <sub>10</sub>	4.50	19.71			

**Major NSR Summary Table**

Permit Numbers 9346 and PSDTX612M2					Issuance Date: March 2, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
CG801	Gas Turbine and Duct Burner Firing	PM <sub>2.5</sub>	3.90	17.08	2, 4, 5, 7, 14, 15, 16, 18	2, 7, 12, 14, 15, 16, 18, 19, 20	2, 15, 16, 21
		H <sub>2</sub> SO <sub>4</sub>	0.07	0.29			
		HAPs	0.60	(8)			
		NO <sub>x</sub>	34.05	149.14			
		NO <sub>x</sub> (7)	186.59				
		CO	38.53	168.74			
		CO (7)	456.64				
		VOC	2.55	11.17			
		VOC (7)	16.16				
		SO <sub>2</sub>	0.76	3.34			
		PM	5.74	25.12			
		PM <sub>10</sub>	5.74	25.12			
		PM <sub>2.5</sub>	5.14	22.50			
		H <sub>2</sub> SO <sub>4</sub>	0.08	0.33			
		HAPs	0.91	(8)			

**Major NSR Summary Table**

Permit Numbers 9346 and PSDTX612M2					Issuance Date: March 2, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
CG802	Gas Turbine and Duct Burner Firing	NO <sub>x</sub>	34.05	149.14	2, 4, 5, 7, 14, 15, 16, 18	2, 7, 12, 14, 15, 16, 18, 19, 20	2, 15, 16, 21
		NO <sub>x</sub> (7)	186.59				
		CO	38.53	168.74			
		CO (7)	456.64				
		VOC	2.55	11.17			
		VOC (7)	16.16				
		SO <sub>2</sub>	0.76	3.34			
		PM	5.74	25.12			
		PM <sub>10</sub>	5.74	25.12			
		PM <sub>2.5</sub>	5.14	22.50			
		H <sub>2</sub> SO <sub>4</sub>	0.08	0.33			
		HAPs	0.91	(8)			
CG803	Gas Turbine and Duct Burner Firing	NO <sub>x</sub>	34.05	149.14	2, 4, 5, 7, 14, 15, 16, 18	2, 7, 12, 14, 15, 16, 18, 19, 20	2, 15, 16, 21
		NO <sub>x</sub> (7)	186.59				
		CO	38.53	168.74			

**Major NSR Summary Table**

Permit Numbers 9346 and PSDTX612M2					Issuance Date: March 2, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
		CO (7)	456.64				
		VOC	2.55	11.17			
		VOC (7)	16.16				
		SO <sub>2</sub>	0.76	3.34			
		PM	5.74	25.12			
		PM <sub>10</sub>	5.74	25.12			
		PM <sub>2.5</sub>	5.14	22.50			
		H <sub>2</sub> SO <sub>4</sub>	0.08	0.33			
		HAPs	0.91	(8)			
CG804	Gas Turbine and Duct Burner Firing	NO <sub>x</sub>	34.05	149.14	2, 4, 5, 7, 14, 15, 16, 18	2, 7, 12, 14, 15, 16, 18, 19, 20	2, 15, 16, 21
		NO <sub>x</sub> (7)	186.59				
		CO	38.53	168.74			
		CO (7)	456.64				
		VOC	2.55	11.17			
		VOC (7)	16.16				

**Major NSR Summary Table**

Permit Numbers 9346 and PSDTX612M2					Issuance Date: March 2, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
		SO <sub>2</sub>	0.76	3.34			
		PM	5.74	25.12			
		PM <sub>10</sub>	5.74	25.12			
		PM <sub>2.5</sub>	5.14	22.50			
		H <sub>2</sub> SO <sub>4</sub>	0.08	0.33			
		HAPs	0.91	(8)			
BO1	Boiler 1	NO <sub>x</sub>	5.50	17.95	2, 4, 7, 8, 9, 12, 14, 15, 16, 17, 18	2, 7, 12, 14, 15, 16, 17, 18, 19, 20	2, 15, 16, 21
		NO <sub>x</sub> (7)	165.00				
		CO	20.35	66.41			
		CO (7)	203.50				
		VOC	2.20	7.18			
		VOC (7)	22.00				
		SO <sub>2</sub>	0.39	1.26			
		PM	4.40	14.36			
		PM <sub>10</sub>	2.75	8.97			

**Major NSR Summary Table**

Permit Numbers 9346 and PSDTX612M2					Issuance Date: March 2, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
		PM <sub>2.5</sub>	1.65	5.38			
		H <sub>2</sub> SO <sub>4</sub>	0.04	0.13			
		HAPs	1.02	(8)			
		NH <sub>3</sub>	2.47	8.07			
BO2	Boiler 2	NO <sub>x</sub>	5.50	17.95	2, 4, 7, 8, 9, 12, 14, 15, 16, 17, 18	2, 7, 12, 14, 15, 16, 17, 18, 19, 20	2, 15, 16, 21
		NO <sub>x</sub> (7)	165.00				
		CO	20.35	66.41			
		CO (7)	203.50				
		VOC	2.20	7.18			
		VOC (7)	22.00				
		SO <sub>2</sub>	0.39	1.26			
		PM	4.40	14.36			
		PM <sub>10</sub>	2.75	8.97			
		PM <sub>2.5</sub>	1.65	5.38			
		H <sub>2</sub> SO <sub>4</sub>	0.04	0.13			



**Major NSR Summary Table**

Permit Numbers 9346 and PSDTX612M2					Issuance Date: March 2, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
BO3	Boiler 3	HAPs	1.02	(8)	2, 4, 7, 8, 9, 12, 14, 15, 16, 17, 18	2, 7, 12, 14, 15, 16, 17, 18, 19, 20	2, 15, 16, 21
		NH <sub>3</sub>	2.47	8.07			
		NO <sub>x</sub>	5.50	17.95			
		NO <sub>x</sub> (7)	165.00				
		CO	20.35	66.41			
		CO (7)	203.50				
		VOC	2.20	7.18			
		VOC (7)	22.00				
		SO <sub>2</sub>	0.39	1.26			
		PM	4.40	14.36			
		PM <sub>10</sub>	2.75	8.97			
		PM <sub>2.5</sub>	1.65	5.38			
		H <sub>2</sub> SO <sub>4</sub>	0.04	0.13			
		HAPs	1.02	(8)			
		NH <sub>3</sub>	2.47	8.07			

**Major NSR Summary Table**

Permit Numbers 9346 and PSDTX612M2					Issuance Date: March 2, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
BO4	Boiler 4	NO <sub>x</sub>	4.95	21.68	2, 4, 7, 8, 9, 12, 14, 15, 16, 17, 18	2, 7, 12, 14, 15, 16, 17, 18, 19, 20	2, 15, 16, 21
		NO <sub>x</sub> (7)	55.00				
		CO	18.15	79.50			
		CO (7)	181.50				
		VOC	1.98	8.67			
		NH <sub>3</sub>	2.48	10.84			
		SO <sub>2</sub>	0.39	1.69			
		PM	3.96	17.34			
		PM <sub>10</sub>	2.48	10.84			
		PM <sub>2.5</sub>	1.49	6.50			
		H <sub>2</sub> SO <sub>4</sub>	0.04	0.17			
		HAPs	0.05	(8)			
		NH <sub>3</sub>	2.48	10.84			
CG801, CG802, CG803, CG804, BO1, BO2, BO3,	Site-wide HAPs	Total HAPs	-	23.51	15, 18	15, 18, 19, 20	15, 21
		Any single HAP	-	10.00			

### Major NSR Summary Table

Permit Numbers 9346 and PSDTX612M2					Issuance Date: March 2, 2023		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
BO4							
MSS-Fug	Maintenance Fugitive Emissions	VOC	16.2	0.04	12, 14	12, 14, 20	
Fug -Ammonia	Fugitive Ammonia Emissions	NH <sub>3</sub>	0.01	0.06	9	9, 20	

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name. For fugitive sources, use area name or fugitive source name.

(3) NO<sub>x</sub> - total oxides of nitrogen

NH<sub>3</sub> - ammonia

SO<sub>2</sub> - sulfur dioxide

CO - carbon monoxide

VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1

PM - total particulate matter, suspended in the atmosphere, including PM<sub>10</sub> and PM<sub>2.5</sub>

PM<sub>10</sub> - total particulate matter equal to or less than 10 microns in diameter, including PM<sub>2.5</sub>

PM<sub>2.5</sub> - particulate matter equal to or less than 2.5 microns in diameter

H<sub>2</sub>SO<sub>4</sub> - sulfuric acid

HAPs - Hazardous Air Pollutants

(4) The pound per hour (lb/hr) and ton per year (tpy) emission limits specified in the MAERT for this facility includes emissions from the facility during both normal operations and planned MSS activities, unless otherwise noted.

(5) For each pollutant whose emissions during planned MSS activities are measured using a CEMS, the MSS lb/hr limits apply only during each clock hour that includes one or more minutes of MSS activities. During all other clock hours, the normal lb/hr limits apply.

(6) Compliance with annual emission limits is based on a rolling 12-month period.

(7) MSS hourly emission limit only. The tpy emission limit specified in the MAERT for this facility includes emissions from the facility during both normal operations and planned MSS activities.

(8) Annual HAPs limits are within the Site-wide HAPs limits below.

**Major NSR Summary Table**

Permit Numbers: GHGPSDTX23						Issuance Date: November 21, 2013		
EPN	FIN	Description	GHG Mass Basis		CO <sub>2</sub> e TPY <sup>1,2</sup>	Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
				TPY <sup>1</sup>		Special Conditions/ Application Information	Special Conditions/ Application Information	Special Conditions/ Application Information
CG801	GT1	Combustion Turbine	CO <sub>2</sub>	485,112	485,588	III.A.2-6, 12-15 III.B.1-3 III.G.1-3 V.A.2, V.B-J	III.A.12 IV.2 VI.1-5	IV.2 V.B-F
			CH <sub>4</sub>	9.15				
			N <sub>2</sub> O	0.91				
CG802	GT2	Combustion Turbine	CO <sub>2</sub>	485,112	485,588	III.A.2-6, 12-15 III.B.1-3 III.G.1-3 V.A.2, V.B-J	III.A.12 IV.2 VI.1-5	IV.2 V.B-F
			CH <sub>4</sub>	9.15				
			N <sub>2</sub> O	0.91				
CG803	GT3	Combustion Turbine	CO <sub>2</sub>	485,112	485,588	III.A.2-6, 12-15 III.B.1-3 III.G.1-3 V.A.2, V.B-J	III.A.12 IV.2 VI.1-5	IV.2 V.B-F
			CH <sub>4</sub>	9.15				
			N <sub>2</sub> O	0.91				
CG804	GT4	Combustion Turbine	CO <sub>2</sub>	485,112	485,588	III.A.2-6, 12-15 III.B.1-3 III.G.1-3 V.A.2, V.B-J	III.A.12 IV.2 VI.1-5	IV.2 V.B-F
			CH <sub>4</sub>	9.15				
			N <sub>2</sub> O	0.91				
BO1	B-305	Boiler 1	CO <sub>2</sub>	209,750	209,957	III.C.10-15 III.G.1-3 V.A.1, V.B-J	IV.2 VI.1-5	IV.2 V.B-F
			CH <sub>4</sub>	3.96				
			N <sub>2</sub> O	0.40				
BO2	B-306	Boiler 2	CO <sub>2</sub>	209,750	209,957	III.C.10-15 III.G.1-3 V.A.1, V.B-J	IV.2 VI.1-5	IV.2 V.B-F
			CH <sub>4</sub>	3.96				
			N <sub>2</sub> O	0.40				

**Major NSR Summary Table**

Permit Numbers: GHGPSDTX23						Issuance Date: November 21, 2013		
EPN	FIN	Description	GHG Mass Basis		CO <sub>2</sub> e TPY <sup>1,2</sup>	Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
				TPY <sup>1</sup>		Special Conditions/ Application Information	Special Conditions/ Application Information	Special Conditions/ Application Information
BO3	B-307	Boiler 3	CO <sub>2</sub>	209,750	209,957	III.C.10-15 III.G.1-3 V.A.1, V.B-J	IV.2 VI.1-5	IV.2 V.B-F
			CH <sub>4</sub>	3.96				
			N <sub>2</sub> O	0.40				
Totals <sup>3</sup>			CO <sub>2</sub>	2,569,698	CO <sub>2</sub> e 2,572,215			
			CH <sub>4</sub>	48.5				
			N <sub>2</sub> O	4.8				

1. The TPY emission limits specified in this table are not to be exceeded for this facility and include emissions from the facility during all operations and include MSS activities.
2. Global Warming Potentials (GWP): CH<sub>4</sub> = 21, N<sub>2</sub>O = 310
3. Totals are given for informational purposes only and do not constitute emission limits.



## Texas Commission on Environmental Quality Air Quality Permit

*A Permit Is Hereby Issued To*  
**Air Liquide Large Industries U.S. LP**  
*Authorizing the Construction and Operation of*  
**Air Liquide Bayport Complex**  
*Located at Pasadena, Harris County, Texas*  
*Latitude 29.621797 Longitude -95.044724*

Permits: 9346 and PSDTX612M2

Amendment Date: March 2, 2023

Expiration Date: November 18, 2031

A handwritten signature in black ink that reads "Erin E. Chamallo".

For the Commission

1. **Facilities** covered by this permit shall be constructed and operated as specified in the application for the permit. All representations regarding construction plans and operation procedures contained in the permit application shall be conditions upon which the permit is issued. Variations from these representations shall be unlawful unless the permit holder first makes application to the Texas Commission on Environmental Quality (commission) Executive Director to amend this permit in that regard and such amendment is approved. [Title 30 Texas Administrative Code (TAC) Section 116.116 (30 TAC § 116.116)] <sup>1</sup>
2. **Voiding of Permit.** A permit or permit amendment is automatically void if the holder fails to begin construction within 18 months of the date of issuance, discontinues construction for more than 18 months prior to completion, or fails to complete construction within a reasonable time. Upon request, the executive director may grant an 18-month extension. Before the extension is granted the permit may be subject to revision based on best available control technology, lowest achievable emission rate, and netting or offsets as applicable. One additional extension of up to 18 months may be granted if the permit holder demonstrates that emissions from the facility will comply with all rules and regulations of the commission, the intent of the Texas Clean Air Act (TCAA), including protection of the public's health and physical property; and (b)(1) the permit holder is a party to litigation not of the permit holder's initiation regarding the issuance of the permit; or (b)(2) the permit holder has spent, or committed to spend, at least 10 percent of the estimated total cost of the project up to a maximum of \$5 million. A permit holder granted an extension under subsection (b)(1) of this section may receive one subsequent extension if the permit holder meets the conditions of subsection (b)(2) of this section. [30 TAC § 116.120]
3. **Construction Progress.** Start of construction, construction interruptions exceeding 45 days, and completion of construction shall be reported to the appropriate regional office of the commission not later than 15 working days after occurrence of the event. [30 TAC § 116.115(b)(2)(A)]
4. **Start-up Notification.** The appropriate air program regional office shall be notified prior to the commencement of operations of the facilities authorized by the permit in such a manner that a representative of the commission may be present. The permit holder shall provide a separate notification for the commencement of operations for each unit of phased construction, which may involve a series of units commencing operations at different times. Prior to operation of the facilities authorized by the permit, the permit holder shall identify the source or sources of allowances to be utilized for compliance with Chapter 101, Subchapter H, Division 3 of this title (relating to Mass Emissions Cap and Trade Program). [30 TAC § 116.115(b)(2)(B)]
5. **Sampling Requirements.** If sampling is required, the permit holder shall contact the commission's Office of Compliance and Enforcement prior to sampling to obtain the proper data forms and procedures. All sampling and testing procedures must be approved by the executive director and coordinated with the regional representatives of the commission. The permit holder is also responsible for providing sampling facilities and conducting the sampling operations or contracting with an independent sampling consultant. [30 TAC § 116.115(b)(2)(C)]
6. **Equivalency of Methods.** The permit holder must demonstrate or otherwise justify the equivalency of emission control methods, sampling or other emission testing methods, and monitoring methods proposed as alternatives to methods indicated in the conditions of the permit. Alternative methods shall be applied for in writing and must be reviewed and approved by the executive director prior to their use in fulfilling any requirements of the permit. [30 TAC § 116.115(b)(2)(D)]
7. **Recordkeeping.** The permit holder shall maintain a copy of the permit along with records containing the information and data sufficient to demonstrate compliance with the permit, including production records and

operating hours; keep all required records in a file at the plant site. If, however, the facility normally operates unattended, records shall be maintained at the nearest staffed location within Texas specified in the application; make the records available at the request of personnel from the commission or any air pollution control program having jurisdiction in a timely manner; comply with any additional recordkeeping requirements specified in special conditions in the permit; and retain information in the file for at least two years following the date that the information or data is obtained. [30 TAC § 116.115(b)(2)(E)]

8. **Maximum Allowable Emission Rates.** The total emissions of air contaminants from any of the sources of emissions must not exceed the values stated on the table attached to the permit entitled "Emission Sources-- Maximum Allowable Emission Rates." [30 TAC § 116.115(b)(2)(F)] <sup>1</sup>
9. **Maintenance of Emission Control.** The permitted facilities shall not be operated unless all air pollution emission capture and abatement equipment is maintained in good working order and operating properly during normal facility operations. The permit holder shall provide notification in accordance with 30 TAC §101.201, 101.211, and 101.221 of this title (relating to Emissions Event Reporting and Recordkeeping Requirements; Scheduled Maintenance, Startup, and Shutdown Reporting and Recordkeeping Requirements; and Operational Requirements). [30 TAC§ 116.115(b)(2)(G)]
10. **Compliance with Rules.** Acceptance of a permit by an applicant constitutes an acknowledgment and agreement that the permit holder will comply with all rules and orders of the commission issued in conformity with the TCAA and the conditions precedent to the granting of the permit. If more than one state or federal rule or regulation or permit condition is applicable, the most stringent limit or condition shall govern and be the standard by which compliance shall be demonstrated. Acceptance includes consent to the entrance of commission employees and agents into the permitted premises at reasonable times to investigate conditions relating to the emission or concentration of air contaminants, including compliance with the permit. [30 TAC § 116.115(b)(2)(H)]
11. **This** permit may not be transferred, assigned, or conveyed by the holder except as provided by rule. [30 TAC § 116.110(e)]
12. **There** may be additional special conditions attached to a permit upon issuance or modification of the permit. Such conditions in a permit may be more restrictive than the requirements of Title 30 of the Texas Administrative Code. [30 TAC § 116.115(c)]
13. **Emissions** from this facility must not cause or contribute to "air pollution" as defined in Texas Health and Safety Code (THSC) §382.003(3) or violate THSC § 382.085. If the executive director determines that such a condition or violation occurs, the holder shall implement additional abatement measures as necessary to control or prevent the condition or violation.
14. **The** permit holder shall comply with all the requirements of this permit. Emissions that exceed the limits of this permit are not authorized and are violations of this permit. <sup>1</sup>

<sup>1</sup> Please be advised that the requirements of this provision of the general conditions may not be applicable to greenhouse gas emissions.

## Common Acronyms in Air Permits

°C = Temperature in degrees Celsius	GLCmax = maximum (predicted) ground-level concentration
°F = Temperature in degrees Fahrenheit	gpm = gallon per minute
°K = Temperature in degrees Kelvin	gr/1000scf = grain per 1000 standard cubic feet
µg = microgram	gr/dscf = grain per dry standard cubic feet
µg/m <sup>3</sup> = microgram per cubic meter	H <sub>2</sub> CO = formaldehyde
acfm = actual cubic feet per minute	H <sub>2</sub> S = hydrogen sulfide
AMOC = alternate means of control	H <sub>2</sub> SO <sub>4</sub> = sulfuric acid
AOS = alternative operating scenario	HAP = hazardous air pollutant as listed in § 112(b) of the Federal Clean Air Act or Title 40 Code of Federal Regulations Part 63, Subpart C
AP-42 = Air Pollutant Emission Factors, 5th edition	HC = hydrocarbons
APD = Air Permits Division	HCl = hydrochloric acid, hydrogen chloride
API = American Petroleum Institute	Hg = mercury
APWL = air pollutant watch list	HGB = Houston/Galveston/Brazoria
BPA = Beaumont/ Port Arthur	hp = horsepower
BACT = best available control technology	hr = hour
BAE = baseline actual emissions	IFR = internal floating roof tank
bbl = barrel	in H <sub>2</sub> O = inches of water
bbl/day = barrel per day	in Hg = inches of mercury
bhp = brake horsepower	IR = infrared
BMP = best management practices	ISC3 = Industrial Source Complex, a dispersion model
Btu = British thermal unit	ISCST3 = Industrial Source Complex Short-Term, a dispersion model
Btu/scf = British thermal unit per standard cubic foot or feet	K = Kelvin; extension of the degree Celsius scaled-down to absolute zero
CAA = Clean Air Act	LACT = lease automatic custody transfer
CAM = compliance-assurance monitoring	LAER = lowest achievable emission rate
CEMS = continuous emissions monitoring systems	lb = pound
cfm = cubic feet (per) minute	lb/day = pound per day
CFR = Code of Federal Regulations	lb/hr = pound per hour
CN = customer ID number	lb/MMBtu = pound per million British thermal units
CNG = compressed natural gas	LDAR = Leak Detection and Repair (Requirements)
CO = carbon monoxide	LNG = liquefied natural gas
COMS = continuous opacity monitoring system	LPG = liquefied petroleum gas
CPMS = continuous parametric monitoring system	LT/D = long ton per day
DFW = Dallas/ Fort Worth (Metroplex)	m = meter
DE = destruction efficiency	m <sup>3</sup> = cubic meter
DRE = destruction and removal efficiency	m/sec = meters per second
dscf = dry standard cubic foot or feet	MACT = maximum achievable control technology
dscfm = dry standard cubic foot or feet per minute	MAERT = Maximum Allowable Emission Rate Table
ED = (TCEQ) Executive Director	MERA = Modeling and Effects Review Applicability
EF = emissions factor	mg = milligram
EFR = external floating roof tank	mg/g = milligram per gram
EGU = electric generating unit	mL = milliliter
EI = Emissions Inventory	MMBtu = million British thermal units
ELP = El Paso	MMBtu/hr = million British thermal units per hour
EPA = (United States) Environmental Protection Agency	MSDS = material safety data sheet
EPN = emission point number	MSS = maintenance, startup, and shutdown
ESL = effects screening level	MW = megawatt
ESP = electrostatic precipitator	NAAQS = National Ambient Air Quality Standards
FCAA = Federal Clean Air Act	NESHAP = National Emission Standards for Hazardous Air Pollutants
FCCU = fluid catalytic cracking unit	NGL = natural gas liquids
FID = flame ionization detector	NNSR = nonattainment new source review
FIN = facility identification number	NO <sub>x</sub> = total oxides of nitrogen
ft = foot or feet	NSPS = New Source Performance Standards
ft/sec = foot or feet per second	
g = gram	
gal/wk = gallon per week	
gal/yr = gallon per year	
GLC = ground level concentration	



PAL = plant-wide applicability limit  
PBR = Permit(s) by Rule  
PCP = pollution control project  
PEMS = predictive emission monitoring system  
PID = photo ionization detector  
PM = periodic monitoring  
PM = total particulate matter, suspended in the atmosphere, including PM<sub>10</sub> and PM<sub>2.5</sub>, as represented  
PM<sub>2.5</sub> = particulate matter equal to or less than 2.5 microns in diameter  
PM<sub>10</sub> = total particulate matter equal to or less than 10 microns in diameter, including PM<sub>2.5</sub>, as represented  
POC = products of combustion  
ppb = parts per billion  
ppm = parts per million  
ppmv = parts per million (by) volume  
psia = pounds (per) square inch, absolute  
psig = pounds (per) square inch, gage  
PTE = potential to emit  
RA = relative accuracy  
RATA = relative accuracy test audit  
RM = reference method  
RVP = Reid vapor pressure  
scf = standard cubic foot or feet  
scfm = standard cubic foot or feet (per) minute  
SCR = selective catalytic reduction  
SIL = significant impact levels  
SNCR = selective non-catalytic reduction  
SO<sub>2</sub> = sulfur dioxide  
SOCMI = synthetic organic chemical manufacturing industry  
SRU = sulfur recovery unit  
TAC = Texas Administrative Code  
TCAA = Texas Clean Air Act  
TCEQ = Texas Commission on Environmental Quality  
TD = Toxicology Division  
TLV = threshold limit value  
TMDL = total maximum daily load  
tpd = tons per day  
tpy = tons per year  
TVP = true vapor pressure  
VOC = volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1  
VRU = vapor recovery unit or system

## Special Conditions

Permit Numbers 9346 and PSDTX612M2

1. This permit covers only those sources of emissions listed in the attached table entitled "Emission Sources - Maximum Allowable Emission Rates," (MAERT) including planned maintenance, startup, and shutdown (MSS) activities, and those sources are limited to the emission limits on that table and other conditions specified in this permit.

If any condition of this permit is more stringent than the regulations so incorporated, then for the purposes of complying with this permit, the permit shall govern and be the standard by which compliance shall be demonstrated.

## Federal Applicability

2. These facilities shall comply with all applicable requirements of the U.S. Environmental Protection Agency (EPA) regulations on Standards of Performance for New Stationary Sources,
  - A. promulgated in Title 40 Code of Federal Regulations (40 CFR) Part 60:
    - (1) Subpart A: General Provisions.
    - (2) Subpart Db: Standards of Performance for Industrial-Commercial-institutional Steam Generating Units.
    - (3) Subpart KKKK: Standards of Performance for Stationary Combustion Turbines, and
  - B. National Emission Standards for Hazardous Air Pollutants for Source Categories promulgated in in 40 CFR Part 63,
    - (1) Subpart A: General Provisions,
    - (2) Subpart ZZZZ: Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.

## Emission Standards and Operating Specifications

3. This permit authorizes four General Electric 7EA combustion turbines (CTs) operating with a heat recovery steam generator (HRSG) with duct burners. The CTs may employ wet compression on the turbine inlets for no more than 1,000 hours per year. The CTs are authorized for planned MSS as described in Attachment B, subject to the conditions of this permit and the representations in the permit application. During periods of planned MSS activities, the CTs shall be limited to the MAERT limits specified for MSS described in this permit. Emissions during CT only operations and emission during CT and duct burner firing operations shall not exceed the limits that are listed below, except during periods of planned MSS activities.

### Concentration Limits for CT Only Firing During Non-MSS Operations

Pollutant	Limit	Averaging time
Nitrogen oxides (NO <sub>x</sub> )	5.0 ppmvd <sup>1</sup>	3-hour rolling average
Carbon monoxide (CO)	15.0 ppmvd <sup>1</sup>	3-hour rolling average
Volatile organic compounds (VOC) <sup>2</sup>	0.002 lb/MMBtu <sup>3</sup>	3- hour average

**Concentration Limits for CT and Duct Burner Firing During Non-MSS Operations**

Pollutant	Limit	Averaging time
Nitrogen oxides (NO <sub>x</sub> )	7.0 ppmvd <sup>1</sup>	3-hour rolling average
Carbon monoxide (CO)	20.0 ppmvd <sup>1</sup>	3-hour rolling average
Volatile organic compounds (VOC) <sup>2</sup>	0.006 lb/MMBtu <sup>3</sup>	3- hour average

Note: <sup>1</sup> ppmvd is parts per million on a dry basis at 15% O<sub>2</sub>

<sup>2</sup> Defined as total hydrocarbons minus methane and ethane, calculated as methane. Also applies to VOC in Special Condition No. 6.

<sup>3</sup> lb/MMBtu is pounds per million British thermal units

4. Fuel for the CT, duct burners, and boilers are subject to the following limitations:
  - A. Pipeline-quality natural gas and fuel gas from neighboring facilities that contains no more than 0.25 grain of total sulfur per 100 dry standard cubic foot (dscf) on an annual basis. The sulfur content shall be monitored pursuant to 40 CFR 60 Subpart KKKK.
  - B. Firing of any other fuel will require authorization from the TCEQ Air Permits Division.
  - C. Upon request by representatives of the Texas Commission on Environmental Quality (TCEQ), EPA, or any local air pollution control program having jurisdiction, the permit holder shall provide a sample and/or an analysis of the fuel fired or shall allow air pollution control agency representatives to obtain a sample for analysis.
5. The duct burners are subject to the following limitations:
  - A. The maximum heat input of fuel fired in each heat recovery steam generator shall not exceed 166 MMBtu/hr.
  - B. Emissions of nitrogen oxides (NO<sub>x</sub>) from the firing of fuel in the heat recovery steam generators shall not exceed 0.10 pound per MMBtu heat input.
6. The boilers are subject to the following limitations:
  - A. Emissions shall not exceed the following limits on a three-hour average, except while operating on hot standby (firing less than 100 MMBtu/hr) and during periods of planned MSS:

**Boiler Concentration Limits**

Pollutant	Limit
NO <sub>x</sub>	0.01 lb/MMBtu
CO	50 ppmvd at 3% O <sub>2</sub>
NH <sub>3</sub>	10 ppmvd at 3% O <sub>2</sub>
VOC	0.004 lb/MMBtu

- B. Each boiler is limited to a maximum heat input of 550 MMBtu/hr, based on the higher heating value of the natural gas.

- C. When all four turbines are operational, the maximum combined hourly heat input to boilers 1-3 (EPNs B01, B02, and B03) shall not exceed 825 MMBtu/hr. An exemption to this provision may occur for a maximum of 720 hours per year when Boiler 4 is not operational. The maximum combined hourly heat input for Boilers 1-3 when Boiler 4 is offline shall not exceed 1,375 MMBTU/hr. **(03/23)**
  - D. The combined annual heat input of Boilers 1-3 (EPNs B01, B02, and B03) and all four turbines (excludes heat input to duct burners) shall not exceed 40,437,912 MMBtu/year.
  - E. The annual heat input for Boiler 4 (EPN B04) shall not exceed 4,818,000 MMBtu/year. The maximum hourly heat input to Boiler 4 shall not exceed 550 MMBtu/hr.
7. Except during planned MSS activities, the opacity shall not exceed five percent averaged over a six-minute period from any stack (EPNs CG801, CG802, CG803, CG804, BO1, BO2, BO3 and BO4). During MSS activities, the opacity shall not exceed 15 percent averaged over a six-minute period. Each determination shall be made by first observing for visible emissions while each facility is in operation. Observations shall be made at least 15 feet and no more than 0.25 mile from the emission point. If visible emissions are observed from an emission point, then the opacity shall be determined and documented within 24 hours of observing the visible emissions for that emission point using 40 CFR Part 60, Appendix A, Test Method 9. Contributions from uncombined water shall not be included in determining compliance with this condition. Observations shall be performed and recorded quarterly. If the opacity exceeds five percent during normal operations or 15 percent during MSS activities, corrective action to eliminate the source of visible emissions shall be taken promptly and documented within one week of first observation.

### **Ammonia Handling**

8. The aqueous NH<sub>3</sub> storage and delivery system is subject to the following requirements.
- A. The permit holder shall maintain loss prevention and protection measures for the storage system. The storage tank area must be marked and protected so as to protect the area from accidents that could cause a rupture.
  - B. Stored NH<sub>3</sub> must have a concentration of less than 29% NH<sub>3</sub> by weight.
  - C. All operating practices and procedures relating to the handling and storage of NH<sub>3</sub> shall conform to the safety recommendations specified for that compound by guidelines of the American National Standards Institute and the Compressed Gas Association.
9. The permit holder shall maintain the piping and valves in NH<sub>3</sub> service as follows:
- A. Audio, visual, and olfactory (AVO) checks for NH<sub>3</sub> leaks shall be made once a day.
  - B. As soon as possible, following the detection of a leak, plant personnel shall take one or more of the following actions:
    - (1) Locate and isolate the leak, if necessary.
    - (2) Commence repair or replacement of the leaking component.
    - (3) Use a leak collection or containment system to control the leak until repair or replacement can be made if immediate repair is not possible.

**Maintenance, Startup, and Shutdown (MSS)**

10. This permit authorizes the emissions from the planned MSS activities listed in Attachment A, Attachment B, and the maximum allowable emission rates table (MAERT) attached to this permit. Attachment A identifies the inherently low emitting (ILE) planned maintenance activities that this permit authorizes to be performed. Attachment B identifies the planned maintenance activities that are non-ILE planned maintenance activities that this permit authorizes to be performed.
11. The holder of this permit shall minimize emissions during planned MSS activities by operating the facility and associated air pollution control equipment in accordance with good air pollution control practices, safe operating practices, and protection of the facility.
12. Emissions during MSS activities will be minimized by limiting the duration of operation in planned MSS modes as follows:
  - A. CTs/Duct Burners
    - (1) Planned startup of each CT is defined as the period that begins when the data acquisition and handling system (DAHS) measures fuel flow to the CT and ends when the CT generator (CTG) load reaches 65 MW. A planned startup for each CT is limited to 240 minutes per event. At the conclusion of the startup period (the CTG load reaches 65 MW or 240 minutes, whichever comes first), the permit holder shall comply with the emission concentration limitations in Special Condition No. 3 and the normal operation emission rates in the MAERT.
    - (2) A planned shutdown of each CT is defined as the period that begins when the CTG output drops below 65 MW load and ends when there is no longer measurable fuel flow to the CT. A planned shutdown for each CT is limited to 60 minutes per event.
    - (3) Emissions from boiler and turbine optimization and tuning activities, identified in Attachment B, shall be subject to the hourly emission limits for MSS activities listed on the MAERT. The emissions from such activities shall not exceed the hourly emission limits listed on the MAERT for normal (non-MSS) operations for more than sixteen hours per calendar year.
  - B. Boilers
    - (1) A planned startup is defined as the period that begins when the DAHS detects measurable fuel flow to the boiler and ends when the boiler reaches hot standby or the fuel flow at which the boiler will operate. A planned startup is limited to 300 minutes per event.
    - (2) A planned shutdown is defined as the period that begins when the boiler drops below the hot standby fuel flow level and ends when no fuel flow is detected. A planned shutdown is limited to 60 minutes per event.
13. The CO mass emissions limits in the MAERT attached to this permit that apply during planned MSS activities constitute alternative case specific specifications for the CO and concentration limits in Title 30 Texas Administrative Code (30 TAC) Chapter 117.310(c) during planned MSS activities.
14. Compliance with the emissions limits for planned MSS activities identified in the MAERT attached to this permit shall be demonstrated as follows.

- A. For ILE planned maintenance activities identified in Attachment A of this permit:
  - (1) The total emissions from all ILE planned maintenance activities shall be considered to be no more than the estimated potential to emit for those activities that are represented in the permit application.
  - (2) The permit holder shall annually confirm the continued validity of the estimated potential to emit represented in the permit application for all ILE planned maintenance activities.
- B. For planned MSS activities identified in Attachment B of this permit, the permit holder shall do the following.
  - (1) For each pollutant whose emissions are measured with a CEMS that has been certified to measure the pollutant's emissions over the entire range of a planned MSS activity, the permit holder shall measure the emissions of the pollutant during the planned MSS activity using the CEMS.
  - (2) For each pollutant whose emissions are not measured with a CEMS in accordance with B.(1) of this condition, determine for each calendar month the emissions of each pollutant listed on the MAERT of this permit from all occurrences of planned MSS activity by calculation. The calculations of the pollutant's hourly and monthly emissions must use data related to the planned MSS activity, identified in turbine operating records, work orders, or equivalent records. The emission rate of the pollutant during the planned MSS activity must be determined either:
    - (a) as represented in the permit application; or
    - (b) as determined with an appropriate method, including but not limited to any of the following methods, provided that the permit holder maintains appropriate records supporting such determination:
      - i. use of emission factor(s), facility-specific parameter(s), and/or engineering knowledge of the facility's operations;
      - ii. use of emissions data measured (by a CEMS or during emissions testing) during the same type of planned MSS activity occurring at or on a similar facility, and correlation of that data with the activity's or facility's relevant operating parameters;
      - iii. use of emissions testing data collected during a planned MSS activity occurring at or on the facility, and correlation of that data with the facility's or activity's relevant operating parameters, such as electric load, temperature, fuel input, or fuel sulfur content; or
      - iv. use of parametric monitoring system data applicable to the facility.

#### **Initial Determination of Compliance**

- 15. The permit holder shall perform stack sampling and other testing as required to establish the actual quantities of air contaminants being emitted into the atmosphere from the four turbines and four boilers (EPNs CG801, CG802, CG803, CG804, BO1, BO2, BO3 and BO4). Sampling shall be conducted in accordance with the appropriate procedures of the TCEQ Sampling Procedures

Manual and in accordance with EPA Test Methods or by other equivalent methods approved by the TCEQ Regional Director.

Fuel sampling using the methods and procedures of 40 CFR § 60.4415 may be conducted in lieu of stack sampling for sulfur dioxide (SO<sub>2</sub>). If fuel sampling is used, compliance with NSPS Subpart KKKK, SO<sub>2</sub> limits shall be based on 100 percent conversion of the sulfur in the fuel to SO<sub>2</sub>. Any deviations from those procedures must be approved by the Executive Director of the TCEQ prior to sampling. The TCEQ Executive Director or his designated representative shall be afforded the opportunity to observe all such sampling.

The permit holder is responsible for providing sampling and testing facilities and conducting the sampling and testing operations at his expense.

- A. The TCEQ Regional Office shall be contacted as soon as testing is scheduled but not less than 30 days prior to sampling to schedule a pretest meeting. The notice shall include:
- (1) Date for pretest meeting.
  - (2) Date sampling will occur.
  - (3) Name of firm conducting sampling.
  - (4) Type of sampling equipment to be used.
  - (5) Method or procedure to be used in sampling.
  - (6) Procedure used to determine turbine loads during and after the sampling period.
  - (7) A description of how stack sampling will be conducted in order to demonstrate compliance with emission standards found in 40 CFR Part 60, Subparts DB and KKKK.

The purpose of the pretest meeting is to review the necessary sampling and testing procedures, to provide the proper data forms for recording pertinent data, and to review the format procedures for submitting the test reports.

A written proposed description of any deviation from sampling procedures specified in permit conditions or the TCEQ or EPA sampling procedures shall be made available to the TCEQ prior to the pretest meeting. The TCEQ Regional Director shall approve or disapprove of any deviation from specified sampling procedures.

Requests to waive testing for any pollutant specified in this condition shall be submitted to the TCEQ Office of Air, Air Permits Division. Test waivers and alternate or equivalent procedure proposals for NSPS testing which must have EPA approval shall be submitted to the TCEQ Air Permits Division.

- B. Air contaminants to be sampled and analyzed from each of the turbines, EPNs CG801, CG802, CG803, and CG804, include (but are not limited to) NO<sub>x</sub>, CO, VOC, SO<sub>2</sub>, opacity, total particulate matter (filterable and condensable) less than ten and two and a half microns in diameter.
- C. The turbine shall be tested at the maximum load for the atmospheric conditions which exist during testing. Each turbine shall be tested while the duct burners are not being fired to demonstrate compliance with the turbine performance standards in Special Condition No. 3. The tested turbine load shall be identified in the sampling report.

- D. Each of the boilers, EPNs BO1, BO2, BO3, and BO4, shall be tested at their maximum firing rate for: NO<sub>x</sub>, CO, VOC, NH<sub>3</sub>, SO<sub>2</sub>, opacity, total particulate matter (filterable and condensable) less than ten and two and a half microns in diameter.
- E. Sampling as required by this condition shall occur within 60 days after achieving the maximum production rate at which the turbine or boiler will be operated, but no later than 180 days after initial startup of each unit. Additional sampling may be required by the TCEQ or EPA.
- F. Within 60 days after the completion of the testing and sampling required herein, two copies of the sampling reports shall be distributed as follows:
  - (1) One copy to the TCEQ Air Permits Division in Austin.
  - (2) One copy to the TCEQ Regional Office.

#### **Continuous Determination of Compliance**

- 16. The permit holder shall install, calibrate, operate, and maintain a CEMS to measure and record the concentrations of NO<sub>x</sub>, CO, and diluent (O<sub>2</sub> or carbon dioxide) from the exhaust stacks of EPNs CG801, CG802, CG803, CG804, BO1, BO2, and BO3, and BO4.
  - A. The NO<sub>x</sub> and diluent CEMS shall meet the design and performance specifications, pass the field tests, and meet the installation requirements and the data analysis and reporting requirements specified in the applicable performance specifications in 40 CFR Part 75, Appendices A and B. The requirements of 40 CFR Part 75, Appendices A and B are deemed an acceptable alternative to the performance specifications and quality assurance requirements of 40 CFR Part 60.
  - B. The CO CEMS shall meet the design and performance specifications, pass the field tests, and meet the installation requirements and the data analysis and reporting requirements specified in the applicable performance specifications in 40 CFR Part 60, Performance Specification No. 4. The CEMS shall meet the applicable quality assurance requirements specified in 40 CFR Part 60, Appendix F, except that cylinder gas audits (CGA) conducted in all four quarters may be used in lieu of the annual relative accuracy test audit. Quarterly CGAs shall be conducted at least 60 days apart. A CGA is not required in any quarter in which the CT or boiler operates less than 168 hours. Relative accuracy exceedances (as specified in 40 CFR 60, Appendix F), CGA exceedances of ±15% accuracy, and any CO CEMS downtime shall be reported to the TCEQ Houston Regional Director, and necessary corrective action shall be taken. Supplemental stack sampling may be required at the discretion of the TCEQ Houston Regional Director.
  - C. The CEMS shall be zeroed and spanned daily and corrective action taken when the 24-hour span drift exceeds two times the amounts specified in the applicable Performance Specification.
  - D. For full operating hours, the monitoring data must be reduced to hourly average values at least once every day, using a minimum of four, and normally 60, approximately equally-spaced data points from each one-hour period. For hours in which calibration checks, zero and span adjustments, system breakdowns, or repairs occur, at least two valid data points separated by a minimum of 15 minutes (where the unit operates for more than one quadrant of an hour) will be sufficient to quality-assure the hour.



- E. The valid hourly average data from the CEMS, in conjunction with the hourly average natural gas fuel consumption data required by Special Condition No. 18, may be used to determine compliance with the concentration and emission limits of Special Condition No. 3 and 6 and with the hourly emission rate in the MAERT. Pounds per hour data from each EPN identified above must be summed monthly to tons per year and used to determine compliance with the annual emission limits of the MAERT.
17. The NH<sub>3</sub> concentration from the boiler exhaust stacks EPN BO1, BO2, BO3 and BO4 shall be tested or calculated according to one of the methods listed below and shall be tested or calculated according to frequency listed below. Testing for NH<sub>3</sub> slip is only required on days when the selective catalytic reduction (SCR) unit is in operation.
- A. The permit holder may install, calibrate, maintain, and operate a CEMS to measure and record the concentrations of NH<sub>3</sub>. Each ammonia CEMS shall be audited at least once each calendar quarter.
  - B. As an approved alternative, the NH<sub>3</sub> slip may be measured using a sorbent or stain tube device specific for NH<sub>3</sub> measurement in the 5 to 10 ppm range. The frequency of sorbent/stain tube testing shall be daily for the first 60 days of operation, after which, the frequency may be reduced to weekly testing if operating procedures have been developed to prevent excess amounts of urea from being introduced in the SCR unit and when operation of the SCR unit have been proven successful with regard to controlling NH<sub>3</sub> slip. Daily sorbent or stain tube testing shall resume when the catalyst is within 30 days of its useful life expectancy. These results shall be recorded and used to determine compliance with Special Condition No. 6.  
  
If the sorbent or stain tube testing indicates an ammonia slip concentration exceeds 10 ppm for a consecutive one-hour period or the average of one or more sorbent or stain tube tests in an hour, the permit holder shall begin NH<sub>3</sub> testing by either the Phenol Nitroprusside Method, the Indophenol Method, or the EPA Conditional Test Method (CTM) 27 on a quarterly basis, in addition to the weekly sorbent or stain tube testing. The quarterly testing shall continue until such time as the SCR unit catalyst is replaced; or if the quarterly testing indicates NH<sub>3</sub> slip is 7 ppm or less, the Phenol-Nitroprusside/Indophenol/CTM 27 tests may be suspended until sorbent/stain tube testing again indicate 10 ppm NH<sub>3</sub> slip or greater. These results shall be recorded and used to determine compliance with Special Condition No. 6.
  - C. As an approved alternative to sorbent or stain tube testing, NH<sub>3</sub> CEMS, or a second NO<sub>x</sub> CEMS, the permit holder may install and operate a dual stream system of NO<sub>x</sub> CEMS at the exit of the SCR. One of the exhaust streams would be routed, in an unconverted state, to one NO<sub>x</sub> CEMS, and the other exhaust stream would be routed through a NH<sub>3</sub> converter to convert NH<sub>3</sub> to NO<sub>x</sub> and then to a second NO<sub>x</sub> CEMS. The NH<sub>3</sub> slip concentration shall be calculated from the difference between the two NO<sub>x</sub> CEMS readings (converted and unconverted). These results shall be recorded and used to determine compliance with Special Condition No. 6.
  - D. Any other method used for measuring NH<sub>3</sub> slip shall require prior approval from the TCEQ.
18. The permit holder shall install, calibrate, maintain, and operate a continuous monitoring system to monitor and record the average hourly natural gas consumption of the turbines and boilers. The permit holder shall comply with the initial certification and quality assurances as specified in 40 CFR Part 60 (boilers) and 75 (turbines).

### **Recordkeeping Requirements**

19. The following records shall be kept at the plant for the life of the permit and shall be made available upon request by representatives of the TCEQ, EPA, or any local air pollution control program having jurisdiction:
  - A. A copy of this permit.
  - B. The permit application dated July 2012 and subsequent representations submitted to the TCEQ.
  - C. A complete copy of the testing reports and records of the initial performance testing completed pursuant to Special Condition No. 15 to demonstrate initial compliance.
  - D. Stack sampling results or other air emissions testing (other than CEMS data) that may be conducted on units authorized under this permit after the date of issuance of this permit.
20. The following information shall be maintained by the permit holder in a form suitable for inspection for a period of five years after collection and shall be made available upon request by representatives of the TCEQ, EPA, or any local air pollution control program having jurisdiction:
  - A. For pollutants that are monitored by CEMS, hourly records of emissions and operations to demonstrate compliance with the applicable performance standards of NSPS Subpart KKKK and Db, the concentration limits of Special Condition No. 3, and 6, and the hourly and annual emission rates listed in the MAERT, as follows.
    - (1) Continuous emission monitoring data for NO<sub>x</sub>, CO, diluent gases, O<sub>2</sub> or CO<sub>2</sub>, and if applicable, NH<sub>3</sub>. Data retention at intervals less than one hour is not required. Records should identify the times when emissions data have been excluded from the calculation of average emission rates because of MSS or malfunction along with the justification for excluding data. Records should also identify factors used in calculations that are used to demonstrate compliance with emission limits and performance standards.
    - (2) Files of all CEMS quality assurance measures, calibration checks, adjustments and maintenance performed on these systems to demonstrate compliance with Special Condition No. 16.
  - B. Records of visible emission/opacity observations and date and description of corrective actions taken pursuant to Special Condition No. 7.
  - C. Records of fuel usage of the boiler to demonstrate compliance with Special Condition Nos. 5, 6, and 18.
  - D. Records necessary to demonstrate compliance with the applicable NSPS identified in Special Condition No. 2, including fuel purchase records, copies of gas supply contracts, test results, or other information to demonstrate compliance with the SO<sub>2</sub> emission limits of NSPS Subpart KKKK and fuel sulfur limits of Special Condition No. 4.
  - E. Records of audio, olfactory, and visual checks for ammonia leaks and maintenance performed to any piping and valves in NH<sub>3</sub> service to show compliance with Special Condition No. 9. In addition, written records of any accidental releases, spills, or venting of NH<sub>3</sub> and the corrective action taken.

- F. As applicable, records of NH<sub>3</sub> emissions sampling and calculations pursuant to Special Condition No. 17.
- G. Records of planned MSS activities including; the date, time, and duration of those activities, emissions from those activities, and periods when CEMS data have been excluded for purposes of demonstrating compliance with Special Condition Nos. 3, 6, 12, 13, and 14.

### **Reporting**

- 21. The permit holder shall submit to the TCEQ Regional Office and the Air Enforcement Branch of EPA in Dallas reports as described in 40 CFR § 60.7 for each emission unit which is required to be continuously monitored pursuant 40 CRF § 60.

Date: March 2, 2023

Attachment A  
Permit Nos. 9346 and PSDTX612M2

Inherently Low Emitting Planned Maintenance Activities					
Planned Maintenance Activity	Emissions				
	NO <sub>x</sub>	CO	VOC	PM	NH <sub>3</sub>
Line breaks <sup>1</sup>			X		
Turbine washing, unit on-line <sup>2</sup>				X	
Catalyst handling and maintenance <sup>3</sup>				X	
Inspect, repair, replace, adjusting, testing, and calibration of analytical equipment, process instruments including sight glasses, meters, gauges				X	
Boiler tube cleaning			X	X	
CEMS calibration	X	X			X
Miscellaneous particulate filter maintenance				X	
Water based washing				X	
Management of sludge from pits, ponds, sumps, and water conveyances			X	X	
Brazing, soldering and welding				X	

Date: November 18, 2021

---

<sup>1</sup> Includes, but is not limited to, fugitive components and gaseous fuel venting that will happen for pump, filter, and valve maintenance.

<sup>2</sup> Involves use of water only.

<sup>3</sup> Includes but not limited to, replacement, cleaning, activation, and deactivation of catalysts.

Attachment B  
Permit Nos. 9346 and PSDTX612M2

Non-Inherently Low Emitting Planned MSS Activities							
Planned Maintenance Activity	EPN	Emissions					
		NO <sub>x</sub>	CO	VOC	PM	NH <sub>3</sub>	SO <sub>2</sub>
Boiler and turbine optimization and tuning <sup>1</sup> following maintenance	CG801, CG802, CG803, CG804, BO1, BO2, BO3, and BO4	X	X	X	X	X	X
SCR maintenance, unit on-line	BO1, BO2, BO3, and BO4	X				X	
Closed Loop Emissions Control Analyzer Maintenance, Unit on-line	CG801, CG802, CG803, CG804	X	X				
Planned startups and shutdowns <sup>2</sup>	CG801, CG802, CG803, CG804, BO1, BO2, BO3, and BO4	X	X	X	X	X	X

Date: November 18, 2021

---

<sup>1</sup> Includes, but is not limited to: (i) leak and operability checks (e.g. CT overspeed trip testing, troubleshooting); (ii) generator balancing; and (iii) tuning activities that occur during seasonal tuning or after the completion of initial construction, a combustor change-out, a major repair, maintenance to a combustor, or other similar circumstances.

<sup>2</sup> Includes, but is not limited to: (i) steam system maintenance; (ii) low customer steam or electricity demand; (iii) turbine oil system inspection and maintenance; and (iv) off-line water wash.

# Emission Sources - Maximum Allowable Emission Rates

Permit Numbers 9346 and PSDTX612M2

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

## Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour (4) (5)	TPY (4) (6)
CG801	Gas Turbine Only	NO <sub>x</sub>	17.46	76.48
		NO <sub>x</sub> (7)	170.00	
		CO	31.89	139.67
		CO (7)	450.00	
		VOC	1.89	8.26
		VOC (7)	15.5	
		SO <sub>2</sub>	0.66	2.91
		PM	4.50	19.71
		PM <sub>10</sub>	4.50	19.71
		PM <sub>2.5</sub>	3.90	17.08
		H <sub>2</sub> SO <sub>4</sub>	0.07	0.29
		HAPs	0.60	(8)
CG802	Gas Turbine Only	NO <sub>x</sub>	17.46	76.48
		NO <sub>x</sub> (7)	170.00	
		CO	31.89	139.67
		CO (7)	450.00	
		VOC	1.89	8.26
		VOC (7)	15.5	
		SO <sub>2</sub>	0.66	2.91
		PM	4.50	19.71
		PM <sub>10</sub>	4.50	19.71
		PM <sub>2.5</sub>	3.90	17.08
		H <sub>2</sub> SO <sub>4</sub>	0.07	0.29
		HAPs	0.60	(8)

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour (4) (5)	TPY (4) (6)
CG803	Gas Turbine Only	NO <sub>x</sub>	17.46	76.48
		NO <sub>x</sub> (7)	170.00	
		CO	31.89	139.67
		CO (7)	450.00	
		VOC	1.89	8.26
		VOC (7)	15.5	
		SO <sub>2</sub>	0.66	2.91
		PM	4.50	19.71
		PM <sub>10</sub>	4.50	19.71
		PM <sub>2.5</sub>	3.90	17.08
		H <sub>2</sub> SO <sub>4</sub>	0.07	0.29
		HAPs	0.60	(8)
CG804	Gas Turbine Only	NO <sub>x</sub>	17.46	76.48
		NO <sub>x</sub> (7)	170.00	
		CO	31.89	139.67
		CO (7)	450.00	
		VOC	1.89	8.26
		VOC (7)	15.5	
		SO <sub>2</sub>	0.66	2.91
		PM	4.50	19.71
		PM <sub>10</sub>	4.50	19.71
		PM <sub>2.5</sub>	3.90	17.08
		H <sub>2</sub> SO <sub>4</sub>	0.07	0.29
		HAPs	0.60	(8)

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour (4) (5)	TPY (4) (6)
CG801	Gas Turbine and Duct Burner Firing	NO <sub>x</sub>	34.05	149.14
		NO <sub>x</sub> (7)	186.59	
		CO	38.53	168.74
		CO (7)	456.64	
		VOC	2.55	11.17
		VOC (7)	16.16	
		SO <sub>2</sub>	0.76	3.34
		PM	5.74	25.12
		PM <sub>10</sub>	5.74	25.12
		PM <sub>2.5</sub>	5.14	22.50
		H <sub>2</sub> SO <sub>4</sub>	0.08	0.33
		HAPs	0.91	(8)
CG802	Gas Turbine and Duct Burner Firing	NO <sub>x</sub>	34.05	149.14
		NO <sub>x</sub> (7)	186.59	
		CO	38.53	168.74
		CO (7)	456.64	
		VOC	2.55	11.17
		VOC (7)	16.16	
		SO <sub>2</sub>	0.76	3.34
		PM	5.74	25.12
		PM <sub>10</sub>	5.74	25.12
		PM <sub>2.5</sub>	5.14	22.50
		H <sub>2</sub> SO <sub>4</sub>	0.08	0.33
		HAPs	0.91	(8)



Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour (4) (5)	TPY (4) (6)
CG803	Gas Turbine and Duct Burner Firing	NO <sub>x</sub>	34.05	149.14
		NO <sub>x</sub> (7)	186.59	
		CO	38.53	168.74
		CO (7)	456.64	
		VOC	2.55	11.17
		VOC (7)	16.16	
		SO <sub>2</sub>	0.76	3.34
		PM	5.74	25.12
		PM <sub>10</sub>	5.74	25.12
		PM <sub>2.5</sub>	5.14	22.50
		H <sub>2</sub> SO <sub>4</sub>	0.08	0.33
		HAPs	0.91	(8)
CG804	Gas Turbine and Duct Burner Firing	NO <sub>x</sub>	34.05	149.14
		NO <sub>x</sub> (7)	186.59	
		CO	38.53	168.74
		CO (7)	456.64	
		VOC	2.55	11.17
		VOC (7)	16.16	
		SO <sub>2</sub>	0.76	3.34
		PM	5.74	25.12
		PM <sub>10</sub>	5.74	25.12
		PM <sub>2.5</sub>	5.14	22.50
		H <sub>2</sub> SO <sub>4</sub>	0.08	0.33
		HAPs	0.91	(8)

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour (4) (5)	TPY (4) (6)
BO1	Boiler 1	NO <sub>x</sub>	5.50	17.95
		NO <sub>x</sub> (7)	165.00	
		CO	20.35	66.41
		CO (7)	203.50	
		VOC	2.20	7.18
		VOC (7)	22.00	
		SO <sub>2</sub>	0.39	1.26
		PM	4.40	14.36
		PM <sub>10</sub>	2.75	8.97
		PM <sub>2.5</sub>	1.65	5.38
		H <sub>2</sub> SO <sub>4</sub>	0.04	0.13
		HAPs	1.02	(8)
		NH <sub>3</sub>	2.47	8.07
BO2	Boiler 2	NO <sub>x</sub>	5.50	17.95
		NO <sub>x</sub> (7)	165.00	
		CO	20.35	66.41
		CO (7)	203.50	
		VOC	2.20	7.18
		VOC (7)	22.00	
		SO <sub>2</sub>	0.39	1.26
		PM	4.40	14.36
		PM <sub>10</sub>	2.75	8.97
		PM <sub>2.5</sub>	1.65	5.38
		H <sub>2</sub> SO <sub>4</sub>	0.04	0.13
		HAPs	1.02	(8)
		NH <sub>3</sub>	2.47	8.07

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour (4) (5)	TPY (4) (6)
BO3	Boiler 3	NO <sub>x</sub>	5.50	17.95
		NO <sub>x</sub> (7)	165.00	
		CO	20.35	66.41
		CO (7)	203.50	
		VOC	2.20	7.18
		VOC (7)	22.00	
		SO <sub>2</sub>	0.39	1.26
		PM	4.40	14.36
		PM <sub>10</sub>	2.75	8.97
		PM <sub>2.5</sub>	1.65	5.38
		H <sub>2</sub> SO <sub>4</sub>	0.04	0.13
		HAPs	1.02	(8)
		NH <sub>3</sub>	2.47	8.07
BO4	Boiler 4	NO <sub>x</sub>	4.95	21.68
		NO <sub>x</sub> (7)	55.00	
		CO	18.15	79.50
		CO (7)	181.50	
		VOC	1.98	8.67
		NH <sub>3</sub>	2.48	10.84
		SO <sub>2</sub>	0.39	1.69
		PM	3.96	17.34
		PM <sub>10</sub>	2.48	10.84
		PM <sub>2.5</sub>	1.49	6.50
		H <sub>2</sub> SO <sub>4</sub>	0.04	0.17
		HAPs	0.05	(8)
		NH <sub>3</sub>	2.48	10.84
CG801, CG802, CG803, CG804, BO1, BO2, BO3, BO4	Site-wide HAPs	Total HAPs	-	23.51
		Any single HAP	-	10.00
MSS-Fug	Maintenance Fugitive Emissions	VOC	16.2	0.04
Fug -Ammonia	Fugitive Ammonia Emissions	NH <sub>3</sub>	0.01	0.06

Emission Sources - Maximum Allowable Emission Rates

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3)
  - NO<sub>x</sub> - total oxides of nitrogen
  - NH<sub>3</sub> - ammonia
  - SO<sub>2</sub> - sulfur dioxide
  - CO - carbon monoxide
  - VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
  - PM - total particulate matter, suspended in the atmosphere, including PM<sub>10</sub> and PM<sub>2.5</sub>
  - PM<sub>10</sub> - total particulate matter equal to or less than 10 microns in diameter, including PM<sub>2.5</sub>
  - PM<sub>2.5</sub> - particulate matter equal to or less than 2.5 microns in diameter
  - H<sub>2</sub>SO<sub>4</sub> - sulfuric acid
  - HAPs - Hazardous Air Pollutants
- (4) The pound per hour (lb/hr) and ton per year (tpy) emission limits specified in the MAERT for this facility includes emissions from the facility during both normal operations and planned MSS activities, unless otherwise noted.
- (5) For each pollutant whose emissions during planned MSS activities are measured using a CEMS, the MSS lb/hr limits apply only during each clock hour that includes one or more minutes of MSS activities. During all other clock hours, the normal lb/hr limits apply.
- (6) Compliance with annual emission limits is based on a rolling 12-month period.
- (7) MSS hourly emission limit only. The tpy emission limit specified in the MAERT for this facility includes emissions from the facility during both normal operations and planned MSS activities.
- (8) Annual HAPs limits are within the Site-wide HAPs limits below.

Date: November 18, 2021

**PREVENTION OF SIGNIFICANT DETERIORATION PERMIT  
FOR GREENHOUSE GAS EMISSIONS  
ISSUED PURSUANT TO THE REQUIREMENTS AT 40 CFR § 52.21**

**U.S. ENVIRONMENTAL PROTECTION AGENCY, REGION 6**

**PSD PERMIT NUMBER:** PSD-TX-612-GHG

**PERMITTEE:** Air Liquide Large Industries U.S., L.P.


**FACILITY NAME:** Air Liquide Large Industries U.S., L.P.  
Bayou Cogeneration Plant

**FACILITY LOCATION:** 11777 Bay Area Blvd.  
Pasadena, Texas 77507

Pursuant to the provisions of the Clean Air Act (CAA), Subchapter I, Part C (42 U.S.C. Section 7470, *et. Seq.*), and the Code of Federal Regulations (CFR) Title 40, Section 52.21, and the Federal Implementation Plan at 40 CFR § 52.2305 (effective May 1, 2011 and published at 76 FR 25178), the U.S. Environmental Protection Agency, Region 6 is issuing a *Prevention of Significant Deterioration* (PSD) permit to Air Liquide Large Industries U.S., L.P. (Air Liquide) for Greenhouse Gas (GHG) emissions. The Permit applies to the redevelopment of its cogeneration facility at their Bayou Cogeneration Plant located in Pasadena, Texas.

Air Liquide is authorized to replace four (4) gas-fired gas turbines with similar units, add three (3) new gas-fired boilers and subsequently remove three (3) existing boilers as described herein, in accordance with the permit application (and plans submitted with the permit application), the federal PSD regulations at 40 CFR § 52.21, and other terms and conditions set forth in this PSD permit in conjunction with the corresponding Texas Commission on Environmental Quality (TCEQ) PSD permit No. PSD-TX-612M2. Failure to comply with any condition or term set forth in this PSD Permit may result in enforcement action pursuant to Section 113 of the Clean Air Act (CAA). This PSD Permit does not relieve Air Liquide of the responsibility to comply with any other applicable provisions of the CAA (including applicable implementing regulations in 40 CFR Parts 51, 52, 60, 61, 72 through 75, and 98) or other federal and state requirements (including the state PSD program that remains under approval at 40 CFR § 52.2303).

In accordance with 40 CFR §124.15(b)(3), this PSD Permit becomes effective immediately upon issuance of this final decision.

  
Wren Stenger, Director  
Multimedia Planning and Permitting Division

11/21/13  
Date

**Air Liquide Large Industries U.S., L.P. (PSD-TX-612-GHG)**  
**Prevention of Significant Deterioration Permit**  
**For Greenhouse Gas Emissions**  
**Final Permit Conditions**

**PROJECT DESCRIPTION**

The redevelopment project at the Bayou Cogeneration Plant will replace components of the power block and the boilers at the existing facility. The power block project will replace the four existing gas turbines at the plant with new GE Frame 7EA gas turbines (which are closest in specification to the existing turbines and are closer to the maximum design thermal efficiency of the original plant).

The project does not include replacement of the Heat Recovery Steam Generators (HRSGs) or duct burners. The redevelopment project will also add three new 550 MMBtu/hr natural gas-fired boilers to the Bayou Cogeneration plant, and the subsequent shutdown of three existing 442.9 MMBtu/hr boilers at the plant. The new boilers will be controlled using Selective Catalytic Reduction (SCR) units for nitrogen oxides (NO<sub>x</sub>) emissions.

The proposed project will be executed in three phases: no more than 18 months shall pass between the completion of a phase and the beginning of the subsequent phase: construction of the phases shall be continuous and completed in a reasonable timeframe:

- Phase 1 commences upon start of construction of the three new boilers. Phase 1 only includes the construction of the three new boilers and does not include construction of the four new turbines. Each of the three new boilers will be equipped with selective catalytic reduction (SCR) systems to reduce NO<sub>x</sub> emissions to the atmosphere. The existing gas turbines and boilers will not be modified during this phase of the project and will continue to operate at currently permitted levels by the TCEQ PSD Permit PSD-TX-612M1; therefore, the only activity during this phase of the project will be the construction of the three new boilers. Phase 1 is complete when construction on the three new boilers has concluded.
- Phase 2 involves the decommissioning, removal and replacement of each of the four existing turbines. Replacement of the existing turbines is anticipated to occur one turbine at a time, but may involve some concurrent overlapping construction and decommissioning activities involving several turbines. During this phase, the four existing gas turbines will be replaced with new GE 7EA gas turbine units. In addition to the three existing boilers, the three new boilers will need to be operational and available to fulfill steam/thermal supply contractual obligations during this phase; however, at no point will the four new gas turbines, three new boilers, and three existing boilers operate simultaneously during Phase 2. Once an existing gas turbine has

been replaced with a new gas turbine, the new gas turbine will complete initial stack testing in accordance with Special Condition V.A.2. The emissions during this phase will not exceed the potential emissions from the overall project, including the CO<sub>2</sub> emissions. Additionally, Air Liquide will operate the equipment such that all emissions during this phase are less than the respective permit limits. Phase 2 is complete when all four existing turbines have been replaced and decommissioned and all new gas turbines have completed an initial stack test.

The additional operation limitations apply in Phase 2 of construction, after the three new boilers have been constructed and before the four existing turbines and three existing boilers have been permanently shutdown. If any one of the four existing turbines have been shut down for replacement, then all six boilers (three new and three existing boilers) may be available for operation simultaneously, with a restriction that the three new boilers will operate with a maximum heat input (combined for all three new boilers) not to exceed 990 MMBtu/hour and 8,672,400 MMBtu/year. If two or more of the existing turbines is offline during the interim period, all six boilers (three new and three existing boilers) may operate at full fire in order to meet contractual steam demand. The additional operational limits will exist until the end of phase 2 when all four existing turbines have been replaced and decommissioned. The four (new or existing) turbines, three new boilers, and the three existing boilers are not allowed to all operate simultaneously at any time during the three construction phases.

- Phase 3 commences upon completion of Phase 2 and involves the permanent shutdown and decommissioning of the three existing boilers. Phase 3 is complete when the three existing boilers have been decommissioned and mothballed. These boilers will not be removed.

## EQUIPMENT LIST

The following devices are subject to this GHG PSD permit

FIN	EPN	Source Name
B-305 B-306 B-307	BO1 BO2 BO3	3 Boilers (Combustion Units) 550 MMBtu/hr (each) rated maximum heat input boilers with Selective Catalytic Reduction (SCR) controls
GT1 GT2 GT3 GT4	CG-801 CG-802 CG-803 CG-804	4 GE 7EA Turbines (Combustion Units) 948MMBtu/hr (each) rated heat input CHP turbines

## **I. GENERAL PERMIT CONDITIONS**

### **A. PERMIT EXPIRATION**

As provided in 40 CFR §52.21(r), this PSD Permit shall become invalid if construction:

1. is not commenced (as defined in 40 CFR §52.21(b)(9)) within 18 months after the approval takes effect; or
2. is not completed within a reasonable time.

This permit applies to a phased construction project. Each phase must commence construction within 18 months of the approved construction phase. Pursuant to 40 CFR § 52.21(r), EPA may extend the 18-month period upon a written satisfactory showing that an extension is justified.

### **B. PERMIT NOTIFICATION REQUIREMENTS**

Permittee shall notify EPA Region 6 in writing or by electronic mail of the:

1. Date construction is commenced, postmarked within 30 days of such date;
2. Actual date of initial startup of each emission unit, as defined in 40 CFR § 60.2, postmarked within 15 days of such date;
3. Date upon which initial performance tests will commence, in accordance with the provisions of Section V, postmarked not less than 30 days prior to such date. Notification may be provided with the submittal of the performance test protocol required pursuant to Condition V.B;
4. Date upon which certification tests of the CO<sub>2</sub> , O<sub>2</sub> continuous emission monitoring system (CEMS) will commence in accordance with 40 CFR § 75.61(a)(1)(i) and 40 CFR Part 60, Appendix B, Performance Specification 3. Additionally, the initial certification or recertification application shall be submitted for the CO<sub>2</sub> CEMS as required by 40 CFR 75.63; and,
5. Date the existing gas-fired boilers; ST-5, ST-6 and ST-7, are shutdown, decommissioned and permanently shut down at facility within 15 days of such date.

### **C. FACILITY OPERATION**

At all times, including periods of startup, shutdown, and malfunction, Permittee shall, to the extent practicable, maintain and operate the facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the EPA, which may include, but is not



limited to monitoring results, review of operating maintenance procedures and inspection of the facility.

#### **D. MALFUNCTION REPORTING**

1. Permittee shall notify EPA by mail, or other means identified by EPA, within 48 hours following the discovery of any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner, which may result in an increase in GHG emissions above the allowable emission limits stated in Section II and III of this permit.
2. Within 10 days of the discovery of any GHG emissions above the allowable emission limits resulting from malfunctions as described in I.D.1., Permittee shall provide a written supplement to the initial notification that includes a description of the malfunctioning equipment or abnormal operation, the date of the initial malfunction, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed in Sections II and Section III, and the methods utilized to mitigate emissions and restore normal operations.
3. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violation of this permit or any law or regulation such malfunction may cause.

#### **E. RIGHT OF ENTRY**

EPA authorized representatives, upon the presentation of credentials, shall be permitted:

1. To enter the premises where the facility is located or where any records are required to be kept under the terms and conditions of this PSD Permit;
2. During normal business hours, to have access to and to copy any records required to be kept under the terms and conditions of this PSD Permit;
3. To inspect any equipment, operation, or method subject to requirements in this PSD Permit; and,
4. To sample materials and emissions from the source(s).

#### **F. TRANSFER OF OWNERSHIP**

In the event of any changes in control or ownership of the facilities to be constructed, this PSD Permit shall be binding on all subsequent owners and operators. Permittee shall notify the succeeding owner and operator of the existence of the PSD Permit and its conditions by letter; a copy of the letter shall be forwarded to EPA Region 6 within thirty days of the letter signature.

#### **G. SEVERABILITY**

The provisions of this PSD Permit are severable, and, if any provision of the PSD Permit is held invalid, the remainder of this PSD Permit shall not be affected.

#### **H. ADHERENCE TO APPLICATION AND COMPLIANCE WITH OTHER ENVIRONMENTAL LAWS**

Permittee shall construct this project in compliance with this PSD Permit, the application on which this permit is based, the TCEQ PSD Permit No. PSD-TX-612M2, and all other applicable federal, state, and local air quality regulations. This PSD permit does not release the Permittee from any liability for compliance with other applicable federal, state and local environmental laws and regulations, including the Clean Air Act.

## I. ACRONYMS AND ABBREVIATIONS

BACT	Best Available Control Technology
Btu <sub>(HHV)</sub>	British Thermal Unit
CAA	Clean Air Act
CC	Carbon Content
CCS	Carbon Capture and Sequestration
CEMS	Continuous Emissions Monitoring System
CFR	Code of Federal Regulations
CH <sub>4</sub>	Methane
CO <sub>2</sub>	Carbon Dioxide
CO <sub>2</sub> e	Carbon Dioxide Equivalent
dscf	Dry Standard Cubic Foot
EF	Emission Factor
EPN	Emission Point Number
FR	Federal Register
GCV	Gross Calorific Value
GHG	Greenhouse Gas
gr	Grains
GWP	Global Warming Potential
HHV	High Heating Value
hr	Hour
kW	Kilowatt
kWh <sub>(gross)</sub>	Gross Kilowatt-Hour
lb	Pound
LDAR	Leak Detection and Repair
MACT	Maximum Achievable Control Technology
MMBtu	Million British Thermal Units
MSS	Maintenance, Start-up and Shutdown
N <sub>2</sub> O	Nitrous Oxides
ppmv	parts per million by volume
PSD	Prevention of Significant Deterioration
QA/QC	Quality Assurance and/or Quality Control
RATA	Relative Accuracy Test Audit
RCRA	Resource Conservation and Recovery Act
SCFH	Standard Cubic Feet per Hour
SCR	Selective Catalytic Reduction
TAC	Texas Administrative Code
TCEQ	Texas Commission on Environmental Quality
TPY	Tons per Year
USC	United States Code
VOC	Volatile Organic Compound

## II. Emission Limits and Standards.

Annual emissions, in tons per year (TPY) on a 12-month total, rolling monthly, shall not exceed the following:

Table 1: Annual Emission Limits

EPN	FIN	Description	GHG Mass Basis		CO <sub>2</sub> e TPY <sup>1, 2</sup>	BACT Requirements
				TPY <sup>1</sup>		
CG801	GT1	Combustion Turbine	CO <sub>2</sub>	485,112	485,588	7,720 Btu <sub>(HHV)</sub> /kWh <sub>gross</sub> equivalent based on a 365-day rolling average. See Permit Conditions at III.B.1.
			CH <sub>4</sub>	9.15		
			N <sub>2</sub> O	0.91		
CG802	GT2	Combustion Turbine	CO <sub>2</sub>	485,112	485,588	7,720 Btu <sub>(HHV)</sub> /kWh <sub>gross</sub> equivalent based on a 365-day rolling average. See Permit Conditions at III.B.1.
			CH <sub>4</sub>	9.15		
			N <sub>2</sub> O	0.91		
CG803	GT3	Combustion Turbine	CO <sub>2</sub>	485,112	485,588	7,720 Btu <sub>(HHV)</sub> /kWh <sub>gross</sub> equivalent based on a 365-day rolling average. See Permit Conditions at III.B.1.
			CH <sub>4</sub>	9.15		
			N <sub>2</sub> O	0.91		
CG804	GT4	Combustion Turbine	CO <sub>2</sub>	485,112	485,588	7,720 Btu <sub>(HHV)</sub> /kWh <sub>gross</sub> equivalent based on a 365-day rolling average. See Permit Conditions at III.B.1.
			CH <sub>4</sub>	9.15		
			N <sub>2</sub> O	0.91		
BO1	B-305	Boiler 1	CO <sub>2</sub>	209,750	209,957	117 lb CO <sub>2</sub> per MMBtu heat input. Good combustion, operating and maintenance practices. See Permit Conditions at III.D.
			CH <sub>4</sub>	3.96		
			N <sub>2</sub> O	0.40		
BO2	B-306	Boiler 2	CO <sub>2</sub>	209,750	209,957	117 lb CO <sub>2</sub> per MMBtu heat input. Good combustion, operating and maintenance practices. See Permit Conditions at III.D.
			CH <sub>4</sub>	3.96		
			N <sub>2</sub> O	0.40		
BO3	B-307	Boiler 3	CO <sub>2</sub>	209,750	209,957	117 lb CO <sub>2</sub> per MMBtu heat input. Good combustion, operating and maintenance practices. See Permit Conditions at III.D.
			CH <sub>4</sub>	3.96		
			N <sub>2</sub> O	0.40		
Totals <sup>3</sup>			CO <sub>2</sub>	2,569,698	CO <sub>2</sub> e 2,572,215	
			CH <sub>4</sub>	48.5		
			N <sub>2</sub> O	4.8		

1. The TPY emission limits specified in this table are not to be exceeded for this facility and include emissions from the facility during all operations and include MSS activities.
2. Global Warming Potentials (GWP): CH<sub>4</sub> = 21, N<sub>2</sub>O = 310
3. Totals are given for informational purposes only and do not constitute emission limits.

### **III. Special Permit Conditions**

#### **A. Combustion Turbines (EPNs: CG801, CG802, CG803, and CG804) Work Practice Standards, Operational Requirements, and Monitoring:**

1. Permittee shall limit fuel for turbines (CG801, CG802, CG803, and CG804) to pipeline quality natural gas or a maximum of 90/10 ratio of pipeline quality natural gas blended with off-gas based on an annual average.
2. Natural gas quality fuels with the carbon content will be obtained by semiannual testing per 40 CFR§98.34(b)(3)(A). Upon request, Permittee shall provide a sample and/or analysis of the fuel that is fired in turbine/duct burner (CG801, CG802, CG803, and CG804) at the time of the request, or shall allow a sample to be taken by EPA for analysis.
3. Permittee shall monitor fuel gas flow continuously; determine fuel higher heating value whenever there is a fuel change or monthly, whichever is less; and calculate the total daily heat input per turbine/duct burner combination.
4. Natural gas/off-gas flow meter shall be calibrated in accordance with 40 CFR§98.34(b)(1).
5. Flow meters shall meet the specification in 40 CFR 60 Appendix B Spec. 6.
6. All continuous emission monitors and flow meters shall meet the Quality Assurance Specifications in 40 CFR Appendix F.
7. Permittee shall not begin commercial operation of the fourth combustion turbine until the final steam boiler (EPNs: ST-5, ST-6, and ST-7) is decommissioned from service.
8. Each startup of each combustion turbine is defined as the period when the data acquisition and handling system (DAHS) measures fuel flow to the combustion turbine and ends when the combustion turbine generator (CTG) load reaches 60%. Each startup is limited to 240 minutes per event.
9. Each shutdown for each combustion turbine is defined as the period that begins when the CTG output drops below 60% load and ends when there is no longer measureable fuel flow to the combustion turbine. Each shutdown is limited to 60 minutes per event.
10. Permittee shall install, operate and maintain according to good engineering practices, a fuel preheater for each of the turbines (CG801, CG802, CG803, and CG804).
11. The emission limits established in Table 1 include emissions associated with MSS activities.
12. Permittee shall monitor and record the following parameters daily:
  - a. Natural gas consumed;
  - b. Net electricity produced;
  - c. Mass of high pressure steam produced;
  - d. Mass of low pressure steam produced;
  - e. Mass of feed water used;

- f. Average pressure and temperature of steam produced; and
  - g. Calculated average enthalpy for low and high pressure steam based on average steam conditions.
13. The combustion turbines shall be equipped with a CO<sub>2</sub> CEMS.
  14. Permittee shall calculate the CH<sub>4</sub> and N<sub>2</sub>O emissions on a 12-month rolling basis to be updated by the last day of the following month. Permittee shall determine compliance with the CH<sub>4</sub> and N<sub>2</sub>O emissions limits contained in this section using the default CH<sub>4</sub> and N<sub>2</sub>O emission factors contained in Table C-2 and equation C-9a of 40 CFR Part 98 and the HHV (for natural gas and/or off-gas), converted to short tons.
  15. Permittee shall calculate the CO<sub>2</sub>e emissions on a 12-month rolling basis, based on the procedures and Global Warming Potentials (GWP) contained in Greenhouse Gas Regulations, 40 CFR Part 98, Subpart A, Table A-1, as published on October 30, 2009 (74 FR 56395). The record shall be updated by the last day of the following month.

**B. Combustion Turbines (EPNs: CG801, CG802, CG803, and CG804) BACT Limit:**

1. Permittee shall maintain a turbine thermal efficiency as measured by calculating the fuel chargeable to power of 7,720 Btu<sub>(HHV)</sub>/kWh<sub>(gross)</sub> on a 365-day rolling average of the calculated daily thermal efficiency for each of the turbines: CG801, CG802, CG803, and CG804.
2. Compliance will be demonstrated by monitoring fuel gas flow, fuel higher heating value, and gross power production and calculating the thermal efficiency using these parameters on a daily basis
3. Permittee shall calculate turbine thermal efficiency daily for turbines (CG801, CG802, CG803, and CG804) as follows:

Equation 1 *Calculation of Fuel Chargeable to Power*

$$FCP = \frac{QGT - FCS}{P_{NET}}$$

Where: FCP = Fuel Chargeable to Power [Btu (HHV)/kWh]

QGT = Heat input to gas turbine [MMBtu/hr]

FCS = Fuel Chargeable to Steam [MMBtu/hr]

P<sub>NET</sub> = Net electrical production [kW]

Fuel Chargeable to Steam (FCS) is the net heat used to generate steam divided by the efficiency of an equivalent boiler. Calculation of FCS is described in Equation 2.

Equation 2 *Calculation of Fuel Chargeable to Steam*

$$FCS = \frac{QHP + QLP - QFW}{e_{\text{boiler}}}$$

Where: FCS = Fuel Chargeable to Steam [MMBtu/hr]

QHP = Heat used to generate high pressure steam [MMBtu/hr]

QLP = Heat used to generate low pressure steam [MMBtu/hr]

QFW = Heat used to heat the feed water [MMBtu/hr]

e<sub>boiler</sub> = Efficiency of an equivalent boiler [0.84]

Equation 3 *Calculation of Heat Consumption for Steam and Feed water*

$$Q_i = \Delta h_i * m_i$$

Where: Q<sub>i</sub> = Heat used for steam or water stream, *i* [MMBtu/hr]

Δh<sub>i</sub> = Change in enthalpy, *i* [MMBtu/lb]

m<sub>i</sub> = Mass flow of stream *i*

### **C. Steam Boilers (EPNs: BO1, BO2, and BO3) Work Practice Standards, Operational Requirements, and Monitoring:**

1. Fuel Specifications: Permittee shall limit fuel for boilers to pipeline quality natural gas or a maximum of 90/10 ratio of pipeline natural gas blended with fuel gas based on an annual average.
2. Each boiler is limited to a maximum heat input of 550 MMBtu/hr based on the higher heating value of the natural gas.
3. Permittee shall limit the total fuel heat input for the combined three (3) boilers to 10,769,647 MMBtu in any 12-month period.
4. Except during Phase 1 and Phase 2 of construction, when all four turbines are operational, the maximum combined hourly heat input to all three new boilers shall not exceed 825 MMBtu/hr.
5. When three turbines are operational (any single turbine is not operating) the maximum combined hourly heat input to all three new boilers shall not exceed 1,650 MMBtu/hr.

6. Except during Phase 1 and Phase 2 of construction, the combined annual heat input to all three new boilers and all four new turbines (excludes heat input to duct burners) shall not exceed 40,437,912 MMBtu/year.
7. Permittee shall install, operate, and maintain according to good engineering practices, an air preheater, and a condensate return system for each of boilers (BO1, BO2, and BO3).
8. Each startup for each boiler is defined as the period that begins when the data acquisition and handling system (DAHS) measures fuel flow to the boiler and ends when the boiler reaches hot standby mode or the fuel flow at which the boiler will operate. Each startup is limited to 240 minutes per event.
9. Each shutdown for each boiler is defined as the period that begins when the boiler drops below the hot standby fuel flow level and ends when no fuel flow is detected. Each shutdown is limited to 60 minutes per event.
10. Permittee shall monitor fuel gas flow continuously; determine fuel higher heating value whenever there is a fuel change or monthly, whichever is less; and calculate the total daily heat input per boiler.
11. Natural gas/fuel gas flow meter shall be calibrated in accordance with 40 CFR §98.34(b)(1).
12. Flow meters shall meet the specification in 40 CFR 60 Appendix B Spec 6.
13. All continuous emission monitors and flow meters shall meet the Quality Assurance Specifications in 40 CFR 60 Appendix F.
14. A data acquisition and handling system (DAHS) shall be used to measure and record the CO<sub>2</sub> emissions and demonstrate compliance with the annual emission rates and BACT limits.
15. Permittee shall maintain the following boiler work practice standards:
  - a. Maintain the Oxygen analyzers and calibration to ensure boiler efficiencies per the manufacturers recommendations. Oxygen analyzers shall be maintained and calibrated using 40 CFR 60 Appendix A-2, Method 3A.
  - b. Perform regular scheduled maintenance on the air preheater to maintain optimum heat transfer per the manufacturer's recommendations.
16. Perform scheduled maintenance and tune-ups of the boiler burners and equipment to include burner tips and heat convection sections to reduce fouling of the heat transfer surfaces and to maximize boiler efficiency.
17. Compliance with the Annual Emission Limit in Table 1 shall be demonstrated on a 12-month total, rolling monthly, calculated in accordance with equation C-5 found in 40 CFR §98.33(a)(3)(iii).
18. The emission limits established in Table 1 for the boilers includes emissions from MSS activities.



**D. Steam Boilers (EPNs: BO1, BO2, and BO3) BACT Limit:**

Permittee shall meet a BACT limit of 117 lb CO<sub>2</sub>/MMBtu heat input when burning natural gas and/or fuel gas based on a 12-month rolling average for each boiler, including emissions from maintenance, startup and shutdown activities and shall be obtained by using daily CO<sub>2</sub> value from the continuous CO<sub>2</sub> stack gas analyzer, daily fuel flow and current fuel use higher heating value. The equation for calculating the BACT limit is as follows:

$$BACT\ Limit = \frac{\sum(monthly\ CO_2\ lbs\ from\ each\ new\ Rentech\ boiler\ duct/stack)}{\sum(monthly\ MM\ Btus\ heat\ input\ to\ each\ new\ Rentech\ steam\ boiler)}$$

**E. Requirements for Steam Boilers to be Decommissioned (EPNs: ST-5, ST-6, and ST-7):**

Permittee shall disable and retire existing steam boilers ST-5, ST-6 and ST-7 concurrent with the startup of the fourth combustion turbine.

**F. Requirements for Combustion Turbines to be Decommissioned:**

Permittee shall decommission, remove, and replace each of the four existing combustion turbines.

**G. Continuous Emissions Monitoring Systems (CEMS)**

1. The Permittee shall ensure that all required CO<sub>2</sub> monitoring system/equipment are installed and all certification tests are completed on or before the earlier of 90 unit operating days or 180 calendar days after the date the unit commences operation.
2. Permittee shall ensure compliance with the specifications and test procedures for CO<sub>2</sub> emission monitoring system at stationary sources, 40 CFR Part 75, or 40 CFR Part 60, Appendix B, Performance Specification numbers 1 through 9, as applicable.
3. The Permittee shall meet the appropriate quality assurance requirements specified in 40 CFR Part 60, Appendix F for the CO<sub>2</sub> emission monitoring system.

**IV. Excess Emission Reporting and Records:**

1. Excess emissions are defined as any period in which the facility emissions exceed a maximum emission limit set forth in this permit. Excess emissions indicated by GHG emission source certification testing or compliance monitoring shall be considered violations of the applicable emission limit for the purpose of this permit.

2. Maintain records and submit a written report of all excess emissions to EPA semi-annually, except when more frequent reporting is specifically required by an applicable subpart; or the Administrator or authorized representative, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. The report is due on the 30<sup>th</sup> day following the end of each semi-annual period and shall include the following:
  - a) Time intervals, data and magnitude of the excess emissions, the nature and cause (if known), corrective actions taken and preventive measures adopted;
  - b) Applicable time and date of each period during which the monitoring equipment was inoperative (monitoring down-time);
  - c) A statement in the report of a negative declaration; that is a statement when no excess emissions occurred or when the monitoring equipment has not been inoperative, repaired or adjusted; and
  - d) Any failure to conduct any required source testing, monitoring, or other compliance activities.
  - e) Any violation of limitations on operation, including but not limited to restrictions on hours of operation.

## **V. Performance Testing Requirements:**

A. The Permittee shall perform stack sampling and other testing to establish the actual pattern and quantities of air contaminants being emitted into the atmosphere from the stacks of the Boilers (BO1, BO2, and BO3), and Combustion Turbines (CG801, CG802, CG803, and CG804), and to determine the initial compliance with the CO<sub>2</sub> emission limits established in this permit. Sampling shall be conducted in accordance with 40 CFR § 60.8 and EPA Method 3a or 3b (40 CFR App. A-2) for the concentration of CO<sub>2</sub>.

1. For the Boilers (BO1, BO2, and BO3) calculate the CO<sub>2</sub> hourly average emission rate determined under maximum operating test conditions, convert to lbs of CO<sub>2</sub>/MMBtu. Use the following equation to calculate the annual emissions for each boiler.

$$CO_2 \text{ TPY} = 410 \frac{\text{MMBtu}}{\text{hr}} * 8,760 \frac{\text{hr}}{\text{year}} * \text{lb} \frac{CO_2}{\text{MMBtu}}$$

Where:

410 MMBtu/hr = is the design annual average furnace firing rate upon which the emissions in Table 1 were based on.

lb CO<sub>2</sub>/MMBtu = calculated from V.A.1.

2. For the Combustion Turbines (CG801, CG802, CG803, and CG804) multiply the CO<sub>2</sub> hourly average emission rate determined under maximum operating conditions by 8,760 hours.
  3. If the above calculated CO<sub>2</sub> emission total exceeds the tons per year (TPY) specified in Table 1, the facility shall;
    - a. Document the exceedance in the test report; and
    - b. Explain within the report how the facility will assure compliance with the CO<sub>2</sub> emission limit listed in Table 1.
- B. The Permittee shall conduct an evaluation of the thermal efficiency of the Combustion Turbines (CG801, CG802, CG803, and CG804) to verify compliance with the BACT Limit specified in Condition III.D.1. when performing testing as stated in V.A.2. above. The results of the thermal efficiency shall be submitted to the EPA within 30 days of testing.
- C. Within 60 days after achieving the maximum production rate at which each boiler will operate, but not later than 180 days after initial startup of the individual boiler, performance tests must be conducted and a written report of the performance testing results furnished to the EPA. Additional sampling may be required by EPA.
- D. Permittee shall submit a performance test protocol to EPA no later than 30 days prior to the test to allow review of the test plan and to arrange for an observer to be present at the test. The performance test shall be conducted in accordance with the submitted protocol, and any changes required by EPA.
- E. Performance tests must be conducted under such conditions to ensure representative performance of the affected facility. The owner or operator must make available to the EPA such records as may be necessary to determine the conditions of the performance tests.
- F. The owner or operator must provide the EPA at least 30 days prior notice of any performance test, except as specified under other subparts, to afford the EPA the opportunity to have an observer present and/or to attend a pre-test meeting. If there is a delay in the original test date, the facility must provide at least 7 days prior notice of the rescheduled date of the performance test unless EPA approves an earlier rescheduled date.
- G. The owner or operator shall provide, or cause to be provided, performance testing facilities as follows:
1. Sampling ports adequate for test methods applicable to this facility,
  2. Safe sampling platform(s),
  3. Safe access to sampling platform(s), and
  4. Utilities for sampling and testing equipment.
- H. Unless otherwise specified, each performance test shall consist of three separate runs using the applicable test method. Each run shall be conducted for the time and under the conditions specified in the applicable standard. For purposes of determining compliance with an applicable standard, the arithmetic mean of the results of the three runs shall apply.

- I. The Permittee shall conduct its initial CO<sub>2</sub> CEMS relative accuracy test audit (RATA), in accordance with 40 CFR Part 60, Appendix F, Procedure 1, to evaluate compliance of each turbine with the emission standards on a continuous basis, within thirty (30) days of installation and startup of each turbine.
- J. Emissions testing, as outlined above, shall be performed every five years, plus or minus 6 months, of when the previous performance test was performed, or within 180 days after the issuance of a permit renewal, whichever comes later to verify continued performance at permitted emission limits.

## **VI. Recordkeeping and Reporting**

- 1. In order to demonstrate compliance with the GHG emission limits in Sections II and III, the Permittee shall monitor the following parameters and summarize the data on a calendar month basis.
  - a. Operating hours for the each steam boiler (BO1, BO2, and BO3) and each combustion turbine (CG801, CG802, CG803, and CG804).
  - b. The daily fuel usage for each steam boiler (BO1, BO2, and BO3) and each combustion turbine (CG801, CG802, CG803, and CG804) using continuous fuel flow monitors of natural gas and/or off-gas.
  - c. Monthly fuel sampling for natural gas and when switch is made to a natural gas/off-gas combination.
  - d. The daily steam production rate steam boiler (BO1, BO2, and BO3) and daily high pressure and low pressure steam produced by each combustion turbine (CG801, CG802, CG803, and CG804).
  - e. Average daily steam pressure and steam temperature produced by each combustion turbine, (CG801, CG802, CG803, and CG804).
  - f. Average daily enthalpy for the low and high pressure steam based on average conditions for each combustion turbine, (CG801, CG802, CG803, and CG804).
  - g. The daily heat input rate for each boiler (BO1, BO2, and BO3) and each turbine/duct burner combination (CG801, CG802, CG803, and CG804).
  - h. Daily CO<sub>2</sub>e/MMBtu heat input for each boiler (BO1, BO2, and BO3) and daily CO<sub>2</sub>e/MMBtu heat input for each combustion turbine/duct burner combination (CG801, CG802, CG803, and CG804).
  - i. Inspection of the air preheater performance for the boilers and turbines and fuel preheater performance for the turbines.
- 2. Maintain a file of all records, data, measurements, reports, and documents related to the operation of the facilities authorized by this permit, including, but not limited to, the following: all records or reports pertaining to the maintenance performed on any system or device that is a part of a facility authorized by this permit; all records relating to performance

tests and monitoring of combustion equipment; and all other information required by this permit recorded in a permanent form suitable for inspection.

3. Maintain records of startup, shutdown, or malfunction, initial startup period for the emission units, performance testing, calibrations, checks, duration of any periods during which a monitoring device is inoperative, and corresponding emission measurement
4. Maintain records of all GHG emission units and CO<sub>2</sub> and O<sub>2</sub> emission certification tests, monitoring and compliance information required by this permit.
5. All records required by this PSD Permit shall be retained for not less than 5 years following the date of such measurements, maintenance, and reporting.

## **VII. Agency Notifications**

Permittee shall submit GHG permit applications, permit amendments, and other applicable permit information to:

Multimedia Planning and Permitting Division  
EPA Region 6  
1445 Ross Avenue (6 PD-R)  
Dallas, TX 75202  
Email: Group R6AirPermits@EPA.gov

Permittee shall submit a copy of all performance tests, analyzers quality assurance tests, compliance and enforcement correspondence as required by this Approval to Construct to:

Compliance Assurance and Enforcement Division  
EPA Region 6  
1445 Ross Avenue (6EN)  
Dallas, TX 75202