

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
Lower Neches Valley Authority

AUTHORIZING THE OPERATION OF
Neches 1st Pumping Station
Water Supply and Irrigation Systems

LOCATED AT
Jefferson County, Texas
Latitude 30° 10' 7" Longitude 94° 9' 17"
Regulated Entity Number: RN100213248

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: O1402 Issuance Date: _____

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions:	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
New Source Review Authorization Requirements	6
Compliance Requirements.....	6
Permit Location	8
Permit Shield (30 TAC § 122.148)	8
Attachments	9
Applicable Requirements Summary.....	10
Permit Shield	22
New Source Review Authorization References	25
Appendix A.....	29
Acronym List	30

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
 - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.

- E. Emission units subject to 40 CFR Part 63, Subpart ZZZZ as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1090 which incorporates the 40 CFR Part 63 Subpart by reference.
2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
- A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
- A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
 - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
 - (ii) Title 30 TAC § 111.111(a)(1)(E)
 - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
 - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that

does not obstruct the transmission of light. Vents, as specified in the “Applicable Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:

- (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
- (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (5) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is

determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
 - (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.
 - (3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

- (4) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- C. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
- D. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
 - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)
 - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
4. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
 - A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
 - B. Title 40 CFR § 60.8 (relating to Performance Tests)
 - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)

- F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
5. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.

New Source Review Authorization Requirements

6. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule (including the terms, conditions, monitoring, recordkeeping, and reporting identified in registered PBRs and permits by rule identified in the PBR Supplemental Tables dated September 4, 2025 in the application for project 37594), standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
- A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
7. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
8. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).

Compliance Requirements

9. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
10. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:

- A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
 - (i) For sources in the Beaumont-Port Arthur Nonattainment area, 30 TAC § 117.9000
 - B. The permit holder shall comply with the Initial Control Plan unit listing requirement in 30 TAC § 117.150(c) and (c)(1).
11. Use of Emission Credits to comply with applicable requirements:
- A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) Offsets for Title 30 TAC Chapter 116
 - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)
 - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
 - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)
12. Use of Discrete Emission Credits to comply with the applicable requirements:
- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
 - B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:

- (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
- (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
- (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
- (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
- (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Permit Location

- 13. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit at Lower Neches Valley Authority, 7850 Eastex Freeway, Beaumont, Texas 77708.

Permit Shield (30 TAC § 122.148)

- 14. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Permit Shield

New Source Review Authorization References

Applicable Requirements Summary

Unit Summary	11
---------------------------	-----------

Applicable Requirements Summary	13
--	-----------

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
CE-02	SRIC ENGINES	N/A	60JJJJ	40 CFR Part 60, Subpart JJJJ	No changing attributes.
CE-02	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
E-01	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
E-03	SRIC ENGINES	N/A	R7201	30 TAC Chapter 117, Subchapter B	No changing attributes.
E-03	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
E-06	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GE-01	SRIC ENGINES	N/A	60JJJJ	40 CFR Part 60, Subpart JJJJ	No changing attributes.
GE-01	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GE-WH1	SRIC ENGINES	N/A	60JJJJ	40 CFR Part 60, Subpart JJJJ	No changing attributes.
GE-WH1	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRPENG1	SRIC ENGINES	E-02, E-04, E-05	R7201- GRPENG1	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRPENG1	SRIC ENGINES	E-02, E-04, E-05	63ZZZZ- GRPENG1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRPENG2	SRIC ENGINES	CE-01, PE-01	60JJJJ- GRPENG2	40 CFR Part 60, Subpart JJJJ	No changing attributes.
GRPENG2	SRIC ENGINES	CE-01, PE-01	63ZZZZ- GRPENG2	40 CFR Part 63, Subpart ZZZZ	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
LOILTNK1	STORAGE TANKS/VESSELS	N/A	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
PE-02	SRIC ENGINES	N/A	60JJJJ	40 CFR Part 60, Subpart JJJJ	No changing attributes.
PE-02	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
SMPTNK1	VOLATILE ORGANIC COMPOUND WATER SEPARATORS	N/A	R5131	30 TAC Chapter 115, Water Separation	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
CE-02	EU	60JJJJ	CO	40 CFR Part 60, Subpart JJJJ	§ 60.4233(d) § 1048.101(c) § 60.4233(h) § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(g)	Owners and operators of stationary non-emergency SI ICE with a maximum engine power greater than 19 KW and less than 75 KW and ARE NOT severe-duty engines and were manufactured on or after 07/01/2008 must comply with a CO emission limit of 6.5 g/KW-hr, as stated in 40 CFR 1048.101(c).	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(e)	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4)	§ 60.4245(d)
CE-02	EU	60JJJJ	HC and NO _x	40 CFR Part 60, Subpart JJJJ	§ 60.4233(d) § 1048.101(c) § 60.4233(h) § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(g)	Owners and operators of stationary non-emergency SI ICE with a maximum engine power greater than 19 KW and less than 75 KW and were manufactured on or after 07/01/2008 must comply with an HC+NO _x emission limit of 3.8 g/KW-hr, as stated in 40 CFR 1048.101(c).	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(d)	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4)	§ 60.4245(d)
CE-02	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						requirements apply for such engines under this part.			
E-01	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.11 § 63.6595(a)(1) § 63.6603(f) § 63.6605(a) § 63.6605(b) § 63.6625(h) § 63.6625(j)	For each existing non-emergency, non-black start 4SRB remote stationary RICE with a site rating greater than 500 HP, located at an area source, you must comply with the requirements as specified in Table 2d.11.a-c.	§ 63.6625(j) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6603(f) § 63.6625(j) § 63.6655(e) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
E-03	EU	R7201	Exempt	30 TAC Chapter 117, Subchapter B	§ 117.103(b)(2)	Units exempted from §117.105 of this title [RACT] include any low annual capacity factor boiler, process heater, stationary gas turbine, or stationary internal combustion engine as defined in §117.10 of this title (relating to Definitions).	None	§ 117.140(i) § 117.145(f) § 117.145(f)(6) § 117.145(f)(6)(B)	[G]§ 117.140(m)
E-03	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.11 § 63.6595(a)(1) § 63.6603(f) § 63.6605(a) § 63.6605(b) § 63.6625(h) § 63.6625(j)	For each existing non-emergency, non-black start 4SRB remote stationary RICE with a site rating greater than 500 HP, located at an area source, you must comply with the requirements as specified in Table 2d.11.a-c.	§ 63.6625(j) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6603(f) § 63.6625(j) § 63.6655(e) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
E-06	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.11 § 63.6595(a)(1) § 63.6603(f) § 63.6605(a) § 63.6605(b) § 63.6625(h) § 63.6625(j)	For each existing non-emergency, non-black start 4SRB remote stationary RICE with a site rating greater than 500 HP, located at an area source, you must comply with the requirements as specified in	§ 63.6625(j) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6603(f) § 63.6625(j) § 63.6655(e) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						Table 2d.11.a-c.			
GE-01	EU	60JJJJ	CO	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table 1 § 60.4234 § 60.4243(b) § 60.4243(b)(1) [G]§ 60.4243(d) § 60.4243(g)	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than or equal to 130 HP and were manufactured on or after 01/01/2009 must comply with a CO emission limit of 4.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(b)	§ 60.4243(a)(1) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(3) § 60.4245(b) § 60.4245(j)	[G]§ 60.4245(e) [G]§ 60.4245(g) [G]§ 60.4245(h) [G]§ 60.4245(i)
GE-01	EU	60JJJJ	NO _x	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table 1 § 60.4234 § 60.4243(b) § 60.4243(b)(1) [G]§ 60.4243(d) § 60.4243(g)	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than or equal to 130 HP and were manufactured on or after 01/01/2009 must comply with a NO _x emission limit of 2.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(b)	§ 60.4243(a)(1) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(3) § 60.4245(b) § 60.4245(j)	[G]§ 60.4245(e) [G]§ 60.4245(g) [G]§ 60.4245(h) [G]§ 60.4245(i)
GE-01	EU	60JJJJ	VOC	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table 1 § 60.4234 § 60.4243(b) § 60.4243(b)(1) [G]§ 60.4243(d) § 60.4243(g)	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than or equal to 130 HP and were manufactured on or after 01/01/2009 must comply with a VOC emission limit of 1.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(b)	§ 60.4243(a)(1) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(3) § 60.4245(b) § 60.4245(j)	[G]§ 60.4245(e) [G]§ 60.4245(g) [G]§ 60.4245(h) [G]§ 60.4245(i)
GE-01	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
GE-WH1	EU	60JJJJ	CO	40 CFR Part 60, Subpart JJJJ	§ 60.4233(d)-Table 1 § 60.4234 § 60.4243(b) § 60.4243(b)(1) [G]§ 60.4243(d) § 60.4243(g)	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than 25 HP and less than 100 HP and were manufactured on or after 01/01/2009 must comply with a CO emission limit of 387 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(c)	§ 60.4243(a)(1) § 60.4245(a) § 60.4245(a)(2) § 60.4245(a)(3) § 60.4245(b)	None
GE-WH1	EU	60JJJJ	HC and NO _x	40 CFR Part 60, Subpart JJJJ	§ 60.4233(d)-Table 1 § 60.4234 § 60.4243(b) § 60.4243(b)(1) [G]§ 60.4243(d) § 60.4243(g)	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than 25 HP and less than 100 HP and were manufactured on or after 01/01/2009 must comply with an HC+NO _x emission limit of 10 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(c)	§ 60.4243(a)(1) § 60.4245(a) § 60.4245(a)(2) § 60.4245(a)(3) § 60.4245(b)	None
GE-WH1	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1)	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
GRPENG S1	EU	R7201-GRPENG S1	CO	30 TAC Chapter 117, Subchapter B	§ 117.105(d) § 117.105(a) § 117.130(a) § 117.140(k)	No person shall allow the discharge into the atmosphere from any gas-fired, rich-burn, stationary, reciprocating internal combustion engine rated 300 horsepower (hp) or greater, CO emissions in excess of a block one-hour average of 3.0 g/hp-hr.	[G]§ 117.135(a)(1) § 117.135(a)(4) § 117.135(b) § 117.135(d) § 117.135(e) § 117.135(g) § 117.140(a) § 117.140(g) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) [G]§ 117.8000(f) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.145(a) § 117.145(f) § 117.145(f)(1) [G]§ 117.145(f)(3) § 117.145(f)(9)	§ 117.135(b) § 117.135(g) [G]§ 117.145(b) [G]§ 117.145(c) [G]§ 117.145(e) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
GRPENG S1	EU	R7201-GRPENG S1	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.105(d) § 117.105(a) § 117.130(a)	No person shall allow the discharge into the atmosphere from any gas-	[G]§ 117.135(a)(1) § 117.135(a)(4) § 117.135(b)	§ 117.145(a) § 117.145(f) § 117.145(f)(1)	§ 117.135(b) § 117.135(g) [G]§ 117.145(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.130(d) § 117.130(d)(6) § 117.130(d)(7) § 117.140(k) § 117.140(l)	fired, rich-burn, stationary, reciprocating internal combustion engine rated 300 horsepower (hp) or greater, NOx emissions in excess of a block one-hour average of 2.0 grams per horsepower-hour (g/hp-hr).	§ 117.135(d) § 117.135(e) § 117.135(g) § 117.140(a) § 117.140(g) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) [G]§ 117.8000(f) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	[G]§ 117.145(f)(3) § 117.145(f)(9)	[G]§ 117.145(c) [G]§ 117.145(e) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)
GRPENG S1	EU	63ZZZZ-GRPENG S1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)-Table 2d.11 § 63.6595(a)(1) § 63.6603(f) § 63.6605(a) § 63.6605(b) § 63.6625(h) § 63.6625(j)	For each existing non-emergency, non-black start 4SRB remote stationary RICE with a site rating greater than 500 HP, located at an area source, you must comply with the requirements as specified in Table 2d.11.a-c.	§ 63.6625(j) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6603(f) § 63.6625(j) § 63.6655(e) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
GRPENG S2	EU	60JJJJ-GRPENG S2	CO	40 CFR Part 60, Subpart JJJJ	§ 60.4233(d) § 1048.101(c) § 60.4233(h) § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(g)	Owners and operators of stationary non-emergency SI ICE with a maximum engine power greater than 19 KW and less than 75 KW and ARE NOT severe-duty engines and were manufactured on or after 07/01/2008 must comply	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(e)	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(j)	§ 60.4245(d) § 60.4245(f) [G]§ 60.4245(g) [G]§ 60.4245(h) [G]§ 60.4245(i)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						with a CO emission limit of 6.5 g/KW-hr, as stated in 40 CFR 1048.101(c).			
GRPENG S2	EU	60JJJJ-GRPENG S2	HC and NO _x	40 CFR Part 60, Subpart JJJJ	§ 60.4233(d) § 1048.101(c) § 60.4233(h) § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(g)	Owners and operators of stationary non-emergency SI ICE with a maximum engine power greater than 19 KW and less than 75 KW and were manufactured on or after 07/01/2008 must comply with an HC+NO _x emission limit of 3.8 g/KW-hr, as stated in 40 CFR 1048.101(c).	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(d)	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(j)	§ 60.4245(d) § 60.4245(f) [G]§ 60.4245(g) [G]§ 60.4245(h) [G]§ 60.4245(i)
GRPENG S2	EU	63ZZZZ-GRPENG S2	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
LOILT NK1	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
PE-02	EU	60JJJJ	CO	40 CFR Part 60, Subpart JJJJ	§ 60.4233(d) § 1048.101(c) § 60.4233(h) § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(g)	Owners and operators of stationary non-emergency SI ICE with a maximum engine power greater than 19 KW and less than 75 KW and ARE NOT severe-duty engines and were manufactured on or after 07/01/2008 must comply with a CO emission limit of 6.5 g/KW-hr, as stated in 40 CFR 1048.101(c).	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(e)	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4)	§ 60.4245(d)
PE-02	EU	60JJJJ	HC and NO _x	40 CFR Part 60, Subpart JJJJ	§ 60.4233(d) § 1048.101(c) § 60.4233(h) § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(g)	Owners and operators of stationary non-emergency SI ICE with a maximum engine power greater than 19 KW and less than 75 KW and were manufactured on or after 07/01/2008 must comply with an HC+NO _x emission limit of 3.8 g/KW-hr, as stated in 40 CFR 1048.101(c).	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(d)	§ 60.4243(b)(2)(i) § 60.4243(e) § 60.4245(a) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4)	§ 60.4245(d)
PE-02	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						requirements apply for such engines under this part.			
SMPTNK1	EU	R5131	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None

Permit Shield

Permit Shield 23

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
CE-02	N/A	30 TAC Chapter 117, Subchapter B	Used solely to power up other engines during startup.
DIESELTNK1	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with a capacity of less than or equal to 1000 gallons.
GASTNK1	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with a capacity of less than or equal to 1000 gallons.
GE-01	N/A	30 TAC Chapter 117, Subchapter B	New unit placed into service after June 9, 1993 and on/after final compliance date in 117.9000.
GE-WH1	N/A	30 TAC Chapter 117, Subchapter B	Stationary internal combustion engines with horsepower (hp) rating of less than 300 hp.
GRPENGs2	CE-01, PE-01	30 TAC Chapter 117, Subchapter B	Stationary internal combustion engines with a horsepower (hp) rating of less than 300 hp.
GRPHTRS	H-01, H-02, H-03, H-04, H-05, H-06, H-30	30 TAC Chapter 112, Sulfur Compounds	Natural gas fired heaters.
GRPHTRS	H-01, H-02, H-03, H-04, H-05, H-06, H-30	30 TAC Chapter 117, Subchapter B	Maximum rated capacity is less than 2 MMBtu/hr.
PE-02	N/A	30 TAC Chapter 117, Subchapter B	Used solely to power up other engines during startup.
PW-01	N/A	30 TAC Chapter 115, Degreasing Processes	Unit is a remote reservoir cold solvent cleaner which uses solvent with a true vapor pressure of less than 0.6 psia at 100°F with a drain area less than 16 in ² , and the waste solvent is disposed of in enclosed containers.
UOILTNK1	N/A	30 TAC Chapter 115, Storage of VOCs	A storage tank with a capacity of less than or

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
			equal to 1000 gallons.

New Source Review Authorization References

New Source Review Authorization References	26
New Source Review Authorization References by Emission Unit	27

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 6	Version No./Date: 05/05/1976
Number: 58	Version No./Date: 01/08/1980
Number: 106.183	Version No./Date: 09/04/2000
Number: 106.454	Version No./Date: 11/01/2001
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 09/04/2000
Number: 106.512	Version No./Date: 06/13/2001
Number: 106.532	Version No./Date: 09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
CE-01	COMPRESSOR ENGINE	106.512/06/13/2001
CE-02	COMPRESSOR ENGINE (BACKUP)	106.512/06/13/2001
DIESELTNK1	DIESEL TANK	106.473/09/04/2000
E-01	ENGINE #1	106.512/06/13/2001 [50376]
E-02	ENGINE #2	6/05/05/1976 [55681]
E-03	ENGINE #3	6/05/05/1976 [55681]
E-04	ENGINE #4	6/05/05/1976 [55681]
E-05	ENGINE #5	6/05/05/1976 [55681]
E-06	ENGINE #6	106.512/06/13/2001 [70373]
GASTNK1	GASOLINE TANK	106.473/09/04/2000
GE-01	EMERGENCY GENERATOR	106.511/09/04/2000
GE-WH1	EMERGENCY GENERATOR (WAREHOUSE)	106.511/09/04/2000
H-01	WATER HEATER #1	106.183/09/04/2000
H-02	WATER HEATER #2	106.183/09/04/2000
H-03	WATER HEATER #3	106.183/09/04/2000
H-04	WATER HEATER #4	106.183/09/04/2000
H-05	WATER HEATER #5	106.183/09/04/2000
H-06	WATER HEATER #6	106.183/09/04/2000
H-30	OFFICE HEATER	106.183/09/04/2000
LOILTNK1	LUBE OIL TANK #1	58/01/08/1980
PE-01	PRIMING ENGINE	106.512/06/13/2001

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
PE-02	PRIMING ENGINE (BACKUP)	106.512/06/13/2001
PW-01	PARTS WASHER # 1	106.454/11/01/2001
SMPTNK1	SUMP TANK#1	106.532/09/04/2000
UOILTANK1	USED OIL TANK	106.472/09/04/2000

**This column may include Permit by Rule (PBR) numbers and version dates, PBR Registration numbers in brackets, Standard Permit Registration numbers, Minor NSR permit numbers, and Major NSR permit numbers.

Appendix A

Acronym List 30

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
RO	Responsible Official
SIP	state implementation plan
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound