

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
Southwestern Public Service Company

AUTHORIZING THE OPERATION OF
Tolk Station Power Plant
Fossil Fuel Electric Power Generation

LOCATED AT
Lamb County, Texas
Latitude 34° 11' 5" Longitude 102° 34' 7"
Regulated Entity Number: RN100224534

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site, emission units and affected source listed in this permit. Operations of the site, emission units and affected source listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site, emission units and affected source authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site, emission units and affected source.

Permit No: 012 Issuance Date: _____

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions:	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements	5
New Source Review Authorization Requirements	6
Compliance Requirements.....	6
Protection of Stratospheric Ozone	7
Temporary Fuel Shortages (30 TAC § 112.15)	7
Permit Location	8
Permit Shield (30 TAC § 122.148)	8
Acid Rain Permit Requirements	8
Cross-State Air Pollution Rule (CSAPR) Trading Program Requirements	12
Federal Implementation Plan for Regional Haze (Texas SO ₂ Trading Program) Requirements ..	18
Attachments	23
Applicable Requirements Summary.....	24
Additional Monitoring Requirements	41
Permit Shield	64
New Source Review Authorization References	66
Appendix A.....	69
Acronym List	70
Appendix B.....	71

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five-year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
 - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.
 - E. Emission units subject to 40 CFR Part 63, Subparts ZZZZ, DDDDD or UUUUU as identified in the attached Applicable Requirements Summary table are subject to 30 TAC

Chapter 113, Subchapter C, § 113.1090, § 113.1130 or § 113.1300 which incorporates the 40 CFR Part 63 Subpart by reference.

2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
 - A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
 - A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
 - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
 - (ii) Title 30 TAC § 111.111(a)(1)(E)
 - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
 - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that

does not obstruct the transmission of light. Vents, as specified in the “Applicable Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:

- (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
- (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (5) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is

determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.
- B. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
- C. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
 - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)
 - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
- D. Outdoor burning, as stated in 30 TAC § 111.201, shall not be authorized unless the following requirements are satisfied:
 - (i) Title 30 TAC § 111.205 (relating to Exception for Fire Training)
 - (ii) Title 30 TAC § 111.207 (relating to Exception for Recreation, Ceremony, Cooking, and Warmth)
 - (iii) Title 30 TAC § 111.209 (relating to Exception for Disposal Fires)
 - (iv) Title 30 TAC § 111.211 (relating to Exception for Prescribed Burn)
 - (v) Title 30 TAC § 111.219 (relating to General Requirements for Allowable Outdoor Burning)
 - (vi) Title 30 TAC § 111.221 (relating to Responsibility for Consequences of Outdoor Burning)
- 4. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
 - A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)

- B. Title 40 CFR § 60.8 (relating to Performance Tests)
 - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
 - F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
5. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.

Additional Monitoring Requirements

6. Unless otherwise specified, the permit holder shall comply with the compliance assurance monitoring requirements as specified in the attached "CAM Summary" upon issuance of the permit. In addition, the permit holder shall comply with the following:
- A. The permit holder shall comply with the terms and conditions contained in 30 TAC § 122.147 (General Terms and Conditions for Compliance Assurance Monitoring).
 - B. The permit holder shall report, consistent with the averaging time identified in the "CAM Summary," deviations as defined by the deviation limit in the "CAM Summary." Any monitoring data below a minimum limit or above a maximum limit, that is collected in accordance with the requirements specified in 40 CFR § 64.7(c), shall be reported as a deviation. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).
 - C. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "CAM Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances in order to avoid reporting deviations. All monitoring data shall be collected in accordance with the requirements specified in 40 CFR § 64.7(c).
 - D. The permit holder shall operate the monitoring, identified in the attached "CAM Summary," in accordance with the provisions of 40 CFR § 64.7.
 - E. The permit holder shall comply with the requirements of 40 CFR § 70.6(a)(3)(ii)(A) and 30 TAC § 122.144(1)(A)-(F) for documentation of all required inspections.
7. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required

intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

8. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule (including the terms, conditions, monitoring, recordkeeping, and reporting identified in registered PBRs and permits by rule identified in the PBR Supplemental Tables dated June 19, 2025 in the application for project 38281), standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
 - A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
9. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
10. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
11. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
 - A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
 - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
 - C. Requirements of the non-rule Air Quality Standard Permit for Pollution Control Projects

Compliance Requirements

12. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous

or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.

13. Use of Discrete Emission Credits to comply with the applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
 - B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Protection of Stratospheric Ozone

14. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
 - A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.

Temporary Fuel Shortages (30 TAC § 112.15)

15. The permit holder shall comply with the following 30 TAC Chapter 112 requirements:
 - A. Title 30 TAC § 112.15 (relating to Temporary Fuel Shortage Plan Filing Requirements)

- B. Title 30 TAC § 112.16(a), (a)(1), and (a)(2)(B) - (C) (relating to Temporary Fuel Shortage Plan Operating Requirements)
- C. Title 30 TAC § 112.17 (relating to Temporary Fuel Shortage Plan Notification Procedures)
- D. Title 30 TAC § 112.18 (relating to Temporary Fuel Shortage Plan Reporting Requirements)

Permit Location

- 16. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

- 17. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Acid Rain Permit Requirements

- 18. For UNIT 1 and UNIT 2 (identified in the Certificate of Representation as units 171B and 172B), located at the affected source identified by ORIS/Facility code 6194, the designated representative and the owner or operator, as applicable, shall comply with the following Acid Rain Permit requirements.
 - A. General Requirements
 - (i) Under 30 TAC § 122.12(1) and 40 CFR Part 72, the Acid Rain Permit requirements contained here are a separable portion of the Federal Operating Permit (FOP) and have an independent public comment process which may be separate from, or combined with the FOP.
 - (ii) The owner and operator shall comply with the requirements of 40 CFR Part 72 and 40 CFR Part 76. Any noncompliance with the Acid Rain Permit will be considered noncompliance with the FOP and may be subject to enforcement action.
 - (iii) The owners and operators of the affected source shall operate the source and the unit in compliance with the requirements of this Acid Rain Permit and all other applicable State and federal requirements.
 - (iv) The owners and operators of the affected source shall comply with the General Terms and Conditions of the FOP that incorporates this Acid Rain Permit.
 - (v) The term for the Acid Rain permit shall commence with the issuance of the FOP that incorporates the Acid Rain permit and shall be run concurrent with the

remainder of the term of the FOP. Renewal of the Acid Rain permit shall coincide with the renewal of the FOP that incorporates the Acid Rain permit and subsequent terms shall be no more than five years from the date of renewal of the FOP and run concurrent with the permit term of the FOP.

B. Monitoring Requirements

- (i) The owners and operators, and the designated representative, of the affected source and each affected unit at the source shall comply with the monitoring requirements contained in 40 CFR Part 75.
- (ii) The emissions measurements recorded and reported in accordance with 40 CFR Part 75 and any other credible evidence shall be used to determine compliance by the affected source with the acid rain emissions limitations and emissions reduction requirements for SO₂ and NO_x under the ARP.
- (iii) The requirements of 40 CFR Part 75 shall not affect the responsibility of the owners and operators to monitor emission of other pollutants or other emissions characteristics at the unit under other applicable requirements of the FCAA Amendments (42 U.S.C. 7401, as amended November 15, 1990) and other terms and conditions of the operating permit for the source.

C. SO₂ emissions requirements

- (i) The owners and operators of each source and each affected unit at the source shall comply with the applicable acid rain emissions limitations for SO₂.
- (ii) As of the allowance transfer deadline the owners and operators of the affected source and each affected unit at the source shall hold, in the unit's compliance subaccount, allowances in an amount not less than the total annual emissions of SO₂ for the previous calendar year.
- (iii) Each ton of SO₂ emitted in excess of the acid rain emissions limitations for SO₂ shall constitute a separate violation of the FCAA amendments.
- (iv) An affected unit shall be subject to the requirements under (i) and (ii) of the SO₂ emissions requirements as follows:
 - (1) Starting January 1, 2000, an affected unit under 40 CFR § 72.6(a)(2); or
 - (2) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR Part 75, an affected unit under 40 CFR § 72.6(a)(3).
- (v) Allowances shall be held in, deducted from, or transferred into or among Allowance Tracking System accounts in accordance with the requirements of the ARP.
- (vi) An allowance shall not be deducted, for compliance with the requirements of this permit, in a calendar year before the year for which the allowance was allocated.
- (vii) An allowance allocated by the EPA Administrator or under the ARP is a limited authorization to emit SO₂ in accordance with the ARP. No provision of the ARP, Acid Rain permit application, this Acid Rain Permit, or an exemption under

40 CFR §§ 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.

- (viii) An allowance allocated by the EPA Administrator under the ARP does not constitute a property right.

D. NO_x Emission Requirements

- (i) The owners and operators of the source and each affected unit at the source shall comply with the applicable acid rain emissions limitations for NO_x under 40 CFR Part 76.

E. Excess emissions requirements for SO₂ and NO_x.

- (i) The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77.

- (ii) If an affected source has excess emissions in any calendar year shall, as required by 40 CFR Part 77:

- (1) Pay, without demand, the penalty required and pay, upon demand, the interest on that penalty.
- (2) Comply with the terms of an approved offset plan.

F. Recordkeeping and Reporting Requirements

- (i) Unless otherwise provided, the owners and operators of the affected source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the permitting authority or the EPA Administrator.

- (1) The certificate of representation for the designated representative for the source and each affected unit and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR § 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative.
- (2) All emissions monitoring information, in accordance with 40 CFR Part 75, provided that to the extent that 40 CFR Part 75 provides for a 3-year period for recordkeeping (rather than a five-year period cited in 30 TAC § 122.144), the 3-year period shall apply.
- (3) Copies of all reports, compliance certifications, and other submissions and all records made or required under the ARP or relied upon for compliance certification.
- (4) Copies of all documents used to complete an acid rain permit application and any other submission under the ARP or to demonstrate compliance with the requirements of the ARP.

- (ii) The designated representative of an affected source and each affected unit at the source shall submit the reports required under the ARP including those under 40 CFR Part 72, Subpart I and 40 CFR Part 75.

G. Liability

- (i) Any person who knowingly violates any requirement or prohibition of the ARP, a complete acid rain permit application, an acid rain permit, or a written exemption under 40 CFR §§ 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to FCAA § 113(c).
- (ii) Any person who knowingly makes a false, material statement in any record, submission, or report under the ARP shall be subject to criminal enforcement pursuant to FCAA § 113(c) and 18 U.S.C. 1001.
- (iii) No permit revision shall excuse any violation of the requirements of the ARP that occurs prior to the date that the revision takes effect.
- (iv) The affected source and each affected unit shall meet the requirements of the ARP contained in 40 CFR Parts 72 through 78.
- (v) Any provision of the ARP that applies to an affected source or the designated representative of an affected source shall also apply to the owners and operators of such source and of the affected units at the source.
- (vi) Any provision of the ARP that applies to an affected unit (including a provision applicable to the DR of an affected unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR § 72.44 (Phase II repowering extension plans) and 40 CFR § 76.11 (NO_x averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR §§ 75.16, 75.17, and 75.18), the owners and operators and the DR of one affected unit shall not be liable for any violation by any other affected unit of which they are not owners or operators or the DR and that is located at a source of which they are not owners or operators or the DR.
- (vii) Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or DR of such source or unit, shall be a separate violation of the FCAA Amendments.

H. Effect on other authorities. No provision of the ARP, an acid rain permit application, an acid rain permit, or an exemption under 40 CFR §§ 72.7 or 72.8 shall be construed as:

- (i) Except as expressly provided in Title IV of the FCAA Amendments, exempting or excluding the owners and operators and, to the extent applicable, the DR of an affected source or affected unit from compliance with any other provision of the FCAA Amendments, including the provisions of Title I of the FCAA Amendments relating to applicable National Ambient Air Quality Standards or State Implementation Plans.
- (ii) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the FCAA Amendments.

- (iii) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law.
 - (iv) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
 - (v) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established.
- I. The number of SO₂ allowances allocated by the EPA in 40 CFR Part 73 is enforceable only by the EPA Administrator.

Cross-State Air Pollution Rule (CSAPR) Trading Program Requirements

19. For UNIT 1 and UNIT 2 (identified in the Certificate of Representation as units 171B and 172B), located at the affected source identified by ORIS/Facility code 6194, the designated representative and the owner or operator, as applicable, shall comply with the following CSAPR requirements.

A. General Requirements

- (i) The owners and operators of the CSAPR NO_x Ozone Season Group 2 source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall operate the source and the unit in compliance with the requirements of the CSAPR NO_x Ozone Season Group 2 Trading Program and all other applicable State and federal requirements.
- (ii) The owners and operators of the CSAPR NO_x Ozone Season Group 2 source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall comply with the requirements of 40 CFR Part 97, Subpart EEEEE for CSAPR NO_x Ozone Season Group 2 Trading Program, and with the General Terms and Conditions of the Federal Operating Permit (FOP) that incorporates the CSAPR requirements.

B. Description of CSAPR Monitoring Provisions

- (i) The CSAPR subject unit(s), and the unit-specific monitoring provisions at this source, are identified in the following paragraph(s). These unit(s) are subject to the requirements for the CSAPR NO_x Ozone Season Group 2 Trading Program.
 - (1) For UNIT 1 and UNIT 2, the owners and operators shall comply with the continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart H for NO_x and heat input.
- (ii) The above description of the monitoring used by a unit does not change, create an exemption from, or otherwise affect the monitoring, recordkeeping, and reporting requirements applicable to the unit under 40 CFR §§ 97.830 through 97.835 (CSAPR NO_x Ozone Season Group 2 Trading Program). The monitoring, recordkeeping and reporting requirements applicable to each unit are included below in the standard conditions for the applicable CSAPR trading program.

- (iii) Owners and operators must submit to the Administrator a monitoring plan for each unit in accordance with 40 CFR §§ 75.53, 75.62 and 75.73, as applicable. The monitoring plan for each unit is available at the EPA's website at <https://www.epa.gov/airmarkets/clean-air-markets-monitoring-plans-part-75-sources>.
- (iv) Owners and operators that want to use an alternative monitoring system must submit to the Administrator a petition requesting approval of the alternative monitoring system in accordance with 40 CFR Part 75, Subpart E and 40 CFR § 75.66 and § 97.835 (CSAPR NO_x Ozone Season Group 2 Trading Program). The Administrator's response approving or disapproving any petition for an alternative monitoring system is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
- (v) Owners and operators that want to use an alternative to any monitoring, recordkeeping, or reporting requirement under 40 CFR §§ 97.830 through 97.834 (CSAPR NO_x Ozone Season Group 2 Trading Program) must submit to the Administrator a petition requesting approval of the alternative in accordance with 40 CFR § 75.66 and § 97.835 (CSAPR NO_x Ozone Season Group 2 Trading Program). The Administrator's response approving or disapproving any petition for an alternative to a monitoring, recordkeeping, or reporting requirement is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
- (vi) The descriptions of monitoring applicable to the unit(s) included above meet the requirement of 40 CFR §§ 97.830 through 97.834 (CSAPR NO_x Ozone Season Group 2 Trading Program), and therefore procedures for minor permit revisions, in accordance with 30 TAC § 122.217, may be used to add or change this unit's monitoring system description.

20. CSAPR NO_x Ozone Season Group 2 Trading Program Requirements (40 CFR § 97.806)

A. Designated representative requirements

- (i) The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR §§ 97.813 through 97.818.

B. Emissions monitoring, reporting, and recordkeeping requirements

- (i) The owners and operators, and the designated representative, of each CSAPR NO_x Ozone Season Group 2 source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR § 97.830 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), § 97.831 (initial monitoring system certification and recertification procedures), § 97.832 (monitoring system out-of-control periods), § 97.833 (notifications concerning monitoring), § 97.834 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and § 97.835 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- (ii) The emissions data determined in accordance with 40 CFR § 97.830 through § 97.835 and any other credible evidence shall be used to calculate allocations of

CSAPR NO_x Ozone Season Group 2 allowances under 40 CFR §§ 97.811(a)(2) and (b) and § 97.812 and to determine compliance with the CSAPR NO_x Ozone Season Group 2 emissions limitation and assurance provisions under paragraph C. below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR §§ 97.830 through 97.835 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

C. NO_x emissions requirements

(i) CSAPR NO_x Ozone Season Group 2 emissions limitation

- (1) As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NO_x Ozone Season Group 2 source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall hold, in the source's compliance account, CSAPR NO_x Ozone Season Group 2 allowances available for deduction for such control period under 40 CFR § 97.824(a) in an amount not less than the tons of total NO_x emissions for such control period from all CSAPR NO_x Ozone Season Group 2 units at the source.
- (2) If total NO_x emissions during a control period in a given year from the CSAPR NO_x Ozone Season Group 2 units at a CSAPR NO_x Ozone Season Group 2 source are in excess of the CSAPR NO_x Ozone Season Group 2 emissions limitation set forth in paragraph C.(i)(1) above, then:
 - (a) The owners and operators of the source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall hold the CSAPR NO_x Ozone Season Group 2 allowances required for deduction under 40 CFR § 97.824(d); and
 - (b) The owners and operators of the source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart EEEEE and the Clean Air Act.

(ii) CSAPR NO_x Ozone Season Group 2 assurance provisions

- (1) If total NO_x emissions during a control period in a given year from all CSAPR NO_x Ozone Season Group 2 units at CSAPR NO_x Ozone Season Group 2 sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO_x emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) CSAPR NO_x Ozone Season Group 2 allowances available for deduction for such control period under 40 CFR § 97.825(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined

by the Administrator in accordance with 40 CFR § 97.825(b), of multiplying -

- (a) The quotient of the amount by which the common designated representative's share of such NO_x emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such NO_x emissions exceeds the respective common designated representative's assurance level; and
 - (b) The amount by which total NO_x emissions from all CSAPR NO_x Ozone Season Group 2 units at CSAPR NO_x Ozone Season Group 2 sources in the state for such control period exceed the state assurance level.
- (2) The owners and operators shall hold the CSAPR NO_x Ozone Season Group 2 allowances required under paragraph C.(ii)(1) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
 - (3) Total NO_x emissions from all CSAPR NO_x Ozone Season Group 2 units at CSAPR NO_x Ozone Season Group 2 sources in the state during a control period in a given year exceed the state assurance level if such total NO_x emissions exceed the sum, for such control period, of the state NO_x Ozone Season Group 2 trading budget under 40 CFR § 97.810(a) and the state's variability limit under 40 CFR § 97.810(b).
 - (4) It shall not be a violation of 40 CFR Part 97, Subpart EEEEE or of the Clean Air Act if total NO_x emissions from all CSAPR NO_x Ozone Season Group 2 units at CSAPR NO_x Ozone Season Group 2 sources in the state during a control period exceed the state assurance level or if a common designated representative's share of total NO_x emissions from the CSAPR NO_x Ozone Season Group 2 units at CSAPR NO_x Ozone Season Group 2 sources in the state during a control period exceeds the common designated representative's assurance level.
 - (5) To the extent the owners and operators fail to hold CSAPR NO_x Ozone Season Group 2 allowances for a control period in a given year in accordance with paragraphs C.(ii)(1) through (3) above,
 - (a) The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
 - (b) Each CSAPR NO_x Ozone Season Group 2 allowance that the owners and operators fail to hold for such control period in accordance with paragraphs C.(ii)(1) through (3) above and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart EEEEE and the Clean Air Act.

(iii) Compliance periods

- (1) A CSAPR NO_x Ozone Season Group 2 unit shall be subject to the requirements under paragraph C.(i) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR § 97.830(b) and for each control period thereafter.
 - (2) A CSAPR NO_x Ozone Season Group 2 unit shall be subject to the requirements under paragraph C.(ii) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR § 97.830(b) and for each control period thereafter.
- (iv) Vintage of allowances held for compliance
 - (1) A CSAPR NO_x Ozone Season Group 2 allowance held for compliance with the requirements under paragraph C.(i)(1) above for a control period in a given year must be a CSAPR NO_x Ozone Season Group 2 allowance that was allocated for such control period or a control period in a prior year.
 - (2) A CSAPR NO_x Ozone Season Group 2 allowance held for compliance with the requirements under paragraphs C.(i)(2)(a) and (ii)(1) through (3) above for a control period in a given year must be a CSAPR NO_x Ozone Season Group 2 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
- (v) Allowance Management System requirements. Each CSAPR NO_x Ozone Season Group 2 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart EEEEE.
- (vi) Limited authorization. A CSAPR NO_x Ozone Season Group 2 allowance is a limited authorization to emit one ton of NO_x during the control period in one year. Such authorization is limited in its use and duration as follows:
 - (1) Such authorization shall only be used in accordance with the CSAPR NO_x Ozone Season Group 2 Trading Program; and
 - (2) Notwithstanding any other provision of 40 CFR Part 97, Subpart EEEEE, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (vii) Property right. A CSAPR NO_x Ozone Season Group 2 allowance does not constitute a property right.

D. FOP revision requirements

- (i) No FOP revision shall be required for any allocation, holding, deduction, or transfer of CSAPR NO_x Ozone Season Group 2 allowances in accordance with 40 CFR Part 97, Subpart EEEEE.

- (ii) This FOP incorporates the CSAPR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR §§ 97.830 through 97.835, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, subpart H), an excepted monitoring system (pursuant to 40 CFR Part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR § 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, subpart E). Therefore the Description of CSAPR Monitoring Provisions for CSAPR subject unit(s) may be added to, or changed, in this FOP using procedures for minor permit revisions in accordance with 30 TAC § 122.217.

E. Additional recordkeeping and reporting requirements

- (i) Unless otherwise provided, the owners and operators of each CSAPR NO_x Ozone Season Group 2 source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
 - (1) The certificate of representation under 40 CFR § 97.816 for the designated representative for the source and each CSAPR NO_x Ozone Season Group 2 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR § 97.816 changing the designated representative.
 - (2) All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart EEEEE.
 - (3) Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the CSAPR NO_x Ozone Season Group 2 Trading Program.
- (ii) The designated representative of a CSAPR NO_x Ozone Season Group 2 source and each CSAPR NO_x Ozone Season Group 2 unit at the source shall make all submissions required under the CSAPR NO_x Ozone Season Group 2 Trading Program, except as provided in 40 CFR § 97.818. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under 30 TAC § 122.165.

F. Liability

- (i) Any provision of the CSAPR NO_x Ozone Season Group 2 Trading Program that applies to a CSAPR NO_x Ozone Season Group 2 source or the designated representative of a CSAPR NO_x Ozone Season Group 2 source shall also apply to the owners and operators of such source and of the CSAPR NO_x Ozone Season Group 2 units at the source.
- (ii) Any provision of the CSAPR NO_x Ozone Season Group 2 Trading Program that applies to a CSAPR NO_x Ozone Season Group 2 unit or the designated

representative of a CSAPR NO_x Ozone Season Group 2 unit shall also apply to the owners and operators of such unit.

G. Effect on other authorities

- (i) No provision of the CSAPR NO_x Ozone Season Group 2 Trading Program or exemption under 40 CFR § 97.805 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a CSAPR NO_x Ozone Season Group 2 source or CSAPR NO_x Ozone Season Group 2 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

Federal Implementation Plan for Regional Haze (Texas SO₂ Trading Program) Requirements

21. For UNIT 1 and UNIT 2 (identified in the Certificate of Representation as units 171B and 172B), located at the affected source identified by ORIS/Facility code 6194, the designated representative and the owner or operator, as applicable, shall comply with the following Texas SO₂ Trading Program requirements.

A. General Requirements

- (i) The owners and operators of the Texas SO₂ Trading Program source and each Texas SO₂ Trading Program unit at the source shall operate the source and the unit in compliance with the requirements of the Texas SO₂ Trading Program and all other applicable State and federal requirements.
- (ii) The owners and operators of the Texas SO₂ Trading Program source and each Texas SO₂ Trading Program unit at the source shall comply with the requirements of 40 CFR Part 97, Subpart FFFFF for Texas SO₂ Trading Program, and with the General Terms and Conditions of the Federal Operating Permit (FOP) that incorporates the Texas SO₂ Trading Program requirements.

B. Description of Monitoring Provisions

- (i) The Texas SO₂ Trading Program subject unit(s), and the unit-specific monitoring provisions at this source, are identified in the following paragraph(s).
 - (1) For UNIT 1 and UNIT 2, the owners and operators shall comply with the continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart B for SO₂ and 40 CFR Part 75, Subpart H for heat input.
- (ii) The above description of the monitoring used by a unit does not change, create an exemption from, or otherwise affect the monitoring, recordkeeping, and reporting requirements applicable to the unit under 40 CFR §§ 97.930 through 97.935 (Texas SO₂ Trading Program). The monitoring, recordkeeping and reporting requirements applicable to each unit are included below in the standard conditions for the Texas SO₂ Trading Program.
- (iii) Owners and operators must submit to the Administrator a monitoring plan for each unit in accordance with 40 CFR §§ 75.53, 75.62 and 75.73, as applicable. The monitoring plan for each unit is available at the EPA's website at <https://www.epa.gov/airmarkets/clean-air-markets-monitoring-plans-part-75-sources>.

- (iv) Owners and operators that want to use an alternative monitoring system must submit to the Administrator a petition requesting approval of the alternative monitoring system in accordance with 40 CFR Part 75, Subpart E and 40 CFR § 75.66 and § 97.935 (Texas SO₂ Trading Program). The Administrator's response approving or disapproving any petition for an alternative monitoring system is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
- (v) Owners and operators that want to use an alternative to any monitoring, recordkeeping, or reporting requirement under 40 CFR §§ 97.930 through 97.934 (Texas SO₂ Trading Program) must submit to the Administrator a petition requesting approval of the alternative in accordance with 40 CFR § 75.66 and § 97.935 (Texas SO₂ Trading Program). The Administrator's response approving or disapproving any petition for an alternative to a monitoring, recordkeeping, or reporting requirement is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
- (vi) The descriptions of monitoring applicable to the unit(s) included above meet the requirement of 40 CFR §§ 97.930 through 97.934 (Texas SO₂ Trading Program), and therefore procedures for minor permit revisions, in accordance with 30 TAC § 122.217, may be used to add or change this unit's monitoring system description.

22. Texas SO₂ Trading Program Requirements (40 CFR § 97.906)

A. Designated representative requirements

- (i) The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR §§ 97.913 through 97.918.

B. Emissions monitoring, reporting, and recordkeeping requirements

- (i) The owners and operators, and the designated representative, of each Texas SO₂ source and each Texas SO₂ unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR § 97.930 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), § 97.931 (initial monitoring system certification and recertification procedures), § 97.932 (monitoring system out-of-control periods), § 97.933 (notifications concerning monitoring), § 97.934 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and § 97.935 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- (ii) The emissions data determined in accordance with §§ 97.930 through 97.935 shall be used to calculate allocations of Texas SO₂ Trading Program allowances under § 97.912 and to determine compliance with the Texas SO₂ Trading Program emissions limitation under paragraph (c) of this section, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with §§ 97.930 through 97.935 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero and any fraction of a ton greater than or equal to 0.50 being deemed to be a whole ton.

C. SO₂ emissions requirements

(i) Texas SO₂ Trading Program emissions limitation

- (1) As of the allowance transfer deadline for a control period in a given year, the owners and operators of each Texas SO₂ Trading Program source and each Texas SO₂ Trading Program unit at the source shall hold, in the source's compliance account, Texas SO₂ Trading Program allowances available for deduction for such control period under § 97.924(a) in an amount not less than the tons of total SO₂ emissions for such control period from all Texas SO₂ Trading Program units at the source.
- (2) If total SO₂ emissions during a control period in a given year from the Texas SO₂ Trading Program units at a Texas SO₂ Trading Program source are in excess of the Texas SO₂ Trading Program emissions limitation set forth in paragraph C.(i)(1) of this section, then:
 - (a) The owners and operators of the source and each Texas SO₂ Trading Program unit at the source shall hold the Texas SO₂ Trading Program allowances required for deduction under § 97.924(d); and
 - (b) The owners and operators of the source and each Texas SO₂ Trading Program unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of this subpart and the Clean Air Act.

(ii) Compliance periods. A Texas SO₂ Trading Program unit shall be subject to the requirements under paragraph C.(i) of this section for the control period starting on the later of January 1, 2019 or the deadline for meeting the unit's monitor certification requirements under § 97.930(b) and for each control period thereafter.

(iii) Vintage of allowances held for compliance

- (1) A Texas SO₂ Trading Program allowance held for compliance with the requirements under paragraph C.(i)(1) of this section for a control period in a given year must be a Texas SO₂ Trading Program allowance that was allocated for such control period or a control period in a prior year.
- (2) A Texas SO₂ Trading Program allowance held for compliance with the requirements under paragraph C.(i)(2)(a) of this section for a control period in a given year must be a Texas SO₂ Trading Program allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.

(iv) Allowance Management System requirements. Each Texas SO₂ Trading Program allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart FFFFFF.

- (v) Limited authorization. A Texas SO₂ Trading Program allowance is a limited authorization to emit one ton of SO₂ during the control period in one year. Such authorization is limited in its use and duration as follows:
 - (1) Such authorization shall only be used in accordance with the Texas SO₂ Trading Program; and
 - (2) Notwithstanding any other provision of 40 CFR Part 97, Subpart FFFFF, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (vi) Property right. A Texas SO₂ Trading Program allowance does not constitute a property right.

D. FOP revision requirements

- (i) No FOP revision shall be required for any allocation, holding, deduction, or transfer of Texas SO₂ Trading Program allowances in accordance with 40 CFR Part 97, Subpart FFFFF.
- (ii) This FOP incorporates the Texas SO₂ Trading Program emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR §§ 97.930 through 97.935, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, subpart B), an excepted monitoring system (pursuant to 40 CFR Part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR § 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, subpart E). Therefore the Description of Monitoring Provisions for Texas SO₂ Trading Program subject unit(s) may be added to, or changed, in this FOP using procedures for minor permit revisions in accordance with 30 TAC § 122.217.

E. Additional recordkeeping and reporting requirements

- (i) Unless otherwise provided, the owners and operators of each Texas SO₂ Trading Program source and each Texas SO₂ Trading Program unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
 - (1) The certificate of representation under § 97.916 for the designated representative for the source and each Texas SO₂ Trading Program unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under § 97.916 changing the designated representative.
 - (2) All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart FFFFF.

(3) Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the Texas SO₂ Trading Program.

(ii) The designated representative of a Texas SO₂ Trading Program source and each Texas SO₂ Trading Program unit at the source shall make all submissions required under the Texas SO₂ Trading Program, except as provided in § 97.918. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under 30 TAC § 122.165.

F. Liability

(i) Any provision of the Texas SO₂ Trading Program that applies to a Texas SO₂ Trading Program source or the designated representative of a Texas SO₂ Trading Program source shall also apply to the owners and operators of such source and of the Texas SO₂ Trading Program units at the source.

(ii) Any provision of the Texas SO₂ Trading Program that applies to a Texas SO₂ Trading Program unit or the designated representative of a Texas SO₂ Trading Program unit shall also apply to the owners and operators of such unit.

G. Effect on other authorities

(i) No provision of the Texas SO₂ Trading Program or exemption under § 97.905 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a Texas SO₂ Trading Program source or Texas SO₂ Trading Program unit from compliance with any other provision of the applicable, approved State implementation plan, a federally enforceable permit, or the Clean Air Act.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Applicable Requirements Summary

Unit Summary	25
---------------------------	-----------

Applicable Requirements Summary	27
--	-----------

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
1-1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63UUUUU-0001	40 CFR Part 63, Subpart UUUUU	No changing attributes.
2-1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63UUUUU-0001	40 CFR Part 63, Subpart UUUUU	No changing attributes.
AUXBLR	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
GRP-BLR-ST	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	1-1, 2-1	R111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRP_ENGINES	SRIC ENGINES	DFP, EG 2A, EG 2B	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
UNIT 1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60-1	40 CFR Part 60, Subpart D	D-Series Fuel Type #2 = Gaseous fossil fuel other than natural gas., D- Series Fuel Type #1 = Solid fossil fuel (fuel that is not lignite, at least 25% coal refuse, or at least 25% lignite mined in North Dakota, South Dakota, or Montana.
UNIT 1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60-2	40 CFR Part 60, Subpart D	D-Series Fuel Type #1 = Solid fossil fuel (fuel that is not lignite, at least 25% coal refuse, or at least 25% lignite mined in North Dakota, South Dakota, or Montana.
UNIT 1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60-3	40 CFR Part 60, Subpart D	D-Series Fuel Type #1 = Gaseous fossil fuel other than natural gas.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
UNIT 2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60-1	40 CFR Part 60, Subpart D	D-Series Fuel Type #2 = Gaseous fossil fuel other than natural gas., D-Series Fuel Type #1 = Solid fossil fuel (fuel that is not lignite, at least 25% coal refuse, or at least 25% lignite mined in North Dakota, South Dakota, or Montana.
UNIT 2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60-2	40 CFR Part 60, Subpart D	D-Series Fuel Type #1 = Solid fossil fuel (fuel that is not lignite, at least 25% coal refuse, or at least 25% lignite mined in North Dakota, South Dakota, or Montana.
UNIT 2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60-3	40 CFR Part 60, Subpart D	D-Series Fuel Type #1 = Gaseous fossil fuel other than natural gas.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
1-1	EU	63UUUUU-0001	Hydrogen Chloride	40 CFR Part 63, Subpart UUUUU	§ 63.9991(a)(1)-Table 2.1.b § 63.10000(a) § 63.10000(b) § 63.10000(d)(1) [G]§ 63.10000(d)(2) § 63.10000(d)(4) § 63.10000(e) § 63.10000(l) § 63.10000(m) § 63.10000(m)(1) § 63.10005(a) § 63.10005(d) § 63.10005(e) § 63.10005(f) § 63.10005(j) [G]§ 63.10006(i) § 63.10007(e) § 63.10011(f)(1) § 63.10011(f)(2) [G]§ 63.10011(g) § 63.10021(e)-Table 7.5 § 63.10021(e)-Table 7.6 § 63.10021(e)-Table 7.7 [G]§ 63.10021(e) [G]§ 63.10021(h) § 63.10040 § 63.9991(a)(1) § 63.9991(a)(1)-Table 3.1 § 63.9991(a)(1)-Table 3.3.a.(1) § 63.9991(a)(1)-Table 3.3.d § 63.9991(a)(1)-Table 3.4	For existing coal-fired unit not low rank virgin coal, hydrogen chloride limit is 0.002 lb/MMBtu heat input. For Method 26A at appendix A–8 to part 60 of this chapter, collect a minimum of 0.75 dscm per run; for Method 26, collect a minimum of 120 liters per run. For ASTM D6348–03 or Method 320 at appendix A to part 63 of this chapter, sample for a minimum of 1 hour.	§ 63.10000(c)(1) § 63.10000(c)(1)(v) § 63.10000(l) § 63.10000(m) § 63.10000(m)(1) § 63.10005(a) § 63.10005(a)(1) § 63.10005(a)(2) § 63.10005(a)(2)(i) § 63.10005(a)(2)(ii) [G]§ 63.10005(a)(2)(iii) [G]§ 63.10005(b) § 63.10005(d)(1) § 63.10006(b)(1) [G]§ 63.10006(f)(1) § 63.10006(f)(2) [G]§ 63.10006(f)(3) § 63.10006(g) § 63.10006(h) § 63.10007(a) § 63.10007(a)(1) § 63.10007(a)(2) § 63.10007(b) § 63.10007(b)-Table 5.3 § 63.10007(d) § 63.10007(e)(1) [G]§ 63.10007(e)(2) § 63.10007(f) [G]§ 63.10007(f)(1) § 63.10007(f)(2) § 63.10010(a)(1) § 63.10010(b) § 63.10010(e) § 63.10011(a) § 63.10011(c)(1) § 63.10011(e) § 63.10020(a) § 63.10020(b) § 63.10020(c) § 63.10021(a)	§ 63.10000(d)(1) [G]§ 63.10000(d)(2) [G]§ 63.10000(d)(5) § 63.10000(l) § 63.10000(m)(2) [G]§ 63.10005(b) § 63.10005(f) § 63.10020(a) § 63.10020(b) § 63.10020(d) [G]§ 63.10032(a) [G]§ 63.10032(b) § 63.10032(c) [G]§ 63.10032(d) [G]§ 63.10032(f) § 63.10032(g) § 63.10032(h) § 63.10032(i) § 63.10033(a) § 63.10033(b) § 63.10033(c)	§ 63.10000(d)(3) § 63.10000(l) § 63.10000(m)(2) § 63.10005(k) § 63.10021(f) § 63.10021(g) § 63.10021(i) § 63.10030(a) § 63.10030(b) § 63.10030(d) [G]§ 63.10030(e) § 63.10030(f) § 63.10031(a) § 63.10031(a)-Table 8.1.a § 63.10031(a)-Table 8.1.b § 63.10031(a)-Table 8.1.c [G]§ 63.10031(b) [G]§ 63.10031(c) § 63.10031(d) § 63.10031(e) § 63.10031(f) § 63.10031(f)(1) § 63.10031(f)(3) § 63.10031(f)(4) § 63.10031(f)(5) [G]§ 63.10031(f)(6) § 63.10031(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 63.10021(b) § 63.10021(b)-Table 7.1 § 63.10021(d) § 63.10021(d)(1) § 63.10021(d)(2) § 63.10021(d)-Table 7.4		
1-1	EU	63UUUUU-0001	Mercury	40 CFR Part 63, Subpart UUUUU	§ 63.9991(a)(1)-Table 2.1.c § 63.10000(a) § 63.10000(b) § 63.10000(d)(1) [G]§ 63.10000(d)(2) § 63.10000(d)(4) § 63.10000(e) § 63.10005(a) § 63.10005(d) § 63.10005(e) § 63.10005(f) § 63.10005(j) [G]§ 63.10006(i) § 63.10007(e) § 63.10011(f)(1) § 63.10011(f)(2) [G]§ 63.10011(g) § 63.10021(e)-Table 7.5 § 63.10021(e)-Table 7.6 § 63.10021(e)-Table 7.7 [G]§ 63.10021(e) [G]§ 63.10021(h) § 63.10040 § 63.9991(a)(1) § 63.9991(a)(1)-Table 3.1 § 63.9991(a)(1)-Table 3.3.a.(1) § 63.9991(a)(1)-Table 3.3.c § 63.9991(a)(1)-Table 3.3.d	For existing coal-fired unit not low rank virgin coal, mercury limit is 1.2 lb/TBtu heat input. LEE Testing for 30 days with a sampling period consistent with that given in section 5.2.1 of appendix A to this subpart per Method 30B at appendix A-8 to part 60 of this chapter run or Hg CEMS or sorbent trap monitoring system only.	§ 63.10000(c)(1) [G]§ 63.10000(c)(1)(vi) § 63.10005(a) § 63.10005(a)(1) § 63.10005(a)(2) § 63.10005(a)(2)(i) § 63.10005(a)(2)(ii) [G]§ 63.10005(a)(2)(iii) [G]§ 63.10005(b) § 63.10005(d)(3) § 63.10006(b)(2) [G]§ 63.10006(f)(1) [G]§ 63.10006(f)(3) § 63.10006(g) § 63.10007(a) § 63.10007(a)(1) § 63.10007(a)(2) § 63.10007(b) § 63.10007(b)-Table 5.4 § 63.10007(d) § 63.10007(e)(1) [G]§ 63.10007(e)(2) § 63.10007(f) [G]§ 63.10007(f)(1) § 63.10007(f)(2) § 63.10010(a)(1) § 63.10010(b) § 63.10010(g) [G]§ 63.10010(j) § 63.10011(a) § 63.10011(c)(1)	§ 63.10000(d)(1) [G]§ 63.10000(d)(2) [G]§ 63.10000(d)(5) [G]§ 63.10005(b) § 63.10005(f) [G]§ 63.10010(j) § 63.10020(a) § 63.10020(b) § 63.10020(d) [G]§ 63.10032(a) [G]§ 63.10032(b) § 63.10032(c) [G]§ 63.10032(d) [G]§ 63.10032(f) § 63.10032(g) § 63.10032(h) § 63.10032(i) § 63.10033(a) § 63.10033(b) § 63.10033(c)	§ 63.10000(d)(3) § 63.10005(k) § 63.10021(f) § 63.10021(g) § 63.10021(i) § 63.10030(a) § 63.10030(b) § 63.10030(d) [G]§ 63.10030(e) § 63.10030(f) § 63.10031(a) § 63.10031(a)-Table 8.1.a § 63.10031(a)-Table 8.1.b § 63.10031(a)-Table 8.1.c [G]§ 63.10031(b) [G]§ 63.10031(c) § 63.10031(d) § 63.10031(e) § 63.10031(f) § 63.10031(f)(1) § 63.10031(f)(2) § 63.10031(f)(3) § 63.10031(f)(4) § 63.10031(f)(5) [G]§ 63.10031(f)(6) § 63.10031(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.9991(a)(1)-Table 3.4		§ 63.10011(e) § 63.10020(a) § 63.10020(b) § 63.10020(c) § 63.10021(a) § 63.10021(b) § 63.10021(b)-Table 7.1		
1-1	EU	63UUUUU-0001	PM	40 CFR Part 63, Subpart UUUUU	§ 63.9991(a)(1)-Table 2.1.a § 63.10000(a) § 63.10000(b) [G]§ 63.10000(c)(1)(i)(C) § 63.10000(e) § 63.10000(l) § 63.10000(m) § 63.10000(m)(1) § 63.10005(a) § 63.10005(d) § 63.10005(e) § 63.10005(f) § 63.10005(h)(1) § 63.10005(h)(1)(i) § 63.10005(j) [G]§ 63.10006(i) § 63.10007(e) § 63.10011(f)(1) § 63.10011(f)(2) [G]§ 63.10011(g) § 63.10021(e)-Table 7.5 § 63.10021(e)-Table 7.6 § 63.10021(e)-Table 7.7 [G]§ 63.10021(e) [G]§ 63.10021(h) § 63.10040 § 63.9991(a)(1) § 63.9991(a)(1)-Table 3.1 § 63.9991(a)(1)-Table 3.3.a.(1) § 63.9991(a)(1)-Table	For existing coal-fired unit not low rank virgin coal, filterable PM limit is 0.03 lb/MMBtu heat input. Collect a minimum of 1 dscm per run.	§ 63.10000(c)(1) § 63.10000(c)(1)(i) § 63.10000(c)(1)(iii) § 63.10000(l) § 63.10000(m) § 63.10000(m)(1) § 63.10005(a) § 63.10005(a)(1) § 63.10005(a)(2) § 63.10005(a)(2)(i) § 63.10005(a)(2)(ii) [G]§ 63.10005(a)(2)(iii) [G]§ 63.10005(b) § 63.10005(d)(1) [G]§ 63.10005(d)(2) [G]§ 63.10005(h)(2) § 63.10006(b) § 63.10006(b)(1) [G]§ 63.10006(f)(1) § 63.10006(f)(2) [G]§ 63.10006(f)(3) § 63.10006(g) § 63.10006(h) § 63.10007(a) § 63.10007(a)(1) § 63.10007(a)(2) § 63.10007(b) § 63.10007(b)-Table 5.1 § 63.10007(d) § 63.10007(e)(1) [G]§ 63.10007(e)(2)	§ 63.10000(l) § 63.10000(m)(2) [G]§ 63.10005(b) § 63.10005(f) § 63.10020(a) § 63.10020(b) § 63.10020(d) [G]§ 63.10032(a) § 63.10032(c) [G]§ 63.10032(d) [G]§ 63.10032(f) § 63.10032(g) § 63.10032(h) § 63.10032(i) § 63.10033(a) § 63.10033(b) § 63.10033(c)	§ 63.10000(l) § 63.10000(m)(2) § 63.10005(k) § 63.10021(f) § 63.10021(g) § 63.10021(i) § 63.10030(a) § 63.10030(b) § 63.10030(d) [G]§ 63.10030(e) § 63.10030(f) § 63.10031(a) § 63.10031(a)-Table 8.1.a § 63.10031(a)-Table 8.1.b § 63.10031(a)-Table 8.1.c [G]§ 63.10031(b) [G]§ 63.10031(c) § 63.10031(e) § 63.10031(f) § 63.10031(f)(4) § 63.10031(f)(5) [G]§ 63.10031(f)(6) § 63.10031(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					3.3.d § 63.9991(a)(1)-Table 3.4		§ 63.10011(a) § 63.10011(d) § 63.10011(e) § 63.10020(a) § 63.10020(b) § 63.10020(c) § 63.10021(a) § 63.10021(d) § 63.10021(d)(1) § 63.10021(d)(2) § 63.10021(d)-Table 7.4		
2-1	EU	63UUUUU-0001	Hydrogen Chloride	40 CFR Part 63, Subpart UUUUU	§ 63.9991(a)(1)-Table 2.1.b § 63.10000(a) § 63.10000(b) § 63.10000(d)(1) [G]§ 63.10000(d)(2) § 63.10000(d)(4) § 63.10000(e) § 63.10000(l) § 63.10000(m) § 63.10000(m)(1) § 63.10005(a) § 63.10005(d) § 63.10005(e) § 63.10005(f) § 63.10005(j) [G]§ 63.10006(i) § 63.10007(e) § 63.10011(f)(1) § 63.10011(f)(2) [G]§ 63.10011(g) § 63.10021(e)-Table 7.5 § 63.10021(e)-Table 7.6 § 63.10021(e)-Table 7.7 [G]§ 63.10021(e) [G]§ 63.10021(h) § 63.10040 § 63.9991(a)(1)	For existing coal-fired unit not low rank virgin coal, hydrogen chloride limit is 0.002 lb/MMBtu heat input. For Method 26A at appendix A–8 to part 60 of this chapter, collect a minimum of 0.75 dscm per run; for Method 26, collect a minimum of 120 liters per run. For ASTM D6348–03 or Method 320 at appendix A to part 63 of this chapter, sample for a minimum of 1 hour.	§ 63.10000(c)(1) § 63.10000(c)(1)(v) § 63.10000(l) § 63.10000(m) § 63.10000(m)(1) § 63.10005(a) § 63.10005(a)(1) § 63.10005(a)(2) § 63.10005(a)(2)(i) § 63.10005(a)(2)(ii) [G]§ 63.10005(a)(2)(iii) [G]§ 63.10005(b) § 63.10005(d)(1) § 63.10006(b)(1) [G]§ 63.10006(f)(1) § 63.10006(f)(2) [G]§ 63.10006(f)(3) § 63.10006(g) § 63.10006(h) § 63.10007(a) § 63.10007(a)(1) § 63.10007(a)(2) § 63.10007(b) § 63.10007(b)-Table 5.3 § 63.10007(d) § 63.10007(e)(1) [G]§ 63.10007(e)(2)	§ 63.10000(d)(1) [G]§ 63.10000(d)(2) [G]§ 63.10000(d)(5) § 63.10000(l) § 63.10000(m)(2) [G]§ 63.10005(b) § 63.10005(f) § 63.10020(a) § 63.10020(b) § 63.10020(d) [G]§ 63.10032(a) [G]§ 63.10032(b) § 63.10032(c) [G]§ 63.10032(d) [G]§ 63.10032(f) § 63.10032(g) § 63.10032(h) § 63.10032(i) § 63.10033(a) § 63.10033(b) § 63.10033(c)	§ 63.10000(d)(3) § 63.10000(l) § 63.10000(m)(2) § 63.10005(k) § 63.10021(f) § 63.10021(g) § 63.10021(i) § 63.10030(a) § 63.10030(b) § 63.10030(d) [G]§ 63.10030(e) § 63.10030(f) § 63.10031(a) § 63.10031(a)-Table 8.1.a § 63.10031(a)-Table 8.1.b § 63.10031(a)-Table 8.1.c [G]§ 63.10031(b) [G]§ 63.10031(c) § 63.10031(d) § 63.10031(e) § 63.10031(f) § 63.10031(f)(1) § 63.10031(f)(3) § 63.10031(f)(4) § 63.10031(f)(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.9991(a)(1)-Table 3.1 § 63.9991(a)(1)-Table 3.3.a.(1) § 63.9991(a)(1)-Table 3.3.d § 63.9991(a)(1)-Table 3.4		§ 63.10007(f) [G]§ 63.10007(f)(1) § 63.10007(f)(2) § 63.10010(a)(1) § 63.10010(b) § 63.10010(e) § 63.10011(a) § 63.10011(c)(1) § 63.10011(e) § 63.10020(a) § 63.10020(b) § 63.10020(c) § 63.10021(a) § 63.10021(b) § 63.10021(b)-Table 7.1 § 63.10021(d) § 63.10021(d)(1) § 63.10021(d)(2) § 63.10021(d)-Table 7.4		[G]§ 63.10031(f)(6) § 63.10031(g)
2-1	EU	63UUUUU-0001	Mercury	40 CFR Part 63, Subpart UUUUU	§ 63.9991(a)(1)-Table 2.1.c § 63.10000(a) § 63.10000(b) § 63.10000(d)(1) [G]§ 63.10000(d)(2) § 63.10000(d)(4) § 63.10000(e) § 63.10005(a) § 63.10005(d) § 63.10005(e) § 63.10005(f) § 63.10005(j) [G]§ 63.10006(i) § 63.10007(e) § 63.10011(f)(1) § 63.10011(f)(2) [G]§ 63.10011(g) § 63.10021(e)-Table 7.5	For existing coal-fired unit not low rank virgin coal, mercury limit is 1.2 lb/TBtu heat input. LEE Testing for 30 days with a sampling period consistent with that given in section 5.2.1 of appendix A to this subpart per Method 30B at appendix A-8 to part 60 of this chapter run or Hg CEMS or sorbent trap monitoring system only.	§ 63.10000(c)(1) [G]§ 63.10000(c)(1)(vi) § 63.10005(a) § 63.10005(a)(1) § 63.10005(a)(2) § 63.10005(a)(2)(i) § 63.10005(a)(2)(ii) [G]§ 63.10005(a)(2)(iii) [G]§ 63.10005(b) § 63.10005(d)(3) § 63.10006(b)(2) [G]§ 63.10006(f)(1) [G]§ 63.10006(f)(3) § 63.10006(g) § 63.10007(a) § 63.10007(a)(1) § 63.10007(a)(2) § 63.10007(b) § 63.10007(b)-Table	§ 63.10000(d)(1) [G]§ 63.10000(d)(2) [G]§ 63.10000(d)(5) [G]§ 63.10005(b) § 63.10005(f) [G]§ 63.10010(j) § 63.10020(a) § 63.10020(b) § 63.10020(d) [G]§ 63.10032(a) [G]§ 63.10032(b) § 63.10032(c) [G]§ 63.10032(d) [G]§ 63.10032(f) § 63.10032(g) § 63.10032(h) § 63.10032(i) § 63.10033(a) § 63.10033(b)	§ 63.10000(d)(3) § 63.10005(k) § 63.10021(f) § 63.10021(g) § 63.10021(i) § 63.10030(a) § 63.10030(b) § 63.10030(d) [G]§ 63.10030(e) § 63.10030(f) § 63.10031(a) § 63.10031(a)-Table 8.1.a § 63.10031(a)-Table 8.1.b § 63.10031(a)-Table 8.1.c [G]§ 63.10031(b) [G]§ 63.10031(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.10021(e)-Table 7.6 § 63.10021(e)-Table 7.7 [G]§ 63.10021(e) [G]§ 63.10021(h) § 63.10040 § 63.9991(a)(1) § 63.9991(a)(1)-Table 3.1 § 63.9991(a)(1)-Table 3.3.a.(1) § 63.9991(a)(1)-Table 3.3.c § 63.9991(a)(1)-Table 3.3.d § 63.9991(a)(1)-Table 3.4		5.4 § 63.10007(d) § 63.10007(e)(1) [G]§ 63.10007(e)(2) § 63.10007(f) [G]§ 63.10007(f)(1) § 63.10007(f)(2) § 63.10010(a)(1) § 63.10010(b) § 63.10010(g) [G]§ 63.10010(j) § 63.10011(a) § 63.10011(c)(1) § 63.10011(e) § 63.10020(a) § 63.10020(b) § 63.10020(c) § 63.10021(a) § 63.10021(b) § 63.10021(b)-Table 7.1	§ 63.10033(c)	§ 63.10031(d) § 63.10031(e) § 63.10031(f) § 63.10031(f)(1) § 63.10031(f)(2) § 63.10031(f)(3) § 63.10031(f)(4) § 63.10031(f)(5) [G]§ 63.10031(f)(6) § 63.10031(g)
2-1	EU	63UUUUU-0001	PM	40 CFR Part 63, Subpart UUUUU	§ 63.9991(a)(1)-Table 2.1.a § 63.10000(a) § 63.10000(b) [G]§ 63.10000(c)(1)(i)(C) § 63.10000(e) § 63.10000(l) § 63.10000(m) § 63.10000(m)(1) § 63.10005(a) § 63.10005(d) § 63.10005(e) § 63.10005(f) § 63.10005(h)(1) § 63.10005(h)(1)(i) § 63.10005(j) [G]§ 63.10006(i) § 63.10007(e) § 63.10011(f)(1)	For existing coal-fired unit not low rank virgin coal, filterable PM limit is 0.03 lb/MMBtu heat input. Collect a minimum of 1 dscm per run.	§ 63.10000(c)(1) § 63.10000(c)(1)(i) § 63.10000(c)(1)(iii) § 63.10000(l) § 63.10000(m) § 63.10000(m)(1) § 63.10005(a) § 63.10005(a)(1) § 63.10005(a)(2) § 63.10005(a)(2)(i) § 63.10005(a)(2)(ii) [G]§ 63.10005(a)(2)(iii) [G]§ 63.10005(b) § 63.10005(d)(1) [G]§ 63.10005(d)(2) [G]§ 63.10005(h)(2) § 63.10006(b) § 63.10006(b)(1) [G]§ 63.10006(f)(1)	§ 63.10000(l) § 63.10000(m)(2) [G]§ 63.10005(b) § 63.10005(f) § 63.10020(a) § 63.10020(b) § 63.10020(d) [G]§ 63.10032(a) § 63.10032(c) [G]§ 63.10032(d) [G]§ 63.10032(f) § 63.10032(g) § 63.10032(h) § 63.10032(i) § 63.10033(a) § 63.10033(b) § 63.10033(c)	§ 63.10000(l) § 63.10000(m)(2) § 63.10005(k) § 63.10021(f) § 63.10021(g) § 63.10021(i) § 63.10030(a) § 63.10030(b) § 63.10030(d) [G]§ 63.10030(e) § 63.10030(f) § 63.10031(a) § 63.10031(a)-Table 8.1.a § 63.10031(a)-Table 8.1.b § 63.10031(a)-Table 8.1.c [G]§ 63.10031(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.10011(f)(2) [G]§ 63.10011(g) § 63.10021(e)-Table 7.5 § 63.10021(e)-Table 7.6 § 63.10021(e)-Table 7.7 [G]§ 63.10021(e) [G]§ 63.10021(h) § 63.10040 § 63.9991(a)(1) § 63.9991(a)(1)-Table 3.1 § 63.9991(a)(1)-Table 3.3.a.(1) § 63.9991(a)(1)-Table 3.3.d § 63.9991(a)(1)-Table 3.4		§ 63.10006(f)(2) [G]§ 63.10006(f)(3) § 63.10006(g) § 63.10006(h) § 63.10007(a) § 63.10007(a)(1) § 63.10007(a)(2) § 63.10007(b) § 63.10007(b)-Table 5.1 § 63.10007(d) § 63.10007(e)(1) [G]§ 63.10007(e)(2) § 63.10011(a) § 63.10011(d) § 63.10011(e) § 63.10020(a) § 63.10020(b) § 63.10020(c) § 63.10021(a) § 63.10021(d) § 63.10021(d)(1) § 63.10021(d)(2) § 63.10021(d)-Table 7.4		[G]§ 63.10031(c) § 63.10031(e) § 63.10031(f) § 63.10031(f)(4) § 63.10031(f)(5) [G]§ 63.10031(f)(6) § 63.10031(g)
AUXBLR	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.3 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(13)	A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of 10 million Btu per hour or greater must conduct a tune-up of the boiler or process heater annually as specified in § 63.7540. Units in either the Gas 1 or Metal Process Furnace subcategories will conduct this tune-up as a work practice for all regulated emissions.	§ 63.7510(g) § 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRP-BLR-ST	EP	R111-1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(C) § 111.111(a)(1)(E) § 111.111(a)(2)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	§ 111.111(a)(1)(D) [G]§ 111.111(a)(1)(F) § 111.111(a)(2)	§ 111.111(a)(1)(C) § 111.111(a)(1)(D)	None
GRP_ENGINES	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table 2c.6 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(f) § 63.6625(h) § 63.6625(j) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	For each existing emergency stationary SI RICE and black start stationary SI RICE with a site rating less than or equal to 500 HP, located at a major source, you must comply with the requirements as specified in Table 2c.6.a-c.	§ 63.6625(j) § 63.6640(a) § 63.6640(a)-Table 6.9.a.i § 63.6640(a)-Table 6.9.a.ii	§ 63.6625(j) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
UNIT 1	EU	60-1	NO _x	40 CFR Part 60, Subpart D	§ 60.44(b)	Except as stated in §60.44(c), (d), and (e), when different fossil fuels are burned simultaneously in any combination, the applicable standard is determined by proration using the specified formula.	§ 60.45(b)(3) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(5) [G]§ 60.46(c) [G]§ 60.46(d)(1) § 60.46(d)(5) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
UNIT 1	EU	60-1	PM	40 CFR Part 60, Subpart D	§ 60.42(a)(1)	On/after the §60.8 test, no affected facility shall emit gases containing particulate matter in excess of 43 ng/J heat input (0.10 lb/MMBtu) derived from fossil fuel or fossil fuel and wood	§ 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(2) [G]§ 60.46(d)(1) § 60.46(d)(2) [G]§ 60.46(d)(3) § 60.46(d)(6)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						residue.	§ 60.46(d)(7) ** See CAM Summary		
UNIT 1	EU	60-1	PM (Opacity)	40 CFR Part 60, Subpart D	§ 60.42(a)(2)	On/after the §60.8 test, no affected facility shall emit gases exhibiting greater than 20% opacity except for one six minute period per hour of not more than 27% opacity.	§ 60.45(a) § 60.45(c) § 60.45(c)(3) § 60.45(g) § 60.45(g)(1) § 60.46(a) § 60.46(b)(3) ** See CAM Summary	None	§ 60.45(g)
UNIT 1	EU	60-1	SO ₂	40 CFR Part 60, Subpart D	§ 60.43(b) § 60.43(c)	When different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) shall be determined by proration using the specified formula.	§ 60.45(b)(2) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(4) [G]§ 60.46(c) [G]§ 60.46(d)(1) [G]§ 60.46(d)(3) § 60.46(d)(4) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
UNIT 1	EU	60-2	NO _x	40 CFR Part 60, Subpart D	§ 60.44(a)(3)	On/after the §60.8 test, no affected facility shall emit gases containing NO _x , expressed as NO ₂ in excess of 300 ng/J heat input (0.70 lb/MMBtu) derived from solid fossil fuel or solid fossil fuel and wood residue (except lignite or a solid fossil fuel containing 25 percent, by weight, or more of coal refuse).	§ 60.45(b)(3) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(5) [G]§ 60.46(d)(1) § 60.46(d)(5) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
UNIT 1	EU	60-2	PM	40 CFR Part 60, Subpart D	§ 60.42(a)(1)	On/after the §60.8 test, no affected facility shall emit gases containing particulate	§ 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(2)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						matter in excess of 43 ng/J heat input (0.10 lb/MMBtu) derived from fossil fuel or fossil fuel and wood residue.	[G]§ 60.46(d)(1) § 60.46(d)(2) [G]§ 60.46(d)(3) § 60.46(d)(6) § 60.46(d)(7) ** See CAM Summary		
UNIT 1	EU	60-2	PM (Opacity)	40 CFR Part 60, Subpart D	§ 60.42(a)(2)	On/after the §60.8 test, no affected facility shall emit gases exhibiting greater than 20% opacity except for one six minute period per hour of not more than 27% opacity.	§ 60.45(a) § 60.45(c) § 60.45(c)(3) § 60.45(g) § 60.45(g)(1) § 60.46(a) § 60.46(b)(3) ** See CAM Summary	None	§ 60.45(g)
UNIT 1	EU	60-2	SO ₂	40 CFR Part 60, Subpart D	§ 60.43(a)(2)	On/after the §60.8 test, no affected facility shall emit gases containing SO ₂ in excess of 520 ng/J heat input (1.2 lb/MMBtu) derived from solid fossil fuel or solid fossil fuel and wood residue.	§ 60.45(b)(2) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(4) [G]§ 60.46(d)(1) [G]§ 60.46(d)(3) § 60.46(d)(4) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
UNIT 1	EU	60-3	NO _x	40 CFR Part 60, Subpart D	§ 60.44(a)(1)	On/after the §60.8 test, no affected facility shall emit gases containing NO _x , expressed as NO ₂ in excess of 86 ng/J heat input (0.20 lb/MMBtu) derived from gaseous fossil fuel.	§ 60.45(b)(3) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(5) [G]§ 60.46(d)(1) § 60.46(d)(5) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
UNIT 1	EU	60-3	PM	40 CFR Part	§ 60.42(a)(1)	On/after the §60.8 test, no	§ 60.46(a)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				60, Subpart D		affected facility shall emit gases containing particulate matter in excess of 43 ng/J heat input (0.10 lb/MMBtu) derived from fossil fuel or fossil fuel and wood residue.	§ 60.46(b)(1) [G]§ 60.46(b)(2) [G]§ 60.46(d)(1) § 60.46(d)(2) [G]§ 60.46(d)(3) § 60.46(d)(6) § 60.46(d)(7) ** See CAM Summary		
UNIT 1	EU	60-3	PM (Opacity)	40 CFR Part 60, Subpart D	§ 60.42(a)(2)	On/after the §60.8 test, no affected facility shall emit gases exhibiting greater than 20% opacity except for one six minute period per hour of not more than 27% opacity.	§ 60.45(a) § 60.45(c) § 60.45(c)(3) § 60.45(g) § 60.45(g)(1) § 60.46(a) § 60.46(b)(3) ** See CAM Summary	None	§ 60.45(g)
UNIT 2	EU	60-1	NO _x	40 CFR Part 60, Subpart D	§ 60.44(b)	Except as stated in §60.44(c), (d), and (e), when different fossil fuels are burned simultaneously in any combination, the applicable standard is determined by proration using the specified formula.	§ 60.45(b)(3) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(5) [G]§ 60.46(c) [G]§ 60.46(d)(1) § 60.46(d)(5) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
UNIT 2	EU	60-1	PM	40 CFR Part 60, Subpart D	§ 60.42(a)(1)	On/after the §60.8 test, no affected facility shall emit gases containing particulate matter in excess of 43 ng/J heat input (0.10 lb/MMBtu) derived from fossil fuel or fossil fuel and wood residue.	§ 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(2) [G]§ 60.46(d)(1) § 60.46(d)(2) [G]§ 60.46(d)(3) § 60.46(d)(6) § 60.46(d)(7) ** See CAM Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
UNIT 2	EU	60-1	PM (Opacity)	40 CFR Part 60, Subpart D	§ 60.42(a)(2)	On/after the §60.8 test, no affected facility shall emit gases exhibiting greater than 20% opacity except for one six minute period per hour of not more than 27% opacity.	§ 60.45(a) § 60.45(c) § 60.45(c)(3) § 60.45(g) § 60.45(g)(1) § 60.46(a) § 60.46(b)(3) ** See CAM Summary	None	§ 60.45(g)
UNIT 2	EU	60-1	SO ₂	40 CFR Part 60, Subpart D	§ 60.43(b) § 60.43(c)	When different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) shall be determined by proration using the specified formula.	§ 60.45(b)(2) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(4) [G]§ 60.46(c) [G]§ 60.46(d)(1) [G]§ 60.46(d)(3) § 60.46(d)(4) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
UNIT 2	EU	60-2	NO _x	40 CFR Part 60, Subpart D	§ 60.44(a)(3)	On/after the §60.8 test, no affected facility shall emit gases containing NO _x , expressed as NO ₂ in excess of 300 ng/J heat input (0.70 lb/MMBtu) derived from solid fossil fuel or solid fossil fuel and wood residue (except lignite or a solid fossil fuel containing 25 percent, by weight, or more of coal refuse).	§ 60.45(b)(3) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(5) [G]§ 60.46(d)(1) § 60.46(d)(5) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
UNIT 2	EU	60-2	PM	40 CFR Part 60, Subpart D	§ 60.42(a)(1)	On/after the §60.8 test, no affected facility shall emit gases containing particulate matter in excess of 43 ng/J heat input (0.10 lb/MMBtu) derived from fossil fuel or	§ 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(2) [G]§ 60.46(d)(1) § 60.46(d)(2) [G]§ 60.46(d)(3)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						fossil fuel and wood residue.	§ 60.46(d)(6) § 60.46(d)(7) ** See CAM Summary		
UNIT 2	EU	60-2	PM (Opacity)	40 CFR Part 60, Subpart D	§ 60.42(a)(2)	On/after the §60.8 test, no affected facility shall emit gases exhibiting greater than 20% opacity except for one six minute period per hour of not more than 27% opacity.	§ 60.45(a) § 60.45(c) § 60.45(c)(3) § 60.45(g) § 60.45(g)(1) § 60.46(a) § 60.46(b)(3) ** See CAM Summary	None	§ 60.45(g)
UNIT 2	EU	60-2	SO ₂	40 CFR Part 60, Subpart D	§ 60.43(a)(2)	On/after the §60.8 test, no affected facility shall emit gases containing SO ₂ in excess of 520 ng/J heat input (1.2 lb/MMBtu) derived from solid fossil fuel or solid fossil fuel and wood residue.	§ 60.45(b)(2) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(4) [G]§ 60.46(d)(1) [G]§ 60.46(d)(3) § 60.46(d)(4) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None
UNIT 2	EU	60-3	NO _x	40 CFR Part 60, Subpart D	§ 60.44(a)(1)	On/after the §60.8 test, no affected facility shall emit gases containing NO _x , expressed as NO ₂ in excess of 86 ng/J heat input (0.20 lb/MMBtu) derived from gaseous fossil fuel.	§ 60.45(b)(3) § 60.45(b)(4) § 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(5) [G]§ 60.46(d)(1) § 60.46(d)(5) § 60.46(d)(6) § 60.46(d)(7) ** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
UNIT 2	EU	60-3	PM	40 CFR Part 60, Subpart D	§ 60.42(a)(1)	On/after the §60.8 test, no affected facility shall emit gases containing particulate matter in excess of 43 ng/J heat input (0.10 lb/MMBtu) derived from fossil fuel or fossil fuel and wood residue.	§ 60.46(a) § 60.46(b)(1) [G]§ 60.46(b)(2) [G]§ 60.46(d)(1) § 60.46(d)(2) [G]§ 60.46(d)(3) § 60.46(d)(6) § 60.46(d)(7) ** See CAM Summary	None	None
UNIT 2	EU	60-3	PM (Opacity)	40 CFR Part 60, Subpart D	§ 60.42(a)(2)	On/after the §60.8 test, no affected facility shall emit gases exhibiting greater than 20% opacity except for one six minute period per hour of not more than 27% opacity.	§ 60.45(a) § 60.45(c) § 60.45(c)(3) § 60.45(g) § 60.45(g)(1) § 60.46(a) § 60.46(b)(3) ** See CAM Summary	None	§ 60.45(g)

Additional Monitoring Requirements

Compliance Assurance Monitoring Summary	42
Periodic Monitoring Summary	54

CAM Summary

Unit/Group/Process Information	
ID No.: UNIT 1	
Control Device ID No.: BH1	Control Device Type: Fabric filter
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-1
Pollutant: PM	Main Standard: § 60.42(a)(1)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: 20% opacity, except for one six minute period per hour of not more than 27% opacity.	
CAM Text: The COMS shall be operated in accordance with 40 CFR § 60.13.	

CAM Summary

Unit/Group/Process Information	
ID No.: UNIT 1	
Control Device ID No.: BH1	Control Device Type: Fabric filter
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-1
Pollutant: PM (Opacity)	Main Standard: § 60.42(a)(2)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: 20% opacity, except for one six minute period per hour of not more than 27% opacity.	
CAM Text: The COMS shall be operated in accordance with 40 CFR § 60.13.	

CAM Summary

Unit/Group/Process Information	
ID No.: UNIT 1	
Control Device ID No.: BH1	Control Device Type: Fabric filter
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-2
Pollutant: PM	Main Standard: § 60.42(a)(1)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: 20% opacity, except for one six minute period per hour of not more than 27% opacity.	
CAM Text: The COMS shall be operated in accordance with 40 CFR § 60.13.	

CAM Summary

Unit/Group/Process Information	
ID No.: UNIT 1	
Control Device ID No.: BH1	Control Device Type: Fabric filter
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-2
Pollutant: PM (Opacity)	Main Standard: § 60.42(a)(2)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: 20% opacity, except for one six minute period per hour of not more than 27% opacity.	
CAM Text: The COMS shall be operated in accordance with 40 CFR § 60.13.	

CAM Summary

Unit/Group/Process Information	
ID No.: UNIT 1	
Control Device ID No.: BH1	Control Device Type: Fabric filter
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-3
Pollutant: PM	Main Standard: § 60.42(a)(1)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: 20% opacity, except for one six minute period per hour of not more than 27% opacity.	
CAM Text: The COMS shall be operated in accordance with 40 CFR § 60.13.	

CAM Summary

Unit/Group/Process Information	
ID No.: UNIT 1	
Control Device ID No.: BH1	Control Device Type: Fabric filter
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-3
Pollutant: PM (Opacity)	Main Standard: § 60.42(a)(2)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: 20% opacity, except for one six minute period per hour of not more than 27% opacity.	
CAM Text: The COMS shall be operated in accordance with 40 CFR § 60.13.	

CAM Summary

Unit/Group/Process Information	
ID No.: UNIT 2	
Control Device ID No.: BH2	Control Device Type: Fabric filter
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-1
Pollutant: PM	Main Standard: § 60.42(a)(1)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: 20% opacity, except for one six minute period per hour of not more than 27% opacity.	
CAM Text: The COMS shall be operated in accordance with 40 CFR § 60.13.	

CAM Summary

Unit/Group/Process Information	
ID No.: UNIT 2	
Control Device ID No.: BH2	Control Device Type: Fabric filter
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-1
Pollutant: PM (Opacity)	Main Standard: § 60.42(a)(2)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: 20% opacity, except for one six minute period per hour of not more than 27% opacity.	
CAM Text: The COMS shall be operated in accordance with 40 CFR § 60.13.	

CAM Summary

Unit/Group/Process Information	
ID No.: UNIT 2	
Control Device ID No.: BH2	Control Device Type: Fabric filter
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-2
Pollutant: PM	Main Standard: § 60.42(a)(1)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: 20% opacity, except for one six minute period per hour of not more than 27% opacity.	
CAM Text: The COMS shall be operated in accordance with 40 CFR § 60.13.	

CAM Summary

Unit/Group/Process Information	
ID No.: UNIT 2	
Control Device ID No.: BH2	Control Device Type: Fabric filter
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-2
Pollutant: PM (Opacity)	Main Standard: § 60.42(a)(2)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: 20% opacity, except for one six minute period per hour of not more than 27% opacity.	
CAM Text: The COMS shall be operated in accordance with 40 CFR § 60.13.	

CAM Summary

Unit/Group/Process Information	
ID No.: UNIT 2	
Control Device ID No.: BH2	Control Device Type: Fabric filter
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-3
Pollutant: PM	Main Standard: § 60.42(a)(1)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: 20% opacity, except for one six minute period per hour of not more than 27% opacity.	
CAM Text: The COMS shall be operated in accordance with 40 CFR § 60.13.	

CAM Summary

Unit/Group/Process Information	
ID No.: UNIT 2	
Control Device ID No.: BH2	Control Device Type: Fabric filter
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-3
Pollutant: PM (Opacity)	Main Standard: § 60.42(a)(2)
Monitoring Information	
Indicator: Opacity	
Minimum Frequency: six times per minute	
Averaging Period: six-minute	
Deviation Limit: 20% opacity, except for one six minute period per hour of not more than 27% opacity.	
CAM Text: The COMS shall be operated in accordance with 40 CFR § 60.13.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: UNIT 1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-1
Pollutant: NO _x	Main Standard: § 60.44(b)
Monitoring Information	
Indicator: NO _x Concentration	
Minimum Frequency: four times per hour	
Averaging Period: 3 hours	
Deviation Limit: When multiple fuels are burned simultaneously, maximum NO _x concentration is determined by proration using the formula in 60.44(b).	
Periodic Monitoring Text: Measure and record the concentration of nitrogen oxide in the exhaust stream with a continuous emission monitoring system (CEMS). In addition, monitor the oxygen or carbon dioxide content of the flue gas with a CEMS. The CEMS shall be operated in accordance with the monitoring requirements of 40 CFR § 60.13 and the performance specifications of 40 CFR Part 60, Appendix B.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: UNIT 1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-1
Pollutant: SO ₂	Main Standard: § 60.43(b)
Monitoring Information	
Indicator: SO ₂ Concentration	
Minimum Frequency: four times per hour	
Averaging Period: 3 hours	
Deviation Limit: 1.2 LB SO ₂ /MMBtu	
Periodic Monitoring Text: Measure and record the concentration of SO₂ in the exhaust stream of the control device with a continuous emission monitoring system (CEMS). In addition, measure and record the oxygen or carbon dioxide content of the flue gas with a CEMS. The CEMS shall be operated in accordance with 40 CFR § 60.13 and the Performance Specifications of 40 CFR Part 60, Appendix B. Any monitoring data above the deviation limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: UNIT 1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-2
Pollutant: NO _x	Main Standard: § 60.44(a)(3)
Monitoring Information	
Indicator: NO _x Concentration	
Minimum Frequency: Four times per hour	
Averaging Period: 3 hours	
Deviation Limit: NO _x limit is 300 ng/J heat input (0.70 lb/MMBtu) when burning solid fossil fuel.	
Periodic Monitoring Text: Measure and record the concentration of nitrogen oxide in the exhaust stream with a continuous emission monitoring system (CEMS). In addition, monitor the oxygen or carbon dioxide content of the flue gas with a CEMS. The CEMS shall be operated in accordance with the monitoring requirements of 40 CFR § 60.13 and the performance specifications of 40 CFR Part 60, Appendix B.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: UNIT 1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-2
Pollutant: SO ₂	Main Standard: § 60.43(a)(2)
Monitoring Information	
Indicator: SO ₂ Concentration	
Minimum Frequency: four times per hour	
Averaging Period: 3 hours	
Deviation Limit: 1.2 LB SO ₂ /MMBtu	
Periodic Monitoring Text: Measure and record the concentration of SO₂ in the exhaust stream of the control device with a continuous emission monitoring system (CEMS). In addition, measure and record the oxygen or carbon dioxide content of the flue gas with a CEMS. The CEMS shall be operated in accordance with 40 CFR § 60.13 and the Performance Specifications of 40 CFR Part 60, Appendix B. Any monitoring data above the deviation limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: UNIT 1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-3
Pollutant: NO _x	Main Standard: § 60.44(a)(1)
Monitoring Information	
Indicator: NO _x Concentration	
Minimum Frequency: four times per hour	
Averaging Period: 3 hours	
Deviation Limit: When multiple fuels are burned simultaneously, maximum NO _x concentration is determined by proration using the formula in 60.44(b).	
Periodic Monitoring Text: Measure and record the concentration of nitrogen oxide in the exhaust stream with a continuous emission monitoring system (CEMS). In addition, monitor the oxygen or carbon dioxide content of the flue gas with a CEMS. The CEMS shall be operated in accordance with the monitoring requirements of 40 CFR § 60.13 and the performance specifications of 40 CFR Part 60, Appendix B.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: UNIT 2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-1
Pollutant: NO _x	Main Standard: § 60.44(b)
Monitoring Information	
Indicator: NO _x Concentration	
Minimum Frequency: four times per hour	
Averaging Period: 3 hours	
Deviation Limit: When multiple fuels are burned simultaneously, maximum NO _x concentration is determined by proration using the formula in 60.44(b).	
Periodic Monitoring Text: Measure and record the concentration of nitrogen oxide in the exhaust stream with a continuous emission monitoring system (CEMS). In addition, monitor the oxygen or carbon dioxide content of the flue gas with a CEMS. The CEMS shall be operated in accordance with the monitoring requirements of 40 CFR § 60.13 and the performance specifications of 40 CFR Part 60, Appendix B.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: UNIT 2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-1
Pollutant: SO ₂	Main Standard: § 60.43(b)
Monitoring Information	
Indicator: SO ₂ Concentration	
Minimum Frequency: four times per hour	
Averaging Period: 3 hours	
Deviation Limit: 1.2 LB SO ₂ /MMBtu	
Periodic Monitoring Text: Measure and record the concentration of SO₂ in the exhaust stream of the control device with a continuous emission monitoring system (CEMS). In addition, measure and record the oxygen or carbon dioxide content of the flue gas with a CEMS. The CEMS shall be operated in accordance with 40 CFR § 60.13 and the Performance Specifications of 40 CFR Part 60, Appendix B. Any monitoring data above the deviation limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: UNIT 2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-2
Pollutant: NO _x	Main Standard: § 60.44(a)(3)
Monitoring Information	
Indicator: NO _x Concentration	
Minimum Frequency: Four times per hour	
Averaging Period: 3 hours	
Deviation Limit: NO _x limit is 300 ng/J heat input (0.70 lb/MMBtu) when burning solid fossil fuel.	
Periodic Monitoring Text: Measure and record the concentration of nitrogen oxide in the exhaust stream with a continuous emission monitoring system (CEMS). In addition, monitor the oxygen or carbon dioxide content of the flue gas with a CEMS. The CEMS shall be operated in accordance with the monitoring requirements of 40 CFR § 60.13 and the performance specifications of 40 CFR Part 60, Appendix B.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: UNIT 2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-2
Pollutant: SO ₂	Main Standard: § 60.43(a)(2)
Monitoring Information	
Indicator: SO ₂ Concentration	
Minimum Frequency: four times per hour	
Averaging Period: 3 hours	
Deviation Limit: 1.2 LB SO ₂ /MMBtu	
Periodic Monitoring Text: Measure and record the concentration of SO₂ in the exhaust stream of the control device with a continuous emission monitoring system (CEMS). In addition, measure and record the oxygen or carbon dioxide content of the flue gas with a CEMS. The CEMS shall be operated in accordance with 40 CFR § 60.13 and the Performance Specifications of 40 CFR Part 60, Appendix B. Any monitoring data above the deviation limit shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: UNIT 2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 40 CFR Part 60, Subpart D	SOP Index No.: 60-3
Pollutant: NO _x	Main Standard: § 60.44(a)(1)
Monitoring Information	
Indicator: NO _x Concentration	
Minimum Frequency: four times per hour	
Averaging Period: 3 hours	
Deviation Limit: When multiple fuels are burned simultaneously, maximum NO _x concentration is determined by proration using the formula in 60.44(b).	
Periodic Monitoring Text: Measure and record the concentration of nitrogen oxide in the exhaust stream with a continuous emission monitoring system (CEMS). In addition, monitor the oxygen or carbon dioxide content of the flue gas with a CEMS. The CEMS shall be operated in accordance with the monitoring requirements of 40 CFR § 60.13 and the performance specifications of 40 CFR Part 60, Appendix B.	

Permit Shield

Permit Shield 66

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
AUXBLR	N/A	40 CFR Part 60, Subpart Dc	Unit is not a small commercial boiler.
UNIT 1	N/A	40 CFR Part 60, Subpart Da	Construction, modification, or reconstruction commenced before September 18, 1978.
UNIT 1	N/A	40 CFR Part 60, Subpart Db	Unit is not a commercial boiler.
UNIT 1	N/A	40 CFR Part 60, Subpart Dc	Unit is not a small commercial boiler.
UNIT 2	N/A	40 CFR Part 60, Subpart Da	Construction, modification, or reconstruction commenced before September 18, 1978.
UNIT 2	N/A	40 CFR Part 60, Subpart Db	Unit is not a commercial boiler.
UNIT 2	N/A	40 CFR Part 60, Subpart Dc	Unit is not a small commercial boiler.

New Source Review Authorization References

New Source Review Authorization References	67
New Source Review Authorization References by Emission Unit	68

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Prevention of Significant Deterioration (PSD) Permits	
PSD Permit No.: PSDTX50M2	Issuance Date: 02/04/2022
Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 6029	Issuance Date: 12/17/2020
Authorization No.: 6030	Issuance Date: 02/04/2022
Authorization No.: 6103	Issuance Date: 02/04/2022
Authorization No.: 113913	Issuance Date: 05/17/2023
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 8	Version No./Date: 06/07/1996
Number: 14	Version No./Date: 03/15/1985
Number: 51	Version No./Date: 06/07/1996
Number: 52	Version No./Date: 03/15/1985
Number: 56	Version No./Date: 03/15/1985
Number: 70	Version No./Date: 06/07/1996
Number: 77	Version No./Date: 03/15/1985
Number: 84	Version No./Date: 09/23/1982
Number: 106.102	Version No./Date: 09/04/2000
Number: 106.144	Version No./Date: 09/04/2000
Number: 106.262	Version No./Date: 11/01/2003
Number: 106.355	Version No./Date: 09/04/2000
Number: 106.412	Version No./Date: 09/04/2000
Number: 106.477	Version No./Date: 09/04/2000
Number: 106.511	Version No./Date: 09/04/2000
Number: 106.532	Version No./Date: 09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
1-1	UNIT 1 BOILER	6029, PSDTX50M2
1-1	UNIT 1 BOILER STACK	6029, PSDTX50M2
2-1	UNIT 2 BOILER STACK	6030, PSDTX50M2
2-1	UNIT 2-1 BOILER	6030, PSDTX50M2
AUXBLR	AUXILIARY BOILER (COMFORT HEAT)	106.102/09/04/2000
DFP	DIESEL FIRE PUMP	106.511/09/04/2000
EG 2A	EMER. GEN. "2A"	106.511/09/04/2000
EG 2B	EMER. GEN. "2A"	106.511/09/04/2000
UNIT 1	UNIT 1 BOILER	6029, PSDTX50M2
UNIT 2	UNIT 2 BOILER	6030, PSDTX50M2

**This column may include Permit by Rule (PBR) numbers and version dates, PBR Registration numbers in brackets, Standard Permit Registration numbers, Minor NSR permit numbers, and Major NSR permit numbers.

Appendix A

Acronym List 70

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
SIP	state implementation plan
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound

Appendix B

Major NSR Summary Table 72

Major NSR Summary Table

Permit Numbers 6029 and PSDTX50M2					Issuance Date: December 17, 2020		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
1-1 (7)	Boiler Generator No.1 5750 MMBtu/hr	NO _x	2,012	5,492	2, 7, 14, 15	2, 7, 14, 15, 20, 21	2, 15
		CO (6)	1,955	8,296	7, 16	7, 16, 20, 21	16
		CO (MSS)	4,025	-	7, 8, 9, 10, 12	7, 8, 9, 10, 20, 21	
		VOC (6)	182	647	7, 17	7, 20, 21	
		PM ₁₀	509	1,793	2, 7, 14, 18	2, 7, 18, 20, 21	2, 18
		SO ₂	6,108	21,520	2, 7, 14, 15	2, 7, 14, 15, 20, 21	2, 15
GAS-VNT-1 (5)	Gas Source Venting	VOC	31	0.42		19, 20, 21	

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
 NO_x - total oxides of nitrogen
 SO₂ - sulfur dioxide
 PM₁₀ - total particulate matter equal to or less than 10 microns in diameter
 CO - carbon monoxide
 MSS - maintenance, startup, shutdown
- (4) Compliance with annual emission limits (tons per year) is based on a 12-month rolling period.
- (5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.
- (6) The CO and VOC emission rates are calculated based on Environmental Protection Agency, AP-42, Compilation of Air Pollution Factors, Volume 1, Chapter 1.
- (7) NO_x, VOC, PM₁₀, and SO₂ MSS emissions are included in the lbs/hr. The annual emission rates include the MSS annual emissions.

Major NSR Summary Table

Permit Numbers 6030 and PSDTX50M2					Issuance Date: February 17, 2022		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hr	TPY (4)	Special Condition/Application Information	Special Condition/Application Information	Special Condition/Application Information
2-1	Boiler Generator No. 2 5750 MMBtu/hr (5) (6)	NO _x	2,013.00	6,296.00	1, 10, 11	1, 10, 11	1
		CO	2,013.00	6,296.00	5, 10, 11	5, 10, 11	
		SO ₂	6,108.30	26,754.00	1, 10, 11	1, 10, 11	1
		VOC	90.60	397.00	6, 10, 11	6, 10, 11	
		PM	508.80	2,228.50	1, 3, 10, 11	1, 3, 10, 11	1, 3
MSS-FUG2	MSS Fugitives, Unit 2	VOC	75.00	0.85	10, 11	10, 11	10, 11
		PM	1.41	0.01			
		PM ₁₀	0.67	0.01			
		PM _{2.5}	0.10	0.01			
		NO _x	0.01	0.01			
		SO ₂	0.01	0.01			

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
 NO_x - total oxides of nitrogen
 SO₂ - sulfur dioxide
 PM - total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented
 PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented
 PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter
 CO - carbon monoxide
- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.

- (5) PSDTX50M2 also authorizes emissions from Boiler Generator No. 1 (EPN 1-1) in Permit No. 6029. **(2/12)**
- (6) The pound per hour and ton per year emission limit specified in the MAERT for this facility includes emissions from the facility during both normal operations and planned MSS activities. **(2/12)**

Jon Niermann, *Chairman*
Emily Lindley, *Commissioner*
Bobby Janecka, *Commissioner*
Toby Baker, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

December 17, 2020

MR DAVID LOW
GENERAL MANAGER POWER GENERATION
SOUTHWESTERN PUBLIC SERVICE COMPANY
790 S BUCHANAN ST
AMARILLO TX 79101-2510

Re: Permit Renewal
Permit Number: 6029
Expiration Date: December 17, 2030
Southwestern Public Service Company
Tolk Station Power Plant
Earth, Lamb County
Regulated Entity Number: RN100224534
Customer Reference Number: CN601481336
Associated Permit Number: PSDTX50M2

Dear Mr. Low:

Southwestern Public Service Company has requested to renew Permit Number 6029. This letter serves as notice that your application for the above-referenced permit is technically complete as of December 4, 2020.

In accordance with Title 30 Texas Administrative Code Section 116.314(a), Permit Number 6029 is hereby renewed. Since you certified there were no changes to your existing permit, it is renewed as written and will be in effect for ten years from the date this renewal was issued. Please attach this letter, including the attachment regarding referenced authorizations, and new general conditions to your permit.

Mr. David Low
Page 2
December 17, 2020

Re: Permit Number: 6029

If you need further information or have any questions, please contact Mr. Michael Gembarowski at (512) 239-1281 or write to the Texas Commission on Environmental Quality, Office of Air, Air Permits Division, MC-163, P.O. Box 13087, Austin, Texas 78711-3087.

Sincerely,

A handwritten signature in black ink, appearing to read 'Samuel Short', followed by a long horizontal line extending to the right.

Samuel Short, Deputy Director
Air Permits Division
Office of Air
Texas Commission on Environmental Quality

Enclosure

cc: Air Section Manager, Region 2 - Lubbock
Air Permits Section Chief, New Source Review Section (6PD-R), U.S. Environmental Protection
Agency, Region 6, Dallas

Project Number: 320417

Permit No. 6029 – Authorizations Referenced on December 17, 2020

This list includes authorizations referenced with the renewal of this permit. It is not intended to be all-inclusive and can be altered at the site without modification to the permit.

Facility/Change	Authorization	Registration Number
Storage silo and distribution system for the storage and injection of activated carbon for mercury control (EPNs AS-1, 1-1, and 2-1).	PCP Standard Permit	113913

Texas Commission on Environmental Quality Air Quality Permit

A Permit Is Hereby Issued To
Southwestern Public Service Company
Authorizing the Continued Operation of
Tolk Station Power Plant
Located at Earth, Lamb County, Texas
Latitude 33° 31' 27" Longitude -101° 44' 23"

Permit: 6029 and PSDTX50M2

Issuance Date: December 17, 2020

Expiration Date: December 17, 2030



For the Commission

1. **Facilities** covered by this permit shall be constructed and operated as specified in the application for the permit. All representations regarding construction plans and operation procedures contained in the permit application shall be conditions upon which the permit is issued. Variations from these representations shall be unlawful unless the permit holder first makes application to the Texas Commission on Environmental Quality (commission) Executive Director to amend this permit in that regard and such amendment is approved. [Title 30 Texas Administrative Code (TAC) Section 116.116 (30 TAC § 116.116)] ¹
2. **Voiding of Permit.** A permit or permit amendment is automatically void if the holder fails to begin construction within 18 months of the date of issuance, discontinues construction for more than 18 months prior to completion, or fails to complete construction within a reasonable time. Upon request, the executive director may grant an 18-month extension. Before the extension is granted the permit may be subject to revision based on best available control technology, lowest achievable emission rate, and netting or offsets as applicable. One additional extension of up to 18 months may be granted if the permit holder demonstrates that emissions from the facility will comply with all rules and regulations of the commission, the intent of the Texas Clean Air Act (TCAA), including protection of the public's health and physical property; and (b)(1) the permit holder is a party to litigation not of the permit holder's initiation regarding the issuance of the permit; or (b)(2) the permit holder has spent, or committed to spend, at least 10 percent of the estimated total cost of the project up to a maximum of \$5 million. A permit holder granted an extension under subsection (b)(1) of this section may receive one subsequent extension if the permit holder meets the conditions of subsection (b)(2) of this section. [30 TAC § 116.120]
3. **Construction Progress.** Start of construction, construction interruptions exceeding 45 days, and completion of construction shall be reported to the appropriate regional office of the commission not later than 15 working days after occurrence of the event. [30 TAC § 116.115(b)(2)(A)]
4. **Start-up Notification.** The appropriate air program regional office shall be notified prior to the commencement of operations of the facilities authorized by the permit in such a manner that a representative of the commission may be present. The permit holder shall provide a separate notification for the commencement of operations for each unit of phased construction, which may involve a series of units commencing operations at different times. Prior to operation of the facilities authorized by the permit, the permit holder shall identify the source or sources of allowances to be utilized for compliance with Chapter 101, Subchapter H, Division 3 of this title (relating to Mass Emissions Cap and Trade Program). [30 TAC § 116.115(b)(2)(B)]
5. **Sampling Requirements.** If sampling is required, the permit holder shall contact the commission's Office of Compliance and Enforcement prior to sampling to obtain the proper data forms and procedures. All sampling and testing procedures must be approved by the executive director and coordinated with the regional representatives of the commission. The permit holder is also responsible for providing sampling facilities and conducting the sampling operations or contracting with an independent sampling consultant. [30 TAC § 116.115(b)(2)(C)]
6. **Equivalency of Methods.** The permit holder must demonstrate or otherwise justify the equivalency of emission control methods, sampling or other emission testing methods, and monitoring methods proposed as alternatives to methods indicated in the conditions of the permit. Alternative methods shall be applied for in writing and must be reviewed and approved by the executive director prior to their use in fulfilling any requirements of the permit. [30 TAC § 116.115(b)(2)(D)]
7. **Recordkeeping.** The permit holder shall maintain a copy of the permit along with records containing the information and data sufficient to demonstrate compliance with the permit, including production records and operating hours;

keep all required records in a file at the plant site. If, however, the facility normally operates unattended, records shall be maintained at the nearest staffed location within Texas specified in the application; make the records available at the request of personnel from the commission or any air pollution control program having jurisdiction in a timely manner; comply with any additional recordkeeping requirements specified in special conditions in the permit; and retain information in the file for at least two years following the date that the information or data is obtained. [30 TAC § 116.115(b)(2)(E)]

8. **Maximum Allowable Emission Rates.** The total emissions of air contaminants from any of the sources of emissions must not exceed the values stated on the table attached to the permit entitled "Emission Sources-- Maximum Allowable Emission Rates." [30 TAC § 116.115(b)(2)(F)]¹
9. **Maintenance of Emission Control.** The permitted facilities shall not be operated unless all air pollution emission capture and abatement equipment is maintained in good working order and operating properly during normal facility operations. The permit holder shall provide notification in accordance with 30 TAC §101.201, 101.211, and 101.221 of this title (relating to Emissions Event Reporting and Recordkeeping Requirements; Scheduled Maintenance, Startup, and Shutdown Reporting and Recordkeeping Requirements; and Operational Requirements). [30 TAC § 116.115(b)(2)(G)]
10. **Compliance with Rules.** Acceptance of a permit by an applicant constitutes an acknowledgment and agreement that the permit holder will comply with all rules and orders of the commission issued in conformity with the TCAA and the conditions precedent to the granting of the permit. If more than one state or federal rule or regulation or permit condition is applicable, the most stringent limit or condition shall govern and be the standard by which compliance shall be demonstrated. Acceptance includes consent to the entrance of commission employees and agents into the permitted premises at reasonable times to investigate conditions relating to the emission or concentration of air contaminants, including compliance with the permit. [30 TAC § 116.115(b)(2)(H)]
11. **This** permit may not be transferred, assigned, or conveyed by the holder except as provided by rule. [30 TAC § 116.110(e)]
12. **There** may be additional special conditions attached to a permit upon issuance or modification of the permit. Such conditions in a permit may be more restrictive than the requirements of Title 30 of the Texas Administrative Code. [30 TAC § 116.115(c)]
13. **Emissions** from this facility must not cause or contribute to "air pollution" as defined in Texas Health and Safety Code (THSC) §382.003(3) or violate THSC § 382.085. If the executive director determines that such a condition or violation occurs, the holder shall implement additional abatement measures as necessary to control or prevent the condition or violation.
14. **The** permit holder shall comply with all the requirements of this permit. Emissions that exceed the limits of this permit are not authorized and are violations of this permit.¹

¹ Please be advised that the requirements of this provision of the general conditions may not be applicable to greenhouse gas emissions.

Common Acronyms in Air Permits

°C = Temperature in degrees Celsius	GLCmax = maximum (predicted) ground-level concentration
°F = Temperature in degrees Fahrenheit	gpm = gallon per minute
°K = Temperature in degrees Kelvin	gr/1000scf = grain per 1000 standard cubic feet
µg = microgram	gr/dscf = grain per dry standard cubic feet
µg/m ³ = microgram per cubic meter	H ₂ CO = formaldehyde
acfm = actual cubic feet per minute	H ₂ S = hydrogen sulfide
AMOC = alternate means of control	H ₂ SO ₄ = sulfuric acid
AOS = alternative operating scenario	HAP = hazardous air pollutant as listed in § 112(b) of the Federal Clean Air Act or Title 40 Code of Federal Regulations Part 63, Subpart C
AP-42 = Air Pollutant Emission Factors, 5th edition	HC = hydrocarbons
APD = Air Permits Division	HCl = hydrochloric acid, hydrogen chloride
API = American Petroleum Institute	Hg = mercury
APWL = air pollutant watch list	HGB = Houston/Galveston/Brazoria
BPA = Beaumont/ Port Arthur	hp = horsepower
BACT = best available control technology	hr = hour
BAE = baseline actual emissions	IFR = internal floating roof tank
bbl = barrel	in H ₂ O = inches of water
bbl/day = barrel per day	in Hg = inches of mercury
bhp = brake horsepower	IR = infrared
BMP = best management practices	ISC3 = Industrial Source Complex, a dispersion model
Btu = British thermal unit	ISCST3 = Industrial Source Complex Short-Term, a dispersion model
Btu/scf = British thermal unit per standard cubic foot or feet	K = Kelvin; extension of the degree Celsius scaled-down to absolute zero
CAA = Clean Air Act	LACT = lease automatic custody transfer
CAM = compliance-assurance monitoring	LAER = lowest achievable emission rate
CEMS = continuous emissions monitoring systems	lb = pound
cfm = cubic feet (per) minute	hp = horsepower
CFR = Code of Federal Regulations	hr = hour lb/day = pound per day
CN = customer ID number	lb/hr = pound per hour
CNG = compressed natural gas	lb/MMBtu = pound per million British thermal units
CO = carbon monoxide	LDAR = Leak Detection and Repair (Requirements)
COMS = continuous opacity monitoring system	LNG = liquefied natural gas
CPMS = continuous parametric monitoring system	LPG = liquefied petroleum gas
DFW = Dallas/ Fort Worth (Metroplex)	LT/D = long ton per day
DE = destruction efficiency	m = meter
DRE = destruction and removal efficiency	m ³ = cubic meter
dscf = dry standard cubic foot or feet	m/sec = meters per second
dscfm = dry standard cubic foot or feet per minute	MACT = maximum achievable control technology
ED = (TCEQ) Executive Director	MAERT = Maximum Allowable Emission Rate Table
EF = emissions factor	MERA = Modeling and Effects Review Applicability
EFR = external floating roof tank	mg = milligram
EGU = electric generating unit	mg/g = milligram per gram
EI = Emissions Inventory	mL = milliliter
ELP = El Paso	MMBtu = million British thermal units
EPA = (United States) Environmental Protection Agency	MMBtu/hr = million British thermal units per hour
EPN = emission point number	MSDS = material safety data sheet
ESL = effects screening level	MSS = maintenance, startup, and shutdown
ESP = electrostatic precipitator	MW = megawatt
FCAA = Federal Clean Air Act	NAAQS = National Ambient Air Quality Standards
FCCU = fluid catalytic cracking unit	NESHAP = National Emission Standards for Hazardous Air Pollutants
FID = flame ionization detector	NGL = natural gas liquids
FIN = facility identification number	NNSR = nonattainment new source review
ft = foot or feet	NO _x = total oxides of nitrogen
ft/sec = foot or feet per second	
g = gram	
gal/wk = gallon per week	
gal/yr = gallon per year	
GLC = ground level concentration	

NSPS = New Source Performance Standards
 PAL = plant-wide applicability limit
 PBR = Permit(s) by Rule
 PCP = pollution control project
 PEMS = predictive emission monitoring system
 PID = photo ionization detector
 PM = periodic monitoring
 PM = total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented
 PM_{2.5} = particulate matter equal to or less than 2.5 microns in diameter
 PM₁₀ = total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented
 POC = products of combustion
 ppb = parts per billion
 ppm = parts per million
 ppmv = parts per million (by) volume
 psia = pounds (per) square inch, absolute
 psig = pounds (per) square inch, gage
 PTE = potential to emit
 RA = relative accuracy
 RATA = relative accuracy test audit
 RM = reference method
 RVP = Reid vapor pressure
 scf = standard cubic foot or feet
 scfm = standard cubic foot or feet (per) minute
 SCR = selective catalytic reduction
 SIL = significant impact levels
 SNCR = selective non-catalytic reduction
 SO₂ = sulfur dioxide
 SOCM = synthetic organic chemical manufacturing industry
 SRU = sulfur recovery unit
 TAC = Texas Administrative Code
 TCAA = Texas Clean Air Act
 TCEQ = Texas Commission on Environmental Quality
 TD = Toxicology Division
 TLV = threshold limit value
 TMDL = total maximum daily load
 tpd = tons per day
 tpy = tons per year
 TVP = true vapor pressure
 VOC = volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
 VRU = vapor recovery unit or system

Special Conditions

Permit Numbers 6029 and PSDTX50M2

1. This permit covers only those sources of emissions listed in the attached table entitled "Emission Sources - Maximum Allowable Emissions Rates," maintenance activities listed in Attachment A [Inherently Low Emitters (ILEs)], Attachment B [non-ILE maintenance activities (non-ILEs)], startup, and shutdown activities. Those sources are limited to the emissions limits and other conditions specified in that attached table.

Federal Applicability

2. This facility shall comply with applicable requirements of the U.S. Environmental Protection Agency (EPA) regulations on Standards of Performance for New Stationary Sources, Title 40 Code of Federal Regulations Part 60 (40 CFR Part 60):

A. Subpart A: General Conditions.

B. Subpart D: Standards of Performance for Fossil-Fuel-Fired Steam Generators.

If any condition of this permit is more stringent than the regulations so incorporated, then for the purposes of complying with this permit, the permit shall govern and be the standard by which compliance shall be demonstrated.

Emission Standards

3. The emissions of carbon monoxide (CO) from the Boiler (Emission Point No. [EPN] 1-1) shall not exceed 0.34 pound per million British thermal units (lb/MMBtu) on a rolling 30-day average.
4. Opacity of emissions from the boiler (EPN 1-1) shall not exceed 20 percent averaged over a six minute period, except as described in Title 30 Texas Administrative Code (30 TAC) § 111.111(a)(1)(E) or 40 CFR § 60.42(a)(2).

Operational Limitations

5. The Boiler (EPN 1-1) shall be limited to a maximum heat input of 5,750 million British thermal units per hour (MMBtu/hr), averaged over a calendar month, and based on the higher heating value (HHV) of the fuel fired.
6. Plant roads shall be paved and cleaned, oiled, or sprinkled with water and/or chemicals as necessary to control the emissions of dust to the minimum level possible under existing conditions.

Fuel Specifications

7. Fuel shall be limited to the following:
 - A. Low sulfur western coal and/or equivalent coal with properties that will ensure compliance with the emission rates specified in the maximum allowable emission rates table (MAERT).
 - B. Pipeline-quality natural gas containing no more than 5 grains sulfur/100 dry standard cubic feet.

Maintenance, Start-up, and Shutdown

8. The emissions from maintenance, startup, and shutdown (MSS) activities are reflected in the MAERT. The emissions will be minimized by the following:
 - A. Facility and air pollution control equipment will be operated in a manner consistent with good practices for minimizing emissions.
 - B. The frequency and duration of MSS activities will be minimized and the applicable emission monitoring systems will be kept in operation.
 - C. Coal shall not be fired during startups unless the baghouse is online.
9. A planned startup is defined as the period that begins when the Forced Draft (FD) fans are turned on and ends when 200 megawatts (MW) of electrical output is achieved. **(1/12)**
 - A. Startup shall not exceed 48 hours after fuel firing has commenced, except as allowed in Special Condition No. 9B.
 - B. An extended startup is defined as a startup that is greater than 48 hours after fuel firing has commenced. Five extended startups are authorized per year and all extended startups combined shall not exceed 600 hours per year (hr/yr).
10. Shutdown is defined as the period that begins with the reduction of fuel flow to the boiler below the level necessary to maintain 20 MW and ends when the unit is no longer receiving fuel. A shutdown shall not exceed 120 minutes.
11. Maintenance activities authorized in this permit are identified in Attachment A and Attachment B.
12. Emissions from planned MSS activities (listed on Attachments A and B) shall be determined by use of any of following:
 - A. Use of a continuous emission monitoring system (CEMS) or predictive emissions monitoring system (PEMS).
 - B. Use of the emission factor(s), facility-specific parameter(s), and/or engineering knowledge of the facility operations.
 - C. Use of emissions data measured (by a CEMS or during emissions testing) during the same type of planned MSS activity occurring at or on an identical or similar facility, and correlation of that data with the facility's relevant operating parameters, including, but not limited to, electric load, temperature, fuel input, and fuel sulfur content.
 - D. Use of emissions testing data collected during a planned MSS activity occurring at or on the facility, and correlation of that data with the facility's relevant operating parameters, including, but not limited to, electric load, temperature, fuel input, and fuel sulfur content.
13. All maintenance activities that are not listed on Attachment A or B and meet the requirements of 30 TAC § 106.263, Routine MSS of Facilities, and Temporary Maintenance Facilities, are authorized.

Initial Demonstrations of Compliance

14. Initial demonstration of compliance testing was completed in 1983.

Continuous Demonstration of Compliance

15. The holder of this permit shall install, calibrate, maintain, and operates a CEMS to measure and record the concentrations of NO_x, SO₂, and diluent gases (oxygen or carbon dioxide) from the Boiler (EPN 1-1).
 - A. The CEMS shall meet the design and performance specification, pass the field tests, the installation requirements, applicable quality-assurance requirements, data analysis, and reporting requirements specified in the applicable Performance Specification in 40 CFR Part 75, Appendix F, or an acceptable alternative.
 - B. All monitoring and quality-assurance data shall be maintained by the source for a period of five years and shall be made available to TCEQ Executive Director or designated representative upon request.

16. The permit holder shall install, calibrate, and maintain a continuous emission monitoring system (CEMS) to measure and record the in-stack concentration of CO from the boiler stack (EPN 1-1).
(09/20)
 - A. The CEMS shall meet the design and performance specifications, pass the field tests, and meet the installation requirements and the data analysis and reporting requirements specified in the applicable Performance Specification Nos. 4 through 4B, 40 CFR Part 60, Appendix B.
 - B. The permit holder shall assure that the CEMS meets the applicable quality-assurance requirements specified in 40 CFR Part 60, Appendix F, Procedure 1. Relative accuracy exceedances, as specified in 40 CFR Part 60, Appendix F, 5.2.3 and any CEMS downtime shall be reported to the appropriate TCEQ Regional Manager, and necessary corrective action shall be taken. Supplemental stack concentration measurements may be required at the discretion of the appropriate TCEQ Regional Manager.

Each monitor shall be quality-assured at least quarterly using Cylinder Gas Audits (CGA) in accordance with 40 CFR Part 60, Appendix F, Procedure 1, Section 5.1.2, with the following exception: a relative accuracy test audit (RATA) is not required once every four quarters (i.e., four successive quarterly CGA may be conducted). As an alternative to CGA, quarterly linearities may be run according to the requirements of 40 CFR §75, Appendix B.

All CGA or linearity exceedances of ± 15 percent accuracy indicate the CEMS is out of control and necessary corrective action shall be taken to eliminate the problem.
 - C. The monitoring data shall be reduced to hourly average concentrations at least once every day, using a minimum of four equally-spaced data points from each one-hour period. The individual average concentrations shall be reduced to units of lbs/hr at least once every day.
 - D. The monitoring data and quality-assurance data shall be maintained by the source. The data from the CEMS may, at the discretion of the TCEQ, be used to determine compliance with the conditions of this permit.
 - E. The appropriate TCEQ Regional Office shall be notified at least 30 days prior to any RATA in order to provide them the opportunity to observe the testing.
 - F. This requirement shall become effective within 180 days of issuance of the permit with this condition.

17. The company shall perform periodic stack sampling for VOC emissions from EPN 1- 1 and it shall be used to demonstrate continuous compliance with the lb/hr emission limits on the MAERT and shall meet the following specifications: **(09/20)**
 - A. Stack sampling shall be performed once every four QA operating quarters (as defined in 40 CFR §72.2) during periods of normal operation, except that if, after two successive stack sampling events, the average of the two stack sampling results for VOC is less than 70 percent of the lb/hr emission limit found in the MAERT, then compliance stack sampling shall be conducted once every twelve QA operating quarters, subject to continued results below 70 percent of the lb/hr emission limit.
 - B. Ongoing compliance with the VOC tons per year emission rates in the MAERT shall be demonstrated by calculating rolling 12-month annual emissions from an emission factor (lb/MMBtu) obtained from the sampling required by this special condition and the monthly total heat input from fuel combustion.
 - C. Ongoing compliance with the VOC pounds per hour emission rates in the MAERT shall be demonstrated hourly emissions from an emission factor (lb/MMBtu) obtained from the sampling required by this special condition and the hourly heat input measured by the 40 CFR Part 75 CEMS system.
 - D. The first test shall occur within 12 calendar months of issuance of the permit with this condition.
18. The holder of this permit shall install, calibrate, maintain, and operate a continuous opacity monitoring system (COMS) to measure and record the opacity from the boiler (EPN: 1-1).
 - A. The COMS shall meet the design and performance specification, pass the field tests, the installation requirements, data analysis, and reporting requirements specified in the applicable Performance Specification in 40 CFR Part 60, Appendix B.
 - B. All monitoring and quality-assurance data shall be maintained by the source for a period of five years and shall be made available to TCEQ Executive Director or designated representative upon request.
 - C. Opacity readings in excess of the limits in Special Condition No. 4 are reportable pursuant to 30 TAC § 101.201, Subchapter F, Division 1, Emission Event Reporting and Recordkeeping Requirements.
19. For all planned MSS activities listed on Attachments A and B and where the emissions are not measured with a CEMS the holder of this permit shall perform the following:
 - A. Annually confirm the continued validity of the estimated potential to emit represented in the permit application dated August 13, 2009 for all inherently low emitting (ILEs) planned maintenance activities listed on Attachment A. The validation shall consist of the estimated emissions for each activity and the basis for that emission estimate.
 - B. For each calendar month determine the emissions for each planned non-ILE maintenance activity in accordance with Special Condition No. 12.

Recordkeeping

20. The following records shall be kept at the plant for the life of the permit. All records required in this permit shall be made available at the request of personnel from the TCEQ, EPA, or any air pollution control agency with jurisdiction:
 - A. A copy of this permit.
 - B. Permit application dated August 13, 2009 and subsequent representations submitted to the TCEQ.
 - C. A complete copy of the testing reports and records of the initial performance testing.
 - D. Stack sampling results and other air emission testing that may be conducted on units authorized under this permit and subsequent modifications after the date of issuance of this permit.
21. The following information shall be maintained by the holder of this permit in a form suitable for inspection for a period of five years after collection and shall be made available upon request to representatives of the TCEQ, EPA, or any local air pollution control program having jurisdiction:
 - A. The CEMS and COMS data of NO_x, SO₂, CO, diluent gas (O₂ or CO₂) and opacity emissions from EPN 1-1. **(09/20)**
 - B. Raw data files of all CEMS and COMS data including calibration checks, adjustments, and maintenance performed on these systems in a permanent form suitable for inspection.
 - C. Startup/Shutdown records shall include the following:
 - (1) Type and quantity of fuel used.
 - (2) Emissions from the event.
 - (3) Date, time, and duration of the event.
 - D. Pursuant to Special Condition No. 19A, the annual confirmation shall be kept with examples of the method of data reduction including units, conversion factors, assumptions, and the basis of the assumptions in accordance with the original manner as represented in the application dated August 13, 2009.
 - E. Monthly maintenance records pursuant to Special Condition No. 19 B shall include the following:
 - (1) Type of activity.
 - (2) Emissions from the activity.
 - (3) Date, time, and duration of the activity.

22. The following operations are authorized through Permit by Rule (PBR) under 30 TAC Chapter 106 and are listed here for reference purposes only:

EPN	Source	Authorization
1-3	Emergency Generator	30 TAC § 106.511

Date: September 30, 2020

ATTACHMENT A

Permit Number 6029 and PSDTX50M2

Inherently Low Emitters					
Activities	Emissions				
	NO _x	CO	VOC	PM	SO ₂ /H ₂ S
Miscellaneous PM filter maintenance ¹				X	
Boiler general maintenance ²				X	
Management of sludge from pits, ponds, sumps, and water conveyances ³			X		
Organic chemical usage - Aerosol Cans			X		
Inspection, repair, replacement, adjusting, testing, and calibration of analytical equipment, process instruments including sight glasses, meters, gauges, CEMS, PEMS	X	X	X	X	X
Deslagging the boiler ⁴	X	X	X	X	
Above ground diesel tanks			X		

Dated March 23, 2011

¹ Includes but is not limited to the following: baghouse filters, ash silo/transfer filters, coal handling filters, and process-related building filters.

² Includes: pre-heater basket handling/maintenance, refractory change-out, fan maintenance/balancing, damper/air heater/soot blower maintenance, and any other general boiler maintenance that does not exceed the worst-case emissions representations in the application.

³ Includes (but it not limited to) the following: management by vacuum truck/dewatering of material in open pits/ponds/sumps/tanks and other closed or open vessels. Material managed included water and sludge materials containing miscellaneous VOCs such as diesel, lube oil, and other waste oils.

⁴ Includes but is not limited to the following: explosive blasting, clinker shooting, and other boiler deslagging activities. This does not include dry abrasive blasting that may occur outside the boiler.

ATTACHMENT B

Permit Numbers 6029 and PSDTX50M2

non - ILE Maintenance Activities						
Activity	EPN	Emissions				
		NO _x	CO	VOC	PM	SO ₂ /H ₂ S
Gaseous fuel venting ⁵	GAS-VNT-1			X		
Combustion unit tuning ⁶	1-1	X	X	X	X	X

Dated March 23, 2011

⁵ Includes (but is not limited to): venting prior to pipeline pigging, and meter proving.

⁶ Includes (but is not limited to): leak and operability checks (e.g. turbine overspeed tests, troubleshooting), seasonal tuning, and balancing.

Emission Sources - Maximum Allowable Emission Rates

Permit Numbers 6029 and PSDTX50M2

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
1-1 (7)	Boiler Generator No.1 5750 MMBtu/hr	NO _x	2,012	5,492
		CO (6)	1,955	8,296
		CO (MSS)	4,025	-
		VOC (6)	182	647
		PM ₁₀	509	1,793
		SO ₂	6,108	21,520
GAS-VNT-1 (5)	Gas Source Venting	VOC	31	0.42

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
 NO_x - total oxides of nitrogen
 SO₂ - sulfur dioxide
 PM₁₀ - total particulate matter equal to or less than 10 microns in diameter
 CO - carbon monoxide
 MSS - maintenance, startup, shutdown
- (4) Compliance with annual emission limits (tons per year) is based on a 12-month rolling period.
- (5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.
- (6) The CO and VOC emission rates are calculated based on Environmental Protection Agency, AP-42, Compilation of Air Pollution Factors, Volume 1, Chapter 1.
- (7) NO_x, VOC, PM₁₀, and SO₂ MSS emissions are included in the lbs/hr. The annual emission rates include the MSS annual emissions.

Date: January 11, 2012

Jon Niermann, *Chairman*
Emily Lindley, *Commissioner*
Bobby Janecka, *Commissioner*
Toby Baker, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

February 4, 2022

MR DAVID LOW
GENERAL MANAGER POWER GENERATION
SOUTHWESTERN PUBLIC SERVICE COMPANY
790 S BUCHANAN ST
AMARILLO TX 79101-2510

Re: Permit Renewal
Permit Number: 6030
Expiration Date: February 4, 2032
Southwestern Public Service Company
Tolk Station Power Plant
Earth, Lamb County
Regulated Entity Number: RN100224534
Customer Reference Number: CN601481336
Associated Permit Number: PSDTX50M2

Dear Mr. Low:

Southwestern Public Service Company has requested to renew Permit Number 6030. This letter serves as notice that your application for the above-referenced permit is technically complete as of December 2, 2021.


In accordance with Title 30 Texas Administrative Code Section 116.314(a), Permit Number 6030 is hereby renewed. Since you certified there were no changes to your existing permit, it is renewed as written and will be in effect for ten years from the date this renewal was issued. In addition, with this permitting action, Permit by Rule (PBR) Registration Numbers 91292, 99204 and 100565, and Standard Permit (SP) Registration Number 113913 have been referenced. This information will be incorporated into the existing permit file. Please attach this letter, including the attachment regarding referenced authorizations, and new general conditions to your permit.

Mr. David Low
Page 2
February 4, 2022

Re: Permit Number: 6030

If you need further information or have any questions, please contact Ms. Miranda Duncan at (512) 239-3402 or write to the Texas Commission on Environmental Quality, Office of Air, Air Permits Division, MC-163, P.O. Box 13087, Austin, Texas 78711-3087.

Sincerely,

A handwritten signature in black ink, appearing to read 'Samuel Short', followed by a long horizontal line extending to the right.

Samuel Short, Deputy Director
Air Permits Division
Office of Air
Texas Commission on Environmental Quality

Enclosure

cc: Air Section Manager, Region 2 - Lubbock
Air Permits Section Chief, New Source Review Section (6PD-R), U.S. Environmental Protection
Agency, Region 6, Dallas

Project Number: 333876

Permit No. 6030 – Authorizations Referenced on February 4, 2022

This list includes authorizations referenced with the renewal of this permit. It is not intended to be all-inclusive and can be altered at the site without modification to the permit.

Facility/Change	Authorization	Registration Number
Vacuum Bulb Compactor	PBR	91292
Lime Silo, Soda Ash Silo and Magnesium Oxide Silo Reactors	PBR	99204
Anhydrous ammonia storage tank and fugitives	PBR	100565
Activated Carbon Injection systems	SP	113913

Texas Commission on Environmental Quality Air Quality Permit

A Permit Is Hereby Issued To
Southwestern Public Service Company
Authorizing the Continued Operation of
Tolk Station Power Plant
Located at Earth, Lamb County, Texas
Latitude 34° 10' 57" Longitude -102° 34' 1"

Permit: 6030

Issuance Date: February 4, 2022

Expiration Date: February 4, 2032



For the Commission

1. **Facilities** covered by this permit shall be constructed and operated as specified in the application for the permit. All representations regarding construction plans and operation procedures contained in the permit application shall be conditions upon which the permit is issued. Variations from these representations shall be unlawful unless the permit holder first makes application to the Texas Commission on Environmental Quality (commission) Executive Director to amend this permit in that regard and such amendment is approved. [Title 30 Texas Administrative Code (TAC) Section 116.116 (30 TAC § 116.116)] ¹
2. **Voiding of Permit.** A permit or permit amendment is automatically void if the holder fails to begin construction within 18 months of the date of issuance, discontinues construction for more than 18 months prior to completion, or fails to complete construction within a reasonable time. Upon request, the executive director may grant an 18-month extension. Before the extension is granted the permit may be subject to revision based on best available control technology, lowest achievable emission rate, and netting or offsets as applicable. One additional extension of up to 18 months may be granted if the permit holder demonstrates that emissions from the facility will comply with all rules and regulations of the commission, the intent of the Texas Clean Air Act (TCAA), including protection of the public's health and physical property; and (b)(1) the permit holder is a party to litigation not of the permit holder's initiation regarding the issuance of the permit; or (b)(2) the permit holder has spent, or committed to spend, at least 10 percent of the estimated total cost of the project up to a maximum of \$5 million. A permit holder granted an extension under subsection (b)(1) of this section may receive one subsequent extension if the permit holder meets the conditions of subsection (b)(2) of this section. [30 TAC § 116.120]
3. **Construction Progress.** Start of construction, construction interruptions exceeding 45 days, and completion of construction shall be reported to the appropriate regional office of the commission not later than 15 working days after occurrence of the event. [30 TAC § 116.115(b)(2)(A)]
4. **Start-up Notification.** The appropriate air program regional office shall be notified prior to the commencement of operations of the facilities authorized by the permit in such a manner that a representative of the commission may be present. The permit holder shall provide a separate notification for the commencement of operations for each unit of phased construction, which may involve a series of units commencing operations at different times. Prior to operation of the facilities authorized by the permit, the permit holder shall identify the source or sources of allowances to be utilized for compliance with Chapter 101, Subchapter H, Division 3 of this title (relating to Mass Emissions Cap and Trade Program). [30 TAC § 116.115(b)(2)(B)]
5. **Sampling Requirements.** If sampling is required, the permit holder shall contact the commission's Office of Compliance and Enforcement prior to sampling to obtain the proper data forms and procedures. All sampling and testing procedures must be approved by the executive director and coordinated with the regional representatives of the commission. The permit holder is also responsible for providing sampling facilities and conducting the sampling operations or contracting with an independent sampling consultant. [30 TAC § 116.115(b)(2)(C)]
6. **Equivalency of Methods.** The permit holder must demonstrate or otherwise justify the equivalency of emission control methods, sampling or other emission testing methods, and monitoring methods proposed as alternatives to methods indicated in the conditions of the permit. Alternative methods shall be applied for in writing and must be reviewed and approved by the executive director prior to their use in fulfilling any requirements of the permit. [30 TAC § 116.115(b)(2)(D)]
7. **Recordkeeping.** The permit holder shall maintain a copy of the permit along with records containing the information and data sufficient to demonstrate compliance with the permit, including production records and operating hours;

keep all required records in a file at the plant site. If, however, the facility normally operates unattended, records shall be maintained at the nearest staffed location within Texas specified in the application; make the records available at the request of personnel from the commission or any air pollution control program having jurisdiction in a timely manner; comply with any additional recordkeeping requirements specified in special conditions in the permit; and retain information in the file for at least two years following the date that the information or data is obtained. [30 TAC § 116.115(b)(2)(E)]

8. **Maximum Allowable Emission Rates.** The total emissions of air contaminants from any of the sources of emissions must not exceed the values stated on the table attached to the permit entitled "Emission Sources--Maximum Allowable Emission Rates." [30 TAC § 116.115(b)(2)(F)]¹
9. **Maintenance of Emission Control.** The permitted facilities shall not be operated unless all air pollution emission capture and abatement equipment is maintained in good working order and operating properly during normal facility operations. The permit holder shall provide notification in accordance with 30 TAC §101.201, 101.211, and 101.221 of this title (relating to Emissions Event Reporting and Recordkeeping Requirements; Scheduled Maintenance, Startup, and Shutdown Reporting and Recordkeeping Requirements; and Operational Requirements). [30 TAC § 116.115(b)(2)(G)]
10. **Compliance with Rules.** Acceptance of a permit by an applicant constitutes an acknowledgment and agreement that the permit holder will comply with all rules and orders of the commission issued in conformity with the TCAA and the conditions precedent to the granting of the permit. If more than one state or federal rule or regulation or permit condition is applicable, the most stringent limit or condition shall govern and be the standard by which compliance shall be demonstrated. Acceptance includes consent to the entrance of commission employees and agents into the permitted premises at reasonable times to investigate conditions relating to the emission or concentration of air contaminants, including compliance with the permit. [30 TAC § 116.115(b)(2)(H)]
11. **This** permit may not be transferred, assigned, or conveyed by the holder except as provided by rule. [30 TAC § 116.110(e)]
12. **There** may be additional special conditions attached to a permit upon issuance or modification of the permit. Such conditions in a permit may be more restrictive than the requirements of Title 30 of the Texas Administrative Code. [30 TAC § 116.115(c)]
13. **Emissions** from this facility must not cause or contribute to "air pollution" as defined in Texas Health and Safety Code (THSC) §382.003(3) or violate THSC § 382.085. If the executive director determines that such a condition or violation occurs, the holder shall implement additional abatement measures as necessary to control or prevent the condition or violation.
14. **The** permit holder shall comply with all the requirements of this permit. Emissions that exceed the limits of this permit are not authorized and are violations of this permit.¹

¹ Please be advised that the requirements of this provision of the general conditions may not be applicable to greenhouse gas emissions.

Common Acronyms in Air Permits

°C = Temperature in degrees Celsius	GLCmax = maximum (predicted) ground-level concentration
°F = Temperature in degrees Fahrenheit	gpm = gallon per minute
°K = Temperature in degrees Kelvin	gr/1000scf = grain per 1000 standard cubic feet
µg = microgram	gr/dscf = grain per dry standard cubic feet
µg/m ³ = microgram per cubic meter	H ₂ CO = formaldehyde
acfm = actual cubic feet per minute	H ₂ S = hydrogen sulfide
AMOC = alternate means of control	H ₂ SO ₄ = sulfuric acid
AOS = alternative operating scenario	HAP = hazardous air pollutant as listed in § 112(b) of the Federal Clean Air Act or Title 40 Code of Federal Regulations Part 63, Subpart C
AP-42 = Air Pollutant Emission Factors, 5th edition	HC = hydrocarbons
APD = Air Permits Division	HCl = hydrochloric acid, hydrogen chloride
API = American Petroleum Institute	Hg = mercury
APWL = air pollutant watch list	HGB = Houston/Galveston/Brazoria
BPA = Beaumont/ Port Arthur	hp = horsepower
BACT = best available control technology	hr = hour
BAE = baseline actual emissions	IFR = internal floating roof tank
bbl = barrel	in H ₂ O = inches of water
bbl/day = barrel per day	in Hg = inches of mercury
bhp = brake horsepower	IR = infrared
BMP = best management practices	ISC3 = Industrial Source Complex, a dispersion model
Btu = British thermal unit	ISCST3 = Industrial Source Complex Short-Term, a dispersion model
Btu/scf = British thermal unit per standard cubic foot or feet	K = Kelvin; extension of the degree Celsius scaled-down to absolute zero
CAA = Clean Air Act	LACT = lease automatic custody transfer
CAM = compliance-assurance monitoring	LAER = lowest achievable emission rate
CEMS = continuous emissions monitoring systems	lb = pound
cfm = cubic feet (per) minute	hp = horsepower
CFR = Code of Federal Regulations	hr = hour lb/day = pound per day
CN = customer ID number	lb/hr = pound per hour
CNG = compressed natural gas	lb/MMBtu = pound per million British thermal units
CO = carbon monoxide	LDAR = Leak Detection and Repair (Requirements)
COMS = continuous opacity monitoring system	LNG = liquefied natural gas
CPMS = continuous parametric monitoring system	LPG = liquefied petroleum gas
DFW = Dallas/ Fort Worth (Metroplex)	LT/D = long ton per day
DE = destruction efficiency	m = meter
DRE = destruction and removal efficiency	m ³ = cubic meter
dscf = dry standard cubic foot or feet	m/sec = meters per second
dscfm = dry standard cubic foot or feet per minute	MACT = maximum achievable control technology
ED = (TCEQ) Executive Director	MAERT = Maximum Allowable Emission Rate Table
EF = emissions factor	MERA = Modeling and Effects Review Applicability
EFR = external floating roof tank	mg = milligram
EGU = electric generating unit	mg/g = milligram per gram
EI = Emissions Inventory	mL = milliliter
ELP = El Paso	MMBtu = million British thermal units
EPA = (United States) Environmental Protection Agency	MMBtu/hr = million British thermal units per hour
EPN = emission point number	MSDS = material safety data sheet
ESL = effects screening level	MSS = maintenance, startup, and shutdown
ESP = electrostatic precipitator	MW = megawatt
FCAA = Federal Clean Air Act	NAAQS = National Ambient Air Quality Standards
FCCU = fluid catalytic cracking unit	NESHAP = National Emission Standards for Hazardous Air Pollutants
FID = flame ionization detector	NGL = natural gas liquids
FIN = facility identification number	NNSR = nonattainment new source review
ft = foot or feet	NO _x = total oxides of nitrogen
ft/sec = foot or feet per second	
g = gram	
gal/wk = gallon per week	
gal/yr = gallon per year	
GLC = ground level concentration	

NSPS = New Source Performance Standards
 PAL = plant-wide applicability limit
 PBR = Permit(s) by Rule
 PCP = pollution control project
 PEMS = predictive emission monitoring system
 PID = photo ionization detector
 PM = periodic monitoring
 PM = total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented
 PM_{2.5} = particulate matter equal to or less than 2.5 microns in diameter
 PM₁₀ = total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented
 POC = products of combustion
 ppb = parts per billion
 ppm = parts per million
 ppmv = parts per million (by) volume
 psia = pounds (per) square inch, absolute
 psig = pounds (per) square inch, gage
 PTE = potential to emit
 RA = relative accuracy
 RATA = relative accuracy test audit
 RM = reference method
 RVP = Reid vapor pressure
 scf = standard cubic foot or feet
 scfm = standard cubic foot or feet (per) minute
 SCR = selective catalytic reduction
 SIL = significant impact levels
 SNCR = selective non-catalytic reduction
 SO₂ = sulfur dioxide
 SOCMF = synthetic organic chemical manufacturing industry
 SRU = sulfur recovery unit
 TAC = Texas Administrative Code
 TCAA = Texas Clean Air Act
 TCEQ = Texas Commission on Environmental Quality
 TD = Toxicology Division
 TLV = threshold limit value
 TMDL = total maximum daily load
 tpd = tons per day
 tpy = tons per year
 TVP = true vapor pressure
 VOC = volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
 VRU = vapor recovery unit or system

Special Conditions

Permit Numbers 6030 and PSDTX50M2

1. This facility shall comply with the following applicable requirements of the U. S. Environmental Protection Agency Regulations on Standards of Performance for New Stationary Sources, Title 40 Code of Federal Regulations, Part 60 (40 CFR Part 60):
 - A. Subpart A, General Conditions; and
 - B. Subpart D, Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction Is Commenced After August 17, 1971.
 - C. If any condition of this permit is more stringent than the regulations so incorporated, then for the purposes of complying with this permit, the permit shall govern and be the standard by which compliance shall be demonstrated.
2. This permit authorizes those sources of emissions listed in the attached table entitled "Emission Sources - Maximum Allowable Emission Rates", (MAERT) and those sources are limited to the emission limits and other conditions specified in that attached table. Also, this permit authorizes the emissions from the planned maintenance, startup, and shutdown (MSS) activities listed in Attachment A, Attachment B, and the MAERT attached to this permit. Attachment A identifies the inherently low emitting (ILE) planned maintenance activities that this permit authorizes to be performed. Attachment B identifies the planned maintenance activities that are non-ILE planned maintenance activities that this permit authorizes to be performed. Furthermore, Permit-by-Rule Registration No. 100565 is incorporated into this permit by reference. **(2/12)**
3. Steam Generator Unit No. 2 shall measure and record opacity with a continuous opacity monitoring system that shall be located, installed, and operated in accordance with 40 CFR Part 60. Opacity of emissions from the boiler stack shall not exceed 20 percent averaged over a six-minute period, except as described in Title 30 Texas Administrative Code ' 111.111(a)(1)(E). If the opacity exceeds the standard, corrective action to eliminate the source of visible emissions shall be taken promptly. **(2/12)**
4. Plant roads shall be paved and cleaned, oiled, or sprinkled with water and/or chemicals as necessary to control the emissions of dust to the minimum level possible under existing conditions.

Demonstration of Compliance

5. The permit holder shall install, calibrate, and maintain a continuous emission monitoring system (CEMS) to measure and record the in-stack concentration of CO from the boiler stack (EPN 1-1). **(09/20)**

- A. The CEMS shall meet the design and performance specifications, pass the field tests, and meet the installation requirements and the data analysis and reporting requirements specified in the applicable Performance Specification Nos. 4 through 4B, 40 CFR Part 60, Appendix B.
- B. The permit holder shall assure that the CEMS meets the applicable quality-assurance requirements specified in 40 CFR Part 60, Appendix F, Procedure 1. Relative accuracy exceedances, as specified in 40 CFR Part 60, Appendix F, 5.2.3 and any CEMS downtime shall be reported to the appropriate TCEQ Regional Manager, and necessary corrective action shall be taken. Supplemental stack concentration measurements may be required at the discretion of the appropriate TCEQ Regional Manager.

Each monitor shall be quality-assured at least quarterly using Cylinder Gas Audits (CGA) in accordance with 40 CFR Part 60, Appendix F, Procedure 1, Section 5.1.2, with the following exception: a relative accuracy test audit (RATA) is not required once every four quarters (i.e., four successive quarterly CGA may be conducted). As an alternative to CGA, quarterly linearities may be run according to the requirements of 40 CFR §75, Appendix B.

All CGA or linearity exceedances of ± 15 percent accuracy indicate the CEMS is out of control and necessary corrective action shall be taken to eliminate the problem.

- C. The monitoring data shall be reduced to hourly average concentrations at least once every day, using a minimum of four equally-spaced data points from each one-hour period. The individual average concentrations shall be reduced to units of lbs/hr at least once every day.
 - D. The monitoring data and quality-assurance data shall be maintained by the source. The data from the CEMS may, at the discretion of the TCEQ, be used to determine compliance with the conditions of this permit.
 - E. The appropriate TCEQ Regional Office shall be notified at least 30 days prior to any RATA in order to provide them the opportunity to observe the testing.
 - F. This requirement shall become effective within 180 days of issuance of the permit with this condition.
6. SPC shall perform periodic stack sampling for VOC emissions from EPN 1- 1 shall be used to demonstrate continuous compliance with the lb/hr emission limits on the MAERT and shall meet the following specifications: **(09/20)**
- A. Stack sampling shall be performed once every four QA operating quarters (as defined in 40 CFR §72.2) during periods of normal operation, except that if, after two successive stack sampling events, the average of the two stack sampling results for VOC is less than 70 percent of the lb/hr emission limit found in the MAERT, then compliance stack sampling shall be conducted once every twelve QA operating quarters, subject to continued results below 70 percent of the lb/hr emission limit.

- B. Ongoing compliance with the VOC tons per year emission rates in the MAERT shall be demonstrated by calculating rolling 12-month annual emissions from an emission factor (lb/MMBtu) obtained from the sampling required by this special condition and the monthly total heat input from fuel combustion.
- C. Ongoing compliance with the VOC pounds per hour emission rates in the MAERT shall be demonstrated hourly emissions from an emission factor (lb/MMBtu) obtained from the sampling required by this special condition and the hourly heat input measured by the 40 CFR Part 75 CEMS system.
- D. The first test shall occur within 12 calendar months of issuance of the permit with this condition.

Maintenance, Startup, and Shutdown

- 7. When a planned maintenance activity identified in Attachment B is associated with a volatile organic compounds (VOC) liquid storage facility and may result in VOC emissions from that facility, the permit holder shall not open that facility to the atmosphere in connection with the planned maintenance activity until the VOC liquids are removed from that facility to the maximum extent practicable. **(2/12)**
- 8. The emissions from planned MSS activities are reflected in the MAERT. The emissions shall be minimized by operating the facility and associated air pollution control equipment in a manner consistent with good air pollution control practices, safe operating practices, and protection of the facility. **(2/12)**
- 9. Emissions during planned startup and shutdown activities will be minimized by limiting the duration of operation in planned startup and shutdown mode as follows: **(2/12)**
 - A. A planned startup of the electric generating facility (EGF), which has Emission Point Number (EPN): 2-1, is defined as the period that begins when a forced draft fan is turned on and ends when 200 megawatts (MW) of electrical output is achieved.
 - (1) A planned startup of that EGF shall not exceed 48 hours after main fuel burning has commenced, except as allowed in Special Condition No. 9A(2).
 - (2) An extended planned startup is defined as a startup that lasts more than 48 hours after main fuel burning has commenced. The total amount of time of all extended startups combined shall not exceed a total of 600 hours per year.
 - B. A planned shutdown of the EGF with EPN: 2-1 is defined as the period that begins when fuel is reduced below the amount necessary to maintain 20 MW and ends when the boiler is no longer receiving fuel. A planned shutdown of the EGF shall not exceed 120 minutes. **(3/12)**
- 10. Compliance with the emissions limits for planned MSS activities identified in the MAERT attached to this permit may be demonstrated as follows. **(2/12)**
 - A. For each pollutant emitted during ILE planned maintenance activities, the permit holder shall annually confirm the continued validity of the estimated potential to emit represented in the permit application for all ILE planned maintenance activities. The total emissions from all ILE

planned maintenance activities (See Attachment A) shall be considered to be no more than the estimated potential to emit for those activities that are represented in the permit application.

- B. For each pollutant emitted during non-ILE planned maintenance activities (See Attachment B) whose emissions are measured using a Continuous Emission monitoring System (CEMS), as per Special Condition No. 11A, the permit holder shall do the following for each calendar month.
 - (1) Compare the pollutant's short-term (hourly) emissions during planned maintenance activities as measured by the CEMS to the applicable short-term planned MSS emissions limit in the MAERT.
 - (2) Once the pollutant's emissions during planned maintenance activities have been measured by the CEMS for 12 months after the MSS permit amendment has been issued, compare the rolling 12-month emissions of the pollutant, as determined using the CEMS data, to the applicable annual planned MSS emissions limit in the MAERT.
 - C. For each pollutant emitted during non-ILE planned maintenance activities (See Attachment B) whose emissions occur through a stack, but are not measured using CEMS as per Special Condition No. 11A, the permit holder shall do the following for each calendar month.
 - (1) Determine the total emissions of the pollutant through the stack that result from such non-ILE planned maintenance activities in accordance with Special Condition No. 11B.
 - (2) Once monthly emissions have been determined in accordance with Special Condition No. 10C(1) for 12 months after the MSS permit amendment has been issued, the permit holder shall compare the rolling 12-month emissions for the pollutant to the applicable annual planned MSS emissions limit in the MAERT.
 - D. For each pollutant emitted during non-ILE planned maintenance activities (See Attachment B) whose emissions do not occur through a stack, the permit holder shall do the following for each calendar month.
 - (1) Determine the total emissions of the pollutant from such non-ILE planned maintenance activities in accordance with Special Condition No. 11B.
 - (2) Once monthly emissions have been determined in accordance with Special Condition No. 10D(1) for 12 months after the MSS permit amendment has been issued, the permit holder shall compare the sum of the rolling 12-month emissions for the pollutant for all non-ILE planned maintenance activities to the annual emissions limit for the pollutant in the MAERT.
11. The permit holder shall determine the emissions during planned MSS activities for use in Special Condition No. 10 as follows. **(2/12)**
- A. For each pollutant whose emissions during normal facility operations are measured with a CEMS that has been certified to measure the pollutant's emissions over the entire range of a

planned MSS activity, the permit holder shall measure the emissions of the pollutant during the planned MSS activity using the CEMS.

- B. For each pollutant not described in Special Condition No. 11A, the permit holder shall calculate the pollutant's emissions during all occurrences of each type of planned MSS activity for each calendar month using the frequency of the planned MSS activity identified in work orders or equivalent records and the emissions of the pollutant during the planned MSS activity as represented in the planned MSS permit application. In lieu of using the emissions of the pollutant during the planned MSS activity as represented in the planned MSS permit application to calculate such emissions, the permit holder may determine the emissions of the pollutant during the planned MSS activity using an appropriate method, including but not limited to, any of the methods described in paragraphs 1 through 3 below, provided that the permit holder maintains appropriate records supporting such determination:
- (1) Use of emission factor(s), facility-specific parameter(s), and/or engineering knowledge of the facility's operations.
 - (2) Use of emissions data measured (by a CEMS or during emissions testing) during the same type of planned MSS activity occurring at or on a similar facility, and correlation of that data with the facility's relevant operating parameters, including, but not limited to, electric load, temperature, fuel input, and fuel sulfur content.
 - (3) Use of emissions testing data collected during a planned MSS activity occurring at or on the facility, and correlation of that data with the facility's relevant operating parameters, including, but not limited to, electric load, temperature, fuel input, and fuel sulfur content.
12. With the exception of the emission limits in the MAERT attached to this permit, the permit conditions relating to planned MSS activities do not become effective until 180 days after issuance of the permit amendment that added such conditions. **(2/12)**

Coordination of the Prevention of Significant Deterioration (PSD) Permit No. PSDTX50M2 between Permit Nos. 6029 and 6030

13. When Permit No. 6029 is amended such that PSD permit is modified, the holder of this permit shall apply for a permit alteration to this permit to change the designation of the PSD permit so that it is the same in both Permit Nos. 6029 and 6030. **(2/12)**

Date: September 30, 2020

Attachment A
Permit No. 6030 and PSDTX50M2
Inherently Low Emitting (ILE) Planned Maintenance Activities

Activities	NO _x	CO	VOC	PM	SO ₂
Miscellaneous PM filter maintenance ¹				X	
Degassing for maintenance of storage vessels storing material with vapor pressure ≤0.5 psia			X		
Degassing for maintenance of storage vessels storing gasoline or other material with vapor pressure >0.5 psia that does not require clearing of the vessels to allow for entry of personnel ²			X		
Boiler general maintenance ³			X	X	
Management of liquids or sediments from pits, ponds, sumps, and water conveyances ^{4,6}			X		
Small equipment and fugitive component repair/replacement in VOC service ⁵			X		
Inspection, repair, replacement, adjusting, testing, and calibration of analytical equipment, process instruments including sight glasses, meters, gauges (including CEMS) ⁶	X		X		X

Dated February 29, 2012

Notes for Attachment A

1. Includes but is not limited to the following: baghouse filters, coal handling filters, and combustion turbine air intake filters.
2. Includes but is not limited to the following: emptying, degassing, and cleaning. All above ground tanks except turbine oil tanks are leased and removed offsite for maintenance.
3. Included in EPN 2-1. Includes: pre-heater basket handling/maintenance, refractory change-out, fan maintenance/balancing, damper/air heater/soot blower maintenance, and any other general boiler maintenance that does not exceed the worst-case emissions representations in the application.
4. Includes, but is not limited to management by vacuum truck of materials in open pits, sumps, tanks and other closed or open vessels, and water based washing. Materials removed by vacuum truck include, but are not limited to, water and sediment mixtures containing miscellaneous VOC's such as diesel, lube oil, and other waste oils.
5. Includes, (i) repair/replacement of pumps, compressors, valves, pipes, flanges, transport lines, filters and screens in natural gas, fuel oil, diesel oil, ammonia, lube oil, and gasoline service, and (ii) vehicle and mobile equipment maintenance that may involve small VOC emissions, such as oil changes, transmission and hydraulic system service.
6. Covers activities in the Boiler 2 Area and Fly Ash Handling Area.

Attachment B
Permit No. 6030 and PSDTX50M2
Non-ILE Planned Maintenance Activities

Activities		NO _x	CO	VOC	PM	SO ₂
Gaseous fuel venting (maintenance) ¹	MSS-FUG2			X		
Combustion unit optimization ²	2-1	X	X	X	X	X
PM control device maintenance – unit online	2-1				X	
PM control device maintenance – unit offline ³	2-1				X	

Dated February 29, 2012

Notes for Attachment B

1. Includes, but is not limited to: venting prior to pipeline pigging, and meter proving.
2. Includes, but is not limited to: leak and operability checks (e.g. turbine overspeed tests or troubleshooting), balancing, and tuning activities that occur during seasonal tuning or after the completion of initial construction, a combustor change-out, a major repair, maintenance to a combustor, or other similar circumstances.
3. Includes operation of baghouse ventilation duct fans

Emission Sources - Maximum Allowable Emission Rates

Permit Numbers 6030 and PSDTX50M2

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
2-1	Boiler Generator No. 2 5750 MMBtu/hr (5) (6)	NO _x	2,013.00	6,296.00
		CO	2,013.00	6,296.00
		SO ₂	6,108.30	26,754.00
		VOC	90.60	397.00
		PM	508.80	2,228.50
MSS-FUG2	MSS Fugitives, Unit 2	VOC	75.00	0.85
		PM	1.41	0.01
		PM ₁₀	0.67	0.01
		PM _{2.5}	0.10	0.01
		NO _x	0.01	0.01
		SO ₂	0.01	0.01

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
- NO_x - total oxides of nitrogen
- SO₂ - sulfur dioxide
- PM - total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented
- PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented
- PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter
- CO - carbon monoxide
- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.

Emission Sources - Maximum Allowable Emission Rates

- (5) PSDTX50M2 also authorizes emissions from Boiler Generator No. 1 (EPN 1-1) in Permit No. 6029. **(2/12)**
- (6) The pound per hour and ton per year emission limit specified in the MAERT for this facility includes emissions from the facility during both normal operations and planned MSS activities. **(2/12)**

Date: February 29, 2012